

# **NOTICE**

**CERTAIN DATA  
CONTAINED IN THIS  
DOCUMENT MAY BE  
DIFFICULT TO READ  
IN MICROFICHE  
PRODUCTS.**

RECORD

- 1. R. H. Beaton
- 2. R. B. Richards
- 3. A. R. Maguire
- 4. V. R. Cooper
- 5. F. W. Woodfield
- 6. G. C. Oberg
- 7. E. F. Carran

- 8. R. F. Smith
- 9. J. T. Stringer
- 10. M. K. Harman
- 11. J. G. Bradley
- 12. F. Doud
- 13. W. S. Figg
- 14. E. T. Merrill

→ 15-18. (Extra)

COPY 1 OF

Classification Cancelled And Changed To

**DECLASSIFIED**

By Authority of CA Bowman

2-13-92 CG-PB-2

by AD Bush 2-24-92

Verified By JL BURSTON, 2-24-92

This document contains  
 information that is  
 exempt from automatic  
 downgrading and  
 declassification  
 because it is  
 essential to the  
 national defense  
 and the national  
 security.

**SECRET**

June 20 1950

TO: F. W. Woodfield  
 FROM: E. T. Merrill & W. S. Figg

EXHIBITS USED IN CHEMICAL DEVELOPMENT SECTION  
SEMINAR ON DECONTAMINATION

Attached for your reference are copies of exhibits presented  
 at the Chemical Development Section Seminar on June 2, 1950.


RECEIVED

JUN 1 1950


300 AREA  
CLASSIFIED FILES

**DECLASSIFIED**


MASTER



**DECLASSIFIED**



DECLASSIFIED



DECLASSIFIED


Derivation of "F" Factor

$$U = \sqrt{\frac{4gD(\rho_0 - \rho)}{3\rho C}}$$

$$U = \sqrt{\frac{4gD(\rho_0 - \rho)}{3C}} \sqrt{\frac{1}{\rho}} = \frac{F}{\rho^{1/2}}$$

$$F = U\rho^{1/2}$$


DECLASSIFIED



References:


1. Holbrook and Baker, Trans. Am. Inst. Chem. Engrs. 32, 520 (1934)
2. Strang, Trans. Inst. Chem. Engrs. (London) 12, 169 (1934).

~~SECRET~~ DECLASSIFIED




DECLASSIFIED


Flow Diagrams of Brookhaven Nat. Lab. and  
Chem. Dev. Sect. Deentrainment Study  
Equipment



DECLASSIFIED




DECLASSIFIED



DECLASSIFIED

### Effect of Packed Height on DF




Reference: Chi-Chuan Shen, Production of Purer Distilled Water, J. Chinese Pharm. Assoc., 2, 293-312 (1940).

DECLASSIFIED


# Figure 1 REDOX LIQUID WASTE SYSTEM

Basis: 24 hr.



DECLASSIFIED


**Figure 2**  
**REDOX GASEOUS WASTE SYSTEM**  
Basis: 24 hr., 5000 lb. U,  $9 \times 10^6$  Curies, 1000g. Pu



DECLASSIFIED

Figure 3  
WASTE METAL RECOVERY PLANT  
LIQUID WASTE SYSTEM

Basis: 24 Hr., 5 Tons U. S.  $10^6$   $\beta$  Curies



**DECLASSIFIED**

TABLE I

EXISTING LIQUID TOLERANCES

<u>Activity</u>	<u>Cribbing Tolerance</u>	<u>IAF Required</u>	<u>Drinking Tolerance</u>	<u>D.F. Required</u>	<u>Proposed Tolerance</u>
U			100 $\mu$ g/l.	$5 \times 10^5$	
Pu	5 $\mu$ g./l.	$10^4$	0.001 $\mu$ g/l	$2 \times 10^7$	0.000,04 $\mu$ g./l.
J	5 $\mu$ curies/l.	$2 \times 10^6$	0.1 curies/l.	$10^8$	
J	50 $\mu$ curies/l.	$10^5$			

Note: This D.F. is defined as the activity in the IAF (feed) processed per day divided by the activity in the cribbed waste per day.

DECLASSIFIED

TABLE II

PROPOSED LIQUID TOLERANCES - HM-1549t

<u>Activity</u>	<u>Pollution Tolerance</u>	<u>Cribbing Tolerance</u>	<u>D<sup>h</sup> Required</u>
U			10 <sup>5</sup>
Pu	0.000,04 $\mu$ g/l.	0.000,04 $\mu$ g/l.	5 x 10 <sup>8</sup>
Sr	0.000,02 $\mu$ curies/l.	0.000,02 curies/l.	5 x 10 <sup>9</sup>
Co	0.1 curies/l.	0.1 curies/l.	2.5 x 10 <sup>2</sup>
Ce	0.0001 curies/l.	1 $\mu$ curies/l.	1.5 x 10 <sup>3</sup>
Zr	"	10 <sup>1</sup> curies/l.	1
Ru <sup>106</sup>	"	0.2 $\mu$ curies/l.	5 x 10 <sup>6</sup>
Ru	0.0002 curies/l.	1 $\mu$ curies/l.	10 <sup>6</sup>
Others	0.0001 curies/l. each	---	

Note: These tolerances are 100 fold lower than those agreed upon at the Chalk River conference.

DECLASSIFIED

TABLE III

EXISTING GASEOUS TOLERANCES

Activity	Breathing Tolerance	Total D.F. (1) Required	Process D.F. (2) Required
U	0.05 $\mu$ g/l	$4 \times 10^6$	40
Pu	$2 \times 10^{-8}$ $\mu$ g/l	$5 \times 10^9$	$5 \times 10^4$
$\beta$	$10^{-7}$ $\mu$ curies/l	$3 \times 10^{11}$	$3 \times 10^6$

- Notes: 1. This D.F. is based on the activity of the feed per day divided by allowable activity in the off gas per day.
2. A dilution DF of  $10^5$  is assumed for the stack.

TABLE IV

INDEX DECONTAMINATION REQUIREMENTS

<u>Boiler</u>	<u># of Total Condensate</u>	<u>D.F. Required</u>	<u>O/D(1)</u>	<u>E. Allowed</u>
T-163 Cond. Stripper	93	4 $\times 10^2$	0.04	1 $\times 10^{-4}$
Q-164 Cond. Stripper	3	$10^3$	10	3 $\times 10^{-2}$
T-160 Waste Cond.	75	5 $\times 10^3$ <sup>(2)</sup> 2.5 $\times 10^3$	1.8	6 $\times 10^{-4}$ <sup>(2)</sup> 1 $\times 10^{-3}$
T-123, 129, 134 U Cond.	82	3.3 $\times 10^3$	1.6	3.4 $\times 10^{-3}$
Q-140 IRP Oxid.	1	50 2. $\times 10^5$	0.5	1 $\times 10^{-4}$
Q-150, 185 3BP Cond.	2.5	10 2 $\times 10^3$	0.18 2	0.12 6 $\times 10^{-3}$
Q-110 IAF Oxid.	6	5 $\times 10^3$ 2.5 $\times 10^3$	3	1 $\times 10^{-2}$ 2 $\times 10^{-3}$

NOTES: 1. O/D is the ratio of the flow rate of liquid subject to decontamination to the flow rate of the distillate.

2. The upper number corresponds to present existing limits and the lower to drinking water tolerances.

DECLASSIFIED

[REDACTED]

HW-17986 Ri

TABLE V  
REDOX DECENTRIMENT TOWER DIMENSIONS

<u>Tower</u>	<u>Diameter,</u> <u>°In.</u>	<u>Decentriment</u> <u>Section</u>	<u>Stripping</u> <u>Section</u>	<u>E Allowed</u>
Dissolver T-102	22	5 ft.	None <sup>(1)</sup>	$3 \times 10^{-7}$
Oxidizer T-110	24	6.4	None	$3 \times 10^{-7}$
ICU Conc. T-123	22	5	5 ft.	$3 \times 10^{-3}$
2EU Conc. T-129	22	5	5	$3 \times 10^{-3}$
3EU Conc. T-134	22	5	5	$3 \times 10^{-3}$
IRP Oxid. T-140	20	5	5	$5 \times 10^{-4}$
3BP Conc. T-143	6	None	4	$6 \times 10^{-5}$
Pu Conc. T-150	8	4	None	$6 \times 10^{-5}$
Waste Conc. T-160	42	3.5 <sup>(1)</sup>	6 trays	$1 \times 10^{-2}$
Cond. Str. T-164	20	4	6	$3 \times 10^{-2}$
Cond. Evap. T-165	54	6 trays	None	$1 \times 10^{-4}$

[REDACTED]

DECLASSIFIED




TABLE VI

THE PLANT DEENTRAINMENT REQUIREMENTS

<u>Tower</u>	<u>Feed Concentrator</u>	<u>Waste Concentrator</u>	<u>UNH Concentrator</u>
% of total condensate	18	30	52
D.F. Required	$3 \times 10^4$ $1.5 \times 10^6$ } (1)	$3 \times 10^4$ $1.5 \times 10^6$	? $2 \times 10^5$
O/D(2)	2	1.2	0.1
E Allowable	$8 \times 10^{-5}$ $1.7 \times 10^{-6}$ } (3)	$1 \times 10^{-4}$ $2 \times 10^{-6}$ } (4)	? $7 \times 10^{-7}$
Tower Cross-section	4.5 x 8.5 ft.		
Deentrainment Section	7 plates at 10"	49" Cyclone	Followed by coarse filter.

NOTES: 1. The upper value is based on existing cribbing limits while the lower corresponds to the drinking water tolerances.

2. O/D is ratio of the flow rate of the liquid subject to entrainment to the flow rate of the distillate.

3. These E's contribute 20% of the tolerance

4. These E's contribute 80% of the tolerance

DECLASSIFIED



**END**

---

**DATE  
FILMED**

**6/03/92**

