

ENGINEERS-CONSTRUCTORS

884 O/S 6546

*R. A. Boettcher*

TO: DAVE NARVER, JR. ✓  
FROM: R. A. BOETTCHER  
JOB: ELECTRICAL SERVICE FOR BLDG. #413  
RE:

1 AUGUST 1953

DATE:

- Ref.: 1. 3230-EE-6, Pwr, Dist., Area 10  
 2. 3285-EE-3, Elec Plan, Bldg. #413

The electrical service for Building #413 is being installed to pole F9 as shown on Reference 2.

Reference 1 shows the electrical service for Building #413 from pole F8 with a span of 3 # 8 between pole F8 and F9. This should be removed from the drawing.

Please add a detail to Reference 2 showing the installation of multi-breaker panel and main switch. If the service equipment is not dust- and water-tight it is suggested that the equipment be enclosed in a wood cabinet with a heater or a 100 watt lamp to lower the humidity.

*R. A. Boettcher*

RAB:JLM:jws

R. A. BOETTCHER  
RESIDENT ENGINEER

- cc: HO Chrono  
 HO Central  
 OS Chrono  
 OS Central  
 OS Engineering (Elec.)

*Copy 11/1/53*

REPOSITORY NATIONAL ARCHIVES  
PACIFIC SOUTHWEST REGION  
 COLLECTION RG 326 ATOMIC ENERGY COMMISSION  
 BOX No. 199624 (#608) A16334 326-6500170  
 FOLDER ELMER GENERAL  
JOB 884 PROJECT ENGINEERING FILE

BEST COPY AVAILABLE

7483  
7484