Reproduced from the holdings of the National Archives
Pacific Southwest Region

HOLMES & NARVER, Inc.
ENGINEERS-CONSTRUCTORS

405865

R

TO: DAVID L. NARVER, JR. JOB: 884 O/S 6477

FROM: R. A. BOETTCHER RE: SUBSTATION EE-411 - ELMER

DATE: 17 JULY 1953

References: 1. 3230-EE-6

2. 5203-EE-9

To avoid conflict with fresh and salt water lines shown on Reference 2, a new location has been selected in the field for the subject substation. The center of the substation is now located 17-1/2 feet from Pole F7D, normal to the pole line, and 3-1/2 feet toward Pole F7C.

Closer checking of drawings before they are issued is requested, to prevent recurrence of similar conflicts in future designs.

R. A. Boettcher.

R. A. BOETTCHER
RESIDENT ENGINEER

RAB:jws

cc: S. P. Howell
HO Chrono
HO Central
OS Chrono
OS Central
OS Engineering (Elec.)

REPOSITORY NATIONAL ARCHIVES PACIFIC SOUTHWEST REGION
COLLECTION RG 326 ATOMIC ENERGY COMMISSION
BOX No. 199624 (#608) A16334 326-65V0170
FOLDER ELMER GENERAL JOB 884 PROJECT ENGINEERING FILE

RECEIVED

7044