

1 of 1

**Cover Sheet for a Hanford
Historical Document
Released for Public Availability**

Released 1994

**Prepared for the U.S. Department of Energy
under Contract DE-AC06-76RLO 1830**

**Pacific Northwest Laboratory
Operated for the U.S. Department of Energy
by Battelle Memorial Institute**



DISCLAIMER

This is a historical document that is being released for public availability. This was made from the best available copy. Neither the United States Government nor any agency thereof, nor Battelle Memorial Institute, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DECLASSIFIED

DOCUMENT NO.

HW-2400 RD

SERIES AND COPY NO.

3

September 14, 1961

HANFORD TECHNICAL RECORD GENERAL ELECTRIC

HANFORD ATOMIC PRODUCTS OPERATION - RICHLAND, WASHINGTON

X

THIS DOCUMENT CONTAINS RESTRICTED DATA AS DEFINED IN THE ATOMIC ENERGY ACT OF 1954. ITS DISSEMINATION TO ANY PERSON IS PROHIBITED UNLESS AUTHORIZED BY THE ISSUING OFFICE.

TITLE

IRRADIATION ANALYSIS, PRODUCTION TEST IP-672; HAPO 268, IRRADIATION OF IMPACTED UO₂-PuO₂ FUEL ROD BUNDLES IN C REACTOR


OTHER OFFICIAL CLASSIFIED INFORMATION

THIS MATERIAL CONTAINS INFORMATION AFFECTING THE NATIONAL DEFENSE OF THE UNITED STATES WITHIN THE MEANING OF THE ESPIONAGE LAWS, TITLE 18, U. S. C., SECS. 793 AND 794, THE TRANSMISSION OR REVELATION OF WHICH IN ANY MANNER TO AN UNAUTHORIZED PERSON IS PROHIBITED BY LAW.

AUTHOR

J. H. COX

ISSUING OFFICE
CIRCULATING COPY
RECEIVED 100 D AREA
OCT 18 1961
RETURN TO



ROUTE TO:	PAYROLL NO.	LOCATION	FILES RECORDED DATE	SIGNATURE AND DATE
<i>P. G. Carlson</i>	<i>13286</i>	<i>1700-D</i>	<i>9-15-61</i>	<i>P. G. Carlson 9-1-65</i>

RECORD COPY

Infinite Retention _____ Disposal Date _____
Authority _____ Authority _____

DISSEMINATION OF THIS DOCUMENT IS UNLIMITED

[Redacted Classification]

(CLASSIFICATION)

DECLASSIFIED

IRRADIATION ANALYSIS
PRODUCTION TEST IP-572, HAP0 288
IRRADIATION OF IMPACTED UO₂-PuO₂ FUEL ROD BUNDLES IN C REACTOR

Loss of Flow

Loss of Inlet Hydraulic Connector:

The burnout characteristics of this test are quite similar to a C-IIN loading, with reduced power, in a C Area ribbed process tube. The pressure drop for the fuel bundle is ~280 psig compared to 320 psig for a C-IIN loading with the same flow rate; likewise, the cross-sectional area of a tube bundle is 0.00393 ft² compared to 0.00403 ft² for a C-IIN element. As a result, the reverse flows and average velocities are very similar.

The heat flux on the fuel bundle is a maximum of 260,000 BTU/hr-ft². A C-IIN loading with a peak heat flux the same has a tube power of ~490 KW.* From Figure IV-6 (see also Figure IV-3) HW-74094, Volume 1, the back pressure required to prevent fuel element burnout is <20 psig for a tube power of ~490 KW. The rear header pressure available for the fuel bundle tubes is ~57 psig. Likewise, from Figure IV-6, 57 psig rear header pressure will protect fuel cladding from burnout up to a tube power of ~1150 KW. As a result, complete severance of the inlet hydraulic connector should not result in melting of the fuel cladding in this test.

Inlet Plugging:

It appears that the probability of inlet plugging to a process tube is very low. If inlet plugging were to occur, it would result in melting of the fuel rod bundles and the process tube; fission products would be released to the reactor core and into the reactor atmosphere.

Water Shutoff Time:

Due to the short water shutoff interval available, as shown in Figure 1, it is imperative that water be kept on the fuel elements at all times. Special care should be taken during discharge and shipment. During discharge, the front cap should remain on until time to push the tube; as much flow as practical should be left on the tube. In addition, a man should view the discharge and be prepared to activate the fog spray. The element must have water cooling during shipment; the water-cooled PRTR loadout cart will be used for shipment. If water is taken off the fuel bundles, fission gases will be released and some fission products could be spread, depending on the location of the fuel bundles at the time.


Vibration and Corrosion

The fuel element bundles were mocked up in the 189-D Flow Laboratory and checked for vibration; none was evident.

*Hazards Summary Report, HW-74094, Volume 2

DECLASSIFIED

Figure I



K&E SEMI-LOGARITHMIC 358-81
KEUFFEL & ESSER CO. MADE IN U.S.A.
4 CYCLES X 70 DIVISIONS

Allowable Water Shutoff Interval, Minutes

Vibration and Corrosion (continued)

At the low temperatures present, there should be no problem of corrosion at the interface of the stainless steel and aluminum tube. Likewise, past experience in the KCR loops and MTR has shown no problems at the Zr-SST interface.

Plutonium Considerations

The UO_2 - PuO_2 elements, similar to the type used in PRTR, should produce no unusual problems. The fact that plutonium is contained in the elements before irradiation will require some additional precautions; alpha monitoring equipment will be used to detect a cladding break during charging.

Prepared by J H Cox
 Engineer
 Test Engineering

Approved by [Signature]
 Test Engineering

JH Cox:mkc

DECLASSIFIED

**DATE
FILMED**

6 / 10 / 194

END

