

DOE/CE/15525--T3

**ADVANCED COOLING TECHNOLOGY, Inc.**

DOE/CE/15525--T3

DE92 018682

**QUARTERLY TECHNICAL PROGRESS REPORT**

July 29, 1992

U.S.

U. S. Department of Energy

Grant Project No. 01-91CE 15525



Homer S. Myers  
Project Director

Copies to:

Mr. Elliot Levine, CE-521  
U. S. Department of Energy  
1000 Independence Ave., S.W.,  
Washington, D. C. 20585

U. S. Department of Energy  
Office of Placement & Administration  
Attn.: Bernard G. Canlas, PR-322.2  
1000 Independence Ave., S.W.,  
Washington, D. C. 20585

U. S. Department of Energy  
Office of Scientific & Technical Information  
P. O. Box 62  
Oak Ridge, TN 37830

**DISCLAIMER**

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

MASTER

SP

## PROJECT DESCRIPTION

Advanced Cooling Technology (ACT), Inc., will perform the following tasks in order to develop an improved, more reliable and more marketable version of their ACT Evaporative Subcooling System.

1. Develop a more stable pump by reducing vibration levels.
2. Design and develop a drainage mechanism that will protect the coil.
3. Apply for Underwriters Laboratories approval and perform follow-up and coordination work to complete task to insure product is safe, within its intended applications.
4. Test invention's performance to demonstrate energy savings and long term resistance to scale and corrosion.
5. Contract with the American Refrigeration Institute to perform engineering tests under controlled laboratory conditions. Tests to include pressure and temperature data throughout the refrigeration cycle.
6. Organize data, and develop technical manual for helping purchasers determining energy savings and invention's merits.
7. Perform a field test in a cooperating supermarket, where utility usage can be measured on a before and after basis.
8. Submit progress and financial reports at the end of each calendar quarter. Submit a final report at the end of the grant period that summarizes the technical accomplishments and next steps to make this technology a commercially viable option. The final report will estimate the energy and other benefits of using this system.

Essentially all of the mechanical design improvements proposed for the Evaporative Subcooler having been completed and the production of pilot quantities of the improved parts was done. An effort was made to have some of these installed in field units where difficulties have been observed in the past. Major attention was focussed during this period on the performance of controlled third party tests of the effectiveness of the unit in improving energy efficiency.

In addition, during this Quarter a second or "Continuation Patent" was granted by the U. S. Patent Office allowing much broader claims than was the case of the first patent which was granted in December, 1991.

Task No. 1  
Pump Design

This task has now been completed. Tests of the improved pump in the laboratory, as reported last period, were highly successful. During this period a number of these improved units were sent to the field both on new subcooler units and also as replacement parts for old pumps which had failed in service because of vibration problems. No reports of difficulties with the new pumps have been received.

Task No. 2  
Drainage Mechanism

This task has now been completed from the design standpoint. Ten subcooler units with coated coils were sent to a Florida area where the most severe corrosion problems have been encountered. Attempts will be made to follow the results of this treatment in affecting coil corrosion.

Task No. 3  
Underwriters Laboratories Approval

This task has been abandoned for the reasons described in the previous Quarterly Report.

Task No. 5  
American Refrigeration Institute Tests

Copies of the reports of the ARI tests performed by ETL Testing Laboratories are included herewith as Appendix A (Refrigeration) and Appendix B (Air Conditioning).

Refrigeration:

A Copeland 5 HP Refrigeration unit was rented and shipped to ETL Testing Laboratories for these tests and was returned to us at their completion. The results showed that at 95° F and at 41% Relative Humidity, the Evaporative Subcooler increased the capacity of the system by 7.86%. At 99.7° F and at 43% Relative Humidity, the increase was 12.48%.

Air Conditioning:

A Carrier Unitary 10 Ton Air Conditioner unit which was being tested for other characteristics at ETL Testing Laboratories was made available by the Carrier Corporation for use in our Evaporative Subcooler tests. The results showed that at 99.4° F and at 43% Relative Humidity, the Evaporative Subcooler improved the Energy Efficiency Ratio (EER) of the system by 8.31%.

Several considerations must be kept in mind in the interpretation of these results:

1. The ambient conditions under which the tests were carried out were rather normal summer temperatures and humidities. In many areas of the country, higher temperatures and lower humidities often prevail, both of which promote greater evaporative cooling.
2. The systems were both well "balanced", i.e., the capacities of the compressor and the condenser were well matched. The Copeland refrigeration components were selected by our engineer to achieve this balance. The Carrier air conditioner system is described as "unitary", with components selected and assembled by the manufacturer at the factory. These considerations along with the fact that the systems were properly charged with the correct amount of refrigerant by ETL Laboratories engineers before testing means that they were operating at top efficiency for the "base-line" tests before the Evaporative Subcoolers were installed. The conclusion that can be drawn from this is that the observed

improvements are the minimum that can be expected for installation on systems operating under these ambient conditions.

3. In contrast, however, much larger improvements are frequently obtained in field installations. If, for example, a system is unbalanced because it has an undersized condenser, the addition of a subcooler, even without any evaporative cooling, will improve the performance of the system by increasing the condenser capacity bringing it nearer to balance with the compressor capacity. Add the effect of evaporative cooling and much more improvement is obtained. Similarly, if a system is not properly charged with refrigerant and, as a part of the subcooler installation, the refrigerant charge is brought to the proper level, additional improvement over that attributable to evaporative subcooling may be observed. While these are not true efficiency improvements achieved by evaporative subcooling, they are real energy efficiency gains resulting from the whole process of installing an evaporative subcooler.



## APPENDIX A

# REPORT ETL TESTING LABORATORIES, INC.

INDUSTRIAL PARK

CORTLAND, NEW YORK 13045

Order No. 64670-410

Date: May 4, 1992

REPORT NO. 517055

RENDERED TO

ADVANCED COOLING TECHNOLOGY INC.

PERFORMANCE TESTS OF A

"ACTEC" MODEL 10

EVAPORATIVE SUBCOOLER

(REFRIGERANT R-12)

### General

This report gives the results of Performance Tests of an "ACTEC" Model 10 Evaporative Subcooler coupled to a "Copeland" Model CBAM-0500-TFC-001 condensing unit for refrigeration.

The samples were selected and submitted by the client and received at ETL on March 18, 1992. The work was authorized by client's letter dated February 26, 1992. Testing was coordinated through Mr. Ira Marsh representing the client.

### Test Method

The test was performed in general accordance with the following standards published by the American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc.

ASHRAE 41.9-88 A Standard Calorimeter Test Method for Flow Measurement of a Volatile Refrigerant

ASHRAE 20-70 Methods of Testing for Rating Remote Mechanical-Draft Air-Cooled Refrigerant Condensers

An independent organization testing for safety, performance, and certification.

All services undertaken subject to the following general policy: Reports are submitted for exclusive use of the clients to whom they are addressed. Their significance is subject to the adequacy and representative character of the samples and to the comprehensiveness of the tests, examinations or surveys made. No quotations from reports or use of ETL's name is permitted except as expressly authorized by ETL in writing.

Description of Test Setup

The evaporative subcooler and the refrigeration system condensing unit were installed in a temperature controlled environment. The refrigerant leaving the condensing unit was valved to go through or to bypass the "ACTEC 10" evaporative subcooler. The test system was coupled to a Secondary Refrigerant Calorimeter. Calibrated precision pressure gauges were used to determine refrigerant pressures throughout the system. Calibrated RTD's and thermocouples were used to measure refrigerant and ambient air temperatures. Refrigerant flow was determined by a turbine-type flow meter.

Calorimeter heat input was determined by a watthour transducer measuring the watt input to the evaporator heaters.

Refrigerant flowrate for the primary measurement was determined as the quotient of the heat input to the calorimeter and the enthalpy change of the refrigerant passing through it. The confirming method of the refrigerant flow was the turbine flow meter.

Checked by: M4

Description of Sample, Physical and Nameplate Data1. General Description of Sample

The subcooler consisted of an aluminum finned copper heat exchanger coil, a down draft fan and a cone pump.

The refrigerant condensing system unit consisted of a compressor, condenser coil, fan and two receivers.

The refrigerant was R-12.

2. Nameplate DataSubcooler

"Advanced Cooling Technology  
ACTEC Evaporative Subcooler  
Model No. 10 Serial 543  
Voltage 230 Hz 60 0.4 Amps"

Condensing Unit

"Copeland  
Model CBAM-0500-TFC-001  
208/230 Volt 3 Ph 60 Hz"

Compressor

"Copeland  
Model 9RA1-0500-TFC"

Description of TestsConditions

Ambient, °F	95	100
Saturation Suction, °F	-10	-10
Return Gas, °F	65	65

Test Runs 1 and 3 were with the refrigerant bypassing the evaporative subcooler.

Test Runs 2 and 4 were with the evaporative subcooler energized and supplied with city water.

Checked by: \w4

Test Conditions

	<u>Test Run</u>	
	<u>1</u>	<u>2</u>
Saturated Suction, F	-10	-10
Return Gas, F	65	65
Ambient of Condenser, F	95	95

Results of TestsCondenser Ambient

Air Inlet, F		
dry-bulb	95.2	95.0
wet-bulb	74.7	75.1
Barometer, in. Hg.	28.73	28.84

Calorimeter Side

Electric Input to Heaters, Whrs	4,584	4,944
REFRIGERATING CAPACITY, BTUH	15,640	16,870
Calculated Refrigerant Flow, lbs/hr	283.9	283.9

Refrigerant Side

Refrigerant Temperature, F		
Liquid at Condenser	107.5	107.0
Liquid Entering Subcooler	-	106.5
Liquid Leaving Subcooler	-	83.5
Liquid at Calorimeter	101.4	82.6
Suction at Calorimeter	61.6	61.4
Suction at Compressor	65.0	65.0
Refrigerant Pressures, PSIG		
Liquid at Condenser	173.5	173.0
Liquid at Calorimeter	172.0	171.5
Suction at Calorimeter	6.0	6.0
Suction at Compressor	4.5	4.5
Refrigerant Enthalpy, Btu/lb		
Entering Calorimeter	31.438	26.972
Leaving Calorimeter	86.512	86.407
Difference Across Calorimeter	55.072	59.435
Refrigerant Flow Rate, lbs/hr	278.6	277.7

Electrical Characteristics

Voltage, volts		
Phase A-B	230	230
Phase B-C	230	230
Phase C-D	230	230
Current, amps		
Phase A	13.8	13.9
Phase B	15.2	15.1
Phase C	14.2	14.2
Total Power Input, watts	3,895	3,953

Checked by: WY

Test Conditions

	<u>Test Run</u>	
	<u>3</u>	<u>4</u>
Saturated Suction, F	-10	-10
Return Gas, F	65	65
Ambient of Condenser, F	100	100

Results of TestsCondenser Ambient

Air Inlet, F		
dry-bulb	99.9	99.5
wet-bulb	78.4	79.5
Barometer, in. Hg.	28.41	28.45

Calorimeter Side

Electric Input to Heaters, Whrs	4,039	4,543
REFRIGERATING CAPACITY, BTUH	13,780	15,500
Calculated Refrigerant Flow, lbs/hr	258.8	262.3

Refrigerant Side

Refrigerant Temperature, F		
Liquid at Condenser	115.9	115.6
Liquid Entering Subcooler	-	114.8
Liquid Leaving Subcooler	-	83.9
Liquid at Calorimeter	107.4	81.6
Suction at Calorimeter	59.5	60.3
Suction at Compressor	64.7	65.2
Refrigerant Pressures, PSIG		
Liquid at Condenser	198.5	196.0
Liquid at Calorimeter	197.5	195.0
Suction at Calorimeter	6.0	6.0
Suction at Compressor	4.5	4.5
Refrigerant Enthalpy, Btu/lb		
Entering Calorimeter	32.894	27.183
Leaving Calorimeter	86.139	86.255
Difference Across Calorimenter	53.245	59.072
Refrigerant Flow Rate, lbs/hr	254.6	254.8

Electrical Characteristics

Voltage, volts		
Phase A-B	230	230
Phase B-C	230	230
Phase C-D	230	230
Current, amps		
Phase A	13.7	13.8
Phase B	14.9	14.7
Phase C	14.2	14.1
Total Power Input, watts	3,820	3,879

Checked by: WY



Dates of Tests: April 22 - 24, 1992

Report Approved by:

*mark w Paquette*

Mark W. Paquette, Manager  
Applied Products

Tests Supervised by:

*Robert J. Hill*

Robert J. Hill  
Project Engineer

Checked by: *WY*

Copy by: *kn*

**REPORT  
ETL TESTING LABORATORIES, INC.**

INDUSTRIAL PARK

CORTLAND, NEW YORK 13045

Order No. 64672-420

Date: June 11, 1992

REPORT NO. 518483

RENDERED TO

ADVANCED COOLING TECHNOLOGY, INCORPORATED

PERFORMANCE TESTS

OF A "CARRIER" UNITARY AIR CONDITIONER

MODEL 38AFC0085 CONDENSING UNIT

WITH MODEL 40RR008 BLOWER COIL

WITH AND WITHOUT AN "ACTEC" EVAPORATIVE SUBCOOLER

General

This report gives the results of Performance Tests of a "Carrier" Unitary Air Conditioner Model 38AFC0085 Condensing Unit With Model 40RR008 Blower Coil, with and without an "ACTEC" Evaporative Subcooler manufactured by Advanced Cooling Technology, Incorporated, Lexington, Kentucky 40503.

The sample used to test the evaporative subcooler was provided by Carrier Corporation.

Authorization for the tests was by client's letter dated February 26, 1992, signed by Mr. Homer S. Myers, President. The work was coordinated through Mr. Ira Marsh, Chief Engineer, representing the client.

The tests were conducted in accordance with ARI Standard 210/240-89, "Standard For Unitary Air-Conditioning And Air-Source Heat Pump Equipment," published by the Air-Conditioning and Refrigeration Institute, and ASHRAE Standard ANSI/ASHRAE 37-88, "Methods of Testing for Rating Unitary Air Conditioning and Heat Pump Equipment," published by the American Society of Heating, Refrigerating and Air Conditioning Engineers, Inc.

Notes: (1) The results contained herein are for technical evaluation only and are applicable only to the specific test specimen referenced herein.

(2) The tests herein reported have not been performed at the request of the Air-Conditioning and Refrigeration Institute, and use of these findings by Advanced Cooling Technology, Inc. in any advertising or other literature shall state therein that the test is not part of the ARI Certification Program.

An independent organization testing for safety, performance, and certification.

Description of Unit, Nameplate Data, etc.1. General Description of Unit

The sample was a split-system air-cooled air conditioner. The condenser air was drawn through the condenser coil on three sides and discharged vertically by a fan from the top of the section. The evaporator air was drawn through the front opening air filters and diagonal evaporator coil, and discharged vertically by a blower through two openings at the top of the section. The sections were connected by 25 ft of 1-1/8-in. O.D. suction line (insulated) and 1/2-in. O.D. liquid line. The refrigerant control device contained in the unit was an expansion valve.

2. Nameplate DataCondensing Unit

Model No. 38AFC008510 Serial No. 0792G78198

Qty	Volts	AC	Ph	Hz	RLA	LRA
Compressor	1	208/230	3	60	32.5	183
					FLA	HP
Fan	1	208/230	1	60	2.9	.50 NEC
Power Supply	208/230	V	3	Ph	60	Hz
R-22 Design Test Pressure				High	477	Low 150
Permissible Voltage At Unit	253	Max.			187	Min.
Min. Circuit Amp	44.4					
					60	Fuse Only

Compressor

Copeland  
Model No. BRE2-0750-TFC-214  
Serial No. 92A 15605 00015  
Customer No. GB30TN010A U019 Oil - 128  
Volts 208/230 Ph 3 Hz 60 LRA 183  
Volts 200/240 Hz 50 Pro T MO-C

Condenser Fan Motor

G.E. Model 5KCP39PGH806S  
V 208/230 Hz 60 Ph 3 Amps 1.7  
Cap 10.00/370 Rot. → RPM 1050  
Mfg. No. HC44VL603A

Blower Coil Unit

Model No. 40RR-008-530 Serial No. 1292F91201  
Design Test Pressure High 410 HP 1 Kw Out 0.75  
Power Supply 208/230-460 Volts 3 Ph 60 Hz  
I.D. Motor 230/460 Volts 3 Ph 60 Hz 3.8/1.9 FLA

Evaporator Blower Motor

Inaccessible

Description of Unit, Nameplate Data, etc. (cont'd)3. Description of Coils

	<u>Evaporator</u>	<u>Condenser</u>
Number of Coils	1	1
Fin Material	Aluminum	Aluminum
Tubing Material	Copper	Copper
Style	Staggered	Staggered
Type of Fins	Rippled	Rippled
Number of Fins per Inch	13	15
Diameter of Tubing (OD), in.	1/2	3/8
Number of Tubes per Row	20	32
Center-to-Center Distance Between Tubes, in.	1.25 x 1.25	1.0 x 0.866
Number of Rows Deep	3	2
Coil Height, in.	25.0	32.0
Coil Length, in.	42.0	77-1/2
Face Area (Total), sq. ft.	7.29	17.22

Results of Tests

	W/Out Subcooler		W/ Subcooler	
	Test	Run	Test	Run
	1A*	A	1A*	A

Evaporator Side

Air Temperature, F*				
Evaporator Inlet, dry-bulb	79.90	80.00	79.95	79.80
wet-bulb	67.10	67.30	67.25	67.20
Evaporator Outlet, dry-bulb	63.45	63.50	62.25	62.10
wet-bulb	59.60	59.80	58.85	58.70
Static Pressure at Unit Outlet, in. W.G.	0.31	0.31	0.30	0.30
Standard Air Flow, cfm	2985	2985	2985	2985
TOTAL COOLING EVAPORATOR SIDE, Btu/hr	74630	74930	83320	84160

Condenser Side

Air Temperature, F*				
Condenser Inlet, dry-bulb	99.40	99.50	99.50	99.30
wet-bulb	78.80	78.90	79.50	79.50
Condenser Outlet, dry-bulb	-	127.30	-	127.90
Static Pressure at Unit Outlet, in. W.G.	-	-0.03	-	-0.04
Standard Air Flow, cfm	-	3555	-	3365
TOTAL COOLING CONDENSER SIDE, Btu/hr	-	74330	-	70200

Miscellaneous

Electrical Characteristics of Motors				
Compressor, Condenser Fan & Evaporator				
Blower				
Voltage, volts				
Phase A-B	231	231	230	230
Phase B-C	229	229	230	229
Phase A-C	230	230	230	229
Current, amps				
Phase A	29.5	29.5	30.3	30.2
Phase B	31.4	31.5	32.5	32.4
Phase C	29.8	29.6	30.6	30.5
Power Input, watts				
Phase A-N/A	3330	3340	3500	3470
Phase B-N/B	3490	3500	3650	3640
Phase C-N/C	3210	3200	3300	3300
Total Power Input, watts	10030	10040	10450	10410
Energy Efficiency Ratio, EER	-	7.46	-	8.08

Refrigerant-Circuit Temperatures, F

Discharge at Compressor	237.5	238.5	233.5	233.0
Liquid at Condenser	110.5	111.5	112.5	113.0
Liquid at Evaporator	109.0	110.0	95.5	95.0
Suction at Evaporator	58.5	59.0	55.5	55.5
Suction at Compressor	61.0	61.0	61.0	61.0
Liquid at Subcooler In	-	-	113.0	112.5
Liquid at Subcooler Out	-	-	96.0	96.0

Refrigerant-Circuit Pressures, psig

Liquid at Condensing Unit	304.0	304.0	310.0	310.0
Suction at Condensing Unit	77.0	77.0	72.0	72.0

Note: Air temperatures are recorded to 0.05°F; this value is estimated and is valid only for obtaining temperature differentials as may be required to determine enthalpies.

\*Preliminary Test Run - Condenser Side Free Air Discharge.



Remarks

In the absence of specified requirements, no conclusion has been drawn. The test results are furnished for the client's information and evaluation.

Dates of Tests: May 21-27, 1992

Report Approved by:

Reginaldo I. Romero  
Program Administrator

Test Supervised by:

Byron F. Horak, Manager  
Unitary Products

Copied by: mb

**END**

**DATE  
FILMED**

**9/21/92**

