




**AIIM**


**Association for Information and Image Management**

1100 Wayne Avenue, Suite 1100  
Silver Spring, Maryland 20910  
301/587-8202

**Centimeter**




**Inches**



MANUFACTURED TO AIIM STANDARDS  
BY APPLIED IMAGE, INC.

1 of 2

SUPPORTING DOCUMENT		1. Total Pages 101
2. Title <b>FIRE LOADING CALCULATIONS FOR 300 AREA N REACTOR FUEL FABRICATION AND STORAGE FACILITY</b>	3. Number <b>WHC-SD-NR-TI-053</b>	4. Rev No. <b>0</b>
5. Key Words <b>Fire Loading Calculations, N Reactor Fuel Supply</b>	6. Author <b>Name: C. F. Myott</b>  <b>Signature</b> <b>10/27/93</b>	
<b>APPROVED FOR PUBLIC RELEASE</b> <i>✓ Building 1/24/94</i>		
7. Abstract <p>Fire loading analyses were provided for the N Reactor Fuel Supply buildings 3712, 3716, 303A, 303B, 303E, 303G, and 303K. Fire loading calculations, maximum temperatures, and fire durations were provided to support the safety analyses documentation. The "combustibles" for this document include: wood, cardboard, cloth, and plastic, and does not include the uranium and fuel assembly loading. The information in this document will also be used to support the fire hazard analysis for the same buildings, therefore, it is assumed that sprinkler systems do not work, or the maximum possible fire loss is assumed.</p>	Organization/Charge Code <b>29530/K32JB</b>	
8. PURPOSE AND USE OF DOCUMENT - This document was prepared for use within the U.S. Department of Energy and its contractors. It is to be used only to perform, direct, or integrate work under U.S. Department of Energy contracts. This document is not approved for public release until reviewed.	10. RELEASE STAMP	
<del>PATENT STATUS - This document copy, since it is transmitted in advance of patent clearance, is made available in confidence solely for use in performance of work under contracts with the U.S. Department of Energy. This document is not to be published nor its contents otherwise disseminated or used for purposes other than specified above before patent approval for such release or use has been secured, upon request, from the Patent Counsel, U.S. Department of Energy Field Office, Richland, WA.</del>	<div style="border: 1px solid black; padding: 5px; text-align: center;"> <b>OFFICIAL RELEASE</b>  <b>BY WHC</b>  <b>(20)</b>  <b>DATE JAN 24 1994</b>  <i>Sta. 21</i> </div>	
9. Impact Level <b>2S</b>		

**MASTER**

**FIRE LOADING CALCULATIONS  
FOR  
300 AREA N REACTOR FUEL  
FABRICATION AND STORAGE FACILITY**

Westinghouse Hanford Company

October 1993

Prepared by  
C. F. Myott  
Fire Protection Programs

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

**DEFINITIONS/CLARIFICATIONS**

- RS3 - Red Shipping Box - This is the name given to a particular shipping box. This box is red in color and is 28-inches wide by 48-inches long by 22 5/8-inches high.
- G4255 - Billet Box - This shipping box is 25 5/8-inches wide by 35-inches long by 10-inches high.
- G4214 - Scrap Box - This shipping box is 16 3/8-inches wide by 34 1/2-inches long by 10-inches high.
- NRFF&SF - N Reactor Fuel Fabrication and Storage Facility
- Uranium (U) - A very hard, heavy, radioactive metallic chemical element used as fuel for the N Reactor. Uranium in massive form is not pyrophoric by itself but will burn if there are other "combustibles" ignited.
- Zircaloy-2 (Zr-2) - A zirconium alloy consisting of tin, iron, chromium, nickel and nitrogen in small percentages. This is used as the cladding for the fuel.
- Thorium (Th) - A rare, grayish radioactive chemical element, used in making electronic equipment and as a nuclear target to produce U<sup>233</sup>.
- Billet - Large pieces of uranium that are cold extruded with Zr-2 into a form that can be used for fuel in the N Reactor.
- Scrap - Chunks of cladding (Zircaloy-2) and uranium removed during the fuel machining process.
- Fines, chips - Finely divided metal pieces (uranium, Zircaloy-2) that are pyrophoric and require special handling and storage techniques since they can spontaneously ignite.
- MPFL - The Maximum Possible Fire Loss is the value of property, excluding land, within a fire area. This assumes the failure of both automatic fire suppression systems and manual fire fighting efforts. (DOE 5480.7A)

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

TABLE OF CONTENTS

1.0 INTRODUCTION . . . . .	1
2.0 DOCUMENT PURPOSE . . . . .	2
3.0 PROCEDURE . . . . .	2
4.0 DOCUMENT ARRANGEMENT . . . . .	2
5.0 DISCUSSION . . . . .	3
6.0 REFERENCES . . . . .	4
7.0 ATTACHMENT INDEX . . . . .	4

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

FIRE LOADING CALCULATIONS  
FOR THE  
300 AREA N REACTOR FUEL  
FABRICATION AND STORAGE FACILITY

## 1.0 INTRODUCTION

Fire Protection Programs was requested to supply fire loading analyses for N Reactor Fuel Fabrication and Storage Facility (NRFF&SF) Buildings 3712, 3716, 303-A, 303-B, 303-E, 303-G, and 303-K. The scope of this document is to supply fire loading calculations, maximum temperatures, and fire durations for the above buildings. The fire loading analyses are needed for safety evaluation purposes. The definition of "combustibles" for the purpose of this document is wood (including wooden boxes used for uranium billet and fuel storage), cardboard, cloth, and plastic. The amounts of radiological release from the uranium billets, fuel, and other metal scrap are NOT considered in this document. This fire loading analysis can not be used without taking the radiological consequences, of the uranium (U) and the thorium (Th), into consideration.

The reason that the "combustibles" are considered separate from the U, Zr-2, and Th is that the elements and alloys alone will not burn. They will burn in conjunction with other combustibles, and they will continue to burn only as long as the combustible loading allows. How much of these elements released, during different accident scenarios, will be determined in other safety analyses based on this combustible loading analysis.

The 303-K Building contains drums of radioactive chips and fines underwater. The chips and fines of U and Zr-2 are pyrophoric. These are looked at in an abbreviated analysis in this document to see if it could be the worst case for "combustibles" but shall be analyzed further as required in other safety documents.

**NOTE:** The calculations supplied for the "combustible" per the scope of this report are supplied to be used in conjunction with further safety analysis of the buildings.

## 2.0 DOCUMENT PURPOSE

The purpose of this supporting document is to prepare and document the fire loading calculations for the seven NRFF&SF Buildings being utilized for U storage. These calculations will be referenced in future documents and will also be used in some of the safety analyses of the buildings.

## 3.0 PROCEDURE

Fire Protection Engineers walked the buildings down and took inventory of the building contents. Conversations were held with employees knowledgeable of the NRFF&SF. Conservative fire load standards were developed by using the references in Section 5. Calculations were then performed, and layout sketches were produced for each building.

## 4.0 DOCUMENT ARRANGEMENT

Attachment "A" contains the British Thermal Unit (Btu) loading standards for the shipping boxes developed from the references in Section 5.

Attachment "B" through "H" contain the individual total Btu loading calculations and sketches for each building. Standards developed for the miscellaneous storage and building materials specific for each building are also contained in the attachment for that building.

Attachment "I" contains the time-temperature curve and other data used to support the material presented in this supporting document.

Attachment "J" contains the inventory and arrangement during the first walk through of the 3712 Building. This information is the basis for several of the safety analyses and is included to show how conservative the analyses are. The combustible load inventory has decreased since the first walk through.

## 5.0 DISCUSSION

Since the information in this document will be referenced in future safety documentation, all the building evaluations are based on the assumption that the sprinkler system does not work. This is a requirement in evaluating the Maximum Possible Fire Loss (MPFL) in a Fire Hazard Analysis (FHA). The MPFL is considered to be the "worst case" scenario. This document and the information herein is technical in nature and does not cover all the items required for an FHA (WHC-CM-4-41, Section 3.4); therefore, this document cannot be substituted for a FHA, and the information in this document can not be used, without further analysis or fire modeling, in the FHA.

The 303-K Building contains drums of radioactive chips and fines underwater. In the abbreviated analysis (see Attachment "H") these U and Zr-2 chips and fines were found to be approximately 13% of the total "combustible" load. When this additional loading from the chips and fines was added to the "combustibles," the fire duration was still less than 30 minutes.

The 303-B Building was found to have the greatest fire load density. It has 45 lb/ft<sup>2</sup>. The fire duration of 5 3/4 hours was obtained by using the standard time-temperature curve (Figure I1). The building contains 480 G4255 Billet Boxes.

Figure I2 (Figure 5-8Q and 5-8R from Reference 2) found in Attachment "I" illustrates the fire endurance for concrete mixed with various types of aggregate. Since the type of aggregate used in the 303-K and 303-B Buildings is not known, the least supportive will have to be assumed. With that in mind and using the above figures to evaluate the 303-K and 303-B Buildings during the potential fire durations, it is predicted that the 303-K Building could withstand the fire duration, but the 303-B Building could not withstand a fire of its predicted duration. Anything greater than 2 1/2 hours would probably cause structural failure of the building.

The 3712 Building has 25 lb/ft<sup>2</sup> fire loading and a fire duration of 2 1/2 hours. A fire of this duration is predicted to cause structural failure of the 3712 Building. Of the seven NRFF&SF Buildings analyzed, the 3712 Building contains the most uranium, and may pose the greatest offsite radiological exposure because of this fact. The building contains a total of 893 Red Shipping Boxes, 321 Billet (G4255) Boxes, and 8 Scrap Boxes.

The 303-B and 3712 Buildings are the worst cases for combustible loading for the two basic structural types looked at in this report. Both buildings contain automatic fire alarms and dry pipe sprinkler systems. The 303-B Building is classified as non-combustible construction and the 3712 Building is classified as unprotected steel construction. The 303-B Building contains the greatest fire loading, but the 3712 Building contains the greatest amount of shipping boxes (and thus greatest radioactive source) and has the greatest potential for structural failure if the sprinkler system did not function.

The 3712 Building was surveyed twice. The building had more combustibles during the first survey, and the first survey is used in some of the safety documentation as the worst or limiting case. Both of the 3712 Building surveys are included in this document (Attachment "B" & "J"). The shipping box Btu loading is higher on the preliminary (first) analysis because Reference 1 (see Figure I3, Attachment "I") had not been located, and the estimates were made conservatively.

## 6.0 REFERENCES

1. WHC-EP-0558 "TEST AND EVALUATION DOCUMENT FOR D.O.T. SPECIFICATION 7A TYPE A PACKAGING," Section 4.12, June 1992.
2. "FIRE PROTECTION HANDBOOK," National Fire Protection Association, Fifteenth Edition.
3. "FLAMMABILITY HANDBOOK FOR PLASTICS", Carlos J. Hilado, Second Edition.
4. NFPA 220, Appendix "D", 1992 Edition.
5. CRC, 1992, "HANDBOOK OF CHEMISTRY AND PHYSICS", 72nd Edition, 1991-1992, The Chemical Rubber Company, Boca Raton, Florida.

## 7.0 ATTACHMENT INDEX

Attachment "A" - Standards  
Attachment "B" - 3712 Building Calculations  
Attachment "C" - 3716 Building Calculations  
Attachment "D" - 303-A Building Calculations  
Attachment "E" - 303-B Building Calculations  
Attachment "F" - 303-E Building Calculations  
Attachment "G" - 303-G Building Calculations  
Attachment "H" - 303-K Building Calculations  
Attachment "I" - Time-Temperature Curve, ETC.  
Attachment "J" - 3712 Building Calculations based  
on an earlier inventory

**ATTACHMENT "A"**

**STANDARDS**

**FOR**

**SHIPPING BOXES**

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

**SHIPPING BOXES**  
Page 1 of 2

The weights for the billet and scrap boxes were taken from WHC-EP-0558. (Figure I3, Attachment "I")

The 8,000 Btu/lb and 40 lb/ft<sup>3</sup> are means for the heat value and density of wood, respectively. These values were obtained from NFPA 220, Appendix C. These values are used throughout this document as the potential heat, weight basis and density for wood and related products (paper, cardboard, etc.).

BILLET (G-4255)

$$107 \text{ lb/billet} \times 8,000 \text{ Btu/lb} = 856,000 \text{ Btu/billet}$$

SCRAP (G4214)

$$70 \text{ lb/scrap} \times 8,000 \text{ Btu/lb} = 560,000 \text{ Btu/scrap}$$

RED SHIPPING BOX (RSB)

There was no reference readily available for the red shipping boxes so the value is calculated on the box measurement.

Bottom: 28" x 45 3/4" x 1 1/2"/1,728 in<sup>3</sup> = 1.11 ft<sup>3</sup>

Back & Front: 22 5/8" x 48" x 1 1/8"/1,728 in<sup>3</sup> x 2 = 1.42 ft<sup>3</sup>

Ends: 22 5/8" x 28" x 1 1/8"/1,728 in<sup>3</sup> x 2 = 0.82 ft<sup>3</sup>

2 stacks of spacers 1 holes:

$$4 (5" x 45 1/2" x 1 1/2") - 36 [\pi (1 7/16)<sup>2</sup> x 1 1/2"]/1,728 in<sup>3</sup> x 2 = 1.17 ft<sup>3</sup>$$

3 skids: 3 1/2" x 3 1/2" x 30 1/4"/1,728 in<sup>3</sup> x 3 = 0.64 ft<sup>3</sup>

8 space guides: 1 1/2" x 2 1/2" x 19 1/4"/1,728 in<sup>3</sup> x 8 = 0.33 ft<sup>3</sup>

Total 5.49 ft<sup>3</sup>

$$5.49 \text{ ft}^3 \times 40 \text{ lb/ft}^3 = 219.60 \text{ lb}$$

$$219.60 \text{ lb} \times 8,000 \text{ Btu/lb} = 1,756,800 \text{ Btu}$$

**SHIPPING BOXES**  
Page 2 of 2

**SHIPPING PLASTIC**

The 20,000 Btu/lb for the plastic was obtained from Reference 3, Table 2.25. This value is used throughout this document as the potential heat, weight basis for plastic and related products.

The plastic was conservatively estimated at 1/2 pound per box.

$$.5 \text{ lb} \times 20,000 \text{ Btu/lb} = 10,000 \text{ Btu}$$

The above amount will be added to ALL the boxes.

**Red Shipping Box Cardboard**

Red shipping boxes with finished fuel assemblies have a 1.20 pound (scale weight) cardboard sheet over the top layer.

$$1.20 \text{ lb} \times 10,000 \text{ Btu/lb} = 12,000 \text{ Btu}$$

The above amount will be added to ALL Red Shipping Boxes.

**ATTACHMENT "B"**


**3712 BUILDING  
CALCULATIONS**

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.


Assemblies- 3712 North  
NOT TO SCALE

8' \* 8' room  
with metal walls  
and ceiling



WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.



WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

## BUILDING CONSTRUCTION

Building Name/Number: Fuels Manufacturing Storage/3712  
Area: 300

### Construction:

Roof:	Metal deck on steel beams
Roof Covering:	Metal deck
Exterior Walls:	Uninsulated corrugated metal
Interior Walls:	Corrugated metal
Floors:	Reinforced concrete slab
Fire Areas:	One
Building Area:	9,720 ft <sup>2</sup> (H-3-17517 & 17419)
Storage Floor Area:	9,492 ft <sup>2</sup>

### Description:

One-story steel frame structure with metal panel siding and roof. Concrete floor and foundation. lighting is incandescent. The steam to the heating system and the water to the evaporator cooler have been disconnected; therefore, the building is unheated and uncooled. The building is equipped with a dry pipe sprinkler system.

**SURVEY DATA**

Sheet 1 of 1

Date: October 1993

LOCATION: 300 AREA

BUILDING: 3712

BOX TYPE & OTHER MATERIALS	NUMBER OF	BTU'S EACH	TOTAL BTU'S
RED SHIPPING	893	1,756,800	1,568,822,400
G4255 BILLET	321	856,000	274,776,000
G4214 SCFAP	8	560,000	4,480,000
RSB CARDBOARD	893	12,000	10,716,000
SHIPPING PLASTIC	893	10,000	8,930,000
MISCELLANEOUS		Attached Sheets	3,842,952
GRAND TOTAL			1,871,567,352

**CALCULATIONS  
FOR 3712 BUILDING**

Page 1 of 1

STORAGE AREA - 9,492 ft<sup>2</sup>

**FIRE LOAD DENSITY**

Grand Total/Area of Storage - 197,173.13 Btu/ft<sup>2</sup>  
(Obtained from Survey Data Table)

**EQUIVALENT FIRE**

135,518.56 Btu/ft<sup>2</sup> ÷ 8,000 Btu/lb = 24.65 lb/ft<sup>2</sup>

**SUMMARY**

<u>APPROX AREA (ft<sup>2</sup>)</u>	<u>FIRE LOAD (Btu)</u>	<u>FIRE LOAD DENSITY (Btu/ft<sup>2</sup>)</u>	<u>EQUIVALENT FIRE (lb/ft<sup>2</sup>)</u>	<u>FIRE DURATION</u>	<u>TEMPERATURE (°F)</u>
9,492	1,871,567,352	197,173	25	2 1/2 hrs	1,888

## MISCELLANEOUS STANDARDS

Page 1 of 2

### WOODEN CABINET

24" wide x 92 1/2" long x 77" high -- 1/2" plywood  
The base is 1" plywood.

Using: 8,000 Btu/lb and  
40 lb/ft<sup>3</sup>

Calculation:

Base: (24 1/2" x 92 1/2" x 1")/1,728 in<sup>3</sup> = 1.31 ft<sup>3</sup> x 1 = 1.31 ft<sup>3</sup>

Top & 3 Shelves: (23 1/2" x 91 1/2" x 1/2")/1,728 in<sup>3</sup>  
= 0.62 ft<sup>3</sup> x 4 = 2.49 ft<sup>3</sup>

Ends: (24" x 77" x 1/2")/1,728 in<sup>3</sup> = 0.53 ft<sup>3</sup> x 2 = 1.07 ft<sup>3</sup>

Dividers: (23 1/2" x 63 3/4" x 1/2")/1,728 in<sup>3</sup>  
= 0.43 ft<sup>3</sup> x 4 = 1.73 ft<sup>3</sup>

Back: (92 1/2" x 77" x 1/2")/1,728 in<sup>3</sup> = 2.06 ft<sup>3</sup> x 1 = 2.06 ft<sup>3</sup>

Front Boards: (21 1/2" x 91 1/2" x 1/2")/1,728 in<sup>3</sup>  
= 0.57 ft<sup>3</sup> x 1 = 0.57 ft<sup>3</sup>

Total 9.23 ft<sup>3</sup>

9.23 ft<sup>3</sup> x 40 lb/ft<sup>3</sup> = 369.17 lb

369.17 lb x 8,000 Btu/lb = 2,953,352 Btu

## MISCELLANEOUS STANDARDS

Page 2 of 2

### WOODEN SCALE WEIGHT BOX

37" X 43" X 12" high  
Top & Bottom 3/4" plywood  
Sides 1 1/2" plywood

#### Calculations:

Top & Bottom:  $(37" \times 43" \times 3/4")/1,728 \text{ in}^3$  - 0.69 ft<sup>3</sup> x 2 = 1.38 ft<sup>3</sup>

Sides:  $(37" \times 10 \frac{1}{2}'' \times 1 \frac{1}{2}"/)1,728 \text{ in}^3$  - 0.34 ft<sup>3</sup> x 2 = 0.67 ft<sup>3</sup>

$(40" \times 10 \frac{1}{2}'' \times 1 \frac{1}{2}"/)1,728 \text{ in}^3$  - 0.36 ft<sup>3</sup> x 2 = 0.73 ft<sup>3</sup>

TOTAL 2.78 ft<sup>3</sup>

2.78 ft<sup>3</sup> x 40 lb/ft<sup>3</sup> = 111.20 lb

111.20 lb x 8,000 Btu/lb = 889,600 Btu

TOTAL MISCELLANEOUS 3,842,952 Btu

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

WHC-SD-NR-TI-053, Rev 0


**ATTACHMENT "C"**

**3716 BUILDING  
CALCULATIONS**

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

## Fuel Elements in 3716



WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

## BUILDING CONSTRUCTION

Building Name/Number: Fuels Manufacturing Storage/3716  
Area: 300

### Construction:

Roof:	Metal deck on steel beams
Roof Covering:	Metal deck
Exterior Walls:	Insulated steel panels
Interior Walls:	Gypsum board on wood stud
Floors:	Reinforced concrete slab
Fire Areas:	One
Building Area:	3,200 ft <sup>2</sup> (H-3-7943)
Storage Floor Area:	3,081 ft <sup>2</sup>

### Description:

One story metal frame structure with insulated aluminum siding and roof. Structure mounted 4 feet above grade on concrete wall with concrete floor slab on grade. The floor and approximately 4 feet of the supporting wall is reinforced concrete on grade. Inside partitions are gypsum board on wood studs. The steam to the heating system and the water to the evaporator cooler have been disconnected; therefore, the building is unheated and uncooled. The structure is protected by a dry pipe sprinkler system.

## SURVEY DATA

Sheet 1 of 1Date: 6 / 3 / 93LOCATION: 300 AREABUILDING: 3716

BOX TYPE	NUMBER OF	BTU'S EACH	TOTAL BTU'S
RED SHIPPING	206	1,756,800	361,900,800
G4255 BILLET		856,000	
G4214 SCRAP	134	560,000	75,040,000
RSB CARDBOARD	206	12,000	2,472,000
WRAPPING PLASTIC	206	10,000	2,060,000
BUILDING MATERIALS			8,720,755
MISCELLANEOUS			16,741,230
GRAND TOTAL			466,934,785

**CALCULATIONS  
FOR 3716 BUILDING**

STORAGE AREA = 3,081 ft<sup>2</sup>

**Calculations:**

Grand Total/Area of Storage = 151,553 Btu/ft<sup>2</sup>  
(Obtained from Survey Data Sheet)

**EQUIVALENT FIRE**

$$151,553 \text{ Btu/ft}^2 + 8,000 \text{ Btu/lb} = 18.94 \text{ lb/ft}^2$$

**SUMMARY**

<u>APPROX AREA (ft<sup>2</sup>)</u>	<u>FIRE LOAD (Btu)</u>	<u>FIRE LOAD DENSITY (Btu/ft<sup>2</sup>)</u>	<u>EQUIVALENT FIRE lb/ft<sup>2</sup></u>	<u>FIRE DURATION</u>	<u>TEMPERATURE (°F)</u>
3,081	466,934,785	151,553	19	2 hrs	1,850

**MISCELLANEOUS  
FOR 3716 BUILDING**  
Page 1 of 1

**Using:**

8,000 Btu/lb -- miscellaneous wood

10,000 Btu/lb -- mixed miscellaneous (wood, cardboard, cloth)

20,000 Btu/lb -- miscellaneous plastic (polyethylene)

**Calculations:**

- Insulation (8 sheets)  $2' \times 10' \times 0.08' \times 8 = 13.36 \text{ ft}^3$

$13.36 \text{ ft}^3 \times 10.4 \text{ lb}/\text{ft}^3 \times 3,380 \text{ Btu/lb} =$	469,630 Btu
---	-------------

- Rolled foam (30 pounds) - Polyvinyl chloride

$30 \text{ lb} \times 7,720 \text{ Btu/lb} =$	231,600 Btu
---	-------------

- Plastic Box (6 pounds)

$6 \text{ lb} \times 20,000 \text{ Btu/lb} =$	120,000 Btu
---	-------------

- Mixes miscellaneous (10 pounds)

$10 \text{ lb} \times 10,000 \text{ Btu/lb} =$	100,000 Btu
--	-------------

- Cardboard (600 pounds)

$600 \text{ lb} \times 10,000 \text{ Btu/lb} =$	6,000,000 Btu
---	---------------

- Box of Rags (9 at 30 pounds each)

$270 \text{ lb} \times 10,000 \text{ Btu/lb} =$	2,700,000 Btu
---	---------------

- 2 large chairs at 100,000 Btu each =

	200,000 Btu
--	-------------

- Miscellaneous Wood (865 pounds)

$865 \text{ lb} \times 8,000 \text{ Btu/lb} =$	<u>6,920,000 Btu</u>
--	----------------------

	TOTAL MISCELLANEOUS 16,741,230 Btu
--	------------------------------------

**BUILDING MATERIALS  
FOR 3716 BUILDING**  
Page 1 of 1

**INSULATION**

1" fiberglass - 2400 ft<sup>2</sup>

Using: 3 lb/ft<sup>3</sup> and 3,040 Btu/lb

Calculation:

$$2400 \text{ ft}^2 \times 0.08 \text{ ft} \times 3 \text{ lb/ft}^3 \times 3,040 \text{ Btu/lb} = 1,751,040 \text{ Btu}$$

1" roof board - 800 ft<sup>2</sup>

Using: 10.4 lb/ft<sup>3</sup> and 3,380 Btu/lb

Calculation:

$$800 \text{ ft}^2 \times 0.08 \text{ ft} \times 10.4 \text{ lb/ft}^3 \times 3,380 \text{ Btu/lb} = 2,249,728 \text{ Btu}$$

TOTAL INSULATION 4,000,768 Btu

**LIGHT DOMES**

4' x 4' x 1/4" -- 4 of them

Using: 86 lb/ft<sup>3</sup> and 9,290 Btu/lb

Calculation:

$$4' \times 4' \times 0.02' \times 86 \text{ lb/ft}^3 \times 9,290 \text{ Btu/lb} \times 4 = 1,022,643 \text{ Btu}$$

**PAINTED AREA**

The paint and gypsum board it covered was considered as a whole. The value for the gypsum board plus paint was taken from NFPA 220, Appendix C.

8.7 ft<sup>3</sup> + 20.6 ft<sup>3</sup> + 13.9 ft<sup>3</sup> = 43.2 ft<sup>3</sup>

Using: 3/8" Gypsum board "A" + alkyd gloss paint  
46.7 lb/ft<sup>3</sup> and 880 Btu/lb

Calculation:

$$43.2 \text{ ft}^3 \times 46.7 \text{ lb/ft}^3 \times 880 \text{ Btu/lb} = 1,775,347 \text{ Btu}$$

**TILE AREA**

36 ft<sup>2</sup> + 168 ft<sup>2</sup> + 84 ft<sup>2</sup> = 288 ft<sup>2</sup>

Using: 1/8" linoleum  
86 lb/ft<sup>3</sup> and 7,760 Btu/lb

Calculation:

$$288 \text{ ft}^2 \times 0.01 \text{ ft} \times 86 \text{ lb/ft}^3 \times 7,760 \text{ Btu/lb} = 1,921,997 \text{ Btu}$$

TOTAL BUILDING MATERIALS 8,720,755 Btu

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.


**ATTACHMENT "D"**

**303-A BUILDING  
CALCULATIONS**

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

Assemblies- 303-A



WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK

## BUILDING CONSTRUCTION

Building Name/Number: Magazine - Product Storage/303-A  
Area: 300

### Construction:

Roof:	Reinforced concrete
Roof Covering:	Tar and gravel
Exterior Walls:	Concrete block
Interior Walls:	Concrete
Floors:	Reinforced concrete slab
Fire Areas:	One
Building Area:	1,296 ft <sup>2</sup> (HW-69534)
Storage Floor Area:	1,150 ft <sup>2</sup>

### Description:

One story concrete block structure with concrete foundation and floor. The roof is precast concrete slab with tar and gravel surface. The structure is protected by a dry pipe sprinkler system.

## SURVEY DATA

Sheet 1 of 1Date: 6 / 3 / 93LOCATION: 300 AreaBUILDING: 303-A

BOX TYPE	NUMBER OF	BTU'S EACH	TOTAL BTU'S
RED SHIPPING	155	1,756,800	272,304,000
G4255 BILLET		856,000	
G4214 SCRAP		560,000	
RSB CARDBOARD	155	12,000	1,860,000
WRAPPING PLASTIC	155	10,000	1,550,000
MISCELLANEOUS			
GRAND TOTAL			275,714,000

**AREA  
CALCULATIONS  
FOR 303-A BUILDING**

Page 1 of 1

STORAGE AREA = 1,150 ft<sup>2</sup>

Calculations:

Grand Total/Area of Storage = 239,751.30 Btu/ft<sup>2</sup>  
(Obtained from Survey Data Sheet)

**EQUIVALENT FIRE**

Calculations:

239,751.30 Btu/ft<sup>2</sup> + 8,000 Btu/lb = 29.97 lb/ft<sup>2</sup>

**SUMMARY**

<u>APPROX AREA (ft<sup>2</sup>)</u>	<u>FIRE LOAD (Btu)</u>	<u>FIRE LOAD DENSITY (Btu/ft<sup>2</sup>)</u>	<u>EQUIVALENT FIRE lb/ft<sup>2</sup></u>	<u>FIRE DURATION</u>	<u>TEMPERATURE (°F)</u>
1,150	275,714,000	239,751	30	3 hrs	1,925

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.


**ATTACHMENT "E"**

**303-B BUILDING  
CALCULATIONS**

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

Billets- 303-B



WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

## BUILDING CONSTRUCTION

Building Name/Number: Magazine - Product Storage/303-B  
Area: 300

### Construction:

Roof:	Reinforced concrete
Roof Covering:	Tar and gravel
Exterior Walls:	Concrete block
Interior Walls:	Concrete
Floors:	Reinforced concrete slab
Fire Areas:	One
Building Area:	1,296 ft <sup>2</sup> (HW-69534)
Storage Floor Area:	1,150 ft <sup>2</sup>

### Description:

One story concrete block structure with concrete foundation and floor. The roof is precast concrete slab with tar and gravel surface. The structure is protected by a dry pipe sprinkler system.

**SURVEY DATA**

Sheet 1 of 1

Date: 6 / 3 / 93

LOCATION: 300 Area

BUILDING: 303-B

BOX TYPE	NUMBER OF	BTU'S EACH	TOTAL BTU'S
RED SHIPPING		1,756,800	
G4255 BILLET	480	856,000	410,880,000
G4214 SCRAP		560,000	
RSB CARDBOARD		12,000	
WRAPPING PLASTIC		10,000	
MISCELLANEOUS			
GRAND TOTAL			410,880,000

**AREA  
CALCULATIONS  
FOR 303-B BUILDING**

Page 1 of 1

STORAGE AREA = 1,150 ft<sup>2</sup>

Calculations:

Grand Total/Area of Storage = 357,286.96 Btu/ft<sup>2</sup>  
(Obtained from Survey Data Sheet)

**EQUIVALENT FIRE**

Calculations:

357,286.96 Btu/ft<sup>2</sup> ÷ 8,000 Btu/lb = 44.66 lb/ft<sup>2</sup>

**SUMMARY**

<u>APPROX AREA (ft<sup>2</sup>)</u>	<u>FIRE LOAD (Btu)</u>	<u>FIRE LOAD DENSITY (Btu/ft<sup>2</sup>)</u>	<u>EQUIVALENT FIRE lb/ft<sup>2</sup></u>	<u>FIRE DURATION</u>	<u>TEMPERATURE (°F)</u>
1,150	410,880,000	357,287	45	5 3/4 hrs	2,131

WHC-SD-NR-TI-053, Rev 0


THIS PAGE LEFT BLANK.

**ATTACHMENT "F"**

**303-E BUILDING  
CALCULATIONS**

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.



WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

## BUILDING CONSTRUCTION

Building Name/Number: Magazine - Product Storage/303-E  
Area: 300

### Construction:

Roof:	Reinforced concrete
Roof Covering:	Tar and gravel
Exterior Walls:	Concrete block
Interior Walls:	Concrete
Floors:	Reinforced concrete slab
Fire Areas:	One
Building Area:	1,296 ft <sup>2</sup> (HW-69534)
Storage Floor Area:	1,150 ft <sup>2</sup>

### Description:

One story concrete block structure with concrete foundation and floor. The roof is precast concrete slab with tar and gravel surface. The structure is protected by a dry pipe sprinkler system.

## SURVEY DATA

Sheet 1 of 1Date: 9 / 3 / 92LOCATION: 300 AreaBUILDING: 303-E

BOX TYPE	NUMBER OF	BTU'S EACH	TOTAL BTU'S
RED SHIPPING	96	1,756,800	168,652,800
G4255 BILLET		856,000	
G4214 SCRAP		560,000	
RSB CARDBOARD	96	12,000	1,152,000
WRAPPING PLASTIC	96	10,000	960,000
MISCELLANEOUS			
GRAND TOTAL			170,764,800

**AREA  
CALCULATIONS  
FOR 303-E BUILDING**

Page 1 of 1

STORAGE AREA = 1,150 ft<sup>2</sup>

Calculations:

Grand Total/Area of Storage = 148,491.13 Btu/ft<sup>2</sup>  
(Obtained from Survey Data Sheet)

**EQUIVALENT FIRE**

Calculations:

148,491.13 Btu/ft<sup>2</sup> + 8,000 Btu/lb = 18.56 lb/ft<sup>2</sup>

**SUMMARY**

<u>APPROX AREA (ft<sup>2</sup>)</u>	<u>FIRE LOAD (Btu)</u>	<u>FIRE LOAD DENSITY (Btu/ft<sup>2</sup>)</u>	<u>EQUIVALENT FIRE lb/ft<sup>2</sup></u>	<u>FIRE DURATION</u>	<u>TEMPERATURE (°F)</u>
1,150	170,764,800	148,491	19	2 hrs	1,850

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

G-1


303-G BUILDING  
CALCULATIONS

ATTACHMENT "G"

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

Billets- 303-G



THIS PAGE LEFT BLANK.

## BUILDING CONSTRUCTION

Building Name/Number: Magazine - Product Storage/303-G  
Area: 300

### Construction:

Roof:	Reinforced concrete
Roof Covering:	Tar and gravel
Exterior Walls:	Concrete block
Interior Walls:	Concrete
Floors:	Reinforced concrete slab
Fire Areas:	One
Building Area:	1,296 ft <sup>2</sup> (HW-69534)
Storage Floor Area:	1,150 ft <sup>2</sup>

### Description:

One story concrete block structure with concrete foundation and floor. The roof is precast concrete slab with tar and gravel surface. The structure is protected by a dry pipe sprinkler system.

## SURVEY DATA

Sheet 1 of 1Date: 9 / 3 / 92LOCATION: 300 AreaBUILDING: 303-G ROOM: N/A

BOX TYPE	NUMBER OF	BTU'S EACH	TOTAL BTU'S
RED SHIPPING		1,756,800	
G4255 BILLET	460	856,000	393,760,000
G4214 SCRAP		560,000	
RSB CARDBOARD		12,000	
WRAPPING PLASTIC		10,000	
MISCELLANEOUS			
GRAND TOTAL			393,760,000

**AREA  
CALCULATIONS  
FOR 303-G BUILDING**

Page 1 of 1

STORAGE AREA = 1,150 ft<sup>2</sup>

Calculations:

Grand Total/Area of Storage = 342,400 Btu/ft<sup>2</sup>  
(Obtained from Survey Data Sheet)

**EQUIVALENT FIRE**

Calculations:

342,400 Btu/ft<sup>2</sup> ÷ 8,000 Btu/lb = 42.80 lb/ft<sup>2</sup>

**SUMMARY**

<u>APPROX</u> <u>AREA</u> <u>(ft<sup>2</sup>)</u>	<u>FIRE LOAD</u> <u>(Btu)</u>	<u>FIRE LOAD</u> <u>DENSITY</u> <u>(Btu/ft<sup>2</sup>)</u>	<u>EQUIVALENT</u> <u>FIRE</u> <u>lb/ft<sup>2</sup></u>	<u>FIRE</u> <u>DURATION</u>	<u>TEMPERATURE</u> <u>(°F)</u>
1,150	393,760,000	342,400	43	5 1/2 hrs	2,113

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.


WHC-SD-NR-TI-053, Rev 0

**ATTACHMENT "H"**

**303-K BUILDING  
CALCULATIONS**

WHC-SD-NR-TI-053, Rev 0


THIS PAGE LEFT BLANK.



NOT TO SCALE


303-K NORTH END

NORTH DOOR



WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.



A Plan View of the 303-K Facility.

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

## BUILDING CONSTRUCTION

Building Name/Number: Magazine - Product Storage/303-K  
Area: 300

### Construction:

Roof:	Reinforced concrete
Roof Covering:	Tar and gravel
Exterior Walls:	Concrete block
Interior Walls:	Concrete
Floors:	Reinforced concrete slab
Fire Areas:	One/Two *
Building Area:	1,296 ft <sup>2</sup> (HW-69534 & H-3-10040)
Storage Floor Area:	612 ft <sup>2</sup> (North) 522 ft <sup>2</sup> (South)

### Description:

One story concrete block structure with concrete foundation and floor. The roof is precast concrete slab with tar and gravel surface. The building is divided by a concrete fire wall. There is no steam or water service in the building. All drain lines are plugged.

- \* The fire wall in the 303-K Building has unsealed penetrations. This technically makes the whole building one fire zone unless the penetrations are repaired.

## SURVEY DATA

Sheet 1 of 1Date: 9 / 3 / 92LOCATION: 300 AreaBUILDING: 303-K

BOX TYPE	NUMBER OF	BTU'S EACH	TOTAL BTU'S
RED SHIPPING		1,756,800	
G4255 BILLET		856,000	
G4214 SCRAP		560,000	
RSB CARDBOARD		12,000	
WRAPPING PLASTIC		10,000	
MISCELLANEOUS		SEPARATE SHEET	4,707,004
<b>TOTAL "COMBUSTIBLES"</b>			<b>4,707,004</b>
CHIPS AND FINES		SEPARATE SHEET	697,035
<b>GRAND TOTAL</b>			<b>5,404,039</b>

**AREA  
CALCULATIONS  
FOR 303-K BUILDING**

Page 1 of 1

TOTAL AREA = 1,134 ft<sup>2</sup>

**Calculations:**

Total "Combustibles"/Area of Storage = 4,150.80 Btu/ft<sup>2</sup>  
(Obtained from Survey Data Sheet)

Grand Total/Area of Storage = 4,765.47 Btu/ft<sup>2</sup>  
(Obtained from Survey Data Sheet)

**EQUIVALENT FIRE**

**Calculations:**

4,150.80 Btu/ft<sup>2</sup> + 8,000 Btu/lb = 0.52 lb/ft<sup>2</sup>

4,765.47 Btu/ft<sup>2</sup> + 8,000 Btu/lb = 0.60 lb/ft<sup>2</sup>

**SUMMARY**

<u>APPROX AREA (ft<sup>2</sup>)</u>	<u>FIRE LOAD (Btu)</u>	<u>FIRE LOAD DENSITY (Btu/ft<sup>2</sup>)</u>	<u>EQUIVALENT FIRE lb/ft<sup>2</sup></u>	<u>FIRE DURATION</u>	<u>TEMPERATURE (°F)</u>
1,134	4,707,004	4,151	0.5	less than 30 min	less than 1550
1,134	5,404,039	4,766	0.6	less than 30 min	less than 1550

The chips and fines stored in the building do not significantly effect the results of "combustibles" alone. The predicted fire is still under 30 minutes.

**MISCELLANEOUS  
"COMBUSTIBLES"  
FOR 303-K BUILDING  
(North Room)**

Page 1 of 1

**Using:**

10,000 Btu/lb -- cotton absorbent pads  
20,000 Btu/lb -- 10 mill plastic sheeting

**Calculations:**

- Plastic sheeting (40 pounds)

40 lb x 20,000 Btu/lb - 800,000 Btu

- Cotton absorbent pads (160 pounds)

160 lb x 10,000 Btu/lb - 1,600,000 Btu

**TOTAL FOR NORTH ROOM 2,400,000 Btu**

**MISCELLANEOUS  
"COMBUSTIBLES"  
FOR 303-K BUILDING  
(South Room)**

Page 1 of 2

**Using:**

8,000 Btu/lb & 40 lb/ft<sup>3</sup> -- Wood/Paper Products  
3,040 Btu/lb & 3 lb/ft<sup>3</sup> -- Fiberglass  
7,720 Btu/lb -- Polyvinyl Chloride/Foam

**Calculation:**

- 2 wood boxes 16" wide x 18" high x 12' long  
3/4 " thick

Ends:  $(16" \times 18" \times 3/4")/1,728 \text{ in}^3 = 0.13 \text{ ft}^3 \times 2 = 0.25 \text{ ft}^3$

Top & Bottom:  $(16" \times 144" \times 3/4")/1,728 \text{ in}^3 = 1.00 \text{ ft}^3 \times 2 = 2.00 \text{ ft}^3$

Front & Back:  $(18" \times 144" \times 3/4")/1,728 \text{ in}^3 = 1.13 \text{ ft}^3 \times 2 = \underline{2.25 \text{ ft}^3}$

Total 4.50 ft<sup>3</sup>

$4.50 \text{ ft}^3 \times 40 \text{ lb/ft}^3 = 180 \text{ lb}$   
 $180 \text{ lb} \times 8,000 \text{ Btu/lb} = 1,440,000 \text{ Btu}$

- 4 - 4" wide x 4" high x 3' long - wood

$(4" \times 4" \times 36")/1,728 \text{ in}^3 = 0.33 \text{ ft}^3 \times 4 = 1.33 \text{ ft}^3$

$1.33 \text{ ft}^3 \times 40 \text{ lb/ft}^3 = 53.20 \text{ lb}$   
 $53.20 \text{ lb} \times 8,000 \text{ Btu/lb} = 425,600 \text{ Btu}$

- 6 - 6" wide x 2" high x 2' long - wood

$(6" \times 2" \times 24")/1,728 \text{ in}^3 = 0.17 \text{ ft}^3 \times 6 = 1.00 \text{ ft}^3$

$1.00 \text{ ft}^3 \times 40 \text{ lb/ft}^3 = 40 \text{ lb}$   
 $40 \text{ lb} \times 8,000 \text{ Btu/lb} = 320,000 \text{ Btu}$

- 5 lb misc wood/paper combustibles  
 $5 \text{ lb} \times 8,000 \text{ Btu/lb} = 40,000 \text{ Btu}$

**MISCELLANEOUS  
"COMBUSTIBLES"  
FOR 303-K BUILDING  
(South Room)**

Page 2 of 2

- 5 fiberglass cases 20" wide x 3" high x 8' long  
3/8" thick

Ends:  $(20" \times 3" \times 3/8")/1,728 \text{ in}^3 = 0.01 \text{ ft}^3 \times 2 = 0.03 \text{ ft}^3$

Top & Bottom:  $(20" \times 96" \times 3/8")/1,728 \text{ in}^3 = 0.42 \text{ ft}^3 \times 2 = 0.83 \text{ ft}^3$

Front & Back:  $(3" \times 96" \times 3/8")/1,728 \text{ in}^3 = 0.06 \text{ ft}^3 \times 2 = \underline{0.13 \text{ ft}^3}$

Total 0.99 ft<sup>3</sup>

0.99 ft<sup>3</sup> x 3 lb/ft<sup>3</sup> = 2.97 lb

2.97 lb x 3,040 Btu/lb = 9,029 Btu

- 10 - 3 oz foam spacers in each fiberglass case

3 oz/ 16 oz/lb x 50 x 7,720 Btu/lb = 72,375 Btu

TOTAL FOR SOUTH ROOM 2,307,004 Btu

**TOTAL MISCELLANEOUS COMBUSTIBLES FOR 303-K  
4,707,004**

**CHIPS AND FINES  
303-K BUILDING  
(North Room)**

Page 1 of 1

There is 86.47 kg (190.64 lb) of uranium and 41.19 kg (90.8 lb) of zirconium distributed in 24 drums located in the north end of the 303-K Building.

Using information obtained from Reference 5, Btu content for the uranium and zirconium were calculated.

Given:

$U_3O_8$

$\Delta H_f = -854.4 \text{ kcal/mol}$  ( $\Delta H_f$ , enthalpy of formation at  $25^\circ\text{C}$ )  
1 mol = 842.08 g

$ZrO_2$

$\Delta H_f = -263.04 \text{ kcal/mol}$   
1 mol = 123.22 g

Calculations:

$U_3O_8$

$-854.4 \text{ kcal/mol} \times 1 \text{ mol}/842.08 \text{ g} \times 86.47 \text{ kg} \times 1000 \text{ g/l kg}$   
 $\times 3.968 \text{ Btu/kcal}$   
 $= -348,132.85 \text{ Btu}$

$ZrO_2$

$-263.04 \text{ kcal/mol} \times 1 \text{ mol}/123.22 \text{ g} \times 41.19 \text{ kg} \times 1000 \text{ g/l kg}$   
 $\times 3.968 \text{ Btu/kcal}$   
 $= -348,902.47 \text{ Btu}$

TOTAL U & Zr LOADING: -697,035.32 Btu

The 303-K Building combustible loading "Grand Total" is 5,404,039 Btu (see Data Sheet, Page H-8); therefore, the chips and fines only make up approximately 13% of all the combustibles found in the 303-K Building.

697,035 - 13%  
5,404,039

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

WHC-SD-NR-TI-053, Rev 0

**ATTACHMENT "I"**


**REFERENCE TABLES  
AND GRAPHS**

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

FIGURE II

STANDARD TIME-TEMPERATURE CURVE



Reference 2, Figure 5-9A, Page 5-89

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

FIGURE I2  
FIRE ENDURANCE OF CONCRETE




Fig. 5-8R. Relationship of slab thickness and type of aggregate fire endurance.




Fig. 5-8Q. Effect of various types of aggregate on the fire endurance of 4 1/4-in. slabs.

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.

**FIGURE I3**  
**SHIPPING BOX INFORMATION**

**Dimensions and Weights**

Model	External dimension				Internal dimension			Empty weight (lb)	Authorized gross weight (lb)
	Width (in.)	Length (in.)	Height (in.)	Skid (in.)	Width (in.)	Length (in.)	Height (in.)		
G-4214	16.38	34.50	10.0	4.00	14.13	30.00	8.38	70.0	1,260
G-4245	12.25	18.50	10.0	3.13	10.00	14.00	8.50	25.0	225
G-4255	25.63	35.00	10.0	3.50	24.13	30.75	8.00	107.0	1,470
G-4273-5	27.00	41.25	13.0	3.38	25.50	37.00	12.00	132.0	3,035
G-4273-6	37.00	41.25	16.0	3.38	25.50	37.00	14.00	146.0	3,540
G-4292	16.38	34.50	17.0	3.38	14.13	30.00	16.13	85.0	1,330

**Materials/Method of Construction**

Drawing No. G-4292 00F-5500-X-00491, Rev. 9	
Drawing No. G-4214 00F-5500-X-00431, Rev. 19 00F-5500-X-01490, Rev. 3	
Sides and ends	1.125-in. thick white pine
Bottom	1-in. hardwood
Lids	2, 0.5-in. plywood
Banding	See drawing - 1.25-in. steel
Skids	3 wooden, 3.625 in. or 4 in.
Drawing No. G-4245 00F-5500-X-00460, Rev. 3	
Lid	1, 0.5-in. plywood
Banding	2 vertical and 2 horizontal
Skids	3.25 in.
Drawing No. G-4255 00F-5500-X-00468, Rev. 5 00F-5500-X-00470, Rev. 0	
Drawing No. G-4273 00F-5500-X-00471, Rev. 14 00F-5500-X-00472, Rev. 7 00F-5500-X-00473, Rev. 4	
All construction	0.75-in. exterior grade plywood
Skids	3 wooden, 3.625 in. or 4 in.

WHC-SD-NR-TI-053, Rev 0


THIS PAGE LEFT BLANK.

ATTACHMENT "J"

3712 BUILDING INVENTORY  
ON FIRST WALK THROUGH

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.



BUILDING 3712

NTS

WHC-SD-NR-TI-053, Rev 0

THIS PAGE LEFT BLANK.



**AIIM**


**Association for Information and Image Management**

1100 Wayne Avenue, Suite 1100


Silver Spring, Maryland 20910

301/587-8202

**Centimeter**



**Inches**



MANUFACTURED TO AIIM STANDARDS  
BY APPLIED IMAGE, INC.

2 of 2

## BUILDING CONSTRUCTION

Building Name/Number: Fuels Manufacturing Storage/3712  
Area: 300

### Construction:

Roof:	Metal deck on steel beams
Roof Covering:	Metal deck
Exterior Walls:	Uninsulated corrugated metal
Interior Walls:	N/A
Floors:	Reinforced concrete slab
Fire Areas:	Three - This is based on distance separation of the combustibles.
Building Area:	9,720 ft <sup>2</sup>

### Description:

One-story steel frame structure with metal panel siding and roof. Concrete floor and foundation. lighting is incandescent. Heat furnished by steam-heated forced-air and cool by forced-air evaporative type unit. Building is equipped with automatic fire alarm sprinkler system.

NOTE: Three fire areas were called out in this survey because of the distance separations between the groupings of boxes. The second survey (Attachment "B") had one because the storage had been rearranged and the separations went away.

## SURVEY DATA

Sheet 1 of 3Date: 8 / 31 / 92

LOCATION:

BUILDING: 3712 ROOM: AREA 1

BOX TYPE	NUMBER OF	BTU'S EACH	TOTAL BTU'S
RED SHIPPING	341	2,032,000	692,912,000
G4255 BILLET	248	960,000	238,080,000
G4214 SCRAP		440,000	
CARDBOARD -- 7 OZ (LARGE)		4,400	
CARDBOARD -- 5 OZ (MEDIUM)		3,100	
CARDBOARD -- 4 OZ (SMALL)		2,500	
CARDBOARD -- 3 OZ (TINY)		1,900	
WOOD BOX TYPE "A"		102,400	
WOOD BOX TYPE "B"		38,400	
WOOD BOX TYPE "C"		16,000	
WOOD BOX TYPE "D"		51,200	
SHIPPING PLASTIC	589	10,000	5,890,000
MISCELLANEOUS			1,920,000
GRAND TOTAL			938,802,000

MEASURED STORAGE AREA: 3.138 ft<sup>2</sup>

## SURVEY DATA

Sheet 2 of 3Date: 8 / 31 / 92

LOCATION:

BUILDING: 3712ROOM: AREA 2

BOX TYPE	NUMBER OF	BTU'S EACH	TOTAL BTU'S
RED SHIPPING		2,032,000	
G4255 BILLET		960,000	
G4214 SCRAP		440,000	
CARDBOARD -- 7 OZ (LARGE)	11	4,400	48,400
CARDBOARD -- 5 OZ (MEDIUM)	43	3,100	133,300
CARDBOARD -- 4 OZ (SMALL)	231	2,500	577,500
CARDBOARD -- 3 OZ (TINY)	69	1,900	131,100
WOOD BOX TYPE "A"		102,400	
WOOD BOX TYPE "B"		38,400	
WOOD BOX TYPE "C"	5	16,000	80,000
WOOD BOX TYPE "D"	4	51,200	204,800
PLASTIC BOXES	9 lb	20,000 Btu/lb	180,000
MISCELLANEOUS			500,000
<b>GRAND TOTAL</b>			<b>1,855,100</b>

MEASURED STORAGE AREA: 260 ft<sup>2</sup>

## SURVEY DATA

Sheet 3 of 3Date: 8 / 31 / 92

LOCATION:

BUILDING: 3712 ROOM: AREA 3

BOX TYPE	NUMBER OF	BTU'S EACH	TOTAL BTU'S
RED SHIPPING	202	2,032,000	410,464,000
G4255 BILLET	616	960,000	591,360,000
G4214 SCRAP		440,000	
CARDBOARD -- 7 OZ (LARGE)	58	4,400	255,200
CARDBOARD -- 5 OZ (MEDIUM)		3,100	
CARDBOARD -- 4 OZ (SMALL)	133	2,500	332,500
CARDBOARD -- 3 OZ (TINY)		1,900	
WOOD BOX TYPE "A"	703	102,400	71,987,200
WOOD BOX TYPE "B"	385	38,400	14,784,000
WOOD BOX TYPE "C"	193	16,000	3,088,000
WOOD BOX TYPE "D"		51,200	
PLASTIC ON SHELVES	8-1/2 lb	20,000/lb	170,000
SHIPPING PLASTIC	818	10,000	8,180,000
MISCELLANEOUS		SEE SEPARATE PAGE	11,980,000
GRAND TOTAL			1,112,600,900

MEASURED STORAGE AREA: 4,138 ft<sup>2</sup>

**AREA  
CALCULATIONS  
FOR 3712 BUILDING**  
Page 1 of 1

MEASURED STORAGE AREA 1 = 3,138 ft<sup>2</sup>

Calculations:

Grand Total/Area of Storage = 299,172 Btu/ft<sup>2</sup>  
(Obtained from Area 1 Survey Data Sheet)

MEASURED STORAGE AREA 2 = 260 ft<sup>2</sup>

Calculations:

Grand Total/Area of Storage = 7,135 Btu/ft<sup>2</sup>  
(Obtained from Area 2 Survey Data Sheet)

MEASURED STORAGE AREA 3 = 4,138 ft<sup>2</sup>

Calculations:

Grand Total/Area of Storage = 268,874 Btu/ft<sup>2</sup>  
(Obtained from Area 3 Survey Data Sheet)

**SUMMARY**

<u>FIRE AREA</u>	<u>APPROX AREA (ft<sup>2</sup>)</u>	<u>FIRE LOAD (Btu)</u>	<u>FIRE LOAD DENSITY (Btu/ft<sup>2</sup>)</u>	<u>EQUIVALENT FIRE (lb/ft<sup>2</sup>)</u>	<u>FIRE DURATION</u>	<u>TEMPERATURE (°F)</u>
1	3,138	938,802,000	299,172	37	4 hrs	2000
2	260	1,855,100	7,135	0.9	5 mins	1000
3	4,138	<u>1,112,600,900</u>	268,874	34	3 1/2 hrs	1963
<b>TOTAL FIRE LOAD</b>		<b>2,053,258,000</b>				

ENTIRE BUILDING SPREAD

9,720 2,053,258,000 211,241 26 2.5 hrs 1888

**AREA MISCELLANEOUS  
FOR 3712 BUILDING**

Page 1 of 1

**Using:**

8,000 Btu/lb -- miscellaneous wood

10,000 Btu/lb -- mixed miscellaneous (wood, cardboard, cloth)

20,000 Btu/lb -- miscellaneous plastic (polyethylene)

**Calculations:**

Area 1      80 lb x 20,000 Btu/lb = 1,600,000 Btu

40 lb x 8,000 Btu/lb = 320,000 Btu

Total      1,920,000 Btu

Area 2      25 lb x 20,000 Btu/lb = 500,000 Btu

Total      500,000 Btu

Area 3      100 lb x 20,000 Btu/lb = 2,000,000 Btu

610 lb x 8,000 Btu/lb = 4,880,000 Btu

200 lb x 10,000 Btu/lb = 2,000,000 Btu

One Large Chair      = 100,000 Btu

Wooden Case      = 3,000,000 Btu

Total 11,980,000 Btu

DATE  
FILMED

8/25/94

END

