
Evaluation of Potential Severe Accidents During Low Power and Shutdown Operations at Surry, Unit 1

Analysis of Core Damage Frequency from
Internal Events During Mid-Loop Operations

Appendix E (Sections E.1-E.8)

Manuscript Completed: January 1994
Date Published: June 1994

Prepared by
T. L. Chu, Z. Musicki, P. Kohut, D. Bley¹, J. Yang, B. Holmes²,
G. Bozoki, C. J. Hsu, D. J. Diamond, D. Johnson¹, J. Lin¹,
R. F. Su³, V. Dang³, D. Ilberg⁴, S. M. Wong, N. Siu³

Brookhaven National Laboratory
Upton, NY 11973

Prepared for
Division of Safety Issue Resolution
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001
NRC FIN L1922

¹PLG Inc., 4590 MacArthur Boulevard, Newport Beach, CA 92660-2027

²AEA Technology, Winfrith, Dorchester, Dorset, England, DT2 8DH

³MIT, Cambridge, MA 02139 (N. Siu currently at EG&G, Idaho Falls, ID 83415)

⁴Soreq Nuclear Research Center, Yavne 70600, Israel

MASTER

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, make any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

ABSTRACT

Traditionally, probabilistic risk assessments (PRA) of severe accidents in nuclear power plants have considered initiating events potentially occurring only during full power operation. Some previous screening analyses that were performed for other modes of operation suggested that risks during those modes were small relative to full power operation. However, more recent studies and operational experience have implied that accidents during low power and shutdown could be significant contributors to risk.

During 1989, the Nuclear Regulatory Commission (NRC) initiated an extensive program to carefully examine the potential risks during low power and shutdown operations. The program includes two parallel projects being performed by Brookhaven National Laboratory (BNL) and Sandia National Laboratories (SNL). Two plants, Surry (pressurized water reactor) and Grand Gulf (boiling water reactor), were selected as the plants to be studied.

The objectives of the program are to assess the risks of severe accidents initiated during plant operational states other than full power operation and to compare the estimated core damage frequencies, important accident sequences and other qualitative and quantitative results with those accidents initiated during full power operation as assessed in NUREG-1150. The scope of the program includes that of a level-3 PRA.

The objective of this volume of the report is to document the approach utilized in the level-1 internal events PRA for the Surry plant, and discuss the results obtained. A phased approach was used in the level-1 program. In phase 1, which was completed in Fall 1991, a coarse screening analysis examining accidents initiated by internal events (including internal fire and flood) was performed for all plant operational states (POSS). The objective of the phase 1 study was to identify potential vulnerable plant configurations, to characterize (on a high, medium, or low basis) the potential core damage accident scenarios, and to provide a foundation for a detailed phase 2 analysis.

In phase 2, mid-loop operation was selected as the plant configuration to be analyzed based on the results of the phase 1 study. The objective of the phase 2 study is to perform a detailed analysis of the potential accident scenarios that may occur during mid-loop operation, and compare the results with those of NUREG-1150. The scope of the level-1 study includes plant damage state analysis, and uncertainty analysis. Volume 1 summarizes the results of the study. Internal events analysis is documented in Volume 2. It also contains an appendix that documents the part of the phase 1 study that has to do with POSSs other than mid-loop operation. Internal fire and internal flood analyses are documented in Volumes 3 and 4. A separate study on seismic analysis, documented in Volume 5, was performed for the NRC by Future Resources Associates, Inc. Volume 6 documents the accident progression, source terms, and consequences analysis.

In the phase 2 study, system models applicable for shutdown conditions were developed and supporting thermal hydraulic analysis were performed to determine both the timing of the accidents and success criteria for systems. Initiating events that may occur during mid-loop operations were identified and accident sequence event trees were developed and quantified. In the preliminary quantification of the mid-loop accident sequences, it was found that the decay heat at which the accident initiating event occurs is an important parameter that determines both the success criteria for the mitigating functions and the time available for operator actions. In order to better account for the decay heat, a "time window" approach was

developed. In this approach, time windows after shutdown were defined based on the success criteria established for the various methods that can be used to mitigate the accident. Within each time window, the decay heat and accident sequence timing are more accurately defined and new event trees developed and quantified accordingly. Statistical analysis of the past outage data was performed to determine the time at which a mid-loop condition is reached, and the duration of the mid-loop operation. Past outage data were used to determine the probability that an accident initiating event occurs in each of the time windows. This probability is used in the quantification of the accident sequences.

The mean core damage frequency of the Surry plant due to internal events that may take place during mid-loop operations is $5\text{E-}06$ per year, and the 5th and 95th percentiles are $5\text{E-}07$ and $2\text{E-}05$ per year, respectively. This can be compared with the mean core damage frequency from internal events of $4\text{E-}05$ per year estimated in the NUREG-1150 study for full power operations.

Contents

Appendix E	Event Trees and Their Associated High Level Fault Trees
-------------------	--

FOREWORD

(NUREG/CR-6143 and 6144) Low Power and Shutdown Probabilistic Risk Assessment Program

Traditionally, probabilistic risk assessments (PRA) of severe accidents in nuclear power plants have considered initiating events potentially occurring only during full power operation. Some previous screening analysis that were performed for other modes of operation suggested that risks during those modes were small relative to full power operation. However, more recent studies and operational experience have implied that accidents during low power and shutdown could be significant contributors to risk.

During 1989, the Nuclear Regulatory Commission (NRC) initiated an extensive program to carefully examine the potential risks during low power and shutdown operations. The program includes two parallel projects performed by Brookhaven National Laboratory (BNL) and Sandia National Laboratories (SNL), with the seismic analysis performed by Future Resources Associates. Two plants, Surry (pressurized water reactor) and Grand Gulf (boiling water reactor), were selected as the plants to be studied.

The objectives of the program are to assess the risks of severe accidents due to internal events, internal fires, internal floods, and seismic events initiated during plant operational states other than full power operation and to compare the estimated core damage frequencies, important accident sequences and other qualitative and quantitative results with those accidents initiated during full power operation as assessed in NUREG-1150. The scope of the program includes that of a level-3 PRA.

The results of the program are documented in two reports, NUREG/CR-6143 and 6144. The reports are organized as follows:

For Grand Gulf:

NUREG/CR-6143 - Evaluation of Potential Severe Accidents during Low Power and Shutdown Operations at Grand Gulf, Unit 1

- Volume 1: Summary of Results
- Volume 2: Analysis of Core Damage Frequency from Internal Events for Operational State 5 During a Refueling Outage
 - Part 1: Main Report
 - Part 1A: Sections 1 - 9
 - Part 1B: Section 10
 - Part 1C: Sections 11 - 14
 - Part 2: Internal Events Appendices A to H
 - Part 3: Internal Events Appendices I and J
 - Part 4: Internal Events Appendices K to M
- Volume 3: Analysis of Core Damage Frequency from Internal Fire Events for Plant Operational State 5 During a Refueling Outage
- Volume 4: Analysis of Core Damage Frequency from Internal Flooding Events for Plant Operational State 5 During a Refueling Outage
- Volume 5: Analysis of Core Damage Frequency from Seismic Events for Plant Operational State 5 During a Refueling Outage

Foreword (continued)

- Volume 6: Evaluation of Severe Accident Risks for Plant Operational State 5
During a Refueling Outage
Part 1: Main Report
Part 2: Supporting MELCOR Calculations

For Surry:

NUREG/CR-6144- Evaluation of Potential Severe Accidents during Low Power and Shutdown
Operations at Surry Unit-1

- Volume 1: Summary of Results

- Volume 2: Analysis of Core Damage Frequency from Internal Events during
Mid-loop Operations
Part 1: Main Report
Part 1A: Chapters 1 - 6
Part 1B: Chapters 7 - 12
Part 2: Internal Events Appendices A to D
Part 3: Internal Events Appendix E
Part 3A: Sections E.1 - E.8
Part 3B: Sections E.9 - E.16

- Part 4: Internal Events Appendices F to H
Part 5: Internal Events Appendix I
Volume 3: Analysis of Core Damage Frequency from Internal Fires during
Mid-loop Operations
Part 1: Main Report
Part 2: Appendices
Volume 4: Analysis of Core Damage Frequency from Internal Floods during
Mid-loop Operations
Volume 5: Analysis of Core Damage Frequency from Seismic Events during
Mid-loop Operations
Volume 6: Evaluation of Severe Accident Risks during Mid-loop Operations
Part 1: Main Report
Part 2: Appendices

APPENDIX E
EVENT TREES AND THEIR ASSOCIATED HIGH LEVEL
FAULT TREES

APPENDIX E

EVENT TREES AND THEIR ASSOCIATED HIGH LEVEL

FAULT TREES


	Page
E.1 Event Trees and High Level Fault Trees for Over Draining to Mid-loop (RHR2A)	E-3
E.2 Event Trees and High Level Fault Trees for Loss of Inventory (RHR2B)	E-60
E.3 Event Trees and High Level Fault Trees for Non-Recoverable Loss of RHR (RHR3)	E-117
E.4 Event Trees and High Level Fault Trees for Loss of Operation Train of RHR (RHR4)	E-166
E.5 Event Trees and High Level Fault Trees for Recoverable Loss of RHR (RHR5)	E-219
E.6 Event Trees and High Level Fault Trees for Loss of Offsite Power (L1)	E-272
E.7 Event Trees and High Level Fault Trees for Loss of Offsite Power (L2)	E-368
E.8 Event Trees and High Level Fault Trees for Unit 1 Blackout (L3)	E-453
E.9 Event Trees and High Level Fault Trees for Two Unit Blackout (B1)	E-537
E.10 Event Trees and High Level Fault Trees for Two Unit Blackout (B2)	E-592
E.11 Event Trees and High Level Fault Trees for Loss of 4KV Bus (4K)	E-618
E.12 Event Trees and High Level Fault Trees for Loss of Vital Bus (VB)	E-701
E.13 Event Trees and High Level Fault Trees for Spurious Safety Injection Signal (SI)	E-784
E.14 Event Trees and High Level Fault Trees for Loss of Component Cooling Water (AR)	E-867
E.15 Event Trees and High Level Fault Trees for Loss of Instrument Air (CC)	E-910
E.16 Event Trees and High Level Fault Trees for Loss of Switchgear Room Cooling (SR)	E-967

Appendix E.1 Event Trees and High Level Fault trees for Over Draining to Mid-loop(RHR2A)


UNITY	IRAW1	MRAW1	PRAW1	VW1	SRAW1	FRAW1	GRAW1	CRAW1	SEQ #	END-STATE-
									1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18	OK OK CD CD CD CD OK OK CD CD OK CD CD CD OK OK CD CD
RAWIR6 Event Tree										

UNITY	IRAW1	MRAW1	RRAW1	FRAW1V	CRAW1V	SEQ #	END-STATE-NAMES
1 2 3 4 5 6 7 8 OK OK OK CD CD OK CD CD RAWID6 Event Tree							


RCS Makeup in Window 1




Restore RHR given RHR2B in Window 1




Safety Valves Not Removed in Window 1




Reflux Cooling in Window 1




RCS Loops Isolated to Cause Failure of Reflux in Window 1




Feed and Bleed the RCS in RHR2A, Window 1




Safety Valves Removed in Window 1




Feed and Bleed the RCS with V failed in RHR2A, Window 1




Gravity from RWST in RHR2A, Window 1




Pressure Window 1



Failure of Recirculation Spray in Window 1—cause HPR failure




Failure of High Pressure Recirculation in Window 1




UNITY	IRAW2	MRAW2	RRAW2	VW2	SRAW2	FRAW2	GRAW2	CRAW2	SEQ #	END-STATE
RAW2R6 Event Tree										OK OK OK CD CD CD OK OK CD CD OK CD CD CD OK OK CD CD

UNITY	IRAW2	MRAW2	RRAW2	SRAW2	FRAW2V	CRAW2V	SEQ #	END-STATE-NAMES
RAW2D6 Event Tree								OK
								OK
								OK
								OK
								CD
								CD
								OK
								OK
								CD
								CD


RCS Makeup in Window 2




Restore RHR given RHR2A in Window 2




Safety Valves Not Removed in Window 2




Reflux Cooling in Window 2




RCS Loops Isolated to Cause Failure of Reflux in Window 2




Feed and Bleed the RCS in RHR2A, Window 2




Safety Valves Removed in Window 2




Feed and Bleed the RCS with V failed in RHR2A, Window 2




Gravity from RWST in RHR2A, Window 2




Foils of High Pressure Packcussion in Window 2





Failure of Recirculation Spray in Window 2-cause HPR failure



Folds of High
Pressure Facetation
in Window 2




UNITY	IRAW3	MRAW3	RRAW3	VW3	FRAW3	GRAW3	SEQ #	END-STATE-NAMES
 RAW3R6 Event Tree								OK OK OK CD OK CD OK CD CD OK CD CD


UNITY	IRAW3	MRAW3	RRAW3	SRAW3	FRAW3V	SEQ #	END-STATE-NAMES
						1 2 3 4 5 6 7 8	OK OK OK OK CD OK OK CD
 RAW3D6 Event Tree							

UNITY	IRAW3	MRAW3	RRAW3	VW3	FRAW3	GRAW3	SEQ #	END-STATE-NAMES
RAW3R10 Event Tree								OK OK OK CD CD OK CD OK CD CD OK CD


RCS Makeup in Window 3




Restore RHR given RHR2A in Window 3




Safety Valves Not Removed in Window 3




Reflux Cooling in Window 3




RCS Loops Isolated to Cause Failure of Reflux in Window 3




Feed and Bleed the RCS in RHR2A, Window 3




Safety Valves Removed in Window 3




Feed and Bleed the RCS with V failed in RHR2A, Window 3




Gravity from RWST in RHR2A, Window 3




UNITY	IRAW4	MRAW4	RRAW4	VW4	SRAW4	FRAW4	GRAW4	SEQ #	END-STATE-NAMES
								1 2 3 4 5 6 7 8 9 10 11 12 13 14	OK OK OK OK CD OK OK CD OK OK CD OK OK CD




RAW4R6 Event Tree

UNITY	IRAW4	MRAW4	RRAW4	SRAW4	FRAW4V	SEQ #	END-STATE-NAMES
 RAW4D6 Event Tree							OK OK OK OK CD OK OK CD


1 top event for over Draining in window 4




RCS Makeup in Window 4




Restore RHR given RHR2A in Window 4




Safety Valves Not Removed in Window 4




Reflux Cooling in Window 4




RCS Loops Isolated to Cause Failure of Reflux in Window 4




Feed and Bleed the RCS in RHR2A Window 4




Safety Valves Removed in Window 4



Feed and Bleed the RCS with V failed in RHR2B, Window 4




Gravity from RWST in RHR2A, Window 4




Appendix E.2 Event trees and High Level Fault Trees for Loss of Inventory(RHR2B)


UNITY	IRBW1	MRBW1	RRBW1	VW1	SRBW1	FRBW1	GRBW1	CRBW1	SEQ #	END-STATE
									1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18	OK OK OK CD CD CD OK OK CD CD OK CD CD CD OK OK CD CD
RBW1R6 Event Tree										

UNITY	IRBW1	MRBW1	RRBW1	FRBW1V	CRBW1V	SEQ #	END-STATE-NAMES
 RBW1D6 Event Tree							OK OK OK CD CD OK CD CD


I Top Event for Loss of Inventory in Window 1




RCS Makeup in Window 1




Restore RHR given RHR2B in Window 1




Safety Valves Not Removed in Window 1




Reflux Cooling in Window 1




RCS Loops Isolated to Cause Failure of Reflux in Window 1




Feed and Bleed the RCS in RHR2B, Window 1




Safety Valves Removed in Window 1




Feed and Bleed the RCS with V failed in RHR2B, Window 1




Gravity from RWST in RHR2B, Window 1



E-73



Failure of Recirculation Spray in Window 1-cause HPR failure




in Window 1




UNITY	IRBW2	MRBW2	RRBW2	SRBW2	FRBW2V	CRBW2V	SEQ #	END-STATE-NAMES
RBW2D6 Event Tree								OK OK OK OK CD CD OK OK CD CD


Window 2




RCS Makeup in Window 2




Restore RHR given RHR2B in Window 2




Safety :Valves Not Removed in Window 2




Reflux Cooling in Window 2




RCS Loops Isolated to Cause Failure of Reflux in Window 2




Feed and Bleed the RCS in RHR2B, Window 2




Safety Valves Removed in Window 2




Feed and Bleed the RCS with V failed in RHR2B, Window 2




Gravity from RWST in RHR2B, Window 2



Failure of High Pressure Recirculation in Window 2



Failure of Recirculation Spray in Window 2-cause HPR failure




[illegible]

UNITY	IRBW3	MRBW3	RRBW3	VW3	FRBW3	GRBW3	SEQ #	END-STATE-NAMES
RBW3R6 Event Tree								OK OK OK CD CD OK CD OK CD CD OK CD


UNITY	IRBW3	MRBW3	RRBW3	VW3	FRBW3	GRBW3	SEQ #	END-STATE-NAMES
RBW3R10 Event Tree								OK OK OK CD CD OK OK OK CD CD OK CD

UNITY	IRBW3	MRBW3	RRBW3	SRBW3	FRBW3V	SEQ #	END-STATE-NAMES
						1 2 3 4 5 6 7 8	OK OK OK CD OK OK CD
RBW3D6 Event Tree							


I Top Event for Loss of Inventory in Window 3




RCS Makeup in Window 3




Restore RHR given RHR2B in Window 3




Safety Valves Not Removed in Window 3




Reflux Cooling in Window 3




RCS Loops Isolated to Cause Failure of Reflux in Window 3




Feed and Bleed the RCS in RHR2B, Window 3




Safety Valves Removed in Window 3




Feed and Bleed the RCS with V failed in RHR2B, Window 3




Gravity from RWST in RHR2B, Window 3




UNITY	IRBW4	MRBW4	RRBW4	VW4	FRBW4	GRBW4	SEQ #	END-STATE-NAMES
 RBW4R6 Event Tree								OK OK OK OK CD OK CD CD OK OK CD OK CD

UNITY	IRBW4	MRBW4	RRBW4	SRBW4	PRBW4V	SEQ #	END-STATE-NAMES
1 2 3 4 5 6 7 8 OK OK OK OK CD CD OK CD 1 2 3 4 5 6 7 8 OK OK OK OK CD CD OK CD RBW4D6 Event Tree							


RCS Makeup in Window 4




Restore RHR given RHR2B in Window 4




Safety Valves Not Removed in Window 4




Reflux Cooling in Window 4




RCS Loops Isolated to Cause Failure of Reflux in Window 4




Feed and Bleed the RCS in RHR2B, Window 4




Safety Valves Removed in Window 4



Feed and Bleed the RCS with V failed in RHR2B, Window 4



Gravity from RWST in RHR2B, Window 4




**Appendix E.3 Event Tree and High Level Fault Trees for Non-recoverable Loss of
RHR(RHR3)**


UNITY	IR3W1	VW1	SR3W1	FR3W1	GR3W1	CR3W1	SEQ #	END-STATE-NAMES
							1 2 3 4 5 6 7 8 9	OK OK CD CD CD CD OK OK CD CD
R3W1R6 Event Tree								

UNITY	IR3W1	FR3W1V	CR3W1V	SEQ #	END-STATE-NAMES
			 R3W1D6 Event Tree	1 2 3 4	OK OK CD CD


Safety Valves Not Removed in Window 1




RCS Loops Isolated to Cause Failure of Reflux in Window 1




Feed and Bleed the RCS in RHR3, Window 1




Safety Valves Removed in Window 1



Feed and Bleed the RCS with V failed in RHR3, Window 1




Gravity from RWST in RHR3, Window 1





Feed and Steam
with LPR


Failure of Recirculation Spray in Window 1-cause HPR failure :




Failure of High Pressure Recirculation in Window 1




UNITY	IR3W2	VW2	SR3W2	FR3W2	GR3W2	CR3W2	SEQ #	END-STATE-NAMES
 R3W2R6 Event Tree								OK OK CD CD CD OK OK CD CD

UNITY	IR3W2	SR3W2	FR3W2V	CR3W2V	SEQ #	END-STATE-NAMES
					1 2 3 4 5	OK OK OK CD CD
						R3W2D6 Event Tree


Safety Valves Not Removed in Window 2




Reflux Cooling Given RHR3 in Window 2




RCS Loops Isolated to Cause Failure of Reflux in Window 2




Feed and Bleed the RCS in RHR3, Window 2




Safety Valves Removed in Window 2




Feed and Bleed the RCS with V failed in RHR3, Window 2




Gravity from RWST in RHR3, Window 2



Failure of High Pressure Recirculation in Window 2




Failure of Recirculation Spray in Window 2-cause HPR failure for RHR3 Event



```

graph TD
    A[Failure of High Pressure Reactivation in Window 2] --- B[CRASH]
  
```




UNITY	IR3W3	VW3	FR3W3	GR3W3	SEQ #	END-STATE-NAMES
 R3W3R6 Event Tree						OK OK CD CD OK CD

UNITY	IR3W3	VW3	FR3W3	GR3W3	SEQ #	END-STATE-NAMES
						OK OK CD CD OK OK CD

1 2 3 4 5 6


R3W3R10 Event Tree

UNITY	IR3W3	SR3W3	FR3W3	SEQ #	END-STATE-NAMES
 R3W3D6 Event Tree					OK OK OK CD


— 37 —




Safety Valves Not Removed in Window 3




Reflux Cooling Given RHR3 in Window 3




RCS Loops Isolated to Cause Failure of Reflux in Window 3




Feed and Bleed the RCS in RHR3, Window 3







Feed and Bleed the RCS with V failed in RHR3, Window 3



Gravity from RWST in RHR3, Window 3




UNITY	IR3W4	VW4	FR3W4	GR3W4	SEQ #	END-STATE-NAMES
 R3W4R6 Event Tree						OK OK OK CD OK CD


UNITY	IR3W4	VW4	FR3W4	GR3W4	SEQ #	END-STATE-NAMES
					1 2 3 4 5 6	OK OK OK CD OK CD
 R3W4R10 Event Tree						

UNITY	IR3W4	SR3W4	FR3W4V	GR3W4	SEQ #	END-STATE-NAMES
1 2 3 4 R3W4D6 Event Tree						OK OK OK OK CD


I Top Event for Loss of RHR- R3 in Window 4




Safety Valves Not Removed in Window 4




Reflux Cooling Given RHR3 in Window 4




RCS Loops Isolated to Cause Failure of Reflux in Window 4




Feed and Bleed the RCS in RHR3, Window 4




Safety Valves Removed in Window 4



Feed and Bleed the RCS with V failed in RHR3, Window 4




Gravity from RWST in RHR3, Window 4




Appendix E.4 Event Trees and High Level Fault Trees for Loss of Operation Train of RHR(RHR4)

UNITY	IR4W1	RR4W1	VW1	SR4W1	FR4W1	GR4W1	CR4W1	SEQ #	END-STATE-NAMES
R4W1R6 Event Tree									OK OK OK CD CD CD OK OK CD CD


Restore RHR given RHR4 in Window 1




Safety Valves Not Removed in Window 1




Reflux Cooling in Window 1




RCS Loops Isolated to Cause Failure of Reflux in Window 1




Feed and Bleed the RCS in RHR4, Window 1




Safety Valves Removed in Window 1




Feed and Bleed the RCS with V failed in RHR4, Window 1




Gravity from RWST in RHR4, Window 1



E-178



Failure of Recirculation Spray in Window 1—cause HPR failure




UNITY	IR4W2	RR4W2	VW2	SR4W2	FR4W2	GR4W2	CR4W2	SEQ #	END-STATE-NAMES
								1	OK
								2	OK
								3	OK
								4	CD
								5	CD
								6	CD
								7	OK
								8	OK
								9	CD
								10	CD

. R4W2R6 Event Tree


UNITY	IR4W2	RR4W2	SR4W2	FR4W2V	CR4W2V	SEQ #	END-STATE-NAMES
						1 2 3 4 5 6	OK OK OK OK CD CD

1 2 3 4 5 6




R4W2D6 Event Tree


Restore RHR given RHR4 in Window 2




Safety :Valves Not Removed in Window 2




Reflux Cooling in Window 2




RCS Loops Isolated to Cause Failure of Reflux in Window 2




Feed and Bleed the RCS in RHR4, Window 2




Safety Valves Removed in Window 2




Feed and Bleed the RCS with V failed in RHR4, Window 2





Gravity from RWST in RHR4, Window 2




Failure of Recirculation Spray in Window 2-cause HPR failure




UNITY	IR4W3	RR4W3	VW3	FR4W3	GR4W3	SEQ #	END-STATE-NAMES
 R4W3R6 Event Tree							OK OK OK CD CD OK CD


UNITY	IR4W3	RR4W3	VW3	FR4W3	GR4W3	SEQ #	END-STATE-NAMES
 R4W3R10 Event Tree							OK OK OK CD CD OK CD

UNITY	IR4W3	RR4W3	SR4W3	FR4W3V	SEQ #	END-STATE-NAMES
 R4W3D6 Event Tree						OK OK OK OK CD


| top event for loss of RHR-4 in window 3




Restore RHR given RHR4 in Window 3




Safety Valves Not Removed in Window 3




Reflux Cooling in Window 3




RCS Loops Isolated to Cause Failure of Reflux in Window 3




Feed and Bleed the RCS in RHR5, Window 3




Safety Valves Removed in Window 3





Feed and Bleed the RCS with V failed in RHR4, Window 3



Gravity from RWST in RHR4, Window 3



UNITY	IR4W4	RR4W4	VW4	FR4W4	GR4W4	SEQ #	END-STATE-NAMES
						1 2 3 4 5 6 7	OK OK OK CD OK OK CD
 R4W4R6 Event Tree							


UNITY	IR4W4	RR4W4	VW4	FR4W4	GR4W4	SEQ #	END-STATE-NAMES
						1 2 3 4 5 6 7	OK OK OK CD OK OK CD
 R4W4R10 Event Tree							

UNITY	IR4W4	RR4W4	SR4W4	FR4W4V	SEQ #	END-STATE-NAMES
						OK OK OK OK CD


1
2
3
4
5

R4W4D6 Event Tree


| top event for loss of RHR-4 in window 4 |




Restore RHR given RHR4 in Window 4




Safety Valves Not Removed in Window 4




Reflux Cooling in Window 4




RCS Loops Isolated to Cause Failure of Reflux in Window 4




Feed and Bleed the RCS in RHR4, Window 4




Safety Valves Removed in Window 4



Feed and Bleed the RCS with V failed in RHR4, Window 4




Gravity from RWST in RHR4, Window 4




**Appendix E.5 Event Trees and High Level Fault Trees for Recoverable Loss of RHR
(RHR5)**

UNITY	IR5W1	RR5W1	VW1	SR5W1	FR5W1	GR5W1	CR5W1	SEQ #	END-STATE-NAMES
1 2 3 4 5 6 7 8 9 10 OK OK OK CD CD CD OK OK CD CD 1 2 3 4 5 6 7 8 9 10 OK OK OK CD CD CD OK OK CD CD R5W1R6 Event Tree									


| top event for loss of RHR— R5 in Window 1




Restore RHR given RHR5 in Window 1




Safety Valves Not Removed in Window 1




RCS Loops Isolated to Cause Failure of Reflux in Window 1




Feed and Bleed the RCS in RHR5, Window 1




Safety Valves Removed in Window 1




Feed and Bleed the RCS with V failed in RHR5, Window 1




Gravity from RWST in RHR5, Window 1






Failure of Recirculation Spray in Window 1-cause HPR failure for RHR5 Event




[illegible]


UNITY	IR5W2	RR5W2	VW2	SR5W2	FR5W2	GR5W2	CR5W2	SEQ #	END-STATE-NAMES
								1 2 3 4 5 6 7 8 9 10	OK OK OK CD CD CD OK OK CD CD
R5W2R6 Event Tree									

UNITY	IR5W2	RR5W2	SR5W2	FR5W2V	CR5W2V	SEQ #	END-STATE-NAMES
						1 2 3 4 5 6	OK OK OK OK CD CD
 R5W2D6 Event Tree							


| Top Event for Loss of RHR— R5 in Window 2




Restore RHR given RHR5 in Window 2




Safety Valves Not Removed in Window 2




Reflux Cooling Given RHR5 in Window 2




RCS Loops Isolated to Cause Failure of Reflux in Window 2




Feed and Bleed the RCS in RHR5, Window 2




Safety Valves Removed in Window 2




Feed and Bleed the RCS with V failed in RHR5, Window 2




Gravity from RWST in RHR5, Window 2




Failure of Recirculation Spray in Window 2-cause HPR failure for RHR5 Event




Failure of High Pressure Reactor in Window 2




Failure of High Pressure Recirculation in Window 2




UNITY	IR5W3	RR5W3	VW3	FR5W3	GR5W3	SEQ #	END-STATE-NAMES
 R5W3R6 Event Tree							OK OK OK CD CD OK CD

UNITY	IR5W3	RR5W3	VW3	FR5W3	GR5W3	SEQ #	END-STATE-NAMES
						1	OK
						2	OK
						3	OK
						4	CD
						5	CD
						6	OK
						7	CD


R5W3R10 Event Tree

UNITY	IR5W3	RR5W3	SR5W3	FR5W3V	SEQ #	END-STATE-NAMES
					1 2 3 4 5	OK OK OK OK CD
 R5W3D6 Event Tree						


Restore RHR given RHR5 in Window 3




Safety Valves Not Removed in Window 3




Reflux Cooling Given RHR5 in Window 3




RCS Loops Isolated to Cause Failure of Reflux in Window 3




Feed and Bleed the RCS in RHR5, Window 3




Safety Valves Removed in Window 3




Feed and Bleed the RCS with V failed in RHR5, Window 3



Gravity from RWST in RHR5, Window 3




UNITY	IR5W4	RR5W4	VW4	FR5W4	GR5W4	SEQ #	END-STATE-NAMES
						1 2 3 4 5 6 7	OK OK OK OK CD OK CD
 R5W4R6 Event Tree							


UNITY	IR5W4	RR5W4	VW4	FR5W4	GR5W4	SEQ #	END-STATE-NAMES
R5W4R10 Event Tree							OK OK OK OK CD OK CD

UNITY	IR5W4	RR5W4	SR5W4	PR5W4V	SEQ #	END-STATE-NAMES
 R5W4D6 Event Tree						OK OK OK OK CD


| Top Event for Loss of RHR-5 in Window 4




Restore RHR given RHR5 in Window 4




Safety Valves Not Removed in Window 4




Reflux Cooling Given RHR5 in Window 4




RCS Loops Isolated to Cause Failure of Reflux in Window 4




Feed and Bleed the RCS in RHR5, Window 4




Safety Valves Removed in Window 4



Feed and Bleed the RCS with V failed in RHR5, Window 4



Gravity from RWST in RHR5, Window 4




Appendix E.6 Event Trees and High Level Fault Trees for Loss of Offsite Power (L1)

UNITY	IL1W1	RL1W1	NL1W1	FL1W1	CL1W1	SEQ #	END-STATE
						1	@
						2	@
						3	@
						4	CD
						5	CD
						6	@
						7	CD
						8	CD


L1W1D6

LOSS OF OFFSITE POWER
CAT. L1, WINDOW 1
DRAINED MAINTENANCE


| top event for L1 LOSP – L1 in window 1




Restore RHR given L1 in POS 6 - Refueling




Safety valves Not Removed in Window 1




Non-Recovery of AC Power in 144 min. of LOOP




Reflux Cooling in window 1




Reflux Cooling in window 1




RCS Loops isolated to cause failure of reflux in window 1





Feed and Bleed the RCS in L1, Window 1




Feed and Bleed the RCS in L1, Window 1









Gravity from RWST in L1, Window 1




Gravity from RWST in L1, Window 1




Safety Valves Removed in Window 1




Failure of High Pressure Recirculation in Window 1




Failure of High Pressure Recirculation in Window 1




Failure of High Pressure Recirculation in Window 1




Failure of High Pressure Recirculation in Window 1






















UNITY	IL1W2	RL1W2	VW2	NL1W2	SL1W2	FL1W2	GL1W2	CL1W2	SEQ #	END-STATE-NAMES
L1W2R6 --- LOSP L1, WINDOW W2, POS R6										

UNITY	IL1W2	RL1W2	NL1W2	SL1W2	FL1W2	CL1W2	SEQ #	END-STATI
L1W2D6 -- LOSP L1, WINDOW W2, POS D6								
								@ @ @ @ CD CD @ @ CD CD


1 top event for L1 in window 2




Restore RHR given L1 in POS 6 - Refueling




Safety valves Not Removed in Window 2




Non-Recovery of AC Power in W2




Reflux Cooling in window 2




Reflux Cooling in window 2




RCS Loops isolated to cause failure of reflux in window 1





Feed and Bleed the RCS in L1, Window 2




Feed and Bleed the RCS in L1, Window 2









Gravity from RWST in L1, Window 2




Gravity from RWST in L1, Window 2




Safety Valves Removed in Window 2



Failure of High Pressure Recirculation in Window 2




Failure of High Pressure Recirculation in Window 2




[illegible]


Failure of High Pressure Recirculation in Window 2




Failure of Recirculation Spray in Window 2-cause HPR failure




Failure of Recirculation Spray in Window 2-cause HPR failure





Failure of Recirculation Spray in Window 2-cause HPR failure





Failure of Recirculation Spray in Window 2-cause HPR failure



























UNITY	IL1W3	RL1W3	VW3	NL1W3	FL1W3	GL1W3	SEQ #	END-STATE-NAMES
L1W3R6 -- LOSP L1, WINDOW W3, POS R6								1 2 3 4 5 6 7 8 9 10 11 12 @ @ @ CD CD @ CD CD @ CD @ CD


UNITY	IL1W3	RL1W3	NL1W3	SL1W3	FL1W3	SEQ #	END-STATE-NAMES
L1W3D6 -- LOSP L1, WINDOW W3, POS D6							
							1 2 3 4 5 6 7 8 @ @ @ @ CD @ @ @ CD

UNITY	ILIW3	RLIW3	VW3	NLIW3	FLIW3	GLIW3	SEQ #	END-STATE-NAMES
L1W3R10 --- LOSP L1, WINDOW W3, POS R10								
							1	Ⓢ
							2	Ⓢ
							3	Ⓢ
							4	CD
							5	CD
							6	Ⓢ
							7	CD
							8	CD
							9	Ⓢ
							10	CD
							11	Ⓢ
							12	CD


I top event for L1 in window 3




Restore RHR given L1




Safety valves Not Removed in Window 3




Non-Recovery of AC Power




Reflux Cooling in window 3




Reflux Cooling in window 3




RCS Loops isolated to cause failure of reflux in window 3





Feed and Bleed the RCS in L1, Window 3




Feed and Bleed the RCS in L1, Window 3









Safety Valves Removed in Window 3



Gravity from RWST in L1, Window 3




Gravity from RWST in L1, Window 3




UNITY	IL1W4	RL1W4	VW4	NL1W4	FL1W4	GL1W4	SEQ #	END-STATE-NAMES
L1W4R6 -- LOSP L1, WINDOW W4, POS R6								
								@ @ @ OK CD @ OK CD @ CD @ CD CD


UNITY	IL1W4	RL1W4	NL1W4	SL1W4	FL1W4	SEQ #	END-STATE-NAMES
L1W4D6 -- LOSP L1, WINDOW W4, POS D6							
							1 2 3 4 5 6 7 8 @ @ @ @ CD @ @ CD

UNITY	IL1W4	RL1W4	VW4	NLIW4	FL1W4	GL1W4	SEQ #	END--STATE--NAMES
L1W4R10 --- LO SP L1, WINDOW W4, POS R10								
								@ @ @ OK CD @ @ OK CD @ CD @ @ CD


Restore RHR given L1




Safety valves Not Removed in Window 4




Non-Recovery of AC Power




Reflux Cooling in window 4




Reflux Cooling in window 4




RCS Loops isolated to cause failure of reflux in window 4




Feed and Bleed the RCS in L1, Window 4




Feed and Bleed the RCS in L1, Window 4









Gravity from RWST in L1, Window 4



Gravity from RWST in L1, Window 4



Safety Valves Removed in Window 4




Appendix E.7 Event Trees and High Level Fault Trees for Loss of Offsite Power(L2)


UNITY	IL2W1	RL2W1	VW1	NL2W1	SL2W1	FL2W1	GL2W1	CL2W1	SEQ #	END-STATE-NAME
L2WIR6 --- LOSP L2, WINDOW W1, POS R6										1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 @ @ @ CD CD CD @ CD CD CD @ @ CD CD @ @ CD CD

UNITY	IL2W1	RL2W1	NL2W1	FL2W1	CL2W1	SEQ #	END-STATE
L2W1D6 --- LOSP L2, WINDOW W1, DRAINED MAINT. POS 6							
						1	@
						2	@
						3	@
						4	CD
						5	CD
						6	@
						7	CD
						8	CD


Restore RHR given L2 in POS 6 - Refueling




Non-Recovery of AC Power in 144 min. of LOOP




Reflux Cooling in window 1




Reflux Cooling in window 1





Feed and Bleed the RCS in L2, Window 1




Feed and Bleed the RCS in L2, Window 1









Gravity from RWST in L2, Window 1




Gravity from RWST in L2, Window 1




Failure of High Pressure Recirculation in Window 1




Failure of High Pressure Recirculation in Window 1





Failure of High Pressure Recirculation in Window 1




Failure of High Pressure Recirculation in Window 1
























UNITY	IL2W2	RL2W2	VW2	NL2W2	SL2W2	FL2W2	GL2W2	CL2W2	SEQ #	END-STATE-NAMES
L2W2R6 -- LOSP L2, WINDOW W2, POS R6										
									1	@
									2	@
									3	@
									4	CD
									5	CD
									6	CD
									7	@
									8	CD
									9	CD
									10	CD
									11	@
									12	@
									13	CD
									14	CD
									15	@
									16	@
									17	CD
									18	CD

UNITY	IL2W2	RL2W2	NL2W2	SL2W2	FL2W2	CL2W2	SEQ #	END-STATI
L2W2D6 -- LOSP L2, WINDOW W2, POS D6								
							1	@
							2	@
							3	@
							4	@
							5	CD
							6	CD
							7	@
							8	@
							9	CD
							10	CD


1 top event for L2 LOSP - L2 in window 2




Restore RHR given L2 in POS 6 - Refueling




Non-Recovery of AC Power in W2




Reflux Cooling in window 2




Reflux Cooling in window 2





Feed and Bleed the RCS in L2, Window 2




Feed and Bleed the RCS in L2, Window 2









Gravity from RWST in L2, Window 2




Gravity from RWST in L2, Window 2




Failure of High Pressure Recirculation in Window 2




Failure of High Pressure Recirculation in Window 2




Failure of High Pressure Recirculation in Window 2




Failure of High Pressure Recirculation in Window 2




Failure of Recirculation Spray in Window 2-cause HPR failure




Failure of Recirculation Spray in Window 2-cause HPR failure





Failure of Recirculation Spray in Window 2-cause HPR failure





Failure of Recirculation Spray in Window 2-cause HPR failure



























UNITY	IL2W3	RL2W3	NL2W3	SL2W3	FL2W3	SEQ #	END-STATE-NAMES
L2W3D6 --- LOSP L2, WINDOW W3, POS D6							
							1 2 3 4 5 6 7 8 @ @ @ @ CD @ @ CD

UNITY	IL2W3	RL2W3	VW3	NL2W3	FL2W3	GL2W3	SEQ #	END-STATE-NAMES
L2W3R10 -- LOSP L2, WINDOW W3, POS R10								
								@ @ @ CD CD @ CD @ CD @ CD CD @ CD


| top event for L2 LOSP – L2 in window 3




Restore RHR given L2 in POS 6 - Refueling




Safety Valves Not Removed in Window 3




Non-Recovery of AC Power




Reflux Cooling in window 3




Reflux Cooling in window 3




Feed and Bleed the RCS in L2, Window 3




Feed and Bleed the RCS in L2, Window 3




Feed and Bleed the RCS in L2, Window 3




Feed and Bleed the RCS in L2, Window 3




Gravity from RWST in L2, Window 3




Gravity from RWST in L2, Window 3




UNITY	IL2W4	RL2W4	VW4	NL2W4	FL2W4	GL2W4	SEQ #	END-STATE-NAMES
L2W4R6 -- LOSP L2, WINDOW W4, POS R6								
								@ @ @ OK CD @ OK CD @ CD @ CD

UNITY	IL2W4	RL2W4	VW4	NL2W4	FL2W4	GL2W4	SEQ #	END-STATE-NAMES
L2W4R10 -- LOSP L2, WINDOW W4, POS R10								
								@ @ @ OK CD @ @ OK CD @ CD CD @ CD


I top event for L2 LOSP - L2 in window 4




Restore RHR given L2 in POS 6 - Refueling




Non-Recovery of AC Power




Reflux Cooling in window 4




Reflux Cooling in window 4




Feed and Bleed the RCS in L2, Window 4




Feed and Bleed the RCS in L2, Window 4




Feed and Bleed the RCS in L2, Window 4



Gravity from RWST in L2, Window 4




Gravity from RWST in L2, Window 4




Appendix E.8 Event Trees and High Level Fault Trees for Unit 1 Blackout(L3)


UNITY	IL3W1	RL3W1	VW1	NL3W1	SL3W1	FL3W1	GL3W1	CL3W1	SEQ #	END-STATE-NAN
L3W1R6 --- LO SP L3, WINDOW W1, POS R6										
										@ @ @ CD CD CD @ CD CD CD @ @ CD CD @ @ CD CD

UNITY	IL3W1	RL3W1	NL3W1	FL3W1	CL3W1	SEQ #	END-STATE
L3W1D6 -- LOSP L3, WINDOW W1, POS D6							
							@ @ @ CD CD @ CD CD
1 2 3 4 5 6 7 8							


1 top event for L3 LOSP - L3 in window 1




Restore RHR given L3 in POS 6 - Refueling




Non-Recovery of AC Power in 144 min. of LOOP




Reflux Cooling in window 1





Reflux Cooling in window 1




Feed and Bleed the RCS in L3, Window 1









Gravity from RWST in L3, Window 1




Gravity from RWST in L3, Window 1




Failure of High Pressure Recirculation in Window 1




Failure of High Pressure Recirculation in Window 1



Failure of High Pressure Recirculation in Window 1





Failure of High Pressure Recirculation in Window 1

























UNITY	IL3W2	RL3W2	VW2	NL3W2	SL3W2	FL3W2	GL3W2	CL3W2	SEQ #	END-STATE-NAMES
L3W2R6 --- LOSP L3, WINDOW W2, POS R6										
										@ @ @ @ CD CD CD CD @ CD CD CD CD CD @ @ CD CD @ CD @ CD CD CD

UNITY	IL3W2	RL3W2	NL3W2	SL3W2	FL3W2	CL3W2	SEQ #	END-STATI
L3W2D6 -- LOSP L3, WINDOW W2, POS D6								
								1 2 3 4 5 6 7 8 9 10
								@ @ @ @ CD CD @ @ CD CD


l top event for L3 LOSP – L3 in window 2




Restore RHR given L3 in POS 6 - Refueling




Non-Recovery of AC Power in W2




Reflux Cooling in window 2




Reflux Cooling in window 2





Feed and Bleed the RCS in L3, Window 2




Feed and Bleed the RCS in L3, Window 2









Gravity from RWST in L3, Window 2




Gravity from RWST in L3, Window 2




Failure of High Pressure Recirculation in Window 2




Failure of High Pressure Recirculation in Window 2




Failure of High Pressure Recirculation in Window 2




Failure of High Pressure Recirculation in Window 2




Failure of Recirculation Spray in Window 2-cause HPR failure




Failure of Recirculation Spray in Window 2-cause HPR failure





Failure of Recirculation Spray in Window 2-cause HPR failure



Failure of Recirculation Spray in Window 2-cause HPR failure



























UNITY	IL3W3	RL3W3	VW3	NL3W3	FL3W3	GL3W3	SEQ #	END-STATE-NAMES
L3W3R6 -- LO SP L3, WINDOW W3, POS R6								
								e e e CD CD e CD CD e CD e CD CD e CD


UNITY	IL3W3	RL3W3	NL3W3	SL3W3	FL3W3	SEQ #	END--STATE--NAMES
L3W3D6 -- LOSP L3, WINDOW W3, POS D6							
							@ @ @ @ CD @ @ CD 1 2 3 4 5 6 7 8

UNITY	IL3W3	RL3W3	VW3	NL3W3	FL3W3	GL3W3	SEQ #	END-STATE-NAMES
L3W3R10 --- LOSP L3, WINDOW W3, POS R10								
								@ @ @ CD CD @ CD CD @ CD CD @ CD


1 top event for L3 LOSP - L3 in window 3




Restore RHR given L3 in POS 6 - Refueling




Non-Recovery of AC Power




Reflux Cooling in window 3




Reflux Cooling in window 3




Feed and Bleed the RCS in L3, Window 3




Feed and Bleed the RCS in L3, Window 3




Feed and Bleed the RCS in L3, Window 3




Feed and Bleed the RCS in L3, Window 3




Gravity from RWST in L3, Window 3




Gravity from RWST in L3, Window 3




UNITY	IL3W4	RL3W4	VW4	NL3W4	FL3W4	GL3W4	SEQ #	END-STATE-NAMES
L3W4R6 -- LO SP L3, WINDOW W4, POS R6								
								@ @ @ OK CD @ OK CD @ CD @ CD


UNITY	IL3W4	RL3W4	NL3W4	SL3W4	FL3W4	SEQ #	END--STATE--NAMES
L3W4D6 -- LOSP L3, WINDOW W4, POS D6							
							@ @ @ @ CD @ @ CD 1 2 3 4 5 6 7 8

UNITY	IL3W4	RL3W4	VW4	NL3W4	FL3W4	GL3W4	SEQ #	END-STATE-NAMES
L3W4R10 --- LOSP L3, WINDOW W4, POS R10								
								@ @ @ OK CD @ OK CD @ CD @ CD


Restore RHR given L3 in POS 6 - Refueling




Non-Recovery of AC Power




Reflux Cooling in window 4




Reflux Cooling in window 4




Feed and Bleed the RCS in L3, Window 4




Feed and Bleed the RCS in L3, Window 4




Feed and Bleed the RCS in L3, Window 4




Feed and Bleed the RCS in L3, Window 4



Gravity from RWST in L3, Window 4



Gravity from RWST in L3, Window 4



Kiyoharu Abe
Dept. of Reactor Safety Research
Nuclear Safety Research Center
Tokai Research Establishment
JAERI
Tokai-mura, Naga-gun
Ibaraki-ken,
JAPAN

Sarbes Acharya
Department of Energy
NS-1/FORS
Washington, DC 20585

Dr. Ulvi Adalioglu
Cekmece Nukleer Arastraima ve
Egitim Merekezi
P.K. 1
Havaalani/ISTANBUL
TURKEY

Dr. Eng. Kiyoto Aizawa
Senior Engineer
Reactor Eng. Dev. Department
PNC
9-13, Chome, Akasaka
Minato-K, Tokyo
JAPAN

Harry Alter
Manager Applied Tech
Nuclear Systems Tech
NE-46
US DOE
Washington, DC 20585

R.M. Andrews
Nuclear Installations Insp.
St. Peters House
Balliol Road, Bootle
Merseyside L20 3LZ
UNITED KINGDOM

George Apostolakis
UCLA
Boelter Hall, Room 5532
Los Angeles, CA 90024-1597

Director of Reactor Engineering
Argonne National Laboratory
9700 S Cass Ave
Bldg 208
Argonne, IL 60439

Ephraim Asculai
Division of Nuclear Safety
Wagramstrasse, 5
P.O. Box 100
A-1400 Wien
AUSTRIA

Vladimar Asmolov
Head, Nuclear Safety Department
I. V. Kurchatov Institute
of Atomic Energy
Moscow, 123181
RUSSIA

J. de Assuncao
Cabinete de Proteccao e
Seguranca Nuclear
Ministerio da Industria
Ave. de Republica 45-6
1000 Lisbon
PORTUGAL

H.P. Balfanz, Head
Institute of Probabilistic
Safety Analysis
TUV Nord
Grosse Bahnstrasse 31
D-22525 Hamburg 54
GERMANY

Pat Baranowsky
USNRC-AEOD/TPAB
MS: T-4A9

Robert A. Bari, Deputy Chairman
Dept of Nuclear Energy
Bldg 197C
Brookhaven National Laboratory
Upton, NY 11973

Librarian
Technical Information Section
Battelle Pacific Northwest Lab
P. O. Box 999
Richland, WA 99352

Dr. John Baum
Dept of Nuclear Energy
Radiological Sciences Div
Bldg 703 M
Brookhaven National Laboratory
Upton, NY 11973

Eric Beckjord
USNRC-RES/DO
MS: T-10F12

Robert Bernero
USNRC-NMSS/DO
MS: T-8A23

Andrea Besi
Institute for Systems Engineering
and Informatics
CEC Joint Research Centre
CP N 1
1-21020 Ispra (Varese)
ITALY

John Bickel
Idaho National Engineering Lab.
EG&G MS: 3850
P.O. Box 1625
Idaho Falls, ID 83415

Vicki Bier
Dept. of Industrial Engineering
University of Wisconsin-Madison
1513 University Avenue, Room 389
Wisconsin, WI 53706

Scott Bigelow
S-CUBED
2501 Yale SE, Suite 300
Albuquerque, NM 87106

Prof. Dr. Dr.-Ing. E. H. Adolf
Birkhofer
Gesellschaft für Anlagen und
Reaktorsicherheit (GRS) mbH
Forschungsgelände
D-8046 Garching
Federal Republic of Germany

David Black
American Electric Power
1 Riverside Plaza
Columbus, OH 43215

Harold Blackman
Idaho National Engineering Lab.
EG&G MS: 3850
P.O. Box 1625
Idaho Falls, ID 83415-3850

Dennis Bley
Buttonwood Consulting
17291 Buttonwood St.
Fountain Valley, CA 92708

Roger Blond
Booz-Allen & Hamilton
4330 East West Highway
Bethesda, MD 20814

M. P. Bohn
Division 6449
Sandia National Laboratories
Albuquerque, NM 87185

Dr. Mario Bonaca
Manager, Reactor Engineering
Northeast Utilities
P.O. Box 270
Hartford, Conn. 06141

Robert B. Borsum
Nuclear Power Division
B & W Nuclear Tech
1700 Rockville Pike
Suite 525
Rockville, MD 20852

Stephen Boulton
Electrowatt Engineering Services
(UK) Ltd.
Grandford House
16 Carfax, Horsham
West. Sussex RH12 IUP
ENGLAND

Gary Boyd
Safety & Reliability Optimization
Services
9724 Kingston Pike, Suite 102
Knoxville, TN 37922

Brookhaven National Laboratory (2)
Attn: Lev Neymotin
Arthur Tingle
Building 130
Upton, NY 11973

David M. Brown
Paul C. Rizzo Associates, Inc.
300 Oxford Drive
Monroeville, PA 15146-2347

Tom D. Brown
Sandia National Laboratories
Dept. 6413
P.O. Box 5800
Albuquerque, NM 87185

A. L. Camp
Division 6412
MS: 0748
Sandia National Laboratories
Albuquerque, NM 87185-0748

Robert J. Budnitz
Future Resources Associates, Inc.
2039 Shattuck Avenue, Suite 402
Berkeley, CA 94704

John Forbes Campbell
HM Superintending Inspector
Health & Safety Executive
St. Peter's House
Balliol Road
Bootle L20 31Z
UNITED KINGDOM

Gary Burdick
USNRC-RES/SAIB
MS: T-10F13

Leonel Canelas
New University of Lisbon
Quinta de Torre
2825 Monte de Caparica
PORTUGAL

Arthur Buslik
USNRC-RES/PRAB
MS: T-9F31

Edward Butcher
USNRC-NRR/SPSB
MS: O-10E4

Harold Careway
General Electric Co., M/C 754
175 Curtner Ave.
San Jose, CA 95129

Technical Library
B&W Nuclear Service Co
P. O. Box 10935
Lynchburg, VA 24506

D. D. Carlson
Division 6411
Sandia National Laboratories
Albuquerque, NM 87185

Stefaan Caeymaex
Safety & Systems Section
Nuclear Generation Dept.
TRACTEBEL
Avenue Ariane 7
B-1200 Bruxelles
BELGIUM

Jose E. De Carlos
CSN International Coordinator
Consejo de Seguridad Nuclear
Calle Justo Dorado 11
28040 Madrid
SPAIN

Leonard Callan, Administrator
U.S. Nuclear Regulatory Commission
Harris Tower and Pavilion
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Annick Carnino
International Atomic Energy Agency
Wagramerstrasse 5, P.O. Box 100
A-1400 Vienna
AUSTRIA

J. Calvo
Division of PSA & Human Factors
Consejo de Seguridad Nuclear
Calle Justo Dorado, 11
28040 Madrid
SPAIN

S. Chakraborty
Swiss Federal Nuclear Safety
Inspectorate
Hauptabteilung für die Sicherheit
der Kernanlagen
CH-5232 Villigen-HSK
SWITZERLAND

Erulappa Chelliah
USNRC-RES/PRAB
MS: T-9F31

Mike Cheok
NUS
910 Clopper Road
Gaithersburg, MD 20878

Nilesh Chokshi
USNRC-RES/SSEB
MS: T-10L1

T. L. Chu
Brookhaven National Laboratory
Department of Nuclear Energy
Bldg. 130
Upton, NY 11973

Peter Cooper
SRD/AEA Technology
Wigshaw Lane
Culcheth
Cheshire WA3 4NE
England

Susan E. Cooper
Science Applications Int'l. Corp.
11251 Roger Bacon Drive
Reston, VA 22090

Michael Corradini
University of Wisconsin
1500 Johnson Drive
Madison, WI 53706

E.R. Corran
ANSTO Reasearch Establishment
Lucas Heights Reserch Labs.
Private Mail Bag 1
Manai, NSW 2234
AUSTRALIA

Massimo Cozzone
A.N.P.A.
Via V. Brancati, 48
I-00144 Rome
ITALY

George Crane
1570 E. Hobble Creek Dr.
Springville, Utah 84663

Mark Cunningham
USNRC-RES/PRAB
MS: T-9F31

S. Daggupaty
Environment Canada
4905 Dufferin Street
Downsview
Ontario, M3H ST4
CANADA

Louise Dahlerup
Inspectorate of Nuclear Inst.
Danish Civil Defense &
Emergency Planning Agency
16, Datavej
DK-3460 Birkerod
DENMARK

John Darby
SEA, Inc.
6100 Uptown Blvd. NE
Albuquerque, NM 87110

Gerald Davidson
Fauske and Associates, Inc.
16 W 070 West 83rd Street
Burr Ridge, IL 60521

Peter Davis
PRD Consulting
P.O. Box 2046
Sheridan, WY 82801

P. De Gelder
Secretary, BELGIAN NUCLEAR
SOCIETY (BNS)
A V Nuclear
Avenue du Roi 157
B-1060 Brussels
BELGIUM

Lennart Devell
Studsvik Nuclear
Studsvik Energiteknik AB
S-611 82 Nykoping
SWEDEN

J. Devooght
Service de la Metrologie Nucl
University Libre de Bruxelles
Faculte des Sciees Appliqu.
50 Avenue F-D Roosevelt
Bruxelles 5
BELGIUM

G. Diederick
Commonwealth Edison Co.
LaSalle County Station
RR1, Box 220
2601 North 21st Rd.
Marsielles, IL 61341

Chuck Dobbe
Idaho National Engineering Lab.
EG&G MS: 3840
P.O. Box 1625
Idaho Falls, ID 83415

Mary Drouin
USNRC-RES\SAIB
MS: T-10F13

Duke Power Co. (2)
Attn: Duncan Brewer
Steve Deskevich
422 South Church Street
Charlotte, NC 28242

Bill Eakin
Northeast Utilities
Box 270
Hartford, CT 06141

Stewart D. Ebnetter
USNRC
101 Marietta St., Suite 2900
Atlanta, GA 30323-0199

Adel A. El-Bassioni
USNRC-NRR/PRAB
MS: O-10E4

ENEA/DISP (2)
Attn: Alvaro Valeri
Alfredo Bottino
Via Vitaliano Brancati, 48
00144 Roma EUR
ITALY

Walter P. Engel
PRAG MGR Analysis & Reg Matter
NE-60
CRYCITY
US DOE
Washington, DC 20585

John Flack
USNRC-RES/SAIB
MS: T-10F13

Karl Fleming
Pickard, Lowe & Garrick
2260 University Drive
Newport Beach, CA 92660

Terry Foppe
Safety Analysis Engineering
Rocky Flats Plant
Energy Systems Group
Rockwell International Corp
P.O. Box 464
Golden, CO 80401

R H. Gauger
Manager-Reliability Engr
A/E Div
Holmes & Narver Inc.
R Roanne Circle
Irvine, CA 92714

Robert Gobel
Clark University
Center for Technology, Environment
and Development
950 Main St.
Worcester, MA 01610-1477

Paul Govaerts
Studiecentrum voor Kernenergie
(SCK/CEN)
Boeretang, 200
B-2400 Mol
BELGIUM

Mr. Gubler
International Atomic Energy Agency
NENS/SAD BQ842
Wagramerstrasse 5, P.O. Box 100
A-1140 Vienna
AUSTRIA

Paul M. Haas, President
Concord Associates, Inc.
725 Pellissippi Parkway
Suite 101, Box 6
Knoxville, TN 37933

F. T. Harper
Division 6413
MS: 0748
Sandia National Laboratories
Albuquerque, NM 87185-0748

Dr. U. Hauptmanns
Gesellschaft für Anlagen und
Reaktorsicherheit (GRS) mgH
Schwertnergasse 1
D-5000 Köln 1
GERMANY

Sharif Heger
UNM Chemical and Nuclear
Engineering Department
Farris Engineering, Room 209
Albuquerque, NM 87131

Jon C. Helton
Dept. of Mathematics
Arizona State University
Tempe, AZ 85287

Dr. P. M. Herttrich
Gesellschaft für Anlagen und
Reaktorsicherheit (GRS) mbH
Schwertnergasse 1
5000 Köln 1
GERMANY

Dr. D.J. Higson
Radiological Safety Bureau
Australian Nuclear Science &
Technology Organisation
P.O. Box 153
Roseberry, NSW 2018
AUSTRALIA

Dr. Mitsumasa Hirano
Deputy General Manager
Institute of Nuclear Safety
NUPEC
3-6-2, Toranomon, Minato-ku
Tokyo 108
JAPAN

Dr. S. Hirschberg
Paul Scherrer Institute
Vurenlingen and Villigen
CH-5232 Villigen PSI
SWITZERLAND

Steven Hodge
Oak Ridge National Laboratories
P. O. Box Y
Oak Ridge, TN 37831

Gary Holahan
USNRC-AEOD/OSP
MS: T-4A9

N.J. Holloway
A72.1
Atomic Weapons Establishment
Ademaston
Reading RG7 4PR
UNITED KINGDOM

Griff Holmes
Westinghouse Electric Co.
Energy Center East
Bldg. 371
P.O. Box 355
Pittsburgh, PA 15230

William Hopkins
Bechtel Power Corporation
15740 Shady Grove Road
Gaithersburg, MD 20877

Dean Houston
USNRC-ACRS
MS: P-315

Der-Yu Hsia
Institute of Nuclear Energy Research
Lung-Tan 325
TAIWAN

Alejandro Huerta-Bahena
National Commission on Nuclear
Safety and Safeguards (CNSNS)
Insurgentes Sur N. 1776
C. P. 04230 Mexico, D. F.
MEXICO

Peter Humphreys
US Atomic Energy Authority
Wigshaw Lane, Culcheth
Warrington, Cheshire
UNITED KINGDOM, WA3 4NE

W. Huntington
Commonwealth Edison Co.
LaSalle County Station
RR1, Box 220
2601 North 21st Rd.
Marsielles, IL 61341

J.S. Hyslop
USNRC-RES/PRAB
MS: T-9F31

Idaho National Engineering Lab. (2)
Attn: Doug Brownson
Darrel Knudson
EG&G MS: 3840
P.O. Box 1625
Idaho Falls, ID 83415

Idaho National Engineering Lab. (2)
Attn: Art Rood
Mike Abbott
EG&G MS: 2110
P.O. Box 1625
Idaho Falls, ID 83415

Hanspeter Isaak
Abteilung Strahlenschutz
Hauptabteilung für die Sicherheit
der Kernanlagen (HSK)
CH-5303 Würenlingen
SWITZERLAND

Brian Ives
UNC Nuclear Industries
P. O. Box 490
Richland, WA 99352

Kamiar Jamili
DP-62/FTN
Department of Energy
Washington, D.C. 20585

Robert Jones
USNRC-NRR/DSSA
MS: O-8E1

Edward Jordan
USNRC-AEOD/DO
MS: T-4D18

Dr. H. Kalfsbeek
DG/XII/D/1
Commission of the European
Communities
Rue de la Loi, 200
B-1049 Brussels
BELGIUM

Yoshio Kano
General Mngr. & Sr. Engineer
Systems Analysis Section
O-arai Engineer. Centr, PNC
Higashi-Ibaraki-gun
Ibaraki-Ken, 133-13
JAPAN

William Kastenberg
UCLA
Boelter Hall, Room 5532
Los Angeles, CA 90024

Barry Kaufer
OECD/NEA
"Le Seine St. Germain" 12
Boulevard des Iles
92130 Issy-les-Moulineaux
FRANCE

Paul Kayser
Division de la Radioprotection
Avenue des Archiducs, 1
L-1135 Luxembourg-Belair
LUXEMBOURG

Ken Keith
TVA
W 20 D 201
400 West Surmnit Hill
Knoxville, TN 37092

G. Neale Kelly
Commission of the European
Communities
Joint Research Centre
Rue de la Loi 200
B-1049 Brussels
BELGIUM

John Kelly
Sandia National Laboratories
P. O. Box 5800
MS 0742
Albuquerque, NM 87185

Knolls Atomic Power Laboratory (2)
Attn: Ken McDonough
Dominic Sciaudone
Box 1072
Schenectady, NY 12301

Dr. K. Koberlein
Gesellschaft für
Reaktorsicherheit mbH
Forschungsgelände
D-8046 Garching
GERMANY

Alan Kolaczowski
Science Applications International
Corporation
2109 Air Park Rd. S. E.
Albuquerque, NM 87106

Jim Kolanowski
Commonwealth Edison Co.
35 1st National West
Chicago, IL 60690

John G. Kollas
Institute of Nuclear Technology and
Radiation Protection
N.R.C.P.S. "Demokritos"
P.O. Box 60228
GR-153 10 Aghia Paraskevi
Attiki
GREECE

S. Kondo
Department of Nuclear Engineering
Faculty of Engineering
University of Tokyo
3-1, Hongo 7, Bunkyo-ku
Tokyo
JAPAN

D. Lamy
CEN/SCK
Dept. Scientific Irradiation
Experiment & Study BR2
Boeretang, 200
B-2400 Mol
BELGIUM

Dr. J.M. Lanore
CEA/IPSN/DAS
Centre d'Etudes Nucléaires de
Fontenay-aux-Roses
B.P. n° 6
92265 Fontenay-aux-Roses CEDEX
FRANCE

Jose A. Lantaron
Consejo de Seguridad Nuclear
Sub. Analisis y Evaluaciones
Calle Justo Dorado, 11
28040 Madrid
SPAIN

Josette Larchier-Boulanger
Electricite de France
Direction des Etudes Et Recherches
30, Rue de Conde
75006 Paris
FRANCE

H. Larsen
Head of Department
Riso National Laboratory
P.O. Box 49
DK-4000 Roskilde
DENMARK

Lawrence Livermore Nat'l Lab. (4)
Attn: George Greenly
Marvin Dickerson
Rolf Lange
Sandra Brereton
Livermore, CA 94550

Shengdar Lee
Yankee Atomic Electric Company
580 Main St.
Boston, MA 17407

B.T.F. Liwaang
Dept. of Plant Safety Assessment
Swedish Nuclear Power Inspec.
P.O. Box 27106
S-10252 Stockholm
SWEDEN

Peter Lohnberg
Expresswork International, Inc.
1740 Technology Drive
San Jose, CA 95110

Steven M. Long
USNRC-NRR/SPSB
MS: O-10E4

D. Eugenio Gil Lopez
Consejo de Seguridad Nuclear
Calle Justo Dorado, 11
28040 Madrid
SPAIN

Los Alamos National Laboratory (2)
Attn: Kent Sasser
N-6, K-557
Los Alamos, NM 87545

Christiana H. Lui
USNRC-RES/PRAB
MS: T-9F31

John Luke
Florida Power & Light
P.O. Box 14000
Juno Beach, FL 33408

Daniel Manesse
ISPN
Boite Postale n° 6
92265 Fontenay-aux-Roses CEDEX
FRANCE

Fred Mann
Westinghouse Hanford Co.
WIA-53
P.O. Box 1970
Richland, WA 99352

Nadia Soido Falcao Martins
Comissao Nacional de Energia Nuclear
R General Severiano 90 S/408-1
Rio de Janeiro
BRAZIL

Harry F. Martz
Analysis and Assessment Division
Los Alamos National Laboratory
Los Alamos, NM 87545

Herbert Massin
Commonwealth Edison Co.
35 1st National West
Chicago, IL 60690

Hideo Matsuzuru
Tokai Research Establishment
Tokai-mur
Maka-gun
Ibaraki-ken, 319-11
JAPAN

Jim Mayberry
Ebasco Services
60 Chubb Ave.
Lyndhurst, NJ 07071

Andrew S. McClymont
IT-Delian Corporation
1340 Saratoga-Sunnyvale Rd.
Suite 206
San Jose, CA 95129

Michael McKay
Los Alamos National Laboratory
A-1, MS F600 Services
P.O. Box 1663
Los Alamos, NM 87545

Zen Mendoza
SAIC
5150 El Camino Real
Suite C3 1
Los Altos, CA 94022

Dr. J. Mertens
Division of Risk Analysis &
Reactor Technology
Institute of Safety Research
Research Centre Julich (KFA)
D-52425 Julich
GERMANY

Jim Meyer
Sciencetech
11821 Parklawn Dr.
Suite 100
Rockville, MD 20852

Joe Minarick
Science Applications Int'l Corp.
301 Laboratory Road
P.O. Box 2501
Oak Ridge, TN 37830

Jose I. Calvo Molins, Head
Division of P.S.A. and Human Factors
Consejo de Seguridad Nuclear
Calle Justo Dorado, 11
28040 Madrid
SPAIN

Ken Muramatsu
Risk Analysis Laboratory
Japan Atomic Energy Research
Institute
Tokai-mura, Naka-gun
Ibaraki-ken, 319-11, Tokyo
JAPAN

Joseph A. Murphy
Division of Safety Issue Resolution
U.S. Nuclear Regulatory Commission
MS: T-10E50
Washington, DC 20555

Kenneth G. Murphy, Jr.
US Department of Energy
19901 Germantown Rd.
Germantown, MD 20545

Shankaran Nair
Central Electricity
Generating Board
Berkeley Nuclear Laboratories
Berkeley
Gloucestershire CL13 9PB
UNITED KINGDOM

Ray Ng
NEI
1776 Eye St. N
Suite 300
Washington, DC 20006-2496

G. Niederauer
Los Alamos National Laboratory
P. O. Box 1663
MSK 575
Los Alamos, NM 87545

Oak Ridge National Laboratory (2)
Attn: Steve Fisher
Sherrel Greene
MS-8057
P.O. Box 2009
Oak Ridge, TN 37831

Ken O'Brien
University of Wisconsin
Nuclear Engineering Dept.
153 Engineering Research Blvd.
Madison, WI 53706

Theresa Oh
INEL Tech Library
EG&G MS: 2300
P. O. Box 1625
Idaho Falls, ID 83415-2300

N. R. Ortiz, Director
Nuclear Energy Technology
Division 6400
Sandia National Laboratories
Albuquerque, NM 87185

Robert Ostmeyer
U.S. Department of Energy
Rocky Flats Area Office
P. O. Box 928
Golden, CO 80402

Robert Palla
USNRC-NRR/SPSB
MS: O-10E4

Gareth Parry
NUS Corporation
910 Clopper Rd.
Gaithersburg, MD 20878

Vern Peterson
Building T886B
EG&G Rocky Flats
P.O. Box 464
Golden, CO 80402

G. Petrangeli
ENEA Nuclear Energy ALT Disp
Via V. Brancati, 48
00144 Rome
ITALY

Ing. Jose Antonio Becerra Perez
Comision Nacional De Seguridad
Nuclear Y Salvaguardias
Insurgentes Sur 1806
01030 Mexico, D. F.
MEXICO

William T. Pratt
Brookhaven National Laboratory
Building 130
Upton, NY 11973

Urho Pulkkinen
Technical Research Centre of
Finland
Laboratory of Electrical &
Automation Engineering
Otakaari 7B, 02150 Espoo 15
FINLAND

Blake Putney
Science Applications
International Corporation
5150 El Camino Real, Suite C31
Los Altos, Ca 94022

Dr. V. M. Raina
Project Manager-Risk Assessment
Ontario Hydro H11 G1
700 University Ave.
Toronto, Ontario M5G 1X6
CANADA

William Raisin
NEI
1726 M. St. NW
Suite 904
Washington, DC 20036

Ann Ramey-Smith
USNRC-RES/PRAB
MS: T-9F31

Dale Rasmuson
USNRC-AEOD/TPAB
MS: T-4A9

John Ridgely
USNRC-RES/SAIB
MS: T-10F13

Richard Robinson (2)
USNRC-RES/PRAB
MS: T-9F31

M. Roch
Manager of Design, Nuclear
Department
TRACTEBEL
Avenue Ariane 7
B-1200 Bruxelles
BELGIUM

A.E. Rogers
General Electric Co
175 Curtner Ave
MC-489
San Jose, CA 95125

Judy Rollstin
GRAM Inc
8500 Manual Blvd. NE
Albuquerque, NM 87112

Marc Rothschild
Halliburton NUS
1303 S. Central Ave.
Suite 202
Kent, WA 98032

Christopher Ryder
USNRC-RES/PRAB
MS: T-9F31

Takashi Sato, Deputy Manager
Nuclear Safety Engineering Section
Reactor Design Engineering Dept.
Nuclear Energy Group, Toshiba Corp.
Isogo Engineering Center
8, Shinsugita-cho, Isogo-ku,
Yokohama 235, JAPAN

Martin Sattison
Idaho National Engineering Lab.
P. O. Box 1625
Idaho Falls, ID 83415

Dr. U. Schmocker
Hauptabteilung für die
Sicherheit der Kernanlagen
CH-5232 Villigen HSK
SWITZERLAND

A.J. Seebregts
ECN Nuclear Energy
Westerduinweg, 3
Postbus 1
NL-1755 Petten ZG
THE NETHERLANDS

Dr. S. Serra
Ente Nazionale per l'Energia
Eletttrica (ENEL)
via G.B. Martini 3
I-00198 Rome
ITALY

Stone & Webster Engineering Corp
Technical Information Center
A. Hosford
245 Summer Street
245/01
Boston, MA 02210

H. Shapiro
Licensing & Risk Branch
Atomic Energy of Canada Ltd.
Sheridan Park Research Comm.
Mississauga, Ontario L5K 1B2
CANADA

Dennis Strenge
Pacific Northwest Laboratory
RTO/ 125
P.O. Box 999
Richland, WA 99352

Nathan O. Siu
Center for Reliability and Risk
Assessment
Idaho National Engineering Lab.
EG&G MS: 3850
P.O. Box 1625
Idaho Falls, ID 83415-3855

Technadyne Engineer. Consultants (3)
Attn: David Chanin
Jeffery Foster
Walt Murfin
Suite A225
8500 Manual Blvd. N
Albuquerque, NM 87112

E. Soederman
ES-Konsult AB
Energy and Safety
P.O. Box 3096
S-16103 Bromma
SWEDEN

Ashok Thadani
USNRC-NRR/ADT
MS: O-12G18

T. G. Theofanous
University of California, S. B.
Department of Chemical and Nuclear
Engineering
Santa Barbara, CA 93106

Desmond Stack
Los Alamos National Laboratory
Group Q-6, Mail Stop K556
Los Alamos, NM 87545

Catherine Thompson
USNRC-RES/SAIB
MS: T-10F13

Jao Van de Steen
KEMA Laboratories
Utrechtseweg, 310
Postbus 9035
NL 800 ET Arnhem
THE NETHERLANDS

Soren Thykier-Nielsen
Riso National Laboratory
Postbox 49
DK4000 Roskilde
DENMARK

Eli Stern
Israel AEC Licensing Div.
P.O. Box 7061
Tel-Aviv 61070
ISRAEL

R. Toossi
Physical Research, Inc.
25500 Hawthorn Blvd.
Torrance, CA 90505

Dr. Egil Stokke
Advisory Group
OECD Halden Reactor Project
P.O. Box 173
N-1751 Halden
NORWAY

Ennio Traina
ENEL
Via Vialiano, 48
00144 Rome
ITALY

Ulf Tveten
Environmental Physics Section
Institutt for Energiteknikk
Postboks 40
N-2007 Kjeller
NORWAY

US Department of Energy
Energy Library
Room G 034/GTN
AD-622.1
Washington, DC 20585

US Department of Energy
NS-50 (GTN)
NS-10.1
S-161
Washington, DC 20585

U.S. Environmental
Protection Agency (2)
Attn: Allen Richardson
Joe Logsdon
Office of Radiation Programs
Environmental Analysis Division
Washington, DC 20460

Harold VanderMolen
USNRC-RES/PRAB
MS: T-9F31

Dr. A. Valeri
A.N.P.A.
Via Vitaliano Brancati, 48
I-00144 Rome
ITALY

Magiel F. Versteeg
Ministry of Social Affairs
and Employment
P.O. Box 90804
2509 LV Den Haag
THE NETHERLANDS

Martin Virgilio
USNRC-NRR/DSSA
MS: O-8E2

R. Virolainen, (Chairman PWG5)
Systems Integ. Off. (STUK)
P.O. Box 268
Kumpulante 7
SF-60101 Helsinki
FINLAND

Seppo Vuori
Technical Research Centre of Finland
Nuclear Engineering Laboratory
Lonnrotinkatu 37
P.O. Box 169
SF-00181 Helsinki 18
FINLAND

Dr. Ian B. Wall
81 Irving Avenue
Atherton, CA 94027

Edward Warman
Stone & Webster Engineering Corp.
P.O. Box 2325
Boston, MA 02107

J.E. Werner
Reactor Research & Techn Division
US DOE Idaho Operations
MS: 1219
850 Energy Drive
Idaho Falls, ID 83401-1563

Dr. Wolfgang Werner
Safety Assessment Consulting GmbH
Veilchenweg 8
D 83254 Breitbrunn
GERMANY

Westinghouse Electric Corp
Technical Library
P. O. Box 355
East 209
Pittsburgh, PA 15230

Westinghouse Electric Corp
NTD
Central File Nuclear Safety
P. O. Box 355
408 1-A
Pittsburgh, PA 15230

Westinghouse Electric Company (3)
Attn: John Lacovin
Burt Morris
Griff Holmes
Energy Center East, Bldg. 371
P.O. Box 355
Pittsburgh, PA 15230

Westinghouse Savannah River Co. (2)
Attn: Kevin O'Kula
Jackie East
Safety Technology Section
1991 S. Centennial Ave., Bldg. 1
Aiken, SC 29803

Donnie Whitehead
Department 6412, MS: 0747
Sandia National Laboratories
P.O. Box 5800
Albuquerque, NM 87185-0747

Keith Woodard
PLG, Inc.
7315 Wisconsin Ave.
Suite 620 East
Bethesda, MD 20814-3209

John Wreathall
John Wreathall & Co.
4157 MacDuff Way
Dubin, OH 43017

M. K. Yeung
University of Hong Kong
Mechanical Engineering Dept.
Polfulam
HONG KONG

Bob Youngblood
Brookhaven National Laboratory
Department of Nuclear Energy
Bldg. 130
Upton, NY 11973

Carlo Zaffiro
A.N.P.A.
Directorate for Nuclear
Via Vitaliano Brancate, 48
I-00144 Rome
ITALY

Dr. X. Zikidis
Greek Atomic Energy Comm.
N.R.C.P.S. "Demokritos"
GR-153 10 Agia Paraskevi
Attiki
GREECE

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

1. REPORT NUMBER
(Assigned by NRC. Add Vol., Supp., Rev.,
and Addendum Numbers, if any.)

NUREG/CR-6144
BNL-NUREG-52399
Vol.2, Part 3A

3. DATE REPORT PUBLISHED

MONTH | YEAR

June 1994

4. FIN OR GRANT NUMBER

L1922

2. TITLE AND SUBTITLE

Evaluation of Potential Severe Accidents During Low
Power and Shutdown Operations at Surry, Unit 1:
Analysis of Core Damage Frequency from Internal
Events During Mid-loop Operations-Appendices E
(Sections E.1-E.8)

5. AUTHOR(S)

T.L. Chu, Z. Musicki, P. Kohut, D. Bley¹, J. Yang,
B. Holmes², G. Bozoki, C.J. Hsu, D.J. Diamond, D. Johnson¹,
J. Lin, R.F. Su, V. Dang, D. Ilberg, S.M. Wong, N. Siu³

6. TYPE OF REPORT

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Brookhaven National Laboratory
Upton, NY 11973

¹PLG Inc., 4590 McArthur Blvd. Newport Bch. CA 92660-2027

²AEA Technology, Winfrith, Dorchester, Dorset, England, DT2 8DH

³MIT, Cambridge, MA 02139 (N. Siu currently at EG&G, Idaho Falls,
ID 84315)

⁴Soreq Nuclear Research Center, Yavne 70600, Israel

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Division of Safety Issue Resolution
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

During 1989, the Nuclear Regulatory Commission (NRC) initiated an extensive program to carefully examine the potential risks during low power and shutdown operations. The program includes two parallel projects being performed by Brookhaven National Laboratory (BNL) and Sandia National Laboratories (SNL). Two plants, Surry (pressurized water reactor) and Grand Gulf (boiling water reactor), were selected as the plants to be studied. The objectives of the program are to assess the risks of severe accidents initiated during plant operational states other than full power operation and to compare the estimated core damage frequencies, important accident sequences and other qualitative and quantitative results with those accidents initiated during full power operation as assessed in NUREG-1150. The objective of this report is to document the approach utilized in the Surry plant and discuss the results obtained. A parallel report for the Grand Gulf plant is prepared by SNL. This study shows that the core-damage frequency during mid-loop operation at the Surry plant is comparable to that of power operation. We recognize that there is very large uncertainty in the human error probabilities in this study. This study identified that only a few procedures are available for mitigating accidents that may occur during shutdown. Procedures written specifically for shutdown accidents would be useful.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

Surry-1 Reactor-Reactor Shutdown; Surry-1 Reactor-Risk Assessment;
Surry-2 Reactor-Reactor Shutdown; Surry-2 Reactor-Risk Assessment;
Failure Mode Analysis, Reactor Accidents, Reactor Core Disruption,
Reactor Start-up, RHR Systems, Systems Analysis, Thermodynamics,
Sandia National Laboratories

13. AVAILABILITY STATEMENT

Unlimited

14. SECURITY CLASSIFICATION

(This Page)

Unclassified

(This Report)

Unclassified

15. NUMBER OF PAGES

16. PRICE