

1 of 1

LBL-34243
UC - 1600

**TECHNOLOGY DATA CHARACTERIZING LIGHTING IN COMMERCIAL
BUILDINGS: APPLICATION TO END-USE FORECASTING WITH COMMEND 4.0**

A. Osman Sezgen, Y. Joe Huang, Barbara A. Atkinson, Joe H. Eto and Jonathan G. Koomey

Energy Analysis Program
Energy and Environment Division
Lawrence Berkeley Laboratory
University of California
Berkeley, CA 94720

May 1994

This work was supported by the Assistant Secretary for Energy Efficiency and Renewable Energy, Office of Planning and Analysis and Office of Building Technologies, and the Office of Environmental Analysis, Office of Policy, Planning, and Analysis of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098.

MASTER

rb

Technology Data Characterizing Lighting in Commercial Buildings: Application to End-Use Forecasting with COMMEND 4.0

Abstract

End-use forecasting models typically utilize technology tradeoff curves to represent technology options available to consumers. A tradeoff curve, in general terms, is a functional form which relates efficiency to capital cost. Each end-use is modeled by a single tradeoff curve. This type of representation is satisfactory in the analysis of many policy options. On the other hand, for policies addressing individual technology options or groups of technology options, because individual technology options are accessible to the analyst, representation in such reduced form is not satisfactory.

To address this and other analysis needs, the Electric Power Research Institute (EPRI) has enhanced its Commercial End-Use Planning System (COMMEND) to allow modeling of specific lighting and space conditioning (HVAC) technology options. The EPRI contractor for this effort, Regional Economic Research, Inc. (RER), worked with Lawrence Berkeley Laboratory (LBL) in the development and testing of the technology modules contained in COMMEND 4.0. LBL is also providing assistance in the development and refinement of technology data for the model.

This report characterizes the present commercial floorstock in terms of lighting technologies and develops cost-efficiency data for these lighting technologies. The report also characterizes the present lighting utilization patterns and lighting level requirements. Much of the data presented in this report were developed for the Analysis of Federal Policy Options for Improving U.S. Lighting Energy Efficiency, a study performed by LBL for the U.S. Department of Energy. This report organizes the data from the above-mentioned study in a form usable by a forecasting analyst.

This report also characterizes the interactions between the lighting and space conditioning end uses in commercial buildings in the U.S. In general, lighting energy reductions increase the heating and decrease the cooling requirements. The net change in a building's energy requirements, however, depends on the building characteristics, operating conditions, and the climate. Lighting/HVAC interactions data were generated through computer simulations using the DOE-2 building energy analysis program. Ten building types of two vintages and ten climates were used to represent the U.S. commercial building stock for this purpose.

Acknowledgments

This report on commercial sector lighting is the first in a series summarizing technology data for various commercial end-uses in the United States. A companion report describes technology data for HVAC end-uses in office buildings. Reports due later in 1994 will characterize HVAC, water heating, office equipment, and refrigeration in all building types.

We would like to thank the analysts who reviewed this report, including Mohammad Adra of the Energy Information Administration in the U.S. Department of Energy, Ingrid Rohmund of Regional Economic Research, Inc., and James McMahon and Ellen Franconi of Lawrence Berkeley Laboratory.

The work was funded by David Patton of the Office of Planning and Assessment, Dick Jones of the Office of Building Technologies, and Ted Williams and John Conti of the Office of Policy, Planning, and Analysis in the U.S. Department of Energy. We are grateful for their support and insights.

This work was supported by the Assistant Secretary for Energy Efficiency and Renewable Energy, Office of Planning and Analysis and Office of Building Technologies, and the Office of Environmental Analysis, Office of Policy, Planning, and Analysis of the U.S. Department of Energy under Contract No. DE-AC03-76SF00098.

Table of Contents

Introduction	1
COMMEND Structure	1
Description and Development of Data	2
Equipment Definitions	2
Service and Electricity Demand	6
Service Demand-- Operating Hours and Lighting Levels	6
Room Factors	7
EUI vs. Operating Hours	7
Lighting Systems	9
Cost/Efficiency Data for Lighting Systems	9
Saturation Data for Lighting Systems	24
Luminaire Data	33
Controls Data	36
Lighting/HVAC Interactions	40
Conclusions	51
References	52

List of Tables

Table 1. Systems with Fluorescent Fixture Types	4
Table 2. Systems with Fixture Types other than Fluorescent	5
Table 3. Effective Lighting Hours (Annual) and Lighting Levels by Building Type	8
Table 4.a. Characteristics of 4-Foot Lamps with Energy-Efficient Magnetic Ballast	11
Table 4.b. Characteristics of 4-Foot Fluorescent Lamps with Cathode-Cutout Ballast	12
Table 4.c. Characteristics of 4-Foot Fluorescent Lamps with Electronic Ballast	
Table 4.d. Characteristics of 8-Foot Fluorescent Lamps with Energy-Efficient Magnetic Ballast	14
Table 4.e. Characteristic of 8-Foot Fluorescent High-Output Lamps with Energy-Efficient Magnetic Ballast	15
Table 4.f. Characteristics of 8-Foot Fluorescent Lamps with Electronic Ballast	
Table 4.g. Characteristics of 8-Foot Fluorescent High-Output Lamps with Electronic Ballast	17
Table 5.a. Characteristics of General Service Incandescent Lamps	18
Table 5.b. Characteristics of Reflector Type Incandescent Lamps	19
Table 5.c. Characteristics of Compact Fluorescent Lamps	20
Table 6.a HID Lamps - 100W Mercury Vapor Lamps and Replacements	21
Table 6.b HID Lamps - 400W Mercury Vapor Lamps and Replacements	22
Table 6.c HID Lamps - 1000W Mercury Vapor Lamps and Replacements	23
Table 7. Lighting Power Density by Building Type	26
Table 8. Fixture Shares of Delivered Lumens	27
Table 9. Fluorescent System Shares--1986 Stock	29
Table 10. Fluorescent System Shares--1986 New Construction	30
Table 11. Fluorescent System Shares--1995 Stock	31
Table 12. Standard Fixture Shares of Floor Area--Stock/New Construction	32
Table 13. Luminaire Efficiencies	34

Table 14.a. Fluorescent Fixture Saturation as a Percentage of Number of Lamps per Fixture (1986)	35
Table 14.b. Fluorescent Fixture Saturation as a Percentage of Number of Lamps per Fixture (1995)	35
Table 15. Impacts, Costs and Applicability of Controls	38
Table 16.a. Heating and Cooling Coincidence Factors for Fast-Foods Restaurant	42
Table 16.b. Heating and Cooling Coincidence Factors for Hospital	42
Table 16.c. Heating and Cooling Coincidence Factors for Large Hotel	43
Table 16.d. Heating and Cooling Coincidence Factors for Large Office	43
Table 16.e. Heating and Cooling Coincidence Factors for Large Retail	44
Table 16.f. Heating and Cooling Coincidence Factors for Medium Office	44
Table 16.g. Heating and Cooling Coincidence Factors for Small Hotel/Motel	
Table 16.h. Heating and Cooling Coincidence Factors for Sit-Down Restaurant	
Table 16.i. Heating and Cooling Coincidence Factors for Supermarket	46
Table 16.j. Heating and Cooling Coincidence Factors for Secondary School	46

List of Figures

Figure 1. Heating and Cooling Coincidence Factors for Lighting.....	47
---	----

INTRODUCTION

Lighting represents over 20% of all energy delivered to commercial buildings, and about 40% of commercial buildings' electricity consumption. Because of this large share in energy consumption, as well as the availability and emergence of efficient lighting technologies, the lighting end use is a major area of attention for energy policy and utility Demand Side Management (DSM) programs.

End-use forecasting models used by utilities and government agencies provide forecasts of energy consumption by fuel type, end use and building type. Energy-efficiency policy analysis and Demand Side Management (DSM) planning, which address specific energy technologies, required the development of new policy analysis tools. Based on these needs, the Electric Power Research Institute has expanded its Commercial End-Use Planning System, COMMEND, to include detailed technology representations of lighting and HVAC.¹ These detailed technology modules, available in COMMEND 4.0, replaced the generic technology trade-off curves available in previous versions (COMMEND 3.2). LBL assisted in the development of the technology-analysis framework and continues to provide assistance in the development and refinement of technology data for the model.

This report covers all of the building types for the lighting end use and also attempts to characterize the secondary effects of reduction in lighting energy use on HVAC consumption in these building types under different climate conditions. A similar report is available for the HVAC end uses [1]. The HVAC report covers only office buildings at this point, but work is in progress for the other commercial building types.

COMMEND STRUCTURE²

In COMMEND 3.2 and earlier versions of the model, the lighting end use was represented by a single technology tradeoff curve. In COMMEND 4.0, this end-use level of modeling remains available. However, a more detailed option is also available that allows modeling of specific lighting technologies.

The main features of the detailed interior lighting model are as follows:

Lighting Systems. The model deals directly with an enumerated list of specific lighting systems. These systems are defined as specific combinations of lamps, ballasts and fixture types.

Lighting Terminology. In place of general end-use concepts, such as utilization indices, an expanded set of lighting terms are used in the model. Illuminance, or lighting level, is computed in footcandles. *Source lumens* represent the amount of

¹ Heating, ventilation and air conditioning

² Adapted from COMMEND 4.0 User's Guide, Appendix F [2].

light given off by lamps alone. *Fixture efficiency* and *room factors* are fractions that convert source lumens to delivered lumens at the work plane. *System efficacy* defines the amount of light supplied in lumens per Watt of electricity input. Usage is measured directly in hours of use.

Lighting Shares. Lighting systems (lamp/ballast/fixture combinations) are grouped into fixture types. This grouping has advantages for modeling retrofits during the forecast years. Shares are defined for the fixture types and for the systems within each fixture type. Shares give the fraction of lighting capacity that is provided by that system. This system capacity is expressed in delivered lumens per square foot (footcandles), which is a measure of delivered light output, adjusted for lamp/ballast efficiency, fixture efficiency, and room factors.

Decision Models. System shares are computed using a set of decision models. The new construction model gives system shares in new buildings. The lamp replacement model allows lamp changes at the time of lamp decay. The ballast replacement model allows changes in ballast efficiency at the time of ballast decay. The system conversion model allows changes in lamp, ballast, and fixture efficiency, as well as conversion from one light source to another.

DESCRIPTION AND DEVELOPMENT OF DATA

This report characterizes the present floorstock in terms of lighting technologies and develops cost-efficiency data for these lighting technologies. The report also characterizes the present lighting utilization patterns and lighting level requirements. Lighting/HVAC interactions are also a part of this report. Parameters related to the decision algorithms and characterization of future trends are not a concern of this report. Such parameters are best developed using utility DSM survey data.

Most of the data presented in this report were developed as part of the Lighting Policy Analysis (LPA) [3] at LBL. This report compiles the technology data and presents them in a fashion usable by a forecasting analyst. However, the characterization of lighting/HVAC interactions has been improved and expanded subsequent to the publication of the LPA report.

EQUIPMENT DEFINITIONS

Lighting systems are defined to be combinations of lamps and ballasts for a given fixture type. The fixture types considered in the data development are: 4-foot fluorescent fixtures, 8-foot fluorescent fixtures, standard (screw-in) fixtures and high-intensity discharge (HID) fixtures. Systems covered in this report either have significant market share or are promising in terms of future utilization. Table 1 shows the system types in the category of fluorescent fixtures, and Table 2 shows system types in the categories of standard (screw-in) and HID fixtures. There are a few system types that have not been

included in the data set. The most important of these are systems utilizing U-lamps and T10 lamps. Market saturation data are developed for the set of technologies shown in Tables 1 and 2. Cost efficiency data are presented for a broader range of system types.

The properties of the luminaire and controls associated with the lighting system are necessary to complete the characterization of the lighting end-use. Luminaires--sometimes referred to as fixtures--for the fluorescent fixture types considered are (1) lensed troffer, (2) wraparound and (3) parabolic luminaires. Saturation and efficiency data are developed for these three types of fluorescent luminaires. Luminaires considered for the HID fixture type are: (1) round, (2) square, and (3) indirect. Luminaires for the standard fixture type are not enumerated and only average efficiencies are presented for these. In previous work [3], control types considered for conservation analysis were: (1) programmable timers, (2) timers and lumen maintenance, (3) occupancy sensors, and (4) daylighting controls. Energy management systems vary in terms of size and costs, and they mostly perform the above functions. Therefore, they were not explicitly addressed.

Table 1. Systems with Fluorescent Fixture Types

Fixture Type	Ballast	Lamp
4-Foot Fluorescent		
	Standard Ballast	Standard F40 T12 Reduced Wattage 34WT12
	Energy Efficient Magnetic Ballast	Standard F40 T12 Reduced Wattage 34WT12 T-8
	Cathode Cutout Ballast	Standard F40 T12 Reduced Wattage 34WT12 T-8
	Electronic Ballast	Standard F40 T12 Reduced Wattage 34WT12 T-8
8-Foot Fluorescent		
<i>Slimline Lamps</i>		
	Standard Ballast	Standard F96 Reduced Wattage F96
	Energy Efficient Magnetic Ballast	Standard F96 Reduced Wattage F96
	Electronic Ballast	Standard F96 Reduced Wattage F96
<i>High Output Lamps</i>		
	Standard Ballast	Standard F96 Reduced Wattage F96
	Energy Efficient Magnetic Ballast	Standard F96 Reduced Wattage F96
	Electronic Ballast	Standard F96 Reduced Wattage F96

Table 2. Systems with Fixtures Types other than Fluorescent

Fixture Type	Lamp
Standard Base	
<i>General Service, Incandescent</i>	> 150 W 15-150 W Standard Wattage Reduced Wattage Halogen
<i>Reflector, Incandescent</i>	Standard Par Standard R Reduced Wattage (Par/R) Halogen Halogen Infrared (HIR)
<i>Compact Fluorescent</i>	Compact Fluorescent
High Intensity Discharge (HID)	Mercury Vapor High-Pressure Sodium Metal Halide

SERVICE AND ELECTRICITY DEMAND

Service demand is lighting requirements in terms of lighting levels and lighting schedules; and is independent of the lighting technologies utilized. Within the COMMEND 4 framework, operating hours and delivered lighting levels determine the level of service demand. Electricity demand is a function of the service demand, together with other factors like (1) properties and geometry of the space being lit, (2) efficiency of the luminaire used, and (3) efficacy of the lamp/ballast combination.

Service Demand--Operating Hours and Lighting Levels

Data for lighting operating hours come from CBECS [4] NBECS [5], and the DOE/EIA "Lighting in Commercial Buildings" report [6]. The distinction between building operating hours and lighting operating hours should be made. As an example, DOE/EIA [6] indicates that large office buildings may be operating for 2932 hours annually, where the lighting equipment for the same building type is operated for 3603 effective lighting hours. Effective lighting hours are specified as

$$\text{Effective lighting hours} = \text{operating hours} + \\ (\text{space lit during non-op. hours}/\text{space lit during op. hours}) * \text{non-operating hours.}$$

Table 3 shows annual lighting operating hours by building type. Fluorescent and incandescent operating hours were developed based on communication with EIA.³

The distinction between source lumen and delivered lumen requirements should be made. Delivered lumens are measured at the work plane and are independent of the lighting technology used and the characteristics of the room. Level of delivered lumens is obtained as a product of source lumens, luminaire efficiency (fixture efficiency) and the room factor. COMMEND requires levels of delivered lumens by building type. Illuminance-delivered can be estimated using IES Lighting Handbook [7] which gives three levels of recommended lighting intensities for categories of activities. For a given building type, the lighting level has to be developed as the weighted average of these intensities based on the distribution of different activities over the floorstock. EIA has used the higher end of this data to develop average source lumen intensities for CBECS building types [6]. Table 3 shows illuminance requirements by building type derived from the data given in the EIA lighting study [6]. These data have to be multiplied by average luminaire efficiencies and room factors before they can be input to COMMEND.

The building type definitions are not identical in COMMEND and CBECS [4]/EIA [6]. The mapping used in developing data on operating hours and lighting levels by building

³ Energy Information Administration, U.S. Department of Energy, Washington, D.C.

type is as follows:⁴

- 5% of Assembly floor area (from CBECS) goes to Colleges (in COMMEND),
- 95% of Assembly floor area (from CBECS) goes to Miscellaneous (in COMMEND),
- 73% of Education floor area (from CBECS) goes to Schools (in COMMEND), and
- 27% of Education floor area (from CBECS) goes to Colleges (in COMMEND).

Room Factors

The Room Factor models losses due to factors other than the luminaire, like the room geometry, room surface reflectances, furniture, etc. In the lighting industry, Coefficient of Utilization (CU) is used to quantify the combined effect of luminaire (fixture) efficiency together with room properties. For each luminaire, manufacturers catalogues provide the CU under various conditions of room geometry and surface properties. Within the COMMEND framework, the effects of the room properties are separated from the luminaire efficiency mainly because the room specifications are independent of the technology that is used to illuminate the space. Luminaire efficiency represents light output from the luminaire before room factor losses. The product of the room factor for a building type and the average luminaire efficiency for a specific lighting systems utilized in that building type should give the average CU (e.i weighted average of the CUs for the luminaires used for the specific lighting system, under average conditions for that building type). For commercial buildings, room factors are generally close to 0.6.

EUI vs. Operating Hours

In its present state, COMMEND 4 does not utilize the operating hours presented in the input data set. Instead, the Energy Utilization Index (EUI) developed for the lighting end-use determines the level of consumption. Lighting operating hours are part of the output of the program. The operating hours output by the program should be compared to the intended operating hours and model inputs must be corrected to reconcile the two sets. A difference between the two set of operating hours may be an indication of wrong lighting levels and/or market shares of technologies in the input file.

⁴ Pacific Northwest Laboratories (PNL). Personal communication, Dave Belzer. 1991.

Table 3. Effective Lighting Hours (Annual) and Lighting Levels by Building Type

COMMEND Building Type	Fluo. Hours(2)	Incand. Hours(2)	HID Hours(2)	Source-Lumen Level (1) (lumens/sqft)
small office	3624	3365	3583	91
large office	3624	3365	3583	91
restaurant	4957	5361	7223	20
retail	4064	3867	4883	50
grocery	6019	5477	8601	50
warehouse	3739	3465	4711	18
school	2462	3337	2943	100
college	3249	3186	3174	93
health	7955	8086	8694	186
lodging	8572	8331	8502	50
miscellaneous	4005	3062	5404	64

(1) Source: EIA 1992 [6].

(2) Source: Communication with EIA--based on unpublished information supporting [6].

LIGHTING SYSTEMS

Cost/Efficiency Data for Lighting Systems

Data presented include service lifetimes, equipment prices and labor costs for lamps and ballasts; and efficacies and watts for lamp/ballast combinations. Tables 4a-g present data for fluorescent lamps and their associated ballasts. The first three of these tables are for 4-foot lamps; operated with energy-efficient magnetic, cathode cutout and electronic ballasts, respectively. Tables 4d-g give data for 8-foot and 8-foot-high-output lamps operated with magnetic and electronic ballasts. Tables 5a-c give data for lamps associated with standard (screw-in) systems for general service, reflector type incandescent lamps and compact fluorescent, respectively. Table 6a-c gives the efficient replacements for 100W, 400W, and 1000W Mercury Vapor Lamps, respectively, within the HID fixture type.

Many of the energy-efficient lamp technologies considered in this report are relatively new to the marketplace. In order to arrive at prices that are representative of the price a typical large commercial purchaser would pay for energy-efficient lamps and ballasts, prices have been collected from a wide variety of sources. These sources include wholesalers, manufacturers, distributors, local outlets, and sources of lighting design and analysis software. There is no single accepted consensus on prices for these products. Nevertheless, input from all of the above sources contributes to the development of the prices given in this section. The LPA report [3] gives the methodology for developing prices presented in this report from the above-mentioned sources [3]. Both equipment price data and labor rates are 1992 prices in 1990 dollars.

Service lifetimes of lamps and ballast are presented in years instead of hours of use for the convenience of the reader. Each table indicates the annual operating hours used for that table. Since operating hours vary by building type, the service lifetime figures should be used with caution. COMMEND input requires lifetimes in hours of operation.

The lamp/ballast efficacy and watts are corrected for ballast factor and also for thermal interactions. The correction for thermal interactions is applied only on 4-foot fluorescent technologies based on saturation of different luminaire types over the stock of 4-foot lamps. It is assumed that thermal interactions in 8-foot fixtures are negligible because of the high saturation of open fixtures.

The most popular high-efficiency fluorescent lamp/ballast combination on the market is the T8 lamp with electronic ballast. The standard-wattage fluorescent lamps in all categories will become obsolete under the standards of the Energy Policy Act of 1992 (EPAct) in late 1995.

For incandescent reflector lamps, the standard- and reduced-wattage lamps will become obsolete at the same time under EPAct. The halogen PAR lamp and the halogen infrared PAR will become the efficient substitutes. The EPAct does not impose standards on incandescent general service lamps. In this family, the halogen lamp may become more popular if its price drops. Lamp companies may introduce a halogen IR lamp. Research on various filament applications may result in even higher efficacies.

Compact fluorescent lamps are moving towards models with electronic ballasts. Dimmable ballasts allow their use in more applications.

The high intensity discharge (HID) lamp market is moving away from mercury vapor to the more efficient metal halide and high pressure sodium. Lower wattage versions with better color rendering will allow wider application of these sources.

Table 4a. Characteristics of 4-Foot Fluorescent Lamps with Energy-Efficient Magnetic Ballast
 (2 lamps, 1 ballast per fixture)

No.	Technology Option	Ballast	Ballast	ANSI	Rated	Fixture	Efficacy(4)			
		Labor	Service							
				Cost (1)	Price	Life (2)	Watts	Lumens	Watts (3)	(lum/watt)
0*	Baseline (F40CW T12, 40 W cool white)	24.93	13.61	88.0	3,050	12.00	78.9	69.6		
1*	F40CW/WM (34W, reduced wattage)	24.93	13.61	72.0	2,650	12.00	73.7	60.4		
2	F40SP41/WM (34W, RE 70)	24.93	13.61	72.0	2,800	12.00	73.7	63.8		
3	F40AXT10 (1 1/4" dia)	24.93	13.61	92.0	3,700	12.00	82.9	80.3		
4*	F32T8 (1" dia, triphosphor)	24.93	13.88	70.0	2,900	12.00	64.0	82.5		
5	F40SP41 (40W, RE 70)	24.93	13.61	88.0	3,200	12.00	78.9	73.0		
6	F40SP41/WMP (cathode cutout lamp, RE 70)	24.93	13.61	64.4	2,650	12.00	62.0	76.9		
7	F40SPX41 (40W, RE 80)	24.93	13.61	88.0	3,250	12.00	78.9	74.1		
8	F40CW/WMP (cathode cutout lamp)	24.93	13.61	64.3	2,525	12.00	62.0	73.3		
9	F40SPX41/WM (34W, RE 80)	24.93	13.61	72.0	2,850	12.00	73.7	65.0		

Lamp Replacement Cost:

No.	Technology Option	Lamp	Lamp	Lamp
		Labor	Cost (1)	Service
0*	Baseline (F40CW T12, 40 W cool white)	8.54	2.24	3.41
1*	F40CW/WM (34W, reduced wattage)	8.54	3.12	3.41
2	F40SP41/WM (34W, RE 70)	8.54	6.08	3.41
3	F40AXT10 (1 1/4" dia)	8.54	11.20	4.09
4*	F32T8 (1" dia, triphosphor)	8.54	4.90	3.66
5	F40SP41 (40W, RE 70)	8.54	5.78	3.41
6	F40SP41/WMP (cathode cutout lamp, RE 70)	8.54	7.36	3.41
7	F40SPX41 (40W, RE 80)	8.54	11.78	3.41
8	F40CW/WMP (cathode cutout lamp)	8.54	4.76	3.41
9	F40SPX41/WM (34W, RE 80)	8.54	12.28	3.41

* Appears in Table 1.

(1) Labor Rates (\$1990 per hour) = \$25.63 (electrician helper), \$36.69 (electrician)--it is assumed that the time for lamp replacement is charged at electrician helper rate, and the time for ballast replacement is evenly split between the electrician and helper.

(2) Calculated using annual lighting hours of 4,103.

(3) Corrected for fixture interactions.

(4) Corrected for fixture interactions and ballast factor

Table 4b. Characteristics of 4-Foot Fluorescent Lamps with Cathode-Cutout Ballast
 (2 lamps, 1 ballast per fixture)

No.	Technology Option	Ballast	Ballast	Rated	Fixture	Efficacy(4)	
		Labor	Ballast				
		Cost (1) (\$1990)	Price (\$1990)	Life (2) (years)	ANSI	Lumens	Watts (3)
0*	Baseline (F40CW T12, 40W cool white)	26.52	18.52	12.00	80.0	3,050	71.5
1	F40AXT10 (1 1/4" dia)	26.52	18.52	12.00	88.0	3,700	75.5
2	F40SPX41/WM (34W, RE 80)	26.52	18.52	12.00	66.0	2,850	67.5
3	F40SP41/WM (34W, RE 70)	26.52	18.52	12.00	66.0	2,800	67.5
4*	F40CW/WM (34W, reduced wattage)	26.52	18.52	12.00	66.0	2,650	67.5
5	F40SP41 (40W, RE 70)	26.52	18.52	12.00	80.0	3,200	71.5
6*	F32T8 (1" dia, triphosphor)	26.52	18.52	12.00	62.0	2,900	65.1
7	F40SPX41 (40W, RE 80)	26.52	18.52	12.00	80.0	3,250	71.5

Lamp Replacement Cost:

No.	Technology Option	Lamp	Lamp	Lamp Service
		Labor	Lamp	
		Cost (1) (\$1990)	Price (\$1990)	Life (2) (years)
0*	Baseline (F40CW T12, 40W cool white)	8.54	2.24	3.41
1	F40AXT10 (1 1/4" dia)	8.54	11.20	4.09
2	F40SPX41/WM (34W, RE 80)	8.54	12.28	3.41
3	F40SP41/WM (34W, RE 70)	8.54	6.08	3.41
4*	F40CW/WM (34W, reduced wattage)	8.54	3.12	3.41
5	F40SP41 (40W, RE 70)	8.54	5.78	3.41
6*	F32T8 (1" dia, triphosphor)	8.54	4.90	3.66
7	F40SPX41 (40W, RE 80)	8.54	11.78	3.41

* Appears in Table 1.

(1) Labor Rates (\$1990 per hour) = \$25.63 (electrician helper), \$36.69 (electrician)--it is assumed that the time for lamp replacement is charged at electrician helper rate, and the time for ballast replacement is evenly split between the electrician and helper.

(2) Calculated using annual lighting hours of 4,103.

(3) Corrected for fixture interactions.

(4) Corrected for fixture interactions and ballast factor

Table 4c. Characteristics of 4-Foot Fluorescent Lamps with Electronic Ballast
 (2 lamps, 1 ballast per fixture)

No.	Technology Option	Ballast	Ballast	ANSI	Rated	Fixture	Efficacy(4)		
		Labor	Service						
				Cost (1)	Price	Life (2)	Watts	Lumens	Watts(3)
						(years)		(lum/lamp)	
0*	Baseline (F40CW T12, 40W cool white)	26.52	22.56	12.00	72.0	3,050	66.2	78.3	
1	F40AXT10 (1 1/4" dia)	26.52	22.56	12.00	83.0	3,700	70.2	89.6	
2	F32T8 (1" dia, triphosphor) w/Rapid Start	26.52	21.76	12.00	62.0	2,900	55.9	88.2	
3	F40SP41 (40W, RE 70)	26.52	22.56	12.00	72.0	3,200	66.2	82.2	
4	F40SPX41 (40W, RE 80)	26.52	22.56	12.00	72.0	3,250	66.2	83.5	
5*	F32T8 (1" dia, triphosphor) w/Instant Start	26.52	25.44	12.00	63.0	2,900	52.7	101.3	
6	F40SPX41/WM (34W, RE 80)	26.52	22.56	12.00	60.0	2,850	60.1	78.7	
7	F40SP41/WM (34W, RE 70)	26.52	22.56	12.00	60.0	2,800	60.1	77.3	
8*	F40CW/WM (34W, reduced wattage)	26.52	22.56	12.00	60.0	2,650	60.1	73.2	

1

Lamp Replacement Cost:

No.	Technology Option	Lamp	Lamp	Lamp
		Labor	Cost (1)	Service
0*	Baseline (F40CW T12, 40W cool white)	8.54	2.24	3.41
1	F40AXT10 (1 1/4" dia)	8.54	11.20	4.09
2	F32T8 (1" dia, triphosphor) w/Rapid Start	8.54	4.90	3.66
3	F40SP41 (40W, RE 70)	8.54	5.78	3.41
4	F40SPX41 (40W, RE 80)	8.54	11.78	3.41
5*	F32T8 (1" dia, triphosphor) w/Instant Start	8.54	4.90	2.74
6	F40SPX41/WM (34W, RE 80)	8.54	12.28	3.41
7	F40SP41/WM (34W, RE 70)	8.54	6.08	3.41
8*	F40CW/WM (34W, reduced wattage)	8.54	3.12	3.41

* Appears in Table 1.

(1) Labor Rates (\$1990 per hour) = \$25.63 (electrician helper), \$36.69 (electrician)--it is assumed that the time for lamp replacement is charged at electrician helper rate, and the time for ballast replacement is evenly split between the electrician and helper.

(2) Calculated using annual lighting hours of 4,103.

(3) Corrected for fixture interactions.

(4) Corrected for fixture interactions and ballast factor.

Table 4d. Characteristics of 8-Foot Fluorescent Lamps with Energy-Efficient Magnetic Ballast
 (2 lamps, 1 ballast per fixture)

No.	Technology Option	Ballast	Ballast	ANSI	Rated	Efficacy(3)
		Labor Cost (1) (\$1990)	Ballast Price (\$1990)			
0*	Baseline (F96CW T12, 75 W cool white)	31.16	21.50	12.00	158.0	6,150 70.1
1*	F96T12/CW/WM (60W, reduced wattage)	31.16	21.50	12.00	136.0	5,500 72.8
2	F96T12/SPX41/WM (60W, RE 80)	31.16	21.50	12.00	136.0	5,900 78.1
3	F96T12/SP41/WM (60W, RE 70)	31.16	21.50	12.00	136.0	5,750 76.1
4	F96T12/SP41 (75W, RE 70)	31.16	21.50	12.00	158.0	6,425 73.2
5	F96T12/SPX41 (75W, RE 80)	31.16	21.50	12.00	158.0	6,550 74.6

Lamp Replacement Cost:

No.	Technology Option	Lamp	Lamp	Service Life (2) (years)
		Labor Cost (1) (\$1990)	Lamp Price (\$1990)	
0*	Baseline (F96CW T12, 75 W cool white)	6.19	5.20	2.05
1*	F96T12/CW/WM (60W, reduced wattage)	6.19	6.54	2.05
2	F96T12/SPX41/WM (60W, RE 80)	6.19	23.32	2.05
3	F96T12/SP41/WM (60W, RE 70)	6.19	13.32	2.05
4	F96T12/SP41 (75W, RE 70)	6.19	13.74	2.05
5	F96T12/SPX41 (75W, RE 80)	6.19	22.46	2.05

* Appears in Table 1.

(1) Labor Rates (\$1990 per hour) = \$25.63 (electrician helper), \$36.69 (electrician)--it is assumed that the time for lamp replacement is charged at electrician helper rate, and the time for ballast replacement is evenly split between the electrician and helper.

(2) Calculated using annual lighting hours of 4,103.

(3) Corrected for ballast factor.

Table 4e. Characteristics of 8-Foot Fluorescent High-Output Lamps with Energy-Efficient Magnetic Ballast
 (2 lamps, 1 ballast per fixture)

No.	Technology Option	Ballast	Ballast	Rated	Lumens	Efficacy(3)
		Labor	Ballast			
		Cost (1) (\$1990)	Price (\$1990)	Service	ANSI	(lum/lamp)
0*	Baseline (F96T12/CW/HO, 110 W cool white)	31.16	36.12	12.00	237.0	8,900 67.6
1	F96T12/SP41/HO/WM (95W, RE 70)	31.16	36.12	12.00	209.0	8,350 71.9
2	F96T12/SP41/HO (110W, RE 70)	31.16	36.12	12.00	237.0	9,200 69.9
3*	F96T12/CW/HO/WM (95W reduced wattage)	31.16	36.12	12.00	209.0	8,000 68.9

Lamp Replacement Cost:

No.	Technology Option	Lamp	Lamp	Service	Life (2) (years)
		Labor	Lamp		
		Cost (1) (\$1990)	Price (\$1990)	Life (2) (years)	
0*	Baseline (F96T12/CW/HO, 110 W cool white)	6.62	7.04	2.05	
1	F96T12/SP41/HO/WM (95W, RE 70)	6.62	15.00	2.05	
2	F96T12/SP41/HO (110W, RE 70)	6.62	14.72	2.05	
3*	F96T12/CW/HO/WM (95W reduced wattage)	6.62	9.00	2.05	

* Appears in Table 1.

(1) Labor Rates (\$1990 per hour) = \$25.63 (electrician helper), \$36.69 (electrician)--it is assumed that the time for lamp replacement is charged at electrician helper rate, and the time for ballast replacement is evenly split between the electrician and helper.

(2) Calculated using annual lighting hours of 4,103.

(3) Corrected for ballast factor.

Table 4f. Characteristics of 8-Foot Fluorescent Lamps with Electronic Ballast
 (2 lamps, 1 ballast per fixture)

No.	Technology Option	Ballast	Ballast	ANSI	Rated	
		Labor Cost (1) (\$1990)	Ballast Price (\$1990)			
0*	Baseline (F96CW T12, 75 W cool white)	31.16	29.20	12.00	132.0	6,150 83.9
1*	F96T12/WM (60W, reduced wattage)	31.16	29.20	12.00	110.0	5,500 90.0
2	F96T12/SP41/WM (60W, RE 70)	31.16	29.20	12.00	110.0	5,750 94.1
3	F96T12/SPX41/WM (60W, RE 80)	31.16	29.20	12.00	110.0	5,900 96.5
4	F96T12/SP41 (75W, RE 70)	31.16	29.20	12.00	132.0	6,425 87.6
5	F96T12/SPX41 (75W, RE 80)	31.16	29.20	12.00	132.0	6,550 89.3
6	F096T8/41K	31.16	37.50	12.00	105.0	5,800 93.9

Lamp Replacement Cost:

No.	Technology Option	Lamp	Lamp
		Labor Cost (1) (\$1990)	Lamp Price (\$1990)
0*	Baseline (F96CW T12, 75 W cool white)	6.19	5.20 2.05
1*	F96T12/WM (60W, reduced wattage)	6.19	6.54 2.05
2	F96T12/SP41/WM (60W, RE 70)	6.19	13.32 2.05
3	F96T12/SPX41/WM (60W, RE 80)	6.19	23.32 2.05
4	F96T12/SP41 (75W, RE 70)	6.19	13.74 2.05
5	F96T12/SPX41 (75W, RE 80)	6.19	22.46 2.05
6	F096T8/41K	6.19	17.00 2.56

* Appears in Table 1.

(1) Labor Rates (\$1990 per hour) = \$25.63 (electrician helper), \$36.69 (electrician)--it is assumed that the time for lamp replacement is charged at electrician helper rate, and the time for ballast replacement is evenly split between the electrician and helper.

(2) Calculated using annual lighting hours of 4,103.

(3) Corrected for ballast factor.

Table 4g. Characteristics of 8-Foot Fluorescent High-Output Lamps with Electronic Ballast
 (2 lamps, 1 ballast per fixture)

No.	Technology Option	Ballast	Ballast	Ballast	Rated	
		Labor Cost (1) (\$1990)	Ballast Price (\$1990)	Service Life (2) (years)	ANSI Watts	Lumens (lum/lamp)
0*	Baseline (F96T12HO, 110 W cool white)	31.16	40.08	12.00	190.0	8,900
1*	F96T12CW/HO/WM (95W, reduced wattage)	31.16	40.08	12.00	171.0	8,000
2	F96T12/SP41/HO (110W, RE 70)	31.16	40.08	12.00	190.0	9,200
3	F96T12/SP41/HO/WM (95W, RE 70)	31.16	40.08	12.00	171.0	8,350

Lamp Replacement Cost:

No.	Technology Option	Lamp	Lamp	Lamp
		Labor Cost (1) (\$1990)	Lamp Price (\$1990)	Service Life (2) (years)
0*	Baseline (F96T12HO, 110 W cool white)	6.62	7.04	2.05
1*	F96T12CW/HO/WM (95W, reduced wattage)	6.62	9.00	2.05
2	F96T12/SP41/HO (110W, RE 70)	6.62	14.72	2.05
3	F96T12/SP41/HO/WM (95W, RE 70)	6.62	15.00	2.05

* Appears in Table 1.

(1) Labor Rates (\$1990 per hour) = \$25.63 (electrician helper), \$36.69 (electrician)--it is assumed that the time for lamp replacement is charged at electrician helper rate, and the time for ballast replacement is evenly split between the electrician and helper.

(2) Calculated using annual lighting hours of 4,103.

(3) Corrected for ballast factor.

Table 5a. Characteristics of General Service Incandescent Lamps

No.	Technology Option	Lamp Labor Cost (1) (\$1990)	Lamp Price (\$1990)	Lamp Service Life (2) (years)	Rated Watts	Efficacy Lumens (lum/Watt)
0*	Baseline 75A (75W)	2.14	0.34	0.18	75	1,190 15.9
1*	75A/67WM (67W reduced wattage)	2.14	0.45	0.18	67	1,130 16.9
2*	72 W halogen	2.14	1.87	0.82	72	1,300 18.1
3	70A/MI/LL (70W reduced wattage)	2.14	0.62	0.18	70	1,140 16.3

* Appears in Table 2.

(1) Labor Rates (\$1990 per hour) = \$25.63 (electrician helper), \$36.69 (electrician)--it is assumed that the time for lamp replacement is charged at electrician helper rate.

(2) Calculated using annual lighting hours of 4,270.

Table 5b. Characteristics of Reflector Type Incandescent Lamps

No.	Technology Option	Lamp Labor Cost (1) (\$1990)	Lamp Price (\$1990)	Lamp Service Life (2) (years)	Rated Watts	Lumens	Efficacy (lum/Watt)
0*	Baseline 150PAR/FL	2.14	2.66	0.47	150	2,000	13.3
1*	150PAR/FL/120WM (120W red watt)	2.14	3.63	0.47	120	1,500	12.5
2*	90PAR/FL/HAL (90W halogen)	2.14	4.91	0.47	90	n/a	20(3)
3*	60PAR/HIR (60W halogen infrared)	2.14	6.15	0.59	60	n/a	30(3)

* Appears in Table 2.

(1) Labor Rates (\$1990 per hour) = \$25.63 (electrician helper), \$36.69 (electrician)--it is assumed that the time for lamp replacement is charged at electrician helper rate.

(2) Calculated using annual lighting hours of 4,270.

(3) Estimate. Source: Eley Associates. 1993. Advanced Lighting Guidelines: 1993, pp. 7-3. Eley Associates, San Francisco, CA.

n/a Data on lumen output not available.

Table 5c. Characteristics of Compact Fluorescent Lamps

No.	Technology Option	Ballast		Service Life (2) (years)	Watts	Rated Lumens	Efficacy (lum/watt)
		Labor Cost (1) (\$1990)	Price (3) (\$1990)				
0*	Baseline 75A (75W Incandescent)	2.14	0.34	0.18	75	1190	15.9
1*	Quad Integral, Electronic Ballast	3.20	9.12	2.11	17	1200	70.6
2	Quad Tube + Electronic Ballast	1.71	8.91	10.54	18.5	1200	64.9

No.	Technology Option	Lamp	Lamp	Lamp
		Labor Cost (1) (\$1990)	Price (\$1990)	Service Life (2) (years)
0*	Baseline 75A (75W Incandescent)	NA	NA	NA
1*	Quad Integral, Electronic Ballast	NA	NA	NA
2	Quad Tube + Electronic Ballast	1.71	6.57	1.64

* Appears in Table 2.

(1) Labor Rates (\$1990 per hour) = \$25.63 (electrician helper), \$36.69 (electrician)--it is assumed that the time for lamp replacement is charged at electrician helper rate, and the time for ballast replacement is evenly split between the electrician and helper.

(2) Calculated using annual labor hours of 4,270.

(3) For equipment purchased and replaced as a unit (Options 0 and 1), Price is unit cost (for 0 = lamp, for 1 = lamp/ballast) and is incurred once every Service Life. For equipment with two sections that are replaced at different intervals (Option 2), Price is the ballast cost and is incurred every Service Life.

NA Not Applicable

Table 6a. HID Lamps - 100W Mercury Vapor Lamps and Replacements

No.	Technology Option	Ballast		Ballast		Lamp	
		Labor	Ballast	Service	System	Rated	
		Cost (2)	Price	Life (3)	Watts	Lumens	Efficacy
Base(1)	(\$1990)	(\$1990)	(\$1990)	(years)		(Initial)	(lum/watt)
0	Baseline (Mercury Vapor, 100 W H38JA-100/DX)	mogul	32.72	31.00	18.31	118.0	4,200 35.6
1	LU50 (HPS 50W, S68MS-50) (low CRI)	mogul	32.72	84.58	18.31	66.0	4,000 60.6
2	LU70/DX/MED (HPS 70W, S62LG-70/DX)(CRI 65)	medium	32.72	72.60	18.31	91.0	3,800 41.8

Lamp Replacement Cost:

No.	Technology Option	Lamp		Lamp	
		Labor	Lamp	Service	
		Cost (2)	Price	Life (3)	
(\$1990)	(\$1990)	(\$1990)	(\$1990)	(years)	
0	Baseline (Mercury Vapor, 100 W H38JA-100/DX)		7.26	15.68	4.88
1	LU50 (HPS 50W, S68MS-50) (low CRI)		7.26	27.40	4.88
2	LU70/DX/MED (HPS 70W, S62LG-70/DX)(CRI 65)		7.26	21.98	3.05

(1) Medium is a 27mm (1 1/16") screw in base and mogul is a 40mm (1 19/32") screw in base.

(2) Labor Rates (\$1990 per hour) = \$25.63 (electrician helper), \$36.69 (electrician)--it is assumed that the time for lamp replacement is charged at electrician helper rate, and the time for ballast replacement is evenly split between the electrician and helper.

(3) Calculated using annual lighting hours of 4,916.

Table 6b. HID Lamps - 400W Mercury Vapor Lamps and Replacements

No.	Technology Option	Base(1)	Ballast	Ballast	Ballast	Lamp	Fixture	Lumens	Rated
			Labor	Ballast	Service	Lamp			
			Cost (2)	Price	Life (3)	Watts			
0*	Baseline (Mercury Vapor, 400 W H33GL--400/DX)	mogul	32.72	49.52	18.31	454.0	22,500	49.6	
1*	LU200 (HPS 200W, S66MN-200) (low cri)	mogul	32.72	100.74	18.31	240.0	22,000	91.7	
2*	Metal Halide 250 W (M58PG-250/U)(enclosed)	mogul	32.72	63.75	18.31	295.0	20,500	69.5	

Lamp Replacement Cost:

No.	Technology Option	Lamp	Lamp	Lamp
		Labor	Lamp	Service
		Cost (2)	Price	Life (3)
		(\$1990)	(\$1990)	(years)
0*	Baseline (Mercury Vapor, 400 W H33GL--400/DX)	7.26	15.84	4.88
1*	LU200 (HPS 200W, S66MN-200) (low cri)	7.26	31.39	4.88
2*	Metal Halide 250 W (M58PG-250/U)(enclosed)	7.26	28.19	2.03

* Appears in Table 2.

(1) Mogul is a 40mm (1 19/32") screw in base.

(2) Labor Rates (\$1990 per hour) = \$25.63 (electrician helper), \$36.69 (electrician)--it is assumed that the time for lamp replacement is charged at electrician helper rate, and the time for ballast replacement is evenly split between the electrician and helper.

(3) Calculated using annual lighting hours of 4,916.

Table 6c. HID Lamps - 1000W Mercury Vapor Lamps and Replacements

No.	Technology Option	Base(1)	Ballast	Ballast	Lamp	Rated	Lumens	Efficacy
			Labor Cost (2)	Ballast Price	Service Life (3)			
0	Baseline (Mercury Vapor, 1000 W)	mogul	32.81	64.98	18.31	1075.0	63,000	58.6
1	2*400 W Metal Halide (MVT400/I/U)	mogul	56.03	152.56	18.31	890.0	72,000	80.9
2	2*400 W HPS (LU400)	mogul	56.03	270.84	18.31	914.0	100,000	109.4
3	2*400 W Deluxe HPS (LU400/DX)cri=65	mogul	56.03	270.84	18.31	914.0	74,800	81.8
4	2*310 W HPS (LU310)	mogul	56.03	312.07	18.31	730.0	74,000	101.4

Lamp Replacement Cost:

No.	Technology Option	Lamp	Lamp	Lamp
		Labor Cost (2)	Lamp Price	Service Life (3)
0	Baseline (Mercury Vapor, 1000 W)	10.25	36.83	4.88
1	2*400 W Metal Halide (MVT400/I/U)	13.67	38.66	4.07
2	2*400 W HPS (LU400)	13.67	36.23	4.88
3	2*400 W Deluxe HPS (LU400/DX)cri=65	13.67	57.91	2.03
4	2*310 W HPS (LU310)	13.67	101.57	4.88

(1) Mogul is a 40mm (1 19/32") screw in base.

(2) Labor Rates (\$1990 per hour) = \$25.63 (electrician helper), \$36.69 (electrician)--it is assumed that the time for lamp replacement is charged at electrician helper rate, and the time for ballast replacement is evenly split between the electrician and helper.

(3) Calculated using annual lighting hours of 4,916.

Saturation Data for Lighting Systems

There are several ways to define technology shares: some of these are shares of connected load, shares of floorspace illuminated, shares of delivered lumens, and shares of supplied lumens (lumens out of lamps before fixture and room losses). COMMEND uses shares of delivered lumens. Within the COMMEND 4 framework, lighting systems (lamp/ballast combinations) are grouped into fixture types. Parallel to this type of representation, shares are defined in two levels: (1) the shares for the different fixture types, and (2) the shares for different systems within the fixture types.

Fixture Shares of Lighting

Previously, stock 1986 Energy Utilization Intensities (EUIs) were developed from the average of seven different utility studies[8]. The implied Lighting Power Densities (LPDs) were calculated using the annual lighting hours mentioned above. LPDs by fixture type were estimated by applying fixture shares of connected load developed from a large and detailed set of audit data collected in 1986 [9]. Table 7 gives LPDs for the building stock for the year 1986, and new buildings (sales) for 1986 and 1995. Using this information and efficacies from Tables 4, 5 and 6 for lamp/ballast combinations, data can be converted to the COMMEND format. The following equations show the derivation of fixture shares using information on connected load. An average efficacy for each fixture type has to be developed using the shares within fixture types presented in the following section. The average efficacy for a fixture type for a given building type is:

$$\text{Average Efficacy}_{i,b} = \frac{1}{\sum_{j=1}^m \text{System Share}_j * \frac{1}{\text{System Efficacy}_j * \text{Luminaire Efficiency}_j * \text{Room Factor}_b}}$$

where,

b : index for building type

i : index for fixture type

j : index for system type

m : number of system types within a fixture type.

Illuminance delivered and fixture share for each fixture type and building type can be calculated as follows:

$$\text{Illuminance Delivered}_{i,b} = \text{Connected Load}_{i,b} * \text{Average Efficacy}_{i,b}$$

$$\text{Fixture Share}_{i,b} = \frac{\text{Illuminance Delivered}_{i,b}}{\sum_{i=1}^n \text{Illuminance Delivered}_{i,b}}$$

where,

b : index for building type

i : index for fixture type

n : number of fixture types.

Stock and new fixture shares for 1986, and new fixture shares for 1995 are presented in Table 8. These shares on Table 8 are developed using data from Table 7 as discussed above. The 1995 data in Tables 7 and 8 are to be used as a calibration check for the equations determining future new-construction shares. Future trends are input to COMMEND as equations by the users.

Table 7. Lighting Power Density by Building Type (W/sqft)(1)

1986 Stock

	fluo	incand	hid	other
small office	1.32	0.17	0.04	0.00
large office	1.00	0.13	0.02	0.00
restaurant	0.58	0.54	0.00	0.01
retail	0.94	0.32	0.00	0.00
grocery	1.66	0.14	0.00	0.00
warehouse	0.58	0.12	0.10	0.00
school	0.61	0.13	0.01	0.00
college	1.44	0.12	0.00	0.00
health	0.64	0.11	0.00	0.00
lodging	0.07	0.36	0.00	0.00
miscellaneous	0.61	0.18	0.03	0.00

1986 sales

	fluo	incand	hid	other
small office	1.32	0.17	0.03	0.00
large office	1.00	0.13	0.02	0.00
restaurant	0.58	0.54	0.00	0.01
retail	0.93	0.32	0.00	0.00
grocery	1.66	0.14	0.00	0.00
warehouse	0.58	0.12	0.08	0.00
school	0.61	0.13	0.01	0.00
college	1.44	0.12	0.00	0.00
health	0.64	0.11	0.00	0.00
lodging	0.07	0.36	0.00	0.00
miscellaneous	0.61	0.18	0.02	0.00

1995 sales

	fluo	incand	hid	other
small office	1.01	0.13	0.03	0.00
large office	0.77	0.10	0.01	0.00
restaurant	0.44	0.43	0.00	0.01
retail	0.72	0.26	0.00	0.00
grocery	1.27	0.12	0.00	0.00
warehouse	0.44	0.09	0.07	0.00
school	0.46	0.11	0.01	0.00
college	1.10	0.09	0.00	0.00
health	0.49	0.09	0.00	0.00
lodging	0.06	0.29	0.00	0.00
miscellaneous	0.47	0.14	0.02	0.00

(1) The numbers apply to the total floor area for the building type, and not to the area which has the particular fixture type. These numbers were developed from [8] and [9].

Table 8. Fixture Shares of Delivered Lumens (1)

1986 Stock

	fluo	incand	hid	other
small office	96%	2%	2%	0%
large office	96%	2%	1%	0%
restaurant	84%	15%	0%	1%
retail	94%	6%	0%	0%
grocery	98%	2%	0%	0%
warehouse	86%	3%	11%	0%
school	95%	4%	1%	0%
college	98%	2%	0%	0%
health	97%	3%	0%	0%
lodging	51%	49%	0%	0%
miscellaneous	92%	5%	3%	0%

1986 sales

	fluo	incand	hid	other
small office	96%	2%	2%	0%
large office	97%	2%	1%	0%
restaurant	85%	14%	0%	1%
retail	94%	6%	0%	0%
grocery	98%	2%	0%	0%
warehouse	88%	3%	8%	0%
school	95%	4%	1%	0%
college	99%	1%	0%	0%
health	97%	3%	0%	0%
lodging	52%	48%	0%	0%
miscellaneous	93%	5%	3%	0%

1995 sales

	fluo	incand	hid	other
small office	96%	3%	2%	0%
large office	96%	3%	1%	0%
restaurant	82%	16%	0%	1%
retail	93%	7%	0%	0%
grocery	98%	2%	0%	0%
warehouse	88%	4%	9%	0%
school	95%	5%	1%	0%
college	98%	2%	0%	0%
health	96%	4%	0%	0%
lodging	50%	50%	0%	0%
miscellaneous	92%	6%	3%	0%

(1) Shares represent % of delivered lumens by fixture type.

Shares may not add to 100% due to rounding error.

System Shares within Fixture Types

LBL has developed system shares of illuminance delivered within a fixture type. This is done using a combination of survey data collected by the Lighting Research Institute [10], DOE [5], and the Bureau of the Census [11]. Table 9 gives fluorescent shares for the building stock in 1986, Table 10 gives shares for new buildings (sales) in 1986, and Table 11 gives the shares for new buildings (sales) in 1995. Table 12 gives standard fixture system shares of illuminance delivered in 1986 and 1995. It should be noted that the the shares for 4-foot and 8-foot fixtures add up to approximately 100. If the intention is to treat 4-foot and 8-foot fixtures separately, then shares within each category can be developed using Table 9.

Shares for energy-efficient magnetic ballast were estimated based on work by Geller and Miller [12]. Market shares for 1987 sales were adjusted by Geller and Miller to represent market shares if state standards did not exist in 1987. By the end of 1987, standards prohibiting sale of inefficient core-coil ballasts existed in five states representing about one quarter of the U.S. population (California, New York, Massachusetts, Connecticut, and Florida). Without the standards, market share for energy efficient magnetic ballasts were estimated to be about 10 percent. Considering the fact that energy efficient magnetic ballast have been in the market since the seventies, the stock saturation in this report for this ballast type was estimated to be about 10 percent. The market share in sales is estimated to be 33 percent which is 25 percent (for states with standards), plus 8 percent (for states with no standards for ballasts). Estimates based on NBECS [5] give higher shares for energy efficient magnetic ballasts. This may be because, when a survey response indicates that this type of ballast is used in the building, it is sometimes interpreted to mean that the whole building is utilizing such ballasts.

The 1995 data in Table 11 can be used as a calibration check for the equations determining future shares. In COMMEND either trend equations or discrete choice equations can be used to determine future shares.

Table 9. Fluorescent System Shares--1986 Stock

System	Relative * Share (%)	Market Share (%)	Notes
4-Foot Lamps	78.3		
Std Ballast	90		Census Data (100-EE Magnetic-Electronic-Cathode Cut.)%
Std F40	86.3	60.8	Census Data
ES 34W	13.7	9.7	(100 - Std F40 - T-8)%
EE Mag Ballast	9.7		Estimated based on [12]
Std F40	86.2	6.5	
ES 34W	13.7	1.0	
T-8	0.1	0.0	
Cath Cut Ballast	0		LBL Estimate
Std F40	86.2	0	
ES 34W	13.7	0	
T-8	0.1	0	
Elect Ballast	0.3		Census Data
Std F40	86.2	0.2	
ES 34W	13.7	0	
T-8	0.1	0	
8-Foot Lamps	12.9		
Std Ballast	90		Census Data (100 - EE Magnetic - Electronic)%
Std F96	55	6.4	NBECS 1986
ES F96	45	5.2	NBECS 1986
EE Mag Ballast	9.7		Estimated based on [12]
Std F96	55	0.7	
ES F96	45	0.6	
Elect Ballast	0.3		Census Data
Std F96	55	0	
ES F96	45	0	
8-foot High Out.	7.4		
Std Ballast	90		Census Data (100 - EE Magnetic - Electronic)%
Std F96	55	3.7	NBECS 1986
ES F96	45	3.0	NBECS 1986
EE Mag Ballast	9.7		Estimated based on [12]
Std F96	55	0.4	
ES F96	45	0.3	
Elect Ballast	0.3		Census Data
Std F96	55	0	
ES F96	45	0	
Total:	98.6	98.5	

* Relative Share stands for share within fixture type, ballast type or lamp type

Table 10. Fluorescent System Shares--1986 New-Construction

System	Relative* Share (%)	Market Share (%)	Notes
4-Foot Lamps	78.3		
Std Ballast	66.2		Census Data (100-EE Magnetic-Electronic-Cathode Cut.)%
Std F40	86.4	44.8	Census Data
ES 34W	13.6	7.0	(100 - Std F40 - T-8)%
EE Mag Ballast	33.0		Estimated based on [12]
Std F40	86.2	22.3	
ES 34W	13.6	3.5	
T-8	0.2	0.1	
Cath Cut Ballast	0		Estimate
Std F40	86.2	0	
ES 34W	13.6	0	
T-8	0.2	0	
Elect Ballast	0.8		Census Data
Std F40	86.2	0.5	
ES 34W	13.6	0.1	
T-8	0.2	0	
8-Foot Lamps	13.0		Census Data
Std Ballast	66.2		(100 - EE Magnetic - Electronic)%
Std F96	55	4.7	NBECS 1986
ES F96	45	3.9	NBECS 1986
EE Mag Ballast	33.0		Estimated based on [12]
Std F96	55	2.4	
ES F96	45	1.9	
Elect Ballast	0.8		Census Data
Std F96	55	0.1	
ES F96	45	0.0	
8-foot High Out.	7.5		Census Data
Std Ballast	66.2		(100 - EE Magnetic - Electronic)%
Std F96	55	2.7	NBECS 1986
ES F96	45	2.2	NBECS 1986
EE Mag Ballast	33.0		Estimated based on [12]
Std F96	55	1.4	
ES F96	45	1.1	
Elect Ballast	0.8		Census Data
Std F96	55	0	
ES F96	45	0	
Total:	98.8	98.7	

* Relative Share stands for share within fixture type, ballast type or lamp type

Table 11. Fluorescent System Shares--1995 New-Construction

System	Relative* Share (%)	Market Share (%)	Notes
4-Foot Lamps			
Std Ballast	80.3		LRI Lamp Manufacturer Survey
Std F40	0		1990 Ballast Std
ES 34W	25	0	LRI NALMCO 25% of (100 - T-8)
EE Mag Ballast	75	0	LRI NALMCO 75% of (100 - T-8)
Std F40	53.7		LRI Bal Manf Survey
ES 34W	20	8.6	
T-8	60	25.9	
Cath Cut Ballast	20	8.6	
Std F40	9.3		20% of LRI Bal Manf Survey
ES 34W	20	1.5	46.3
T-8	60	4.5	
Elect Ballast	20	1.5	
Std F40	37		80% of LRI Bal Manf Survey
ES 34W	20	5.9	46.3
T-8	60	17.8	
Std F40	20	5.9	
EE 8-Foot Lamps	10.5		LRI Lamp Manufacturer Survey
Std Ballast	0		1990 Ballast Std
Std F96	9.9	0	LRI NALMCO Survey
ES F96	90.1	0	LRI NALMCO Survey
EE Mag Ballast	76.2		LRI Ballast Manufacturer Survey
Std F96	9.9	0.8	
ES F96	90.1	7.2	
Elect Ballast	23.8		LRI Ballast Manufacturer Survey
Std F96	23.8	0.2	
ES F96	90.1	2.3	
8-foot High Out.			
Std Ballast	4.4		LRI Lamp Manufacturer Survey
Std F96	0		1990 Ballast Std
ES F96	56.4	0	LRI NALMCO Survey
EE Mag Ballast	43.6	0	LRI NALMCO Survey
Std F96	82.1		LRI Ballast Manufacturer Survey
ES F96	56.4	2	
Elect Ballast	43.6	1.6	
Std F96	17.9		LRI Ballast Manufacturer Survey
ES F96	56.4	0.4	
Elect Ballast	43.6	0.3	
Total:	95.2	95.1	

* Relative Share stands for share within fixture type, ballast type or lamp type

Table 12. Standard Fixture Shares--Stock/New-Construction

1986			
System	Relative* Share (%)	Market Share (%)	Notes
<i>Incandescent</i>	<i>100</i>		
General Service	80		Census Data
> 150	2	1.6	Census Data
15-150 Std	93	74.4	(100 - others)%
Reduced Wattage	5	4	Estimate
Halogen	0	0	
Reflector	10		Census Data
Standard Par	33.2	3.3	(100-others)*census=42/(42+53)
Standard R	41.8	4.2	(100-others)*census=53/(42+53)
Reduced Wattage Par/R	20	2	Estimate
Halogen	5	0.5	census
Halogen Infrared (IR)	0	0	
Other	10		Census Data
Std	100	10	
<i>Compact Fluor.</i>	<i>0</i>	<i>0</i>	

1995			
System	Relative* Share (%)	Market Share (%)	
<i>Incandescent</i>	<i>80</i>		
General Service	80		Census Data (1989)
> 150	2	1.3	Census Data
15-150 Std	43	27.5	100 - others
Reduced Wattage	50	32.0	Estimate
Halogen	5	3.2	Estimate
Reflector	10		Census Data (1989)
Standard Par	13.3	1.1	(100-others)*census=42/(42+53)
Standard R	16.7	1.3	(100-others)*census=53/(42+53)
Reduced Wattage Par/R	30	2.4	Estimate
Halogen	30	2.4	Estimate
Halogen Infrared (IR)	10	0.8	Estimate
Other	10		Census Data (1989)
Std	100	8.0	
<i>Compact Fluor.</i>	<i>20</i>	<i>20.0</i>	LRI Lamp Manf Survey

* Relative Share stands for share within fixture type or lamp type

LUMINAIRE DATA

Luminaire efficiency stands for the percentage of the light output from the lamps that is actually emitted from the fixture. In other words, it models losses due to the luminaire. These losses are affected by the fixture geometry and also the reflectances of the interior surfaces of the luminaire. Table 13 presents efficiencies for the important fixture types. Table 14a characterizes the fixture distribution over the market in the year 1986. Table 14b presents an estimate of future trends.

The luminaire market is expected to move from lensed troffers to recessed parabolic luminaires as more office spaces have VDT screens. Less 4-lamp luminaires will be used as the lamp/ballast efficacy increases.

Table 13. Luminaire Efficiencies

	1-lamp	2-lamp	3-lamp	4-lamp
Fluorescent				
Lensed Troffer	54%	59%	64%	62%
Wraparound	80%	72%	70%	62%
Parabolic				
Narrow&Medium	61%	61%	63%	58%
Wide	72%	71%	64%	64%
Standard Base				
Incandescent				
General Service	50%			
Reflector	50%			
Compact Fluorescent	48%	57%	61%	
HID				
Round-No Refractor	68%			
Round-Refractor	77%			
Square	60%			
Indirect	69%	71%	71%	

Source: LBL Luminaire Database and New York State Energy Office Luminaire Database

Table 14a. Fluorescent Fixture Saturation as a Function of Number of Lamps per Fixture (1986)

Type	All	1-lamp	2-lamp	3-lamp	4-lamp
Lensed Troffer	42.0%	0.4%	7.6%	11.8%	22.3%
Wraparound	17.0%	0.9%	11.4%	0.2%	4.6%
Parabolic	18.0%	0.9%	5.4%	7.2%	4.5%
Other	23.0%	n/a	n/a	n/a	n/a

Source: Bureau of Census [11]

Table 14b. Fluorescent Fixture Saturation as a Function of Number of Lamps per Fixture (1995)(1)

Type	All	1-lamp	2-lamp	3-lamp	4-lamp
Lensed Troffer	22.0%	n/a	n/a	n/a	n/a
Wraparound	23.0%	n/a	n/a	n/a	n/a
Parabolic	32.0%	1.6%	12.8%	14.4%	3.2%
Other	23.0%	n/a	n/a	n/a	n/a

n/a : not available

(1) LBL estimates

CONTROLS DATA

Controls generally change the use pattern of the connected load, and decrease consumption by customizing operating hours to user needs. Controls range from simple mechanical timeclocks to sophisticated multi-level electronic devices that interface with a building's energy management system. The types of controls covered here are: programmable timers, lumen maintenance/dimming, occupancy sensors and daylighting/dimming.

Programmable timers provide time-based control of lighting equipment. The usual method of implementation is a system of low-voltage relays controlled by a programmable timeclock. To accommodate off-hours lighting needs, systems usually have overrides, so lights can be turned on by building occupants either by low-voltage switches or telephone procedures. In this report, timers are assumed to be multi-level and are applied to both fluorescent and incandescent lights.

Lumen maintenance controls limit power and light output when fluorescent lamps are new and the fixtures are clean. Without controls, light output decreases as the lamps age and dirt accumulates on the fixture reflector and/or lens. With lumen maintenance dimming controls, power is gradually increased over time until full power operation occurs when it is time to replace the lamps and clean the fixtures. This light output remains fairly constant throughout the lamp lifetime. This option is applied to full-size fluorescent lamps only (not compact fluorescent lamps).

Occupancy sensors are activated by the presence or absence of people in the field of view. The lights in the controlled zone are turned on automatically when a person enters the area, and are turned off after the room is unoccupied for a set period of time. There are two basic types of sensors: passive infrared and ultrasonic. In this report, this control option applies to fluorescent and incandescent lights.

Daylighting controls use a photocell with a dimming system to provide a fixed light level at the work plane by decreasing the amount of light as daylight levels increase and increasing it with reduced daylight. This option is applied to full-size fluorescent lamps only. Daylighting affects both operating hours and lighting load.

Other types of controls, such as two-level switching, incandescent or compact fluorescent dimmers, and stepped switching are not covered in this report.

Effectiveness, saturations, and penetration trends of control options for new buildings and retrofit situations by building type are supplied as inputs to COMMEND. Table 15 presents savings, price, and applicability of controls. For timers and occupancy sensors, percentage savings, applicable percent floor area, and applicable building types are determined from manufacturer estimates and staff experience.⁵ Energy savings from lumen maintenance accrue in watts/sqft during the early part of a lamp's lifetime. In California's Title 24 energy code, controls credits allow 0.1 watts/sqft savings for lumen maintenance. Energy savings from daylighting accrue in reduced lighting hours for on-off controls and in watts/sqft for dimming. This is translated into percentage savings, estimated by the LBL Lighting Systems Research Group. Daylighting controls are applied to one-half of the building perimeter floor area taken from NBECS 1986.

⁵ Timers: Dave Peterson, GE Wiring Devices, Rhode Island and LBL's Lighting Systems Research Group. Occupancy sensors: Jerry Mix, The Watt-Stopper, Santa Clara, California, and LBL's Lighting Systems Research Group.

Table 15. Impacts, Costs and Applicability of Controls

TIMERS

	Savings Fraction	Applicable Fraction(1)	Applicable Technology(2)	Price(3) (\$/sqft)	Notes
Small Off	0.23	1	F + I	0.30	
Lg Off	0.23	1	F + I	0.30	
Rest	0.00	1	F + I	0.00	
Retail	0.10	1	F + I	0.25	
Grocery	0.10	1	F + I	0.25	
Warehse	0.30	1	F + I	0.25	
School	0.15	1	F + I	0.45	
College	0.15	1	F + I	0.45	
Health	0.00	1	F + I	0.00	
Lodging	0.00	1	F + I	0.00	
Misc	0.15	1	F + I	0.30	

TIMERS + LUMEN MAINTENANCE

	Savings Fraction	Applicable Fraction(1)	Applicable Technology(2)	Price(3) (\$/sqft)	Notes
Small Off	0.33	1	F	0.57	Assumes 10% savings; cost=
Lg Off	0.33	1	F	0.49	30c/sq ft where F LPD=1.0
Rest	0.10	1	F	0.16	No Timer
Retail	0.20	1	F	0.39	
Grocery	0.20	1	F	0.59	
Warehse	0.40	1	F	0.31	
School	0.25	1	F	0.52	
College	0.25	1	F	0.70	
Health	0.10	1	F	0.16	No Timer
Lodging	0.10	1	F	0.02	No Timer
Misc	0.25	1	F	0.38	

(1) Fraction of floorspace to which the technology option is applicable.

(2) F = fluorescent, and I = incandescent.

(3) Capital cost of the technology option per applicable square foot.

Table 15. Impacts, Costs and Applicability of Controls (continued)

OCCUPANCY SENSORS

	Savings Fraction	Applicable Fraction(1)	Applicable Technology(2)	Price(3) (\$/sqft)	Notes(4)
Small Off	0.30	0.35	F + I	0.46	
Lg Off	0.30	0.50	F + I	0.46	
Rest	0.40	0.10	F	0.70	No Timer
Retail	0.40	0.10	F	0.70	
Grocery	0.40	0.10	F	0.70	
Warehse	0.50	0.60	F + I	0.40	
School	0.20	0.80	F + I	0.36	No T, LM
College	0.30	0.80	F + I	0.36	No T, LM
Health	0.30	0.15	F + I	0.70	No Timer
Lodging	0.40	0.20	F + I	0.50	No Timer
Misc	0.30	0.60	F + I	0.50	No T, LM

DAYLIGHTING

	Savings Fraction	Applicable Fraction(1)	Applicable Technology(2)	Price(3) (\$/sqft)	Notes(4)
Small Off	0.35	0.28	F	1.10	
Lg Off	0.35	0.28	F	1.10	
Rest	0.35	0.00	F	1.10	No T,OS
Retail	0.35	0.00	F	1.10	
Grocery	0.35	0.00	F	1.10	
Warehse	0.35	0.00	F	1.10	
School	0.35	0.20	F	1.10	No T, LM, OS
College	0.35	0.20	F	1.10	No T, LM
Health	0.35	0.25	F	1.10	No Timer
Lodging	0.35	0.00	F	1.10	No Timer
Misc	0.35	0.20	F	1.10	No T, LM, OS

(1) Fraction of floorspace to which the technology option is applicable.

(2) F = fluorescent, and I = incandescent.

(3) Capital cost of the technology option per applicable square foot.

(4) T=timers, LM=lumen maintenance, OS=occupancy sensor

LIGHTING/HVAC INTERACTIONS

The secondary effect of lighting energy reduction on building energy use is due to lighting/HVAC interactions. This report looks at changes in energy use for cooling and heating but does not address the additional benefits due to reduced equipment sizing. The general belief within expert groups advocating energy-efficiency is that there are additional net benefits from lighting reduction because of reduced cooling demand. LBL research shows that there are net benefits for cooling dominated regions and net penalties for heating dominated regions.

For ten building types in ten climate zones, prototype buildings are simulated using the DOE-2 building energy analysis program. Lighting/HVAC *coincidence factors* for each building/climate combination are developed. Cooling and heating coincidence factors are defined as the annual fractions of lighting energy saved resulting in reduced cooling and increased heating loads respectively.

Coincidence Factors for Prototypical Buildings

The attached tables and figures show DOE-2 simulation results for Heating and Cooling Coincidence Factors (HCF and CCF) for varying lighting power densities (W/ft^2) for ten commercial building types (large and medium offices, large retail, large and small hotels, hospital, fast-food and sit-down restaurants, supermarket and secondary school) in ten cities (Charleston, Chicago, Lake Charles, Miami, Minneapolis, New York, Pasadena, Phoenix, San Francisco, and Washington).

The Heating and Cooling Coincidence Factors can be conceptualized as the coincidence of a building's lighting load and its space conditioning load. In reality, since the load due to heat gain from lights may be delayed for hours, these "coincidence factors" are actually calculated using DOE-2 hour-by-hour simulations where the lighting power density of the building is varied and the resultant changes in annual heating and cooling loads noted.

The prototypical building used for this study are a subset of the 481 prototypical commercial buildings described for the GRI Cogeneration Study [13]. The ten selected cities represent major climate variations within the U.S. Depending on the building type and vintage, the ten prototypes vary by city in size, shell characteristics, and internal conditions. The Cogeneration Study data base did not include five of the cities. Those cities were modeled with the appropriate weather tape, but using prototypes defined for the nearest available location : Chicago for Minneapolis, Miami for Charleston, Philadelphia for Washington, Houston for Lake Charles, and Los Angeles for Pasadena.

Both building vintages defined in the Cogeneration study were simulated - (1) *Current*, representing post-1980s construction following the ASHRAE-90.75 building energy

standard, and (2) *Old*, representing the average characteristics of all buildings built prior to 1980. For each of the two restaurant prototypes (sit-down and fast-food), a single *Average* vintage was simulated. Since the coincidence factors must be expressed in terms of building loads, not HVAC-system or -plant loads, system variations were not studied. Building loads incorporating only the thermostat settings and the minimum fresh-air requirements were developed.

For each building-type/location/vintage combination, two simulations were done using the recently released DOE-2.1E program: (1) *Average* lighting power density, and (2) *Low* lighting power density (0.667 times the *Average*). The results of these simulations are shown in Tables 16a-j. Each table shows the changes in heating, cooling, and lighting loads from the base case. The last two columns show the heating (HCF) and cooling (CCF) coincidence factors calculated by dividing the change in space conditioning load by the change in lighting load.

The results are also plotted as bar charts in Figure 1. To illustrate the reverse relationship between HCF and CCF, the former are plotted as negative (e.g., increases the heating load) while the latter are plotted as positive (e.g., decreases the cooling load). Note that in the larger building types (large office, large retail, hospital, etc.) the sums of the HCF and CCF are constant across the ten locations, indicating that their space conditioning requirements are determined mostly by their internal loads rather than the climate or building shell. On the other hand, the smaller buildings, notably the small hotels, have coincidence factors that vary by location and vintage.

The plots also indicate that the coincidence factors of the larger buildings are more sensitive to the internal load than to differences in vintages. However, the coincidence factors for the smaller buildings vary more by vintage than by lighting power density.

Table 16a. Heating and Cooling Coincidence Factors for Fast Foods Restaurant

Location	Vintage	Δ HL (kBtu/sf)	Δ CL (kBtu/sf)	Δ LL (kBtu/sf)	HCF	CCF
Charleston	Average	-1.14	-14.12	-16.26	0.070	0.868
Chicago	Average	-2.62	-12.78	-16.26	0.161	0.786
Lake Charles	Average	-0.81	-14.46	-16.26	0.050	0.889
Miami	Average	-0.04	-15.38	-16.26	0.002	0.946
Minneapolis	Average	-3.49	-11.88	-16.26	0.215	0.731
New York	Average	-2.68	-12.61	-16.26	0.165	0.776
Pasadena	Average	-0.66	-14.59	-16.26	0.041	0.897
Phoenix	Average	-0.53	-14.83	-16.26	0.033	0.912
San Francisco	Average	-1.47	-13.62	-16.26	0.090	0.838
Washington	Average	-2.12	-13.20	-16.26	0.130	0.812

Table 16b. Heating and Cooling Coincidence Factors for Hospital

Location	Vintage	Δ HL (kBtu/sf)	Δ CL (kBtu/sf)	Δ LL (kBtu/sf)	HCF	CCF
Charleston	Current	-0.60	-13.13	-13.86	0.043	0.947
	Old	-0.64	-13.08	-13.86	0.046	0.944
Chicago	Current	-0.78	-12.96	-13.86	0.056	0.935
	Old	-1.51	-12.16	-13.86	0.109	0.877
Lake Charles	Current	-0.39	-13.37	-13.86	0.028	0.965
	Old	-0.47	-13.26	-13.86	0.034	0.957
Miami	Current	-0.04	-13.79	-13.86	0.003	0.995
	Old	-0.04	-13.80	-13.86	0.003	0.996
Minneapolis	Current	-0.96	-12.78	-13.86	0.069	0.922
	Old	-1.87	-11.79	-13.86	0.135	0.851
New York	Current	-0.81	-12.77	-13.87	0.058	0.921
	Old	-1.58	-11.97	-13.87	0.114	0.863
Pasadena	Current	-0.11	-13.72	-13.86	0.008	0.990
	Old	-0.15	-13.68	-13.86	0.011	0.987
Phoenix	Current	-0.14	-13.71	-13.86	0.010	0.989
	Old	-0.17	-13.66	-13.86	0.012	0.986
San Francisco	Current	-0.39	-13.35	-13.86	0.028	0.963
	Old	-0.55	-13.14	-13.86	0.040	0.948
Washington	Current	-0.47	-13.29	-13.86	0.034	0.959
	Old	-1.02	-12.68	-13.86	0.074	0.915

Table 16c. Heating and Cooling Coincidence Factors for Large Hotel

Location	Vintage	Δ HL (kBtu/sf)	Δ CL (kBtu/sf)	Δ LL (kBtu/sf)	HCF	CCF
Charleston	Current	-1.03	-7.07	-8.97	0.115	0.788
	Old	-0.99	-7.14	-8.97	0.110	0.796
Chicago	Current	-1.38	-6.01	-8.97	0.154	0.670
	Old	-2.13	-5.12	-8.97	0.237	0.571
Lake Charles	Current	-0.68	-7.81	-8.97	0.076	0.871
	Old	-0.73	-7.73	-8.97	0.081	0.862
Miami	Current	-0.04	-8.85	-8.97	0.004	0.987
	Old	-0.03	-8.87	-8.97	0.003	0.989
Minneapolis	Current	-1.76	-5.31	-8.97	0.196	0.592
	Old	-2.47	-4.49	-8.97	0.275	0.501
New York	Current	-1.25	-6.01	-8.97	0.139	0.670
	Old	-2.09	-5.00	-8.97	0.233	0.557
Pasadena	Current	-0.15	-8.61	-8.97	0.017	0.960
	Old	-0.21	-8.53	-8.97	0.023	0.951
Phoenix	Current	-0.22	-8.58	-8.97	0.025	0.957
	Old	-0.29	-8.49	-8.97	0.032	0.946
San Francisco	Current	-0.54	-7.90	-8.97	0.060	0.881
	Old	-0.83	-7.53	-8.97	0.093	0.839
Washington	Current	-0.87	-6.77	-8.97	0.097	0.755
	Old	-1.82	-5.56	-8.97	0.203	0.620

Table 16d. Heating and Cooling Coincidence Factors for Large Office

Location	Vintage	Δ HL (kBtu/sf)	Δ CL (kBtu/sf)	Δ LL (kBtu/sf)	HCF	CCF
Charleston	Current	-0.55	-5.61	-6.89	0.080	0.814
	Old	-0.64	-7.23	-8.78	0.073	0.823
Chicago	Current	-1.54	-4.27	-6.58	0.234	0.649
	Old	-1.97	-4.98	-7.97	0.247	0.625
Lake Charles	Current	-0.29	-6.02	-6.90	0.042	0.872
	Old	-0.39	-7.60	-8.78	0.044	0.866
Miami	Current	-0.02	-6.35	-6.89	0.003	0.922
	Old	-0.02	-8.07	-8.78	0.002	0.919
Minneapolis	Current	-2.09	-3.69	-6.58	0.318	0.561
	Old	-2.66	-4.30	-7.97	0.334	0.540
New York	Current	-1.98	-3.77	-6.58	0.301	0.573
	Old	-2.34	-4.17	-7.55	0.310	0.552
Pasadena	Current	-0.18	-5.46	-6.26	0.029	0.872
	Old	-0.23	-6.93	-7.98	0.029	0.868
Phoenix	Current	-0.21	-5.48	-6.26	0.034	0.875
	Old	-0.26	-6.98	-7.98	0.033	0.875
San Francisco	Current	-0.58	-4.66	-6.26	0.093	0.744
	Old	-0.64	-6.17	-7.98	0.080	0.773
Washington	Current	-1.18	-4.62	-6.58	0.179	0.702
	Old	-1.48	-5.10	-7.55	0.196	0.675

Table 16e. Heating and Cooling Coincidence Factors for Large Retail

Location	Vintage	Δ HL (kBtu/sf)	Δ CL (kBtu/sf)	Δ LL (kBtu/sf)	HCF	CCF
Charleston	Current	-1.23	-5.55	-7.97	0.154	0.696
	Old	-1.34	-6.52	-9.29	0.144	0.702
Chicago	Current	-3.31	-3.42	-7.81	0.424	0.438
	Old	-3.95	-3.81	-9.11	0.434	0.418
Lake Charles	Current	-0.83	-6.02	-7.97	0.104	0.755
	Old	-0.98	-6.92	-9.29	0.105	0.745
Miami	Current	-0.02	-7.08	-7.97	0.003	0.888
	Old	-0.02	-8.20	-9.29	0.002	0.883
Minneapolis	Current	-3.84	-2.97	-7.81	0.492	0.380
	Old	-4.55	-3.32	-9.11	0.499	0.364
New York	Current	-3.58	-4.46	-9.05	0.396	0.493
	Old	-4.15	-5.17	-10.56	0.393	0.490
Pasadena	Current	-0.31	-8.52	-9.71	0.032	0.877
	Old	-0.33	-9.96	-11.32	0.029	0.880
Phoenix	Current	-0.37	-8.55	-9.70	0.038	0.881
	Old	-0.44	-9.93	-11.32	0.039	0.877
San Francisco	Current	-1.17	-7.27	-9.70	0.121	0.749
	Old	-2.11	-7.27	-11.32	0.186	0.642
Washington	Current	-3.01	-5.00	-9.05	0.333	0.552
	Old	-3.60	-5.65	-10.56	0.341	0.535

Table 16f. Heating and Cooling Coincidence Factors for Medium Offices

Location	Vintage	Δ HL (kBtu/sf)	Δ CL (kBtu/sf)	Δ LL (kBtu/sf)	HCF	CCF
Charleston	Current	-0.98	-5.94	-7.91	0.124	0.751
	Old	-1.19	-8.46	-10.98	0.108	0.770
Chicago	Current	-2.55	-4.06	-7.55	0.338	0.538
	Old	-3.91	-5.01	-10.48	0.373	0.478
Lake Charles	Current	-0.64	-6.38	-7.91	0.081	0.807
	Old	-0.85	-8.83	-10.98	0.077	0.804
Miami	Current	-0.05	-7.14	-7.91	0.006	0.903
	Old	-0.06	-9.90	-10.98	0.005	0.902
Minneapolis	Current	-3.12	-3.52	-7.55	0.413	0.466
	Old	-4.75	-4.32	-10.48	0.453	0.412
New York	Current	-2.68	-3.81	-7.55	0.355	0.505
	Old	-3.89	-4.90	-10.48	0.371	0.468
Pasadena	Current	-0.41	-5.84	-7.19	0.057	0.812
	Old	-0.62	-7.92	-9.98	0.062	0.794
Phoenix	Current	-0.36	-6.07	-7.19	0.050	0.844
	Old	-0.59	-8.18	-9.98	0.059	0.820
San Francisco	Current	-1.14	-4.66	-7.19	0.159	0.648
	Old	-1.68	-6.31	-9.98	0.168	0.632
Washington	Current	-2.10	-4.43	-7.55	0.278	0.587
	Old	-3.06	-5.77	-10.48	0.292	0.551

Table 16g. Heating and Cooling Coincidence Factors for Small Hotel/Motel

Location	Vintage	Δ HL (kBtu/sf)	Δ CL (kBtu/sf)	Δ LL (kBtu/sf)	HCF	CCF
Charleston	Current	-1.12	-2.44	-4.16	0.269	0.587
	Old	-1.11	-2.47	-4.16	0.267	0.594
Chicago	Current	-1.45	-2.26	-4.16	0.349	0.543
	Old	-1.98	-1.75	-4.16	0.476	0.421
Lake Charles	Current	-0.68	-2.92	-4.16	0.163	0.702
	Old	-0.81	-2.74	-4.16	0.195	0.659
Miami	Current	-0.07	-3.87	-4.16	0.017	0.930
	Old	-0.07	-3.86	-4.16	0.017	0.928
Minneapolis	Current	-1.79	-1.98	-4.16	0.430	0.476
	Old	-2.24	-1.54	-4.16	0.538	0.370
New York	Current	-1.50	-2.23	-4.16	0.361	0.536
	Old	-1.85	-1.85	-4.16	0.445	0.445
Pasadena	Current	-0.67	-2.64	-4.16	0.161	0.635
	Old	-0.90	-2.33	-4.16	0.216	0.560
Phoenix	Current	-0.48	-3.24	-4.16	0.115	0.779
	Old	-0.63	-3.06	-4.16	0.151	0.736
San Francisco	Current	-1.30	-1.67	-4.16	0.312	0.401
	Old	-1.81	-1.11	-4.16	0.435	0.267
Washington	Current	-1.14	-2.59	-4.16	0.274	0.623
	Old	-1.65	-2.10	-4.16	0.397	0.505

Table 16h. Heating and Cooling Coincidence Factors for Sit-down Restaurant

Location	Vintage	Δ HL (kBtu/sf)	Δ CL (kBtu/sf)	Δ LL (kBtu/sf)	HCF	CCF
Charleston	Average	-3.86	-11.64	-16.80	0.230	0.693
Chicago	Average	-7.37	-8.49	-16.81	0.438	0.505
Lake Charles	Average	-2.89	-12.66	-16.80	0.172	0.754
Miami	Average	-0.30	-15.60	-16.80	0.018	0.929
Minneapolis	Average	-8.54	-7.42	-16.81	0.508	0.441
New York	Average	-7.12	-8.67	-16.81	0.424	0.516
Pasadena	Average	-2.95	-12.27	-16.82	0.175	0.729
Phoenix	Average	-2.02	-13.71	-16.81	0.120	0.816
San Francisco	Average	-5.77	-9.09	-16.80	0.343	0.541
Washington	Average	-6.17	-9.65	-16.80	0.367	0.574

Table 16i. Heating and Cooling Coincidence Factors for Supermarket

Location	Vintage	Δ HL (kBtu/sf)	Δ CL (kBtu/sf)	Δ LL (kBtu/sf)	HCF	CCF
Charleston	Current	-2.90	-15.72	-20.90	0.139	0.752
	Old	-3.54	-14.93	-20.90	0.169	0.714
Chicago	Current	-6.23	-12.75	-20.90	0.298	0.610
	Old	-8.76	-10.00	-20.90	0.419	0.478
Lake Charles	Current	-1.49	-17.86	-20.90	0.071	0.855
	Old	-2.48	-16.30	-20.90	0.119	0.780
Miami	Current	-0.08	-20.26	-20.90	0.004	0.969
	Old	-0.15	-20.00	-20.90	0.007	0.957
Minneapolis	Current	-7.74	-11.21	-20.90	0.370	0.536
	Old	-10.46	-8.54	-20.90	0.500	0.409
New York	Current	-5.78	-13.05	-20.90	0.277	0.624
	Old	-8.19	-10.30	-20.90	0.392	0.493
Pasadena	Current	-0.88	-17.83	-20.90	0.042	0.853
	Old	-1.74	-16.17	-20.90	0.083	0.774
Phoenix	Current	-0.70	-19.17	-20.90	0.033	0.917
	Old	-1.73	-17.37	-20.90	0.083	0.831
San Francisco	Current	-2.03	-15.72	-20.90	0.097	0.752
	Old	-4.63	-11.54	-20.90	0.222	0.552
Washington	Current	-4.66	-14.23	-20.90	0.223	0.681
	Old	-7.16	-11.36	-20.90	0.343	0.544

Table 16j. Heating and Cooling Coincidence Factors for Secondary School

Location	Vintage	Δ HL (kBtu/sf)	Δ CL (kBtu/sf)	Δ LL (kBtu/sf)	HCF	CCF
Charleston	Current	-0.86	-3.34	-5.15	0.167	0.649
	Old	-0.94	-3.23	-5.15	0.183	0.627
Chicago	Current	-1.59	-2.72	-5.15	0.309	0.528
	Old	-2.27	-1.91	-5.15	0.441	0.371
Pasadena	Current	-0.39	-3.86	-5.15	0.076	0.750
	Old	-0.54	-3.63	-5.15	0.105	0.705
Lake Charles	Current	-0.56	-3.70	-5.15	0.109	0.718
	Old	-0.75	-3.43	-5.15	0.146	0.666
Miami	Current	-0.04	-4.26	-5.15	0.008	0.827
	Old	-0.04	-4.23	-5.15	0.008	0.821
Minneapolis	Current	-2.06	-2.28	-5.15	0.400	0.443
	Old	-2.63	-1.55	-5.15	0.511	0.301
New York	Current	-1.41	-2.88	-5.15	0.274	0.559
	Old	-2.18	-1.97	-5.15	0.423	0.383
Phoenix	Current	-0.25	-4.06	-5.15	0.049	0.788
	Old	-0.41	-3.79	-5.15	0.080	0.736
San Francisco	Current	-0.77	-3.40	-5.15	0.150	0.660
	Old	-1.21	-2.84	-5.15	0.235	0.551
Washington	Current	-1.11	-3.20	-5.15	0.216	0.621
	Old	-1.88	-2.28	-5.15	0.365	0.443

Figure 1. Heating and Cooling Coincidence Factors for Lighting




Figure 1. Heating and Cooling Coincidence Factors for Lighting (cont.)




Figure 1. Heating and Cooling Coincidence Factors for Lighting (cont.)





Figure 1. Heating and Cooling Coincidence Factors for Lighting (cont.)



CONCLUSIONS

In this study, data characterizing lighting technologies for commercial buildings were developed. Together with data from parallel projects developing data for space conditioning [1], these data facilitate more detailed national level policy analysis using COMMEND 4.0.

Detailed technology representation is currently available only for space-conditioning and lighting end uses in COMMEND 4.0. Extension of such representation to refrigeration and office-equipment end uses is underway by RER.

REFERENCES

- (1) Sezgen, A.O., E.M. Franconi, S.E. Greenberg, J.G. Koomey, and H. Akbari. 1994. *Technology Data Characterizing Space Conditioning in Office Buildings: Application to End-Use Forecasting with COMMEND 4.0*. LBL-34123, Lawrence Berkeley Laboratory, Berkeley, California. May.
- (2) Electric Power Research Institute. 1993. *COMMEND 4.0 User's Guide*. Electric Power Research Institute, Palo Alto, California.
- (3) B.A. Atkinson, J.E. McMahon, E. Mills, P. Chan, T.W. Chan, J.H. Eto, J.D. Jennings, J.G. Koomey, K.W. Lo, M. Lecar, L. Price, F. Rubinstein, O. Sezgen, and T. Wenzel. 1992. *Analysis of Federal Policy Options for Improving U.S. Lighting Energy Efficiency: Commercial and Residential Buildings*. LBL-31469, Lawrence Berkeley Laboratory, Berkeley, California.
- (4) U.S. Department of Energy/ Energy Information Administration. 1992. *Commercial Buildings Energy Consumption Survey: Characteristics of Commercial Buildings 1989*. DOE/EIA-0246(89), U.S. Department of Energy, Washington, D.C.
- (5) U.S. Department of Energy/ Energy Information Administration. 1988. *Non-residential Buildings Energy Consumption Survey: Characteristics of Commercial Buildings 1986*. DOE/EIA-0246(86), U.S. Department of Energy, Washington, D.C.
- (6) U.S. Department of Energy/ Energy Information Administration. 1992. *Lighting in Commercial Buildings*. DOE/EIA-0555(92)/1, U.S. Department of Energy, Washington, D.C.
- (7) Illuminating Engineering Society of North America. 1987. *IES Lighting Handbook 1987: Applications Volume*. Illuminating Engineering Society of North America, New York, N.Y.
- (8) H. Akbari, I. Turiel, J. Eto, K. Heinemeier, B. Lebot, and L. Rainer. 1990. "A Review of Existing Commercial Energy Use Intensity and Load-Shape Studies." *ACEEE 1990 Summer Study on Energy Efficiency in Buildings*, vol. 3, pp3.7-3.18. American Council for an Energy Efficient Economy, Washington, D.C.
- (9) ADM Associates, Inc. 1986. *CEC Commercial On-Site Survey Database, PG&E Selected Sample of Commercial Premises*. ADM Associates, Sacramento, California.
- (10) Lighting Research Institute and Plexus Research. 1991. *Survey and Forecast of Marketplace Supply and Demand for Energy-Efficient Lighting Products*. Phase I Report, Electric Power Research Institute, Palo Alto, California.

(The report contains projected supply and demand of lighting products from surveys of lamp and ballast manufacturers, utility DSM program planners, and lighting maintenance companies.)

- (11) U.S. Department of Commerce, Bureau of Census, 1982 to 1989. *Current Industrial Report Series for Electric Lamps, Fluorescent Lamp Ballasts and Fixtures*. U.S. Department of Commerce, Bureau of Census, Industry Division, Washington, D.C.
- (12) Geller, H.S. and P.M. Miller. 1988. *1988 Lighting Ballast Efficiency Standards: Analysis of Electric and Economic Savings*. American Council for an Energy-Efficient Economy, Washington, D.C.
- (13) Huang, Y.J., H. Akbari, L. Rainer, and R. Ritschard. 1990. *481 Prototypical Commercial Buildings for Twenty Urban Market Areas*. (Technical documentation of building loads data base developed for the GRI Cogeneration Market Assessment Model), LBL-29798, Lawrence Berkeley Laboratory, Berkeley, California.



AIM

Association for Information and Image Management

1100 Wayne Avenue, Suite 1100
Silver Spring, Maryland 20910


301/587 8202

A 3D surface plot showing the relationship between three variables. The vertical axis represents the value of the function, with labels 1.0, 1.1, 1.25, 1.4, 1.6, 1.8, 2.0, 2.2, 2.5, and 2.8. The horizontal axes represent two other variables. The surface is composed of several peaks and valleys, with the highest peaks reaching a value of 2.8 and the lowest valleys reaching a value of 1.0. The plot is rendered with a perspective view, showing the depth of the surface.


A technical drawing of a stepped block. The block is oriented diagonally, showing a series of parallel horizontal lines representing its top surface. The depth of the block increases from left to right. Several dimensions are labeled in black text, each associated with a specific step or feature:

- 1.0: The top-most step.
- 1.1: The second step from the top.
- 1.25: The third step from the top.
- 1.4: The fourth step from the top.
- 1.6: The fifth step from the top.
- 1.8: The sixth step from the top.
- 2.0: The seventh step from the top.
- 2.2: The eighth step from the top.
- 2.5: The ninth step from the top.
- 2.8: The tenth step from the top.
- 3.2: The eleventh step from the top.
- 3.5: The twelfth step from the top.
- 4.1: The thirteenth step from the top.


Centimeter



Inches



MANUFACTURED TO AIIM STANDARDS
BY APPLIED IMAGE, INC.



A vertical stack of three abstract graphic shapes. The top shape is a rectangle divided into four quadrants by a vertical and a horizontal line. The middle shape is a trapezoid with a diagonal line from the top-left to the bottom-right. The bottom shape is a large, thick, dark U-shaped block with a white circular cutout in the center.

DATE
TIME
11/29/94