






**AIIM**

**Association for Information and Image Management**


1100 Wayne Avenue, Suite 1100  
Silver Spring, Maryland 20910  
301/587-8202





**Centimeter**



**Inches**



1.25 1.4 1.6



MANUFACTURED TO AIIM STANDARDS  
BY APPLIED IMAGE, INC.

1 of 2

# Evaluation of Potential Severe Accidents During Low Power and Shutdown Operations at Surry, Unit 1

## Analysis of Core Damage Frequency from Seismic Events During Mid-Loop Operations

---

---

Manuscript Completed: June 1994  
Date Published: August 1994

Prepared by  
R. J. Budnitz, Future Resources Associates, Inc.  
P. R. Davis, PRD Consulting  
M. K. Ravindra, W. H. Tong, EQE International, Inc.

Future Resources Associates, Inc.  
2039 Shattuck Avenue, Suite 402  
Berkeley, CA 94704

PRD Consulting  
P.O. Box 2046  
Sheridan, WY 82801

EQE International, Inc.  
18101 Von Karman Avenue, Suite 400  
Irvine, CA 92715

Prepared for  
Division of Safety Issue Resolution  
Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001  
NRC FIN L1922

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

JP. 100-STERI

## ABSTRACT

Traditionally, probabilistic risk assessments (PRAs) of severe accidents at nuclear power plants have explored accidents initiated during full-power operation. However, in 1989 the U.S. Nuclear Regulatory Commission (NRC) initiated an extensive program to examine carefully the potential risks during low-power and shutdown operations. The program included two parallel projects, one at Brookhaven National Laboratory studying a pressurized water reactor (Surry Unit 1) and the other at Sandia National Laboratories studying a boiling water reactor (Grand Gulf). Both the Brookhaven and Sandia projects have examined only accidents initiated by internal plant faults --- so-called "internal initiators". This project, which has explored the likelihood of seismic-initiated core damage accidents during refueling shutdown conditions, is complementary to the internal-initiator analyses at Brookhaven and Sandia. This report covers the seismic analysis at Surry Unit 1, while a companion report documents the Grand Gulf seismic analysis.

All of the many systems modeling assumptions, component non-seismic failure rates, and human error rates that were used in the internal-initiator study at Surry have been adopted here, so that the results of the two studies can be as comparable as possible. Both the Brookhaven study and this study examine only two shutdown plant operating states (POSs) during refueling outages at Surry, called POS 6 and POS 10, which represent mid-loop operation before and after refueling, respectively. This analysis has been limited to work analogous to a level-1 seismic PRA, in which estimates have been developed for the core-damage frequency from seismic events during POSs 6 and 10. The methodology is almost identical to that used for full-power seismic PRAs, as widely practiced in the nuclear industry.

The results of the analysis are that the core-damage frequency for earthquake-initiated accidents during refueling outages in POS 6 and POS 10 is found to be low in absolute terms, less than  $10^{-6}$ /year. The core-damage frequencies are also low relative to the frequencies during POS 6 and POS 10 for internal initiators, as analyzed in the companion study by Brookhaven.

## TABLE OF CONTENTS

<b>ABSTRACT</b> .....	iii
<b>EXECUTIVE SUMMARY</b> .....	ix
<b>FOREWORD</b> .....	xi
<b>ACKNOWLEDGMENTS</b> .....	xiii
<b>1. INTRODUCTION</b> .....	1-1
1.1 Objective of the Report .....	1-1
1.2 Importance of the Issue .....	1-1
1.3 Scope .....	1-2
1.4 Assumptions .....	1-2
1.5 Organization of the Report .....	1-4
<b>2. SEISMIC RISK ANALYSIS METHODOLOGY</b> .....	2-1
2.1 Seismic Hazard Analysis .....	2-1
2.2 Seismic Fragility Evaluation .....	2-2
2.3 Analysis of Plant Systems and Accident Sequences .....	2-2
2.4 Evaluation of Core Damage Frequency .....	2-3
<b>3. SEISMIC HAZARD ANALYSIS</b> .....	3-1
3.1 EPRI and LLNL Seismic Hazard Studies .....	3-1
<b>4. SYSTEMS ANALYSIS FOR SURRY</b> .....	4-1
4.1 Identification of Accident Sequences .....	4-1
4.1.1 Introduction .....	4-1
4.1.2 Assumptions .....	4-1
4.1.3 BNL Event Tree for POS 6 .....	4-1
4.1.4 Seismic Shutdown Event Tree for POS 6 .....	4-3
4.1.5 BNL Event Tree for POS 10 .....	4-4
4.1.6 Seismic Shutdown Event Tree for POS 10 .....	4-5
4.2 Selection of Components .....	4-6
4.3 Operator Reliability .....	4-7
4.3.1 Human Error as a Function of Acceleration Level .....	4-7
4.3.2 Initial Human Error .....	4-7
4.3.3 Subsequent Human Errors .....	4-8
4.4 Consideration of Outage Duration .....	4-8
4.4.1 Introduction .....	4-8
4.4.2 Plant Outages .....	4-8
4.4.3 Refueling Outage Duration for Surry Unit 1 .....	4-8

5.	<b>SEISMIC FRAGILITY EVALUATION FOR SURRY .....</b>	5-1
5.1	Introduction .....	5-1
5.2	Seismic Walkdown of Surry .....	5-1
5.2.1	General .....	5-1
5.2.2	Walkdown Procedures .....	5-2
5.2.3	Walkdown Documentation .....	5-6
5.2.4	Walkdown Findings.....	5-6
5.3	Seismic Fragility Evaluation .....	5-9
5.3.1	Seismic Fragility Methodology .....	5-9
5.3.2	Surry Seismic Fragilities .....	5-17
5.3.3	Example of Equipment Fragility Evaluation .....	5-19
6.	<b>SEISMIC RISK QUANTIFICATION FOR SURRY .....</b>	6-1
6.1	Base Case .....	6-1
6.2	Sensitivity Studies .....	6-1
6.2.1	Impact of Seismic Hazard.....	6-1
6.2.2	Uncertainty Analyses .....	6-2
6.3	Comparison with CDF from Internal Initiators During Mid-loop Operations and with CDF at Full Power .....	6-2
7.	<b>CONCLUSIONS AND RECOMMENDATIONS .....</b>	7-1
8.	<b>REFERENCES .....</b>	8-1

## LIST OF FIGURES

2-1	Seismic Hazard Curves For a Nuclear Power Plant Site .....	2-4
2-2	Family of Fragility Curves For a Component .....	2-5
2-3	Probability Distribution of Seismically-Induced Severe Core Damage Frequency .....	2-6
3-1	EPRI Seismic Hazard Curves For Surry Site .....	3-2
3-2	LLNL Seismic Hazard Curves For Surry Site .....	3-3
3-3	10,000-Year Return Period Ground Response Spectrum For Surry Site .....	3-4
4-1	Event Tree for POS 6 From BNL Study .....	4-11
4-2	Seismic Event Tree for POS 6 .....	4-12
4-3	Event Tree for POS 10 From BNL Study .....	4-13
4-4	Seismic Event Tree for POS 10 .....	4-14
5.2-1	SEWS of 125V Batteries (3 pages) .....	5-26
5.2-2	SEWS of LHSI Pumps (2 pages) .....	5-29
5.2-3	Masonry Block Walls of 125V Battery Enclosure .....	5-31
5.2-4	Masonry Block Walls of 125V Battery Enclosure .....	5-31
5.2-5	110,000 Gallon Condensate Water Storage Tank Concrete Enclosure ..	5-32
5.2-6	100,000 Gallon Emergency Condensate Makeup Tank .....	5-32
5.2-7	Refueling Water Storage Tank .....	5-33
5.2-8	Trapeze Supported Cable Trays .....	5-33
5.2-9	Floor Supported Cable Trays .....	5-34
5.2-10	LHSI Pump Upper Lateral Support .....	5-35
5.2-11	Lower CCW Heat Exchangers .....	5-36
5.2-12	Upper CCW Heat Exchangers .....	5-36
5.2-13	Anchorage Details at Concrete Pier of Lower CCW Heat Exchanger ..	5-37
5.2-14	Vital Bus Distribution Panel in the Control Room .....	5-37
5.2-15	Typical Battery Rack of 125V Batteries .....	5-38
5.2-16	Live Tank Design Circuit Breakers in the Switchyard .....	5-38
5.2-17	Dead Tank Design Circuit Breakers in the Switchyard .....	5-39
5.2-18	Friction Clip at the Base of Steel Frame Supporting Circuit Breakers .....	5-39
5.3-1	Median, 5% Non-Exceedance, and 95% Non-Exceedance Fragility Curves For a Component .....	5-40
6-1	Surry Boolean Expressions for the Two Plant Operating States .....	6-4

## LIST OF TABLES

4-1	Human Error Rates and Uncertainty Bounds for POS 6 and 10 .....	4-10
4-2	Duration of Surry-1 in Plant Operating States 6 and 10.....	4-10
5.3-1	Surry Low Power PRA Components Seismic Fragilities (3 pages).....	5-23
6-1	POS Frequency Estimates For Surry Plant .....	6-5
6-2	Sensitivity of POS 6 Frequency to Seismic Site Hazard .....	6-5
6-3	Impact of Human Error Rates on POS Annual Frequencies .....	6-6
6-4	Impact of Bus Stub Human Error Rate on POS Annual Frequencies ..	6-6
6-5	Surry: Comparison of CDF for Shutdown vs. Full-Power Conditions and for Seismic Initiators vs. Internal Initiators .....	6-7

## EXECUTIVE SUMMARY

Traditionally, probabilistic risk assessments (PRAs) of severe accidents at nuclear power plants have explored accidents initiated during full-power operation. However, in 1989 the U.S. Nuclear Regulatory Commission (NRC) initiated an extensive program to examine carefully the potential risks during low-power and shutdown operations. The program included two parallel projects, one at Brookhaven National Laboratory studying a pressurized water reactor (Surry Unit 1) and the other at Sandia National Laboratories studying a boiling water reactor (Grand Gulf). Both the Brookhaven and Sandia projects have examined only accidents initiated by postulated internal plant faults --- so-called "internal initiators".

This project, which has explored the likelihood of seismic-initiated core damage accidents during refueling shutdown conditions, is complementary to the internal-initiator analyses at Brookhaven and Sandia. This report covers the seismic analysis at Surry Unit 1, while a companion report documents the Grand Gulf seismic analysis. The project reported here is the second phase of a two-phase effort, the initial phase of which was scoping in character, having been performed primarily to establish if the issue was judged to be important enough to justify the more extensive and more quantitative evaluation reported here.

All of the many systems modeling assumptions, component non-seismic failure rates, and human error rates that were used in the internal-initiator study at Surry have been adopted here, so that the results of the two studies can be as comparable as possible. This study, which is based on key inputs from the Brookhaven study, examines only two shutdown plant operating states (POSSs) during refueling outages at Surry, called POS 6 and POS 10, which represent mid-loop operation during refueling. POS 6 is mid-loop operation before refueling while POS 10 represents mid-loop operation after refueling.

This analysis has been limited to work analogous to a level-1 seismic PRA, in which estimates have been developed for the core-damage frequency from seismic events during POSSs 6 and 10. The methodology is almost identical to that used for full-power seismic PRAs, as widely practiced in the nuclear industry. However, seismic-induced relay chatter is beyond the scope of this analysis. Seismic hazard curves from both the Electric Power Research Institute (EPRI) and the Lawrence Livermore National Laboratory (LLNL) have been used. Assessments of the likelihood of various post-core-damage plant-damage states (level-2 PRA) and of significant radioactive releases (level-3 PRA) are beyond the scope of this evaluation.

The results of the analysis are that the mean core-damage frequency for earthquake-initiated accidents during refueling outages in POS 6 and POS 10 is found to be low in absolute terms, less than  $10^{-6}$ /year. This is true using both the EPRI and the LLNL seismic hazard curves. The reasons for this are (i) Surry's seismic capacity in responding to earthquakes during shutdown is excellent, well above its design basis and similar to its ability to respond to earthquakes during full-power conditions; (ii) the Surry site enjoys one of the least seismically active locations in the United States; (iii) the Surry plant is only in POS 6 and POS 10 (combined) for an average (mean) of 6.6% of the time. The core-damage frequencies are also low relative to the frequencies during POS 6 and POS 10 for internal initiators, as analyzed in the companion study by Brookhaven.

## FOREWORD

### (NUREG/CR-6143 and 6144)

### Low Power and Shutdown Probabilistic Risk Assessment Program

Traditionally, probabilistic risk assessments (PRA) of severe accidents in nuclear power plants have considered initiating events potentially occurring only during full power operation. Some previous screening analyses that were performed for other modes of operation suggested that risks during those modes were small relative to full power operation. However, more recent studies and operational experience have implied that accidents during low power and shutdown could be significant contributors to risk.

During 1989, the Nuclear Regulatory Commission (NRC) initiated an extensive program to carefully examine the potential risks during low power and shutdown operations. The program includes two parallel projects performed by Brookhaven National Laboratory (BNL) and Sandia National Laboratories (SNL), with the seismic analysis performed by Future Resources Associates. Two plants, Surry (pressurized water reactor) and Grand Gulf (boiling water reactor), were selected as the plants to be studied.

The objectives of the program are to assess the risks of severe accidents due to internal events, internal fires, internal floods, and seismic events initiated during plant operational states other than full power operation and to compare the estimated core damage frequencies, important accident sequences and other qualitative and quantitative results with those accidents initiated during full power operation as assessed in NUREG-1150. The scope of the program includes that of a level-3 PRA.

The results of the program are documented in two reports, NUREG/CR-6143 and 6144. The reports are organized as follows:

#### For Grand Gulf:

NUREG/CR-6143 -      Evaluation of Potential Severe Accidents During Low Power and Shutdown Operations at Grand Gulf, Unit 1

Volume 1:	Summary of Results
Volume 2:	Analysis of Core Damage Frequency from Internal Events for Plant Operational State 5 During a Refueling Outage
	Part 1: Main Report
	Part 1A: Sections 1 - 9
	Part 1B: Section 10
	Part 1C: Sections 11 - 14
	Part 2: Internal Events Appendices A to H
	Part 3: Internal Events Appendices I and J
	Part 4: Internal Events Appendices K to M
Volume 3:	Analysis of Core Damage Frequency from Internal Fire Events for Plant Operational State 5 During a Refueling Outage
Volume 4:	Analysis of Core Damage Frequency from Internal Flooding Events for Plant Operational State 5 During a Refueling Outage
Volume 5:	Analysis of Core Damage Frequency from Seismic Events for Plant Operational State 5 During a Refueling Outage
Volume 6:	Evaluation of Severe Accident Risks for Plant Operational State 5 During a Refueling Outage
	Part 1: Main Report
	Part 2: Supporting MELCOR Calculations

## **FOREWORD (continued)**

### **For Surry:**

**NUREG/CR-6144 - Evaluation of Potential Severe Accidents During Low Power and Shutdown Operations at Surry Unit-1**

- Volume 1: Summary of Results**
- Volume 2: Analysis of Core Damage Frequency from Internal Events During Mid-loop Operations**
  - Part 1: Main Report**
    - Part 1A: Chapters 1 - 6**
    - Part 1B: Chapters 7 - 12**
  - Part 2: Internal Events Appendices A to D**
  - Part 3: Internal Events Appendix E**
    - Part 3A: Sections E.1 - E.8**
    - Part 3B: Sections E.9 - E.16**
  - Part 4: Internal Events Appendices F to H**
  - Part 5: Internal Events Appendix I**
- Volume 3: Analysis of Core Damage Frequency from Internal Fires During Mid-loop Operations**
  - Part 1: Main Report**
  - Part 2: Appendices**
- Volume 4: Analysis of Core Damage Frequency from Internal Floods During Mid-loop Operations**
- Volume 5: Analysis of Core Damage Frequency from Seismic Events During Mid-loop Operations**
- Volume 6: Evaluation of Severe Accident Risks During Mid-loop Operations**
  - Part 1: Main Report**
  - Part 2: Appendices**

## ACKNOWLEDGMENTS

This project has been supported by the U.S. Nuclear Regulatory Commission under contract NRC-04-92-058, "PRA Analysis of LWR Low-Power and Shutdown Accidents Initiated by Earthquakes", as a Phase II project under the NRC's Small Business Innovation Research Program. Richard C. Robinson Jr. of NRC's Office of Nuclear Regulatory Research provided technical liaison with the project team.

The project could not have been effectively accomplished without the insights gained from the much larger shutdown-risk projects that have recently been completed under NRC support at Brookhaven National Laboratory (for Surry) and at Sandia National Laboratories (for Grand Gulf). We wish to thank all the many participants in those projects for their excellent work, and in particular Tsong-Lun Chu of Brookhaven and Donnie W. Whitehead of Sandia.

Finally, we wish to thank the staff members at Virginia Electric Power Company's Surry power station for their cooperation, both during our walkdowns of the plant and afterward in furnishing technical information.

# 1. INTRODUCTION

## 1.1 Objective of the Report

This project has explored the likelihood of seismic-initiated core damage accidents during refueling outage conditions at the Surry (Unit 1) and Grand Gulf nuclear power plants. This report documents the Surry analysis, while a companion report documents the Grand Gulf analysis (Ref. FRA/Grand Gulf, 1994). The project reported here is the second phase of a two-phase effort, the initial phase of which (Ref. FRA, 1991) was scoping in character, having been performed primarily to establish if the issue was judged to be important enough to justify the more extensive and more quantitative evaluation reported here. Throughout this report, we will refer to the earlier study as the "Phase-I study" and, where necessary for clarity, this study as the "Phase-II study".

The Phase-I results were preliminary in character, and served principally both to establish that the issue is important enough to merit further study, and to assure the study team that it is fully feasible to adapt the seismic-PRA methodology for full-power seismic PRA to this problem. The findings on both points were favorable enough to justify continuing with this Phase-II project..

## 1.2 Importance of the Issue

The issue of whether the risk of a large core-damage accident is significant when nuclear power plants are in shutdown conditions has received increasing attention in recent years. It is beyond our scope here to summarize the several recent studies of this issue: suffice it to state that the problem has been judged important enough that the U.S. Nuclear Regulatory Commission (NRC) has supported a major shutdown-risk research program for the past three years. The program has examined shutdown risk by performing in-depth probabilistic risk assessments (PRAs) at two U.S. nuclear power plants, Surry Unit 1 and Grand Gulf, and has resulted in significant insights into various safety issues that may arise during shutdown conditions. The Surry study was carried out at Brookhaven National Laboratory, and the Grand Gulf study at Sandia National Laboratories, both under contract to NRC and both using subcontractors to supplement the in-house expertise at the two laboratories.

The results of this effort have recently been published (Ref. BNL, 1994; Sandia, 1994), and the findings are important: the overall core-damage frequency for postulated accidents during the shutdown conditions that were examined is comparable to the core-damage frequency during full power operation.

However, the NRC shutdown-risk projects at Brookhaven and Sandia did not examine risks during shutdown that might arise from earthquake-initiated accidents: they both concentrated on so-called "internal initiators" such as transients, loss-of-coolant accidents, and loss of offsite power. They also both examined scenarios that might arise from internal fires and internal flooding. In the project being reported here for Surry Unit 1, and in the companion project for Grand Gulf, the earthquake-initiator issue has been examined. Both of these projects are fully coordinated with these two larger studies of internal initiators.

## 1.3 Scope

The scope of this effort was limited to an examination of two nuclear power plants: Surry Unit 1, a Westinghouse 3-loop PWR with a subatmospheric containment, and Grand Gulf, a General Electric BWR/6 with a Mark-III containment. Surry-1, owned by Virginia Electric Power Company, is located on a two-unit site in the tidewater region of southeastern Virginia, and has a nearly identical companion unit. Grand Gulf, owned by Entergy Corporation, is located on the Mississippi River in east-central Mississippi, and is alone on its site. There were two principal reasons for selecting these two plants:

- o As mentioned above, both the Surry-1 and the Grand Gulf nuclear stations have been the subject of probabilistic shutdown risk studies (excluding seismic-initiated events) recently completed for the U.S. Nuclear Regulatory Commission. The Surry study was accomplished by Brookhaven National Laboratory (Ref. BNL, 1994), and the Grand Gulf study by Sandia National Laboratories (Ref. Sandia, 1994). Appropriate models, data, and results from these studies were available for direct use in this seismic shutdown risk study. This information proved to be invaluable in completing this analysis.
- o Both Surry (Ref. Breeding et al., 1990) and Grand Gulf (Ref. Brown et al., 1990) have also been the subjects of an extensive risk assessment for full-power conditions sponsored by the Nuclear Regulatory Commission and performed by Sandia National Laboratories, as part of the very large NUREG-1150 PRA study (Ref. NRC/1150, 1990). For Surry (but not for Grand Gulf), this NUREG-1150 analysis included an investigation of seismic-initiated accidents during full power conditions (Ref. Bohn et al., 1990), in which a limited amount of plant-specific seismic fragility information was developed for Surry's components and structures. This information was utilized in part where appropriate.

The NUREG-1150 full-power PRA study covered five plants. Seismic-initiated accidents at full power were analyzed for only two of them, the other (besides Surry) being Peach Bottom Unit 2, a BWR. Parts of the Peach Bottom external-events report (Ref. Lambright et al., 1990) also served as an important source of information for the Phase-I scoping project (Ref. FRA, 1991) that preceded this full-scope project.

While Surry and Grand Gulf were the only plants specifically examined in this study, some seismic-hazard data were examined for other LWR sites in the U.S., and insights relative to the applicability of the Surry results to other plants were developed and are included in this report.

This analysis has been limited to work analogous to a level-1 seismic PRA.

We have developed an estimate for the core-damage frequency from seismic events during certain shutdown operating states. Assessments of the likelihood of various post-core-damage plant-damage states (level-2 PRA) and of significant radioactive releases (level-3 PRA) are beyond the scope of this evaluation.

## 1.4 Assumptions

The following key assumptions have made for this study of Surry Unit 1:

- a. As mentioned, the recent shutdown risk study for Surry Unit 1 (Ref. BNL, 1994) is the principal basis for the systems-analysis parts of our work here: indeed, we could not have

accomplished this work at all without using the other very extensive analysis as our point of departure. The Brookhaven analysis contains numerous assumptions that are necessary to bound the scope and to simplify the detailed work, and we have adopted all of these assumptions without exception. Most importantly, we have adopted directly the loss-of-offsite-power (LOOP) event trees, including the definitions of the top events and underlying thermal-hydraulic and other assumptions that support these event trees, namely those corresponding to mid-loop operation.

b. Only refueling outages have been considered in this seismic analysis. Indeed, only certain specific operating states occurring within the standard refueling outages at Surry have been considered. Outages for other reasons frequently occur at nuclear power plants, and they are of two broad types: controlled shutdowns and uncontrolled (rapid) shutdowns. Although these outages for other reasons can produce the same plant operating states but with configurations unique to the reason for the shutdown, resources in this analysis did not permit examining outage configurations other than those for refueling. In any event, refueling outages contribute a majority of the shutdown time.

c. We assume that the only seismic events of concern are those that cause loss-of-offsite-power (LOOP) transients. Seismic events of lower acceleration than those causing LOOP are expected to have a negligible probability of causing severe plant accidents for two reasons: (i) Critical plant equipment, including the residual heat removal (RHR) system, can withstand significantly higher accelerations than that which is sufficient to cause LOOP (Ref. Bohn et al., 1990; Lambright et al., 1990). Thus, loss of core-cooling capability will have a very low probability for seismic events too small to cause a LOOP. (ii) With offsite power available, sources of water sufficient to cool the core from alternative pumping sources will generally be available even if the RHR system fails.

d. We also assume that seismic-initiated LOOP is non-recoverable in the time frame of interest in this study (from about one to several hours). This is a reasonable and only slightly conservative assumption, because the LOOP initiator is most likely to arise from the seismic-caused failure of the ceramic insulators in the plant substation (Ref. Bohn et al., 1990; Lambright et al., 1990). Replacement of these insulators would likely require several hours at a minimum, and probably much longer. Additionally, other damage caused by the earthquake, for example to offsite transmission systems and offsite switchyards, would likely hamper efforts to recover offsite power.

e. The Brookhaven analysis of internal initiators (Ref. BNL, 1994) used a time-window approach to differentiate different parts of the Plant Operating States that they studied, so as to account better for decay-heat differences within the POSSs. Our seismic analysis has not used this time-window approach, because the distinctions that it embodies are not important for our analysis.

f. The engineering methodology to develop probabilistic seismic fragility curves is described below (Chapter 2). The methodology uses a successive-screening approach, in which structures and equipment that are judged to be very strong under earthquake loading are screened out first, so that the number of items for which actual numerical fragilities must be developed is limited. Also, for a few items the study team was unable to obtain enough information, either because access to some parts of the plants was limited or because engineering information in the appropriate form was not available. For these items, generic fragilities have been used.

g. We have assumed that the seismic failures of identical equipment in similar locations are fully correlated. This means, for example, that when a postulated earthquake causes one diesel generator to fail, we have assumed that the other diesel generator(s) will also fail. This simplifying assumption is probably conservative in many cases, but perhaps not overly so for

truly identical equipment. Sensitivity studies performed in several past seismic PRAs have shown that the bottom-line results are sensitive to this assumption at a level of about a factor of plus-or-minus two.

h. Equipment failure from seismic-induced relay chatter is outside the scope of this analysis. While relay chatter can be important (Ref. Budnitz, Lambert, and Hill, 1987), it is a complicated issue, and the resources to study it were not available within this project. In any event, relay chatter is being studied at every U.S. nuclear plant as part of the current IPREEE program (Ref. Chen et al., 1991), and it is expected that almost all of the relays that are especially sensitive to relay chatter will be identified and, if appropriate, modified in the course of the IPREEE studies.

i. As discussed below (see Chapter 3), we will use both the LLNL and EPRI seismic hazard analyses.

## **1.5 Organization of the Report**

The report is organized into three parts. First, we discuss the methodology used (Chapter 2 --- risk-assessment methodology and Chapter 3 --- seismic hazard analysis inputs). Next, we discuss the analysis and results (Chapters 4, 5, and 6); and then we summarize in Chapter 7 the principal findings of the analysis.

## 2. SEISMIC RISK ANALYSIS METHODOLOGY

The objectives of a full-scope seismic PRA of a nuclear power plant are to estimate the frequencies of occurrence of severe core damage, serious radiological releases, and consequences in terms of early fatalities, long term adverse health effects and property damage, and to identify significant contributors to plant risks. In this study, only a level-1 seismic PRA has been performed, leading only to estimates of the frequency of occurrence of severe core damage.

The key elements of a level-1 seismic PRA are:

1. Seismic hazard analysis - estimation of the frequency of various levels of seismic ground motion (acceleration) occurring at the site.
2. Seismic fragility evaluation - estimation of the conditional probabilities of structural or equipment failure for given levels of ground acceleration.
3. Systems/accident sequence analysis - modeling of the various combinations of structural and equipment failures that could initiate and propagate a seismic core damage accident sequence.
4. Evaluation of core damage frequency - assembly of the results of the seismic hazard, fragility, and systems analyses to estimate the frequencies of core damage for various accident sequences and for the plant as a whole.

In the following subsections, the methods used in each of the above stages of a level-1 seismic PRA are outlined.

### 2.1 Seismic Hazard Analysis

Seismic hazard is usually expressed in terms of the frequency distribution of the peak value of a ground-motion parameter (e.g., peak ground acceleration) during a specified time interval. Somewhat different approaches to implementing the basic methodology are documented in (Bernreuter et al, 1989) and (EPRI, 1989). The different steps of this analysis are as follows:

1. Identification of the sources of earthquakes, such as faults and seismotectonic provinces.
2. Evaluation of the earthquake history of the region to assess the frequencies of occurrence of earthquakes of different magnitudes or epicentral intensities.
3. Development of attenuation relationships to estimate the intensity of earthquake-induced ground motion (e.g., peak ground acceleration) at the site.
4. Integration of the above information to estimate the frequency of exceedance for selected ground motion parameters.

The hazard estimate depends on uncertain estimates of attenuation, upperbound magnitudes, and the geometry and seismic activity of the postulated sources. Such uncertainties are included in the hazard analysis by assigning probabilities or weights to alternative hypotheses

about these parameters. A probability distribution for the frequency of occurrence is thereby developed. The annual frequencies for exceeding specified values of the ground motion parameter are displayed as a family of curves with different weights (Figure 2-1).

A Bayesian estimate of the frequency of exceedance at any peak ground acceleration is obtained as the weighted sum of the frequencies of exceedance at this acceleration given by the different hazard curves; the weighting factor is the probability assigned to each hazard curve.

## 2.2 Seismic Fragility Evaluation

The methodology for evaluating seismic fragilities of structures and equipment is documented in (Ref. Ravindra and Kennedy, 1983) and (Ref. Kennedy and Ravindra, 1984). Seismic fragility of a structure or equipment item is defined as the conditional probability of its failure at a given value of the seismic input or response parameter (e.g., ground acceleration, stress, moment, or spectral acceleration). Seismic fragilities are needed in a PRA to estimate the conditional probabilities of occurrence of initiating events (e.g., loss of offsite power, large LOCA, small LOCA, RPV rupture) and the conditional failure probabilities of different mitigating systems (e.g., safety injection system, residual heat removal system, containment spray system).

The objective of fragility evaluation is to estimate the ground acceleration capacity of a given component. This capacity is defined as the peak ground motion acceleration value at which the seismic response of a given component located at a specified point in the structure exceeds the component's resistance capacity, resulting in its failure. The ground acceleration capacity of the component is estimated using information on plant design bases, responses calculated at the design analysis stage, as-built dimensions, and material properties. Because there are many variables in the estimation of this ground acceleration capacity, component fragility is described by a family of fragility curves; a probability or weighting value is assigned to each curve to reflect the uncertainty in the fragility estimation (Figure 2-2).

## 2.3 Analysis of Plant Systems and Accident Sequences

Frequencies of severe core damage and radioactive release to the environment are calculated by combining plant logic with component fragilities and seismic hazard estimates. Event and fault trees are constructed to identify the accident sequences that may lead to severe core damage and radioactive release.

The plant systems and sequence analyses used in seismic PRAs are based on the PRA Procedures Guide (Ref. NRC, 1983) and can generally be summarized for a level-1 PRA as follows:

1. The analyst constructs event and fault trees reflecting (a) failures of key system components or structures that could initiate an accident sequence and (b) failures of key system components or structures that would be called on to stop the accident sequence.
2. The fragility of each such component (initiators and mitigators) is estimated.
3. Fault trees and event trees are used to develop Boolean expressions for severe core damage that lead to each distinct accident sequence.

As an example, the Boolean expression for severe core damage in the Zion Probabilistic Safety Study (Ref. Zion, 1981) is:

$$\text{Boolean} = 4 + 8 + 10 + 14 + 17 + 21 + (12 + 22 + 26) * 9 \quad (\text{Eq. 2-1})$$

The numbers represent components for which seismic fragilities have been developed, as described earlier. The symbols "+" and "\*" indicate "OR" and "AND" operations, respectively. Plant level fragility curves are obtained by aggregating the fragilities of individual components according to Equation 2-1, using either Monte Carlo simulation or numerical integration. The plant level fragility means the conditional probability of severe core damage for a given peak ground acceleration at the site. The uncertainty in plant level fragility is displayed by developing a family of fragility curves; the weight (probability) assigned to each curve is derived from the fragility curves of components appearing in the specific accident sequence.

## 2.4 Evaluation of Core Damage Frequency

Plant level fragilities are convolved with the seismic hazard curves to obtain a set of doublets for the accident frequency,

$$\{ \langle p_{ij}, f_{ij} \rangle \} \quad (\text{Eq. 2-2})$$

where  $f_{ij}$  is the seismically-induced accident frequency and  $p_{ij}$  is the discrete probability of this frequency,


$$p_{ij} = q_i p_j \quad (\text{Eq. 2-3})$$

$$f_{ij} = f_i(a) \int (dH_j/da) da \quad (\text{Eq. 2-4})$$

Here,  $H_j$  represents the  $j^{\text{th}}$  hazard curve,  $f_i$  the  $i^{\text{th}}$  accident fragility curve;  $q_i$  is the probability associated with the  $i^{\text{th}}$  fragility curve and  $p_j$  is the probability associated with the  $j^{\text{th}}$  hazard curve.


The above equations state that the convolution between the seismic hazard and plant level fragility is carried out by selecting hazard curve  $j$  and fragility curve  $i$ ; the probability assigned to the accident frequency resulting from the convolution is the product of the probabilities  $p_i$  and  $q_j$  assigned to these two curves. The convolution operation given by Equation 2-4 consists of multiplying the occurrence frequency of an earthquake peak ground acceleration between  $a$  and  $a + da$  (obtained as the derivative of  $H_j$  with respect to  $a$ ) with the conditional probability of the accident fragility curve, and integrating such products over the entire range of peak ground accelerations zero to infinity. In this manner, a probabilistic distribution on the frequency of a given accident sequence can be obtained.

Severe core damage occurs if any one of the accident sequences occurs. By probabilistically combining the various sequences, the plant level fragility curves for severe core damage are obtained. Integration of the family of fragility curves over the family of seismic hazard curves yields the probability distribution function of the occurrence frequency of severe core damage (Figure 2-3).



2HD 533nb/SRA-F191

Figure 2-1: Seismic Hazard Curves For A Nuclear Power Plant Site



2HD 533nb/SRA-F194

Figure 2-2: Family of Fragility Curves for a Component




Figure 2-3: Probability Distribution of Seismically-Induced Severe Core Damage Frequency

### 3. SEISMIC HAZARD ANALYSIS

#### 3.1 EPRI and LLNL Seismic Hazard Studies

Seismic hazard curves are needed to estimate the core-damage frequencies of different plant operating states. Typically, a site-specific seismic hazard analysis is performed to obtain the hazard curves. For the Surry site, two such studies have already been conducted and the results are available in a usable form.

Figure 3-1 is the set of seismic hazard curves for the Surry site developed by the Electric Power Research Institute (Ref. EPRI, 1989). Shown are the mean, median, 5th-percentile and 95th-percentile curves. Each curve is the annual probability of exceedance plotted against the peak ground acceleration. Similar curves developed by the Lawrence Livermore National Laboratory (Ref. Bernreuter, et al. 1989) are shown in Figure 3-2. These two sets of hazard curves are used in the seismic risk quantification reported in Chapter 6.

For fragility evaluation, a site-specific ground motion response spectrum is needed. In NUREG-1407 (Ref. Chen et al., 1991), it is recommended that either of the spectral shapes developed in the above EPRI and LLNL studies could be used. The median spectral shape corresponding to a 10,000-year return period along with variability estimates given in the LLNL study (Bernreuter et al., 1989) is suggested for this purpose (Figure 3-3).

Two important considerations arise in the use of these seismic hazard curves. These curves provide estimates of probability of exceedance per year. However, the plant outages only extend for a fraction of the year. This must be taken into account in the estimation of frequencies of different plant operating states during shutdown (See Section 4.4 below). Secondly, the objective of this study is to assess the contribution of the seismic-induced risks in refueling outages and to compare it to the risks from other events during the same refueling outages. It would be interesting to know how the seismic-induced shutdown risk varies from nuclear plant site to site. Towards this end, we have performed sensitivity studies by "moving" the Surry power station to different sites elsewhere in the eastern United States (with different seismic hazard curves) and estimating the impact. This is discussed in Section 6.2.




Figure 3-1: EPRI Seismic Hazard Curves for Surry Site

E.U.S SEISMIC HAZARD CHARACTERIZATION  
LOWER MAGNITUDE OF INTEGRATION IS 5.0  
PERCENTILES = 15., 50. AND 85.





Figure 3-2: LLNL Seismic Hazard Curves for Surry Site

Figure 3-3: 10,000 Year Return Period Ground Response Spectrum for Surry Site



## 4. SYSTEMS ANALYSIS FOR SURRY

### 4.1 Identification of Accident Sequences

#### 4.1.1 Introduction

This section develops the accident sequences which are to be quantified in order to provide an estimate of core damage frequency.

#### 4.1.2 Assumptions

Several assumptions were made at the outset of the study to simplify the analysis and provide meaningful results. These assumptions are as follows:

**4.1.2.1 Loss of offsite power:** It was determined that the only seismic events which are of concern in this study are those which cause loss of offsite power (LOOP). Seismic events of lower ground-motion than those causing LOOP are expected to have a negligible probability of causing severe plant accidents for two reasons. First, critical plant equipment, including the residual heat removal (RHR) system, is designed for significantly higher seismic acceleration than that which is sufficient to cause LOOP. Indeed, as shown in Chapter 5 following, the seismic capacity of the offsite power system is significantly lower than the systems and components necessary to maintain core cooling. Thus, loss of core cooling capability for seismic events less than those causing a LOOP initiating event will have a negligible probability. Second, with offsite power available, sources of water sufficient to cool the core from alternate pumping sources would be available even if the RHR system fails. Thus, only LOOP-initiated accidents are considered in this study.

**4.1.2.2 LOOP recovery:** It has been assumed that seismic-initiated LOOP is non-recoverable in the time frame of interest in this study (from about one to many hours). While this is a slightly conservative assumption, it is considered reasonable because the LOOP initiator is most likely to be failure of the ceramic insulators in the plant substation (see Chapter 5). Replacement of these insulators would very likely require more than a few hours. Furthermore, other damage caused by the earthquake would likely hamper efforts to repair the switchyard. Offsite damage to other parts of the electrical power grid that supplies power to the plant would also be expected, which would likely delay efforts to restore offsite power. Thus, recovery of offsite power is not considered likely after an earthquake large enough to cause LOOP, and has been ignored.

#### 4.1.3 BNL Event Tree for POS 6

In order to develop accident sequences for the study, seismic shutdown event trees were developed based on applicable event trees from the BNL study. These event trees identify the functions and systems which are important in evaluating the progression of accidents during shutdown conditions following the occurrence of a seismic event. As indicated previously, two plant operating states (POSs) are of interest in this study, POS 6 and POS 10. This section considers the POS 6 event tree from the BNL study.

The development of the event trees appropriate for this study involved extracting and modifying the appropriate event trees from the BNL study on shutdown risks (Ref. BNL, 1994), and identifying core damage accident sequences appropriate to a seismic initiated loss of offsite power event. It was determined in the BNL study that plant operating states 6 and 10 during refueling shutdown were the most significant plant states in terms of core damage accident vulnerability. These states involve so-called mid-loop operation wherein the water inventory in the primary system is reduced, which means that less water is available for core cooling if RHR is lost. Further details are provided in the BNL study (Ref. BNL, 1994).

The appropriate event trees from the BNL study are those which examine the accident sequences from LOOP for POSs 6 and 10. The BNL event tree for POS 6 is shown, modified somewhat for clarity, as Figure 4-1. The event headings are defined as follows:

**4.1.3.1 Power to RHR:** This event, following LOOP, is manual connection of the RHR pumps to the stub bus which is powered by the emergency AC power system. The operator must take manual action to connect the RHR pumps to the stub bus. This is an assumption made in the BNL study (Ref. BNL, 1994), and was confirmed during a site visit on October 27 and 28, 1993.

**4.1.3.2 RCS Vent:** This is not technically an event during the accident, but is a preexisting plant condition that is important for subsequent evaluation. According to the BNL study, this vent condition involves removal of three pressurizer safety relief valves for maintenance. A probability of 0.1 was estimated by BNL for this condition based on information from the plant, and this value has been adopted for this seismic analysis. (Actually, BNL used a time-window approach in their analysis for internal initiators, but in this seismic analysis the additional refinement of the time-window approach is not necessary.)

**4.1.3.3 RCVR PWR:** This event is the probability that offsite power would be recovered in time to influence the probability of subsequent events. As noted previously in this section, this event is not considered in the seismic-initiated LOOP case.

**4.1.3.4 F & B Secondary:** This function signifies the feed-and-bleed cooling operation using the steam generators. This activity maintains core cooling by natural circulation of the primary system water through the steam generators. The feed is accomplished normally by auxiliary feedwater, but other water sources may also be available. The bleed operation is through the steam generator relief valves. This cooling mechanism is assumed to be unavailable if the primary system is vented because natural circulation would not occur. This is consistent with the BNL study.

**4.1.3.5 F & B Primary:** In this case, core cooling is provided by feed-and-bleed of the primary. Feed is by one of the high-pressure emergency core cooling injection systems, and bleed is accomplished by venting out the pressurizer (which is already available for the RCS Vent case).

**4.1.3.6 Gravity Feed:** This event is a gravity-feed mode in which appropriate valves are opened to allow water from the refueling water storage tank (RWST) to flow through the low pressure injection system into the primary system. This cooling mode requires that the reactor coolant system be vented, as shown by the event tree logic.

**4.1.3.7 Other Modes:** This event represents the restoration of other modes of decay heat removal capability, for example, feed-and-bleed of the primary system, after gravity feed of RWST inventory has been initially established. Consideration of this event is necessary because the gravity feed mode is not sufficient to provide sufficient cooling beyond a few hours.

#### 4.1.4 Seismic Shutdown Event Tree for POS 6

The BNL event tree for POS 6 for the loss of offsite power event was modified to provide a seismic shutdown event tree which was used in this study to estimate core damage frequency. This modified tree is shown in Figure 4-2. The event tree contains functions (top row) corresponding to the BNL tree, with some modifications to be considered, and also contains equipment associated with each function in the second row. The equipment items identified are judged to be the most fragile component(s) that can cause failure of the associated function. The judgment is based on the results of a previous seismic core damage assessment for Surry at full power conditions (Ref. Bohn et al., 1990) as well as a plant walkdown to examine in detail each system which supports the function. System drawings were also obtained and examined to determine the most fragile critical components for each system. Section 4.2 provides additional information regarding the process used for selecting equipment. Each heading of the event tree will be considered separately, as follows:

**4.1.4.1 LOOP:** This event is loss of offsite power. The most likely mechanism to cause LOOP is failure of the ceramic insulators in the switchyard. This failure mechanism was also identified as the most likely in the previous Surry seismic analysis (Ref. Bohn et al., 1990). If LOOP does not occur, it is assumed that core damage has a negligible probability, and subsequent events are not considered (see previous discussion in Section 4.1.2).

**4.1.4.2 Stub Bus:** This event involves the connection of the stub bus AC power to the RHR pumps. As noted previously, at the Surry plant this requires a manual action by the control room operator. It was determined that the limiting probability for failure of this event would be human error, or failure of the plant operator to connect the RHR pumps. As indicated in the tree, the top branch for this event is for the case where the human error does not occur (the stub bus is successfully connected to the RHR pumps), while the lower branch considers the case where the operator fails to make the connection. The human error modeling for this case is considered in Section 4.3. If the operator fails to connect the RHR pumps to the stub bus, then the RHR function (considered next) is unavailable, as shown on the tree.

**4.1.4.3 RHR:** This event is failure of the Residual Heat Removal function due to seismic failure of RHR components. In this case, it was determined that three critical components had the potential to fail during a seismic event: the component cooling water heat exchanger (which provides cooling to the recirculating RHR system water), the RHR pumps, and the RHR heat exchanger. If the RHR system has not failed because of the seismic failure of any of the components considered, then core damage is avoided unless emergency power (to be considered later) fails, as shown by the tree.

If RHR fails by any of the three component failures, then alternative means of core cooling must be considered, as indicated on the tree.

**4.1.4.4 No RCS Vent:** This event is not affected by the seismic event, but is a pre-existing condition which is important for subsequent events. This condition is the removal of the three pressurizer relief valves as noted in Section 4.1.3.2 above. If the RCS vent condition does not exist (top branch under this heading) then secondary feed-and-bleed is considered as a subsequent core cooling mechanism. However, if the RCS is vented (bottom branch), then secondary feed-and-bleed is not considered because the primary system vent condition is assumed to interrupt the natural circulation cooling in the primary system as indicated in the BNL study.

**4.1.4.5 Secondary F & B:** The secondary feed-and-bleed event is the same as described in Section 4.1.3.4 above for the BNL event tree. The most fragile component supporting this function is the condensate storage tank. No other components were found which had the potential to be significant contributors to failure. However, because this cooling mode requires manual actions, human error is also considered as a failure mechanism. If Secondary F&B is successful (top branch), then core cooling is provided as long as emergency power is available to power the auxiliary feedwater pumps, as indicated in the tree. If Secondary F&B is not successful, then primary feed-and-bleed must be considered as shown.

**4.1.4.6 Primary F & B:** This function, primary feed-and-bleed, is the injection of water into the primary system and venting from the pressurizer as discussed for the BNL event tree in Section 4.1.3.5 above. For this function, the refueling water storage tank (RWST) was found to be the dominant seismic failure mode. However, as with Secondary F&B, this activity requires human action to be successful. Accordingly, human error is also considered. If primary feed-and-bleed is successful, core cooling is maintained as long as emergency power is available (as indicated on the tree). If primary feed-and-bleed fails, then all sequences lead to core damage as shown.

**4.1.4.7 Emergency AC Power:** This event represents the emergency on-site power function. It is provided by the emergency diesel generators. Three failure modes are considered for this event: fuel oil day tank failure, control panel failure, and the motor control centers which distribute the electrical power to various items of equipment. If the AC power function fails, then core damage occurs, as indicated by the tree.

Note that the gravity-feed mode considered in the BNL event tree as discussed in Section 4.1.3.6 is not considered on the seismic shutdown tree for POS 6. This is because the gravity-feed mode requires the RWST as a source of water. If the RWST is available, then the primary feed-and-bleed function is available and would be the preferred method of decay heat removal. Also, as noted in Section 4.1.3.6, success of the gravity-feed mode requires subsequent restoration of some other means of decay heat removal after a few hours. For the seismic event, this is not considered probable because the restoration of equipment failed by a seismic event would likely not be feasible in a short time frame.

The POS 6 Event Tree provides a total of 41 core damage sequences as shown on Figure 4-2.

#### 4.1.5 BNL Event Tree for POS 10

Figure 4-3 illustrates the BNL event tree for a loss of offsite power event when the plant is in POS 10. This figure is taken from BNL's study (Ref. BNL, 1994) and has been modified slightly for clarity. The following events or functions are covered by the tree:

**4.1.5.1 LOOP:** This is the loss of offsite power initiating event.

**4.1.5.2 Power to RHR:** This event covers the possibility of loss of electrical power to the RHR pumps. If power is not lost, the core remains cooled by the RHR system.

**4.1.5.3 RCS Vent:** This is a pre-existing condition which can occur and influence subsequent events. As explained in Section 4.1.3.2, this event covers the case wherein the pressurizer relief valves have been removed, providing a flow path out of the primary system. If vent occurs, then gravity is an option for cooling because the low pressure gravity flow is able to flow through the primary system and out the vent.

**4.1.5.4 Recover PWR:** This event considers the probability that offsite power is recovered in time to provide power to injection pumps for feed-and-bleed cooling of the primary system. If this power is not recovered, then the feed-and-bleed function must consider the availability of emergency power.

**4.1.5.5 F & B Primary:** This event covers the feed-and-bleed mode of cooling the core in the primary system. Emergency core cooling injection pumps are used, and venting is provided by the pressurizer relief valves. They must be manually opened if the RCS Vent function is not a pre-existing condition.

**4.1.5.6 Gravity Feed:** This cooling mode involves gravity flow from the refueling water storage tank (RWST) through the low pressure injection system. As shown on the tree, it is only considered if the primary system has been previously vented by removal of the relief valves because a large primary system opening is necessary to provide sufficient gravity flow.

#### 4.1.6 Seismic Shutdown Event Tree for POS 10

An event tree was developed for POS 10 based on the BNL LOOP event tree, in a manner similar to the development of the seismic shutdown event tree for POS 6. This tree is illustrated in Figure 4-4. The tree provides both a function (top row) and the equipment failures which were found to be important to support each function. As with the POS 6 event tree, the equipment was identified based on fragility and other information from a previous Surry seismic analysis at full power (Ref. Bohn et al., 1990), and a plant walkdown to examine the systems which perform each function. Each event in the tree is discussed in the sub-sections which follow.

**4.1.6.1 LOOP:** This event is loss of offsite power. As discussed in Section 4.1.4.1 preceding, the most likely mechanism to cause LOOP is failure of the ceramic insulators in the switchyard based on an examination of the offsite power system. This failure mechanism was also identified as the most likely in a previous Surry seismic risk analysis (Ref. Bohn et al., 1990). If LOOP does not occur, it is assumed that core damage has a negligible probability, and subsequent events are not considered (see discussion in Sect. 4.1.2.1).

**4.1.6.2 Stub Bus:** This event involves the connection of the stub bus power to the RHR pumps. As noted in Section 4.1.3.1, at the Surry plant this requires a manual action by the control room operator. It was determined that the limiting probability for failure of this event would be human error, or failure of the plant operator to connect the RHR pumps. As indicated in the tree, the top branch for this event is for the case where the human error does not occur (the stub bus is successfully connected to the RHR pumps), while the lower branch considers the case where the operator fails to make the connection. The human error modeling for this case is considered in Section 4.3. If the operator fails to connect the RHR pumps to the stub bus, then the RHR function (considered next) is unavailable, as shown on the tree.

**4.1.6.3 RHR:** This event is failure of the Residual Heat Removal function due to seismic failure of RHR components. As indicated in Section 4.1.4.3, it was determined that three critical components had the potential to fail during a seismic event: the component cooling water heat exchanger (which provides cooling to the recirculating RHR system water), the RHR pumps, and the RHR heat exchanger. If the RHR system has not failed by the seismic failure of any of the components considered, then core damage is avoided unless emergency power (to be considered later) fails, as shown by the tree. If RHR fails by any of the three component failures, then alternative means of core cooling must be considered as indicated on the tree.

**4.1.6.4 No RCS Vent:** This event is not affected by the seismic event, but is a pre-existing condition that is important for subsequent events. This condition is the removal of the three pressurizer relief valves as noted in Section 4.1.4.4 above. If the RCS vent condition does not exist (lower branch under this heading) then gravity feed is considered as a subsequent core cooling mechanism because the large vent area will allow gravity flow through the primary system. However, if the RCS is not vented (bottom branch), then gravity feed is not considered because the primary system would not allow sufficient flow to provide cooling, according to the BNL analysis. This logic is shown on the event tree.

**4.1.6.5 Primary F & B:** This function, primary feed-and-bleed, is the injection of water into the primary system and venting from the pressurizer as discussed in Section 4.1.5.5. For this function, the refueling water storage tank (RWST) was found to be the dominant seismic failure mode. However, this activity requires human action to be successful. Accordingly, human error is considered. If primary feed-and-bleed is successful, core cooling is maintained as long as emergency power is available (as indicated on the tree). If primary feed-and-bleed fails due to seismic failure of the RWST, then all sequences lead to core damage as shown because the gravity-feed cooling event also requires the RWST. If, however, the failure mode of primary feed-and-bleed is a human error with the RWST intact, then gravity feed is considered, as shown on the tree.

Note that secondary feed-and-bleed is not considered on this tree because, according to the BNL study, all three primary coolant loops are isolated in POS 10 such that the steam generators are unavailable.

**4.1.6.6 Emergency AC Power:** This event represents the emergency on-site power function. It is provided by the emergency diesel generators and associated electrical distribution equipment. Three failure modes are considered for this event: fuel oil day tank failure, control panel failure, and the failure of motor control centers that distribute the electrical power to various equipment items. If the AC power function fails, then core damage occurs for all cases except for the case when the RWST is intact and the RCS has been vented, as shown in the tree. In these cases, gravity feed remains as a cooling option.

**4.1.6.7 Gravity Feed:** This event involves manually opening a path between the RWST and the primary system through the low pressure injection system to allow gravity flow through the core and out the pressurizer relief valve openings. Accordingly, this cooling method is only considered if the RWST remains intact following the seismic event, and the primary system has been vented by removal of the pressurizer relief valves.

This cooling mode is considered viable for POS 10 because the decay heat generation rate is lower than for POS 6. According to the BNL study, in POS 10 gravity feed can provide sufficient core cooling acting alone, unlike the condition for POS 6.

The event tree in Figure 4-4 depicts a total of 27 core damage sequences. The quantification of these sequences, as well as those derived in Section 4.1.4 for POS 6, is described in Chapter 6.

## 4.2 Selection of Components

The selection of components involved the following process. First, the functional event trees were derived based on the BNL event trees and associated discussion as given in Section 4.1. From the functional event trees, systems available to perform each function were determined

from the BNL study (Ref. BNL, 1994), a previous Surry seismic risk study (Ref. Bohn et al., 1990), and other information obtained from the plant visit. For each system, components were identified based on system information from the same sources. An initial screening was performed to eliminate components which are known to have high seismic capacity from previous studies and confirmed by a walkdown at the Surry plant. Such components include most valves, most piping, and other components which have been found to be rugged from past seismic evaluations. For those components remaining, a seismic screening capacity evaluation was performed based on information obtained during the plant walkdown, supplemented by system drawings. This evaluation resulted in the elimination of additional components which had high capacity. For the remaining components, a fragility assessment was performed to establish the probability of failure as a function of input acceleration. These components appear in the event trees for POSs 6 and 10 as discussed in Section 4.1. A detailed discussion of the seismic fragility evaluation, as well as a listing of all components examined, is given in Chapter 5.

## 4.3 Operator Reliability

This section describes the operator reliability model that was used when quantifying the accident sequences. The event trees each contain three human errors. For the POS 6 tree (Figure 4-2), the errors are: failure to connect the stub bus to the RHR pumps, failure to initiate secondary feed-and-bleed, and failure to initiate primary feed-and-bleed. For the POS 10 event tree (Figure 4-4), the errors are: failure to connect the stub bus to the RHR pumps, failure to initiate secondary feed-and-bleed, and failure to initiate gravity feed. It is necessary to assign failure (and success) probabilities to these events in order to quantify the trees. The remaining parts of this Section provide the derivation of the human error model.

### 4.3.1 Human Error as a Function of Acceleration Level

It was assumed at the outset that the human error probabilities would be independent of the magnitude of the seismic event. This was done because virtually no data could be found that could be used to relate human error probability to the magnitude of the seismic event. This assumption is considered valid because the dominant core damage contribution comes from a relatively narrow range of accelerations. Thus, the probability of human error would not be expected to vary significantly over this rather narrow range.

### 4.3.2 Initial Human Error

The first human error to be considered is failure of the operator to connect the stub bus to the RHR pumps. This action occurs in both event trees considered in the study. This is a fairly simple task which can be accomplished locally from the Emergency Switchgear Room. However, given the large seismic event which has occurred, coupled with a loss of offsite power, it is obvious this will be an extreme stress situation, with the operator likely to be preoccupied with personal concerns. According to the Brookhaven study (Ref. BNL, 1994), a minimum of 42 minutes is available before boil down of the coolant in the primary system. To establish a human error rate under these conditions, the work of Swain & Guttmann (Ref. Swain & Guttmann, 1980) was used. According to Table 20-26 of this reference, a mean human error probability of 0.1 is estimated, given a high stress condition and 30 minutes to several hours to take action. Thus, it was assumed that 90% of the time, the operator would successfully connect the RHR pumps to the stub bus, and would fail to do so 10% of the time. This value is considered highly uncertain, and is thus the subject of a sensitivity study as documented below in Section 6.2.

### 4.3.3 Subsequent Human Errors

In both the POS 6 and POS 10 event trees (Figures 4-2 and 4-4), human actions need to be considered following the event described in the preceding section. There are two circumstances considered for these subsequent events: human error given that the initial error has been committed, and human error given that the initial error has not been committed. It is considered that if the initial error has been committed, subsequent errors will be more likely than if the initial error has not been committed. Thus, the following model is assumed, based on judgment and information in (Ref. Swain & Guttmann, 1980): If the initial error has not been committed, then all subsequent errors are given a mean probability of 0.01 to account for the expected improved performance after successful completion of the first action. For those actions needed after the first error has been made, it is assumed that the mean error probability remains at 0.1. This is based on the fact that the time available will not increase appreciably, and that additional failures have occurred to equipment which will tend to maintain a high stress condition. Again, these values are considered highly uncertain, and have been subject to a sensitivity study as discussed below in Section 6.2.

In all cases, the human errors derived above are mean values. Uncertainty bounds have been estimated based on judgment and information contained in (Ref. Swain & Guttmann, 1980). The basic human error rates and the uncertainty bounds are provided in Table 4-1.

## 4.4. Consideration of Outage Duration

### 4.4.1 Introduction

This section provides a discussion of the estimated duration, in hours, for the plant operating states of interest in this study. This time interval is important in estimating the annual core damage frequency from seismic events because the estimate must account for the fraction of the time during a given year that the plant is in an operating state of interest.

### 4.4.2 Plant Outages

Only refueling outages were considered in this seismic analysis. Outages for other reasons frequently occur at nuclear power plants, and they are of two broad types: controlled shutdowns and uncontrolled (rapid) shutdowns. These outages, for reasons other than refueling, can produce the same plant operating states but with unique configurations based on the reason for the shutdown. However, this analysis did not examine outage configurations other than those for mid-loop operations during refueling. The reason for this limitation is because it was outside our scope, and because the companion study from which this analysis derived considerable input information (Ref. BNL, 1994) also considered mid-loop states during refueling. In any event, refueling outages contribute a majority of the shutdown time.

### 4.4.3 Refueling Outage Duration for Surry Unit 1

As part of the BNL shutdown risk study (Ref. BNL, 1994), an evaluation was completed to estimate the time that the Surry plant was in various plant operating states during shutdown. In this study, we are interested only in Plant Operating States (POSs) 6 and 10, the mid-loop-operation POS states, because these are the POSs that Brookhaven studied in their internal-events analysis (Ref. BNL, 1994). They are also the most important shutdown states from the standpoint of vulnerability to loss of decay heat removal. POS 6 represents mid-loop operation before refueling, while POS 10 represents mid-loop operation after refueling.


Brookhaven identified two different states for POS 6, which they called R6 and D6 (see Ref. BNL, 1994), but for our purposes here this time-window distinction is not important. Brookhaven also used a time-window approach to account better for decay-heat differences in the POS states, but again this distinction is not important here. Therefore, we will use the summed values for the times per year in refueling-related POS 6 and POS 10. These are found in Table 4-2. Note that the fractions of the time in POS 6 and POS 10 are 5.1% and 1.5%, respectively.

**TABLE 4-1**  
**HUMAN ERROR RATES AND UNCERTAINTY BOUNDS FOR POS 6 AND 10**


<u>ACTIVITY</u>	<u>ERROR RATES</u>		
	5% upper bound	Mean	95% lower bound
A. Stub Bus Connection to RHR Pumps	0.5	0.1	0.02
B. All Subsequent Events Given Failure of A	0.5	0.1	0.02
C. All Subsequent Events Given Success of A	0.1	0.01	0.001

**TABLE 4-2**  
**DURATION OF SURRY-1 IN PLANT OPERATING STATES 6 AND 10**


<u>POS</u>	<u>AVERAGE OUTAGE DURATION</u>	
	Fraction of Year	Hours per Year
POS 6	0.051	444 hr
POS 10	0.015	131 hr



**Figure 4-1: Event Tree for POS 6 from BNL Study  
(modified for clarity)**




**Figure 4-2: Seismic Event Tree for POS 6**



**Figure 4-3: Event Tree for POS 10 from BNL Study  
(modified for clarity)**

LOOP	Stub Bus	RHR			No RCS Vnt	Primary F & B		Emer Pwr	Gravity Fd	
CI	Not HE	CCW Hex	Pumps	RHR Hex	S/R Valves	RWST	Not HE	EDG	RWST	Not HE



**Figure 4-4: Seismic Event Tree for POS 10**

## 5. SEISMIC FRAGILITY EVALUATION FOR SURRY

### 5.1 Introduction

In this Chapter, the details concerning the seismic fragility evaluation for Surry be discussed. Section 5.2 will discuss the seismic walkdown, and Section 5.3 will discuss the seismic fragility evaluation.

### 5.2. Seismic Walkdown of Surry

#### 5.2.1 General

The seismic walkdown of Surry Power Station Unit 1 was performed in October, 1992 and included the following personnel:

Michael Kacmarcik	Virginia Power
William Gallagher	Virginia Power
Thomas Hsu	Virginia Power
Robert Budnitz	Future Resources Associates
Peter Davis	PRD Consulting
M.K. Ravindra	EQE
Wen H. Tong	EQE.

The purposes of the seismic walkdown were to:

1. Pre-screen all equipment items that have sufficiently high seismic capacities.
2. Clearly define the failure modes of components which are not pre-screened. Review and gather detailed information and measurements on equipment and structures for performing seismic fragility evaluations.
3. Identify spatial system interaction (SI) concerns that are judged to be potentially serious problems (such as heavy, questionably secured space heaters or ceiling fixtures over critical batteries, etc.)

One of the primary objectives of the seismic walkdown was to screen all equipment items that are judged to have High Confidence of Low Probability of Failure (HCLPF) capacities higher than 0.3g peak ground acceleration (pga).

Prior to the walkdown, an initial list of components was made available based on the components modeled in the internal event fault trees that were judged to be critical from a seismic standpoint. Using the plant layout drawings the equipment locations were identified. The following provides a list and brief discussion of the structures and equipment identified

as target areas for seismic walkdown review.

**Yard Equipment and Structures:** Yard equipment and structures reviewed during the walkdown included:

- o Auxiliary Building
- o Service Building
- o Safeguards Building
- o Emergency Generator Enclosure
- o Essential Service Water Pumphouse
- o Emergency Condensate Water Storage Tanks
- o Refueling Water Storage Tanks
- o Emergency Condensate Make-up Tanks
- o Underground Fuel Oil Tanks.

A cursory walkdown was performed on the turbine building since only the component cooling water heat exchangers are located in this building. The concrete internal structure and the containment building were not reviewed since both units were in operation. Seismic review of these structures was performed using primarily the as-built structural drawings.

**Equipment:** The Surry plant layout drawings were reviewed prior to the walkdown to locate mechanical and electrical equipment identified on the equipment list. Seismic Evaluation Walkdown Sheets (SEWS) were prepared for each component to record detailed information for fragility evaluation.

All of the major equipment components identified by the system analysts were reviewed during the walkdown in accordance with the procedures discussed in the section below. Generically reviewed components included piping, valves, ducting, cable trays, and instrument racks.

### **5.2.2 Walkdown Procedures**

**5.2.2.1 Structures:** Information necessary for seismic evaluation of civil structures is normally obtained from design drawings rather than walkdowns. Drawings are reviewed to obtain a general understanding of construction and configuration of the structures and to identify any specific data to be obtained during the walkdown. The walkdown of structures is to determine the following:

- o Verify that the structures are in general conformance with the design drawings
- o Identify any gross deficiencies that might result in reduced capacities
- o Confirm that structural separations indicated on the drawings are provided
- o Obtain structural details not available from the drawings.

**5.2.2.2 Equipment:** Components which were reasonably accessible and located in non-radioactive or moderately radioactive environments were reviewed. To assess components in high-radioactive environments, or within contaminated containment, smaller inspection teams and more hurried inspection were employed. For components which were not accessible, the equipment inspection relied on alternate means such as photographic inspection and seismic reanalysis.

In the event that the walkdown team had a reasonable basis for assuming that a group of components is similar and is similarly anchored, then only a single component of this group was inspected. The "similarity-basis" was developed during the walkdown. The one component of each type which was selected was thoroughly inspected. The other components were then reviewed during the walkdown to ensure similarity with the selected unit. Outliers, lack of similarity, anchorage which was different from that shown on drawings or prescribed in the criteria for that component, potential SI problems, situations that are at odds with the team members' past experience, and any other areas of concern were looked for during the walkdown. When such concerns surfaced, the limited sample size of one component of each type for thorough inspection was increased. The increase in sample size which should be inspected depended upon the number of outliers and different anchorages, etc., which were observed. The following provides specific procedures used for the review of different classes of equipment inspected during the walkdown.

**Tanks.** Design drawings for the tanks and their foundations and or supports were reviewed to obtain a general understanding of the tank configurations and anchorage details. Walkdown procedures for the tanks included the following:

- o Verification that the overall tank configuration and anchorage details conform with the design drawings.
- o Review of piping flexibility and other attachments to identify any potential sources of damage due to seismic anchor movement.
- o Inspection of any unique features, which are not common to tanks, but are identified during a review of the drawings.
- o Identification and inspection of potential sources for seismic interaction.

**Pumps.** Historical performance during past earthquakes of horizontal and vertical pumps has shown high seismic capacities. The walkdown procedures concentrated on:

- o Verifying pump and motor anchorage including type of anchorage, foundation configuration and integrity.
- o Reviewing potential nozzle loads and piping flexibility.
- o Identifying interaction potential from attached or adjacent components.

**Heat Exchangers.** Walkdown procedures for heat exchangers concentrated on:

- o Reviewing the supports including support saddles and anchorage details between the saddles and the concrete piers.
- o Reviewing nozzle loads and piping flexibility.
- o Identifying interaction potential from attached or adjacent components.

SEWS sheets were used to record configuration and dimensional data from the walkdown for heat exchanger support, anchorage, and attached or adjacent component interaction potential details that were not available from the plant data reviewed prior to the walkdown.

Diesel Generators. Past performance of diesel generators demonstrates their lower bound capacity levels higher than 0.5g pga. The walkdown procedures concentrated on:

- o Reviewing anchorage and support integrity, noting if any vibration isolators were present.
- o Reviewing the peripherals such as engine control panel, diesel day tank, fuel oil lines, air intake and exhaust ducting, and starting air receiver for positive anchorage.

SEWS sheets were used during the walkdown to record any problem areas encountered.

Electrical Distribution Equipment. Walkdown procedures for electrical distribution equipment included:

- o Reviewing and collecting anchorage details of the cabinet or enclosures for subsequent analytical review.
- o Verifying that the internal instruments and components are positively attached to the cabinet framing or enclosure walls and that the device mountings are not excessively flexible.
- o Identifying any system spatial interaction problems or flood or spray concerns.

Past performance of electrical distribution equipment during earthquakes suggests lower bound seismic capacities to exceed 0.5g pga, providing the equipment and internals, instruments, breakers, contactors, etc., are properly anchored.

HVAC. Two procedures for reviewing the HVAC equipment were used:

- o For HVAC equipment found mounted on vibration isolators, a detailed walkdown review was performed.
- o For HVAC equipment found positively anchored to a supporting structure, an engineering judgmental evaluation was performed and documented during the walkdown.

HVAC equipment positively anchored, as well as vibration isolator supported equipment with positive lateral restraints, have performed well during past earthquakes.

The review for HVAC equipment mounted on vibration isolators included recording the dimensional data and support configuration sufficient to perform an analytical evaluation after the walkdown.

The review of components in the second case included air intake and exhaust dampers, and exhaust fans. The walkdown review assessed anchorage and any seismic deficiencies present in order to judge that the component has a high seismic capacity. The predominant form of documentation for these components was the use of photographs to record the walkdown findings.

HVAC Ducting. The walkdown procedures consisted of two approaches:

- o Inspecting samples of the ducting system selected during the walkdown.

- o Inspecting the ducting in close proximity to the HVAC equipment components reviewed. This includes:
  - i) Vertical and lateral load resisting members of the ducting
  - ii) Any possible anchor point displacements that could impart significant loads to connected ducting

Documentation consisted of noting any anomalies and taking several photographs.

Valves. Walkdown procedures consisted of a review of valves identified in the equipment list. Areas of concern reviewed during the walkdown included observing interaction potential between the valve operator and adjacent structure or component, evaluation of oversized or eccentric operators, and reviewing possible anchor point displacements between piping and valve. SEWS were used to document the walkdowns, and similar valves were reviewed by a less detailed walkby to verify similarity and to verify the absence of a seismic-interaction concern.

Piping. Past seismic PRA studies and earthquake experience data have shown that welded steel piping systems have a very high resistance to seismic loads.

Two piping failure modes that were addressed during the walkdown include:

- o Impacting failures of valve operators
- o Damage to piping caused by the failure of anchorage of attached equipment. The valve clearance issue and the equipment anchorage issue were addressed in the evaluation of the specific equipment component and not as a part of the piping review.

The procedure for walking down the piping system included following the piping layout drawings to verify support locations, assessing system interaction potential to the piping, and noting detailed configuration information for piping details that were judged to be of potential concern. Particular attention was placed on evaluation of nonseismic piping, such as fire protection piping, and potential impacts on critical components.

Cable Trays. Inspection of the cable trays was performed with a general survey of cable tray systems in the plant. This general survey was performed to obtain an overview of cable tray construction throughout the plant. This included a review of the variety of cable tray system layouts, support configurations, and construction details. The inspection also considered items identified as being of potential concern, including failure of taut cables due to large relative displacement, severing of cables caused by sharp edges at the ends of cable trays, and weld failure.

Instrument Racks. Walkdown procedures of instrument racks consisted of:

- o Reviewing and collecting anchorage details of instrument racks supporting instruments.
- o Reviewing and verifying positive attachment of the instruments and components to the racks.
- o Identifying seismic spatial interaction concerns to instrument tubing or air lines due to seismic failure of adjacent equipment.

### **5.2.3 Walkdown Documentation**

Walkdown documentation for equipment and structures consisted of recording the findings using SEWS forms (Figures 5.2-1 and 5.2-2) and photographs (Figures 5.2-3 through 5.2-18). The SEWS forms were developed for each particular class of component indicating specific information required to confirm the high seismic capacity of the component in place as well as to record details sufficient to perform a seismic fragility evaluation if necessary. The SEWS forms reflect the varying levels of information required between different classes of equipment depending on their seismic ruggedness (e.g. pumps require little review other than to verify anchorage and interaction potential whereas HVAC components supported by vibration isolators require a detailed review, and thus a greater amount of information must be recorded for a fragility evaluation).

Photographs were also used to record details of the equipment walkdown review. Photographs provide a permanent record of what was reviewed and support any notes or details taken during the walkdown. System interaction concerns were typically documented with photographs. Additionally, photographs were used in the fragility evaluation to confirm details taken in the walkdown or to provide additional clarification.

### **5.2.4 Walkdown Findings**

#### **5.2.4.1 Structures**

**Safety Related Structures:** The following safety related structures were surveyed during the walkdown:

- o Auxiliary Building
- o Service Building
- o Emergency Generator Enclosure
- o Essential Service Water Pumphouse
- o Safeguards Building.

These structures are constructed of reinforced concrete except the service building which consists of a structural steel superstructure and a reinforced concrete substructure. Information required to develop structural fragilities is obtained primarily from the structural drawings. Thus, the seismic walkdown review of building structures was limited to verification of building separations and identification of block walls which may pose a seismic interaction concern to safety related equipment components.

**Block Walls:** Masonry block walls that are located adjacent to safety related equipment were noted in several places such as the 125V DC battery enclosures (Figures 5.2-3 and 5.2-4), the control room, and the oil storage room of the ESW pumphouse. Seismic retrofits resulting from the I.E. Bulletin No. 80-11 activities were observed at these masonry walls. In the I.E. Bulletin 80-11 reevaluation effort, all safety related masonry block walls in the Category I structures of Surry Station were identified and were modified subsequently as needed.

**Yard Tanks:** Ground mounted storage yard tanks included in the walkdown are the emergency condensate water storage tank (CST), emergency condensate makeup tank, refueling water storage tank (RWST), and underground fuel oil tanks. The CST is a large diameter vertical storage tank completely enclosed in a reinforced concrete structure (Figure 5.2-5). It is

marginally anchored to the concrete foundation with only four (4) anchor bolts. Detailed information for fragility evaluation is obtained from vendor drawings and foundation drawings.

The emergency condensate makeup tank is a 100,000 gallon horizontal tank half-buried and continuously supported on well compacted backfill. The tank is enclosed with a reinforced concrete structure (Figure 5.2-6). The diesel fuel oil storage tanks are horizontal tanks buried underground. The tanks are accessible only through reinforced concrete hatches at the plant grade. Review of these tanks relied on the drawings.

The RWST is a vertical flat bottom storage tank with a nominal radius of 19 feet. The height of the contents is about 47 feet. The tank is sprayed with light weight insulation material (Figure 5.2-7). Thus, details of bolt and bolt chairs were not visible. The adjacent tall vessel, refueling water chemical additive tank, as noted in Figure 5.2-7 is a potential seismic interaction source that could impact the RWST. Details for the RWST fragility evaluation were obtained from vendor drawings and foundation drawings.

#### 5.2.4.2 Equipment

The Surry seismic walkdown reviewed the majority of the equipment components included in the study except RHR pumps and RHR heat exchangers which are located inside the containment. The following provides brief summaries for various classes of equipment reviewed during the walkdown.

**Cable Trays:** Cable tray systems in the plant were sampled. Both trapeze and floor mounted supports were observed as shown in Figure 5.2-8 and 5.2-9. No seismic deficiency was noted.

**Mechanical Equipment:** With few exceptions, the mechanical equipment including piping, valves, pumps, vessels and heat exchangers, was well anchored and appeared rugged in construction. Based on our experience with similar equipment in past earthquakes and in conducting other PRAs, we do not expect mechanical equipment in general to be dominant contributors to seismic risk. Each of the exceptions noted during the seismic walkdown is discussed next.

**Low Head Safety Injection (LHSI) Pumps:** These are long shaft vertical pumps located at Elevation 13 feet of the safeguards building. The pump casing is laterally supported at the top (Elevation 13'-4") and bottom (Elevation -28'-1"). The upper lateral support of the casing consists of a pair of upper and lower steel angle brackets which are anchored to the containment wall as shown in Figure 5.2-10. The Unit 1 pump upper lateral support brackets are attached to the vibration plate of the pump casing by frictional assembly as shown in Figure 5.2-10. The frictional assembly of the Unit 2 pump was observed to be replaced with welds. The effects of differential movements between the containment wall and the safeguards building to the LHSI pumps may be of concern but was not included in this analysis.

**Component Cooling Water Heat Exchangers:** The component cooling water heat exchangers are located at the ground floor of the turbine building. There are four shell and tube type heat exchangers. The upper two exchangers are supported on a heavy braced steel frame as shown in Figures 5.2-11 and 5.2-12. The lower two exchangers are supported on concrete piers as shown in Figure 5.2-13. Seismic retrofits at the interface of the support saddles and the concrete piers were observed as shown in Figure 5.2-13.

**Electrical and Control Equipment:** Some concerns for the following electrical equipment were

Electrical and Control Equipment: Some concerns for the following electrical equipment were noted during the walkdown:

- o 480V Unitrol Motor Control Centers
- o Normal Service Buses A, B, and C.

480-Volt Unitrol Motor Control Centers: The Unitrol MCCs were observed in the emergency switchgear room and the cable vault areas. These MCCs appeared to be well constructed. However, the MCCs were not opened for inspection during the walkdown since they were energized. Thus, mounting of the internal components, bolting of the adjacent cabinets and base anchorage of the MCC cabinets were not inspected. Some MCCs were observed to be backed up against walls. Therefore, welding between the base channels and the steel embeds could not be verified.

Normal Service Buses: These buses are located in the emergency switchgear room in the service building. The cabinets of these buses appeared to be well constructed. However, the anchorage of the cabinets was not verified during the walkdown since the buses were energized.

Control Instrumentation Panels: Various control panels and bench boards are located in the control room. The safety injection and auxiliary feedwater bench boards were observed to have low profiles and anchored to the floor. The vital bus distribution panels (35" high by 20" wide by 6" deep) are wall-mounted units in an area behind the control room panels (Figure 5.2-14). The units appeared to be well mounted. No concern with the control instrumentation panels was noted during the walkdown.

Batteries: All 125V battery banks were reviewed for construction of the battery cells (Exide G), flexibility of the cables, spacers between the cells and between the cells and racks, and construction and anchorage of the battery racks. A typical battery bank reviewed is shown in Figure 5.2-15. All the batteries and battery racks reviewed in the seismic walkdown were found to be well constructed and well anchored. The battery enclosures were constructed of masonry block walls. Retrofits of these walls in response to IE Bulletin No. 80-11 were observed during the walkdown.

Offsite Power: A walkdown review of the switchyard components was performed. Equipment observed in the Surry switchyard is similar to what has been observed by the team members in other east coast power stations. Both the live tank design (Figure 5.2-16) and dead tank design (Figure 5.2-17) circuit breakers were observed in the switchyard. Circuit breakers of live tank design have been found to be susceptible to earthquake damage due to the heavy mass at the top of the porcelain bushing. Furthermore, anchorage of the steel support frames of these circuit breakers to the concrete foundation mat is provided by friction clips as shown in Figure 5.2-18. Heavy equipment anchored by similar friction clips were found to have moved in past earthquakes due to failure of the anchorage.

Seismic Spatial Interactions: Only a few potential seismic spatial interaction (SI) concerns were noted during the seismic walkdown. The SI concerns can be categorized into two groups:

- o Impact of control room control panels or electrical cabinets by an adjacent unanchored bookcase.
- o Impact of 125V battery banks by the masonry block enclosure. Seismic retrofits of these walls were observed in the walkdown such that the SI concerns were judged to be not significant.

## 5.3 Seismic Fragility Evaluation

### 5.3.1 Seismic Fragility Methodology

The seismic fragility of a structure or equipment is defined as the conditional probability of its failure at a given value of peak ground acceleration. The methodology for evaluating the seismic fragilities of structures and equipment is documented in (Ref. Ravindra and Kennedy (1983); PRA Procedures Guide (1983), and Kennedy and Ravindra (1984)). It has been developed and applied in over twenty-five seismic PRAs.

The objective of fragility evaluation is to estimate the ground acceleration capacity of a given component. This capacity is defined as the peak ground acceleration value at which the seismic response of a given component located at a specified point in the structure exceeds the component's resistance, resulting in its failure. The ground acceleration capacity of the component is estimated using information on plant design bases, responses calculated at the design-analysis stage, as-built dimensions, and material properties. The ground acceleration capacity is a random variable which can be described completely by its probability distribution. However, there is uncertainty in the estimation of the parameters of this distribution, the exact shape of this distribution, and in the appropriate failure model for the component. For any postulated failure model and set of parameter values and shape of the probability distribution, a fragility curve depicting the conditional probability of failure as a function of ground acceleration can be obtained. Hence, for different models and parameter assumptions, one could obtain different fragility curves. A satisfactory way to consider these uncertainties is to represent the component fragility by means of a family of fragility curves obtained as above; a subjective probability value is assigned to each curve to reflect the analyst's degree of belief in the model that yielded the particular fragility curve.

At any acceleration value, the component fragility (i.e., conditional probability of failure) varies from 0 to 1; this variation is represented by a subjective probability distribution. On this distribution we can find a fragility value (say, 0.01) that corresponds to the cumulative subjective probability of 5%. We have 5% cumulative subjective probability (confidence) that the fragility is less than 0.01. Similarly, we can find a fragility value for which we have a confidence of 95%. Note that these statements can be made without reference to any probability model. Using this procedure, the median (50%), high (95%), and low (5%) confidence fragility curves can be drawn. On the high confidence curve, we can locate the fragility value of 5%; the acceleration corresponding to this fragility on the high confidence curve is the so called HCLPF (High Confidence Low Probability of Failure) capacity of the component. By characterizing the component fragility through a family of fragility curves, the analyst has expressed all his knowledge about the seismic capacity of the component along with the uncertainties. Given the same information, two analysts with similar experience and expertise would produce approximately the same fragility curves. Development of the family of fragility curves using different failure models and parameters for a large number of components in a seismic PRA is impractical if it is done as described above. Hence, a simple model for the fragility was proposed as described in the above cited references. In the following this fragility model is described.

#### 5.3.1.1 Fragility Model

The entire fragility family for an element corresponding to a particular failure mode can be expressed in terms of the best estimate of the median ground acceleration capacity,  $A_m$ , and

two random variables. Thus, the ground acceleration capacity,  $A$ , is given by

$$A = A_m e_R e_U \quad (\text{Eq. 5.3-1})$$

in which  $e_R$  and  $e_U$  are random variables with unit medians, representing, respectively, the inherent randomness about the median and the uncertainty in the median value. In this model, we assume that both  $e_R$  and  $e_U$  are lognormally distributed with logarithmic standard deviations,  $\beta_R$  and  $\beta_U$ , respectively. The formulation for fragility given by Eq. (5.3-1) and the assumption of lognormal distribution allow easy development of the family of fragility curves which appropriately represents fragility uncertainty. For the quantification of fault trees in the plant system and accident sequence analyses, the uncertainty in fragility needs to be expressed in a range of conditional failure probabilities for a given ground acceleration. This is achieved as explained below:

With perfect knowledge (i.e., only accounting for the random variability,  $\beta_R$ ), the conditional probability of failure,  $f_o$ , for a given peak ground acceleration level,  $a$ , is given by

$$f_o = \Phi [ \ln(a/A_m) / \beta_R ] \quad (\text{Eq. 5.3-2})$$

where  $\Phi(.)$  is the standard Gaussian cumulative distribution function. The relationship between  $f_o$  and  $a$  is the median fragility curve plotted in Figure 5.3-1 for a component with a median ground acceleration capacity  $A_m = 0.87g$  and  $\beta_R = 0.25$ . For the median conditional probability of failure range of 5% to 95%, the ground acceleration capacity would range from 0.58g to 1.31g.

When the modeling uncertainty  $\beta_U$  is included, the fragility becomes a random variable (uncertain). At each acceleration value, the fragility  $f$  can be represented by a subjective probability density function. The subjective probability,  $Q$  (also known as "confidence") of not exceeding a fragility  $f'$  is related to  $f'$  by

$$f' = \Phi [ (\ln(a/A_m + \beta_U \Phi^{-1}(Q)) / \beta_R] \quad (\text{Eq. 5.3-3})$$

where

$$Q = P[f < f' | a] \text{ i.e., the subjective probability (confidence) that the conditional probability of failure, } f, \text{ is less than } f' \text{ for a peak ground acceleration } a$$

$$\Phi^{-1}(.) = \text{the inverse of the standard Gaussian cumulative distribution function.}$$

For example, the conditional probability of failure  $f'$  at acceleration 0.6g that has a 95% nonexceedance subjective probability (confidence) is obtained from Eq. (5.3-3) as 0.79. The 5% to 95% probability (confidence) interval on the failure at 0.6g is 0 to 0.79 with a median value of 0.068 and mean of 0.20. Subsequent computations are made easier by discretizing the random variable probability of failure  $f$  into different intervals and deriving a probability  $q_i$  for each interval (Figure 2-2). Note that the sum of the  $q_i$  probabilities associated with all the intervals is unity. The process develops a family of fragility curves, each with an associated probability  $q_i$ .

The median ground acceleration capacity  $A_m$  and its variability estimates  $\beta_R$  and  $\beta_U$  are evaluated by taking into account the safety margins inherent in capacity predictions, response analysis, and equipment qualification, as explained below.

### 5.3.1.2 Failure Modes

The first step in generating fragility curves such as those in Figure 5.3-1 is to develop a clear definition of what constitutes failure for each of the critical elements in the plant. This definition of failure must be agreeable to both the structural analyst generating the fragility curves and the systems analyst who must judge the consequences of component failure. Several modes of failure (each with a different consequence) may have to be considered and fragility curves may have to be generated for each of these modes. The following definitions of failure are assumed for structures and equipment.

**Structures:** For elements of structures which support safety related equipment, failure is assumed to occur when inelastic deformations due to seismic motions are large enough to potentially affect the operability of equipment or when a concrete wall is cracked sufficiently so that equipment attachments fail. This is a conservative definition of failure of a structure, and is at a lower acceleration level than the acceleration level for total collapse of a building. Considerable margin exists for structural collapse compared to the capacities calculated for failure related to equipment (functional and structural failure modes). Also, a structural failure has been generally assumed to result in a common cause failure of multiple safety systems, housed in the same structure. Structures which are susceptible to sliding are considered to have failed when sufficient sliding deformation has occurred to fail buried or interconnecting piping or electrical duct banks.

**Equipment:** Safety related equipment is assumed to fail when it can no longer perform its function. Failure can be caused by either direct failure (i.e. structural failure) or functional failure due to inertial loads or relative displacement-induced loading, or indirect failure caused by failure of an adjacent structure or component which can fall onto and fail the safety related equipment. Structural failure includes bending, buckling of supports, anchor bolt pullout, etc. Functional failures include binding of valves, excessive deflection, and relay trip or chatter.

It may be possible to identify the failure mode most likely to be caused by the seismic event by reviewing the equipment design and considering only that mode. Otherwise, fragility curves are developed based on the premise that the component could fail in any one of many potential failure modes. Identification of the credible modes of failure is largely based on the analyst's experience and judgment. Review of plant design criteria, calculated stress levels in relation to the allowable limits, qualification test results, seismic fragility evaluation studies done on other plants, and reported failures (in past earthquakes, in licensee event reports and fragility tests) are useful in this task.

Consideration should also be given to the potential for soil failure modes (e.g., liquefaction, toe bearing pressure failure, base slab uplift, and slope failures). For buried equipment (i.e., piping and tanks), failure due to lateral soil pressures may be an important mode. Seismically induced failures of structures or equipment under impact of another structure or equipment (e.g., a crane) may also be a consideration.

### 5.3.1.3 Estimation of Fragility Parameters

In estimating fragility parameters, it is convenient to work in terms of an intermediate random variable called the factor of safety. The factor of safety,  $F$ , on ground acceleration capacity above the safe shutdown earthquake level specified for design,  $A_{SSE}$ , is defined as follows:

$$A = F A_{SSE}$$

$$F = \frac{\text{Actual seismic capacity of element}}{\text{Actual response due to SSE}}$$

$$= \frac{\text{Actual seismic capacity of element}}{\text{Calculated capacity}}$$

$$\times \frac{\text{Calculated capacity}}{\text{Design response due to SSE}}$$

$$\times \frac{\text{Design response due to SSE}}{\text{Actual response due to SSE}}$$

$F$  is further simplified as:

$$F = \frac{\text{Actual seismic capacity of element}}{\text{Design response due to SSE}}$$

$$\times \frac{\text{Design response due to SSE}}{\text{Actual response due to SSE}}$$

$$F = F_C F_{RS} \quad (\text{Eq. 5.3-4})$$

The median factor of safety,  $F_m$ , can be directly related to the median ground acceleration capacity,  $A_m$ , as:

$$F_m = A_m / A_{SSE} \quad (\text{Eq. 5.3-5})$$

The logarithmic standard deviations of  $F$ , representing inherent randomness and uncertainty, are identical to those for the ground acceleration capacity  $A$ .

### 5.3.1.4 Structural fragility

For structures, the factor of safety can be modeled as the product of three random variables:

$$F = F_S F_\mu F_{RS} \quad (\text{Eq. 5.3-6})$$

The strength factor,  $F_S$ , represents the ratio of ultimate strength (or strength at loss-of-function) to the stress calculated for  $A_{SSE}$ . In calculating the value of  $F_S$ , the nonseismic portion of the total load acting on the structure is subtracted from the strength as follows:

$$F_S = (S - P_N) / (P_T - P_N) \quad (\text{Eq. 5.3-7})$$

where  $S$  is the strength of the structural element for the specific failure mode,  $P_N$  is the normal operating load (i.e., dead load, operating temperature load, etc.) and  $P_T$  is the total load on the structure (i.e., sum of the seismic load for ASSE and the normal operating load). For higher earthquake levels, other transients (e.g., SRV discharge, and turbine trip) may have a high probability of occurring simultaneously with the earthquake; the definition of  $P_N$  in such cases should be extended to include the loads from these transients.

The inelastic energy absorption factor (ductility),  $F_\mu$ , accounts for the fact that an earthquake represents a limited energy source and many structures or equipment items are capable of absorbing substantial amounts of energy beyond yield without loss-of-function. A suggested method to determine the deamplification effect resulting from inelastic energy dissipation involves the use of ductility modified response spectra (Ref. Newmark, 1977). The deamplification factor is primarily a function of the ductility ratio  $\mu$  defined as the ratio of maximum displacement to displacement at yield. More recent analyses (Ref. Riddell and Newmark, 1979) have shown the deamplification factor to be a function of system damping. One might estimate a median value of  $\mu$  for low-rise concrete shear walls (typical of auxiliary building walls) of 4.0. The corresponding median  $F_\mu$  value would be 2.4. The variabilities in the inelastic energy absorption factor,  $F_\mu$ , are estimated as  $B_R = 0.21$  and  $B_U = 0.21$ , taking into account the uncertainty in the predicted relationship between  $F_\mu$ ,  $\mu$ , and system damping.

The structure response factor,  $F_{RS}$ , recognizes that in the design analyses structural response was computed using specific (often conservative) deterministic response parameters for the structure. Because many of these parameters are random (often with wide variability) the actual response may differ substantially from the design-calculated response for a given peak ground acceleration.

The structure response factor,  $F_{RS}$ , is modeled as a product of factors influencing the response variability:

$$F_{RS} = F_{SA} F_\phi F_\delta F_M F_{MC} F_{EC} F_{SD} F_{SS}, \quad (\text{Eq. 5.3-8})$$

where

$F_{SA}$  = spectral shape factor representing variability in ground motion and associated ground response spectra

$F_\phi$  = direction factor representing the variability in the two earthquake direction response spectral values about the mean value

$F_\delta$  = damping factor representing variability in response due to difference between actual damping and design damping

$F_M$  = modeling factor accounting for uncertainty in response due to modeling assumptions

$F_{MC}$  = mode combination factor accounting for variability in response due to the method used in combining dynamic modes of response

$F_{EC}$  = earthquake component combination factor accounting for variability in response due to the method used in combining earthquake components

$F_{SD}$  = factor to reflect the reduction with depth of seismic input

$F_{SS}$  = factor to account for the effect of soil-structure interaction

The median and logarithmic standard deviations of  $F$  are expressed as:

$$F_m = F_{Sm} F_{\mu} F_{SAm} F_{\delta_m} F_{Mm} F_{MCm} F_{ECm} F_{SDm} F_{SSm} \quad (\text{Eq. 5.3-9})$$

and

$$\beta_F^2 = (\beta_S^2 + \beta_U^2 + \beta_{SA}^2 + \dots + \beta_{SS}^2)^{1/2} \quad (\text{Eq. 5.3-10})$$

The logarithmic standard deviation  $\beta_F$  is further divided into random variability,  $\beta_R$ , and uncertainty,  $\beta_U$ . To obtain the median ground acceleration capacity  $A_m$  the median factor of safety,  $F_m$ , is multiplied by the safe shutdown earthquake peak ground acceleration.

### 5.3.1.5 Equipment Fragility

For equipment and other components, the factor of safety is composed of a capacity factor,  $F_C$ ; a structure response factor,  $F_{RS}$ ; and an equipment response (relative to the structure) factor,  $F_{RE}$ . Thus,

$$F = F_C F_{RE} F_{RS} \quad (\text{Eq. 5.3-11})$$

The capacity factor  $F_C$  for the equipment is the ratio of the acceleration level at which the equipment ceases to perform its intended function to the seismic design level. This acceleration level could correspond to a breaker tripping in a switchgear, excessive deflection of the control rod drive tubes, or failure of a steam generator support. The capacity factor for the equipment may be calculated as the product of  $F_S$  and  $F_{\mu}$ . The strength factor,  $F_S$ , is calculated using Eq. (5.3-7). The strength,  $S$ , of equipment is a function of the failure mode. Equipment failures can be classified into three categories:

1. Elastic functional failures
2. Brittle failures
3. Ductile failures.

Elastic functional failures involve the loss of intended function while the component is stressed below its yield point. Examples of this type of failure include the following:

- o Elastic buckling in tank walls and component supports
- o Excessive blade deflection in fans
- o Shaft seizure in pumps.

The strength of the component is considered to be the load level at which functional failure occurs.

Brittle failure modes are those which have little or no system inelastic energy absorption capability. Examples include the following:

- o Anchor bolt failures
- o Component support weld failures
- o Shear pin failures.

Each of these failure modes has the ability to absorb some inelastic energy on the component level, but the plastic zone is very localized and the system ductility for an anchor bolt or a support weld is very small. The strength of the component failing in a brittle mode is therefore calculated using the ultimate strength of the material.

Ductile failure modes are those in which the structural system can absorb a significant amount of energy through inelastic deformation. Examples include the following:

- o Pressure boundary failure of piping
- o Structural failure of cable trays and ducting
- o Polar crane failure.

The strength of the component failing in a ductile mode is calculated using the yield strength of the material for tensile loading. For flexural loading, the strength is defined as the limit load or load to develop a plastic hinge.

The inelastic energy absorption factor,  $F_\mu$ , for a piece of equipment is a function of the ductility ratio,  $\mu$ . The median value  $F_\mu$  is considered close to 1.0 for brittle and functional failure modes. For ductile failure modes of equipment that respond in the amplified acceleration region of the design spectrum (i.e., 2 to 8 Hz):

$$F_\mu = e (2\mu - 1)^{1/2} \quad (\text{Eq. 5.3-12})$$

where  $e$  is a random variable reflecting the error in Eq. (5.3-12) and has a median value of 1.0 and a logarithmic standard deviation,  $B_U$ , ranging from 0.02 to 0.10 (increasing with the ductility ratio). For rigid equipment,  $F_\mu$  is given by

$$F_\mu = e \mu^{0.13} \quad (\text{Eq. 5.3-13})$$

Again,  $e$  is a random variable of median equal to 1.0 and logarithmic standard deviation ranging from 0.02 to 0.10.

The median and logarithmic standard deviation of ductility ratios for different equipment are calculated considering recommendations of (Newmark, 1977). This reference gives a range of ductility ratios to be used for design. The upper end of this range might be considered to represent approximately the median value, while the lower end of the range might be estimated at about two logarithmic standard deviations below the median.

The equipment response factor  $F_{RE}$ , is the ratio of equipment response calculated in the design to the realistic equipment response; both responses are calculated for design floor spectra.  $F_{RE}$  is the factor of safety inherent in the computation of equipment response. It depends upon the response characteristics of the equipment and is influenced by some of the variables listed under Eq. (5.3-8). These variables differ according to the seismic qualification procedure. For equipment qualified by dynamic analysis, the important variables that influence response and variability are as follows:

- o Qualification method (QM)
- o Spectral shape (SA) - including the effects of peak broadening and smoothing, and artificial time history generation
- o Modeling (affects mode shape and frequency results) (M)
- o Damping ( $\delta$ )
- o Combination of modal responses (for response spectrum method) (MC)
- o Combination of earthquake components (EC).

For rigid equipment qualified by static analysis, all variables, except the qualification method, are not significant. The equipment response factor is the ratio of the specified static coefficient divided by the zero period acceleration of the floor level where the equipment is mounted. If the equipment is flexible and was designed via the static coefficient method, the dynamic characteristics of the equipment must be considered. This requires estimating the fundamental frequency and damping, if the equipment responds predominantly in one mode. The equipment response factor is the ratio of the static coefficient to the spectral acceleration at the equipment fundamental frequency.

Where testing is conducted for seismic qualification, the response factor must take into account the following:

- o Qualification method (QM)
- o Spectral shape (SA)
- o Boundary conditions in the test versus installation (BC)
- o Damping ( $\delta$ )
- o Spectral test method (sine beat, sine sweep, complex waveform, etc.) (STM)
- o Multi-directional effects (MDE).

The overall equipment response factor is the product of these factors of safety corresponding to each of the variables identified above. The median and logarithmic standard deviations for randomness and uncertainty are estimated following Eqs. (5.3-9) and (5.3-10).

The structural response factor,  $F_{Rs}$ , is based on the response characteristics of the structure at the location of component (equipment) support. The variables pertinent to the structural response analyses used to generate floor spectra for equipment design are the only variables of interest to equipment fragility. Time-history analyses using the same structural models used to conduct structural response analysis for structural design are typically used to generate floor spectra. The applicable variables are as follows:

- o Spectral shape
- o Damping
- o Modeling
- o Soil-structure interaction.

For equipment with a seismic capacity level that has been reached while the structure is still within the elastic range, the structural response factors should be calculated using damping values corresponding to less than yield conditions (e.g., about 5% median damping for reinforced concrete). The combination of earthquake components is not included in the structural response since the variable is to be addressed for specific equipment orientation in the treatment of equipment response.

Median  $F_m$  and variability  $\beta_R$  and  $\beta_U$  estimates are made for each of the parameters affecting capacity and response factors of safety. These median and variability estimates are then combined using the properties of lognormal distributions in accordance with Eqs. (5.3-6), (5.3-8), and (5.3-11) to obtain the overall median factor of safety  $F_m$  and variability  $\beta_R$  and  $\beta_U$  estimates required to define the fragility curves for the structure or equipment. For each variable affecting the factor of safety, the random ( $\beta_R$ ) and uncertainty ( $\beta_U$ ) variabilities must be separately estimated. The differentiation is somewhat judgmental, but it can be based on general guidelines. Essentially,  $\beta_R$  represents variability due to the randomness of the earthquake characteristics for the same acceleration and to the structural response parameters which relate to these characteristics. The dispersion represented by  $\beta_U$  is due to factors such as the following:

- o Our lack of understanding of structural material properties such as strength, inelastic energy absorption, and damping.
- o Errors in calculated response due to use of approximate modeling of the structure and inaccuracies in mass and stiffness representations.
- o Usage of engineering judgment in lieu of complete plant-specific data on fragility levels of equipment capacities, and responses.

For structures such as concrete shear walls, prestressed concrete containment, steel frames, masonry walls, field-erected tanks, and buried structures, the fragility parameters are generally estimated using plant-specific information. For major passive equipment (e.g., reactor pressure vessel, steam generator, reactor coolant pump, recirculation pump, major vessels, heat exchangers, and major piping), it is preferable to develop plant-specific fragilities using original design analyses.

For certain types of passive equipment that are used in very large quantities (e.g., piping and supports, cable trays and supports, HVAC ducting and supports, conduit, and miscellaneous vessels and heat exchangers), it is generally necessary to use generic fragilities. For active equipment, use of a combination of generic and plant-specific information is needed to develop fragilities.

### 5.3.2 Surry Seismic Fragilities

The seismic fragilities of equipment included in the Surry low power probabilistic risk assessment are presented in Table 5.3-1. Selection of these equipment items was discussed in Section 5.2. Detailed discussions of the fragility evaluation are provided in this section. Structural responses (i.e., floor response spectra) generated from the probabilistic response analyses for the Surry IPPEE program were used to develop the equipment fragilities. Fragilities of Category I structures were not included in this study. The previous study (Ref. Bohn et al., 1990) showed that Surry Category I structures generally were not significant seismic risk contributors.

### 5.3.2.1 Median-Centered Response Analysis

The median-centered in-structure response spectra generated from probabilistic response analyses were used for evaluating Surry equipment fragilities. The advantages of using the probabilistic response results for fragility evaluation are:

- o The probabilistic response analysis is based on the best-estimates of input parameters and analysis procedures leading to median estimate of seismic response.
- o Variability in the response resulting from variations in earthquake ground motion (spectral shape), the physical properties of the soil-structure system and the ability to model them are explicitly acknowledged and propagated throughout the analysis.

Detailed discussions of the Surry response analyses can be found in EQE's report (Ref. EQE, 1992). The following information provides a brief summary of the Surry response analyses and their results:

1. Category I structures were modeled as three-dimensional stick models with lumped masses. Eccentricities were explicitly considered in the models. Important structural parameters such as hysteretic damping and natural frequencies varied around their median values to account for uncertainties.
2. Soil-structure interaction effects were considered for all dynamic analyses. For each structure the foundation embedment was considered and frequency dependent impedance and scattering functions were calculated for each strain compatible soil case. Soil parameters varied around their median values to account for uncertainty.
3. Horizontal 10,000 year return period EPRI Uniform Hazard Spectra anchored to 0.15g, 0.30g, and 0.45g were used for input ground motion. Ensembles of thirty earthquake time histories were developed such that the median and the standard deviation of their spectra match the median and the standard deviation of the targets.
4. Median and 84th percentile in-structure response spectra were generated at 5% damping at all major floors of each Category I structure.

The use of Surry in-structure response spectra for developing seismic fragility of an equipment item supported in a Category I structure is illustrated by an example in Section 5.3.3.

### 5.3.2.2 Screening of Equipment

Surry equipment that is inherently seismically rugged was screened from detailed fragility evaluation. Such equipment included all the horizontal motor driven pumps, small shell and tube type heat exchangers, and emergency diesel generators (including peripherals). Screening of equipment was performed following the procedures in (Ref. EPRI, 1988) including the seismic walkdown review and equipment anchorage evaluation. The 84th percentile floor response spectra from the probabilistic response analyses were used for anchorage evaluation. Motor and air operated valves (MOV and AOV) were screened out after the walkdown review confirmed that there were no concerns of excessively high and heavy operator and seismic interaction of soft targets on the valves.

### 5.3.2.3 Generic Equipment Seismic Fragilities

Some equipment items in this study were assigned generic seismic fragilities for the following reasons:

- o Some equipment was not reviewed during the walkdown due to inaccessibility, such as RHR pumps and heat exchangers
- o Some anchorages could not be verified during the walkdown since the equipment was energized and could not be opened. This included the motor control centers and the distribution bus.
- o Some items lacked design information such as as-built drawings for performing fragility evaluation.

For these equipment items, conservatively estimated seismic fragility values which were developed either from limited design information or from a review of (Ref. Bohn et al., 1990) and (Ref. Campbell et al., 1988) were assigned as indicated in Table 5.3-1.

### 5.3.2.4 Surry Specific Equipment Fragilities

For the remaining Surry shutdown components, seismic fragilities were calculated following the methodology discussed in Section 5.2 using information such as walkdown data, design documents, and seismic qualification packages. The seismic demand on equipment was calculated using the median-centered floor response spectra. Since uncertainties in structural damping, modeling (natural frequency) and soil-structure interaction and randomness of earthquake ground motion (i.e. spectral shape) were explicitly included in the probabilistic response analysis, a combined variability,  $B_C$  can be estimated from the median and 84th percentile floor response spectra as shown in the example given in Section 5.3.3. Other variabilities associated with structural response factors such as mode shape, mode combination, and earthquake components combination were individually calculated and incorporated in the final equipment fragilities.

### **5.3.3 Example of Equipment Fragility Evaluation**

In this section, we describe the seismic fragility derivation of the low head safety injection (LHSI) pump. The LHSI pump is a vertical pump located in the Safeguards Building. It consists of a motor, a discharge head, pump shaft, pump column, and a pump casing.

Two lateral supports are provided to the pump casing, i.e., an upper support at Elevation 13'-4" (pump casing attached to the containment wall) and a lower support at Elevation (-) 28'-1" (casing bolted to the Safeguards Building basemat). The upper support consists of a pair of top and a pair of bottom steel brackets (or weldments) which are anchored to the containment wall with Red Head bolts. The pump column is attached to the discharge head flange at the top and is laterally supported by two intermediate lateral restraints at Elevation (-)4'-1" and Elevation (-)24'-1", respectively. The unsupported length of the pump column is about 20 feet.

### Equipment Capacity Factor

**Strength Factor:** The design calculations of the pump were reviewed in the course of the fragility evaluation. Loadings considered for the seismic analysis of the pump included:

- o OBE (horizontal and vertical directions)
- o SSE (horizontal and vertical directions)
- o Dead loads
- o Operating loads
- o Piping loads
- o Containment displacements due to pressure (LOCA) and seismic environments.

The dynamic response spectrum method was used for the seismic analyses. Each of the pump major components including pump column, pump casing, pump shaft, discharge head, motor mounting bolts, pump flange to pump casing bolts, suction and discharge nozzles, and pump column flange bolts, was designed for the loads listed above and the factor of safety (defined as code allowable to demand) was discussed in the design calculations. Based on review of the design calculations, the following components were identified as critical and were evaluated for the fragility development:

- o Discharge head
- o Motor mounting bolts (total of four)
- o Attachment of the upper lateral support to the pump casing.

The strength factor for the most critical failure mode (i.e. motor mounting bolts) is presented next.

The median strength factor ( $F_{Sm}$ ) of the motor mounting bolts was calculated using the original design loads and the best estimate bolt capacities along with the best estimate shear-tension interaction failure criteria for the bolts.

$$F_{Sm} = 1.26$$

$$\beta_R = 0$$

$$\beta_U = 0.13$$

The associated uncertainty included the variation of median bolt material ultimate tensile strength and failure criteria for bolts subject to both tension and shear.

**Ductility Factor:** Because the bolt ultimate failure criteria were used for the strength factor calculation, no more credit is given to the ductility factor. Thus,

$$F_{\mu m} = 1.0$$

$$\beta_R = 0$$

$$\beta_U = 0$$

Thus, the overall equipment capacity factor is

$$F_{Cm} = 1.26$$

$$\beta_R = 0$$

$$\beta_U = 0.13$$

### Equipment Response Factors

Qualification Method: A finite element model was used in the design analysis with proper boundary conditions considered, thus,

$$F_{QMm} = 1.0$$

$$\beta_R = 0$$

$$\beta_U = 0$$

Spectral Shape: The conservatism in the use of design loads for the strength factor calculation was adjusted by comparing the design spectral acceleration level with the 5% damped median-centered floor response spectra at the dominant frequency of the motor.

$$F_{SSm} = 7.66$$

Since the median-centered floor response spectrum was unbroadened and unsmoothed, there is no  $\beta_R$  and  $\beta_U$  associated with peak broadening and smoothing. Variability between the median and the 84th percentile floor response spectra which is associated with the structural response factors is considered separately under the structural response factors.

Damping: The 5% damped median floor response spectrum was used in the spectral shape calculation, thus,

$$F_{\delta m} = 1.0$$

Estimating that 3% damping is  $-1.33\beta$  from the median value

$$\beta_R = 0.19$$

$$\beta_U = 0$$

Modeling: Judging that the model used for the design calculation was detailed and adequate to capture dynamic characteristics of the pump,  $F_M = 1.0$  was assigned. Variabilities associated with the modal frequency and mode shape of the pump are 0.15 and 0.10, respectively. The variability associated with the median response due to uncertainty of the modal frequency was estimated to be 0.08. Thus, the total  $\beta_U = (0.08^2 + 0.10^2)^{1/2} = 0.13$ . Note that  $\beta_R = 0$  since there is no randomness associated with modeling.

Modal Combination: Since the response spectrum method was used and that the modes were combined using the SRSS method,  $F_{MC} = 1.0$ . For the pump motor, the response was judged to be primarily a single mode response. Thus  $\beta_R = 0.05$  (nominal) and  $\beta_U = 0$ .

Earthquake Component Combination: The design loads used in the strength factor calculation were obtained by absolute sum of response from one horizontal earthquake component and the vertical earthquake component. Based on the configuration of the mounting bolts and the contribution of the two horizontal earthquake components to the bolt tensile and shear loads, the median earthquake component combination was estimated to be 0.97. Since conservatism was already included in the estimation of the factor of safety, no value is assigned to  $\beta_R$  to avoid introducing additional conservatism.

Thus, the overall equipment response factor is:

$$F_{ER} = (7.66)(0.97) = 7.43$$

$$\beta_R = 0.05$$

$$\beta_U = 0.23$$

Structural Response Factor: Variabilities of the following structural response factors are estimated by using the median and 84th percentile floor response spectra:

- o Spectral shape (input ground motion)
- o Structural damping
- o Structural modeling (frequency only)
- o Soil-structure interaction.

At the fundamental frequency of the motor (i.e 5.58 Hz), the 5% damped median and 84th spectral accelerations are 0.175g and 0.225g, respectively. Thus,

$$\beta_C = \ln(0.225/0.175) = 0.25$$

The  $\beta_R$  and  $\beta_U$  were estimated to be 0.19 and 0.16, respectively. By combining them with variabilities associated with the mode shape factor and earthquake component combination of the building response, the final  $\beta_R$  and  $\beta_U$  associated with structural response factors were estimated to be 0.20 and 0.22, respectively.

Thus, the median peak ground acceleration capacity of the LHSI pump motor mounting bolts was determined to be:

$$A_m = (1.26)(7.43)(1.0)(0.15g) = 1.40g$$

The variabilities associated with this median PGA capacity were determined to be 0.21 and 0.34, respectively for  $\beta_R$  and  $\beta_U$ , by combining variabilities of equipment capacity factor, equipment response factor and structural response factors (using Equation 5.3-10).

Table 5.3-1  
SURRY LOW POWER PRA COMPONENTS SEISMIC FRAGILITIES

COMPONENT ID	COMPONENT DESCRIPTION	$A_m$ (g)	$\beta_R$	$\beta_U$	HCLPF (g)	COMMENTS
RHRP	RHR PUMPS	1.40	0.25	0.35	0.52	Conservatively estimated median capacity with generic variabilities.
RHRHEX	RHR HEAT EXCHANGERS	2.00	0.25	0.35	0.74	Conservatively estimated median capacity with generic variabilities.
1-CC-P-1A/B	Component Cooling Pumps	--	--	--	0.30	Screened per EPRI NP-6041.
CCWHEX	CCW Heat Exchangers	0.96	0.20	0.27	0.34	Surry specific fragility.
1-CH-P-1A/B/C	Charging Pumps	--	--	--	--	Screened per EPRI NP-6041.
MOV1115-B/D	Charging Pump Suction from RWST	--	--	--	--	Screened per EPRI NP-6041.
MOV1867-C/D	MOVs	--	--	--	--	Screened per EPRI NP-6041.
MOV1842-	MOV	--	--	--	--	Screened per EPRI NP-6041.
RWST	Refueling Water Storage Tank	0.75	0.21	0.35	0.30	Surry specific fragility.
MDPSW10A/B	Pumps	--	--	--	--	Screened per EPRI NP-6041.
MDPCC2A/B	Pumps	--	--	--	--	Screened per EPRI NP-6041.
SW108A/B/C	AOVs	--	--	--	--	Screened per EPRI NP-6041.

Table 5.3-1 (Continued)

## SURRY LOW POWER PRA COMPONENTS SEISMIC FRAGILITIES

COMPONENT ID	COMPONENT DESCRIPTION	$A_m$ (g)	$\beta_R$	$\beta_U$	HCLPF (g)	COMMENTS
HXCH5A/B/C	Heat Exchangers	--	--	--	--	Screened per EPRI NP-6041.
HXCH7 A to F	Heat Exchangers	--	--	--	--	Screened per EPRI NP-6041.
HXSW1A/B	Heat Exchangers	--	--	--	--	Screened per EPRI NP-6041.
MDPS11	LHSI Pumps	1.40	0.21	0.34	0.56	Surry specific fragility.
1864A/B	MOVs	--	--	--	--	Screened per EPRI NP-6041.
DG1&3	Emergency Diesel Generators	--	--	--	--	Screened per EPRI NP-6041.
1-CS-P-1A	Containment Spray Pump	--	--	--	--	Screened per EPRI NP-6041.
1-EE-TK-3	Fuel Oil Day Tank	>2.0	--	--	--	High median seismic capacity (>2g) was calculated.
DG1&3	Diesel Fuel Oil Tanks	--	--	--	--	Screened per EPRI NP-6041.
CNTRL-PNL	Control Panels	1.10	0.21	0.31	0.47	Surry specific fragility.
BATTERIES	Batteries	2.20	0.25	0.35	0.82	Fragility of Batteries 1A/B is assumed for DG batteries.
AIR-ACCUM	Air Accumulators	1.20	0.21	0.31	0.51	Conservatively estimated capacity.

Table 5.3-1 (Continued)  
SURRY LOW POWER PRA COMPONENTS SEISMIC FRAGILITIES

COMPONENT ID	COMPONENT DESCRIPTION	$A_m$ (g)	$\beta_R$	$\beta_U$	HCLPF (g)	COMMENTS
1H1-12	MCCs	0.70	0.25	0.35	0.26	Generic median capacity from NUREG-1150.
1J1-12	MCCs	0.70	0.25	0.35	0.26	Generic median capacity from NUREG-1150.
Bus A/B	DC Bus	0.70	0.25	0.35	0.26	Generic median capacity from NUREG-1150.
Battery 1A/B	Batteries	2.20	0.25	0.35	0.82	Surry specific fragility.
1864A/B	MOVs	--	--	--	--	Screened per EPRI NP-6041.
1-FW-P-3A/B	Motor Driven Aux Feed Pumps	--	--	--	--	Screened per EPRI NP-6041.
CST	Emergency Condensate Storage Tanks	0.46	0.21	0.35	0.18	Surry specific fragility.
Offsite Power	Offsite power	0.30	0.25	0.35	0.11	Generic values.

Status Y N U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 3

Surry

Equip. ID No. 1-EPD-B-1AEquip. Class 15 - Batteries on RacksEquipment Description EE/125V BATTERY 1ALocation: Bldg. SERVICE Floor El. 9.5' Room, Row/Col EMER SWGRManufacturer, Model, Etc. (optional) Exide G

30 11:04 (corner of the battery room)

SEISMIC CAPACITY VS DEMAND

1. Elevation where equipment receives seismic input
2. Elevation of seismic input below about 40' from grade
3. Equipment has fundamental frequency above about 8 Hz
4. Capacity based on: Existing Documentation  
Bounding Spectrum  
GERS
5. Demand based on: Ground Response Spectrum  
1.5 x Bounding Spectrum  
Conserv. Des. In-Str. Resp. Spec.  
Realistic M-Ctr. In-Str. Resp. Spec.

	9.5'
<input checked="" type="checkbox"/>	N U
<input type="checkbox"/>	N U <u>(N/A)</u>
DOC	
BS	
GERS	
GRS	
ABS	
CRS	
RRS	

Does capacity exceed demand? Y N UCAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

1. Equipment is included in earthquake experience equipment class
2. Plates of the cells are of lead-calcium flat-plate, Planté or of Manchex design
3. Each individual battery weighs less than 450 lbs ?
4. Close-fitting, crush resistant spacers fill two-thirds of vertical space between cells crushable foam <sup>use and</sup>
5. Cells restrained by end and side rails
6. Racks have longitudinal cross bracing
7. Wood racks evaluated to industry accepted standards
8. Batteries greater than 10 years old specifically evaluated for aging effects
9. Anchorage adequate (See checklist below for details)
10. Have you looked for and found no other adverse concerns?

<input checked="" type="checkbox"/>	N	U	N/A
<input checked="" type="checkbox"/>	N	U	N/A
<input checked="" type="checkbox"/>	N	U	N/A
<input checked="" type="checkbox"/>	N	U	N/A
<input checked="" type="checkbox"/>	N	U	N/A
<input checked="" type="checkbox"/>	N	U	N/A
<input checked="" type="checkbox"/>	N	U	N/A
<input checked="" type="checkbox"/>	N	U	N/A
<input checked="" type="checkbox"/>	N	U	N/A
<input checked="" type="checkbox"/>	N	U	N/A

Is the intent of all the caveats met for Bounding Spectrum? Y N U N/ACAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

1. Equipment is included in generic seismic testing equipment class
2. Meets all Bounding Spectrum caveats
3. Plates of the cells are of lead-calcium flat-plate design (i.e., not Manchex design)

<input type="checkbox"/>	N	U	N/A
<input type="checkbox"/>	N	U	N/A
<input type="checkbox"/>	N	U	N/A

\* For 5-bay battery assembly - 3 crushable foams were present.

3 " " " - 2 " " " - " "

Figure 5.2-1: SEWS of 125V Batteries

Surry

Equip. ID No. 1-EPD-B-1A      Equip. Class 15 - Batteries on RacksEquipment Description EE/125V BATTERY 1ACAVEATS - GERS (Cont'd)

4. Batteries supported on two-step racks or single-tier racks; restrained by double side and end rails which are symmetrically located with respect to the cell center-of-gravity

Is the intent of all the caveats met for GERS?

Y N U N/A

Y N U (N/A)

ANCHORAGE

- Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)
- Type of anchorage covered by GIP Hilti -Kwik
- Sizes and locations of anchors determined
- Adequacy of anchorage installation evaluated (weld quality and length, nuts and washers, expansion anchor tightness, etc.)
- Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking
- For bolted anchorages, gap under base less than 1/4-inch
- Base has adequate stiffness and effect of prying action on anchors considered
- Strength of equipment base and load path to CG adequate
- Embedded steel, grout pad or large concrete pad adequacy evaluated anchored directly to floor slab.

 N U N/A  
 N U N/A  
 N U N/A

Y N U (N/A)

 N U N/A  
 N U N/A  
 N U N/A

 N U N/A  
 N U N/A  
 N U N/A

 N U (N/A) Y N U
INTERACTION EFFECTS

- Soft targets free from impact by nearby equipment or structures
- Attached lines have adequate flexibility
- Overhead equipment or distribution systems are not likely to collapse
- Have you looked for and found no other adverse concerns?

Is equipment free of interaction effects?

 N U N/A  
 N U N/A

 N U N/A  
 N U N/A

(Y) N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

Y (N) U

\* Eccentricity between the post and the welds at the base needs to be considered in the anchorage evaluation (see sketch next sheet)

\*\* Seismic retrofits to the block walls were noted. See next sheet.

See notes made to the drawings



Figure 5.2-1: (Continued)

SARRY

Equip. ID No. 1-EPD-B-1A

Equip. Class 15 - Batteries on Racks

Equipment Description EE/125V BATTERY 1A

COMMENTSBattery EnclosureBattery Rack

Evaluated by: de zeeuw Tong  
McAske


Date: 6/30/936/30/93

Figure 5.2-1: (Continued)

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 2

Surry 2-SI-P-1A/18

Equip. ID No. 1-SI-P-1A <sup>8</sup> Equip. Class 6 - Vertical Pumps

Equipment Description SI / LH SI Pump 1A

Location: Bldg. SFGD Floor El. 12.8' Room, Row/Col Spray Pump

Manufacturer, Model, Etc. (optional) Byron Jackson Pump (Dwg 2C 4718) Turbine Pump

Horsepower/Motor Rating (opt.) RPM (opt.) 1750 Head (opt.) 3000 Flow Rate (opt.) GPM

SEISMIC CAPACITY VS DEMAND

1. Elevation where equipment receives seismic input	12.8'	
2. Elevation of seismic input below about 40' from grade	<input checked="" type="radio"/> Y	N U
3. Equipment has fundamental frequency above about 8 Hz	Y	N U <u>N/A</u>
4. Capacity based on: Existing Documentation	DOC	
Bounding Spectrum	BS	
5. Demand based on:	GRS	
Ground Response Spectrum	ABS	
1.5 x Bounding Spectrum	CRS	
Conserv. Des. In-Str. Resp. Spec.	RRS	
Realistic M-Ctr. In-Str. Resp. Spec.		

Does capacity exceed demand?  Y N U

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

1. Equipment is included in earthquake experience equipment class	<input checked="" type="radio"/> Y	N U N/A
2. Casing and impeller shaft not cantilevered more than 20 feet, with radial bearing at bottom to support shaft	Y	N <u>U</u> <sup>(1)</sup> N/A
3. No risk of excessive nozzle loads such as gross pipe motion or differential displacement	<input checked="" type="radio"/> Y	N U N/A
4. Attached lines (cooling, air, electrical) have adequate flexibility	<input checked="" type="radio"/> Y	N U N/A
5. Anchorage adequate (See checklist below for details)	Y	N <u>U</u> N/A <sup>(1)</sup> <sup>(2)</sup>
6. Relays mounted on equipment evaluated	Y	N U <u>N/A</u>
7. Have you looked for and found no other adverse concerns?	<input checked="" type="radio"/> Y	N U N/A

Is the intent of all the caveats met for Bounding Spectrum?  Y N U N/A

ANCHORAGE

1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)	<input checked="" type="radio"/> Y	N U N/A
2. Type of anchorage covered by GIP	<input checked="" type="radio"/> Y	N U N/A
3. Sizes and locations of anchors determined	<input checked="" type="radio"/> Y	N U N/A
4. Adequacy of anchorage installation evaluated (weld quality and length, nuts and washers, expansion anchor tightness, etc.)	<input checked="" type="radio"/> Y	N U N/A

Figure 5.2-2: SEWS of LHSI Pumps

Surry  
quip. ID No. 1-SI-P-1A Equip. Class 6 - Vertical Pumps

Equipment Description SI/LHSI Pump 1A

ANCHORAGE (Cont'd)

5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking
6. For bolted anchorages, gap under base less than 1/4-inch
7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors
8. Base has adequate stiffness and effect of prying action on anchors considered
9. Strength of equipment base and load path to CG adequate
10. Embedded steel, grout pad or large concrete pad adequacy evaluated

Are anchorage requirements met?

Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A

INTERACTION EFFECTS

1. Soft targets free from impact by nearby equipment or structures
2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures
3. Attached lines have adequate flexibility
4. Overhead equipment or distribution systems are not likely to collapse
5. Have you looked for and found no other adverse concerns?

Is equipment free of interaction effects?

Y	N	U	( <sup>3</sup> )	N/A
Y	N	U	N/A	Y N U
Y	N	U	N/A	Y N U
Y	N	U	N/A	Y N U
Y	N	U	N/A	Y N U



IS EQUIPMENT SEISMICALLY ADEQUATE?

\*\* The bottom brackets are welded to the ring plate. This would result in all loads dumped to the bottom brackets.

Y N U

COMMENTS

1. Perform a review of drawings and design analysis
2. Review vertical support details (ring plate does not provide vert. support.)
3. Overhead missile shield
4. One nut is observed missing at the well bracket that support a tubing (3014:51) (1-SI-P-1A only)
5. Seismic brackets and ring plate attachment bolts were observed removed at 2-SI-P-1B.

Evaluated by: John Jones Figure 5.2-2: (Continued)

6. Review anchorage at the following locations

2HD 688nb/Surrych5

- Attachment of the bracket to the containment wall
- Attachment of the bracket to the ring plate
- Attachment between the motor & the casing.




Figure 5.2-3: Masonry Block Walls of 125V Battery Enclosure




Figure 5.2-4: Masonry Block Walls of 125V Battery Enclosure




Figure 5.2-5: 110,000 Gallon Condensate Water Storage Tank Concrete Enclosure




Figure 5.2-6: 100,000 Gallon Emergency Condensate Makeup Tank




Figure 5.2-7: Refueling Water Storage Tank



Figure 5.2-8: Trapeze Supported Cable Trays





Figure 5.2-9: Floor Supported Cable Trays

Figure 5.2-10: LHSI Pump Upper Lateral Support






Figure 5.2-11: Lower CCW Heat Exchangers




Figure 5.2-12: Upper CCW Heat Exchangers




Figure 5.2-13: Anchorage Details at the Concrete Pier of Lower CCW Heat Exchanger



Figure 5.2-14: Vital Bus Distribution Panel in the Control Room



Figure 5.2-15: Typical Battery Rack of 125V Batteries




Figure 5.2-16: Live Tank Design Circuit Breakers in the Switchyard




Figure 5.2-17: Dead Tank Design Circuit Breakers in the Switchyard



Figure 5.2-18: Friction Clip at the Base of Steel Frame Supporting Circuit Breakers




Figure 5.3-1: Median, 5% Non-Exceedance, and 95% Non-Exceedance Fragility Curves For a Component

## 6. SEISMIC RISK QUANTIFICATION FOR SURRY

### 6.1 Base Case

The key elements of seismic risk quantification are seismic hazard analysis (Chapter 3), systems analysis (Chapter 4) and seismic fragility evaluation (Chapter 5). In this Chapter, these are assembled together to obtain estimates of the frequencies of different plant operating states.

In Chapter 4, two plant operating states were studied, because they were selected by the Brookhaven team (Ref. BNL, 1994) for analysis for internal initiators during shutdown. Based on the event trees described in Chapter 4, we have developed the Boolean equations for these plant operating states, and they are shown in Figure 1.

Note that the basic events in these Boolean equations are seismic-induced failures and human errors. The seismic fragilities of components appearing as basic events have been estimated as described in Chapter 5. The human error rates have been discussed in Chapter 4.

The seismic quantification, using the methodology described in Chapter 2, was done using the software package EQESRA (proprietary to EQE International Inc.) which takes as input the family of seismic hazard curves and the family of seismic fragility curves for all components appearing in the Boolean equations along with the probability distribution of human error rates. The component failures are treated as statistically independent in the computations.

Table 6-1 shows the base case results. The base case consists of the Surry plant (systems and fragilities) at the Surry site with EPRI and LLNL seismic hazard curves. In Table 6-1, the mean, median, 5 percentile and 95 percentile frequencies of the two plant operating states are shown. It is seen from the table that mean annual frequency of the two plant operating states is less than  $10^{-6}$  per year using either the LLNL or the EPRI seismic hazard curves. Therefore, we conclude that the seismic contribution to mean annual core damage frequency during both POS 6 and POS 10 is very small at Surry Unit 1.

### 6.2 Sensitivity Studies

In the following, we describe the sensitivity studies conducted to assess the robustness of the insights obtained in this analysis.

#### 6.2.1 Impact of Seismic Hazard

Since one objective of this study is to derive generic conclusions on the significance of seismic events to shutdown risks, it is of interest to know how the seismic core damage frequency would vary with the site location. For this purpose, we assumed that the Surry plant could be at a site with a seismic hazard typical of the ensemble of nuclear power plants in the eastern United States. The Zion nuclear power plant site in Illinois was chosen. To study the effect for the plant with one of the highest seismic hazards in the eastern U.S., we chose the Pilgrim site in Massachusetts. Table 6-2 compares the frequency of plant operating state POS 6 for the two sites with that at Surry site.

It can be seen from the Table that the core-damage frequency would be a factor of about 1.8 higher if the Surry plant were located at Zion, and slightly more than a factor of 10 higher if it were located at the Pilgrim site.

### 6.2.2 Uncertainty Analyses

In the following, we describe the analyses performed to treat the uncertainties in human actions.

**6.2.2.1 Human Actions:** Human error rates and uncertainty bounds for different operator actions were discussed in Section 4.3. The error rates given in Table 4-1 were used in the risk quantification described above (Sections 6.1 and 6.2.1). In order to study the sensitivity of these results, we have assumed that the 95% upper bound human-error rates used in the base case are constant (deterministic) values and we have used these in this sensitivity study.

Table 6-3 shows the results of increased human error rates: for both POS 6 and POS 10, the increase in core-damage frequency is a factor of about 7.5.

**6.2.2.2 Human Error Performing the Stub Bus Connection:** A somewhat unique feature of Surry is the manual connection of the RHR pumps to the stub bus which is powered by the emergency AC power system following the loss of offsite power. For other plants, this connection is done automatically with a resultant increase in reliability and decreased sensitivity to human error. In order to examine the impact of this manual stub bus connection, we performed a sensitivity study wherein the human error in this operation was assumed to be the lower bound of the base case (i.e., 0.02). Table 6-4 compares the revised mean annual frequencies of the two plant operating states (POS 6 and POS 10) with the base case results. It is seen that the seismic contribution to the shutdown risk is much lower: for both POS 6 and POS 10, the reduction in core-damage frequency is a factor of slightly less than 5.

## 6.3 Comparison with CDF from Internal Initiators During Mid-loop Operations and with CDF at Full Power

It is instructive to compare the results for annual core-damage frequency (CDF) from this study with the CDF during shutdown arising from so-called "internal initiators", which has been analyzed by Brookhaven National Laboratory (Ref. BNL, 1994). Also instructive is a comparison with the NUREG-1150 findings for CDF at Surry for full-power operation.

The comparison of core-damage-frequency results is shown in Table 6.5. From examining the table, several important observations emerge:

- o During shutdown conditions (in POS 6 + POS 10 combined), the total annual mean CDF arising from earthquakes is small compared to the CDF arising from internal initiators from (Ref. BNL, 1994): a factor of about 15 smaller for the LLNL seismic hazard curves and a factor of about 60 smaller using the EPRI hazard curves.
- o The seismic mean CDF during shutdown (in POS 6 + POS 10 combined) is small compared to the mean CDF at full power from seismic initiators from (Ref. Bohn, 1990): a factor of about 350 times smaller for the LLNL hazard curves and about 300 times smaller for the EPRI hazard curves.

- o The Error Factor (EF) in this seismic study is significantly greater than the EF in Brookhaven's analysis of CDF from internal initiators during shutdown (POS 6 plus POS 10). This is primarily due to the large uncertainty in the seismic hazard curves but another contribution arises from the uncertainty in the seismic fragilities.

**FIGURE 6.1**  
**SURRY: BOOLEAN EXPRESSIONS FOR THE TWO**  
**PLANT OPERATING STATES**

**POS6** = SBHE [ CCWHEX \* { RHRP \* ( RHRHEX \* EDG + RHRHEX \* SEQ1 ) + RHRP + SEQ1 } + CCWHEX \* SEQ1 ] + SBHE \* SEQ2

**POS10** = CI \* [ SBHE \* { CCWHEX \* ( RHRP \* ( RHRHEX \* ( SRV \* ( 1-EE-TK-3 + CNTRL-PNL + BATTERIES + AIR-ACCUM + 1H1-12 + 1J1-12 + SRV \* ( 1-EE-TK-3 + CNTRL-PNL + BATTERIES + AIR-ACCUM + 1H1-12 + 1J1-12 ) \* ( RWST \* ( GFDHE1 + RWST ) ) + RHREX \* SEQ3 ) + RHRP \* SEQ3 ) + CCWHEX \* SEQ3 } + SBHE2 \* SEQ4 ]

where

**SEQ1** = SRV \* ( CST \* ( SFBHE1 \* ( 1-EE-TK-3 + CNTRL-PNL + BATTERIES + AIR-ACCUM + 1H1-12 + 1J1-12 ) + SFBHE1 \* ( RWST \* ( PFBHE1 \* ( 1-EE-TK-3 + CNTRL-PNL + BATTERIES + AIR-ACCUM + 1H1-12 + 1J1-12 ) + PFBHE1 ) + RWST ) ) + CST \* SFBHE1 \* ( RWST \* ( PFBHE1 \* ( 1-EE-TK-3 + CNTRL-PNL + BATTERIES + AIR-ACCUM + 1H1-12 + 1J1-12 ) + PFBHE1 ) + RWST ) ) + SRV \* ( RWST \* ( PFBHE1 \* ( 1-EE-TK-3 + CNTRL-PNL + BATTERIES + AIR-ACCUM + 1H1-12 + 1J1-12 ) + PFBHE1 ) RWST ) )

**SEQ2** = SRV \* ( CST \* ( SFBHE2 \* ( 1-EE-TK-3 + CNTRL-PNL + BATTERIES + AIR-ACCUM + 1H1-12 + 1J1-12 ) + SFBHE2 \* ( RWST \* ( PFBHE2 \* ( 1-EE-TK-3 + CNTRL-PNL + BATTERIES + AIR-ACCUM + 1H1-12 + 1J1-12 ) + PFBHE2 ) + RWST ) ) + CST \* SFBHE2 \* ( RWST \* ( PFBHE2 \* ( 1-EE-TK-3 + CNTRL-PNL + BATTERIES + AIR-ACCUM + 1H1-12 + 1J1-12 ) + PFBHE2 ) + RWST ) ) + SRV \* ( RWST \* ( PFBHE2 \* ( 1-EE-TK-3 + CNTRL-PNL + BATTERIES + AIR-ACCUM + 1H1-12 + 1J1-12 ) + PFBHE2 ) + RWST ) )

**SEQ3** = SRV \* ( RWST \* ( PFBHE1 \* ( 1-EE-TK-3 + CNTRL-PNL + BATTERIES + AIR-ACCUM + 1H1-12 + 1J1-12 ) + PFBHE1 ) + RWST ) + SRV \* ( RWST \* ( PFBHE1 \* ( 1-EE-TK-3 + CNTRL-PNL + BATTERIES + AIR-ACCUM + 1H1-12 + 1J1-12 ) \* GFDHE1 + PFBHE1 \* GFDHE1 ) + RWST ) )

and

**SEQ4** = SRV \* ( RWST \* ( PFBHE2 \* ( 1-EE-TK-3 + CNTRL-PNL + BATTERIES + AIR-ACCUM + 1H1-12 + 1J1-12 ) + PFBHE2 ) + RWST ) + SRV \* ( RWST \* ( PFBHE2 \* ( 1-EE-TK-3 + CNTRL-PNL + BATTERIES + AIR-ACCUM + 1H1-12 + 1J1-12 ) \* GFDHE2 + PFBHE2 \* GFDHE2 ) + RWST ) )

**TABLE 6.1**  
**SURRY: POS FREQUENCY ESTIMATES**  
(all values are core-damage frequency per year)

<b><u>POS State</u></b>	<b><u>Mean</u></b>	<b><u>Median</u></b>	<b><u>5% Confidence</u></b>	<b><u>95% Confidence</u></b>
<b>EPRI Hazard Curves</b>				
POS 6	6.6 E-8	7.4 E-9	1.9 E-10	2.8 E-7
POS 10	2.0 E-8	2.3 E-9	6.2 E-11	8.8 E-8
Total, POSs 6 & 10	8.6 E-8	9.7 E-9	2.5 E-10	3.7 E-7
<b>LLNL Hazard Curves</b>				
POS 6	2.6 E-7	3.0 E-8	9.6 E-10	1.0 E-6
POS 10	9.1 E-8	1.0 E-8	3.5 E-10	3.5 E-7
Total, POSs 6 & 10	3.5 E-7	4.0 E-8	1.3 E-9	1.4 E-6

**TABLE 6.2**  
**SURRY: SENSITIVITY OF POS 6 CDF TO SEISMIC SITE HAZARD**  
(all values are core-damage frequency per year)  
(using EPRI hazard curves)

<b><u>Site</u></b>	<b><u>Mean</u></b>	<b><u>Median</u></b>	<b><u>95% Confidence</u></b>
Surry Site	6.6 E-8	7.4 E-9	2.8 E-7
Pilgrim Site	7.2 E-7	1.9 E-7	2.8 E-6
Zion Site	1.2 E-7	2.8 E-8	6.6 E-7

---

a) This sensitivity study represents "moving" the Surry reactor to the other two sites shown, with all other features of Surry remaining the same as in Table 6-1

TABLE 6.3

**SURRY: SENSITIVITY OF CDF TO INCREASING ALL HUMAN ERROR RATES**

(all values are mean core-damage frequency per year)  
(using EPRI hazard curves)

<u>POS State</u>	<u>Base Case</u>	<u>Increased Human Error Rates<sup>a</sup></u>
POS 6	6.6 E-8	5.1 E-7
POS 10	2.0 E-8	1.5 E-7

---

a) Human error rates: use of the 95% upper confidence-bound error rates (representing poorer human performance) instead of the mean rate that is used in the base case, for all human errors in Table 4-1

TABLE 6.4

**SURRY: SENSITIVITY OF CDF TO IMPROVED HUMAN ERROR RATE  
FOR STUB-BUS CONNECTION**

(all values are mean core-damage frequency per year)  
(using EPRI hazard curves)

<u>POS State</u>	<u>Base Case</u>	<u>Stub-Bus Connection: Decreased Human Error Rate<sup>a</sup></u>
POS 6	6.6 E-8	1.3 E-8
POS 10	2.0 E-8	4.1 E-9

---

a) The human error rate for the stub-bus connection: sensitivity of using the 5% upper-confidence bound (representing improved human performance) as a deterministic value instead of the mean rate that is used in the base case

**TABLE 6.5**  
**COMPARISONS OF CDF FOR SHUTDOWN vs. FULL-POWER CONDITIONS**  
**AND FOR SEISMIC INITIATORS vs. INTERNAL-INITIATORS**

<u>Analysis Condition</u>	<u>Reference</u>	<u>Mean CDF/year</u>	<u>Error Factor<sup>a</sup></u>
Shutdown (POSs 6 & 10) internal initiators <sup>b</sup>	Brookhaven (Ref. BNL, 1994)	5.0 E-6	5.6
Shutdown (POSs 6 & 10) seismic initiator	This study	3.5 E-7 (LLNL) <sup>c</sup> 8.6 E-8 (EPRI) <sup>c</sup>	32 37
Full power internal initiators <sup>b</sup>	NUREG-1150 (Ref. NRC/1150, 1990)	4.0 E-5	4.4
Full power seismic initiator	NUREG-1150 (Ref. Bohn, 1990)	1.2 E-4 (LLNL) <sup>c</sup> 2.5 E-5 (EPRI) <sup>c</sup>	33 19

---

**Footnotes for Table 6.5:**

- a) The Error Factor is the ratio of the 95%-percentile value to the median value of CDF (core-damage frequency/year).
- b) The notation "internal initiators" includes all initiators that start with internal plant faults or loss of offsite power, but excludes internal fires and internal flooding.
- c) The notation (LLNL) and (EPRI) indicates use of the LLNL or the EPRI seismic hazard curves for the Surry site.

## 7. CONCLUSIONS AND SUMMARY

A number of important insights emerge from this Surry analysis, including:

**Core-damage frequency:** The core-damage frequency for earthquake-initiated accidents during refueling outages in POS 6 and POS 10 is found to be low in absolute terms, below  $10^{-6}$ /year. The reasons for this are (i) Surry's seismic capacity in responding to earthquakes during shutdown is excellent, well above its design basis and similar to its ability to respond to earthquakes during full-power conditions; (ii) the Surry site enjoys one of the least seismically active locations in the United States; (iii) the Surry plant is only in POS 6 and POS 10 (combined) for an average (mean) of 6.6% of the time.

The core-damage frequencies are also low relative to the frequencies during POS 6 and POS 10 for internal initiators, as analyzed in the companion study by Brookhaven (Ref. BNL, 1994). This can be seen in Table 6.5.

**The results are plant-specific:** We believe that the results for Surry are highly plant-specific, in the sense that the seismic capacities, the specific sequences that are found to be most important, and the seismicity of the site are all difficult to generalize to other reactors elsewhere.

**Shutdown seismic sequences are similar to full-power seismic sequences:** Nevertheless, it is important to observe that all of the sequence types, components, and human errors that emerge in the key sequences in this analysis are similar or identical to sequences, components, and human errors that appear in typical full-power seismic PRAs. That is, nothing that has arisen as important in this study appears to be unique to earthquakes occurring during shutdown conditions. Whether this observation is generalizable to other reactors at other sites is unknown to us.

**Sensitivities:** Sensitivity studies reveal that if the Surry reactor were moved to the Zion site in Illinois (a typical midwestern site) or the Pilgrim site in Massachusetts (one of the most seismically active sites among all of the reactor sites in the eastern U.S.), the mean annual CDF from this study would increase by factors of about 1.8 and 10, respectively.

**Uncertainties:** While there are significant uncertainties in the numerical values of core-damage frequencies found in this study (see Tables 6.1 through 6.5), the above conclusions are relatively robust --- they do not depend on the detailed numerical values found.

## 8. REFERENCES

Bernreuter et al. 1989: D.L. Bernreuter, J.B. Savy, R.W. Mensing and J.C. Chen, "Seismic Hazard Characterization of 69 Nuclear Plant Sites East of the Rocky Mountains," NUREG/CR-5250, Lawrence Livermore National Laboratory, January 1989

BNL, 1994: T-L. Chu et al., "Evaluation of Potential Severe Accidents During Low-Power and Shutdown Operations at Surry Unit 1", NUREG/CR-6144, Volume 2, "Analysis of Core Damage Frequency from Internal Events during Mid-Loop Operations", Brookhaven National Laboratory for the U.S. Nuclear Regulatory Commission, June 1994

Bohn et al. 1990: M.P. Bohn, J.A. Lambright, S.L. Daniel, J.J. Johnson, M.K. Ravindra, P.O. Hashimoto, M.J. Mraz, and W.H. Tong, "Analysis of Core Damage Frequency: Surry Power Station, Unit 1, External Events", NUREG/CR-4551, Vol. 3, Rev. 1, Part 3, Sandia National Laboratories, December 1990

Breeding et al. 1990: R.J. Breeding, J.C. Helton, W.B. Murfin, and L.N. Smith, "Evaluation of Severe Accident Risks: Surry Unit 1, Main Report", NUREG/CR-4551, Vol. 3, Rev. 1, Part 1, Sandia National Laboratories, October 1990

Brown et al. 1990: T.D. Brown, R.J. Breeding, H.-N. Jow, J.C. Helton, S.J. Higgins, C.N. Amos, and A.W. Shiver, "Evaluation of Severe Accident Risks: Grand Gulf, Unit 1, Main Report", NUREG/CR-4551, Vol. 6, Rev. 1, Part 2, Sandia National Laboratories, December 1990

Budnitz, Lambert, and Hill, 1987: R.J. Budnitz, H.E. Lambert, and E.E. Hill, "Relay Chatter and Operator Response After a Large Earthquake", NUREG/CR-4910, Future Resources Associates, Inc., August 1987

Campbell et al. 1988: R.D. Campbell, M.K. Ravindra, and R.C. Murray, "Compilation of Fragility Information from Available Probabilistic Risk Assessments", Report UCID-20571, Rev. 1, Lawrence Livermore National Laboratory, Livermore, California, 1988

Chen et al. 1991: J.T. Chen et al., "Procedural and Submittal Guidance for the Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities," NUREG-1407, U.S. Nuclear Regulatory Commission, June 1991

EPRI-1988: Electric Power Research Institute, "A Methodology for Assessment of Nuclear Power Plant Seismic Margin.", EPRI Report NP-6041, 1988

EPRI, 1989: Electric Power Research Institute, "Probabilistic Seismic Hazard Evaluations at Nuclear Power Plant Sites in the Central and Eastern United States: Resolution of the Charleston Earthquake Issue," Prepared by Risk Engineering Inc., Yankee Atomic Power Company and Woodward Clyde Consultants, EPRI Report NP-6395-D, April 1989

EQE, 1992: "Transmittal of Final Seismic Response Analysis Results for Surry and North Anna IPEEE and USI A-46 Resolution", EQE Correspondence No. 52182-O-015, EQE International, San Francisco, November 30, 1992

FRA, 1991: R.J. Budnitz and P.R. Davis, "A Scoping Evaluation of Severe Accidents at the Surry and Grand Gulf Nuclear Power Plants Resulting from Earthquakes During Shutdown Conditions", Future Resources Associates, Inc. for the U.S. Nuclear Regulatory Commission, 1991

FRA/Grand Gulf, 1994: R.J. Budnitz, P.R. Davis, M.K. Ravindra, and W.H. Tong, "Evaluation of Potential Severe Accidents During Low-Power and Shutdown Operations at Grand Gulf", NUREG/CR-6143, Volume 5, "Analysis of Core Damage Frequency from Seismic Events for Plant Operational State 5 During a Refueling Outage", Future Resources Associates, Inc. for the U.S. Nuclear Regulatory Commission, August 1994

Kennedy and Ravindra, 1984: R.P. Kennedy and M.K. Ravindra, "Seismic Fragilities for Nuclear Power Plant Risk Studies," Nuclear Engineering and Design, Vol. 79, No. 1, pp. 47-68, May 1984

Lambright et al, 1990: J.A. Lambright, M.P. Bohn, S.L. Daniel, J.J. Johnson, M.K. Ravindra, P.O. Hashimoto, M.J. Mraz, W.H. Tong, and D.A. Brosseau, "Analysis of Core Damage Frequency: Peach Bottom Unit 2, External Events", NUREG/CR-4550, Vol. 4, Rev. 1, Part 3, Sandia National Laboratories, December 1990

Newmark, 1977: N.M. Newmark, "Inelastic Design of Nuclear Reactor Structures and Its Implications on Design of Critical Equipment", Paper K 4/1, "Proceedings of the Fourth Conference on Structural Mechanics in Reactor Technology", San Francisco, California, August 1977

NRC, 1983: PRA Procedures Guide, Chapter 10, "Analysis of External Events", and Chapter 11, "Seismic Risk Analysis", NUREG/CR-2300, U.S. Nuclear Regulatory Commission, January 1983

NRC/NUREG-1150, 1990: U.S. Nuclear Regulatory Commission, "Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants, Final Summary Report", NUREG-1150, December 1990

Ravindra and Kennedy, 1983: M.K. Ravindra, and R.P. Kennedy, "Lessons Learned from Seismic PRA Studies," Paper M6/4, in "Proceedings of the Seventh Conference on Structural Mechanics in Reactor Technology," Chicago, Illinois, August 1983

Riddell and Newmark, 1979: R. Riddell and N.M. Newmark, "Statistical Analysis of the Response of Nonlinear Systems Subjected to Earthquakes", Report UILU 79-2016, University of Illinois, Urbana, August 1979

Sandia, 1994: D.W. Whitehead et al., "Evaluation of Potential Severe Accidents During Low-Power and Shutdown Operations at Grand Gulf", NUREG/CR-6143, Volume 2, "Analysis of Core Damage Frequency from Internal Events for Plant Operational State 5 During a Refueling Outage", Sandia National Laboratories for the U.S. Nuclear Regulatory Commission, June 1994

Swain and Guttmann, 1980: A.D. Swain and H.E. Guttmann, "Handbook of Human Reliability Analysis With Emphasis on Nuclear Power Plant Applications", NUREG/CR-1278, Sandia National Laboratories, April 1980

Zion, 1981: Commonwealth Edison Company, "Zion Probabilistic Safety Study", 1981

Kiyoharu Abe  
Dept. of Reactor Safety Research  
Nuclear Safety Research Center  
Tokai Research Establishment  
JAERI  
Tokai-mura, Naga-gun  
Ibaraki-ken,  
JAPAN

Sarbes Acharya  
Department of Energy  
NS-1/FORS  
Washington, DC 20585

Dr. Ulvi Adalioglu  
Cekmece Nukleer Arastraime ve  
Egitim Merekezi  
P.K. 1  
Havaalani/ISTANBUL  
TURKEY

Dr. Eng. Kiyoto Aizawa  
Senior Engineer  
Reactor Eng. Dev. Department  
PNC  
9-13, Chome, Akasaka  
Minato-K, Tokyo  
JAPAN

Harry Alter  
Manager Applied Tech  
Nuclear Systems Tech  
NE-46  
US DOE  
Washington, DC 20585

R.M. Andrews  
Nuclear Installations Insp.  
St. Peters House  
Balliol Raod, Bootle  
Merseyside L20 31Z  
UNITED KINGDOM

George Apostolakis  
UCLA  
Boelter Hall, Room 5532  
Los Angeles, CA 90024-1597

Director of Reactor Engineering  
Argonne National Laboratory  
9700 S Cass Ave  
Bldg 208  
Argonne, IL 60439

Ephraim Asculai  
Division of Nuclear Safety  
Wagramestrasse, 5  
P.O. Box 100  
A-1400 Wien  
AUSTRIA

Vladimir Asmolov  
Head, Nuclear Safety Department  
I. V. Kurchatov Institute  
of Atomic Energy  
Moscow, 123181  
RUSSIA

J. de Assuncao  
Cabinete de Proteccao e  
Seguranca Nuclear  
Ministerio da Indusstria  
Ave. de Republica 45-6  
1000 Lisbon  
PORTUGAL

H.P. Balfanz, Head  
Institute of Probabilistic  
Safety Analysis  
TUV Nord  
Grosse Bahnstrasse 31  
D-22525 Hamburg 54  
GERMANY

Pat Baranowsky  
USNRC-AEOD/TPAB  
MS: T-4A9

Robert A. Bari, Deputy Chairman  
Dept of Nuclear Energy  
Bldg 197C  
Brookhaven National Laboratory  
Upton, NY 11973

Librarian  
Technical Information Section  
Battelle Pacific Northwest Lab  
P. O. Box 999  
Richland, WA 99352

Dr. John Baum  
Dept of Nuclear Energy  
Radiological Sciences Div  
Bldg 703 M  
Brookhaven National Laboratory  
Upton, NY 11973

Eric Beckjord  
USNRC-RES/DO  
MS: T-10F12

Robert Bernero  
USNRC-NMSS/DO  
MS: T-8A23

Andrea Besi  
Institute for Systems Engineering  
and Informatics  
CEC Joint Research Centre  
CP N 1  
1-21020 Ispra (Varese)  
ITALY

John Bickel  
Idaho National Engineering Lab.  
EG&G MS: 3850  
P.O. Box 1625  
Idaho Falls, ID 83415

Vicki Bier  
Dept. of Industrial Engineering  
University of Wisconsin-Madison  
1513 University Avenue, Room 389  
Wisconsin, WI 53706

Scott Bigelow  
S-CUBED  
2501 Yale SE, Suite 300  
Albuquerque, NM 87106

Prof. Dr. Dr.-Ing. E. H. Adolf  
Birkhofer  
Gesellschaft für Anlagen und  
Reaktorsicherheit (GRS) mbH  
Forschungsgelände  
D-8046 Garching  
Federal Republic of Germany

David Black  
American Electric Power  
1 Riverside Plaza  
Columbus, OH 43215

Harold Blackman  
Idaho National Engineering Lab.  
EG&G MS: 3850  
P.O. Box 1625  
Idaho Falls, ID 83415-3850

Dennis Bley  
Buttonwood Consulting  
17291 Buttonwood St.  
Fountain Valley, CA 92708

Roger Blond  
Booz-Allen & Hamilton  
4330 East West Highway  
Bethesda, MD 20814

M. P. Bohn  
Division 6449  
Sandia National Laboratories  
Albuquerque, NM 87185

Dr. Mario Bonaca  
Manager, Reactor Engineering  
Northeast Utilities  
P.O. Box 270  
Hartford, Conn. 06141

Robert B. Borsum  
Nuclear Power Division  
B & W Nuclear Tech  
1700 Rockville Pike  
Suite 525  
Rockville, MD 20852

Stephen Boult  
Electrowatt Engineering Services  
(UK) Ltd.  
Grandford House  
16 Carfax, Horsham  
West. Sussex RH12 IUP  
ENGLAND

Gary Boyd  
Safety & Reliability Optimization  
Services  
9724 Kingston Pike, Suite 102  
Knoxville, TN 37922

Brookhaven National Laboratory (2)  
Attn: Lev Neymotin  
Arthur Tingle  
Building 130  
Upton, NY 11973

David M. Brown  
Paul C. Rizzo Associates, Inc.  
300 Oxford Drive  
Monroeville, PA 15146-2347

Tom D. Brown  
Sandia National Laboratories  
Dept. 6413  
P.O. Box 5800  
Albuquerque, NM 87185

Robert J. Budnitz  
Future Resources Associates, Inc.  
2039 Shattuck Avenue, Suite 402  
Berkeley, CA 94704

Gary Burdick  
USNRC-RES/SAIB  
MS: T-10F13

Arthur Buslik  
USNRC-RES/PRAB  
MS: T-9F31

Edward Butcher  
USNRC-NRR/SPSB  
MS: O-10E4

Technical Library  
B&W Nuclear Service Co  
P. O. Box 10935  
Lynchburg, VA 24506

Stefaan Caeymaex  
Safety & Systems Section  
Nuclear Generation Dept.  
TRACTEBEL  
Avenue Ariane 7  
B-1200 Bruxelles  
BELGIUM

Leonard Callan, Administrator  
U.S. Nuclear Regulatory Commission  
Harris Tower and Pavilion  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

J. Calvo  
Division of PSA & Human Factors  
Consejo de Seguridad Nuclear  
Calle Justo Dorado, 11  
28040 Madrid  
SPAIN

A. L. Camp  
Division 6412  
MS: 0748  
Sandia National Laboratories  
Albuquerque, NM 87185-0748

John Forbes Campbell  
HM Superintending Inspector  
Health & Safety Executive  
St. Peter's House  
Balliol Road  
Bootle L20 31Z  
UNITED KINGDOM

Leonel Canelas  
New University of Lisbon  
Quinta de Torre  
2825 Monte de Caparica  
PORTUGAL

Harold Careway  
General Electric Co., M/C 754  
175 Curtner Ave.  
San Jose, CA 95129

D. D. Carlson  
Division 6411  
Sandia National Laboratories  
Albuquerque, NM 87185

Jose E. De Carlos  
CSN International Coordinator  
Consejo de Seguridad Nuclear  
Calle Justo Dorado 11  
28040 Madrid  
SPAIN

Annick Carnino  
International Atomic Energy Agency  
Wagramerstrasse 5, P.O. Box 100  
A-1400 Vienna  
AUSTRIA

S. Chakraborty  
Swiss Federal Nuclear Safety  
Inspectorate  
Hauptabteilung für die Sicherheit  
der Kernanlagen  
CH-5232 Villigen-HSK  
SWITZERLAND

Erulappa Chelliah  
USNRC-RES/PRAB  
MS: T-9F31

Mike Cheok  
NUS  
910 Clopper Road  
Gaithersburg, MD 20878

Nilesh Chokshi  
USNRC-RES/SSEB  
MS: T-10L1

T. L. Chu  
Brookhaven National Laboratory  
Department of Nuclear Energy  
Bldg. 130  
Upton, NY 11973

Peter Cooper  
SRD/AEA Technology  
Wigshaw Lane  
Culcheth  
Cheshire WA3 4NE  
England

Susan E. Cooper  
Science Applications Int'l. Corp.  
11251 Roger Bacon Drive  
Reston, VA 22090

Michael Corradini  
University of Wisconsin  
1500 Johnson Drive  
Madison, WI 53706

E.R. Corran  
ANSTO Research Establishment  
Lucas Heights Reserch Labs.  
Private Mail Bag 1  
Manai, NSW 2234  
AUSTRALIA

Massimo Cozzone  
A.N.P.A.  
Via V. Brancati, 48  
I-00144 Rome  
ITALY

George Crane  
1570 E. Hobble Creek Dr.  
Springville, Utah 84663

Mark Cunningham  
USNRC-RES/PRAB  
MS: T-9F31

S. Daggupaty  
Environment Canada  
4905 Dufferin Street  
Downsview  
Ontario, M3H ST4  
CANADA

Louise Dahlerup  
Inspectorate of Nuclear Inst.  
Danish Civil Defense &  
Emergency Planning Agency  
16, Datavej  
DK-3460 Birkerod  
DENMARK

John Darby  
SEA, Inc.  
6100 Uptown Blvd. NE  
Albuquerque, NM 87110

Gerald Davidson  
Fauske and Associates, Inc.  
16 W 070 West 83rd Street  
Burr Ridge, IL 60521

Peter Davis  
PRD Consulting  
P.O. Box 2046  
Sheridan, WY 82801

P. De Gelder  
Secretary, BELGIAN NUCLEAR  
SOCIETY (BNS)  
A V Nuclear  
Avenue du Roi 157  
B-1060 Brussels  
BELGIUM

Lennart Devell  
Studsvik Nuclear  
Studsvik Energiteknik AB  
S-611 82 Nykoping  
SWEDEN

J. Devooght  
Service de la Metrologie Nucl  
University Libre de Bruxelles  
Faculte des Sciences Appliqu.  
50 Avenue F-D Roosevelt  
Bruxelles 5  
BELGIUM

G. Diederick  
Commonwealth Edison Co.  
LaSalle County Station  
RR1, Box 220  
2601 North 21st Rd.  
Marsielles, IL 61341

Chuck Dobbe  
Idaho National Engineering Lab.  
EG&G MS: 3840  
P.O. Box 1625  
Idaho Falls, ID 83415

Mary Drouin  
USNRC-RES\SAIB  
MS: T-10F13

Duke Power Co. (2)  
Attn: Duncan Brewer  
Steve Deskevich  
422 South Church Street  
Charlotte, NC 28242

Bill Eakin  
Northeast Utilities  
Box 270  
Hartford, CT 06141

Stewart D. Ebneter  
USNRC  
101 Marietta St., Suite 2900  
Atlanta, GA 30323-0199

Adel A. El-Bassioni  
USNRC-NRR/PRAB  
MS: O-10E4

ENEA/DISP (2)  
Attn: Alvaro Valeri  
Alfredo Bottino  
Via Vitaliano Brancati, 48  
00144 Roma EUR  
ITALY

Walter P. Engel  
PRAG MGR Analysis & Reg Matter  
NE-60  
CRYCITY  
US DOE  
Washington, DC 20585

John Flack  
USNRC-RES/SAIB  
MS: T-10F13

Karl Fleming  
Pickard, Lowe & Garrick  
2260 University Drive  
Newport Beach, CA 92660

Terry Foppe  
Safety Analysis Engineering  
Rocky Flats Plant  
Energy Systems Group  
Rockwell International Corp  
P.O. Box 464  
Golden, CO 80401

R H. Gauger  
Manager-Reliability Engr  
A/E Div  
Holmes & Narver Inc.  
R Roanne Circle  
Irvine, CA 92714

Robert Gobel  
Clark University  
Center for Technology, Environment  
and Development  
950 Main St.  
Worcester, MA 01610-1477

Paul Govaerts  
Studiecentrum voor Kernenergie  
(SCK/CEN)  
Boeretang, 200  
B-2400 Mol  
BELGIUM

Mr. Gubler  
International Atomic Energy Agency  
NENS/SAD BO842  
Wagramerstrasse 5, P.O. Box 100  
A-1140 Vienna  
AUSTRIA

Paul M. Haas, President  
Concord Associates, Inc.  
725 Pellissippi Parkway  
Suite 101, Box 6  
Knoxville, TN 37933

F. T. Harper  
Division 6413  
MS: 0748  
Sandia National Laboratories  
Albuquerque, NM 87185-0748

Dr. U. Hauptmanns  
Gesellschaft Für Anlagen und  
Reaktorsicherheit (GRS) mbH  
Schwertnergasse 1  
D-5000 Köln 1  
GERMANY

Sharif Heger  
UNM Chemical and Nuclear  
Engineering Department  
Farris Engineering, Room 209  
Albuquerque, NM 87131

Jon C. Helton  
Dept. of Mathematics  
Arizona State University  
Tempe, AZ 85287

Dr. P. M. Herttrich  
Gesellschaft für Anlagen und  
Reaktorsicherheit (GRS) mbH  
Schwertnergasse 1  
5000 Köln 1  
GERMANY

Dr. D.J. Higson  
Radiological Safety Bureau  
Australian Nuclear Science &  
Technology Organisation  
P.O. Box 153  
Roseberry, NSW 2018  
AUSTRALIA

Dr. Mitsumasa Hirano  
Deputy General Manager  
Institute of Nuclear Safety  
NUPEC  
3-6-2, Toranomon, Minato-ku  
Tokyo 108  
JAPAN

Dr. S. Hirschberg  
Paul Scherrer Institute  
Vurenlingen and Villigen  
CH-5232 Villigen PSI  
SWITZERLAND

Steven Hodge  
Oak Ridge National Laboratories  
P. O. Box Y  
Oak Ridge, TN 37831

Gary Holahan  
USNRC-AEOD/OSP  
MS: T-4A9

N.J. Holloway  
A72.1  
Atomic Weapons Establishment  
Ademaston  
Reading RG7 4PR  
UNITED KINGDOM

Griff Holmes  
Westinghouse Electric Co.  
Energy Center East  
Bldg. 371  
P.O. Box 355  
Pittsburgh, PA 15230

William Hopkins  
Bechtel Power Corporation  
15740 Shady Grove Road  
Gaithersburg, MD 20877

Dean Houston  
USNRC-ACRS  
MS: P-315

Der-Yu Hsia  
Institute of Nuclear Energy Research  
Lung-Tan 325  
TAIWAN

Alejandro Huerta-Bahena  
National Commission on Nuclear  
Safety and Safeguards (CNSNS)  
Insurgentes Sur N. 1776  
C. P. 04230 Mexico, D. F.  
MEXICO

Peter Humphreys  
US Atomic Energy Authority  
Wigshaw Lane, Culcheth  
Warrington, Cheshire  
UNITED KINGDOM, WA3 4NE

W. Huntington  
Commonwealth Edison Co.  
LaSalle County Station  
RR1, Box 220  
2601 North 21st Rd.  
Marsielles, IL 61341

Dr. H. Kalfsbeek  
DG/XII/D/1  
Commission of the European  
Communities  
Rue de la Loi, 200  
B-1049 Brussels  
BELGIUM

J.S. Hyslop  
USNRC-RES/PRAB  
MS: T-9F31

Idaho National Engineering Lab. (2)  
Attn: Doug Brownson  
Darrel Knudson  
EG&G MS: 3840  
P.O. Box 1625  
Idaho Falls, ID 83415

Yoshio Kano  
General Mngr. & Sr. Engineer  
Systems Analysis Section  
O-arai Engineer. Centr, PNC  
Higashi-Ibaraki-gun  
Ibaraki-Ken, 133-13  
JAPAN

Idaho National Engineering Lab. (2)  
Attn: Art Rood  
Mike Abbott  
EG&G MS: 2110  
P.O. Box 1625  
Idaho Falls, ID 83415

William Kastenberg  
UCI  
Boelter Hall, Room 5532  
Los Angeles, CA 90024

Hanspeter Isaak  
Abteilung Strahlenschutz  
Hauptabteilung für die Sicherheit  
der Kernanlagen (HSK)  
CH-5303 Wurenlingen  
SWITZERLAND

Barry Kaufer  
OECD/NEA  
"Le Seine St. Germain" 12  
Boulevard les Iles  
92130 Issy-les-Moulineaux  
FRANCE

Brian Ives  
UNC Nuclear Industries  
P. O. Box 490  
Richland, WA 99352

Paul Kayser  
Division de la Radioprotection  
Avenue des Archiducs, 1  
L-1135 Luxembourg-Belair  
LUXEMBOURG

Kamiar Jamili  
DP-62/FTN  
Department of Energy  
Washington, D.C. 20585

Ken Keith  
TVA  
W 20 D 201  
400 West Surmnit Hill  
Knoxville, TN 37092

Robert Jones  
USNRC-NRR/DSSA  
MS: O-8E1

G. Neale Kelly  
Commission of the European  
Communities  
Joint Research Centre  
Rue de la Loi 200  
B-1049 Brussels  
BELGIUM

Edward Jordan  
USNRC-AEOD/DO  
MS: T-4D18



John Kelly  
Sandia National Laboratories  
P. O. Box 5800  
MS 0742  
Albuquerque, NM 87185




**AIIM**

**Association for Information and Image Management**



1100 Wayne Avenue, Suite 1100  
Silver Spring, Maryland 20910  
301/587-8202




**Centimeter**



**Inches**



MANUFACTURED TO AIIM STANDARDS  
BY APPLIED IMAGE, INC.



2 of 2

Knolls Atomic Power Laboratory (2)  
Attn: Ken McDonough  
Dominic Sciaudone  
Box 1072  
Schenectady, NY 12301

Dr. K. Koberlein  
Gesellschaft für  
Reaktorsicherheit mbH  
Forschungsgelände  
D-8046 Garching  
GERMANY

Alan Kolaczkowski  
Science Applications International  
Corporation  
2109 Air Park Rd. S. E.  
Albuquerque, NM 87106

Jim Kolanowski  
Commonwealth Edison Co.  
35 1st National West  
Chicago, IL 60690

John G. Kollas  
Institute of Nuclear Technology and  
Radiation Protection  
N.R.C.P.S. "Demokritos"  
P.O. Box 60228  
GR-153 10 Aghia Paraskevi  
Attiki  
GREECE

S. Kondo  
Department of Nuclear Engineering  
Facility of Engineering  
University of Tokyo  
3-1, Hongo 7, Bunkyo-ku  
Tokyo  
JAPAN

D. Lamy  
CEN/SCK  
Dept. Scientific Irradiation  
Experiment & Study BR2  
Boeretang, 200  
B-2400 Mol  
BELGIUM

Dr. J.M. Lanore  
CEA/IPSN/DAS  
Centre d'Etudes Nucléaires de  
Fontenay-aux-Roses  
B.P. n° 6  
92265 Fontenay-aux-Roses CEDEX  
FRANCE

Jose A. Lantaron  
Consejo de Seguridad Nuclear  
Sub. Analisis y Evaluaciones  
Calle Justo Dorado, 11  
28040 Madrid  
SPAIN

Josette Larchier-Boulanger  
Electricité de France  
Direction des Etudes Et Recherches  
30, Rue de Conde  
75006 Paris  
FRANCE

H. Larsen  
Head of Department  
Riso National Laboratory  
P.O. Box 49  
DK-4000 Roskilde  
DENMARK

Lawrence Livermore Nat'l Lab. (4)  
Attn: George Greenly  
Marvin Dickerson  
Rolf Lange  
Sandra Brereton  
Livermore, CA 94550

Shengdar Lee  
Yankee Atomic Electric Company  
580 Main St.  
Boston, MA 17407

B.T.F. Liwaang  
Dept. of Plant Safety Assessment  
Swedish Nuclear Power Inspec.  
P.O. Box 27106  
S-10252 Stockholm  
SWEDEN

Peter Lohnberg  
Expresswork International, Inc.  
1740 Technology Drive  
San Jose, CA 95110

Steven M. Long  
USNRC-NRR/SPSB  
MS: O-10E4

D. Eugenio Gil Lopez  
Consejo de Seguridad Nuclear  
Calle Justo Dorado, 11  
28040 Madrid  
SPAIN

Los Alamos National Laboratory (2)  
Attn: Kent Sasser  
N-6, K-557  
Los Alamos, NM 87545

Christiana H. Lui  
USNRC-RES/PRAB  
MS: T-9F31

John Luke  
Florida Power & Light  
P.O. Box 14000  
Juno Beach, FL 33408

Daniel Manesse  
ISPNC  
Boite Postale n° 6  
92265 Fontenay-aux-Roses CEDEX  
FRANCE

Fred Mann  
Westinghouse Hanford Co.  
WIA-53  
P.O. Box 1970  
Richland, WA 99352

Nadia Soido Falcao Martins  
Comissao Nacional de Energia Nuclear  
R General Severiana 90 S/408-1  
Rio de Janeiro  
BRAZIL

Harry F. Martz  
Analysis and Assessment Division  
Los Alamos National Laboratory  
Los Alamos, NM 87545

Herbert Massin  
Commonwealth Edison Co.  
35 1st National West  
Chicago, IL 60690

Hideo Matsuzuru  
Tokai Research Establishment  
Tokai-mura  
Maka-gun  
Ibaraki-ken, 319-11  
JAPAN

Jim Mayberry  
Ebasco Services  
60 Chubb Ave.  
Lyndhurst, NJ 07071

Andrew S. McClymont  
IT-Delian Corporation  
1340 Saratoga-Sunnyvale Rd.  
Suite 206  
San Jose, CA 95129

Michael McKay  
Los Alamos National Laboratory  
A-1, MS F600 Services  
P.O. Box 1663  
Los Alamos, NM 87545

Zen Mendoza  
SAIC  
5150 El Camino Real  
Suite C3 1  
Los Altos, CA 94022

Dr. J. Mertens  
Division of Risk Analysis &  
Reactor Technology  
Institute of Safety Research  
Research Centre Julich (KFA)  
D-52425 Julich  
GERMANY

Jim Meyer  
Scientech  
11821 Parklawn Dr.  
Suite 100  
Rockville, MD 20852

Joe Minarick  
Science Applications Int'l Corp.  
301 Laboratory Road  
P.O. Box 2501  
Oak Ridge, TN 37830

Jose I. Calvo Molins, Head  
Division of P.S.A. and Human Factors  
Consejo de Seguridad Nuclear  
Calle Justo Dorado, 11  
28040 Madrid  
SPAIN

Ken Muramatsu  
Risk Analysis Laboratory  
Japan Atomic Energy Research  
Institute  
Tokai-mura, Naka-gun  
Ibaraki-ken, 319-11, Tokyo  
JAPAN

Joseph A. Murphy  
Division of Safety Issue Resolution  
U.S. Nuclear Regulatory Commission  
MS: T-10E50  
Washington, DC 20555

Kenneth G. Murphy, Jr.  
US Department of Energy  
19901 Germantown Rd.  
Germantown, MD 20545

Shankaran Nair  
Central Electricity  
Generating Board  
Berkeley Nuclear Laboratories  
Berkeley  
Gloucestrshire CL13 9PB  
UNITED KINGDOM

Ray Ng  
NEI  
1776 Eye St. N  
Suite 300  
Washington, DC 20006-2496

G. Niederauer  
Los Alamos National Laboratory  
P. O. Box 1663  
MSK 575  
Los Alamos, NM 87545

Oak Ridge National Laboratory (2)  
Attn: Steve Fisher  
Sherrel Greene  
MS-8057  
P.O. Box 2009  
Oak Ridge, TN 37831

Ken O'Brien  
University of Wisconsin  
Nuclear Engineering Dept.  
153 Engineering Research Blvd.  
Madison, WI 53706

Theresa Oh  
INEL Tech Library  
EG&G MS: 2300  
P. O. Box 1625  
Idaho Falls, ID 83415-2300

N. R. Ortiz, Director  
Nuclear Energy Technology  
Division 6400  
Sandia National Laboratories  
Albuquerque, NM 87185

Robert Ostmeyer  
U.S. Department of Energy  
Rocky Flats Area Office  
P. O. Box 928  
Golden, CO 80402

Robert Palla  
USNRC-NRR/SPSB  
MS: O-10E4

Gareth Parry  
NUS Corporation  
910 Clopper Rd.  
Gaithersburg, MD 20878

Vern Peterson  
Building T886B  
EG&G Rocky Flats  
P.O. Box 464  
Golden, CO 80402

G. Petrangeli  
ENEA Nuclear Energy ALT Disp  
Via V. Brancati, 48  
00144 Rome  
ITALY

Ing. Jose Antonio Becerra Perez  
Comision Nacional De Seguridad  
Nuclear Y Salvaguardias  
Insurgentes Sur 1806  
01030 Mexico, D. F.  
MEXICO

William T. Pratt  
Brookhaven National Laboratory  
Building 130  
Upton, NY 11973

Urho Pulkkinen  
Technical Research Centre of  
Finland  
Laboratory of Electrical &  
Automation Engineering  
Otakaari 7B, 02150 Espoo 15  
FINLAND

Blake Putney  
Science Applications  
International Corporation  
5150 El Camino Real, Suite C31  
Los Altos, Ca 94022

Dr. V. M. Raina  
Project Manager-Risk Assessment  
Ontario Hydro H11 G1  
700 University Ave.  
Toronto, Ontario M5G 1X6  
CANADA

William Raisin  
NEI  
1726 M. St. NW  
Suite 904  
Washington, DC 20036

Ann Ramey-Smith  
USNRC-RES/PRAB  
MS: T-9F31

Dale Rasmussen  
USNRC-AEOD/TPAB  
MS: T-4A9

John Ridgely  
USNRC-RES/SAIB  
MS: T-10F13

Richard Robinson (2)  
USNRC-RES/PRAB  
MS: T-9F31

M. Roch  
Manager of Design, Nuclear  
Department  
TRACTEBEL  
Avenue Ariane 7  
B-1200 Bruxelles  
BELGIUM

A.E. Rogers  
General Electric Co  
175 Curtner Ave  
MC-489  
San Jose, CA 95125

Judy Rollstin  
GRAM Inc  
8500 Menual Blvd. NE  
Albuquerque, NM 87112

Marc Rothschild  
Halliburton NUS  
1303 S. Central Ave.  
Suite 202  
Kent, WA 98032

Christopher Ryder  
USNRC-RES/PRAB  
MS: T-9F31

Takashi Sato, Deputy Manager  
Nuclear Safety Engineering Section  
Reactor Design Engineering Dept.  
Nuclear Energy Group, Toshiba Corp.  
Isogo Engineering Center  
8, Shinsugita-cho, Isogo-ku,  
Yokohama 235, JAPAN

Martin Sattison  
Idaho National Engineering Lab.  
P. O. Box 1625  
Idaho Falls, ID 83415

Dr. U. Schmocke  
Hauptabteilung für die  
Sicherheit der Kernanlagen  
CH-5232 Villigen HSK  
SWITZERLAND

A.J. Seebregts  
ECN Nuclear Energy  
Westerduinweg, 3  
Postbus 1  
NL-1755 Petten ZG  
THE NETHERLANDS

Dr. S. Serra  
Ente Nazionale per l'Energia  
Elettrica (ENEL)  
via G.B. Martini 3  
I-00198 Rome  
ITALY

Stone & Webster Engineering Corp  
Technical Information Center  
A. Hosford  
245 Summer Street  
245/01  
Boston, MA 02210

H. Shapiro  
Licensing & Risk Branch  
Atomic Energy of Canada Ltd.  
Sheridan Park Research Comm.  
Mississauga, Ontario L5K 1B2  
CANADA

Nathan O. Siu  
Center for Reliability and Risk  
Assessment  
Idaho National Engineering Lab.  
EG&G MS: 3850  
P.O. Box 1625  
Idaho Falls, ID 83415-3855

E. Soederman  
ES-Konsult AB  
Energy and Safety  
P.O. Box 3096  
S-16103 Bromma  
SWEDEN

Desmond Stack  
Los Alamos National Laboratory  
Group Q-6, Mail Stop K556  
Los Alamos, NM 87545

Jao Van de Steen  
KEMA Laboratories  
Utrechtseweg, 310  
Postbus 9035  
NL 800 ET Arnhem  
THE NETHERLANDS

Eli Stern  
Israel AEC Licensing Div.  
P.O. Box 7061  
Tel-Aviv 61070  
ISRAEL

Dr. Egil Stokke  
Advisory Group  
OECD Halden Reactor Project  
P.O. Box 173  
N-1751 Halden  
NORWAY

Dennis Strenge  
Pacific Northwest Laboratory  
RTO/ 125  
P.O. Box 999  
Richland, WA 99352

Technadyne Engineer. Consultants (3)  
Attn: David Chanin  
Jeffery Foster  
Walt Murfin  
Suite A225  
8500 Menual Blvd. N  
Albuquerque, NM 87112

Ashok Thadani  
USNRC-NRR/ADT  
MS: O-12G18

T. G. Theofanous  
University of California, S. B.  
Department of Chemical and Nuclear  
Engineering  
Santa Barbara, CA 93106

Catherine Thompson  
USNRC-RES/SAIB  
MS: T-10F13

Soren Thykier-Nielsen  
Riso National Laboratory  
Postbox 49  
DK4000 Roskile  
DENMARK

R. Toossi  
Physical Research, Inc.  
25500 Hawthorn Blvd.  
Torrance, CA 90505

Ennio Traini  
ENEL  
Via Vialiano, 48  
00144 Rome  
ITALY

Ulf Tveten  
Environmental Physics Section  
Institutt for Energiteknikk  
Postboks 40  
N-2007 Kjeller  
NORWAY

US Department of Energy  
Energy Library  
Room G 034/GTN  
AD-622.1  
Washington, DC 20585

US Department of Energy  
NS-50 (GTN)  
NS-10.1  
S-161  
Washington, DC 20585

U.S. Environmental  
Protection Agency (2)  
Attn: Allen Richardson  
Joe Logsdon  
Office of Radiation Programs  
Environmental Analysis Division  
Washington, DC 20460

Harold VanderMolen  
USNRC-RES/PRAB  
MS: T-9F31

Dr. A. Valeri  
A.N.P.A.  
Via Vitaliano Brancati, 48  
I-00144 Rome  
ITALY

Magiel F. Versteeg  
Ministry of Social Affairs  
and Employment  
P.O. Box 90804  
2509 LV Den Haag  
THE NETHERLANDS

Martin Virgilio  
USNRC-NRR/DSSA  
MS: O-8E2

R. Virolainen, (Chairman PWG5)  
Systems Integ. Off. (STUK)  
P.O. Box 268  
Kumpulanite 7  
SF-60101 Helsinki  
FINLAND

Seppo Vuori  
Technical Research Centre of Finland  
Nuclear Engineering Laboratory  
Lonnrotinkatu 37  
P.O. Box 169  
SF-00181 Helsinki 18  
FINLAND

Dr. Ian B. Wall  
81 Irving Avenue  
Atherton, CA 94027

Edward Warman  
Stone & Webster Engineering Corp.  
P.O. Box 2325  
Boston, MA 02107

J.E. Werner  
Reactor Research & Techn Division  
US DOE Idaho Operations  
MS: 1219  
850 Energy Drive  
Idaho Falls, ID 83401-1563

Dr. Wolfgang Werner  
Safety Assessment Consulting GmbH  
Veilchenweg 8  
D 83254 Breitbrunn  
GERMANY

Westinghouse Electric Corp  
Technical Library  
P. O. Box 355  
East 209  
Pittsburgh, PA 15230

Westinghouse Electric Corp  
NTD  
Central File Nuclear Safety  
P. O. Box 355  
408 1-A  
Pittsburgh, PA 15230

Westinghouse Electric Company (3)  
Attn: John Lacovin  
Burt Morris  
Griff Holmes  
Energy Center East, Bldg. 371  
P.O. Box 355  
Pittsburgh, PA 15230

Westinghouse Savannah River Co. (2)  
Attn: Kevin O'Fula  
Jackie East  
Safety Technology Section  
1991 S. Centennial Ave., Bldg. 1  
Aiken, SC 29803

Donnie Whitehead  
Department 6412, MS: 0747  
Sandia National Laboratories  
P.O. Box 5800  
Albuquerque, NM 87185-0747

Keith Woodard  
PLG, Inc.  
7315 Wisconsin Ave.  
Suite 620 East  
Bethesda, MD 20814-3209

John Wreathall  
John Wreathall & Co.  
4157 MacDuff Way  
Dubin, OH 43017

M. K. Yeung  
University of Hong Kong  
Mechanical Engineering Dept.  
Polfulam  
HONG KONG

Bob Youngblood  
Brookhaven National Laboratory  
Department of Nuclear Energy  
Bldg. 130  
Upton, NY 11973

Carlo Zaffiro  
A.N.P.A.  
Directorate for Nuclear  
Via Vitaliano Brancate, 48  
I-00144 Rome  
ITALY

Dr. X. Zikidis  
Greek Atomic Energy Comm.  
N.R.C.P.S. "Demokritos"  
GR-153 10 Agia Paraskevi  
Attiki  
GREECE

100-1894

FILED  
DATE

