

RECEIVED

NOV 02 1994

OSTI

RELEASE AUTHORIZATION

Document Number: WHC-SD-TP-SEP-026, REV. 0

Document Title: Safety Evaluation for Packaging 101-SY Hydrogen Mitigation Mixer Pump Package

Release Date: 10/05/94

* * * * *

This document was reviewed following the procedures described in WHC-CM-3-4 and is:

APPROVED FOR PUBLIC RELEASE

* * * * *

WHC Information Release Administration Specialist:

N.L. Solis N.L. SOLIS
(Signature)

10/5/94
(Date)

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

SUPPORTING DOCUMENT

1. Total Pages 359

2. Title

Safety Evaluation for Packaging 101-SY Hydrogen Mitigation Mixer Pump Package

3. Number

WHC-SD-TP-SEP-026

4. Rev No.

0

5. Key Words

Packaging, Hydrogen Mitigation Mixer Pump, Risk Acceptance, Low-Level Mixed Waste, Containment, Shielding, Dose Consequence, Accident Frequency, Structural, Tiedowns, Hydrogen Generation, Equivalent Safety

6. Author

Name: R. F. Carlstrom

R. F. Carlstrom

Signature

Organization/Charge Code 84100/N2B6D

7. Abstract

APPROVED FOR PUBLIC RELEASE
10/5/94 D.S.H.

This Safety Evaluation for Packaging (SEP) provides analysis and evaluations considered necessary to approve a one-time transfer of the 101-SY Hydrogen Mitigation Mixer Pump (HMMP). This SEP will demonstrate that the transfer of the HMMP in a new shipping container will provide an equivalent degree of safety as would be provided by packages meeting U.S. Department of Transportation (DOT)/U.S. Nuclear Regulatory Commission (NRC) requirements. This fulfills onsite transportation requirements implemented by WHC-CM-2-14.

~~8. PURPOSE AND USE OF DOCUMENT - This document was prepared for use within the U.S. Department of Energy and its contractors. It is to be used only to perform, direct, or integrate work under U.S. Department of Energy contracts. This document is not approved for public release until reviewed.~~

~~PATENT STATUS - This document copy, since it is transmitted in advance of patent clearance, is made available in confidence solely for use in performance of work under contracts with the U.S. Department of Energy. This document is not to be published nor its contents otherwise disseminated or used for purposes other than specific above before patent approval for such release. Use has been secured, upon request, from the Patent Counsel, U.S. Department of Energy Field Office, Richland, WA.~~

DISCLAIMER - This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or any third party's use or the results of such use of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

10. RELEASE STAMP

OFFICIAL RELEASE
BY WHC
DATE OCT 05 1994
35 SHHC.21

9. Impact Level SQ

EXECUTIVE SUMMARY

This Safety Evaluation for Packaging (SEP) evaluates and documents the ability of the 101-SY Hydrogen Mitigation Mixer Pump (HMMP) Package to meet the radioactive material packaging requirements of WHC-CM-2-14, *Hazardous Material Packaging and Shipping*.^{*} This packaging is used for the onsite transfer of the radioactively contaminated HMMP from the SY Tank Farm to designated storage or disposal areas. Onsite transfer is the transport of hazardous materials on controlled routes confined to established limited areas and to portions of federally owned roadways to which public access is prohibited during transfer.

The HMMP Package is used only for the transfer of the HMMP. The HMMP Package consists of two cylindrical carbon steel standard wall pipes with bolted flanged ends which provide two containment barriers for the contaminated pump. An annulus space between the pipes is provided to add lead or steel shot as required for shielding purposes. The package is loaded onto a truck-trailer combination and transferred to the designated storage or disposal site.

Part A of this SEP provides a description of the packaging, payload, and transfer operations. It also sets forth operational requirements for package transfer. Part B of this document contains the package evaluations: shielding, structural, tiedown, thermal, containment, risk, dose consequence, pressure, and hydrogen generation.

^{*}WHC-CM-2-14, *Hazardous Material Packaging and Shipping*, Westinghouse Hanford Company, Richland, Washington.

TABLE OF CONTENTS

PART A - PACKAGE DESCRIPTION AND OPERATIONS

1.0 INTRODUCTION A1-1
 1.1 BACKGROUND INFORMATION A1-1
 1.2 PURPOSE AND SCOPE A1-2

2.0 PACKAGING SYSTEMS A2-1
 2.1 GENERAL INFORMATION A2-1
 2.2 CONFIGURATION AND DIMENSIONS A2-1
 2.3 MATERIALS OF CONSTRUCTION A2-2
 2.4 FABRICATION METHODS A2-2
 2.5 WEIGHTS A2-2
 2.6 CONTAINMENT BOUNDARY A2-2
 2.7 CAVITY SIZE A2-3
 2.8 HEAT DISSIPATION A2-3
 2.9 SHIELDING A2-3
 2.10 LIFTING DEVICES A2-3
 2.11 TIEDOWN DEVICES A2-3

3.0 PACKAGE CONTENTS A3-1
 3.1 GENERAL DESCRIPTION A3-1
 3.2 RADIONUCLIDE ACTIVITY A3-1
 3.3 FISSILE CONTENT A3-1

4.0 TRANSPORTATION SYSTEM A4-1
 4.1 TRANSPORTER A4-1
 4.2 TIEDOWN SYSTEM A4-1
 4.3 SPECIAL TRANSFER REQUIREMENTS A4-1

5.0 ACCEPTANCE OF PACKAGING FOR USE A5-1

6.0 OPERATING REQUIREMENTS A6-1
 6.1 GENERAL A6-1
 6.2 INSTALLATION OF PACKAGE CONTENTS A6-1
 6.3 UNLOADING THE PACKAGE A6-3

7.0 QUALITY ASSURANCE A7-1
 7.1 INTRODUCTION A7-1

8.0 MAINTENANCE A8-1

9.0 APPENDICES A9-1
 9.1 REFERENCES A9-1
 9.2 HYDROGEN MIXER PUMP CONTAINER (H-2-83750 and H-2-83734) A9-2
 9.3 STRONGBACK SECTIONS AND DETAILS (H-2-83736) A9-15

TABLE OF CONTENTS (Continued)

9.4	TILT TRAILER SKETCH	A9-31
9.5	LIFTING BEAM ASSEMBLY (H-2-83744)	A9-33

PART B - PACKAGE EVALUATION

1.0	INTRODUCTION	B1-1
1.1	SAFETY EVALUATION METHODOLOGY	B1-1
1.2	EVALUATION SUMMARY AND CONCLUSIONS	B1-2
2.0	CONTENTS EVALUATION	B2-1
2.1	CHARACTERIZATION	B2-1
2.2	CONTENT RESTRICTIONS	B2-5
2.3	CONCLUSIONS	B2-5
3.0	RADIOLOGICAL RISK EVALUATION	B3-1
3.1	INTRODUCTION	B3-1
3.2	RISK ACCEPTANCE CRITERIA	B3-1
3.3	ACCIDENT FREQUENCY ASSESSMENT	B3-1
3.4	DOSE CONSEQUENCE ANALYSIS	B3-2
3.5	RISK EVALUATION AND CONCLUSIONS	B3-2
3.6	ACCIDENT FREQUENCY ASSESSMENT	B3-3
3.7	DOSE CONSEQUENCE ANALYSIS	B3-12
4.0	CONTAINMENT EVALUATION	B4-1
4.1	INTRODUCTION	B4-1
4.2	NORMAL TRANSFER CONDITIONS	B4-1
4.3	CONTAINMENT EVALUATION AND CONCLUSIONS	B4-1
5.0	SHIELDING EVALUATION	B5-1
5.1	INTRODUCTION	B5-1
5.2	SHIELDING REQUIREMENTS	B5-1
5.3	SHIELDING EVALUATION AND CONCLUSIONS	B5-1
5.4	SHIELDING ANALYSIS	B5-3
6.0	STRUCTURAL EVALUATION	B6-1
6.1	INTRODUCTION	B6-1
6.2	STRUCTURAL REQUIREMENTS	B6-1
6.2.1	Packaging Materials	B6-1
6.2.2	Packaging Dimensions	B6-1
6.2.3	Tiedown System	B6-1
6.2.4	Lifting Devices	B6-2
6.2.5	Closure Design	B6-2
6.2.6	Normal Transfer Conditions	B6-3

TABLE OF CONTENTS (Continued)

6.3	STRUCTURAL EVALUATION AND CONCLUSIONS	B6-3
6.3.1	Packaging Materials	B6-3
6.3.2	Packaging Dimensions	B6-4
6.3.3	Tiedown System	B6-4
6.3.4	Lifting Devices	B6-4
6.3.5	Closure Design	B6-4
6.3.6	Normal Transfer Conditions	B6-5
6.4	STRUCTURAL ANALYSIS	B6-6
6.4.1	Weight and Center of Gravity Determination	B6-7
6.4.2	Determination of G Loading on 12 in. Thick Reinforced Concrete	B6-33
6.4.3	Pressure Increase and Decrease Evaluation	B6-39
6.4.4	ASME Design and Bolt Engagement Verification	B6-51
6.4.5	Package Lifting Evaluation	B6-61
6.4.6	Penetration Evaluation	B6-68
6.4.7	Low Temperature Brittle Fracture Evaluation	B6-72
6.4.8	Vibration Evaluation (Induced by Peak Shock Loading)	B6-76
6.4.9	Drop Evaluation Loaded with No Shielding (101-SY Package)	B6-101
6.4.10	Drop Evaluation Loaded and Fully Shielded (101-SY)	B6-136
6.4.11	Drop Evaluation Loaded and Partially Shielded (101-SY)	B6-169
6.5	TIEDOWN ANALYSIS	B6-201
7.0	THERMAL EVALUATION	B7-1
7.1	INTRODUCTION	B7-1
7.2	THERMAL SOURCE SPECIFICATION	B7-1
7.3	SUMMARY OF THERMAL PROPERTIES OF MATERIALS	B7-1
7.4	THERMAL EVALUATION FOR NORMAL TRANSFER CONDITIONS	B7-1
7.4.1	Conditions to be Evaluated	B7-1
7.4.2	Acceptance Criteria	B7-2
7.4.3	Thermal Model	B7-2
7.4.4	Thermal Analysis	B7-2
7.5	THERMAL EVALUATIONS AND CONCLUSIONS	B7-3
7.6	THERMAL ANALYSIS	B7-4
8.0	GAS GENERATION EVALUATION	B8-1
8.1	GENERAL INFORMATION	B8-1
8.2	GAS GENERATION EVALUATION AND CONCLUSIONS	B8-1
8.3	HYDROGEN GAS GENERATION ANALYSIS	B8-2
9.0	APPENDIX	B9-1
9.1	REFERENCES	B9-1

LIST OF TABLES

Table B2-1.	Radionuclide Activity for the HMMP Package	B2-2
Table B2-2.	Effective A_2 -- HMMP Package	B2-3
Table B2-3.	Fissile Content	B2-4
Table B3-1.	Risk Acceptance Criteria	B3-1

LIST OF TERMS

ASME	American Society for Mechanical Engineers
ASTM	American Society for Testing and Materials
CWC	Central Waste Complex
DOT	U.S. Department of Transportation
ECN	Engineering Change Notice
EDE	effective dose equivalent
HEPA	high-efficiency particulate air (filter)
HMMP	Hydrogen Mitigation Mixer Pump
LST	lowest service temperature
NBS	Nominal Breaking Strength
NDT	Nil Ductility Testing
NRC	U.S. Nuclear Regulatory Commission
PDC	Packaging Design Criteria
QA	Quality Assurance
RL	U.S. Department of Energy, Richland Operations Office
SARP	Safety Analysis Report for Packaging
SEP	Safety Evaluation for Packaging
WHC	Westinghouse Hanford Company

PART A - PACKAGE DESCRIPTION AND OPERATIONS**1.0 INTRODUCTION****1.1 BACKGROUND INFORMATION**

Radioactive waste material in storage tank 241-SY-101 (101-SY) causes higher-than-normal hydrogen gas buildup in the tank waste. Rollover of the radioactive waste contents occurs periodically during venting of the hydrogen gas. A modified test pump 60 ft long, 19,247 lb in weight, and powered by a 150 horsepower electric motor was installed in 101-SY to evaluate whether the agitation of the tank contents would lead to gradual release of hydrogen and, thereby, avoid safety concerns with periodic release of large quantities of hydrogen. This pump is referred as the Hydrogen Mitigation Mixer Pump (HMMP).

After completion of the testing program for hydrogen mitigation, this pump will be removed from 101-SY. As it is pulled out of 101-SY, the radioactively contaminated pump will undergo a high pressure water spray operation and then will be enclosed inside a portable flexible bag assembly. The pump will then be inserted into a shipping container which provides two containment barriers for the contaminated pump. Approximately 13 ft of the upper section of the pump will be cut off and the shipping container will then be sealed. This loaded shipping container is referred to as the HMMP Package. The packaging and contents will be transferred from the Tank Farms to the Central Waste Complex (CWC) for interim storage and then to T Plant for evaluation and processing for final disposition.

A Packaging Design Criteria (PDC), WHC-SD-TP-PDC-019 (WHC 1994), was developed to provide design criteria for both the onsite transfer and storage of the removed equipment. Data presented in the PDC indicates that the equipment (pump) is a Type B quantity of waste and should be classified as mixed low-level waste for purposes of packaging design and transfer evaluations.

Classification as mixed waste requires that the equipment must be transferred from the Tank Farms to a licensed mixed waste storage facility within 90 days. This classification requires that the packaging must be designed and evaluated to meet special storage acceptance requirements at the CWC. Special package requirements for storage at the CWC include two containment barriers, 20 year service life, and 100 mrem/h or less radiation dose rate at the surface of the package.

1.2 PURPOSE AND SCOPE

This Safety Evaluation for Packaging (SEP) provides safety analyses and evaluations considered necessary to support a safe one-time onsite waste transfer of the HMMP Package. The scope will include the transfer of the HMMP Package from the Tank Farms to the CWC for interim storage and then to T Plant for processing and disposition.

This SEP demonstrates that the short-term onsite transfer of the HMMP Package meets the onsite transportation criteria. This fulfills the onsite transportation safety requirements implemented in WHC-CM-2-14, *Hazardous Material Packaging and Shipping*.

2.0 PACKAGING SYSTEMS

2.1 GENERAL INFORMATION

This section provides a description of the packaging system that will be used to transfer and store the HMMP described in Part A, Section 1.0 of this SEP. Information presented in this section will be evaluated in Part B of the SEP to assure that the proposed packaging system meets identified criteria and requirements.

The packaging consists of two cylindrical carbon steel standard wall pipes with bolted flanged ends which provide two containment barriers for the contaminated pump. The HMMP Package is designed to withstand normal transfer conditions and accident tests described in Part B of this SEP. The design lifetime is 20 years in the environment of the CWC. The HMMP Package will only be transferred in the horizontal position and will include adequate lifting attachments and tiedown devices. Internal shielding, if required, will be added in the form of lead or steel shot in an annular space between two containment barriers to limit dose rates at the surface of the HMMP Package to acceptable values during transfer and interim storage. If additional shielding is required to reduce dose rates, external shielding will be installed on the outside of the HMMP Package.

This SEP will approve transfer of the HMMP Package within one year from date of issue unless otherwise designated by issue of an Engineering Change Notice (ECN).

2.2 CONFIGURATION AND DIMENSIONS

The main packaging assembly consists of a long section of standard wall pipe with closures on each end. The piping section is 64 in. outside diameter x 0.5 in. wall thickness. The closure on one end of the packaging is a 2 in. thick plate welded inside the end of the 64 in. diameter pipe. The inner closure on the opposite end of the assembly is a top hat assembly bolted to a 2 in. thick ring flange attached to the end of the 64 in. diameter pipe. The removable inner closure plate is attached to the ring flange with twenty-eight 1 in. diameter bolts, nuts, and lock washers. A 1/8 in. thick gasket seals the bolted inner plate to the ring flange. The removable outer closure plate is attached to the ring flange with thirty-two 1 in. diameter bolts, nuts, and lock washers. A 1/8 in. thick gasket seals the bolted outer plate to the ring flange. Double containment of the end closures is provided by a 2 in. thick plate welded to the end of the 64 in. pipe at the welded closure end of the packaging and by another top hat assembly installed around the outside of the bolted inner closure end.

Stiffening rings are installed at intervals along the length of the HMMP Package to support/protect the package during lifting and normal transfer

and/or potential accident conditions. An outer layer of plate is installed between the stiffening rings to form a 2 in. wide annulus for installation of shielding material along the full length of the package. The outer plate is 5/16 in. thick along the container length, except from column line 8 through 15 which uses $\frac{1}{2}$ in. thick plate. The shielding annulus also provides double containment of the waste contents along the sidewalls of the package for storage.

The overall length of the HMMP Package is nominally 52 ft.

2.3 MATERIALS OF CONSTRUCTION

Material requirements for the HMMP Package are described in the parts list on Westinghouse Hanford Company (WHC) design Drawing H-2-83734, Sheet 1 (Part A, Section 9.2). In general, all structural components are carbon steel. Specifically, the standard wall $\frac{1}{2}$ in. diameter piping material and closure end plates are American Society for Testing and Materials (ASTM) A671 carbon steel. The outer 5/16 in. diameter plate material is ASTM A516 carbon steel. End closure bolts and nuts are alloy steel American Society of Mechanical Engineers (ASME) SA307. Gasket material for sealing the bolted end closure connections is made of reinforced flexible graphite.

2.4 FABRICATION METHODS

Specific fabrication methods for construction and assembly of the package are described in the "General Notes" of packaging design Drawing H-2-83734, Sheet 1 (Part A, Section 9.2).

2.5 WEIGHTS

The calculated maximum gross weight of the HMMP Package with external shielding (lead shot) and contents (HMMP) is approximately 138,800 lb. The weight of the HMMP Package without shielding and with contents (HMMP) is approximately 72,930 lb. The maximum weight of the package is based on installing shielding material in the full length of the shielding annulus.

2.6 CONTAINMENT BOUNDARY

The packaging enclosure (pipe and end plates) is the single containment required during transfer of the HMMP Package and is the primary containment barrier during interim storage of the package. The primary containment boundary is sealed on one end with a welded plate and is sealed on the opposite end with a bolted top hat assembly and gasket. A secondary containment boundary is provided on the HMMP Package by installing additional plates on each end of the main enclosure, by installing the shielding annulus

the full length of the package, and by sealing with a bolted top hat assembly and gasket. One pipe fitting is provided on the outside of the package for venting and will be sealed during transfer of the package.

2.7 CAVITY SIZE

The cavity size of the HMMP Package is 63 in. diameter by 52 ft long.

2.8 HEAT DISSIPATION

Maximum heat dissipation from waste contents for the HMMP Package is 0.88 W. The heat is transferred passively to the environment.

2.9 SHIELDING

Shielding will be added on the outside surface of the HMMP Package, if required, to limit dose rate at the surface of the package to 100 mrem/h or less. Shielding will consist of lead shot or steel shot, or other approved material, poured through openings provided on the outside wall of the "shielding annulus." If other shielding is required in addition to the lead shot or steel shot, layers of solid lead shielding will be installed around the outside of the package as necessary to limit the dose rate to acceptable values.

If dose rates are slightly above 100 mrem/h after sealing of the package, use of solid lead shielding on the outside of the package only may be considered.

2.10 LIFTING DEVICES

Lifting attachments are installed on each end of the packaging and are suitable for raising and lowering a fully loaded package in the horizontal position. The lifting attachments are designed for use with a special lifting beam assembly (Drawing H-2-83744 in Part A, Section 9.5).

2.11 TIEDOWN DEVICES

Two special attachments are installed on the bottom end and midpoint of the packaging to secure the package to a strongback/tilt mechanism unit on the transport trailer. Stiffening rings are installed at intervals along the length of the packaging and are provided with holes that are used to attach tiedowns to the transport trailer.

3.0 PACKAGE CONTENTS

3.1 GENERAL DESCRIPTION

Contents of the HMMP Package are considered to be the HMMP placed in a portable flexible bag assembly. The following data relates to the HMMP scheduled for removal from 101-SY and placed in the specific package for transfer:

1. The test pump is located in 101-SY. The physical description and reference drawings are as follows:

Maximum length: 60 ft*
Maximum diameter: 53 in.
Estimated weight: 19,427 lb
Reference drawings: H-2-89945 through H-2-89967

3.2 RADIONUCLIDE ACTIVITY

Radionuclide activity in terms of curie content is evaluated in Part B, Section 2.1 and indicates that the HMMP Package must be transported as a Type B quantity of waste. Specifically the total curies of waste material attached to the HMMP is 561 Ci and is 280 times the effective A_2 value of the mixture of radionuclides.

3.3 FISSILE CONTENT

Fissile content (in grams) of the estimated amount of waste material attached to the HMMP is evaluated in Part B, Section 2.2. The evaluation indicated that the quantity of fissile material attached to the pump is 1.8 g. The HMMP is thus considered as "fissile excepted" since the total fissile content is less than 15 g.

*Approximately 13 ft of the upper section of the hydrogen mitigation mixer pump will be cut off after insertion into the shipping container.

4.0 TRANSPORTATION SYSTEM

4.1 TRANSPORTER

The transporter system consists of a truck/trailer assembly suitable for transfer of the HMMP Package system including the shipping container, strongback, and tilting mechanism (maximum 100 tons - Sketch in Part A, Section 9.4). The strongback (Drawing H-2-82736 in Part A, Section 9.3) is used to interface the shipping container with the tilting mechanism. Suitable attachments are provided on the vehicle for securing the HMMP Package to the trailer bed.

4.2 TIEDOWN SYSTEM

Design of a tiedown system is provided to safely secure the HMMP Package on the transport vehicle during transfer to the storage and processing/repackaging facilities. A sketch of the tiedown system is shown in Part B, Section 6.5.

4.3 SPECIAL TRANSFER REQUIREMENTS

1. The speed of the transport vehicle during waste package transfer shall not exceed 35 mph on straight sections of the highway and 15 mph for curved sections of the highway. The maximum speed may be reduced (as directed) due to adverse weather or road conditions.
2. The transporter is considered for "Exclusive Use" only. The transporter is restricted from use for any other purpose while assigned to the 101-SY pump removal project.
3. Escorts shall be provided at the front and rear of the transport vehicle during package transfer to warn and/or control oncoming traffic and to observe the package.
4. The vent opening shall be sealed prior to transfer of the package according to Drawing H-2-83750 (Part A, Section 9.2).
5. The package shall be loaded, secured, and unloaded in the horizontal position.
6. The transport vehicle shall stop at all railroad crossings that have warning lights or crossing gates prior to crossing.
7. The HMMP Package shall be secured to the transport vehicle using the tiedown system described in Part B, Section 6.5.

8. The HMMP Package shall not be transferred at ambient temperatures less than 0 °F and shall not be transferred during extreme fog conditions. If ice or adverse snow conditions exist, the road shall be cleared and sanded prior to transfer.
9. The dose rate on the surface of the package and at 2 m from the vehicle shall be limited to 200 mrem/h and 10 mrem/h, respectively, for transfer of the package. For storage of the package, the dose rate on the surface of the package shall be limited to 100 mrem/h. The dose rate at the vehicle driver location shall not exceed 2 mrem/h during transfers of the package.

5.0 ACCEPTANCE OF PACKAGING FOR USE

The following requirements shall be verified and/or inspections shall be performed prior to use of the HMMP Package according to WHC-CM-4-2, *Quality Assurance Manual*, and Part A, Section 7.0:

1. Verify that all non-destructive testing and inspections have been completed as specified by the design drawings and information included in this SEP.
2. Inspect the package to assure that it is in good physical condition without any visual deficiencies.
3. Inspection shall include the verification of a Quality Assurance (QA) acceptance tag.
4. Verify that bolts do not have headmarks matching those on the "Suspect Fastener Headmark List."
5. Verify gasket material and geometry are in accordance with drawing requirements.
6. Verify visible painted surfaces do not have scratches or gouges exposing bare metal.
7. Verify that there are no gouges, dents, or scratches on flange sealing surfaces that would prevent sealing.

6.0 OPERATING REQUIREMENTS

6.1 GENERAL

Specific operating procedures shall be developed and approved by designated Transportation and Packaging personnel to verify transportation requirements are provided prior to transfer of the package.

All applicable instructions and procedures for onsite transfer of the package shall be in compliance with WHC-CM-2-14. The approved SEP shall be considered the controlling document for transfer of the package except where other applicable WHC requirements are more restrictive. Operating procedures shall include instructions to assure that the package is being used in accordance with the SEP.

Operating procedures, in general, shall cover the mounting of the empty shipping container onto the tilt mechanism on the trailer, loading of the contents into the package, loading of the package on the transport vehicle, transporting the package, and unloading the package at transfer destination(s). Bolt tightening specifications, or reference to the specifications, for all flanged connections shall also be included in the operating procedures.

6.2 INSTALLATION OF PACKAGE CONTENTS

The HMMP (Part A, Section 2.2) will undergo several operations before placement into the shipping container. The pump, as it is removed from the tank, will undergo a high pressure water spray operation and then will be enclosed inside a portable flexible bag assembly prior to insertion into the shipping container. Approximately 13 ft of the upper section of the pump will be cut off after removal. Basic steps for removing the pump and placing into the shipping container are as follows:

1. The shipping container shall be located in the special strongback and tilt assembly on the truck-trailer and raised into the vertical position in accordance with DOE-RL-92-36, *Hanford Site Hoisting and Rigging Manual* (RL 1993) and the vendor's operating manual.
2. The pump shall be attached (hooked) to a portable flexible bag assembly installed on a spray wash assembly in accordance with DOE-RL-92-36, *Hanford Site Hoisting and Rigging Manual* (RL 1993) and the appropriate work plan.
3. During removal from the tank by the crane and during insertion into the portable flexible bag assembly, the pump shall be sprayed with 3000 psi, 160 °F water.

4. The pump shall be fully raised into the portable flexible bag assembly in accordance with DOE-RL-92-36, *Hanford Site Hoisting and Rigging Manual* (RL 1993). The bottom section of the bag shall be remotely closed in accordance with the appropriate work plan. It shall be confirmed that approved absorbent material has been placed in the flexible bag and/or the shipping container to absorb at least twice the amount of expected free liquids that may be present in the waste contents.
5. Using the crane, the pump inside the flexible bag shall be moved at a minimum possible elevation, then lifted approximately 75 ft, transferred over to the tilt assembly, and inserted into the shipping container in accordance with DOE-RL-92-36, *Hanford Site Hoisting and Rigging Manual* (RL 1993) and the appropriate work plan.
6. The shipping container shall be lowered toward the horizontal position in accordance with DOE-RL-92-36, *Hanford Site Hoisting and Rigging Manual* (RL 1993) and the appropriate work plan.
7. In accordance with the appropriate work plan, the loaded shipping container in the tilt assembly shall be moved to the designated area and the upper section of the pump (approximately 13 ft) shall be cut off. The pump shall then be stabilized inside the shipping container.
8. The two top closure plates on the shipping container shall be installed with care not to damage the gasket material. The bolts on the closure plates shall be tightened using the tightening sequence and torquing requirements provided in Drawing H-2-83750 (Part A, Section 9.2) and in the field procedures.
9. The shipping container shall be lowered completely to the horizontal position.
10. The radiation dose rate at any contact surface of the shipping container shall be verified not exceed 100 mrem/h. If this dose rate is exceeded significantly, lead shot or steel shot shall be added to the shipping container annulus and additional solid lead shielding may be installed on the external surfaces to reduce the dose rate to acceptable limits prior to transfer of the package. If dose rates are slightly above 100 mrem/h after sealing of the package, use of solid lead shielding on the outside of the package only may be considered. The surface contamination levels of the shipping container shall be verified to not exceed the limits of the following table (*WHC Radiological Control Manual*, WHC-CM-1-6):

Nuclide (note 1)	Removable (dpm/100 cm ²) (note 2)	Total (Fixed + Removable) (dpm/100 cm ²) (note 3)
U-natural, ²³⁵ U, ²³⁸ U, and associated decay products.	220 alpha	5,000 alpha
Transuranics, ²²⁶ Ra, ²²⁸ Ra, ²³⁰ Th, ²²⁸ Th, ²³¹ Pa, ²²⁷ Ac, ¹²⁵ I, ¹²⁹ I	20	500
Th-nat, ²³² Th, ⁹⁰ Sr, ²²³ Ra, ²²⁴ Ra, ²³² U, ¹²⁶ I, ¹³¹ I, ¹³³ I	200	1,000
Beta-gamma emitters (nuclides with decay modes other than alpha emission or spontaneous fission) except ⁹⁰ Sr and others noted above. Includes mixed fission products containing ⁹⁰ Sr.	1,000 beta/gamma	5,000 beta/gamma
<p>Table notes:</p> <ol style="list-style-type: none"> The values in this table apply to radioactive contamination deposited on, but not incorporated into the interior of the contaminated item. Where contamination by both alpha-and beta/gamma-emitting nuclides exists, the limits established for the alpha-and beta/gamma-emitting nuclides apply independently. The amount of removable radioactive material per 100 cm² of surface area should be determined by swiping the area with dry filter or soft absorbent paper, while applying moderate pressure, and then assessing the amount of radioactive material on the swipe with an appropriate instrument of known efficiency. For objects with a surface area less than 100 cm², the entire surface should be swiped, and the activity per unit area should be based on the actual surface area. Except for transuranic elements, ²²⁶Ra, ²²⁷Ac, ²²⁸Th, ²³⁰Th, ²³¹Pa, and alpha emitters, it is not necessary to use swiping techniques to measure removable contamination levels if direct scan surveys indicate that the total residual contamination levels are below the values for removable contamination. The levels may be averaged over 1 m² provided the maximum activity in any area of 100 cm² is less than three times the values in the Table. 		

10. Install the package tiedowns on the special tilt/trailer per instructions in Part B, Section 6.5. Fully inspect the package to confirm that all transportation requirements are met and release the package for transport.

6.3 UNLOADING THE PACKAGE

1. Verify that the dose rate at the surface of the package does not exceed 100 mrem/h and that surface contamination does not exceed the limits specified in Part A, Section 6.2 (10). Inspect the package and determine that it is acceptable for storage and/or processing of the contents at the designated facility.
2. Determine the actual center of gravity of the package and total gross weight based on the package, waste contents, and shielding installed in or on the package. Information is provided in the tiedown analysis in Part B, Section 6.5 for specific scenarios for addition of shielding which estimate approximate centers of gravity. Prepare a plan to safely lift the package in the horizontal position. Hoisting and rigging operations shall approve this plan.
3. Remove the tiedowns and prepare the package for rigging.

4. Provide a suitable crane, rigging, and lifting beam (Drawing H-2-83744, Part A, Section 9.5) to safely lift the specified load and transfer the package horizontally to the storage or process facility in accordance with DOE-RL-92-36, *Hanford Site Hoisting and Rigging Manual* (RL 1993) and the appropriate work plan.

7.0 QUALITY ASSURANCE

7.1 INTRODUCTION

The QA requirements for packaging and transport systems described in this SEP are based on a short term transfer campaign of specific package contents. In addition, it is not the intent of this SEP to approve reuse of the packaging after removal of the specific contents (equipment) described in this SEP. Under these conditions, an extensive QA program that would normally be provided in a SARP (for long-term use of packaging) is not considered necessary for this short-term transfer campaign. However, a QA plan or specific set of instructions are considered necessary to assure that the packaging and transport systems are acceptable for their intended use.

Verifications shall be made to assure that the following requirements were included in the QA plan or set of instructions and that these instructions were followed to control the design, and fabrication of the packaging:

1. Design, material procurement, construction, testing, and verification activities for the packaging are in accordance with, or equivalent to WHC-CM-4-2 for the assigned safety class.
2. Approval requirements associated with the analysis, design, and fabrication of the packaging and components are in accordance with WHC-CM-3-5, *Document Control and Records Management Manual*, and are properly documented.
3. The assigned Safety Class 3 of the packaging and Safety Class 3 of the packaging components (WHC 1994) are in accordance with requirements of *Management Requirements and Procedures* (MRP) 5.46, WHC-CM-1-3.
4. All required inspections and testing of the packaging are properly documented.

8.0 MAINTENANCE


Preventive maintenance shall be performed on the packaging during the 20 year design lifetime as required to prevent deterioration of the packaging. Preventive maintenance shall consist of inspection, repair and/or replacement of parts, and repainting.

9.0 APPENDICES

9.1 REFERENCES

- RL, 1993, *Hanford Site Hoisting and Rigging Manual*, DOE-RL-92-36, U.S. Department of Energy, Richland Operations Office, Richland, Washington.
- WHC, 1994, *Packaging Design Criteria for Transfer and Disposal of Hydrogen Mitigation Mixer Pump*, WHC-SD-TP-PDC-019, Westinghouse Hanford Company, Richland, Washington.
- WHC-CM-1-3, *Management Requirements and Procedures*, Westinghouse Hanford Company, Richland, Washington.
- WHC-CM-1-6, *WHC Radiological Control Manual*, Westinghouse Hanford Company, Richland, Washington.
- WHC-CM-2-14, *Hazardous Material Packaging and Shipping*, Westinghouse Hanford Company, Richland, Washington.
- WHC-CM-3-5, *Document Control and Records Management Manual*, Westinghouse Hanford Company, Richland, Washington.
- WHC-CM-4-2, *Quality Assurance Manual*, Westinghouse Hanford Company, Richland, Washington.

9.2 HYDROGEN MIXER PUMP CONTAINER (H-2-83750 and H-2-83734)



SEE H-2-83736
SH 5 DETAIL 2

SEE H-2-83736
SH 5 DETAIL 2

FASTEN ATTACHMENT ASSEMBLY TO
STRONGBACK WITH SIX HEX HEAD
BOLTS 1-BUNG-2x4 1/2" L ASTM A325
4 PL 1" # FLAT WASHER, ASTM F436
1 REQD UNDER HEAD OF EACH BOLT, 4 PL.
SEE NOTE 4

PICK POINT FOR LIFTING
CONTAINER WHEN NOT
ATTACHED TO STRONG-BACK

2 1/2" # BOLTS
ATTACHING
CONTAINER TO
STRONG-BACK

SEE H-2-83736 SH 5
DETAIL 2

STRONG-BACK (H-2-83736)


SUPPLIED BY
TRAILER
MANUFACTURER

PLAN
SCALE


GENERAL NOTES (UNLESS OTHERWISE SPECIFIED)

1. THREADED FASTENERS SHALL BE COATED WITH A THIN COAT OF NICKEL NEVER SEIZE #NS-160 OR LOCTITE C. THEN TORQUED TO (SEE NOTE 2) IN ACCORDANCE WITH THE GASKET SUPPLIER'S INSTRUCTIONS AND PROCEDURES TO BE PROVIDED BY COGNIZANT ENGINEER.
2. BOLT TORQUES VALUES
1-8 UNC-2B ASTM A307 GR B = 295-305 ft-lbs
3. BOLTING OF STRONG-BACK TO CONTAINER JOINT CONNECTION. BOLTING SHALL BE PER AISC SPECIFICATION FOR STRUCTURAL JOINTS USING A325 OR BOLTS FROM MANUAL OF STEEL CONSTRUCTION, ALLOWABLE STRESS DESIGN, 9TH EDITION. 2 1/2" BOLTS SHALL BE TIGHTENED TO SNUG TIGHT CONDITION PER WHC-SD-WM-DA170. FASTENER THREADS SHALL NOT BE LUBRICATED BEYOND THE AS DELIVERED CONDITION AS SPECIFIED IN 8(a).
4. THE FOUR CONTAINER ATTACHMENT ASSEMBLIES SHALL BE BOLTED TO THE STRONG-BACK WITH 1-8UNC-2A HEX HEAD BOLTS AND 1-8UNC-2B HEX NUTS. THE BOLTS SHALL BE TIGHTENED TO SNUG TIGHT CONDITION WHC-SD-WM-DA-170. AFTER THE CONTAINER IS IN PLACE AND FULLY BOLTED TO THE CONTAINER ATTACHMENT ASSEMBLY.
5. SHIELD WITH LEAD (Pb) SHOT OR STEEL SHOT. SHIELDING SHALL BE FIELD INSTALLED PER WHC-SD-TP-SEP-026.
6. USE DRUM PLUG (McMASTER-CARR #9019T11) FOR SYSTEM TEST AND TRANSPORT ONLY FOR STORAGE USE VENTED PLUG, (NUCIFIL 016, 2"NPT, 304SS LID AND HOUSING) WITH DETAIL E.
7. STORAGE AND SHIPPING OF CONTAINER SHALL BE AS FOLLOWS: THE CONTAINER SHALL BE SUPPORTED DURING STORAGE AT COLUMNS 6, AND 21. DURING TRANSPORT THE CONTAINER SHALL BE SUPPORTED AT COLUMNS 3 AND 21
8. FOR ALIGNMENT OF THE CONTAINER AND STRONG-BACK IN THE VERTICAL POSITION THE RED PAINT MARK ON THE TOP OF THE CONTAINER SHALL BE IN LINE WITH THE SHIELDING FILLER PLUGS. THE RED PAINT MARK ON THE SIDES OF THE THE CONTAINER SHALL BE IN LINE WITH 2 1/2" BOLTS ATTACHING THE CONTAINER TO THE STRONG-BACK, 1/4" WIDE MAXIMUM.
9. ALIGNMENT OF CONTAINER WITH STRONG-BACK AT ASSEMBLY: LONGITUDINAL CENTER LINES OF THE CONTAINER AND STRONG-BACK SHALL BE EQUAL $\pm 1/8"$.
10. ALL SPECIFICATIONS SHALL MEET THE FOLLOWING REVISIONS:

- A36/A36M-92
- A105/A105M-93
- A194/194M-93a
- A325-93
- F436-93
- A490M-93
- A515/A515M-90
- A671-89a
- A307-94



HYDROGEN MIXER PUMP CONTAINER)
E: 1/2" = 1'-0"




VATION (HYDROGEN MIXER PUMP CONTAINER)
E: 1/2" = 1'-0"


OFFICIAL RECORD
DATE SEP 15 1994

WHC-SD-WM-AP-275 SUPPORTING DOCUMENT	
H-2-83748	SUPPORT
H-2-83744	LIFTING BEAM
H-2-83736	STRONGBACK
H-2-83734	STORAGE CONTAINER
REF NUMBER	TITLE
REF NUMBER	TITLE
REF NUMBER	TITLE
REF NUMBER	TITLE


U.S. DEPARTMENT OF ENERGY DOE Field Office, Richland Westinghouse Hanford Company	
HYDROGEN MIXER PUMP STORAGE TRANSPORT ASSEMBLY ARRANGEMENT	
DATE: 290G	ISSUE NO: 2303
DATE: 701225	REV: 1
H-2-83750-0	



A SECTION
1 SCALE: 1/2" = 1'-0"



B SECTION
1 SCALE: 1/2" = 1'-0"



NUT, HEAVY HEX 2 1/2-4 UNC-2B, ASTM A194 GR 2H 1 REQUIRED, 4 PL

HEX HEAD BOLT 2 1/2-4 UNC-2A ± 7 1/2" LONG ASTM A 449, TYPE 1, W/ 1/4" 1/8" THREAD 1 REQD, 4 PL SEE NOTE 3.

2 1/2" FLAT WASHER, ASTM F436, 2 REQD, 1 UNDER HEAD OF BOLT AND 1 UNDER NUT, 4 PL

HEX HEAD BOLTS 1-8 UNC-2A ASTM A325, TYPE 1, 1 REQUIRED, 24 PL SEE NOTE 4

1" FLAT WASHER, ASTM F436, 1 REQUIRED, UNDER HEAD OF BOLT

NUT, HEAVY HEX 1-8 UN-2B ASTM A194 GR 2H 1 REQUIRED, 24 PL, PREVIOUSLY INSTALLED IN NUT CUPS ON STRONGBACK (H-2-83750)

HEX HEAD BOLT, 1-8 UNC-2A x 4" LONG ASTM A307, GR. 3
WASHER, FLAT 1", ASTM F-436
WASHER, SPLIT-LOCK 1" ANSI B18.21.1 28 EACH REQUIRED FOR INNER TOP CAP SMUG TIGHT

OUTER TOP CAP (H-2-83734) SH 6 DETAIL 3

INNER TOP CAP (H-2-83734) SH 5 DETAIL 9


INNER TOP CAP GASKET 1/8" THICK FLEXITALLIC, FLEXOCARB MRG GASKETS REQUIRED FOR (H-2-83734 SH 2 DETAIL 19) TEMPLATE HOLES FROM (H-2-83734 SH 4)

HEX HEAD BOLT, 1-8 UNC 2A x 4" LONG, ASTM A307 GR. 3
WASHER, FLAT 1" ASTM F-436
WASHER, SPLIT-LOCK 1" ANSI B18.21.1 32 EACH REQUIRED FOR OUTER TOP CAP SEE NOTE 1

OUTER TOP CAP GASKET 1/8" THICK FLEXITALLIC, FLEXOCARB MRG GASKETS REQUIRED FOR (H-2-83734 SH 2 DETAIL 19) TEMPLATE HOLES FROM (H-2-83734 SH 4)

1 DETAIL
1 SCALE: 1/2" = 1'-0"

USE DRUM PLUG (McMASTER-CARR. # 90119T1) FOR CONTAINER TRANSPORT. USE CARBON COMPOSITE FILTER (NUCLEAR FILTER TECHNOLOGY INC., MODEL #NUCFIL 016, DIA 2" 104 STAINLESS STEEL LID AND HOUSING, FLOW RATE >1000M/MIN), FOR STORAGE.



2 DETAIL
1 SCALE: FULL


DATE SEP 15 1994

FOR GENERAL NOTES SEE SHEET 1

DESIGNED BY: AB PHILLIPS CHECKED BY: D. HANLEY DATE: 10/11/94 VS GSTR016/94 DATE: 1/7/94	U.S. DEPARTMENT OF ENERGY DOE Fund Office, Baltimore Washington Nonfissile Campaign HYDROGEN MIXER PUMP STORAGE TRANSPORT ASSEMBLY ARRANGEMENT H-2-83750
DRAWING NUMBER: 107 NUMBER TITLE: REFERENCES ICAOFFICE 90837508 ICAOFFICE POS:5ACD2:13.CO:SS	REVISIONS F 200G 2703 701228 SHEET 2 OF 2


CON FOR TIEDOWN (P/N 1018614)

DRAWING TRACEABILITY LIST



C SECTION
 SCALE : 1/2" = 1'-0"

NOTE: EN
 FROM THE
 3" ON 1"



ASSEMBLY
SCALE: 1/2" = 1'-0"

SEE DWG H-2-83744

CONTAINER MAY BE LIFTED
LUGS SHOWN IN SECTION
2


OFFICIAL RELEASE
DATE SEP 18 1994

FOR GENERAL NOTES SEE SHEET 1

TITLE	REF NUMBER	REFERENCES	REVISIONS

U.S. DEPARTMENT OF ENERGY OEC Field Office, Richmond Washington Hardware Company	
HYDROGEN MIXER PUMP STORAGE TRANSPORT ASSEMBLY ARRANGEMENT	
F 300G 1 SHOWN	2303 1
H-2-83750 0 701228 1	



11-2-83750
 1
 3
 1
 0



GENERAL NOTES (UNLESS OTHERWISE SPECIFIED)

- REMOVE ALL BURRS AND BREAK ALL SHARP EDGES.
- WELD AND INSPECT PER AWS D1.1-1994. ALSO SEE NOTE 10. VT FINAL PASS OF ALL WELDS. VT FIT UP, ROOT PASS AND FINAL PASS OF ALL CONTAINMENT WELDS AND LIFTING WELDS. WT OR PT FINAL PASS OF DESIGNATED WELDS. FINAL PASS OF WELDS MADE BY PIPE SUPPLIER ON PROCURED PIPE SHALL BE VT AND RT BY THE PIPE SUPPLIER. WELDER QUALIFICATIONS AND WELD PROCEDURES PER ASME SECTION IX ARE AN ACCEPTABLE SUBSTITUTION. STAINLESS TO STAINLESS STEEL AND STAINLESS TO CARBON STEEL WELDING SHALL BE PERFORMED PER HS-VS-0013.
- MATERIAL SHALL CONFORM TO THE FOLLOWING SPECIFICATIONS:
 - 5"-4"OD PIPE: ASTM A671, GRADE CC70, CLASS 31 - 1993
 - 2" BOTTOM PLATE, OUTER TOP CAP FLANGE, INNER TOP CAP, INNER CONTAINER FLANGE AT CCL 25, INNER RETAINING PLATE, INNER TOP CAP FLANGE, AND VENT PLATE: ASTM A516, GRADE 70, NORMALIZED - 1990
 - 1 1/2" THICK RINGS, LIFTING LUG, ATTACHMENT PLATE, SUPPORT BAR, 2" BLIND FLANGE, OUTER TOP CAP, SPACERS, BACKING BAR, OUTER CONTAINER FLANGE AT CCL 25, OUTER SHELL, SADDLE SUPPORT PLATE AND SADDLE SUPPORT STIFFENER PLATE: ASTM A36 - 1993
 - VENT PIPE: ASTM A106 - 1994
 - FUNNEL GUSSET PLATES, FUNNEL PLATES, FUNNEL RING AND SADDLE PLATE: ASTM A240 REV B 304L - 1993
 - HEAVY HEX HEAD BOLTS: ASTM A307 GRADE B - 1993
 - FLAT WASHERS: ASTM F436 - 1993
 - LOCK WASHERS: ANSI B18.21.1
 - HEX HEAD PLUG: ASTM A105 - 1993
 - FLANGE GUIDE PINS: ASTM A322 GR4130, HEAT TREATED TO A MINIMUM TENSILE STRENGTH OF 135 KSI AND HARDNESS OF HB 270 - 1991
- ALL MACHINED SURFACES SHALL BE IN ACCORDANCE WITH ANSI B46.1.
- GASKETS SHALL BE FLEXICARB MRG GASKETS BY FLEXITALLIC AND SHALL HAVE A NOMINAL CORE THICKNESS OF 1/8" OF A-304 MATERIAL. GASKETS SHALL HAVE A 0.030" GRAPHITE LAYER ON EACH SIDE.
- PAINT ALL EXTERIOR SURFACES WITH ONE COAT OF AMERLOCK 400 FOLLOWED WITH ONE TOP COAT OF AMERSHIELD. FINAL COLOR SHALL BE AMERON WHITE. DO NOT PAINT SURFACES OF FLANGES. PREPARATION AND APPLICATION SHALL BE PER MANUFACTURER'S INSTRUCTIONS.

(GENERAL NOTES CONTINUED ON SHEET 8, ZONE 2F)



OFFICIAL RELEASE BY WHC DATE SEP 29 1994

NO	TITLE	REFERENCES
H-2-83744	LIFTING BEAM	
H-2-83736	STRONGBACK	
H-2-83750	ASSEMBLY ARRANGEMENT	
WHC-SD-WM-DA-165	SUPPORTING OCC	
REF NUMBER	TITLE	

DRAWING TRACEABILITY LIST

NEXT USED ON H-2-83750

REV	DATE	BY	CHKD	APP'D	DESCRIPTION
1	10/1/93	RN KYLE			ISSUED FOR CONSTRUCTION
2	10/1/93	D. HANCOCK			ISSUED FOR CONSTRUCTION
3	10/1/93	QJ GASTROM			ISSUED FOR CONSTRUCTION
4	10/1/93				ISSUED FOR CONSTRUCTION

CA/PLE - 8083734A

REVISIONS

1 CAD/CDC DOS:5.0:ACD2:12.00:55


U.S. DEPARTMENT OF ENERGY
 OGC Field Office, Richmond
 Westinghouse Hanford Company

HYDROGEN MIXER PUMP STORAGE CONTAINER

DATE: 10/1/93
 SHEET NO: 1001
 DRAWING NO: H-2-83734
 SCALE: SHOWN
 TOTAL SHEETS: 706/34


DATE: 10/1/93
 SHEET NO: 1001
 DRAWING NO: H-2-83734
 SCALE: SHOWN
 TOTAL SHEETS: 706/34

A9-6





1
1

DETAIL (7 REQS. 1 EACH AT COLUMN 2, 4, 5, 12, 13, 22 & 23)
 SCALE: 1 1/2" = 1'-0"



4	4
1	4

DETAIL
 SCALE: 1/2" SIZE




19
1

DETAIL
SCALE: 3/4 SIZE

2
1

DETAIL
SCALE: 1 1/2" = 1'-0"

(16 RECD, 1 EACH AT COLUMN 3, 6, 7, 8, 9, 10, 11, 16, 17, 18, 19, 20, 21 & 24)



8
1


SECTION
SCALE: 3/4 SIZE

OFFICIAL RELEASE
BY NRC
DATE SEP 29 1994


FOR GENERAL NOTES SEE SHEET 1

DESIGNED BY J. KYLE	DATE 1-2-84	U.S. DEPARTMENT OF ENERGY DOE Field Office, Richland Westinghouse Hanford Company
CHECKED BY W. HARRIS	DATE 1-9-84	
SCALE 1/2" = 1'-0"	PROJECT NO. 7-374	HYDROGEN MIXER PUMP STORAGE CONTAINER
DATE 1-2-84	ISSUE NO. 1	
SCALE SHOWN 1/2"	700434	REV. 0


TITLE	REV NUMBER	REFERENCES	REV	DATE	DESCRIPTION
DRAWING TRACEABILITY LIST					
		NEXT USED ON H-2-83734 SH 1			



5
1
DETAIL
SCALE: 1/4 SIZE
(4 PL. 1 ON EACH SIDE OF CONTAINER IN LOCATION SHOWN BETWEEN COL 4 & 5 AND COL 22 & 23)





D
1
SECTION (23 PL.)
SCALE: 1/2 SIZE




NOTE: ATTACHMENT LUG IS TO BE FIELD POSITIONED AND WELDED AFTER CONTAINER IS PLACED INSIDE OF STRONGBACK. 2 9/16" Ø HOLE SHALL BE MATCH DRILLED BETWEEN CONTAINER AND STRONGBACK

2 PL. SEE NOTE 1/4 3/8
 ROOT & 100% OF 1/4 FILLET
 ROOT, 50% & 100% OF 1" FILLET
 MT



6
 1
 DETAIL
 (4 PL. 1 ON EACH SIDE OF CONTAINER IN LOCATION SHOWN BETWEEN COL 1 & 2 AND COL 12 & 13)
 SCALE: 1/4 SIZE



SECTION
 3/8 SIZE


OFFICIAL RELEASE
 BY WMS
 DATE SEP 29 1994

FOR GENERAL NOTES SEE SHEET 1


U.S. DEPARTMENT OF ENERGY DOE Field Office, Richland Westinghouse Hanford Company	
HYDROGEN MIXER PUMP STORAGE CONTAINER	
F 200-G 1001 H-2-83734 0	700434 1 of 3

NO	TITLE	REV NUMBER	TITLE	REV	DATE	BY	CHKD	APP'D	REVISIONS
1	DRAWING TRACEABILITY LIST	1	H-2-83734 SH 1	1					


11-2-83734




(A)
1 VIEW
SCALE: 1 1/2" = 1'-0"



(M)
1 SECTION
SCALE: 1 1/2" = 1'-0"



7
1
DETAIL
SCALE: 3/8 SIZE




18
9
DETAIL
SCALE: 1/2 SIZE

OFFSHORE
DATE SEP 29 1954

FOR GENERAL NOTES SEE SHEET 1

DESIGNED BY R. N. KYLE	DATE 9-10-54	U.S. DEPARTMENT OF ENERGY OCC. Field Office, Richmond Westinghouse Hanford Company
CHECKED BY C. HANLEY	DATE 9-10-54	
DATE 9-10-54	SCALE AS SHOWN	HYDROGEN MIXER PUMP STORAGE CONTAINER
DATE 9-10-54	SCALE 700434	
DRAWING NUMBER H-2-83734-10		PROJECT NUMBER H-2-83734

TITLE	REV NUMBER	REFERENCES	TITLE	DATE	BY	CHKD	APP'D	REVISIONS
DRAWING TRACEABILITY LIST								
NEXT USED ON H-2-83734 SM 1								
DRAWING: HCS3734-0								
TELETYPE: C35:5.9:AC02:12.00:55								



GUIDE PIN HOLE, $9/16" \pm 1/32$ THRU, 2 PLACES, SEE NOTE

1/2 THICK RETAINING PLATE

1/2 THICK RING

RETAINING RING

INNER TOP CAP & CONTAINER

(32)

(32)

4'-10 1/2"


5'-3 00"

BOLT HOLE (3'-1 00")
SEE NOTE

BOLT HOLE, $1 3/16" \pm 1/32$ THRU, 28 PLACES, SEE NOTE

INNER TOP CAP & CONTAINER TEMPLATE OD (4'- THICK RING

NOTE: BOLT HOLE



1 1/2"

15/16" THRU FOR 3/4 TON SHACKLE

3/4" THICK PLATE, ASTM A36


21

DETAIL

SCALE: FULL SIZE

9
1

5 4 3 2 1



TAIL

3/16 SIZE


11-2-B3734



OFFICIAL RELEASE
BY NRC
DATE SEP 29 1994

FOR GENERAL NOTES SEE SHEET 1


U.S. DEPARTMENT OF ENERGY DOE Field Office, Richland Westinghouse Hanford Company	
HYDROGEN MIXER PUMP STORAGE CONTAINER INSIDE TOP CAP	
SHEET NO. 1 OF 1	PROJECT NO. H-2-83734
DRAWING NO. F 200-G 1001	SHEET NO. 1 OF 5
DATE 7/20/83	SCALE SHOWN 1" = 6"

NO.	TITLE	REV. NUMBER	TITLE	DATE	BY	CHKD.	APP'D.





9
DETAIL
SCALE: 3/4 SIZE



8
DETAIL
SCALE: 3/4 SIZE


DETAIL
SCALE: 3/16 SIZE

DATE SEP 29 1984


FOR GENERAL NOTES SEE SHEET 1

U.S. DEPARTMENT OF ENERGY OGE Field Office, Alton Washington, Missouri Company	HYDROGEN MIXER PUMP STORAGE CONTAINER OUTER TOP CAP
SHEET NO. 1001 DRAWING NO. 200-G DATE SHOWN 700434	PROJECT NO. H-2-83734 SHEET NO. 0


NO.	TITLE	REV. NUMBER	REFERENCES	REVISIONS
1	CRAWLING TRACEABILITY LIST		INCLT USED ON H-2-83734 SH 1	
2			ICADP/LE 8083734F	ICADG/DE DOS:3.0JAC02:12.00:SS



SECTION K
SCALE: 1 1/2" = 1'-0"




SECTION L
SCALE: 1 1/2" = 1'-0"




H
5 SECTION
SCALE: 3/8" SIZE

J
1 SECTION
SCALE: 1 1/2" = 1'-0"



G
5 SECTION
SCALE: 1 1/2" = 1'-0"





15
DETAIL
SCALE: 1/2" SIZE


OFFICIAL RELEASE
BY 10-3
DATE SEP 29 1994

FOR GENERAL NOTES SEE SHEET 1

DESIGNED BY RN KYLE	DATE 4-24	U.S. DEPARTMENT OF ENERGY DOE Field Office, Colorado Westborough Materials Company
CHECKED BY D. WATKINS	DATE 9-04	
APPROVED BY [Signature]	DATE 2-14	
DATE 1-5-54	BY OSTROM	
HYDROGEN MIXER PUMP STORAGE CONTAINER		SHEET NO. 1001 OF 1001 DRAWING NO. H-2-83734-0 SCALE SHOWN 1" = 700.434"



TITLE	REF NUMBER	REFERENCES	TITLE	REVISIONS
DRAWING TRACEABILITY LIST		NEXT USED ON H-2-83734 SH 1		






GENERAL NOTES (CONTINUED FROM SHEET 1)

7. THREADED FASTENERS SHALL BE COATED WITH NICKEL NEVER SEIZE #HS-160 OR LOCITE C.
8. MATERIAL SHALL BE MARKED SUCH THAT IT IS TRACEABLE TO THE CHEMICAL ANALYSIS AND MECHANICAL TEST REPORTS. HEAT NUMBER TRACEABILITY OF MATERIAL SHALL BE MAINTAINED ON THE BILL OF MATERIALS.
9. EACH ANNULUS SHALL BE PRESSURE DECAY TESTED TO 11.2 PSI PER HS-BS-0076 TYPE I, HOLD 10 MINUTES (NO LEAKAGE ALLOWED).
10. WELD AND INSPECT ALL PRIMARY CONTAINMENT WELDS PER ASME B & PV CODE, SECTION VIII.
11. GRIND WELD BEAD ON STIFFENING RINGS AS NECESSARY TO ALLOW FITTING OF OUTSIDE SHELL.
12. MARK PER HS-BS-0015, TYPE B, IN LOCATION INDICATED USING 1" HIGH BLACK CHARACTERS:
 DWG. NO., REV. NO. _____ LBS
 CONTAINER WT. _____
13. MARK PER HS-BS-0015, TYPE B, IN LOCATION INDICATED USING 1" HIGH BLACK CHARACTERS:
 DWG. NO., REV. NO. _____ LBS
 TOP CAP WT. _____
14. MARK PER HS-BS-0015, TYPE B, IN LOCATION INDICATED USING 2" HIGH BLACK CHARACTERS:
 ANNULUS NO. _____
 ANNULUS NUMBER IS THE SAME AS THE COLUMN LINE NUMBER ON THE LEFT SIDE OF ANNULUS.



SECTION F SCALE: FULL



SECTION E SCALE: FULL


DETAIL 13/9 SCALE: 1 1/2" = 1'-0"

OFFICIAL RECORD DRAWING
DATE SEP 29 1954

FOR GENERAL NOTES SEE SHEET 1


DESIGNED BY: RN KYLE	DATE: 8-24-54	U.S. DEPARTMENT OF ENERGY OSR Field Office, Richmond Washington Ordnance Company
CHECKED BY: J. HARRIS	DATE: 9-08-54	
DATE: 9-16-54	DATE: 9-20-54	
DATE: 9-24-54	DATE: 9-24-54	
DRAWN BY: AUSTROM		HYDROGEN MIXER PUMP STORAGE CONTAINER
SCALE: SHOWN		
DRAWING NUMBER: H-2-83734		REV: 0

TITLE	REV NUMBER	REFERENCES	TITLE	REVISIONS
CRAWLING TRACEABILITY UST	1	NOT USED ON H-2-83734 Sd 1	CADFILE	8083734H
			ICADCODE	005.5.0.A02:12.C0.55




14
8


DETAIL
SCALE 1/4 SIZE




P SECTION
SCALE: FULL



16 DETAIL
SCALE: FULL



N SECTION
SCALE: 1 1/2" = 1'-0"



17 DETAIL
SCALE: FULL

OFFICIAL TITLE
SPEC. NO.
DATE SEP 29 1994

FOR GENERAL NOTES SEE SHEET 1

DESIGNED BY	RN KYLE	DATE	1-8-94
CHECKED BY	D. WILSON	DATE	9-9-94
APPROVED BY	[Signature]	DATE	9-29-94
DATE	1-5-94		


U.S. DEPARTMENT OF ENERGY
OCE Field Office, Richmond
Westinghouse Monitor Company

**HYDROGEN MIXER PUMP
STORAGE CONTAINER**


SCALE: SHOWN FOR 7004-34
SHEET 9 OF 9
A9-14

NO.	TITLE	REV. NUMBER	DATE	DESCRIPTION	BY	CHKD	APP'D	OTHER
1	DRAWING TRACEABILITY LIST							
2								

9.3 STRONGBACK SECTIONS AND DETAILS (H-2-83736)



TOP PLAN
SCALE: 3/4"=1'-0"





ELEVATION
SCALE: 3/4"=1'-0"


GENERAL NOTES

(UNLESS OTHERWISE SPECIFIED)


- ALL PLATE, SHEET, FLAT BAR, AND WIDE FLANGES SHALL CONFORM TO ASTM A36-1992 CARBON STEEL. ALL STRUCTURAL TUBING SHALL CONFORM TO ASTM A500-1992 GRADE B CARBON STEEL. HEX HEAD BOLTS SHALL CONFORM TO ASTM A325-1993 CARBON STEEL. HEX NUTS SHALL CONFORM TO ASTM A194 GRADE 2H CARBON STEEL.
- WELD AND INSPECT PER AWS D1.1-1992. THE FINAL PASS OF ALL WELDS. THE FINAL PASS OF DESIGNATED WELDS. WELD QUALIFICATIONS AND WELDING PROCEDURES PER ASME SECTION IX-1992 ARE AN ACCEPTABLE SUBSTITUTION.
- REMOVE ALL BURRS AND BREAK ALL SHARP EDGES.
- IDENTIFY ASSEMBLY WITH THE DRAWING NUMBER AND DRAWING REVISION NUMBER IN THE LOCATION INDICATED ON THE DRAWING ON BOTH SIDES OF THE STRONGBACK PER HS-BS-0015, TYPE B. CHARACTERS SHALL BE 2" HIGH AND SHALL BE PAINTED WITH BLACK ENAMEL.
- PAIN "STRONGBACK WEIGHT **** LESS" IN THE LOCATION INDICATED ON THE DRAWING ON BOTH SIDES OF THE STRONGBACK PER HS-BS-0015, TYPE B. THE ASSEMBLY SHALL BE WEIGHED PRIOR TO PAINTING THE ABOVE AND THE WEIGHT TO THE NEAREST POUND SHALL BE INSERTED WHERE THE **** ARE. THE CHARACTERS SHALL BE 2" HIGH AND SHALL BE BLACK ENAMEL ON A YELLOW ENAMEL BACKGROUND.
- THE FOUR CONTAINER ATTACHMENT ASSEMBLIES SHALL BE BOLTED TO THE STRONGBACK WITH 1-BUNC-2A HEX HEAD BOLTS AND 1-BUNC-2B HEX NUTS. THE BOLTS AND NUTS SHALL BE FULLY TIGHTENED AFTER THE CONTAINER IS IN PLACE AND FULLY BOLTED TO THE CONTAINER ATTACHMENT ASSEMBLY BY USING THE TURN OF THE NUT METHOD PER ASCE STEEL CONSTRUCTION MANUAL, 9TH EDITION.
- AFTER FABRICATION, PREPARE AND PAINT ALL EXPOSED CARBON STEEL EXCEPT NUTS, BOLTS, BOLT AND WASHER CONTACT SURFACES, BOLT HOLES, BEARINGS AND PINS WITH TWO COATS OF AMERLOCK 400 AND ONE TOP COAT OF AMERCCAT 450 HS. FINAL COLOR SHALL BE BEIGE RT-8304. PREPARATION AND APPLICATION SHALL BE PER MANUFACTURER'S INSTRUCTIONS.
- ROUND BAR USED FOR PINS SHALL CONFORM TO ASTM A331-1990, STANDARD SPECIFICATION FOR COLD-FINISHED ALLOY STEEL BARS, GRADE E4340. THE ROUND BAR SHALL BE COLD DRAWN AND SHALL BE QUENCHED AND TEMPERED. THE ROUND BAR SHALL HAVE A MINIMUM HARDNESS OF HRC 51. WORK SHALL BE DONE BY TRAILER MANUFACTURER.
- HOLES THROUGH CLEVIS PLATES AND LUGS AT CONNECTIONS A AND B SHALL BE IN-LINE WITHIN A DIAMETER OF .0035 INCH. WORK SHALL BE DONE BY TRAILER MANUFACTURER.
- RING PINS SHALL BE INSTALLED THROUGH THE 3" DIAMETER PIN ON BOTH SIDES OF THE ASSEMBLY AS SHOWN. RING PINS SHALL BE 1/2" DIAMETER x 3 1/4" EFFECTIVE LENGTH AND SHALL BE SUPPLIED WITHOUT A COLLAR. RING PINS SHALL BE ZINC PLATED CARBON STEEL. RING PINS SHALL BE SUPPLIED WITH A J5 COTTER PIN FOR SECURING IN PLACE. RING PINS MAY BE PROCURED FROM:
 AMSCO, INC.
 P.O. BOX 80304
 SEATTLE, WA 98108
 1-800-426-0244
 RING PINS TO BE INSTALLED BY TRAILER MANUFACTURER.
- BEARINGS SHALL BE GAR-MAX FILAMENT WOUND, HIGH LOAD, SELF-LUBRICATING BEARINGS AS MANUFACTURED BY CARLOCK BEARINGS, INC., BEARING #CM4856. BEARINGS SHALL HAVE A NOMINAL SIZE OF 3" ID x 3 1/2" OD. BEARINGS FOR THE 2" CLEVIS PLATES SHALL BE 1 15/16" LONG. BEARINGS FOR THE 3" LUGS SHALL BE 2 15/16" LONG. BEARINGS SHALL BE PRESS FIT AND SHALL BE INSTALLED PER MANUFACTURER'S INSTRUCTIONS. BEARINGS TO BE INSTALLED BY TRAILER MANUFACTURER.
- SEAL WELD ALL JOINTS THAT ARE NOT WELDED.



WHC-SD-WM-CA-165 SUPPORTING DOC H-2-83734 STORAGE CONTAINER REF NUMBER TITLE REFERENCES NEXT USED ON W-2-83750 DRAWING TRACEABILITY LIST	ICADPLE 8083736A ICADGCE 8083736A ICADGCE 8083736A	REVISIONS 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15	U.S. DEPARTMENT OF ENERGY DOE Field Office, Richmond Warehouse Standort Company STRONGBACK PLAN AND ELEVATION H-2-83736 F 200-G 1001 700433 1 of 15
--	--	--	--



MM
 1
 BOTTOM VI
 SCALE: 3/4" = 1'-0"




(SHOWN WITHOUT BASE ASSEMBLIES)


FOR GENERAL NOTES SEE SHEET 1

U.S. DEPARTMENT OF ENERGY DOE Field Office, Richmond Westinghouse Nuclear Company	
STRONGBACK SECTIONS AND VIEWS	
DRAWING NO: 200-G TITLE: STRONGBACK SECTIONS AND VIEWS DATE: 11-2-83 DESIGNED BY: JLD CHECKED BY: JLD SCALE: SHOWN SHEET: 2 OF 2	PROJECT NO: 1001 DRAWING NO: H-2-83736 REV: 0 SCALE: SHOWN SHEET: 2 OF 2


DWG NO	TITLE	REV NUMBER	REFERENCES
200-G	STRONGBACK SECTIONS AND VIEWS	0	



E SECTION
SCALE: 3/16 SIZE



C VIEW
SCALE: 3/16 SIZE
(SHOWN WITH BASE ASSEMBLY AND CONTAINER ATTACHMENT ASSEMBLY REMOVED)



D SECTION (2 PL)
SCALE: 3/16 SIZE

NOTE: PROVIDE CMTR TRACEABILITY FOR J LUG

FOR GENERAL NOTES SEE SHEET 1



DESIGNED BY	KD JUNI
CHECKED BY	J. HARVEY
DATE	1-27-94
APP'D BY	TR BENECASTI
DATE	5-94


U.S. DEPARTMENT OF ENERGY
DOE Field Office, Richland
Westinghouse Hanford Company

STRONGBACK SECTIONS AND VIEWS


NO	TITLE	REV NUMBER	REFERENCES	TITLE	BY	DATE	REVISIONS	DATE	BY	DATE	SCALE	NO
1	DRAWING TRACEABILITY LIST		NEXT USED ON SHEET 1									
					CAOPLE	8083736C						

SCALE: 200-G 1001 H-2-83736 0
SCALE SHOWN 1:1 700+33





SECTION
3/16 SIZE



H SECTION
SCALE: 3/16 SIZE


FOR GENERAL NOTES SEE SHEET 1

DESIGNED BY	A. PHILLIPS	DATE	5-22-94
CHECKED BY	D. VANCE	DATE	6-24-94
DRAWN BY	J. H. ...	DATE	5-27-94
DATE SHOWN	TR. BENEGAS	DATE	4-94


U.S. DEPARTMENT OF ENERGY
DOE Field Office, Richmond
Westinghouse Hanford Company

STRONGBACK SECTIONS


NO.	TITLE	REF NUMBER	TITLE	DESCRIPTION	DATE	BY	CHKD	APP'D	OTHER	REVISIONS	SCALE	SHEET NO	TOTAL SHEETS
1	DRAWING TRACEABILITY LIST											4	10
CADFILE: E0837360 ICA0000E DOS:3.3:ACD2:12.00:55											200-G 1001 H-2-83736 0	0	



BASE PLATE PLAN



FRONT VIEW




SIDE VIEW

1 ATTACHMENT ASSEMBLY
 SCALE: 3"=1'-0" (4 RECD)
 (PROVIDE CNTR TRACEABILITY FOR THIS ITEM)

NOTE: THE SIDES OF THIS ASSEMBLY WHICH COME IN CONTACT WITH THE 1" x 4 3/4" x 1'-0" PLATES MOUNTED ON TOP OF THE W36 SHALL BE MACHINED AS REQUIRED SO ASSEMBLY WILL SLIDE SMOOTHLY BETWEEN PLATES. DIMENSION +0
 "A" TO BE EQUAL TO DIMENSION "B" -1/32 (SEE SHEET 3 AND 7 FOR DIMENSION "B")


STIFFENER PLATE, 2" THICK, 4PL.
 ROOT PASS & FINAL PASS MT MT
 STIFFENER PLATE TO CLEVIS & BASE PLATE

(3 1/2") FOR HOLE AND BEARING REQUIREMENTS SEE




PLAN

NOTE: CLEVIS PLATES ARE TO BE PLACED AS SHOWN USING THE 3" LUG ON THE STRONGBACK AS A SPACER TO INSURE A SNUG FIT THE CLEVIS PLATES SHALL HAVE DIRECT CONTACT WITH BOTH SIDES OF THE LUG BEFORE WELDING IN PLACE




FRONT VIEW

CLEVIS TO BASE
2 PL
MT



SIDE VIEW



3
2
SCALE: 3"=1'-0"
(2 PL)
(6 SIMILAR)


2
1
BASE CLEVIS ASSEMBLY
SCALE: 3"=1'-0" (2 RECD)
(DETAIL 2 SHALL BE FABRICATED BY TRAILER MANUFACTURER)

FOR GENERAL NOTES SEE SHEET 1

DRAWN A. PHILLIPS 12-94 CHECKED D. HENDON 12-94 DATE 11/2/94 DOE DWT BENEGAS 14-94		U.S. DEPARTMENT OF ENERGY DOE Field Office, Richmond Westinghouse Hanford Company	
STRONGBACK DETAILS			
REV. 200-G DATE SHOWN	REVISIONS 1001	SHEET NO. H-2-83736 OF 5	DATE


NO	TITLE	REF NUMBER	TITLE	DATE	BY	CHKD	APP'D	OTHER	OTHER
1	DRAWING TRACEABILITY LIST								

11-2-83736




CC SECTION
 4 SCALE: 3/4 SIZE

(SECTION CC SHALL BE ASSEMBLED BY TRAILER MANUFACTURER)



6 BASE ASSEMBLY PIN
 SCALE: 3/4 SIZE

(DETAIL 6 SHALL BE SUPPLIED BY TRAILER MANUFACTURER)



NOTE: 1/16"x15" CHAMFERS ARE TO BE PLACED ONLY ON THE SIDE OF THE LUG AND CLEVIS PLATES THAT THE BEARINGS WILL BE INSTALLED FROM

BB
SECTION
4 SCALE: 3/4 SIZE


(SECTION BB SHALL BE FABRICATED BY TRAILER MANUFACTURER)

FOR GENERAL NOTES SEE SHEET 1


DESIGNED BY PHILLIPS 4-94 CHECKED BY HANNAH 6-94 DATE 11-94 TR. BENECAS 4-94	U.S. DEPARTMENT OF ENERGY DOE Field Office, Richmond Westinghouse Hanford Company
STRONGBACK PIN & SECTIONS	
F 200-G 1001 H-2-83736 0 SCALE SHOWN 1:1	A9-21

NO	TITLE	REF NUMBER	TITLE	DESCRIPTION	DATE	BY	CHKD	APP'D
1	DRAWING TRACEABILITY LIST							
2								


11-2-83736



VIEW
SCALE: 3/16 SIZE



VIEW
SCALE: 3/16 SIZE




SECTION
SCALE: 3/16 SIZE

FOR GENERAL NOTES SEE SHEET 1


DRAWN BY: AL PHILLIPS CHECKED BY: D. HAYNES DATE: 12-22-94 DESIGNED BY: D. HAYNES DATE: 12-22-94 DESIGNED BY: D. HAYNES DATE: 12-22-94	U.S. DEPARTMENT OF ENERGY DOE Field Office, Richmond Westinghouse Hanford Company
STRONGBACK SECTIONS & VIEWS	
SHEET NO: F SCALE: SHOWN PROJECT NO: 200-G DRAWING NO: 1001	SHEET NO: H-2-83736 OF: 0 SCALE: 1/8" = 1'-0" PROJECT: 700433

NO	TITLE	REF NUMBER	TITLE	DESCRIPTION	REV	DATE	BY	CHKD	DATE	OTHER	OTHER

11-2-03736
 5 7 3
 4 0



5 4 3 2 1



- 1\"/>
- COPE TO FIT, TYP 32 PL
- 1 1/2\"/>
- 1\"/>
- 5 11/16\"/>
- (7/16)\"/>
- 7/16\"/>

5
1

DETAIL

SCALE: 1 1/2" = 1'-0"

(PROVIDE CNTR TRACEABILITY FOR 2" AND 1 1/2" PLATE FOR THIS DETAIL)


AUG 12 1994


FOR GENERAL NOTES SEE SHEET 1

U.S. DEPARTMENT OF ENERGY DOE Field Office, Richmond Westinghouse Hanford Company	
STRONGBACK SECTIONS AND VIEWS	
NO. 1 200-G SCALE SHOWN 1" = 700433	NO. 1001 H-2-83736 700433


NO.	TITLE	REF NUMBER	REFERENCES	TITLE	DATE	BY	CHKD	APP'D	OTHER	OTHER
1	DRAWING TRACEABILITY LIST									
		NEXT USED ON SHEET 1								

11-2-83736





SECTION (2 PL)
SCALE: 1 1/2" = 1'-0"






VIEW (2 PL)
SCALE: 1 1/2" = 1'-0"

FOR GENERAL NOTES SEE SHEET 1

4-29 12 7:59

CHECKED BY: D. HAVENS 18-34 DATE: 11/15/94 DESIGNED BY: TR. BENECAZI 5-94	U.S. DEPARTMENT OF ENERGY OCE Field Office, Richmond Westinghouse Hanford Company
STRONGBACK SECTION AND VIEW	
SHEET: F DRAWING NO: 200-G PROJECT NO: 1C01 SHEET NO: 9 TOTAL SHEETS: 9	REV: 0 DATE: 11-15-94 BY: TR. BENECAZI CHECKED BY: D. HAVENS
DRAWING TRACEABILITY LIST NEXT USED ON SHEET 1 CADFILE: 2083736J I:\CADD\005\3\ACD2\12 00:55	





Z VIEW
SCALE: 1 1/2" = 1'-0"

4 PL
1/4" THK STIFFENER
2" 4 PL
1/4" THK LINER
1" THK STIFFENER
COPE 1/4" THK LINER AS REQUIRED FOR 1/2" THK STIFFENER 12 PLACES
1/4" THK LINER 1/2" THK LINER
SEE DETAIL **S**

1/2" THK STIFFENER TO W36X160 12 PL
STIFFENER THK LINER
4 PL

1/2" THK STIFFENER 6 PL

4 PL (1) 1" MT
2" THK 4 PL
1/2" THK 4 PL
4 PL 1 7/8" MT
(1 3/4)" 4 PL MT
(7/16)" 4 PL MT

FOR GENERAL NOTES SEE SHEET 1


DESIGNED BY: KO JUNG CHECKED BY: D. HAVENS DATE: 12-14-74 DRAWN BY: TR. BENEKAS DATE: 5-84	U.S. DEPARTMENT OF ENERGY OGE Field Office, Richmond Westinghouse nonferrous Company
STRONGBACK SECTIONS AND VIEWS	
SHEET NO: 200-G DRAWING NO: 1001 PROJECT NO: H-2-83736	SCALE: SHOWN DATE: 700433 SHEET NO: 10 OF 10

NO.	DATE	REVISIONS


DRAWING TRACEABILITY LIST

NO.	DATE	TITLE	REF NUMBER	TITLE


ICAO FILE # 83736-C
 ICAO CODE 805,33-ACD2-12 00 85



SECTION 2 PL
 EE 8 SCALE: 1 1/2"=1'-0"




VIEW AA 10 SCALE: 1 1/2"=1'-0"



FOR GENERAL NOTES SEE SHEET 1

U.S. DEPARTMENT OF ENERGY DOE Field Office, Richland Westinghouse Hanford Company	STRONGBACK SECTIONS AND VIEWS
H-2-83736 0	0

NO.	TITLE	REV. NUMBER	REFERENCES	TITLE	DATE	BY	CHKD	APP'D	OTHER
1	CRAWLING TRACEABILITY LIST		INDXT USED ON SHEET 1						
CADFILE 8083735L					ICADCODE 005-3.3-ACD2-12 00:55				




7
11


DETAIL
SCALE: FULL

LL
11


SECTION
SCALE: FULL



HH SECTION
SCALE: FULL



KK SECTION
SCALE: FULL




JJ SECTION
SCALE: FULL

FOR GENERAL NOTES SEE SHEET 1

DRAWN BY: KD JUNI CHECKED BY: D. WELLS DATE: 12-94 TR: BENECASTI 5-94	U.S. DEPARTMENT OF ENERGY DOE Field Office, Richland Westinghouse Hanford Company
STRONGBACK SECTIONS AND DETAILS	
TITLE: 200-G REF: 1001 SCALE: SHOWN SHEET: 12 OF 12	H-2-8373610


TITLE	REF NUMBER	REFERENCES	REVISIONS





NOTE: 1" & 1/2" STIFFENER PLATES SHALL BE INSTALLED ON CENTERLINE OF COLUMNS, WELDS & DIMENSIONS SHOWN ARE TYP FOR CONNECTING STIFFENER PLATES AND LINER PLATES TO EACH OTHER & TO THE TUBE STEEL AND WIDE FLANGE

3/16" 1 1/2" - 12 / 3/16" 1 1/2" - 12 STIFFENER TO TS4X4X3/8 SEAL AS REQD SEE NOTE 12



B SECTION
 1 SCALE: 1 1/2" = 1'-0"
 (TYP AT COL 2 & COL 3, LINER PLATE & 1/2" STIFFENER PLATE CONFIGURATION & WELDING ALSO TYP AT COL 1 & COL 5)



GG SECTION
 1 SCALE: 1 1/2" = 1'-0"
 (TYP 2 PL MIDSPAN BETWEEN COLUMNS 1 & 2 AND)



(K) SECTION
 SCALE: FULL




(J) VIEW (B PL)
 SCALE: FULL

FOR GENERAL NOTES SEE SHEET 1


DRAWN: KD LUNT CHECKED: S. HAYES DATE: 10-94 DESIGNED: TR BENECASTI DATE: 5-94	U.S. DEPARTMENT OF ENERGY DOE Field Office, Richmond Warehouse/Monland Campus
STRONGBACK SECTIONS	
SIZE: F NO. IN SET: 200-G SHEET NO.: 1001 TITLE: H-2-8373610 SCALE: SHOWN DATE: 700+33 1 OF 13	11-2-83736 13 2

NO.	TITLE	REF NUMBER	TITLE	REVISIONS
1	DRAWING TRACEABILITY LIST			
	NEXT USED ON SHEET:			

CAGILE 8083736N
 ICODE 005 3.3-CD2-12.00.55




S
7
 VIEW
 SCALE: 3/16 SIZE




NOTE: INSTALLATION SIMILAR AT COLUMN LINE 5

M M
7 3
 SECTION
 SCALE: 3/16 SIZE



R SECTION
SCALE: 3/16 SIZE




3 DETAIL (24 REOD)
SCALE: FULL


FOR GENERAL NOTES SEE SHEET 1

U.S. DEPARTMENT OF ENERGY DOE Field Office, Richmond Westinghouse Institute Company	
STRONGBACK SECTIONS & VIEWS	
DRAWN BY: J. BENEGASI CHECKED BY: J. BENEGASI DATE: 4-94	SCALE: 1/2" = 1'-0" SHEET NO: 1001 PROJECT NO: 200-G DRAWING NO: H-2-83736 DATE: 11-2-83


NO	TITLE	REF NUMBER	TITLE	DESCRIPTION	REV	DATE	BY	CHKD	APP'D
1									



G SECTION
SCALE: 3/16 SIZE



L SECTION
SCALE: 3/16 SIZE



SECTION
SCALE: 3/16 SIZE

FOR GENERAL NOTES SEE SHEET 1


DRAWN: KD JUNT CHECKED: D. HANDEL DATE: 1/2/94 SIZE: 1/2" x 1/2"	U.S. DEPARTMENT OF ENERGY DOE Field Office, Richmond Westinghouse Manford Company
STRONGBACK SECTIONS AND VIEWS	SHEET: F ALIAS NO: 200-G PAGE NO: 1001 DRAWING NO: H-2-83736 REV: 0

NO	TITLE	REF NUMBER	REFERENCES	REVISIONS


11-2-83736

9.4 TILT TRAILER SKETCH

101-SY Tilt-Trailer Configuration.



9.5 LIFTING BEAM ASSEMBLY (H-2-83744)




3" x 2'-7" LONG ROD
 WITH 3-4UNC-2A x 5"
 THREAD EACH END, 2

ASSEMBLY
 SCALE: 3/16 SIZE

GENERAL NOTES
(UNLESS OTHERWISE NOTED)

1. REMOVE ALL BURRS AND BREAK ALL SHARP EDGES.
2. AFTER FABRICATION AND ACCEPTANCE OF LOAD TESTING, PREPARE AND PAINT ALL EXPOSED CARBON STEEL SURFACES EXCEPT PINS, NUTS, CLEAVES, THE THREAD ON THE ROUND BAR, AND THE INSIDES OF HOLES, WITH TWO COATS OF AMERLOCK #400 FOLLOWED BY ONE COAT OF AMERCOAT #450HS. COLOR SHALL BE BIEGE RT-8304. PREPARATION AND APPLICATION SHALL BE PER MANUFACTURER'S INSTRUCTIONS.
3. PAINT "LOAD CAPACITY 50 TONS" ON BOTH SIDES OF THE WIDE FLANGE BEAM IN THE LOCATION INDICATED ON THE DRAWING PER HS-B5-0015 TYPE 8. CHARACTERS SHALL BE 2" HIGH AND SHALL BE BLACK ENAMEL ON A YELLOW ENAMEL BACKGROUND.
4. PAINT DRAWING NUMBER AND DRAWING REVISION NUMBER ON BOTH SIDES OF THE WIDE FLANGE IN THE LOCATION INDICATED ON THE DRAWING PER HS-B5-0015, TYPE 8. CHARACTERS SHALL BE 1/2" HIGH AND SHALL BE BLACK ENAMEL.
5. PAINT "WEIGHT 1440 LBS" ON BOTH SIDES OF THE WIDE FLANGE BEAM IN THE LOCATION INDICATED ON THE DRAWING PER HS-B5-0015 TYPE 8. CHARACTERS SHALL BE 1" HIGH AND SHALL BE BLACK ENAMEL ON A YELLOW ENAMEL BACKGROUND.
6. WELD AND INSPECT PER AWS D1.1, VI FINAL PASS OF ALL WELDS. MT INDICATED WELDS BEFORE AND AFTER LOAD TESTING. WELD QUALIFICATIONS PER ASME SECTION IX ARE AN APPROVED SUBSTITUTION.
7. THE ASSEMBLY SHALL BE LOAD TESTED PER HANFORD SITE HOISTING AND RIGGING MANUAL DOE-RL-92-36. IF THE ASSEMBLY FAILS TO PASS THE LOAD TEST, NECESSARY REPAIRS SHALL BE MADE AND THE LOAD TEST SHALL BE REPEATED. ANY REPAIRS MADE TO THE WELDING SHALL REQUIRE RE-INSPECTION OF THE WELDS.
8. ALL PLATE AND WIDE FLANGE SHALL CONFORM TO ASTM A36 - 1992. ROUND BAR SHALL CONFORM TO 1018 COLD DRAWN.
9. CLEAVES SHALL BE CLEVIS #7 PER AISC MANUAL OF STEEL CONSTRUCTION, ASD, NINTH EDITION, PART 4, PAGE 148. THE CLEAVES THAT ATTACH TO THE 1 3/4" PLATE SHALL BE PROVIDED WITH A 2" GRIP. THE CLEAVES THAT ATTACH TO THE CONTAINER SHALL BE PROVIDED WITH A 2 1/4" GRIP. CLEAVES SHALL BE PROVIDED WITH A 2 9/16" DIAMETER HOLE FOR THE 2 1/2" DIAMETER PIN.
10. THE 4 PINS REQUIRED FOR THE CLEAVES SHALL BE 2 1/2" DIAMETER BY 6 1/2" LONG. THERE SHALL BE 2 HOLES ON 5 1/4" CENTERS PROVIDED FOR 3/8" COTTER PINS ON EACH 2 1/2" DIAMETER PIN. THE 2 1/2" DIAMETER PINS SHALL BE AISI 1035 CS. 2 1/2" DIAMETER PINS SHALL BE HELD IN PLACE WITH TWO 3/8" COTTER PINS.





OFFICIAL RELEASE
BY NRC
DATE SEP 15 2004


H-2-23750	ASSEMBLY ARRANGEMENT
H-2-23736	STRONGBACK
H-2-23734	STORAGE CONTAINER
WHC-SD-WM-2A-1681	SUPPORTING OCC
NO	TITLE
DRAWING TRACEABILITY LIST	NO. USED ON

NO.	REV.	DATE	BY	CHKD.	DESCRIPTION

U.S. DEPARTMENT OF ENERGY OGC Field Office, Richland Westinghouse Hanford Company	
LIFTING BEAM	
SIZE: F 200-G SHEET NO: 1001 DATE SHOWN: SEP 7 2004	H-2-83744 0



SECTION 1 (TYP BOTH ENDS)
SCALE: 3/8 SIZE




DETAIL 2 (TYP BOTH ENDS)
SCALE: 3/8 SIZE


3/4"x45" CHAMF
8 PLACES

2 PL 5/16"


(3/8)
(3/8)




A
SECTION
SCALE: 3/8 SIZE



B
SECTION
SCALE: 3/8 SIZE



D
SECTION (TYP 50TH ENDS)
SCALE: 3/8 SIZE



1
DETAIL
SCALE: 3/8 SIZE

OFFICIAL RELEASE
SEP 16 1994
DATE SEP 16 1994

FOR GENERAL NOTES SEE SHEET 1

DESIGNED BY: BN KYLE 1-4-84 CHECKED BY: D. HENNELS 19-84 DATE: 1-4-84 DRAWN BY: SENEGAS 5-84 DATE: 7-77	U.S. DEPARTMENT OF ENERGY OCE Field Office, Rockland Washington Maritime Corridor
LIFTING BEAM	
SHEET NO: F DRAWING NO: 200-G PART NO: 1001 SCALE: SHOWN	SHEET NO: H-2-83744 PART NO: 10 SCALE: 2

DRAWING TRACEABILITY LIST	REV. NUMBER	TITLE	REVISIONS	DATE	BY	CHK	APP	DATE	BY	CHK	APP
1											
1											

PART B - PACKAGE EVALUATION**1.0 INTRODUCTION****1.1 SAFETY EVALUATION METHODOLOGY**

Part B of this Safety Evaluation for Packaging (SEP) identifies and evaluates the requirements considered applicable to the one-time transfer of the Hydrogen Mitigation Mixer Pump (HMMP) Package and will evaluate the adequacy and acceptability of the packaging and transfer systems described in Part A of this SEP. The SEP demonstrates that the onsite transfer meets the onsite transportation safety criteria (WHC 1994b).

- A. Methodology used to evaluate the acceptability of the package for safe onsite transfer was to:
1. Determine the probability of an accident during transfer.
 2. Determine the estimated release of radioactive materials following an assumed accident condition.

The results of the studies were compared to approved risk acceptance criteria for onsite transfers at the Hanford Site. This approach determines the applicable dose consequence limits listed in WHC-SD-TP-RPT-001, *Report on Equivalent Safety for Transportation and Packaging of Radioactive Materials* (WHC 1994b). Three accident probability ranges are listed in the equivalent safety document (incredible, credible, and probable). Each accident probability range has a maximum onsite and offsite dose consequence limit. For the short mileage requirements evaluated in this SEP, the probability of an accident during transfer of the package was determined to be "incredible" (less than 10^{-6}). Reference to the equivalent safety document indicated that the applicable dose consequence limits for accidents in the incredible range of events is 25 rem to an offsite person. This information was then compared to results of a dose consequence study which determined that the dose consequence following the potential accident conditions were within acceptance limits of the equivalent safety document.

- B. Specific tests were selected to provide a basis for evaluation of package parameters for normal conditions of transfer and identified accident conditions. The specified tests were simulated and were evaluated by analysis. In cases where the

probability of an accident was considered incredible, only testing for normal conditions of transfer were considered in this SEP.

- C. Methodology used to assure that the large long-length package described in this SEP will not leak contents during normal conditions of transfer consisted of evaluating results of package drop test data. Evaluation of the drop test data consisted of assuring that the integrity of critical package containment components would not be impacted following the simulated drop tests. As noted, development of extensive leak testing criteria associated with hypothetical accident conditions was not evaluated due to the incredible probability of an accident.

1.2 EVALUATION SUMMARY AND CONCLUSIONS

Evaluation of the following safety concerns relating to the design and transfer of the HMMP Package indicated that the proposed packaging/transfer system is considered safe for the intended usage and meets the onsite transportation safety criteria.

An accident frequency assessment of the HMMP Package transferred over a specific route from the Tank Farms to the Central Waste Complex (CWC) and from the CWC to T Plant was conducted and indicated that an accident during transfer is not considered probable (incredible-less than 10^{-6}). This was based on transferring the HMMP Package a total of 4.3 miles.

A dose consequence study showed that radiation dose rates and the radionuclides that may be released in the incredible event of an accident are well below the dose consequence limits of 25 rem to an offsite person.

Conditions relating to normal handling of the package were evaluated and determined to be adequate. Simulated testing performed to evaluate normal transfer conditions include free drop, vibration, pressure, and penetration testing. Results of the drop test analysis indicated that the package would survive a drop test at the designated height(s) without unacceptable physical impairment. In addition, the drop test results indicated that the integrity of critical closure components would not be impacted.

Containment of the package contents during normal transfer conditions was evaluated based on results of the drop test and was determined to be acceptable for the stated conditions of handling and onsite transfer.

Shielding evaluations indicated that sufficient shielding (if required) can be installed on the outside of the package to limit contact dose rates to 100 mrem/h. This will meet the radiation dose rate requirements for both the transfer and storage of mixed, category 3, low-level waste.

The tiedown system design and analysis were evaluated and determined to be adequate to assure that the package will be properly secured to the vehicle during transfer.

A structural analysis of the package indicated that the lifting attachments on the package have sufficient strength to safely lift a fully loaded package in the horizontal position.

A thermal analysis of the package indicated that the fully loaded package would not exceed external surface temperature limits due to solar insolation and radioactive contents decay heat.

2.0 CONTENTS EVALUATION

2.1 CHARACTERIZATION

Certain characteristics of radioactive materials must be identified and evaluated to assure that the contents of a package can be safely transferred. Three major concerns relating to transferring radioactive materials are as follows:

1. The effective A_2 value (A_{2e}) of the material must be calculated to determine if the package must be transferred as a Type A or Type B quantity of material. If the package contents are a Type A or Type B quantity of radioactive material, a SARP or SEP is required to approve onsite transfer of the package. For a description of A_2 values of individual radionuclides and calculations of the A_{2e} of mixtures of radionuclides, see 10 CFR 71, Appendix A.
2. The quantity of fissile materials (normally in grams) must be calculated to determine if the package contents must be classified for transfer as "fissile" or "fissile excepted." If the contents are "fissile" a criticality study must be performed. See 10 CFR 71.4, 71.52, and 71.55 for definition of fissile materials.
3. The corrosive properties of the radioactive materials must be identified and evaluated to assure that the contents are compatible with the packaging materials.

Methods used in this SEP to determine if package contents are Type A or Type B consisted of developing tables to indicate the estimated curies of radioactive materials attached to the equipment and then comparing the estimated curie values to acceptable Type A limits.

Based on a waste generation study (WHC 1994a), Table B2-1 below was developed to indicate the activity of radionuclides estimated to be attached to the mixer pump. The activity in curies is shown for an estimated 3 mm thick film of waste tank material attached to specific areas of the pump and a liquid holdup of 68 gallons inside the pump. This is considered the "worst case" waste that will be attached to and contained inside the pump and will be used throughout this SEP to assure that the package is properly evaluated for the intended use.

Table B2-2 was developed to determine the A_{2e} values for the mixture of radionuclides attached to and contained inside the mixer pump. As noted above, if the total curies of waste material attached to the mixer pump is greater than the A_{2e} value of the mixture, the waste equipment must be transferred as a Type B quantity of waste.

Table B2-1. Radionuclide Activity for the HMMP Package.

Radionuclide	Pump Holdup (Ci)*	Pump Film (Ci)**	Total Curies
²⁴¹ Am	1.02 E-01	6.03 E-02	1.63 E-01
²³⁸ Pu	2.82 E-04	1.66 E-04	4.48 E-04
²³⁹ Pu	5.65 E-03	3.33 E-03	8.97 E-03
²⁴⁰ Pu	1.33 E-03	7.86 E-04	2.12 E-03
²⁴¹ Pu	1.12 E-02	6.61 E-03	1.78 E-02
²⁴² Pu	6.24 E-08	3.68 E-08	9.92 E-08
²⁴³ Cm	1.16 E-04	6.86 E-05	1.85 E-04
²⁴⁴ Cm	2.03 E-03	1.20 E-03	3.22 E-03
²⁴² Cm	5.05 E-05	2.97 E-05	8.02 E-05
¹³⁷ Cs	1.61 E+02	9.50 E+01	2.56 E+02
¹³⁷ Ba	1.52 E+02	8.98 E+01	2.42 E+02
¹⁴ C	3.88 E-04	2.29 E-04	6.17 E-04
⁹⁰ Sr	1.88 E+01	1.11 E+01	2.99 E+01
⁹⁰ Y	1.88 E+01	1.11 E+01	2.99 E+01
⁹⁹ Tc	1.51 E-01	8.90 E-02	2.40 E-01
¹²⁹ I	5.93 E-03	3.49 E-03	9.42 E-03
²³⁷ Np	1.68 E-02	9.87 E-03	2.66 E-02
²³⁸ U	2.14 E-05	1.26 E-05	3.40 E-05
²³⁵ U	2.35 E-06	1.39 E-06	3.74 E-06
⁷⁹ Se	1.35 E-04	7.94 E-05	2.14 E-04
⁹⁴ Nb	1.88 E-05	1.11 E-05	2.99 E-05
^{93m} Nb	1.61 E-03	9.50 E-04	2.56 E-03
⁶⁰ Co	2.10 E-01	1.23 E-01	3.33 E-01
¹⁵⁴ Eu	1.50 E+00	8.83 E-01	2.38 E+00
⁵⁹ Ni	5.40 E-05	3.18 E-05	8.58 E-05
⁶³ Ni	8.61 E-03	5.07 E-03	1.37 E-02
²³⁶ U	1.59 E-06	9.40 E-07	2.53 E-06

* Based on 68 gallon waste holdup in pump legs (987 lb)

** Based on 3 mm film thickness of waste (582 lb)

Table B2-2. Effective A_2 -- HMMP Package.

Radionuclide	A_2 Limit (Ci)	HMMP (Ci)	f_i	f_i/A_2
^{241}Am	0.008	1.63 E-01	2.91 E-04	0.0364
^{238}Pu	0.003	4.48 E-04	7.99 E-07	0.003
^{239}Pu	0.002	8.97 E-03	1.60 E-05	0.008
^{240}Pu	0.002	2.12 E-03	3.78 E-06	0.0019
^{241}Pu	0.1	1.78 E-02	3.17 E-05	0.0003
^{242}Pu	0.003	9.92 E-08	1.77 E-10	0
^{243}Cm	0.009	1.85 E-04	3.30 E-07	0
^{244}Cm	0.01	3.22 E-03	5.74 E-06	0.0006
^{242}Cm	0.2	8.02 E-05	1.07 E-06	0
^{137}Cs	10	2.56 E+02	4.564 E-01	0.0456
^{137}Ba	10	2.42 E+02	4.314 E-01	0.0431
^{14}C	60	6.17 E-04	1.10 E-06	0
^{90}Sr	0.4	2.99 E+01	5.33 E-02	0.1333
^{90}Y	0.4	2.99 E+01	5.33 E-02	0.1333
^{99}Tc	25	2.40 E-01	4.28 E-04	0
^{129}I	2	9.42 E-02	1.68 E-05	0
^{237}Np	0.005	2.66 E-02	4.74 E-05	0.0948
^{238}U	U	3.40 E-05	6.06 E-08	0
^{235}U	0.2	3.74 E-06	6.67 E-09	0
^{79}Se	NA	2.14 E-04	0	0
^{94}Nb	NA	2.99 E-05	0	0
$^{93\text{m}}\text{Nb}$	NA	2.56 E-03	0	0
^{60}Co	7	3.33 E-01	5.94 E-04	0.0001
^{154}Eu	5	2.38 E+00	4.24 E-03	0.0008
^{59}Ni	900	8.58 E-05	1.53 E-07	0
^{63}Ni	100	1.37 E-02	2.44 E-05	0
^{236}U	0.2	2.53 E-06	4.51 E-09	0
TOTALS		561	1.00	0.4985
Effective A_2				2.01

Note: The effective A_2 value is $1.00/0.4985 = 2.006$ Ci. The total curies are greater than the effective A_2 value, therefore, the mixer pump must be transferred as a Type 8 quantity of waste. The total activity in terms of A_2 is $560.79/2.01 = 280 A_2\text{'s}$

The total estimated curies of material in the package contents (561 Ci) is 281 times greater than the A_{2e} value of the mixture of radionuclides indicating that the mixer pump must be transferred as a Type B quantity of waste. The A_{2e} value for a mixture is equal to $1/\sum f_i/A_2$ where f_i is a fraction of activity for each radionuclide in the mixture and A_2 is the appropriate Type A curie limit for each radionuclide.

Fissile materials present in the waste are ^{238}Pu , ^{239}Pu , ^{241}Pu , and ^{235}U . The quantity (grams) of each component of fissile material is based on the total curies of each component divided by the specific activity of each component. Table B2-3 was developed to determine the total grams of fissile materials in the HMMP Package evaluated in this SEP.

Table B2-3. Fissile Content.

	Activity (Ci/g)	Curies	Grams
^{238}Pu	17	4.48 E-04	2.63 E-05
^{239}Pu	0.62	8.97 E-03	1.45 E-02
^{241}Pu	110	1.78 E-02	1.62 E-04
^{235}U	2.10 E-06	3.74 E-06	1.78 E+00
TOTAL GRAMS			1.7947

As shown in Table B2-3, the total quantity of the fissile radionuclides estimated to be attached to and contained inside the mixer pump is 1.7947 g. Radioactive waste is excepted from fissile classification if the total quantity of fissile components are less than 15 g (DOT 1992) in each package. Under the conditions stated above, the package containing the mixer pump will be considered as "Fissile Excepted." Based on the "Fissile Excepted" classification, a criticality study will not be performed as part of this SEP evaluation.

The corrosive components are considered to be the non-radioactive chemicals in the waste contents. These chemicals are the hazardous components that resulted in classification of the materials as "mixed waste." Two conditions should be considered with reference to the potential corrosive properties of these chemicals:

1. Materials in underground radioactive waste storage tanks are neutralized to a 10 pH or higher to prevent corrosive reactions with the carbon steel tank materials.

2. The chemicals are normally in a liquid phase in the tank and will normally be washed off by spraying the equipment with water during removal.

For purposes of evaluating the package for transfer, the potential corrosion of packaging materials from the estimated minute quantity of non-radioactive chemicals that may remain attached to the solid waste material is considered insignificant. It should also be noted that absorbent material will be included in the package to absorb any free liquids. This will prevent direct contact of liquids with the packaging materials and will tend to prevent or delay any potential corrosive reactions that may impact the package during the specified service life.

2.2 CONTENT RESTRICTIONS

Since this SEP approves the transfer of specific package contents, generic restrictions of the contents are not considered applicable. However, by definition of the SEP document, contents that exceed estimated weights and/or radionuclide limits cannot be transferred under the SEP unless an Engineering Change Notice (ECN) is issued. The maximum amount of curies for each radionuclide estimated to be attached to the hydrogen mitigation mixer pump is shown in Table B2-1. The estimated maximum quantities of fissile radionuclides attached to the pump is shown in Table B2-3.

2.3 CONCLUSIONS

Package contents as characterized in the waste generation study (WHC 1994a) shown in Part A, Section 3.0, and evaluated in this section of the SEP are considered to be properly identified and sufficiently analyzed to be considered acceptable for transfer in the HMMP Package.

3.0 RADIOLOGICAL RISK EVALUATION

3.1 INTRODUCTION

Packaging and transportation systems were evaluated to determine if calculated radiological releases that may occur during transfer of the package are considered to be within acceptable radiological limits listed in WHC-SD-TP-RPT-001, *Report on Equivalent Safety for Transportation and Packaging of Radioactive Materials* (WHC 1994b). Results of an accident frequency assessment and dose consequence study were used as the basis for analyzing and comparing identified risks to the approved risk acceptance criteria.

3.2 RISK ACCEPTANCE CRITERIA

Specific risk acceptance criteria for onsite transfers of material at the Hanford Site are shown in the *Report on Equivalent Safety for Transportation and Packaging of Radioactive Materials* (WHC 1994b); however, for purposes of evaluations in this SEP, specific criteria data from the referenced document are shown in Table B3-1.

Table B3-1. Risk Acceptance Criteria.

Accident Condition	Annual Accident Frequency	Dose Limits Onsite Worker (rem)	Dose Limits Offsite Farmer (rem)
Incredible	$< 10^{-7}$	N/A	N/A
Incredible	10^{-7} to $< 10^{-6}$	N/A	25 (EDE)
Credible	10^{-6} to $< 10^{-3}$	5/15/50	0.5/1.5/0.5
Probable	10^{-3} to 1	0.2/0.6/2	0.01/0.03/0.1

3.3 ACCIDENT FREQUENCY ASSESSMENT

An accident frequency assessment (see Part B, Section 3.6) was performed to determine the probability of an accident for the one-time shipment described in this SEP. Results of the accident frequency assessment indicated that the short-term mileage of this campaign precludes the activity from falling within the credible or probable frequency range for accidents. The accident frequency was calculated to be 4.97×10^{-8} indicating that accidents are considered incredible for the onsite transfer of the HMMP Package

described in this SEP. As noted in Table B3-1, no radiation release limits to an offsite farmer are required for a calculated accident frequency of below 10^{-7} . However, the predicted effect to an offsite individual was evaluated based on the 10^{-6} to 10^{-7} accident frequency for added conservatism.

3.4 DOSE CONSEQUENCE ANALYSIS

A dose consequence analysis (see data sheets - Part B, Section 3.7) was performed to assess the results of a radiological release of material to an offsite farmer for the HMMP Package in the unlikely event of an accident. The analysis assumed in the worst case that 30% of the radionuclide inventory is released to the environment in less than one hour, 50% of the released inventory is dispersed to the atmosphere, and that decay of the radionuclides began at the time of release. The analysis indicated that an offsite farmer at the nearest site boundary would be subjected to a 50 year committed effective dose equivalent (EDE) of 4.1 rem for an accident with an estimated 15% dispersement of the radionuclide inventory to the atmosphere.

3.5 RISK EVALUATION AND CONCLUSIONS

For incredible accident conditions for acceptable release limits at the Hanford Site, the calculated 4.1 rem EDE to an offsite farmer is well below the 25 rem limit shown in Table B3-1. The conclusions of this evaluation are that the identified radiological risks associated with the one-time transfer of the HMMP Package described in this SEP are acceptable.

3.6 ACCIDENT FREQUENCY ASSESSMENT

HYDROGEN MITIGATOR MIXER PUMP TRANSPORT FROM
101-SY TANK FARM
TO CENTRAL WASTE COMPLEX AND T PLANT

J. E. Kelly/ S. E. Lindberg
Risk Assessment Technology

June 1994

CONTENTS

1.0	INTRODUCTION.....	1
2.0	APPROACH.....	1
3.0	TRAVEL DISTANCE.....	1
4.0	HANFORD VEHICLE ACCIDENT STATISTICS.....	4
	4.1 Event Tree Evaluation.....	5
5.0	SUMMARY.....	6
6.0	REFERENCES.....	6

FIGURES

2-1	Onsite Transfer of Hydrogen Mitigation Mixer Pump From SY Tank ..	2
3-1	Transportation of Pump from SY Farm to CWC.....	3

HYDROGEN MITIGATION MIXER PUMP TRANSPORT FROM 101-SY TANK FARM TO CENTRAL WASTE COMPLEX AND T PLANT

1.0 INTRODUCTION

This report contains an accident frequency assessment for transferring the Hydrogen Mitigation Mixing Pump (HMMP) package containing contamination removed from Tank 101-SY to the Central Waste Complex (CWC) and eventually to T Plant for treatment/processing. To perform the analysis, an estimate must be made of the distance that will be travelled and then apply the site data for vehicle accident frequencies which are based on this distance.


2.0 APPROACH

The approach that will be used in this analysis is to develop an event tree that defines all of the events required for an accident leading to a possible release of radioactive material in the transport of the HMMP package by truck. The event tree (Figure 2-1) maps transportation accident sequences resulting in radioactive releases by considering a series of questions. These questions, also called top events, appear across the top of the tree. The decisions or "branch" points under these top events are described and discussed in the paragraphs that follow.

3.0 TRAVEL DISTANCE


The pathway selected for this analysis has the vehicle leaving the SY tank farm and going South on Camden Avenue to 10th Street. Turn West on 10th Street and go to Cooper Avenue. Turn North on Cooper to 13th Street. Turn West on 13th Street to Dayton Avenue. Turn North on Dayton Avenue and drive to the CWC. The distance from SY Tank Farm to the CWC is less than three miles. The additional trip from the CWC to T Plant is 1.3 miles. Go North on Dayton and East on 23rd Street to accomplish this trip. Therefore, the total mileage for this trip is less than 4.3 miles. This is the distance that will be used in this study. It will not be used directly in the event tree development, but the results of the generic event tree (see Figure 2-1) will be multiplied by this mileage to determine the frequency of the potential accidents. The first event of the event tree, **SHIPPING ACTIVITY**, will be assigned a frequency of one (see Figure 3-1 for pathway driven).

Figure 2-1. Transportation Event Tree.



SOURCE: TRANSPORTATION EVENT TREE FROM ST. LOUIS, MISSOURI, 1984

Figure 3-1. Transportation of Pump from SY Tank Farm to CWC.



4.0 HANFORD VEHICLE ACCIDENT STATISTICS

Hanford Site specific data, rather than Washington State statistics, were used to develop accident frequencies and probabilities. Washington State statistics represent a significantly different transportation environment than the Hanford Site because commercial transportation has little influence on its operating conditions while Hanford on-site shipping is highly controlled.

Due to a computer system upgrade, it is not possible to separate mileage by vehicle class prior to 1992. Therefore, a single accident rate for all classes is developed by dividing the number of truck accidents by the total truck miles. The occurrence of 114 reportable accidents over 26.0 million miles results in an accident rate of $4.38E-06$ accidents per mile. See WHC-SD-TP-RPT-007 for a list of the accidents and the mileage. This frequency will be assigned to the second event, **REPORTABLE**, on the event tree.

The Hanford Site had 114 reportable truck accidents (Gross Vehicle Weight over 8500 pounds) over a period in which 26.0 million miles were driven. The U.S. Department of Energy requires accidents with \$500 or more damage be reported. A proposed change to WHC-CM-1-13 may increase the amount to \$5,000. Of these accidents only thirty-one (27.2 percent) resulted in major damage in which an undesired radioactive release could occur. This probability or percentage will be applied to event three, **DAMAGE LEVEL**, on the event tree. (Two were rollovers, twenty-three were collisions, one was a random fire, and five occurred on icy roads). Ratios will be used on the fourth event, **ACCIDENT TYPE**, to divide the 31 major accidents on the event tree. The remaining eighty-three were minor "fender benders" or accidents involving special vehicles such as fire trucks and cranes.

Commercial truck transportation data shows that secondary fires occur in approximately one percent of all truck accidents (Clark, 1976). Vehicle fires can damage the cargo and allow radioactive releases. Cargo environments can range from minor thermal exposure to severe thermal exposure. The fifth event, **SECONDARY FIRE**, is evaluated based on the one percent fire occurrence data.

Few vehicle fires seriously threaten the cargo because fires are usually confined to small areas or are of short duration. Because fires typically start in the engine compartment, cargo will not be significantly damaged if a fire is controlled within ten minutes. Based on the response time of the fire department, ninety percent of all truck fires can be extinguished during the initiating phase. One-third of the remaining ten percent can be controlled by the fire department before the cargo is damaged.

Two facts justify these assumptions. First, hand-held fire extinguishers are effective on vehicle fires if less than seventy-five gallons of fuel or less than one thousand pounds of solid combustible cargo are involved. Second, the locations of the three fire stations on the Hanford Site allow fire trucks to get to one-third of the site within five minutes,

two-thirds of the site within ten minutes, and to the entire site within fifteen minutes (Reference 4). From this information a probability of $6.66e-02$ was formulated and used for event six, **FIRE CONTROL**, on the event tree.

The final event, **PACKAGE**, on the event tree evaluates the proposed packaging. Based on the packaging design criteria, WHC-SD-TP-PDC-019, Draft, the transfer pump located in tank 241-SY-101 weighs 20,906 lbs. with total weight waste matrix, is 41 inches in diameter, and 60 feet long. The package for this pump will be analyzed for a drop of three feet. The packages will be tied down to the vehicle. The tiedown devices used to secure the package to the transport vehicle shall be designed and evaluated to assure the tie-down assemblies used to secure the packaging can withstand sudden stops or cornering at 15 MPH. Attachments shall be provided on the package container as required to safely lift the waste package and secure the package during transfer. Any lifting attachment that is a structural part of the package shall be designed with one of the following (whichever is more conservative):

- o A minimum safety factor of three against yielding.
- o A safety factor of five based on the ultimate strength of material. When the lifting attachment is used as intended, it must be designed so that the lifting device failure caused by an excessive load will not impair the package from meeting other criteria. Any structural part of the package not approved for lifting the package shall be rendered inoperable for lifting the package during transfer or shall be designed with strength equivalent to that required for the approved lifting attachments.

The speed of the transport trailer shall not exceed 35 mph on straight sections of the road and 15 mph on curved sections of the road during waste transfers. This information was used to estimate the package failure due to a random fire or collision at $5.0E-03$, and $5.0E-02$ due to a rollover. Included in the package failure probability is a factor to account for the percentage of radioactive release. For a complete release, not only would the packaging have to fail, but the pump itself would have to open to result in a complete inventory release. These values appear on the event tree.

4.1 EVENT TREE EVALUATION

Fourteen accident sequences are defined by the event tree. Eight of these result in no release. It should be noted that it was assumed that the transfer would not be allowed to occur during icy road conditions. Three sequences result in a release, and three more result in a fire release. One of the combinations of releases is caused by a random fire where the fire is controlled but the packaging fails or the fire is not controlled. The frequencies for these accidents are $1.80E-10$ and $2.56E-09$ per mile. The next set of two sequences resulting in a release is initiated by a collision. The collision with no fire but with a packaging failure has a frequency of

4.38e-09 accidents per mile, and the collision with an uncontrolled fire has a frequency of 5.89E-10 per mile. The final series is initiated by a rollover accident. When there is no fire the frequency is 3.80E-09 per mile and 5.12E-11 per mile with an uncontrolled fire. Summing the three accidents without a fire results in a frequency of 8.36E-09 accidents per mile. When this is multiplied by the distance of 4.3 miles results in an accident frequency of 3.59E-08 per transfer. The three accidents with a fire release sum to 3.20E-09 accidents per mile. Again using 4.3 miles, results in a frequency of 1.38E-08 per transfer.

5.0 SUMMARY

The sum for the worst case accidents as defined by the maximum mileage for both with and without a fire are less than the annual criteria frequency of 1.0E-06 per transport and therefore no further restrictions are required.

6.0 REFERENCES

1. Clarke, R. K., 1976, "*Severities of Transportation Accidents*", SLA-740001, Sandia Laboratories, Albuquerque, New Mexico, September, 1976.
2. WHC-SD-TP-PDC-019, (Draft), "*Package Design Criteria Transfer and Disposal of Hydrogen Mitigation Mixer Pump*",
3. WHC-SD-TP-RPT-001, Rev. 0, "*Report on Equivalent Safety for Transportation and Packaging of Radioactive Material*", December, 1993.
4. WHC-SD-TP-RPT-007, Rev. 0, "*Standard Transportation Risk Assessment Methodology*", December, 1993.

3.7 DOSE CONSEQUENCE ANALYSIS

**Westinghouse
Hanford Company**

**Internal
Memo**

From: Radiation Physics and Shielding 8D530-RLS-94-007
 Phone: 376-8244 HO-35
 Date: May 5, 1994
 Subject: DOSE CONSEQUENCE ANALYSIS FOR THE HYDROGEN MITIGATION MIXER PUMP
 SHIPPING CONTAINER

To: R. F. Carlstrom G2-02

cc: J. G. Field G2-02 H. J. Goldberg HO-35
 J. Greenberg HO-35 P. D. Rittmann HO-36
 A. E. Waltar HO-32 RLS File/LB

REFERENCES:

1. Internal Memorandum R. L. Simons to R. F. Carlstrom, "Estimated Activity on the Mixer Pump Removed from Tank 101 SY," 22570-RLS-93-010, December 14, 1993.
2. B. E. Hey, "GXQ 3.1 User's Guide," WHC-SD-GN-SWD-30002, Rev 0, Westinghouse Hanford Company, Richland, WA, June 8, 1993.
3. B. A. Napier, et al., "GENII - The Hanford Environmental Radiation Dosimetry Software System Volume 2: Users' Manual," PNL-6584 vol. 2, Pacific Northwest Laboratory, Richland WA, November 1988.

This memorandum reports the calculated dose consequences for the accidental release of radioactive material from the hydrogen mitigation mixer pump that will be shipped from the 200 West area to interim storage and processing facilities. The results of this analysis will be used by Transportation and Packaging to determine the dose consequence off-site. The analysis assumed in the worst case that 30 percent of the radionuclide inventory is released to the environment in less than one hour, 50 percent of the released inventory is dispersed to the atmosphere, and that decay of the radionuclides began at the time of release.

The radionuclide source was reported in reference [1]. The atmospheric dispersion of radionuclides (X/Q) was calculated with the GXQ computer code [2] using Hanford Site specific meteorological data. The Gaussian straight line plume model was used for the analysis. The 50 year committed effective dose equivalent (EDE) to a farmer at the site boundary included direct irradiation from the passing cloud, and uptake by inhalation, terrestrial, and animal pathways. The off-site EDE was calculated with version 1.485 of GENII [3]. The release site was located at the site of the tank 101 SY in the 200 West area. Plume meander was not considered in this analysis.

The EDE calculated by GENII for a net 15 percent release to the atmosphere is 4.1 Rem to a farmer at the nearest site boundary (near the Yakima barricade).

Attachment A gives GXQ input data and Attachment B gives GENII input data for future reference and for review of this work.

If you have any questions regarding this analysis, please contact me.



R.L. Simons, Principal Scientist
Physics and Radiation Shielding



Concurrence:

J. Greenborg, Manager



Reviewed by:

P. D. Rittmann, Principal Engineer
Environmental Risk and Performance Assessment

HEDOP REVIEW CHECKLIST
for
Radiological and Nonradiological Release Calculations

Document Reviewed: Internal Memorandum: 8D530-RLS-94-007

Dose Consequence Analysis for the Hydrogen Mitigation Mixer Pump Shipping Container

Submitted by: R. L. Simons Date Submitted: May 5, 1994

Scope of Review: Entire Document

YES NO* N/A

- [] [] 1. A detailed technical review and approval of the environmental transport and dose calculation portion of the analysis has been performed and documented.
- [] [] 2. Detailed technical review(s) and approval(s) of scenario and release determinations have been performed and documented.
- [] [] 3. HEDOP-approved code(s) were used.
- [] [] 4. Receptor locations were selected according to HEDOP recommendations.
- [] [] 5. All applicable environmental pathways and code options were included and are appropriate for the calculations.
- [] [] 6. Hanford site data were used.
- [] [] 7. Model adjustments external to the computer program were justified and performed correctly.
- [] [] 8. The analysis is consistent with HEDOP recommendations.
- [] 9. Supporting notes, calculations, comments, comment resolutions, or other information is attached. (Use the "Page 1 of X" page numbering format and sign and date each added page.)
- [] 10. Approval is granted on behalf of the Hanford Environmental Dose Overview Panel.

* All "No" responses must be explained and use of nonstandard methods justified.

Reviewer Name: Paul D. Rittmann, PhD CHP
(print or type)

Paul Rittmann 5-5-94
HEDOP-Approved Reviewer (Signature) Date

ATTACHMENT A
GXQ INPUT DATA

Calc of GXQ for tank SY101 pump in 200 west area.

c GXQ Ver. 3.1 Input File

c mode

1

c

c MODE CHOICE:

c mode = 1 then X/Q based on Hanford site specific meteorology

c mode = 2 then X/Q based on atmospheric stability class and wind speed

c mode = 3 then X/Q plot file is created

c

c LOGICAL CHOICES:

c ifox inorm icdf ichk isite ipop icon

t f f f f f f

c ifox = t then joint frequency used to compute frequency to exceed X/Q

c = f then joint frequency used to compute annual average X/Q

c inorm = t then joint frequency data is normalized (as in GENII)

c = f then joint frequency data is un-normalized

c icdf = t then cumulative distribution file created (CDF.OUT)

c = f then no cumulative distribution file created

c ichk = t then X/Q parameter print option turned on

c = f then no parameter print

c isite = t then X/Q based on joint frequency data for all 16 sectors

c = f then X/Q based on joint frequency data of individual sectors

c ipop = t then X/Q is population weighted

c = f then no population weighting

c icon = t then X/Q is air concentration

c = f then X/Q is integrated exposure

c

c MODEL CHOICES:

c idep iwake ipm irise igrav iwash iflow iwind

0 0 0 0 0 0 0 0

c idep = 1 then plume depletion model turned on (Chamberlain model)

c iwake = 1 then NRC RG 1.145 building wake model turned on

c = 2 then MACCS virtual distance building wake model turned on

c ipm = 1 then NRC RG 1.145 plume meander model turned on

c = 2 then 5th Power Law plume meander model turned on

c = 3 then sector average model turned on

c irise = 1 then momentum/buoyancy plume rise model turned on, buoyancy

c rise based on sensible heat emission

c = 2 then momentum/buoyancy plume rise model turned on, buoyancy

c rise based on initial plume density

c igrav = 1 then gravitational settling model turned on

c iwash = 1 then stack downwash model turned on

c iflow = 1 then sigmas adjusted for volume flow rate

c iwind = 1 then wind speed corrected for plume height

c = 0 to turn any of the above models off

c

c PARAMETER INPUT:

stack	wind		frequency	
release	speed	mixing	to	scaling
height	height	height	exceed	factor
(m)	(m)	(m)	(%)	(?)
0	10	1000	0.5	1

c

building	building	release	deposition	gravitational
width	height	duration	velocity	settling
(m)	(m)	(hr)	(m/s)	velocity
5	5	1	0.001	0.001

c

initial	initial		sensible
plume	plume		heat
flow	flow	stack	emission
density	rate	diameter	rate
(g/cc)	(m ³ /s)	(m)	(cal/s)
0.00122	0	1	4.18000E+05

c

c RECEPTOR DEPENDENT DATA

FOR MODE	make	RECEPTOR DEPENDENT DATA
1 (site specific)		sector distance z-height
2 (by class & wind speed)		class windspeed distance offset z-height
3 (create plot file)		class windspeed xmax imax ymax jmax xqmin power

c

c RECEPTOR PARAMETER DESCRIPTION:

c sector = 0, 1, 2... (all, S, SSW, etc.)

c distance = meters

c class = 1, 2, 3, 4, 5, 6, 7 (P-G stability class A, B, C, D, E, F, G)
c windspeed = m/s
c offset = meters offset from plume centerline
c xmax = maximum distance to plot or calculate to (m)
c imax = distance intervals
c ymax = maximum offset to plot (m)
c jmax = offset intervals
c xqmin = minimum scaled X/Q to calculate
c power = exponent in power function step size

1	13160	0
2	13430	0
3	14860	0
4	12710	0
5	12460	0
6	12680	0
7	16430	0
8	17290	0
9	18960	0
10	27280	0
11	26890	0
12	23640	0
13	23270	0
14	28110	0
15	22790	0
16	18380	0

ATTACHMENT B

INPUT DATA FOR GENII CALCULATION OF DOSE CONSEQUENCES

FAR-FIELD SCENARIOS (IF POPULATION DOSE) #####

0 Definition option: 1-Use population grid in file POP.IN
0 2-Use total entered on this line

NEAR-FIELD SCENARIOS #####

Prior to the beginning of the intake period: (yr)
0 When was the inventory disposed? (Package degradation starts)
0 When was LOIC? (Biotic transport starts)
1.0 Fraction of roots in upper soil (top 15 cm)
0 Fraction of roots in deep soil
0 Manual redistribution: deep soil/surface soil dilution factor
1250 Source area for external dose modification factor (m2)

TRANSPORT #####

====AIR TRANSPORT====SECTION 1====

0-Calculate PM 0 Release type (0-3)
1 Option: 1-Use chi/Q or PM value F Stack release (T/F)
2-Select MI dist & dir 0 Stack height (m)
3-Specify MI dist & dir 0 Stack flow (m3/sec)
1.62E-05 Chi/Q or PM value 0 Stack radius (m)
0 MI sector index (1=S) 0 Effluent temp. (C)
0 MI distance from release point (m) 0 Building x-section (m2)
F Use jf data, (T/F) else chi/Q grid 0 Building height (m)

====SURFACE WATER TRANSPORT====SECTION 2====

0 Mixing ratio model: 0-use value, 1-river, 2-lake
0 Mixing ratio, dimensionless
0 Average river flow rate for: MIXFLG=0 (m3/s), MIXFLG=1,2 (m/s),
0 Transit time to irrigation withdrawal location (hr)
If mixing ratio model > 0:
0 Rate of effluent discharge to receiving water body (m3/s)
0 Longshore distance from release point to usage location (m)
0 Offshore distance to the water intake (m)
0 Average water depth in surface water body (m)
0 Average river width (m), MIXFLG=1 only
0 Depth of effluent discharge point to surface water (m), lake only

====WASTE FORM AVAILABILITY====SECTION 3====

0 Waste form/package half life, (yr)
0 Waste thickness, (m)
0 Depth of soil overburden, m

====BIOTIC TRANSPORT OF BURIED SOURCE====SECTION 4====

T Consider during inventory decay/buildup period (T/F)?
T Consider during intake period (T/F)? 1-Arid non agricultural
0 Pre-Intake site condition..... 2-Humid non agricultural
3-Agricultural

EXPOSURE #####

====EXTERNAL EXPOSURE====SECTION 5====

Exposure time: Residential irrigation:
0 Plume (hr) T Consider: (T/F)
0 Soil contamination (hr) 0 Source: 1-ground water
0 Swimming (hr) 2-surface water
0 Boating (hr) 0 Application rate (in/yr)
0 Shoreline activities (hr) 0 Duration (mo/yr)
0 Shoreline type: (1-river, 2-lake, 3-ocean, 4-tidal basin)
0 Transit time for release to reach aquatic recreation (hr)
1.0 Average fraction of time submersed in acute cloud (hr/person hr)

====INHALATION====SECTION 6====

8766.0 Hours of exposure to contamination per year
0 0-No resus- 1-Use Mass Loading 2-Use Anspaugh model
0 pension Mass loading factor (g/m3) Top soil available (cm)

====INGESTION POPULATION====SECTION 7====

1 Atmospheric production definition (select option):
0 0-Use food-weighted chi/Q, (food-sec/m3), enter value on this line
1-Use population-weighted chi/Q
2-Use uniform production
3-Use chi/Q and production grids (PRODUCTION will be overridden)
0 Population ingesting aquatic foods, 0 defaults to total (person)
0.0 Population ingesting drinking water, 0 defaults to total (person)
F Consider dose from food exported out of region (default=F)

Note below: S* or Source: 0-none, 1-ground water, 2-surface water
 3-Derived concentration entered above
 ==== AQUATIC FOODS / DRINKING WATER INGESTION=====SECTION 8=====

F Salt water? (default is fresh)

USE ?	FOOD TYPE	TRAN- SIT hr	PROD- UCTION kg/yr	-CONSUMPTION- HOLDUP da	RATE kg/yr	DRINKING WATER	
F	FISH	0.00	0.0E+00	1.00	40.0	0	Source (see above)
F	MOLLUS	0.00	0.0E+00	0.00	0.0	T	Treatment? T/F
F	CRUSTA	0.00	0.0E+00	0.00	0.0	1.0	Holdup/transit(da)
F	PLANTS	0.00	0.0E+00	0.00	0.0	730.0	Consumption (L/yr)

====TERRESTRIAL FOOD INGESTION=====SECTION 9=====

USE ?	FOOD TYPE	GROW TIME da	--IRRIGATION--			PROD- UCTION kg/yr	--CONSUMPTION--	
T/F			S RATE in/yr	TIME mo/yr	YIELD kg/m2		HOLDUP da	RATE kg/yr
T	LEAF V	90.00	0	0.0	1.5	0.0E+00	1.0	30.0
T	ROOT V	90.00	0	0.0	4.0	0.0E+00	5.0	220.0
T	FRUIT	90.00	0	0.0	2.0	0.0E+00	5.0	330.0
T	GRAIN	90.00	0	0.0	0.8	0.0E+00	180.0	80.0

====ANIMAL PRODUCTION CONSUMPTION=====SECTION 10=====

USE ?	FOOD TYPE	---HUMAN---		TOTAL PROD- UCTION kg/yr	DRINK WATER CONTAM FRACT.	DIET FRAC- TION	GROW TIME da	-----STORED FEED-----			STOR- YIELD AGE kg/m3 da	
		CONSUMPTION RATE kg/yr	HOLDUP da					S RATE in/yr	TIME mo/yr	YIELD kg/m3		
T	BEEF	80.0	15.0	0.00	0.00	0.00	90.0	0	0.0	0.00	0.80	0.0
T	POULTR	18.0	1.0	0.00	0.00	0.00	90.0	0	0.0	0.00	0.80	0.0
T	MILK	270.0	1.0	0.00	0.00	0.00	45.0	0	0.0	0.00	2.00	0.0
T	EGG	30.0	1.0	0.00	0.00	0.00	90.0	0	0.0	0.00	0.80	0.0
	BEEF					0.00	45.0	0	0.0	0.00	2.00	100.0
	MILK					0.00	30.0	0	0.0	0.00	1.50	0.0

#####

4.0 CONTAINMENT EVALUATION

4.1 INTRODUCTION

Evaluations in this section are provided to assure that the packaging containment system is acceptable to withstand designated conditions during normal onsite transfers of the package. The packaging containment system is described in Part A, Section 2.5.

4.2 NORMAL TRANSFER CONDITIONS

For normal conditions of transfer, the containment system shall withstand a simulated 1 ft drop of the packaging from a horizontal position onto a 12 in. thick reinforced concrete slab with #9 rebar at 12 in. spacings for reinforcement. Evaluation of the simulated drop will verify that material stresses will not exceed yield stresses at critical structural or closure locations.

Normal vibration of the package during transfer will be evaluated to assure that the package is capable of withstanding the expected movements.

The package shall be evaluated to determine the effects of a reduction in external pressure of 3.5 psi absolute and an increase in external pressure of 20 psi absolute.

A penetration test shall be performed on the package to determine the effects of the hemispherical end of a vertical steel cylinder of 3.2 cm diameter and 6 kg mass dropped from a height of 1 m. The steel cylinder shall be dropped onto the exposed surface of the package which is expected to be most vulnerable to penetration. The long axis of the axis of the cylinder must be perpendicular to the package surface.

Testing and evaluations for normal conditions of onsite transfers shall consider the effects of transferring a package at ambient temperatures between 0 °F and 115 °F.

4.3 CONTAINMENT EVALUATION AND CONCLUSIONS

Evaluations to assure that the packaging containment system is acceptable for safe transfer of the pump package was based on results of Normal Transfer Condition testing analyses (Part B, Section 6.4), a radiological risk evaluation (Part B, Section 3.6), dose consequence evaluation (Part B, Section 3.7), and a gas generation study (Part B, Section 8.3).

Results of the simulated free drop, vibration, penetration, and pressure tests indicated that the package will not lose integrity of the containment barrier during normal transfer operations.

Results of the risk evaluation (as shown in Part B, Section 3.6) indicated that a release of the package contents is extremely unlikely, and if a release was made, the dose consequence (as shown in Part B, Section 3.7) would not exceed acceptable Hanford Site limits for an incredible accident assessment.

Results of a gas generation study indicated that hydrogen gas build-up in a package would not exceed 5% (for "worst case" waste material attached to a pump) within the twenty year service life of the package. To prevent the possibility of hydrogen build-up in excess of 5%, the package is fitted with an approved filter when placed into storage.

Conclusions of this evaluation are that the packaging containment system is considered acceptable to safely contain radioactive materials for normal conditions of transfer identified in this SEP.

5.0 SHIELDING EVALUATION

5.1 INTRODUCTION

Evaluations in this section are provided to assure that the packaging shielding system is adequate to provide sufficient shielding of the package during designated normal conditions of transfer. Since the package will be transferred to the CWC for storage, the lowest acceptable dose rate at the surface of the package for either transfer or storage of the package will be considered the controlling dose rate for evaluations in this SEP. A shielding analysis was completed to support evaluations in this SEP and is shown in Part B, Section 5.4

5.2 SHIELDING REQUIREMENTS

Shielding shall limit the dose rate on the surface of the package to 200 mrem/h and 10 mrem/h at 2 m from the vehicle for transfer of the package. For storage of mixed low-level waste, the dose rate on the surface of the package shall be limited to 100 mrem/h (WHC 1993). Shielding material shall be added to the package annulus or secured to the outside of the package as required to withstand normal conditions of transfer. The dose rate at the vehicle driver location shall not exceed 2 mrem/h during transfer of the package.

To assure that the lowest identified shielding requirements of 100 mrem/h can be met at the surface of the package, the packaging design shall include provisions to install sufficient shielding material in the annulus of the package and on the outside of the package to limit dose rates to 100 mrem/h or less. The design shall also include provisions for remote installation of the shielding material.

5.3 SHIELDING EVALUATION AND CONCLUSIONS

A shielding analysis (Part B, Section 5.4) was performed for addition of lead shot or steel shot in the 2 in. annulus space of the shipping container to reduce dose rates to less than 100 mrem/h at the surface of the package. The analysis was based on "worst case" waste material attached and contained inside the hydrogen mitigation mixer pump. A film thickness of 3 mm and waste material holdup of 68 gallons was assumed (Part B, Section 2.0). Considerations were made for the approximate location of the mixer pump with respect to the ends of the package to assure that the dose rate limits were not exceeded for the total length of the package.

Results of the shielding analysis indicated that the package containing the 101-SY HMMP must require addition of lead shot into the 2 in. annulus space for the "worst case" waste for a minimum length of 800 cm on the "hot"

end of the package. Considering that the annulus for shielding addition is 2 in. thick and that the pump will be rinsed with a high pressure water spray (3000 psi at 160 °F) during removal from the tank, the packaging design is more than adequate to assure that the dose rates on the surface of the package can be limited to 100 mrem/h.

Based on evaluation of the high pressure spray operation for radioactive waste removal and evaluation of the package surface dose rates taken prior to transport, use of steel shot or no shielding may be considered for specific sections of the package. This will satisfy all requirements for transfer and storage of the package except for dose limits at the driver location. Dose limits at the driver location based on the estimated location of the package on the transport vehicle tractor require evaluation and the actual dose rates shall be less than 2 mrem/h. This will be verified in the field prior to transfer of the package.

5.4 SHIELDING ANALYSIS

**Westinghouse
Hanford Company**

**Internal
Memo**

From: Radiation Physics and Shielding 8D530-SRG-94-007
 Phone: 376-9892 HO-35
 Date: July 22, 1994
 Subject: ESTIMATED DOSE RATES OF THE SURFACE OF THE 101-SY MIXER PUMP
 SHIPPING CONTAINER

To: R. F. Carlstrom G2-02

cc: H. E. Adkins, Jr. G2-03 S. R. Crow G2-03
 J. Greenborg HO-35 J. P. Hauptman S2-03
 A. E. Waltar HO-32 SRG File/LB

- References:
- 1) Internal Memorandum from E. R. Selle to D. C. Hetzer, "Cesium Inventory Remaining on Air Lances Removed from Tank 101-SY,": December 16, 1992, 29250-ERS-92014.
 - 2) Briesmeister, J. F., Editor, *MCNP -- A General Monte Carlo N-Particle Transport Code*. Version 4A, LA-12625, Los Alamos National Laboratory, Los Alamos, New Mexico, 1993.
 - 3) Carter, L. L. and R. A. Schwarz, *Certification of MCNP Version 4A for WHC Computer Platforms*, ECN 186710, January 4, 1994.

This analysis provides radiological dose rate estimates for a contaminated 101-SY hydrogen mitigation mixing pump (HMMP) in various configurations of a shielded shipping container. Dose rates were also calculated at the 51 foot elevation, where it is anticipated the pump would be cut after placement in the shipping container.


The shipping container is modelled as two concentric cylinders with an annulus region filled with lead or steel shot. The inner cylinder is 0.5" steel, the outer was modelled as either 0.25" or 0.5" steel. The annulus region between was either 1.5" or 2.0" and modelled with steel shot, lead shot or air. A packing factor of 60% was assumed when calculating the average density of regions filled with shot. The bottom of the shipping container was modelled as two steel plates separated by a 0.5" air gap. The inner plate was placed 21.25" below the bottom of the pump.

The HMMP was modelled as a combination of simple geometrical shapes representing the 6" pump discharge legs, 16" pump support column, riser seal discs and pump casing. These structures comprise the majority of the wetted surface areas and are the basis for a source term of approximately 13 gallons of slurry. Additionally, it was assumed that the 6" discharge legs and the impeller casing are completely filled with slurry. This represents a worst anticipated interior contamination of the mixer pump, and adds 68 gallons of slurry to the source term. The actual MCNP model is shown in Figure 1; the yellow regions show the source regions. Reference 1 indicates that 101-SY slurry has a density of 1.74 g/cc and a ^{137}Cs specific activity of 360 $\mu\text{Ci/g}$.

Results of this analysis are given in the attached Tables. Note that pump column internals (i.e. conduit/pipe/guide plates), riser seal discs, and other components above the wetted zone are not modelled, and that the calculated dose rates at the top end of the model are undoubtedly high. Specifically, the dose rate on the top centerline of the support column is probably high by an order of magnitude.



S. R. Gedeon, Advanced Engineer
Radiation Physics and Shielding



Reviewed by: _____
R. J. Morford, Principal Scientist
Radiation Physics and Shielding

sam

Attachments



7/22/94

Concurrence: _____
J. Greenberg, Manager
Radiation Physics and Shielding

Date: _____

elev above HMMP bottom (cm)	Dose Rate (mrem/hr)						
	air		lead shot			steel shot	
	annulus thickness / outer cover thickness (inches)						
	1.5/.25	2./ .5	1.5/.25	2/.25	2/.5	1.5/.25	2./ .5
12.55	2242	1685	116	44	35	901	481
38.05	2951	2228	159	61	49	1194	640
338.05	3745	2795	181	69	55	1448	756
487.6	6131	4489	280	104	83	2275	1175
566.	6785	4937	295	107	84	2502	1277
600.	6348	4637	298	109	87	2386	1227
650.	4044	2923	183	67	53	1472	754
700.	1259	880	30	10	8	346	159
750.	668	469	22	8	7	196	95
800.	530	383	20	7		177	87
850.	444	328	20	7		158	82
900.	385	289	18	7		149	76
950.	269	200	13	5		105	54
1000.	182	132	8	3		71	36
1050.	91	63					
1100.	38						
1500.	<1						
1550.	<1						

Table 1. Maximum Radial Dose Rate as a Function of Distance from the Bottom of the Hydrogen Mitigation Mixing Pump.

Bottom	Dose Rate mrem/hr	Top	Dose Rate mrem/hr
2" and 1.25" endplates	189	centerline	94
2" and 2" endplates	79	10 cm off centerline	10

Table 2. Dose Rates at Ends of Shipping Container

Attachment

MCNP Input File

Gamma Dose Rate Tank 101-SY Mixer Pump 1.5 inch annulus shipping asby

c	no Pb,	air in annulus	surfaces		
c	mat#	mat.den	surfaces		
1	2	-.0012	-1	-200 100	\$air inside 6" pipe
2	2	-.0012	-2	1 -200 100	\$no cont. inside pipe
3	3	-7.8	-3	2 -200 100	\$6" steel pipe
4	1	-1.5	-4	3 -200 100	\$ cont. outside of pipe
10	2	-.0012	-10	-200 100	\$air inside 6" pipe
11	1	-1.5	-11	10 -200 100	\$1mm cont. inside pipe 2
12	3	-7.8	-12	11 -200 100	\$6" steel pipe 2
13	1	-1.5	-13	12 -200 100	\$1mm cont. outside pipe 2
20	2	-.0012	-20	-200 100	\$air inside pipe 3
21	2	-.0012	-21	20 -200 100	\$no cont. inside pipe 3
22	3	-7.8	-22	21 -200 100	\$6" steel pipe 3
23	1	-1.5	-23	22 -200 100	\$1mm cont. outsid pipe 3
30	2	-.0012	-30	-200 100	\$air inside pipe 4
31	1	-1.5	-31	30 -200 100	\$1mm cont. outside pipe 4
32	3	-7.8	-32	31 -200 100	\$6" steel pipe 4
33	1	-1.5	-33	32 -200 100	\$1mm cont. outside pipe 4
41	2	-.0012	-41	200 -420	\$air inside pipe 1b
42	2	-.0012	41	-42 200 -420	\$1mm cont. inside pipe 1b NOT
43	3	-7.8	42	-43 200 -420	\$6" steel pipe 1b
44	1	-1.5	43	-44 200 -420	\$cont. outside pipe 1b
51	2	-.0012	-51	200 -420	\$air inside pipe 2b
52	1	-1.5	51	-52 200 -420	\$cont. inside pipe 2b
53	3	-7.8	52	-53 200 -420	\$steel pipe 2b
54	1	-1.5	53	-54 200 -420	\$cont. outside pipe 2b
61	2	-.0012	-61	200 -420	\$air inside pipe 3b
62	2	-.0012	61	-62 200 -420	\$cont inside pipe 3b NOT
63	3	-7.8	62	-63 200 -420	\$steel pipe 3b
64	1	-1.5	63	-64 200 -420	\$cont. outside pipe 3b
71	2	-.0012	-71	200 -420	\$air inside pipe 4b
72	1	-1.5	71	-72 200 -420	\$cont. inside pipe 4b
73	3	-7.8	72	-73 200 -420	\$steel pipe 4b
74	1	-1.5	73	-74 200 -420	\$cont. outside pipe 4b
90	2	-.0012	-90	209 -400	\$air inside support column
91	3	-7.8	90	-91 200 -400	\$1/8" steel support column
92	1	-1.5	91	-92 200 -400	\$cont. on column
93	1	-1.5	-90	200 -209	\$volute, impeller filled w/ waste
110	3	-7.8	-101	4 13 23 33 109 -110	\$disc 1
111	1	-1.5	-101	4 13 23 33 111 -109	\$1mm cont. under disc 1
112	1	-1.5	-101	4 13 23 33 110 -112	\$1mm cont. on top of disc 1
120	3	-7.8	-101	4 13 23 33 120 -121	\$disc 2
121	1	-1.5	-101	4 13 23 33 122 -120	\$cont. on bottom disc 2
122	1	-1.5	-101	4 13 23 33 121 -123	\$cont. on top disc 2
130	3	-7.8	-101	4 13 23 33 130 -131	\$disc 3
131	1	-1.5	-101	4 13 23 33 132 -130	\$cont. on bottom disc 3
132	1	-1.5	-101	4 13 23 33 131 -133	\$cont. on top disc 3
140	3	-7.8	-101	4 13 23 33 140 -141	\$disc 4
141	1	-1.5	-101	4 13 23 33 142 -140	\$cont. on bottom disc 4
142	1	-1.5	-101	4 13 23 33 141 -143	\$cont. on top disc 4
150	3	-7.8	-101	4 13 23 33 150 -151	\$disc 5
151	1	-1.5	-101	4 13 23 33 152 -150	\$cont. on bottom disc 5
152	1	-1.5	-101	4 13 23 33 151 -153	\$cont. on top disc 5
160	3	-7.8	-101	4 13 23 33 160 -161	\$disc 6
161	1	-1.5	-101	4 13 23 33 162 -160	\$cont. on bottom disc 6
162	1	-1.5	-101	4 13 23 33 161 -163	\$cont. on top disc 6
170	3	-7.8	-101	4 13 23 33 170 -171	\$disc 7
171	1	-1.5	-101	4 13 23 33 172 -170	\$cont. on bottom disc 7
172	1	-1.5	-101	4 13 23 33 171 -173	\$cont. on top disc 7
180	3	-7.8	-101	4 13 23 33 180 -181	\$disc 8
181	1	-1.5	-101	4 13 23 33 182 -180	\$cont. on bottom disc 8
182	1	-1.5	-101	4 13 23 33 181 -183	\$cont. on top disc 8
210	3	-7.8	-101	92 44 54 64 74 210 -211	\$disc 9
211	1	-1.5	-101	92 44 54 64 74 212 -210	\$cont. on bot. of 9
212	1	-1.5	-101	92 44 54 64 74 211 -213	\$cont. on top of 9
220	3	-7.8	-101	92 220 -221	\$disc 10
221	1	-1.5	-101	92 222 -220	\$cont.on bot. of 10
222	1	-1.5	-101	92 221 -223	\$cont. on top of 10

230	3	-7.8	-101 92	230 -231	\$disc 11
231	1	-1.5	-101 92	232 -230	\$cont. on bot of 11
232	1	-1.5	-101 92	231 -233	\$cont. on top of 11
240	3	-7.8	-101 92	240 -241	\$disc 12
241	1	-1.5	-101 92	242 -240	\$cont. on bot of 12
242	1	-1.5	-101 92	241 -243	\$cont. on top 12
300	2	-.0012	-101 4 13 23 33	100 -111	\$air space b/n datum & dsc1
301	2	-.0012	-101 4 13 23 33	112 -122	\$air space b/n disc 1&2
302	2	-.0012	-101 4 13 23 33	123 -132	\$ " " " " 2&3
304	2	-.0012	-101 4 13 23 33	133 -142	\$ " " " " 3&4
306	2	-.0012	-101 4 13 23 33	143 -152	\$ " " " " 4&5
308	2	-.0012	-101 4 13 23 33	153 -162	\$ " " " " 5&6
310	2	-.0012	-101 4 13 23 33	163 -172	\$ " " " " 6&7
312	2	-.0012	-101 4 13 23 33	173 -182	\$ " " " " 7&8
314	2	-.0012	-101 4 13 23 33	183 -200	\$ " " " "8 and top
320	2	-.0012	-101 92 44 54 64 74	200 -212	\$air b/n sec 1 and dsc 9
322	2	-.0012	-101 92 44 54 64 74	213 -420	\$air b/n dsc 9&top of pipes
324	2	-.0012	-101 92	420 -222	\$air b/n top pipes & dsc 10
326	2	-.0012	-101 92	223 -232	\$air b/n dsc10 & 11
328	2	-.0012	-101 92	233 -242	\$air b/n dsc11 & 12
330	2	-.0012	-101 92	243 -400	\$air b/n dsc12 & top
601	2	-0.0012	101 -93	100 -400	\$air b/n pump & shipping assembly
602	3	-7.8	93 -94	100 -400	\$shipping asby--structural steel
603	2	-0.00122	94 -95	100 -400	\$Pb annulus
604	3	-7.8	95 -96	100 -400	\$steel cover on Pb annulus
605	2	-0.0012	(97 : -455 : 440)	-1000	\$ air outside shipping asby
651	2	-0.0012	-96	-100 451	\$ air
652	3	-7.8	-96	-451 452	\$ inner end plate
653	2	-0.0012	-96	-452 453	\$ half inch air gap btwn end plts
654	3	-7.8	-96	-453 454	\$ outer 2" end plate
661	2	-0.0012	-90	400 -440	\$ air inside support column
662	3	-7.8	90 -91	400 -440	\$ support column
663	2	-0.0012	91 -93	400 -440	\$ air btwn sup col & ship asby
664	3	-7.8	93 -94	400 -440	\$ inner ship container
665	2	-0.0012	94 -95	400 -440	\$ annulus btwn inner & outer
666	3	-7.8	95 -96	400 -440	\$ outer cover
667	2	-0.0012	-97 (96 : -454)	455 -440	\$ 2 in airgap btwn asbly & dose plane
1001	0		1000		\$universe

1	c/z	0	-20.0	7.52	\$1mm thick cont. inside 6" pipe
2	c/z	0	-20.0	7.62	\$inside pipe dia.
3	c/z	0	-20.0	8.414	\$outside pipe dia.
4	c/z	0	-20.0	8.514	\$1mm thick cont. outside 6" pipe
10	c/z	-20.0	0	7.52	\$ "
11	c/z	-20.0	0	7.62	\$ "
12	c/z	-20.0	0	8.414	\$ "
13	c/z	-20.0	0	8.514	\$ "
20	c/z	0	20.0	7.52	\$ "
21	c/z	0	20.0	7.62	\$ "
22	c/z	0	20.0	8.414	\$ "
23	c/z	0	20.0	8.514	\$ "
30	c/z	20.0	0	7.52	\$ "
31	c/z	20.0	0	7.62	\$ "
32	c/z	20.0	0	8.414	\$ "
33	c/z	20.0	0	8.514	\$ "
100	pz	0			\$bottom of mixer pump
200	pz	480.0			\$top of the bottom section
101	cz	56.0			\$radius of the seal discs
109	pz	10.0			\$bottom of disc 1
110	pz	15.1			\$top of disc 1
111	pz	9.9			\$cont. on bottom of disc 1
112	pz	15.2			\$cont. on top of disc 1
120	pz	61.0			\$bottom of disc 2
121	pz	66.1			\$top of disc 2
122	pz	60.9			\$cont. on bottom of disc 2
123	pz	66.2			\$cont. on top of disc 2
130	pz	122.0			\$bottom of disc 3
131	pz	127.1			\$top of disc 3
132	pz	121.9			\$cont. on bottom of disc 3

133	pz	127.2	\$cont. on top of disc 3
140	pz	183.0	\$bottom of disc 4
141	pz	188.1	\$top of disc 4
142	pz	182.9	\$cont. on bottom of disc 4
143	pz	188.2	\$cont. on top of disc 4
150	pz	244.0	\$bottom of disc 5
151	pz	249.1	\$top of disc 5
152	pz	243.9	\$cont. on bottom of disc 5
153	pz	249.2	\$cont. on top of disc 5
160	pz	305.0	\$bottom of disc 6
161	pz	310.1	\$top of disc 6
162	pz	304.9	\$cont. on bottom of disc 6
163	pz	310.2	\$cont. on top of disc 6
170	pz	366.0	\$bottom of disc 7
171	pz	372.1	\$top of disc 7
172	pz	365.9	\$cont. on bottom of disc 7
173	pz	372.2	\$cont. on top of disc 7
180	pz	457.5	\$bottom of disc 8
181	pz	462.6	\$top of disc 8
182	pz	457.4	\$cont. on bottom of disc 8
183	pz	462.7	\$cont. on top of disc 8
209	pz	495.2	\$top of impeller/volute region
210	pz	570.1	\$bottom of disc 9.
211	pz	575.2	\$top of disc 9
212	pz	570.0	\$cont. on bottom of disc 9
213	pz	575.3	\$cont. on top of disc 9
220	pz	670.1	\$bottom disc 10
221	pz	675.2	\$top of disc 10
222	pz	670.0	\$cont. on bottom of disc 10
223	pz	675.3	\$cont. on top of disc 10
230	pz	770.1	\$bottom of disc 11
231	pz	775.2	\$top of disc 11
232	pz	770.0	\$cont. on bottom of disc 11
233	pz	775.3	\$cont. on top of disc 11
240	pz	870.1	\$bottom of disc 12
241	pz	875.2	\$top of disc 12
242	pz	870.0	\$cont. on bottom of disc 12
243	pz	875.3	\$cont. on top of disc 12
400	pz	1016.0	\$top of cont. portion of mixer pump (400 in)
420	pz	652.0	\$top of pump/pipes end
440	pz	1555.0	\$ 51 ft above bottom of pump
451	pz	-53.975	\$air gap betwn pump & inner end plate
452	pz	-57.150	\$outer side of inner end plate
453	pz	-58.420	\$half inch air gap btwn plates
454	pz	-63.500	\$outer side of outer end plate
455	pz	-68.580	\$ tally surface 2" past end plate
41	c/z	0 -43.0 7.52	\$1mm thick cont. inside pipe
42	c/z	0 -43.0 7.62	\$inside pipe dia.
43	c/z	0 -43.0 8.414	\$outside pip dia.
44	c/z	0 -43.0 8.514	\$1mm cont. outside pipe
51	c/z	-43.0 0 7.52	\$1mm cont. inside pipe
52	c/z	-43.0 0 7.62	\$inside pipe dia.
53	c/z	-43.0 0 8.414	\$outside pipe dia.
54	c/z	-43.0 0 8.514	\$1mm cont. outside pipe
61	c/z	0 43.0 7.52	\$ " "
62	c/z	0 43.0 7.62	\$ " "
63	c/z	0 43.0 8.414	\$ " "
64	c/z	0 43.0 8.514	\$ " "
71	c/z	43.0 0 7.52	\$ " "
72	c/z	43.0 0 7.62	\$ " "
73	c/z	43.0 0 8.414	\$ " "
74	c/z	43.0 0 8.514	\$ " "
90	cz	20.0	\$ support column inner wall
91	cz	20.32	\$ support column outer wall
92	cz	20.42	\$ 1mm cont. on surface of column
93	cz	80.015	\$ inner radius shipping asby struct
94	cz	81.285	\$ outer radius " " "
95	cz	85.095	\$ inner radius annulus cover
96	cz	85.730	\$ outer radius annulus cover

97 cz 90.810 \$ tally surface--2" out from annulus cover
 1000 so 4000 \$atmosphere

```

mode p
phys:p 10 1 0
idum 1 0 0 0 0
c cell numbers
c 1 2 3 4 10 11 12 13 20 21 22 23
imp:p 1 2m 2m 2m 1 2m 2m 2m 1 2m 2m 2m
c 30 31 32 33 41 42 43 44 51 52
c 1 2m 2m 2m 1 2m 2m 2m 1 2m
c 53 54 61 62 63 64 71 72 73 74
c 2m 2m 1 2m 2m 2m 1 2m 2m 2m
c 90 91 92 93
c 1 2m 2m 1m
c 110 111 112 120 121 122
c 1m 2m 1m .5m 2m 1m
c 130 131 132 140 141 142 150 151 152
c .5m 2m 1m .5m 2m 1m .5m 2m 1m
c 160 161 162 170 171 172 180 181 182
c .5m 2m 1m .5m 2m 1m .5m 2m 1m
c 210 211 212 220 221 222 230 231 232
c .5m 2m 1m .5m 2m 1m .5m 2m 1m
c 240 241 242
c .5m 2m 1m
c 300 301 302 304 306 308 310 312 314
c 2m 1m 1m 1m 1m 1m 1m 1m 1m
c 320 322 324 326 328 330 601 602 603
c 1m 1m 1m 1m 1m 1m 2m 1m 1m
c 604 605 651-667 1001
c 1m 1m 11r 0
sdef sur=0 erg=.662 wgt=5.897e+12 cel=d1 rad fcel=d2 pos fcel=d3
ext fcel=d4 axs=0 0 1
c wgt = (360 uCi/g)(1.74 g/cc)(3.7E+4 dps/uCi)(.946X.9)(4.80E+4 cc)
c + (360 ) (1.74 ) (3.7e+4 ) (.946x.9)(2.508e+4 )
sc1 source cells
# si1 sp1
l d
4 2.553e+3
10 8.528e+4
11 2.283e+3
13 2.553e+3
23 2.553e+3
30 8.528e+4
31 2.283e+3
33 2.553e+3
44 9.147e+2
51 3.056e+4
52 8.181e+2
54 9.147e+2
64 9.147e+2
71 3.056e+4
72 8.181e+2
74 9.147e+2
92 6.832e+3
93 1.915e+4
111 9.852e+2
112 9.852e+2
121 9.852e+2
122 9.852e+2
131 9.852e+2
132 9.852e+2
141 9.852e+2
142 9.852e+2
151 9.852e+2
152 9.852e+2
161 9.852e+2
162 9.852e+2
171 9.852e+2
    
```

```

172      9.852e+2
181      9.852e+2
182      9.852e+2
211      9.852e+2
212      9.852e+2
221      9.852e+2
222      9.852e+2
231      9.852e+2
232      9.852e+2
241      9.852e+2
242      9.852e+2
c        sample radius
ds2      s 102 142 103 104 106 143 107 108 110 144 111 112 114 145
          115 116 117 146 118 119 120 121 122 123 124 125 126 127 128
          129 130 131 132 133 134 135 136 137 138 139 140 141
si102    8.414  8.514
si142    0      7.52
si103    7.52   7.62
si104    8.414  8.514
si106    8.414  8.514
si143    0      7.52
si107    7.52   7.62
si108    8.414  8.514
si110    8.414  8.514
si144    0      7.52
si111    7.52   7.62
si112    8.414  8.514
si114    8.414  8.514
si145    0      7.52
si115    7.52   7.62
si116    8.414  8.514
si117    20.32  20.42
si146    0      20.0
si118    0      56.0
si119    0      56.0
si120    0      56.0
si121    0      56.0
si122    0      56.0
si123    0      56.0
si124    0      56.0
si125    0      56.0
si126    0      56.0
si127    0      56.0
si128    0      56.0
si129    0      56.0
si130    0      56.0
si131    0      56.0
si132    0      56.0
si133    0      56.0
si134    0      56.0
si135    0      56.0
si136    0      56.0
si137    0      56.0
si138    0      56.0
si139    0      56.0
si140    0      56.0
si141    0      56.0
sc3      sample position
ds3      l
          0 -20.0  0
          -20.0  0.  0.
          -20.0  0  0
          -20.0  0  0
          0  20.0  0
          20.0  0  0
          20.0  0  0
          20.0  0  0
          0 -43.0  0
          -43.0  0  0
    
```


si233	462.6	462.7	
si234	570.0	570.1	
si235	575.2	575.3	
si236	670.0	670.1	
si237	675.2	675.3	
si238	770.0	770.1	
si239	775.2	775.3	
si240	870.0	870.1	
si241	875.2	875.3	
m1	1001.50	.4372	\$H 101 SY slurry
	.6000.50	.0170	\$C
	7014.50	.0579	\$N
	8016.50	.3725	\$O
	11023.50	.0975	\$Na
	13027.50	.0113	\$Al
	15031.50	.0011	\$P
	17000.50	.0029	\$Cl
	19000.50	.0026	\$K
m2	8016.50	.21	\$O air number fraction
	7014.50	.79	\$N
m3	26000.55	1.0	\$Fe iron
m4	8016.50	-.4407	\$O concrete weight fraction
	14000.50	-.2157	\$Si
	20000.50	-.1306	\$Ca
	26000.55	-.0788	\$Fe
	13027.50	-.0607	\$Al
	12000.50	-.0376	\$Mg
	19000.50	-.0066	\$K
	11023.50	-.0182	\$Na
	22000.50	-.0049	\$Ti
	1001.50	-.0031	\$H
	25055.50	-.0013	\$Mn
	15031.50	-.0009	\$P
	16032.50	-.0009	\$S
m5	82000.50	1.0	\$Pb shielding
c			
f5:p	0.0	62 550 +5	
fc5		contact on pump	
fm5	1.3		\$increase tally by 30% for unmodeled surfaces
c			
f15:p	0.0	90.811 12.55 +5	
fc15		cover contact y axis, z=12.55 cm	
c			
f25:p	90.811	0.0 12.55 +5	
fc25		cover contact x axis, z=12.55 cm	
c			
f35:p	0.0	90.811 38.05 +5	
fc35		cover contact y axis, z=38.05 cm	
c			
f45:p	90.811	0.0 38.05 +5	
fc45		cover contact x axis, z=38.05 cm	
c			
f55:p	0.0	90.811 338.05 +5	
fc55		cover contact y axis, z=338.05 cm	
c			
f65:p	90.811	0.0 338.05 +5	
fc65		cover contact x axis, z=338.05 cm	
c			
f75:p	0.0	90.811 487.6 +5	
fc75		cover contact y axis, z=487.6 cm	
c			
f85:p	90.811	0.0 487.6 +5	
fc85		cover contact x axis, z=487.6 cm	
c			
f95:p	0.0	90.811 566.0 +5	
fc95		cover contact y axis, z=566.0 cm	
c			
f105:p	90.811	0.0 566.0 +5	
fc105		cover contact x axis, z=566.0 cm	

c
f115:p 0.0 0.0 1555.0 +5
fc115 top of assembly, center
c
f125:p 45. 0.0 1555.0 +5
fc125 top of assembly, off-center x-axis
c
f135:p 0.0 0.0 -68.579 +5
fc135 center of bottom plates, 2 in out
c
f145:p 0.0 90.811 600.0 +5
fc145 cover contact y axis, z=12.55 cm
c
f155:p 90.811 0.0 600.0 +5
fc155 cover contact x axis, z=12.55 cm
c
f165:p 0.0 90.811 650.0 +5
fc165 cover contact y axis, z=38.05 cm
c
f175:p 90.811 0.0 650.0 +5
fc175 cover contact x axis, z=38.05 cm
c
f185:p 0.0 90.811 700.00 +5
fc185 cover contact y axis, z=338.05 cm
c
f195:p 90.811 0.0 700.00 +5
fc195 cover contact x axis, z=338.05 cm
c
f205:p 0.0 90.811 750.0 +5
fc205 cover contact y axis, z=487.6 cm
c
f215:p 90.811 0.0 750.0 +5
fc215 cover contact x axis, z=487.6 cm
c
f225:p 0.0 90.811 800.0 +5
fc225 cover contact y axis, z=566.0 cm
c
f235:p 90.811 0.0 800.0 +5
fc235 cover contact x axis, z=800.0 cm
c
f245:p 0.0 90.811 850.0 +5
fc245 cover contact y axis, z=850.0 cm
c
f255:p 90.811 0.0 850.0 +5
fc255 cover contact x axis, z=850.0 cm
c
f265:p 0.0 90.811 900.0 +5
fc265 cover contact y axis, z=900.0 cm
c
f275:p 90.811 0.0 900.0 +5
fc275 cover contact x axis, z=900.0 cm
c
f285:p 0.0 90.811 950.00 +5
fc285 cover contact y axis, z=950.00 cm
c
f295:p 90.811 0.0 950.00 +5
fc295 cover contact x axis, z=950.00 cm
c
f305:p 0.0 90.811 1000. +5
fc305 cover contact y axis, z=1000. cm
c
f315:p 90.811 0.0 1000. +5
fc315 cover contact x axis, z=1000. cm
c
f325:p 0.0 90.811 1050. +5
fc325 cover contact y axis, z=1050. cm
c
f335:p 90.811 0.0 1050. +5
fc335 cover contact x axis, z=1050. cm

```
c
f345:p 0.0 90.811 1100. +5
fc345 cover contact y axis, z=1100. cm
c
f355:p 90.811 0.0 1100. +5
fc355 cover contact x axis, z=1100. cm
c
f365:p 0.0 90.811 1350. +5
fc365 cover contact y axis, z=1350. cm
c
f375:p 90.811 0.0 1350. +5
fc375 cover contact x axis, z=1350. cm
c
f385:p 0.0 90.811 1400. +5
fc385 cover contact y axis, z=1400. cm
c
f395:p 90.811 0.0 1400. +5
fc395 cover contact x axis, z=1400. cm
c
f405:p 0.0 90.811 1450. +5
fc405 cover contact y axis, z=1450. cm
c
f415:p 90.811 0.0 1450. +5
fc415 cover contact x axis, z=1450. cm
c
f425:p 0.0 90.811 1500. +5
fc425 cover contact y axis, z=1500. cm
c
f435:p 90.811 0.0 1500. +5
fc435 cover contact x axis, z=1500. cm
c
f445:p 0.0 90.811 1550. +5
fc445 cover contact y axis, z=1550. cm
c
f455:p 90.811 0.0 1550. +5
fc455 cover contact x axis, z=1550. cm
c
c
ctme 360. $time limit
```

CHECKLIST FOR INDEPENDENT TECHNICAL REVIEW

DOCUMENT REVIEWED_ ESTIMATED DOSE RATES OF THE SURFACE OF THE 101-SY
MIXER PUMP SHIPPING CONTAINER

AUTHOR(s) S.R. Gedeon

I. Method(s) of Review

- Input data checked for accuracy
- Independent calculation performed
 - Hand calculation
 - Alternate computer code: _____
- Comparison to experiment or previous results
- Alternate method (define) _____

II. Checklist (either check or enter NA if not applied)

- Task completely defined
- Activity consistent with task specification
- Necessary assumptions explicitly stated and supported
- Resources properly identified and referenced
- Resource documentation appropriate for this application
- Input data explicitly stated
- Input data verified to be consistent with original source
- Geometric model adequate representation of actual geometry
- Material properties appropriate and reasonable
- Mathematical derivations checked including dimensional consistency
- Hand calculations checked for errors
- Assumptions explicitly stated and justified
- Computer software appropriate for task and used within range of validity
- Use of resource outside range of established validity is justified
- Software runstreams correct and consistent with results
- Software output consistent with input
- Results consistent with applicable previous experimental or analytical findings
- Results and conclusions address all points and are consistent with task requirements and/or established limits or criteria
- Conclusions consistent with analytical results and established limits
- Uncertainty assesment appropriate and reasonable
- Other (define) _____

III. Comments:

IV. REVIEWER: *R. J. [Signature]* DATE: 7-20-94



6.0 STRUCTURAL EVALUATION

6.1 INTRODUCTION

Evaluations in this section are provided to assure that the packaging structural system is adequate to withstand designated normal conditions of transfer and other specified structural requirements of the packaging. The structural evaluation is based on requirements provided in the following sections.

6.2 STRUCTURAL REQUIREMENTS

6.2.1 Packaging Materials

Packaging construction materials shall be based on the following requirements for the transfer and storage of the package:

1. Packaging construction materials shall be selected to assure that there will be no significant chemical, galvanic, or other reaction among the packaging components or between the package components and the package contents, including possible reaction resulting from inleakage of water to the maximum credible extent during the 20 year specified lifetime of the packaging.
2. Material structural properties shall conform to packaging structural design analysis provided in this SEP.
3. Packaging containment materials with thickness between 0.4 in. and 4.0 in. shall meet packaging category III fracture toughness requirements shown in Table 6 of NUREG/CR-1815. The Lowest Service Temperature (LST) for design purposes shall be 0 °F.

6.2.2 Packaging Dimensions

The waste shipping container shall be sized to transfer and contain for storage the "package contents" described in Part A, Section 2.0 of the SEP. Specifically, the designated hydrogen mitigation mixer pump placed in a flexible bag assembly. Clearance dimensions required for the packaging enclosure cavity shall consider adequate clearance for installing the flexible bag assembly.

6.2.3 Tiedown System

Tiedown devices that are attached to the shipping container shall be capable of holding the package on the transport trailer during sudden stops and cornering speeds of 15 mph without exceeding the yield strength of the tiedown device or its connection point to the package. In addition, tiedown

devices that are a structural part of the package must be capable of withstanding, without generating stress in any material of the package in excess of its yield strength, a static force applied to the center of gravity of the package having a vertical component of two times the weight of the package with its contents, a horizontal component along the direction in which the vehicle travels of 10 times the weight of the package with its contents, and a horizontal component in the transverse direction of five times the weight of the package with its contents. Any other structural part of the package which could be used to tie down the package shall be rendered inoperable for tying down the package during transport, or shall be designed with strength equivalent to that required for tiedown devices. Each tiedown device which is a structural part of a package must be designed so that failure of the device under excessive load would not impair the ability of the package to meet other requirements of this section.

The tiedown system used to secure the package to the transport vehicle shall be designed and evaluated to assure that the tiedown assemblies used to secure the package against movement in any direction have the aggregate static breaking strength of at least $1\frac{1}{2}$ times the weight of the package. Design and analysis of the tiedown system shall be provided as part of the packaging design project and will be included as part of the SEP documentation.

6.2.4 Lifting Devices

Attachments shall be provided on the shipping container as required to safely lift the waste package and secure the package during transfer. Any lifting attachment that is a structural part of the package shall be designed with one of the following:

- A minimum safety factor of three against yielding.
- A safety factor of five based on the ultimate strength of the material.

When the lifting attachment is used as intended, it must be designed so that a lifting device failure caused by an excessive load would not impair the package from meeting other criteria. Any structural part of the package not approved for lifting the package must be capable of being rendered inoperable for lifting the package during transfer or must be designed with strength equivalent to that required for the approved lifting attachments.

6.2.5 Closure Design

The package shall have positive closure devices that cannot be opened unintentionally and shall keep the closures on. The closure shall also meet the requirements for the primary containment barrier of the package for transfer and storage of the waste. The closure system, if required, shall

provide for remote closure with guides allowing remote lid positioning. Any penetrations on the package that will not be used shall be provided with acceptable closure devices.

6.2.6 Normal Transfer Conditions

Specific requirements for normal conditions of transfer and testing of the packaging are shown in Part B, Section 4.2. The drop test for structural evaluations shall consist of a simulated 1 ft drop of a unshielded HMMP Package, a 1 ft drop with partial shielding to column line 14, and a 1 ft drop of a fully shielded HMMP Package from a horizontal position onto a 12 in. thick reinforced concrete slab with #9 rebar at 12 in. spacings for reinforcement. In addition, the penetration, vibration, and pressure testing described in Part B, Section 4.2 will also be evaluated in the structural section of this SEP.

6.3 STRUCTURAL EVALUATION AND CONCLUSIONS

6.3.1 Packaging Materials

The shipping container is designed for a 20 year lifetime in the environment of the CWC mixed waste storage facility. Significant galvanic reaction will not be present since all containment materials are similar. Internal corrosion due to possible leakage of the contents is not considered critical since the storage tank waste material is normally 10 pH or higher. The structural materials are carbon steel and all exposed surfaces are painted to prevent external corrosion during the specified package lifetime. The structural strength of the packaging materials required to safely contain and lift the package has been analyzed in the structural analysis shown in Part B, Section 6.4. Results of the analysis indicated that the packaging material is structurally safe for containing and lifting the maximum contents of 138,800 lb for the shipping container.

Evaluation of packaging containment materials to meet the required brittle fracture criteria was based on an analysis of 2 in. thick, normalized (fine grain practice) American Society for Testing and Materials (ASTM) A516 steel in accordance with specifications and criteria presented in NUREG 1815, *Recommendations for Protecting Against Failure by Brittle Fracture in Ferritic Steel Shipping containers Up to Four Inches Thick* (Holman and Langland 1981). An evaluation of the brittle fracture guidelines in NUREG 1815 (Holman and Langland 1981) for onsite transfers of radioactive materials under the conditions of this SEP was conducted. In Table 6 of NUREG 1815 (Holman and Langland 1981), there are no requirements for ferritic steels of yield strengths greater than 100 ksi when the material thickness is less than 0.4 in. When material thicknesses are greater than 0.4 in., steels that are made to normalized (fine grain practice) or better, no fracture toughness testing is required. The evaluation indicates that the specified ASTM A516 fine grain material for the shipping container is considered acceptable to

meet designated brittle fracture criteria without requiring specific fracture toughness testing and Nil Ductility Testing (NDT) by the manufacturer of the material.

6.3.2 Packaging Dimensions

The packaging internal cavity dimensions are 63 in. in diameter and 52 ft in length. The internal cavity is considered sufficient to contain the HMMP.

6.3.3 Tiedown System

A tiedown analysis for devices attached to the package is shown in Part B; Section 6.5 and indicates that the strength of the attachments meet the identified tiedown requirements and are considered safe for the intended use.

A sketch of the proposed tiedown system that will be used to secure the package to the vehicle is shown in Part B, Section 6.5. The system is based on using the tilt/trailer assembly with the interfacing strongback to transport the package containing the pump. Analysis of the tiedown system indicates that the proposed system is considered safe to secure the shielded or unshielded HMMP Package on the transport vehicle during normal transfer operations. The tiedown system is based on 12 tiedown points on the HMMP Package with 16 cable legs. The breaking strength of tiedown cables will be equal to or exceed 15,430 lb.

6.3.4 Lifting Devices

Evaluation of the lifting attachment analysis provided in Part B, Section 6.5 indicates that the strength of the attachments meet the above design requirements and are considered safe for the intended usage. Other parts of the package not approved for lifting are not readily accessible and do not have any means to inadvertently connect hoisting equipment.

6.3.5 Closure Design

The closure devices (end plates) were analyzed in the drop tests shown in Part B, Section 6.4 for normal conditions of transfer and were shown to maintain the integrity of the seal after dropping the package onto a 12 in. thick reinforced concrete surface with #9 rebar for reinforcement. This test is considered sufficient to assure that the package closures will not leak for a rollover onto soft soil. Remote operation to install or remove closures is not required for a contact handled package shielded to 100 mrem/h. Closures are provided to seal the vent opening during transfer of the package. These closures provide positive sealing and are considered safe for containment of the package during transfer and will be removed during storage of the package for installation of an approved high-efficiency particulate air (HEPA) filter.

6.3.6 Normal Transfer Conditions

Results of analyses for simulated drop tests of the HMMP Package are shown in Part B, Section 6.4. The analysis was based on the determination if critical structural components of the package will exceed yield stresses during impact of the package from a horizontal drop. If yield stresses are not exceeded, the packaging containment body and end closures will be considered to have maintained their integrity following the drop test. Results of the test analysis indicated that the yield stresses were not exceeded and that the package successfully passed the drop tests.

Evaluation of assumed vibration movements of the package during transfer were analyzed and are shown in Part B, Section 6.4. Results of this study indicated that with the package properly secured to the transport vehicle, and with specified administration controls being applied per this SEP, vibration is not a consideration.

The packaging was evaluated to determine if unacceptable damage would result from dropping an object on the surface of the packaging per requirements described in Part B, Section 4.2. Results of a simulated penetration test are shown in Part B, Section 6.4 and indicated that the packaging containment barrier would not be damaged following the simulated test.

Criteria (Part B, Section 4.2) for normal transfer condition tests require that the package be evaluated to determine if it will safely withstand specific internal and external pressures during normal transport of the package. Results of the pressure tests are shown in Part B, Section 6.4 and indicate that the package will safely withstand the specified pressure tests without damage to the containment barrier.

6.4 STRUCTURAL ANALYSIS

6.4.1 Weight and Center of Gravity Determination

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 1 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

I. Objectives:

The objective of this is to determine the weight and center of gravity of the Hydrogen Mitigation Mixer Pump Package.

II. References:

1. Industrial Press, Machinery's Handbook, 20th Edition.
2. AISC, American Institute Of Steel Construction, Manual Steel Construction, Ninth Edition.
3. WHC, Drawing, No. H-2-83734, "Hydrogen Mixer Pump Storage Container".
4. Ingersoll-Rand, Compressed Air and Gas Data, 2nd Edition.

III. Results and Conclusions:

The weight and center of gravity calculated herein, form the basis for other engineering evaluations applicable to this package. The calculated values a conservative estimates of the actual weight and are the primary input parameters for the drop, lifting, and vibration evaluations. For reasons of conservatism all calculated weights have been rounded upwards. Center of gravity values are all relative to the center of the Bottom End Blind Flange, except for the Top Caps which are relative to the front face of the Top End Flange. The weight and center of gravity of the package for various loading combinations are as follows:

1. Weight of empty package no shielding: $W_{empty} = 57,000 \text{ lbs}$

CG of empty package no shielding: $cg_{epack} = 27.3 \text{ ft}$

2. Weight of empty package with shielding to Column 14:

$$W_{sh1pack} = 88,000 \text{ lbs}$$

CG of empty package with shielding to Column 14:

$$cg_{sh1pack} = 22.36 \text{ ft}$$

3. Weight of empty package with full shielding (Column 25):

$$W_{sh2pack} = 130,000 \text{ lbs}$$

CG of empty package with full shielding (Column 25):

$$cg_{sh2pack} = 26.62 \text{ ft}$$

4. Weight of loaded package with no shielding:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 2 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

$$W_{\text{pack}} = 76,000 \text{ lbs}$$

CG of loaded package with no shielding:

$$cg_{\text{pack}} = 28.45 \text{ ft}$$

5. Weight of loaded package shielded to Column 14:

$$W_{\text{packsh1}} = 110,000 \text{ lbs}$$

CG of loaded package shielded to Column 14:

$$cg_{\text{packsh1}} = 29.59 \text{ ft}$$

6. Weight of loaded package fully shielded to Column 25:

$$W_{\text{packsh2}} = 145,000 \text{ lbs}$$

CG of loaded package fully shielded to Column 25:

$$cg_{\text{packsh2}} = 31.83 \text{ ft}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 3 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

IV. Engineering Evaluation:

Weight Determination of 101-SY Container:

Carbon steel material density (Reference 1, page 2269):

$$\rho_{cstl} = 0.284 \frac{lbs}{in^3}$$

From Reference 3

1. Main containment pipe:

OD of pipe: $od_{pipe} = 64$ in Wall Thickness: $t_{pipe} = 0.5$ in

Length: $l_{pipe} = 52$ ft + 0.75 in

Cross section area:

$$A_{pipe} = \pi \frac{od_{pipe}^2 - (od_{pipe} - 2 t_{pipe})^2}{4}$$

Weight of pipe: $W_{pipe} = \rho_{cstl} \cdot A_{pipe} \cdot l_{pipe}$

$$W_{pipe} = 17,698 \text{ lbs}$$

Calculational Roundoff of Weight: $W_1 = 18,000$ lbs

2. Stiffening Rings Type 1 (with ears, 16 each):

Outer diameter (excluding ears): $od_{sr1} = 5$ ft + 11.625 in

Inside diameter: $id_{sr1} = 5$ ft + 4 in

Thickness of rings: $t_{sr1} = 1.5$ in

Area of ring:

$$A_{sr1} = \pi \frac{od_{sr1}^2 - id_{sr1}^2}{4}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 4 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

For Conservatism model ears as right triangles:

Height: $h_{ear} = 2 \text{ ft} + 2 \text{ in}$ Base: $b_{ear} = 6.5 \text{ in}$

Area of ear:

$$A_{ear} = \frac{1}{2} b_{ear} h_{ear}$$

Weight of ring: $W_{sr1} = \rho_{cstl} \cdot (A_{sr1} + 2 \cdot A_{ear}) \cdot t_{sr1}$

$$W_{sr1} = 418 \text{ lbs}$$

Calculational Roundoff of Weight: $W_2 = 450 \text{ lbs}$

3a. Stiffening Rings Type 2a (with flats, 3 each):

Area excluding flats same as above:

Width of flat: $wi_{sr2} = 3 \text{ in}$ Length of flat: $l_{sr2} = 2 \text{ ft} + 9 \text{ in}$

For conservatism assume rectangular shape.

Area of flats: $A_{flat} = wi_{sr2} \cdot l_{sr2}$

Attachment lug (assume half the weight carried by each ring)

Thickness of long plate with hole: $t_{alh} = 2 \text{ in}$

Height of plate: $h_{alh} = 11.625 \text{ in}$

Width of plate: $wi_{alh} = 8 \text{ in}$

Weight of long plate with hole:

$$W_{lh} = \rho_{cstl} \cdot h_{alh} \cdot wi_{alh} \cdot t_{alh}$$

Thickness of short plate: $t_{as} = 1.5 \text{ in}$

Height of plate: $h_{as} = 3 \text{ in}$

Width of plate: $w_{as} = 9 \text{ in}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 5 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

Weight of bottom support plate:

$$W_{as} = \rho_{cstl} \cdot h_{as} \cdot W_{as} \cdot t_{as}$$

Total weight of one attachment lug:

$$W_{alug} = W_{lh} + W_{as}$$

Weight of ring: $W_{sr2a} = \rho_{cstl} \cdot (A_{sr1} + 2 \cdot A_{flat}) \cdot t_{sr1} + W_{alug}$

$$W_{sr2a} = 495 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{3a} = 525 \text{ lbs}$

3b. Stiffening Rings Type 2b (with flats, 4 each):

Weight of ring only: $W_{sr2b} = \rho_{cstl} \cdot (A_{sr1} + 2 \cdot A_{flat}) \cdot t_{sr1}$

Lifting lug:

Thickness of lifting lug: $t_{ll} = 2 \text{ in}$

Area of ring:

Radius: $r_{ll} = 4.75 \text{ in}$

Height of straight section: $h_{ll} = 1 \text{ ft} + 2.625 \text{ in}$

Width of lug: $w_{ll} = 9.5 \text{ in}$

Total area: $A_{ll} = (\pi \cdot r_{ll}^2) / 2 + h_{ll} \cdot w_{ll}$

Weight of one lifting lug: $W_{ll} = \rho_{cstl} \cdot A_{ll} \cdot t_{ll}$

Weight of ring: $W_{sr2b} = W_{sr2b} + W_{ll}$ $W_{sr2b} = 550 \text{ lbs}$

Calculational Roundoff of Weight: $W_{3b} = 600 \text{ lbs}$

4. Bottom End Flange:

Outside diameter of flange: $od_{bef} = 5 \text{ ft} + 11.625 \text{ in}$

Thickness of flange: $t_{bef} = 2 \text{ in}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 6 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

Area of flange:

$$A_{bef} = \pi \frac{od_{bef}^2}{4}$$

Area of flats same as above.

Weight of Bottom End Flange: $W_{bef} = \rho_{cstl} \cdot (A_{bef} + 2 \cdot A_{flat}) \cdot t_{bef} + W_{alug}$

$$W_{bef} = 2,465 \text{ lbs}$$

Calculational Roundoff of Weight: $W_4 = 2,600 \text{ lbs.}$

5. Outside Top End Flange (Open):

Outside diameter of flange: $od_{tef} = 5 \text{ ft} + 11.625 \text{ in}$

Thickness of flange: $t_{tef} = 2 \text{ in}$

ID of flange is od of the pipe.

Area of the flange:

$$A_{tef} = \pi \frac{od_{tef}^2 - od_{pipe}^2}{4}$$

Weight of Outside Top End Flange: $W_{tef} = \rho_{cstl} \cdot A_{tef} \cdot t_{tef}$

$$W_{tef} = 461 \text{ lbs}$$

Calculational Roundoff of Weight: $W_5 = 500 \text{ lbs}$

6. Inner bottom blind flange:

OD of flange: $od_{ibf} = od_{pipe} - 2 \cdot t_{pipe}$

Thickness of flange: $t_{ibf} = 2 \text{ in}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 7 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow *SR* Date 08/25/94

Area of flange:

$$A_{ibf} = \pi \frac{od_{ibf}^2}{4}$$

Weight of inner bottom flange: $W_{ibf} = \rho_{cstl} \cdot A_{ibf} \cdot t_{ibf}$
 $W_{ibf} = 1,771 \text{ lbs}$

Calculational Roundoff of Weight: $W_6 = 1,800 \text{ lbs}$

7. Inner Top Flange (Open):

OD of flange is same as above.

ID of flange: $id_{itf} = 4 \text{ ft} + 10 \text{ in}$

Area of flange:

$$A_{itf} = \pi \frac{od_{ibf}^2 - id_{itf}^2}{4}$$

Thickness: $t_{itf} = 2 \text{ in}$

Weight of flange: $W_{itf} = \rho_{cstl} \cdot A_{itf} \cdot t_{itf}$
 $W_{itf} = 270 \text{ lbs}$

Calculational Roundoff of Weight: $W_7 = 300 \text{ lbs}$

8. Built-in Outer Funnel:

Gusset plate thickness: $t_{gus} = 0.375 \text{ in}$

Gusset length: $l_{gus} = 10.75 \text{ in}$

Gusset height: $h_{gus} = 9.25 \text{ in}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 8 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

Area of gusset minus cut-out:

$$A_{gus} = l_{gus} h_{gus} - \frac{1}{2} l_{gus} (h_{gus} - 2.5 \text{ in})$$

Weight of 12 gussets: $w_{gus} = 12 \cdot \rho_{cstl} \cdot A_{gus} \cdot t_{gus}$

Outer funnel plate, treated as a frustum of a right circular cone:

Plate thickness: $t_{frcc} = 0.250 \text{ in}$

Height of cone: $h_{frcc} = 10.750 \text{ in}$

Outer radius of cone:

$$R_{frcc} = \frac{id_{ict}}{2}$$

Inner radius of cone:

$$r_{frcc} = \frac{3 \text{ ft} + 8.5 \text{ in}}{2}$$

Surface area of section:

$$A_{frcc} = \pi (R_{frcc} + r_{frcc}) \sqrt{(R_{frcc} - r_{frcc})^2 + h_{frcc}^2}$$

Weight of outer funnel plate:

$$w_{ofp} = \rho_{cstl} \cdot A_{frcc} \cdot t_{frcc}$$

Weight of outer funnel:

$$w_{ifunnel} = w_{gus} + w_{ofp} \quad w_{ifunnel} = 226 \text{ lbs}$$

Calculational Roundoff of Weight: $w_8 = 300 \text{ lbs}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 9 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

9. Funnel Plate:

Plate thickness: $t_{fpl} = 0.5$ in

OD of plate: $od_{fpl} = 5$ ft + 3 in

ID of plate: $id_{fpl} = 3$ ft + 8.5 in

Weight of funnel plate:

$$W_{fpl} = \rho_{cstl} \pi \frac{od_{fpl}^2 - id_{fpl}^2}{4} t_{fpl}$$

$$W_{fpl} = 222 \text{ lbs}$$

Calculational Roundoff of Weight: $W_p = 300$ lbs

10. Built-in Inner Funnel:

Thickness of inner funnel: $t_{ifp} = 0.250$ in

Top section, treat as a half of a cone:

Outside radius: $R_{ifcone} = 5$ ft + 3 in

Inside radius: $r_{ifcone} = 3$ ft + 8.5 in

Height of cone: $h_{ifcone} = 9.5$ in

Surface area of funnel:

$$A_{ifcone} = \frac{\pi (R_{ifcone} + r_{ifcone}) \sqrt{(R_{ifcone} - r_{ifcone})^2 + h_{ifcone}^2}}{2}$$

Weight of half cone:

$$W_{hcone} = \rho_{cstl} \cdot A_{ifcone} \cdot t_{ifp} \quad W_{hcone} = 249 \text{ lbs}$$

Approximate remaining sections as two right circular triangles.

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 10 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow *SR* Date 08/25/94

Length of base:

Angle: $\alpha_{if} = 30 \text{ deg}$

Radius same as ID of pipe.

$$l_{ifb} = R_{ifc} \cdot \alpha_{if}$$

Height of triangle is same as for cone.

Area of triangular sections:

$$A_{iftri} = 2 \left(\frac{1}{2} l_{ifb} h_{ifc} \right)$$

Weight of triangular section (two sections):

$$w_{iftri} = 2 \cdot (\rho_{cstl} \cdot A_{iftri} \cdot t_{ifp}) \quad w_{iftri} = 44 \text{ lbs}$$

Weight of inner funnel:

$$w_{if} = w_{hc} + w_{iftri} \quad w_{if} = 294 \text{ lbs}$$

Calculational Roundoff of Weight: $w_{10} = 350 \text{ lbs}$

11. 3/4 inch thick saddle:

Thickness of plate: $t_{34sad} = 0.750 \text{ in}$

Radius of midplane curvature:

$$r_{34sad} = 1 \text{ ft} + 10 \text{ in} + \frac{t_{34sad}}{2}$$

Total included angle of curvature: $\alpha_{34sad} = 22 \text{ deg}$

Width of saddle: $w_{i34sad} = r_{34sad} \cdot \alpha_{34sad}$

Length of saddle: $l_{sad} = 51 \text{ ft} + 2.75 \text{ in} - 1 \text{ in} - 2 \text{ in} - 3/4 \text{ in}$

Weight of 3/4 inch thick saddle plate:

$$w_{34sad} = \rho_{cstl} \cdot l_{sad} \cdot w_{i34sad} \cdot t_{34sad}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 11 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

$$W_{34sad} = 1,118 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{11} = 1,200 \text{ lbs}$

12. 1/4 thick saddle plates (2 each):

Thickness of saddle: $t_{14sad} = 0.250 \text{ in}$

Width of rolled section:

$$\text{Angle of roll: } \alpha_{14sad} = 45 \text{ deg} - \alpha_{34sad}$$

Radius of roll is same as ID of pipe.

$$W_{i_{rs14sad}} = R_{ifcone} \cdot \alpha_{14sad}$$

Width of straight section: $W_{i_{14sad}} = 2 \text{ ft} + 10.5 \text{ in}$

Weight of both sections of 1/4 inch saddles:

$$W_{14sad} = 2 \cdot [\rho_{cstl} \cdot (W_{i_{rs14sad}} + W_{i_{14sad}}) \cdot l_{sad} \cdot t_{14sad}]$$

$$W_{14sad} = 5,187 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{12} = 5,500 \text{ lbs}$

13. Saddle support plate, 1/2 inch thick (2 each):

Height: $h_{12ssp} = 8.75 \text{ in}$

Thickness of plate: $t_{12ssp} = 0.5 \text{ in}$

Weight of both plates: $W_{12ssp} = 2 \cdot (\rho_{cstl} \cdot l_{sad} \cdot h_{12ssp} \cdot t_{12ssp})$

$$W_{12ssp} = 1,518 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{13} = 1,600 \text{ lbs}$

14. Saddle support plates, 1/8 inch thick (2 each):

Width: $W_{i_{18ssp}} = 2 \text{ ft} + 6.25 \text{ in}$

Thickness of plate: $t_{18ssp} = 0.125 \text{ in}$

Weight of both plates:

$$W_{18ssp} = 2 \cdot (\rho_{cstl} \cdot l_{sad} \cdot W_{i_{18ssp}} \cdot t_{18ssp})$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 12 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow *SR* Date 08/25/94

$$W_{18ssp} = 1,312 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{14} = 1,400 \text{ lbs}$

15. Vent (1 each):

Pipe parameters:

Length: $l_{vent} = 4.5 \text{ in}$

(Reference 4, page 34-64).

Weight per foot:

$$w_{pv} = 5.79 \frac{\text{lbs}}{\text{ft}}$$

Weight of pipe section: $w_{pv} = w_{pv} \cdot l_{vent}$

Flange:

OD of flange: $od_{vf} = 3.25 \text{ in}$

ID of flange: $id_{vf} = 2 \text{ in}$

Thickness: $t_{vf} = 0.5 \text{ in}$

Weight of flange:

$$w_{vf} = \rho_{cstl} \pi \left(\frac{od_{vf}^2 - id_{vf}^2}{4} \right) t_{vf}$$

Weight of vent:

$$w_{vent} = w_{vp} + w_{vf} \quad w_{vent} = 3 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{15} = 10 \text{ lbs}$.

16. Outer shielding shell (thin section):

ID of shell: $id_{shell} = 5 \text{ ft} + 8 \text{ in}$

Thickness of shell: $t_{516sh} = 0.3125 \text{ in}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 13 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

Cross sectional area:

$$A_{516sh} = \pi \frac{(id_{shell} + t_{516sh})^2 - id_{shell}^2}{4}$$

Lengths of shells, columns 1 to 8 and 15 to 25:

$$15_1 = 9.75 \text{ in} - t_{bef}/2 - t_{sr1}/2$$

$$15_2 = (2 \text{ ft} + 10 \text{ in}) - 9.75 \text{ in} - t_{sr1}$$

$$15_3 = (4 \text{ ft} + 10.25 \text{ in}) - (2 \text{ ft} + 10 \text{ in}) - t_{sr1}$$

$$15_4 = (5 \text{ ft} + 7.750 \text{ in}) - (4 \text{ ft} + 10.25 \text{ in}) - t_{sr1}$$

$$15_5 = (8 \text{ ft} + 3.250 \text{ in}) - (5 \text{ ft} + 7.750 \text{ in}) - t_{sr1}$$

$$15_6 = (10 \text{ ft} + 10.750 \text{ in}) - (8 \text{ ft} + 3.250 \text{ in}) - t_{sr1}$$

$$15_7 = (13 \text{ ft} + 6.250 \text{ in}) - (10 \text{ ft} + 10.750 \text{ in}) - t_{sr1}$$

$$15_8 = (32 \text{ ft} + 8.250 \text{ in}) - (30 \text{ ft} + 0.750 \text{ in}) - t_{sr1}$$

$$15_9 = (35 \text{ ft} + 3.750 \text{ in}) - (32 \text{ ft} + 8.250 \text{ in}) - t_{sr1}$$

$$15_{10} = (37 \text{ ft} + 11.250 \text{ in}) - (35 \text{ ft} + 3.750 \text{ in}) - t_{sr1}$$

$$15_{11} = (40 \text{ ft} + 6.750 \text{ in}) - (37 \text{ ft} + 11.250 \text{ in}) - t_{sr1}$$

$$15_{12} = (43 \text{ ft} + 2.250 \text{ in}) - (40 \text{ ft} + 6.750 \text{ in}) - t_{sr1}$$

$$15_{13} = (45 \text{ ft} + 9.750 \text{ in}) - (43 \text{ ft} + 2.250 \text{ in}) - t_{sr1}$$

$$15_{14} = (48 \text{ ft} + 5.250 \text{ in}) - (45 \text{ ft} + 9.750 \text{ in}) - t_{sr1}$$

$$15_{15} = (49 \text{ ft} + 2.750 \text{ in}) - (48 \text{ ft} + 5.250 \text{ in}) - t_{sr1}$$

$$15_{16} = (51 \text{ ft} + 2.750 \text{ in}) - (49 \text{ ft} + 2.750 \text{ in}) - t_{sr1}$$

$$15_{17} = (52 \text{ ft} + 0.750 \text{ in}) - (51 \text{ ft} + 2.750 \text{ in}) - t_{sr1}/2 - t_{ref}/2$$

$$15_{tot} = 15_1 + 15_2 + 15_3 + 15_4 + 15_5 + 15_6 + 15_7 + 15_8 + 15_9 + 15_{10} + 15_{11} + 15_{12} + 15_{13} + 15_{14} + 15_{15} + 15_{16} + 15_{17}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 14 of 25
 Building Tank 24I-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

Weight of Thredolet and plug (Reference: H. E. Atkins, Jr, 7/18/94):

$$W_{thred} = 20.1 \text{ lbs}$$

Weight of thin outer shell:

$$W_{516sh} = (\rho_{cstl} \cdot A_{516sh} \cdot 15_{tot}) + 17 \cdot W_{thred} \quad W_{516sh} = 3,823 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{16} = 4,000 \text{ lbs}$

17. Outer shielding shell (thick section):

Thickness of shell: $t_{12sh} = 0.5 \text{ in}$

Cross sectional area:

$$A_{12sh} = \pi \frac{(id_{shell} + t_{12sh})^2 - id_{shell}^2}{4}$$

Length of shells Columns 8 to 15:

$$l1_1 = (16 \text{ ft} + 1.750 \text{ in}) - (13 \text{ ft} + 6.250 \text{ in}) - t_{sr1}$$

$$l1_2 = (18 \text{ ft} + 9.250 \text{ in}) - (16 \text{ ft} + 1.750 \text{ in}) - t_{sr1}$$

$$l1_3 = (21 \text{ ft} + 4.750 \text{ in}) - (18 \text{ ft} + 9.250 \text{ in}) - t_{sr1}$$

$$l1_4 = (24 \text{ ft} + 0.250 \text{ in}) - (21 \text{ ft} + 4.750 \text{ in}) - t_{sr1}$$

$$l1_5 = (24 \text{ ft} + 9.750 \text{ in}) - (24 \text{ ft} + 0.250 \text{ in}) - t_{sr1}$$

$$l1_6 = (27 \text{ ft} + 5.250 \text{ in}) - (24 \text{ ft} + 9.750 \text{ in}) - t_{sr1}$$

$$l1_7 = (30 \text{ ft} + 0.750 \text{ in}) - (27 \text{ ft} + 5.250 \text{ in}) - t_{sr1}$$

$$l1_{tot} = l1_1 + l1_2 + l1_3 + l1_4 + l1_5 + l1_6 + l1_7$$

Weight of thick outer shell:

$$W_{12sh} = (\rho_{cstl} \cdot A_{12sh} \cdot l1_{tot}) + 7 \cdot W_{thred} \quad W_{12sh} = 2,882 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{17} = 3,000 \text{ lbs}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 15 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

18. Shielding:

Cross sectional area:

$$A_{shsp} = \pi \frac{id_{shell}^2 - od_{pipe}^2}{4}$$

Density of lead (Reference 1, page 2269):

$$\rho_{pb} = 0.4096 \cdot \text{lbs/in}^3$$

Assume 65% density for shot (equivalent density):

$$\rho_{epb} = 0.65 \cdot \rho_{pb}$$

Weight per unit length of lead shielding:

$$w_{pbsh} = \rho_{epb} \cdot A_{shsp}$$

$$w_{pbsh} = 110 \cdot \text{lbs/in}$$

Lead weight up to Column 14:

Lead Length:

$$\text{len}_{sh1} = 15_1 + 15_2 + 15_3 + 15_4 + 15_5 + 15_6 + 15_7 + 11_1 + 11_2 + 11_3 + 11_4 + 11_5 + 11_6$$

$$\text{Weight of lead: } w_{pbsh1} = w_{pbsh} \cdot \text{len}_{sh1} \quad w_{pbsh1} = 30,859 \text{ lbs}$$

$$\text{Calculational Roundoff of Weight: } w_{18a} = 32,000 \text{ lbs}$$

Lead full length to Column 25:

$$\text{Lead length: } \text{len}_{sh2} = 15_{tot} + 11_{tot}$$

$$\text{Weight of lead: } w_{pbsh2} = w_{pbsh} \cdot \text{len}_{sh2} \quad w_{pbsh2} = 64,947 \text{ lbs}$$

$$\text{Calculational Roundoff of Weight: } w_{18b} = 66,000 \text{ lbs}$$

19. Outer Top Cap:

Flange:

$$\text{Thickness: } t_{otcf} = 2.250 \text{ in}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 16 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

OD: $od_{otcf} = 5 \text{ ft} + 11.625 \text{ in}$

ID: $id_{otcf} = 5 \text{ ft} + 5 \text{ in}$

Cross sectional area:

$$A_{otcf} = \pi \frac{od_{otcf}^2 - id_{otcf}^2}{4}$$

Weight of outer top cap flange: $w_{otcf} = \rho_{cstl} \cdot A_{otcf} \cdot t_{otcf}$

Housing:

Thickness: $t_{otch} = 0.375 \text{ in}$

Length: $l_{otch} = 2 \text{ ft} + 1.875 \text{ in}$

ID: $id_{otch} = 5 \text{ ft} + 5 \text{ in}$

OD: $od_{otch} = id_{otch} + 2 \cdot t_{otch}$

Cross sectional area:

$$A_{otch} = \pi \frac{od_{otch}^2 - id_{otch}^2}{4}$$

Weight of housing: $w_{otch} = \rho_{cstl} \cdot A_{otch} \cdot l_{otch}$

End plate:

Thickness: $t_{otcep} = 0.750 \text{ in}$

OD: $od_{otcep} = id_{otch}$

Cross sectional area:

$$A_{otcep} = \pi \frac{od_{otcep}^2}{4}$$

Weight of End plate: $w_{otcep} = \rho_{cstl} \cdot A_{otcep} \cdot t_{otcep}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 17 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Détermination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow *SC* Date 08/25/94

Weight of bolts (1 inch, 4 inch long, weight per 100): $W_{otcb100} = 162 \text{ lbs/100}$

Reference 2, page 4-146.

Number of bolts: $n_{bolt} = 32$

Weight of bolts: $W_{otcb} = n_{bolt} \cdot W_{otcb100}$

Weight of outer top cap:

$W_{otc} = W_{otcf} + W_{otch} + W_{otcep} + W_{otcb}$ $W_{otc} = 1,779 \text{ lbs}$

Calculational Roundoff of Weight: $W_{19} = 1,900 \text{ lbs}$

20. Inner Top Cap:

Flange:

Thickness: $t_{itcf} = 2.250 \text{ in}$

OD: $od_{itcf} = 5 \text{ ft} + 3 \text{ in}$

ID: $id_{itcf} = 4 \text{ ft} + 10 \text{ in}$

Cross sectional area:

$$A_{itcf} = \pi \frac{od_{itcf}^2 - id_{itcf}^2}{4}$$

Weight of flange: $w_{itcf} = \rho_{cstl} \cdot A_{itcf} \cdot t_{itcf}$

Housing:

Thickness: $t_{itch} = 0.500 \text{ in}$ Length: $l_{itch} = 1 \text{ ft} + 11.875 \text{ in}$

OD: $od_{itch} = id_{itcf}$

ID: $id_{itch} = od_{itch} - 2 \cdot t_{itch}$

Cross sectional area:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 18 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow *Sec* Date 08/25/94

$$A_{itch} = \pi \frac{od_{itch}^2 - id_{itch}^2}{4}$$

Weight of flange: $w_{itch} = \rho_{cstl} \cdot A_{itch} \cdot l_{itch}$

Retaining Ring:

Thickness: $t_{itcrr} = 0.375$ in Length: $l_{itcrr} = 2.6875$ in

ID: $id_{itcrr} = od_{itcrr}$

OD: $od_{itcrr} = id_{itcrr} + 2 \cdot t_{itcrr}$

Cross sectional area:

$$A_{itcrr} = \pi \frac{od_{itcrr}^2 - id_{itcrr}^2}{4}$$

Weight of retaining ring: $w_{itcrr} = \rho_{cstl} \cdot A_{itcrr} \cdot l_{itcrr}$

Gussets (8 each):

Thickness: $t_{itcgus} = 0.500$ in

Length: $l_{itcgus} = 7.1875$ in

Height: $h_{itcgus} = 7.0$ in

Weight of gussets: $w_{itcgus} = 8 \cdot \rho_{cstl} \cdot l_{itcgus} \cdot h_{itcgus} \cdot t_{itcgus}$

Retainer Plate:

Thickness: $t_{itcrp} = 0.500$ in

OD: $od_{itcrp} = 3 \text{ ft} + 7 \text{ in}$

ID: $id_{itcrp} = 4 \text{ ft} + 9 \text{ in}$

Cross sectional area:

Weight of retainer plate: $w_{itcrp} = \rho_{cstl} \cdot A_{itcrp} \cdot t_{itcrp}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 19 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

$$A_{itcrp} = \pi \frac{od_{itcrp}^2 - id_{itcrp}^2}{4}$$

End plate:

Thickness: $t_{itcep} = 0.750$ in

OD: $od_{itcep} = id_{itch}$

Cross sectional area:

$$A_{itcep} = \pi \frac{od_{itcep}^2}{4}$$

Weight of end plate: $W_{itcep} = \rho_{cstl} \cdot A_{itcep} \cdot t_{itcep}$

Weight of bolts (1 inch, 4 inch long, weight per 100): $W_{itcb100} = 162$ lbs/100

Reference 2, page 4-146.

Number of bolts: $n_{bolt} = 28$

Weight of bolts: $W_{itcb} = n_{bolt} \cdot W_{itcb100}$

Weight of inner top cap:

$$W_{itc} = W_{itcf} + W_{itch} + W_{itcrr} + W_{itcgus} + W_{itcrp} + W_{itcep} + W_{itcb}$$

$$W_{itc} = 1,463 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{20} = 1,500$ lbs

21. Payload weight and CG (Reference from H. E. Atkins, Jr, 7/18/94):

Weight: $W_{pay} = 19,427$ lbs

CG from bottom of outer top flange: $cg_{pay1} = 19.42$ ft

CG from bottom outer flange center is:

$$cg_{pay2} = (52 \text{ fy} + 0.750 \text{ in}) - cg_{pay1} - t_{bef}/2 \quad cg_{pay2} = 32.56 \text{ ft}$$

Calculational Roundoff of Weight: $W_{21} = 20,000$ lbs

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 20 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

Total weight of package w/o shielding:

$$W_{\text{epack}} = W_1 + 16 \cdot W_2 + 3 \cdot W_{3a} + 4 \cdot W_{3b} + W_4 + W_5 + W_6 + W_7 + W_8 + W_9 + W_{10} + W_{11} + W_{12} + W_{13} + W_{14} + W_{15} + W_{16} + W_{17} + W_{19} + W_{20}$$

$$W_{\text{epack}} = 55,435 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{\text{empty}} = 57,000 \text{ lbs}$

Total weight of package empty with shielding to Column 14:

$$W_{\text{sh1pack}} = W_{\text{epack}} + W_{18a} \quad W_{\text{sh1pack}} = 87,435 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{\text{emptysh1}} = 88,000 \text{ lbs}$

Total weight of package empty with shielding to Column 25:

$$W_{\text{sh2pack}} = W_{\text{epack}} + W_{18b} \quad W_{\text{sh2pack}} = 121,435 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{\text{emptysh2}} = 130,000 \text{ lbs}$

Total weight of loaded package no shielding:

$$W_{\text{pack}} = W_{\text{epack}} + W_{21} \quad W_{\text{pack}} = 75,435 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{\text{fpack}} = 76,000 \text{ lbs}$

Total weight of loaded package shielded up to Column 14:

$$W_{\text{packsh1}} = W_{\text{pack}} + W_{18a} \quad W_{\text{packsh1}} = 107,435 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{\text{fpacksh1}} = 110,000 \text{ lbs}$

Total weight of loaded package shielded up to Column 25:

$$W_{\text{packsh2}} = W_{\text{pack}} + W_{18b} \quad W_{\text{packsh2}} = 141,435 \text{ lbs}$$

Calculational Roundoff of Weight: $W_{\text{fpacksh2}} = 145,000 \text{ lbs}$

Approximate CG calculations of package:

From center of bottom outer flange.

Package weight without top caps, shielding or rings:

$$W_{\text{base}} = W_1 + W_6 + W_7 + W_9 + W_{10} + W_{11} + W_{12} + W_{13} + W_{14} + W_{15} + W_{16} + W_{17}$$

$$W_{\text{base}} = 37,760 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 21 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

Calculational Roundoff of Weight: $W_{base1} = 39,000$ lbs

Assume CG of this portion at center of pipe from bottom:

$$CG_{base1} = l_{pipe}/2 + t_{bef}/2 \quad CG_{base1} = 26.11 \text{ ft}$$

CG of stiffener rings:

Reference is from center of bottom end flange.

$l_{sr1} = 0$ in	$l_{sr14} = 27$ ft + 5.250 in
$l_{sr2} = 9.750$ in	$l_{sr15} = 30$ ft + 0.750 in
$l_{sr3} = 2$ ft + 10 in	$l_{sr16} = 32$ ft + 8.25 in
$l_{sr4} = 4$ ft + 10.250 in	$l_{sr17} = 35$ ft + 3.750 in
$l_{sr5} = 5$ ft + 7.750 in	$l_{sr18} = 37$ ft + 11.250 in
$l_{sr6} = 8$ ft + 3.25 in	$l_{sr19} = 40$ ft + 6.750 in
$l_{sr7} = 10$ ft + 10.750 in	$l_{sr20} = 43$ ft + 2.25 in
$l_{sr8} = 13$ ft + 6.25 in	$l_{sr21} = 45$ ft + 9.750 in
$l_{sr9} = 16$ ft + 1.750 in	$l_{sr22} = 48$ ft + 5.25 in
$l_{sr10} = 18$ ft + 9.25 in	$l_{sr23} = 49$ ft + 2.750 in
$l_{sr11} = 21$ ft + 4.750 in	$l_{sr24} = 51$ ft + 2.750 in
$l_{sr12} = 24$ ft + 0.250 in	$l_{sr25} = 52$ ft + 0.750 in
$l_{sr13} = 24$ ft + 9.750 in	

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 22 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

$$\begin{aligned}
 &W_4 l_{sr1} + W_{3a} l_{sr2} + W_2 l_{sr3} + W_{3b} l_{sr4} + W_{3b} l_{sr5} \\
 &+ W_2 l_{sr6} + W_2 l_{sr7} + W_2 l_{sr8} + W_2 l_{sr9} + W_2 l_{sr10} \\
 &+ W_2 l_{sr11} + W_{3a} l_{sr12} + W_{3a} l_{sr13} + W_2 l_{sr14} + W_2 l_{sr15} \\
 &+ W_2 l_{sr16} + W_2 l_{sr17} + W_2 l_{sr18} + W_2 l_{sr19} + W_2 l_{sr20} \\
 &+ W_2 l_{sr21} + W_{3b} l_{sr22} + W_{3b} l_{sr23} + W_2 l_{sr24} + W_5 l_{sr25} \\
 CG_{sr} = &\frac{\hspace{15em}}{W_4 + W_5 + 16 W_2 + 3 W_{3a} + 4 W_{3b}}
 \end{aligned}$$

cg_{sr} = 21.94 ft

CG of shielding materials for shielding up to Column 14:

Assume concentrated in the center of each shell.

$$\begin{aligned}
 d_1 &= l_{sr2} - 15_1/2 - t_{sr1}/2 & d_8 &= l_{sr9} - 11_1/2 - t_{sr1}/2 \\
 d_2 &= l_{sr3} - 15_2/2 - t_{sr1}/2 & d_9 &= l_{sr10} - 11_2/2 - t_{sr1}/2 \\
 d_3 &= l_{sr4} - 15_3/2 - t_{sr1}/2 & d_{10} &= l_{sr11} - 11_3/2 - t_{sr1}/2 \\
 d_4 &= l_{sr5} - 15_4/2 - t_{sr1}/2 & d_{11} &= l_{sr12} - 11_4/2 - t_{sr1}/2 \\
 d_5 &= l_{sr6} - 15_5/2 - t_{sr1}/2 & d_{12} &= l_{sr13} - 11_5/2 - t_{sr1}/2 \\
 d_6 &= l_{sr7} - 15_6/2 - t_{sr1}/2 & d_{13} &= l_{sr14} - 11_6/2 - t_{sr1}/2 \\
 d_7 &= l_{sr8} - 15_7/2 - t_{sr1}/2 & &
 \end{aligned}$$

$$\begin{aligned}
 &(d_1 15_1 + d_2 15_2 + d_3 15_3 + d_4 15_4 + d_5 15_5 + d_6 15_6 + d_7 15_7 \\
 &+ d_8 11_1 + d_9 11_2 + d_{10} 11_3 + d_{11} 11_4 + d_{12} 11_5 + d_{13} 11_6) \\
 CG_{sh14} = &\frac{\hspace{15em}}{(15_1 + 15_2 + 15_3 + 15_4 + 15_5 + 15_6 + 15_7 + 11_1 \\
 &+ 11_2 + 11_3 + 11_4 + 11_5 + 11_6)}
 \end{aligned}$$

cg_{sh14} = 13.79 ft

CG of shielding materials for shielding up to Column 25:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 23 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

Assume concentrated in the center of each shell.

$$\begin{aligned}
 d_{14} &= l_{sr15} - l_{17}/2 - t_{sr1}/2 & d_{20} &= l_{sr21} - l_{13}/2 - t_{sr1}/2 \\
 d_{15} &= l_{sr16} - l_{15}/2 - t_{sr1}/2 & d_{21} &= l_{sr22} - l_{14}/2 - t_{sr1}/2 \\
 d_{16} &= l_{sr17} - l_{15}/2 - t_{sr1}/2 & d_{22} &= l_{sr23} - l_{15}/2 - t_{sr1}/2 \\
 d_{17} &= l_{sr18} - l_{10}/2 - t_{sr1}/2 & d_{23} &= l_{sr24} - l_{16}/2 - t_{sr1}/2 \\
 d_{18} &= l_{sr19} - l_{11}/2 - t_{sr1}/2 & d_{24} &= l_{sr25} - l_{17}/2 - t_{tef}/2 \\
 d_{19} &= l_{sr20} - l_{12}/2 - t_{sr1}/2
 \end{aligned}$$

$$\begin{aligned}
 & d_1 l_{15_1} + d_2 l_{15_2} + d_3 l_{15_3} + d_4 l_{15_4} + d_5 l_{15_5} + d_6 l_{15_6} + d_7 l_{15_7} \\
 & + d_8 l_{11_1} + d_9 l_{11_2} + d_{10} l_{11_3} + d_{11} l_{11_4} + d_{12} l_{11_5} + d_{13} l_{11_6} \\
 & + d_{14} l_{11_7} + d_{15} l_{15_8} + d_{16} l_{15_9} + d_{17} l_{15_{10}} + d_{18} l_{15_{11}} + d_{19} l_{15_{12}} \\
 & + d_{20} l_{15_{13}} + d_{21} l_{15_{14}} + d_{22} l_{15_{15}} + d_{23} l_{15_{16}} + d_{24} l_{15_{17}} \\
 cg_{sh25} &= \frac{\hspace{15em}}{l_{15_{tot}} + l_{11_{tot}}}
 \end{aligned}$$

$$cg_{sh25} = 26.04 \text{ ft}$$

CG of top caps relative to bottom of outer top flange:

Outer top cap:

$$cg_{otc} = \frac{w_{otcf} \frac{t_{otcf}}{2} + w_{otch} \left(t_{otcf} + \frac{l_{otch}}{2} \right) + w_{otcep} (t_{otcf} + l_{otch})}{W_{otc}}$$

$$cg_{otc} = 1.36 \text{ ft}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 24 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow *SR* Date 08/25/94

Inner top cap:

$$CG_{itc} = \frac{W_{itcf} \left(t_{itf} + \frac{t_{itcf}}{2} \right) + W_{itcb} \left(t_{itf} + t_{itcf} + \frac{l_{itcb}}{2} \right) + W_{itcrr} \left(t_{itf} + \frac{l_{itcrr}}{2} \right) + W_{itcgs} \left(t_{itf} + t_{itcf} + l_{itcb} - \frac{l_{itcgs}}{2} - \frac{t_{itcep}}{2} \right) + W_{itcrp} \left[\left(t_{itf} + t_{itcf} + l_{itcb} \right) - l_{itcgs} - \frac{t_{itcrp}}{2} - \frac{t_{itcep}}{2} \right] + W_{itcep} \left(t_{itf} + t_{itcf} + l_{itcb} - \frac{t_{itcep}}{2} \right)}{W_{itc}}$$

$$cg_{itc} = 1.39 \text{ ft}$$

CG of package empty with no shielding:

$$CG_{epack} = \frac{W_{base1} CG_{base1} + (W_4 + W_5 + 16 W_2 + 3 W_{3a} + 4 W_{3b}) CG_{sr} + W_{19} \left(CG_{otc} + l_{sr25} + \frac{t_{tot}}{2} \right) + W_{20} \left(CG_{itc} + l_{sr25} + \frac{t_{tot}}{e} \right)}{W_{epack}}$$

$$CG_{epack} = 27.3 \text{ ft}$$

CG of loaded package with no shielding:

$$CG_{pack} = (W_{epack} CG_{epack} + W_{pay} CG_{pay2}) / W_{pack}$$

$$CG_{pack} = 28.45 \text{ ft}$$

CG of loaded package with shielding to Column 14:

$$CG_{packsh1} = (W_{pack} CG_{pack} + W_{18a} CG_{sh14}) / W_{sh1pack}$$

$$CG_{packsh1} = 29.59 \text{ ft}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-WTCG-01 Page 25 of 25
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Weight and Center of Gravity Determination
 Originator S. S. Shiraga Date 07/29/94
 Checker S. R. Crow Date 08/25/94

CG of loaded package with shielding to Column 25:

$$CG_{\text{packsh1}} = (W_{\text{pack}} CG_{\text{pack}} + W_{18a} CG_{\text{sh25}}) / W_{\text{sh2pack}}$$

$$CG_{\text{packsh2}} = 31.83 \text{ ft}$$

CG of empty package with shielding to Column 14:

$$CG_{\text{sh1pack}} = (W_{\text{epack}} CG_{\text{epack}} + W_{18a} CG_{\text{sh14}}) / W_{\text{sh1pack}}$$

$$CG_{\text{sh1pack}} = 22.36 \text{ ft}$$

CG of empty package with shielding to Column 25:

$$CG_{\text{sh2pack}} = (W_{\text{epack}} CG_{\text{epack}} + W_{18b} CG_{\text{sh25}}) / W_{\text{sh2pack}}$$

$$CG_{\text{sh2pack}} = 26.62 \text{ ft}$$

Total impact length of package: $L_{\text{tot}} = 52 \text{ ft} + 2.750 \text{ in}$

$$L_{\text{tot}} = 626.75 \text{ in}$$

6.4.2 Determination of G Loading on 12 in. Thick Reinforced Concrete

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-GLOAD-01 Page 1 of 5
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Determination of G Loading on 12 in Thick Reinforced Concrete
 Originator S. S. Shiraga Date 07/31/94
 Checker P. M. Nguyen Date 08/09/94

I. Objectives:

The objective of this analysis is to determine the deceleration loads for various load configurations of the Hydrogen Mixer Mitigation Pump (HMMP) Package when subjected to a simulated 12 inch drop onto a flat horizontal 12 inch thick reinforced concrete slab per Reference 1.

II. References:

1. WHC-SD-TP-PDC-019, "Packaging Design Criteria Transfer and Disposal of Hydrogen Mixer Pump".
2. WHC, Engineering Change Notice 606676, dated June 27, 1994.
3. US-NRC, 10 CFR Part 71, "Packaging and Transportation of Radioactive Materials".
4. EPRI, Electric Power Research Institute, EPRI NP-4830, "The Effect of Target Hardness on the Structural Design of Concrete Storage Pads for Spent Fuel Casks", October 1986.
5. ACI, American Concrete Institute, Manual of Concrete Practice 1989, Part III.
6. WHC, Drawing No. H-2-83734, "Hydrogen Mixer Pump Storage Container".

III. Results and Conclusions:

As stated in Reference 1, to show structural integrity of the package, an simulated analytical drop of the package onto a 12 inch thick reinforced concrete pad is to be performed. Although not consistent with Reference 2, this criterion simulates the condition which exist on the site boundary for on-site transfers. The deceleration load parameters for simulating the drop were determined by using the methodology established in Reference 4. The use of this methodology is justified on the basis that the container is similar in construction to a spent fuel container. The package similar to a spent fuel container is constructed of steel with a relative overall hardness greater than concrete.

Based upon the methodology outlined in Reference 4, the results show the deceleration loading factors for various load conditions as:

1. Package loaded without shielding: $g_{dec} = 33.4$
2. Package loaded and partially shielded: $g_{dec} = 32.3$
3. Package loaded and fully shielded: $g_{dec} = 25.3$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-GLOAD-01 Page 2 of 5
Building Tank 241-SY-101 Rev. 0 Job No. _____
Subject Determination of G Loading on 12 in Thick Reinforced Concrete
Originator S. S. Shiraga Date 07/31/94
Checker P. M. Nguyen Date 08/09/94

The results are used in subsequent drop evaluations. The three configurations were chosen to parametrically determined the largest loads on the package and various critical components. This required since the deceleration loads are inversely dependent on the weight. In part, this is due to the methodology which accounts for the impact energy absorbed by the concrete as it fails under impact. The heavier and stiffer the package the more the concrete fails which absorbs more energy of impact, thereby decreasing the deceleration loading on the package.

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-GLOAD-01 Page 3 of 5
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Determination of G Loading on 12 in Thick Reinforced Concrete
 Originator S. S. Shiraga Date 07/31/94
 Checker P. M. Nguyen Date 08/09/94

IV. Engineering Evaluation:

Calculational assumptions based on EPRI Document (Reference 4):

Assumptions:

Concrete thickness: $h = 12$ in

Cover rebar: $c = 2$

Concrete strength: $f_c = 4,000$ psi

Soil Modulus of Elasticity: $E_s = 25 \times 10^3$ psi

$S_y = 60 \times 10^3$ psi

For normal weight concrete (Reference 5, page 318/318R-83), concrete modulus of elasticity:

$$E_c = (57,000 f_c^{0.5}) \text{ psi}^{0.5}$$

This forced to have psi units, since the constant 57,000 has built in $\text{psi}^{0.5}$ units.

$$E_c = 3.6 \times 10^6 \text{ psi}$$

#9 rebar (Reference 5, Table B.1, Part III)

$$A_9 = [\pi (1.13 \text{ in})^2]/4$$

Package length (Reference 6): $L = 52 \text{ ft} + 2.750 \text{ in}$

Weight of packages:

W_{pack}
76,000 lbs
110,000 lbs
145,000 lbs

Width of footprint: $d = 10$ in

For a side drop:

$$a = (A_9 S_y)/(0.85 F_c h) \quad I_c = (L h^3)/12$$

Ultimate moment capacity of the concrete slab:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-GLOAD-01 Page 4 of 5
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Determination of G Loading on 12 in Thick Reinforced Concrete
 Originator S. S. Shiraga Date 07/31/94
 Checker P. M. Nguyen Date 08/09/94

$$M_u = A_g S_y (d - a/2)$$

$$M_u = 557,353 \text{ lbs in}$$

$$\beta = \left(\frac{E_s}{4 E_c I_c} \right)^{\frac{1}{4}} \quad \beta = 0.012 \text{ in}^{-1}$$

Foot print area: $A = L d$

Target hardness number:

$$S_n = \frac{2 A E_s M_u f_c}{(W_{pack})^3 \beta}$$

S_n
135,187
44,586
19,466

Curve Fit of Data for Interpolation (Reference 4):

Cask G loading from EPRI data at 12 inches:

x_i	y_i
200	5
12,900	21
25,800	28
86,000	32.5
218,000	42
400,000	50

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-GLOAD-01 Page 5 of 5
Building Tank 241-SY-101 Rev. 0 Job No. _____
Subject Determination of G Loading on 12 in Thick Reinforced Concrete
Originator S. S. Shiraga Date 07/31/94
Checker P. M. Nguyen *PUN* Date 08/09/94

G loadings from curve interpolation at 12 inches:

g_{12}
33.41
32.34
25.3

6.4.3 Pressure Increase and Decrease Evaluation

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-PRES-01 Page 1 of 11
Building Tank 241-SY-101 Rev. 0 Job No. _____
Subject Pressure Increase and Decrease Evaluation
Originator S. S. Shiraga *S.S. Shiraga* Date 08/01/94
Checker S. R. Crow *S.R. Crow* Date 08/15/94

I. Objectives:

The objective of this evaluation is to evaluate the pressurization of the package as required in Reference 1.

II. References:

1. WHC-SD-TP-PDC-019, Rev. 0, "Packaging Design Criteria Transfer and Disposal of Hydrogen Mitigation Mixer Pump".
2. ASME, American Society of Mechanical Engineers, Boiler and Pressure Vessels. Section VIII, Division 2, 1989.
3. WHC, Drawing No. H-2-83734, "Hydrogen Mixer Pump Storage Container".
4. Roark, Formulas for Stress and Strain, 4th Edition.

III. Results and Conclusions:

Per Reference 1, this evaluation is to consider increased external pressure of the package of 20 psi and decreased external pressure of 3.5 psi. The largest pressure differential results from decreased external pressure. Only the largest pressure differential of 11.2 psi which is the decrease in external pressure is evaluated herein, since it is the worst case loading. The inner top cap and the 2 inch thick inner blind flange at the bottom end are considered as the primary containment boundaries.

The results show that the package design is adequate to withstand the pressure differentials specified in Reference 1. Also the results are used in conjunction with drop evaluation to determine performance under combined loading.

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-PRES-01 Page 2 of 11
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Pressure Increase and Decrease Evaluation
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow *Sec* Date 08/15/94


IV. Engineering Evaluation:Pressure Change Evaluation Inner Blind Flange:

Figure 1

Modulus of Elasticity (Reference 2): $E_{cstl} = 29.26 \times 10^6$

Poisson's ratio (Reference 2): $\nu_{cstl} = 0.3$

Containment boundary pipe ID: $id_p = 5 \text{ ft} + 3 \text{ in}$

Pipe outside radius: $R_p = id_p/2$

Wall thickness: $t_p = 0.500 \text{ in}$

ASME allowable at temperature: $s_a = 23,270 \text{ psi}$

Per Reference 2, page 513, for allowable bending and discontinuity stresses:

$$1.5 s_a = 34,905 \text{ psi}$$

Flange thickness: $t_f = 2.00 \text{ in}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-PRES-01 Page 3 of 11
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Pressure Increase and Decrease Evaluation
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/15/94

Rigidity Factors (Reference 4, page 298):

Flange:

$$D_f = \frac{E_{cstl} t_f^3}{12 (1 - \nu_{cstl}^2)}$$

Pipe:

$$D_p = \frac{E_{cstl} t_p^3}{12 (1 - \nu_{cstl}^2)}$$

$$\lambda_p = \left(3 \frac{1 - \nu_{cstl}^2}{R_p^2 t_p^2} \right)^{\frac{1}{4}}$$

Container mid section stress (Reference 4, page 298, Case 1):

Evaluate for worst case: reduction in external pressure (Reference 1):

$$P_{red} = 11.2 \text{ psi}$$

Meridional stress:

$$s_1 = (P_{red} R_p) / 2(t_p) \quad s_1 = 353 \text{ psi}$$

Hoop stress:

$$s_2 = (P_{red} R_p) / t_p \quad s_2 = 706 \text{ psi}$$

Total stress:

$$s_{tot} = s_1 + s_2 \quad s_{tot} = 1,058 \text{ psi}$$

Margin of Safety:

$$MS_{mid} = \frac{s_a}{s_{tot}} - 1$$

$$MS_{mid} = 21$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-PRES-01 Page 4 of 11
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Pressure Increase and Decrease Evaluation
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/15/94

Package end discontinuity stress (Reference 4, page 307, Case 30):

Discontinuity moment at joint:

$$M_o = \frac{\frac{P_{red} R_p^3 \lambda_p^2 D_p}{4 D_f (1 + \nu_{cstl})} + \frac{2 P_{red} R_p^2 \lambda_p^3 E_{cstl} t_f D_p}{E_{cstl} t_p \left(1 - \frac{1}{2} \nu_{cstl}\right) [E_{cstl} t_f + 2 R_p D_p \lambda_p^3 (1 - \nu_{cstl})]}}{2 \lambda_p + \frac{2 R_p \lambda_p^2 D_p}{D_f (1 + \nu_{cstl})} - \frac{\lambda_p E_{cstl} t_f}{E_{cstl} t_f + 2 D_p \lambda_p^3 R_p (1 - \nu_{cstl})}}$$

$$M_o = 321.4 \text{ lbs}$$

Discontinuity radial shear at joint:

$$V_o = M_o \left[2 \lambda_p + \frac{2 R_p \lambda_p^2 D_p}{D_f (1 + \nu_{cstl})} \right] - \frac{P_{red} R_p^3 \lambda_p^2 D_p}{4 D_f (1 + \nu_{cstl})}$$

$$V_o = 123 \text{ lbs/in}$$

Stress in pipe at joint:

Hoop stresses:

$$S_{hbmax} = \frac{2 M_o}{t_p} \lambda_p^2 R_p$$

$$S_{hbmax} = 4,248 \text{ psi}$$

$$S_{hsmax} = \frac{-2 V_o}{t_p} \lambda_p R_p$$

$$S_{hsmax} = -5,035 \text{ psi}$$

Total hoop stress:

$$S_{thmax} = S_{hbmax} + S_{hsmax} + S_2$$

$$S_{thmax} = -81 \text{ psi}$$

Meridional stress: $S_{mbmax} = (6 M_o)/t_p^2$ $S_{mbmax} = 7,714 \text{ psi}$

$$S_{msmax} = (1.932 V_o)/(\lambda_p t_p^2) \quad S_{msmax} = 2,944 \text{ psi}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-PRES-01 Page 5 of 11
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Pressure Increase and Decrease Evaluation
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/15/94

Total Meridional stress:

$$s_{tmax} = s_{mbmax} + s_{msmax} + s_1 \quad s_{tmax} = 11,010 \text{ psi}$$

Total stress on pipe at discontinuity:

$$s_{btot} = s_{tmax} + s_{thmax} \quad s_{btot} = 10,929 \text{ psi}$$

Margin of Safety:

$$MS_1 = (1.5 s_o / s_{btot}) - 1 \quad MS_1 = 2.19 \quad \text{OK}$$

Package inner blind flange stress (Reference 4, page 307, Case 30):

Flange Pressure Loading: $W_o = P_{red} \pi R_p^2 \quad W_o = 34,913 \text{ lbs}$

Model flange as flat plate with diameter of pipe, which is simply supported using small deflection theory.

Inverse of Poisson's Ratio: $m = 1/\nu_{cstl}$

Maximum radial stress from pressure at center of flange:

$$s_{fr} = \frac{3 W_o}{8 \pi m t_f^2} (3 m + 1)$$

$$s_{fr} = 3,438 \text{ psi}$$

Maximum radial stress from moment at center of flange:

$$s_{fmr} = \frac{6 M_o}{t_f^2}$$

$$s_{fmr} = 482 \text{ psi}$$

Shear stress:

$$s_s = V_o / t_f \quad s_s = 62 \text{ psi}$$

Total flange stress:

$$s_{ftot} = s_{fr} + s_{fmr} + s_s \quad s_{ftot} = 3,982 \text{ psi}$$

Margin of Safety:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-PRES-01 Page 6 of 11
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Pressure Increase and Decrease Evaluation
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/15/94

$MS_2 = (1.5 s_a / s_{ftot}) - 1$ $MS_2 = 7.77$ OK

Pressure Change Evaluation Inner Top Cap:

Since this unit is equipped with an inner top cap, evaluate inner top cap stresses.

- Top cap pipe thickness: $t_{tcp} = 0.500$ in
- Outside diameter of top cap pipe: $od_{tcp} = 4$ ft + 10 in
- Outside pipe radius: $R_{tcp} = od_{tcp} / 2$
- Flange thickness: $t_{tcf} = 0.750$ in
- Flange radius: $R_{tcf} = (od_{tcp} - 2 t_{tcp}) / 2$
- Rigidity Factors (Reference 4, page 298):

Flange:

$$D_1 = \frac{E_{cstl} t_{tcf}^3}{12 (1 - \nu_{cstl}^2)}$$

Pipe:

$$D_2 = \frac{E_{cstl} t_{tcp}^3}{12 (1 - \nu_{cstl}^2)}$$

$$\lambda_2 = \left(3 \frac{1 - \nu_{cstl}^2}{R_{tcp}^2 t_{tcp}^2} \right)^{\frac{1}{4}}$$

Container mid section stress (Reference 4, page 298, Case 1):

Evaluate for worst case: reduction in external pressure (Reference 1):

$P_{red} = 11.2$ psi

Meridional stress:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-PRES-01 Page 7 of 11
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Pressure Increase and Decrease Evaluation
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/15/94

$$s_{1tcp} = (P_{red} R_{tcp}) / (2 t_{tcp}) \quad s_{1tcp} = 325 \text{ psi}$$

Hoop stress:

$$s_{2tcp} = (P_{red} R_{tcp}) / t_{tcp} \quad s_{2tcp} = 650 \text{ psi}$$

Top cap end discontinuity stress (Reference 4, page 307, Case 30):

Discontinuity moment at joint:

$$M_{tco} = \frac{\frac{P_{red} R_{tcp}^3 \lambda_2^2 D_2}{4 D_1 (1 + \nu_{cstl})} + \frac{2 P_{red} R_{tcp}^2 \lambda_2^3 E_{cstl} t_{tcp} D_2}{E_{cstl} t_{tcp} \left(1 - \frac{1}{2} \nu_{cstl}\right) \left[E_{cstl} t_{tcp} + 2 R_{tcp} D_2 \lambda_2^3 (1 - \nu_{cstl})\right]}}{2 \lambda_2 + \frac{2 R_{tcp} \lambda_2^2 D_2}{D_1 (1 + \nu_{cstl})} - \frac{\lambda_2 E_{cstl} t_{tcp}}{E_{cstl} t_{tcp} + 2 D_2 \lambda_2^3 R_{tcp} (1 - \nu_{cstl})}}$$

$$M_{tco} = 968 \text{ lbs}$$

Discontinuity radial shear at joint:

$$V_{tco} = M_{tco} \left[2 \lambda_2 + \frac{2 R_{tcp} \lambda_2^2 D_2}{D_1 (1 + \nu_{cstl})} \right] - \frac{P_{red} R_{tcp}^3 \lambda_2^2 D_2}{4 D_1 (1 + \nu_{cstl})}$$

$$V_{tco} = 338 \text{ lbs/in}$$

Stress in pipe at joint:

Hoop stresses:

$$s_{htcbmax} = \frac{2 M_{tco}}{t_{tcp}} \cdot \lambda_2^2 R_{tcp}$$

$$s_{htbmax} = 12,796 \text{ psi}$$

$$s_{htsmax} = \frac{-2 V_{tco}}{t_{tcp}} \lambda_2 R_{tcp}$$

$$s_{htsmax} = -13,245 \text{ psi}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-PRES-01 Page 8 of 11
 Building Tank-241-SY-101 Rev. 0 Job No. _____
 Subject Pressure Increase and Decrease Evaluation
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow *SR* Date 08/15/94

Total hoop stress:

$$S_{tthmax} = S_{htbmax} + S_{htsmax} + S_{2tcp} \quad S_{tthmax} = 201 \text{ psi}$$

Meridional stress:

$$S_{mtbmax} = (6 M_{tco})/t_{tcp}^2 \quad S_{mtbmax} = 23,234 \text{ psi}$$

$$S_{mtsmax} = (1.932 V_o)/\lambda_p t_p^2 \quad S_{mtsmax} = 2,944 \text{ psi}$$

Total meridional stress:

$$S_{ttmax} = S_{mtbmax} + S_{mtsmax} + S_{1tcp} + S_{ttmax} = 26,502 \text{ psi}$$

Total stress on pipe at discontinuity:

$$S_{bttot} = S_{ttmax} + S_{tthmax} \quad S_{bttot} = 26,703 \text{ psi}$$

Margin of Safety:

$$MS_1 = (1.5 s_o/s_{bttot}) - 1 \quad MS_1 = 0.31 \quad \text{OK}$$

Package bottom flange stress (Reference 4, page 307, Case 30):

Flange Pressure Loading: $W_{tco} = P_{red} \pi R_{tcp}^2 \quad W_{tco} = 29,591 \text{ lbs}$

Model flange as flat plate with diameter of pipe, which is simply supported using small deflection theory.

Inverse of Poisson's Ratio: $m = 1/\nu_{cstl}$

Maximum radial stress from pressure at center of flange:

$$S_{ftcr} = \frac{3 W_{tco}}{8 \pi m t_{tcf}^2} (3 m + 1)$$

$$S_{ftcr} = 20,722 \text{ psi}$$

Maximum radial stress from moment at center of flange:

$$S_{ftcmr} = \frac{6 M_{tco}}{t_{tcf}^2}$$

$$S_{ftcmr} = 10,326 \text{ psi}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-PRES-01 Page 9 of 11
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Pressure Increase and Decrease Evaluation
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/15/94

Shear stress:

$$s_{tcs} = V_{tco} / t_{tcf} \quad s_{tcs} = 451 \text{ psi}$$

Total flange stress:

$$s_{fttot} = s_{ftcr} + s_{ftcmr} + s_{tcs} \quad s_{fttot} = 31,499 \text{ psi}$$

Margin of Safety:

$$MS_2 = (1.5 s_a / s_{fttot}) - 1 \quad MS_2 = 0.11 \quad \text{OK}$$

Inner top cap flange/pipe junction stress calculations:




Figure 2

Model as Roark Case 32, flanged and bolted pipe.

Resultant bolt tension from preload (ASME Evaluation):

$$W_{bolt} = 19,969 \text{ lbs}$$

OD of pipe: $od_{tcp} = 4 \text{ ft} + 10 \text{ in}$

ID of pipe: $id_{tcp} = od_{tcp} - 2(t_{tcp})$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-PRES-01 Page 10 of 11
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Pressure Increase and Decrease Evaluation
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow *SR* Date 08/15/94

OD of Flange: $od_{tcf} = 5 \text{ ft} + 3 \text{ in}$

Flange thickness: $h_{tcf} = 2.25 \text{ in}$

Bolt circle diameter: $bc = 5 \text{ ft} + 1 \text{ in}$

Dimensional factors:

$$f = \sqrt{id_{tcp} t_{tcp}} \quad T_1 = \frac{t_{tcp}^3 (3 id_{tcp}^2 + 5 od_{tcf}^2)}{h_{tcf}^3 (od_{tcf}^2 - id_{tcp}^2)}$$

$$T_2 = \frac{3.58 t_{tcp}^3}{h_{tcf}^3 (od_{tcf}^2 - id_{tcp}^2)} \left[\frac{od_{tcf}^2}{3} \ln\left(\frac{bc}{id_{tcp}}\right) + 0.1 (bc^2 - id_{tcp}^2) \right]$$

Radial Shear:

$$V_{otc} = \frac{\left(f^2 - \frac{h_{tcf}^3}{t_{tcp}} T_1 \right) (t_{tcp} + 0.2325 f T_1) P_{red} - 2 T_2 (h_{tcf} + 0.5377 f) W_{bolt}}{1.860 f t_{tcp} + T_1 \left[h_{tcf}^2 \left(2 + 0.1160 \frac{f}{t_{tcp}} T_1 \right) + 1.6103 f h_{tcf} + 0.866 f^2 \right]}$$

$$V_{otc} = -43 \text{ lbs/in}$$

Moment:

$$M_{otc} = \frac{(h_{tcf}^2 T_1 + 1.86 f t_{tcp}) V_{otc} + h_{tcf} T_2 W_{bolt} - 0.5 t_{tcp} P_{red} \left(f^2 - \frac{h_{tcf}^3}{2 t_{tcp}} T_1 \right)}{1.5 T_1 h_{tcf} - 3.464 t_{tcp}}$$

$$M_{otc} = 190 \text{ lbs}$$

Longitudinal bending stress in pipe:

$$s'_{tcp1} = \frac{6 M_{otc}}{t_{tcp}^2}$$

$$s'_{tcp1} = 4,549 \text{ psi}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-PRES-01 Page 11 of 11
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Pressure Increase and Decrease Evaluation
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/15/94

Longitudinal direct stress in pipe:

$$s_{tcp1} = \frac{W_{bolt} + P_{red} \pi \left(\frac{1}{2} id_{tcp} - \frac{1}{2} t_{tcp} \right)^2}{\pi id_{tcp} t_{tcp}}$$

$$s_{tcp1} = 537 \text{ psi}$$

Radial bending stress in flange:

$$s'_{tcf1} = \frac{6}{h_{tcf}^2} \left(M_{occ} - \frac{1}{2} V_{occ} h_{tcf} \right)$$

$$s'_{tcf1} = 282 \text{ psi}$$

Radial direct stress in flange:

$$s_{tcf1} = (V_o/h_{tcf}) + P_{red} \quad s_{tcf1} = 66 \text{ psi}$$

$$s'_{tcf2} = s'_{tcf1} + \frac{0.80}{h_{tcf}^2 (od_{tcf}^2 - id_{tcp}^2)} \left[od_{tcf}^2 \left(-15 M_{occ} + 7.5 h_{tcf} V_{occ} + 1.492 W_{bolt} \ln \left(\frac{bc}{id_{tcp}} \right) \right) + 0.4475 W_{bolt} (bc^2 - id_{tcp}^2) \right]$$

$$s'_{tcf2} = -138 \text{ psi}$$

Tangential hoop stress in flange:

$$s_{tcf2} = [h_{tcf}^2 / (4 t_{tcp}^3)] T_1 (V_o + h_{tcf} P_{red}) \quad s_{tcf2} = 679 \text{ psi}$$

Total stress in pipe:

$$s_{pipe} = s_{tcp1} + s'_{tcf1} \quad s_{pipe} = 5,086 \text{ psi}$$

Total stress in flange:

$$s_{flange} = s_{tcf1} + s'_{tcf1} + s_{tcf2} + s'_{tcf2} \quad s_{flange} = 888 \text{ psi}$$

Pipe Margin of Safety:

$$MS_{pipe} = (1.5 s_o / s_{pipe}) - 1 \quad MS_{pipe} = 6 \quad \text{OK}$$

Flange Margin of Safety:

$$MS_{flange} = (1.5 s_o / s_{flange}) - 1 \quad MS_{flange} = 38 \quad \text{OK}$$

6.4.4 ASME Design and Bolt Engagement Verification

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-ASME-01 Page 1 of 9
Building Tank 241-SY-101 Rev. _____ Job No. _____
Subject ASME Design and Bolt Engagement Verification
Originator S. S. Shiraga Date 08/01/94
Checker P. M. Nguyen Date 08/08/94

I. Objectives:

The objective of this evaluation is to verify the package bolts and flange design loads are in accordance with Reference 2. Also the thread engagement of the inner top cap closure flange is evaluated to insure proper strength of flange material with respect to bolting material. The outer top cap loading is not evaluated since it is not considered a containment boundary for transportation.

II. References:

1. WHC-SD-TP-019, Rev. 0, "Packaging Design Criteria Transfer and Disposal of Hydrogen Mixer Pump".
2. ASME, American Society of Mechanical Engineers, Boiler and Pressure Vessels, Section VIII, Division 2, 1989.
3. Industrial Press, Machinery's Handbook, 20rd Edition.
4. WHC, Drawing No. H-2-83734, "Hydrogen Mixer Pump Storage Container".
5. Flexicarb Product Specification.
6. ASTM, American Society for Testing and Materials, ASTM A307, 1989.

III. Results and Conclusions:

The results of this engineering evaluation, independently verifies that the design is adequate to withstand the pressure loads specified in Reference 1 by meeting the requirements of Reference 2. Also, the specified thread engagement is sufficient to provide a flange strength equivalent to the bolt strength, which insures the bolts will not pull away from the material. Bolt stress values are also used in conjunction with drop evaluations.

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-ASME-01 Page 2 of 9
 Building Tank 241-SY-101 Rev. _____ Job No. _____
 Subject ASME Design and Bolt Engagement Verification
 Originator S. S. Shiraga Date 08/01/94
 Checker P. M. Nguyen *PMN* Date 08/08/94

IV. Engineering Evaluation:

ASME Section VIII, Division 2, Verification and Data:

Determination of pipe material allowables and parameters at temperature, Reference 2, Tbl. ACS-1, page 77.

$$s_a = \left[23300 + \frac{(23.1 - 23.3) \cdot 10^3}{(200 - 100)} (115 - 100) \right] \text{ psi}$$

$$s_a = 23,270 \text{ psi}$$

Allowable for bending and discontinuity stresses (Reference 2, page 513):

$$s_{a1} = 1.5 s_a \quad s_{a1} = 34,905 \text{ psi}$$

Modulus of Elasticity at temperature, Reference 3, page 70.

$$E_{cstl} = \left[28.8 \cdot 10^6 + \left[\left(\frac{28.8 - 29.5}{200 - 70} \right) (115 - 200) \cdot 10^6 \right] \right] \text{ psi}$$

$$E_{cstl} = 2.93 \times 10^7 \text{ psi}$$

Poisson's ratio with no cyclic loading based on yield, (Reference 2, page 516):

$$s_{yb} = 38,000 \text{ psi} \quad s_{ab} = 38,000 \text{ psi}$$

$$v_{cstl} = 0.5 - 0.2(s_{yb}/s_{ab}) \quad v_{cstl} = 0.3$$

Design pressure: $p_{des} = 11.2 \text{ psi}$

Allowable tensile on bolting material: $s_{ab} = 55,000 \text{ psi}$

Bolt Loading (Reference 2, Section 3-320, page 488):

Gasket factor from Reference 5:

$$m = 2 \quad y = 1,000 \text{ psi}$$

Inner flange gasket outer diameter: $od_{gas} = 4 \text{ ft} + 11.750 \text{ in}$

Inner flange gasket inner diameter: $id_{gas} = 4 \text{ ft} + 7.750 \text{ in}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-ASME-01 Page 3 of 9
 Building Tank 241-SY-101 Rev. _____ Job No. _____
 Subject ASME Design and Bolt Engagement Verification
 Originator S. S. Shiraga Date 08/01/94
 Checker P. M. Nguyen *PMN* Date 08/08/94

Inner flange gasket seat diameter: $id_{itf} = 4 \text{ ft} + 10 \text{ in}$

$$N = (od_{gas} - id_{itf})/2 \text{ in}$$

Basic gasket seating width: $b_o = N/2$

Since gasket seating width $> 1/4$, effective gasket seating is:

$$b = \frac{\sqrt{b_o}}{2} \text{ in}$$

With $b_o > 1/4$, diameter at location of gasket reaction is:

$$G = od_{gas} - 2(b) \quad G = 59.09 \text{ in}$$

Total hydrostatic end force:

$$H = 0.785 G^2 p_{des} \quad H = 30,697 \text{ lbs}$$

Total joint surface compression load:

$$H_p = 2 b (3.14) G m p_{des} \quad H_p = 2,749 \text{ lbs}$$

Required bolt load (internal pressure):

$$W_{m1} = H + H_p \quad W_{m1} = 33,446 \text{ lbs}$$

Total bolt load required for gasket sealing:

$$W_{m2} = (3.14) b G y \quad W_{m2} = 61,361 \text{ lbs}$$

Since $W_{m1} < W_{m2}$ Gasket seating governs for determining bolt torque.

Bolt diameter: $d_{bolt} = 1 \text{ in}$ Number of bolts: $n_{bolt} = 28$

Threads per inch: $n_{th} = 8/\text{in}$

Load per bolt for gasket seating:

$$W_{bolt} = W_{m2}/n_{bolt} \quad W_{bolt} = 2,191 \text{ lbs}$$

Assume a torquing coefficient of: $K_{coef} = 0.2$

Required tightening torque to seat gasket:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-ASME-01 Page 4 of 9
 Building Tank 241-SY-101 Rev. _____ Job No. _____
 Subject ASME Design and Bolt Engagement Verification
 Originator S. S. Shiraga Date 08/01/94
 Checker P. M. Nguyen Date 08/08/94

$$T_{req} = K_{coef} W_{bolt} d_{bolt} \quad T_{req} = 37 \text{ ft-lbs}$$

Specified bolt torque, Reference 4: $T_{prel} = 310 \text{ ft-lbs}$

Therefore gasket adequately seated and sealed.

Bolt loading:

Preload on bolts: $W_{act} = T_{prel} / (K_{coef} d_{bolt}) \quad W_{act} = 18,600 \text{ lbs}$

Hydrostatic load per bolt: $h_{hyro} = H/28 \quad h_{hyro} = 1,096 \text{ lbs}$

Total load per bolt: $W_{btot} \approx W_{act} + h_{hyro} \quad W_{btot} = 19,696 \text{ lbs}$

Tensile stress in area of bolts, Reference 6:

$$A_b = 0.7845 \left(d_{bolt} - \frac{0.9473}{n_{th}} \right)^2$$

Total stress per bolt: $s_{bolt} = W_{btot} / A_b \quad s_{bolt} = 32,304 \text{ psi}$

Margin of Safety based on tensile:

$$MS_{bolt} = (s_{ab} / s_{bolt}) - 1 \quad MS_{bolt} = 0.7$$

Flange bolt design loads:

Internal pressure load:

$$W_{op} = W_{m1}$$

Required total bolt area:

$$A_{m2} = W_{m2} / s_{ab}$$

Gasket load:

$$W_{gsk} = \frac{(A_{m2} + A_b) s_{ab}}{2}$$

$$W_{gsk} = 47,448 \text{ lbs}$$

Flange moments from internal pressure:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-ASME-01 Page 5 of 9
 Building Tank 241-SY-101 Rev. _____ Job No. _____
 Subject ASME Design and Bolt Engagement Verification
 Originator S. S. Shiraga Date 08/01/94
 Checker P. M. Nguyen *PMN* Date 08/08/94

ID of flange: $B = id_{icf}$

Thickness of hub back of flange assumed as: $g_1 = 0.5$ in

Bolt circle diameter: $C = 5$ ft + 1 in

Radial distance from bc to intersection of hub and back of flange:

$$R_1 = [(C - B)/2] - g_1$$

Hydrostatic end force on area inside of flange:

$$H_b = 0.785 B^2 p_{des} \quad H_b = 29,576 \text{ lbs}$$

Gasket load: $H_G = W_{op} - H \quad H_G = 2,749 \text{ lbs}$

Difference between total hydrostatic end force and the end force on area inside of the flange.

$$H_T = H - H_b \quad H_T = 1,121 \text{ lbs}$$

Radial distance from the bolt circle to the circle on which H_b acts:

$$h_b = R_1 + 0.5 g_1$$

Radial distance from gasket load reaction to the bolt circle:

$$h_G = (C - G)/2$$

Radial distance from the bolt circle to the circle on which H_T acts:

$$h_T = (R_1 + g_1 + h_G)/2$$

Component of moment due to H_b :

$$M_b = H_b h_b \quad M_b = 36,970 \text{ lbs-in}$$

Component of moment due to H_G :

$$M_G = H_G h_G \quad M_G = 2,627 \text{ lbs-in}$$

Component of moment due to H_T :

$$M_T = H_T h_T \quad M_T = 1,376 \text{ lbs-in}$$

Total moments from internal pressure:

$$M_{opress} = M_b + M_G + M_T \quad M_{opress} = 40,974 \text{ lbs-in}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-ASME-01 Page 6 of 9
 Building Tank 241-SY-101 Rev. _____ Job No. _____
 Subject ASME Design and Bolt Engagement Verification
 Originator S. S. Shiraga Date 08/01/94
 Checker P. M. Nguyen P.M.N. Date 08/08/94

Moment from gasket seating:

$$M_{ogas} = [W_{gas} (C - G)]/2 \quad M_{ogas} = 45,346 \text{ lbs-in}$$

Hub Flange Stresses (for integral type flange):

Flange thickness: $t_{fb} = 2 \text{ in}$

Hub length: $h = 0.5 \text{ in}$

Thickness of hub at small end: $g_o = 0.5 \text{ in}$

Hub factor:

$$h_o = \sqrt{B g_o}$$

Ratio of thicknesses: $(g_1/g_o) = 1$

Ratio of hub lengths: $(h/h_o) = 0.09$

From Reference 2, page 497:

Factors for integral type flanges: $F = 0.908920$ $V = 0.550103$

From Reference 2, page 499:

Hub correction factor for integral type flanges: $f = 1$

Flange OD: $A = 5 \text{ ft} + 3 \text{ in}$

Ratio of OD to ID of flange:

$$K_1 = A/B \quad K_1 = 1.09$$

From Reference 2, page 496, K Factors:

$$U = \frac{K_1^2 (1 + 8.55246 \log(K_1)) - 1}{1.36136 (K_1^2 - 1) (K_1 - 1)}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-ASME-01 Page 7 of 9
 Building Tank 241-SY-101 Rev. _____ Job No. _____
 Subject ASME Design and Bolt Engagement Verification
 Originator S. S. Shiraga Date 08/01/94
 Checker P. M. Nguyen *PMN* Date 08/08/94

$$T_1 = \frac{K_1^2 (1 + 8.55246 \log(K_1)) - 1}{[1.04720 + 1.9448 (K_1)^2] (K_1 - 1)}$$

$$d = (U/V) h_o g_o^2 \quad ec = F/h_o \quad z = (K_1^2 + 1)/(K_1^2 - 1)$$

$$L = \frac{t_{fb} ec + 1}{T_1} + \frac{t_{fb}^3}{d}$$

$$Y = \frac{1}{K_1 - 1} \left(0.66845 + 5.71690 \frac{K_1^2 \log(K_1)}{K_1^2 - 1} \right)$$

Longitudinal hub stress:

$$S_H = (f M_{ogas}) / (L g_1^2 B) \quad S_H = 3,732 \text{ psi}$$

Operation:

$$s_h = (f M_{opress}) / (L g_1^2 B) \quad s_h = 3,372 \text{ psi}$$

$$\text{Total combined stress: } H_t = S_H + s_h \quad H_t = 7,105 \text{ psi}$$

Radial flange stress:

Gasket seating:

$$S_R = \frac{(1.33 t_{fb} ec + 1) M_{ogas}}{L t_{fb}^2 B}$$

$$S_R = 338 \text{ psi}$$

Operation:

$$s_r = \frac{(1.33 t_{fb} ec + 1) M_{opress}}{L t_{fb}^2 B}$$

$$s_r = 305 \text{ psi}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-ASME-01 Page 8 of 9
 Building Tank 241-SY-101 Rev. _____ Job No. _____
 Subject ASME Design and Bolt Engagement Verification
 Originator S. S. Shiraga Date 08/01/94
 Checker P. M. Nguyen Date 08/08/94

Total combined stress: $R_t = S_r + s_r$ $R_t = 643$ psi

Tangential flange stresses:

Gasket seating:

$$S_T = \frac{Y M_{ogas}}{t_{fb}^2 B} - Z S_r$$

$$S_T = 473 \text{ psi}$$

Operation:

$$s_c = \frac{Y M_{opress}}{t_{fb}^2 B} - Z S_r$$

$$s_c = 427 \text{ psi}$$

Total combined stress: $T_t = S_T + s_c$ $T_t = 900$ psi

Allowable Design Stresses for ASTM A-516 Gr. 70, Normalized:

$$s_a = 23,270 \text{ psi}$$

$$1.5 s_a = 34,905 \text{ psi}$$

For conservatism base on combined stresses:

Paragraph (a)(1): $H_t < 1.5 s_a$ OK

Paragraph (b): $R_t < s_a$ OK

Paragraph (c): $T_t < s_a$ OK

Paragraph (d): $(H_t + R_t)/2 < s_a$ OK

Paragraph (e): Check weld size

Weld size, assume only one leg: $w_w = 0.500$ in

Weld area: $A_w = 0.707 w_w \pi B$

Shear stress on weld: $\tau_w = W_{m2}/A_w$ $\tau_w = 953$ psi

ASME allowable on weld: $s_{wa} = 0.8 s_a$ $s_{wa} = 18,616$ psi

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-ASME-01 Page 9 of 9
 Building Tank 241-SY-101 Rev. _____ Job No. _____
 Subject ASME Design and Bolt Engagement Verification
 Originator S. S. Shiraga Date 08/01/94
 Checker P. M. Nguyen Date 08/08/94

Margin of Safety:

$$MS_w = (s_w/\tau_w) - 1 \quad MS_w = 18.54 \quad \text{OK}$$

Thread Length Engagement Check:

Reference 3, page 1278, for 1-8UN x 4 Bolt:

$$K_{rmax} = 0.86 \text{ in} \quad E_{smin} = 0.92 \text{ in} \quad n_{th} = 8/\text{in}$$

Bolt effective tensile area:

$$A_t = 0.7845 [1 \text{ in} - (0.9743/n_{th})]^2$$

Required effective engagement length, since tensile strengths are approximately equal:

$$L_e = \frac{2 A_t}{(\pi K_{rmax}) \left[\frac{1}{2} + 0.57735 n_{th} (E_{smin} - K_{rmax}) \right]}$$

$$L_e = 0.58 \text{ in}$$

Actual thread engagement:

$$\text{Bolt length: } l_{bolt} = 4 \text{ in}$$

$$\text{Gasket thickness: } t_{gask} = 1/8 \text{ in}$$

$$\text{Flange thickness: } t_{itcf} = 2.25 \text{ in}$$

$$L_{act} = l_{bolt} - t_{gask} - t_{itcf} \quad L_{act} = 1.62 \text{ in}$$

Margin of Safety:

$$MS_{te} = (L_{act}/L_e) - 1 \quad MS_{te} = 1.82 \quad \text{OK}$$

6.4.5 Package Lifting Evaluation

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-LIFT-01 Page 1 of 6
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Package Lifting Evaluation
 Originator S. S. Shiraga Date 07/30/94
 Checker P. M. Nguyen Date 08/03/94

I. Objectives:

The objective of this evaluation is to determine if the structural integrity of the package remains intact during lifting.

II. References:

1. American Society of Mechanical Engineers, "Boiler and Pressure Vessels", Section VIII, Division 2, 1989.
2. American Institute of Steel Construction, Manual of Steel Construction, Ninth Edition.
3. ANSI N14.6, "American National Standard for Radioactive Materials Special Lifting Devices for Shipping Containers Weighing 10,000 lbs (4,500 kg) or More", 1993.
4. WHC, Drawing No. H-2-83734, "Hydrogen Mixer Pump Storage Container".
5. AWS, American Welding Society, AWS/ANSI D1.1, "Structural Welding Code"

III. Results and Conclusions:

The packaging cognizant engineer (S. R. Crow) has stated that the package will be horizontally lifted with a straight vertical lift using two cranes. Subsequently only a straight horizontal lifting situation is evaluated. Since perfectly straight vertical lifts are not always possible, for conservatism, the lifting of the package is modeled as a simply supported beam with concentrated load at the center of gravity. To further add conservatism, the lifting is modeled as if the package were to be lifted by the end stiffening rings. To account for acceleration loading by the lift, the g loading factor for lifting is incorporated from Reference 3.

Due to the long length of the package, the allowable material strengths for this evaluation, are derived from Reference 2 to insure buckling of the inner containment boundary or tear out of the lifting lugs do not occur. The weld allowable strength on the lifting lugs were established from Reference 5, bridge building standards to added conservatism.

Results of the analysis show that there are sufficient margins of safety to for safe lifting of the container. This is demonstrated in the evaluation by showing:

1. Localized buckling of the inner containment boundary will not occur.
2. Tear out of the lifting lugs will not occur.
3. Lifting lug welds will not fail.

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-LIFT-01 Page 2 of 6
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Package Lifting Evaluation
 Originator S. S. Shiraga Date 07/30/94
 Checker P. M. Nguyen Date 08/03/94

IV. Engineering Evaluation:

Yield Strength of material from Reference 1:

$$s_y = 38,000 \text{ psi}$$

Assume crane components are rigid and straight vertical lift.

Package parameters (Reference 4):

OD of pipe: $od_{\text{pipe}} = 64 \text{ in}$ Wall thickness: $t_{\text{pipe}} = 0.500 \text{ in}$

$$\text{ID of pipe: } id_{\text{pipe}} = od_{\text{pipe}} - 2(t_{\text{pipe}})$$

$$\text{Area: } A_{\text{pipe}} = \pi (od_{\text{pipe}}^2 - id_{\text{pipe}}^2)/4$$

$$\text{Moment of inertia: } I_{\text{pipe}} = \pi (od_{\text{pipe}}^4 - id_{\text{pipe}}^4)/64$$

Outer shell cross section (thin portion):

ID of shell: $id_{\text{sh1}} = 5 \text{ ft} + 8 \text{ in}$ Wall thickness: $t_{\text{sh1}} = 0.3125 \text{ in}$

$$\text{OD of shell: } od_{\text{sh1}} = id_{\text{sh1}} + 2(t_{\text{sh1}})$$

$$\text{Cross sectional area: } A_{\text{sh1}} = \pi (od_{\text{sh1}}^2 - id_{\text{sh1}}^2)/4$$

$$\text{Moment of inertia: } I_{\text{sh1}} = \pi (od_{\text{sh1}}^4 - id_{\text{sh1}}^4)/64$$

$$\text{Total moment of section: } I_{p1} = I_{\text{pipe}} + I_{\text{sh1}}$$

Outer shell cross section (thick portion):

ID of shell: $id_{\text{sh2}} = 5 \text{ ft} + 8 \text{ in}$ Wall thickness: $t_{\text{sh2}} = 0.500 \text{ in}$

$$\text{OD of shell: } od_{\text{sh2}} = id_{\text{sh1}} + 2(t_{\text{sh2}})$$

$$\text{Cross sectional area: } A_{\text{sh2}} = \pi (od_{\text{sh2}}^2 - id_{\text{sh2}}^2)/4$$

$$\text{Moment of inertia: } I_{\text{sh2}} = \pi (od_{\text{sh2}}^4 - id_{\text{sh2}}^4)/64$$

$$\text{Total moment of section: } I_{p2} = I_{\text{pipe}} + I_{\text{sh2}}$$

Total Length of package excluding top caps: $l_{\text{pack}} = 626.75 \text{ in}$

Weight of loaded package with full shielding: $W_{\text{pack}} = 145,000 \text{ lbs}$

CG of container from bottom end flange: $cg_{\text{pack}} = 31.83 \text{ ft} + 1 \text{ in}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-LIFT-01 Page 3 of 6
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Package Lifting Evaluation
 Originator S. S. Shiraga Date 07/30/94
 Checker P. M. Nguyen *PMN* Date 08/03/94

G loading factor for lift from (Reference 3): $g_{lift} = 1.5$

AISC allowable determination for unsupported lateral length, Reference 2:

Limiting Width to Thickness Ratio:

$$330,000 \text{ psi}/s_y = 86.84$$

Width to thickness ratio of pipe: $od_{pipe}/t_{pipe} = 128$

Since width to thickness ratio exceeds specified AISC allowables (Reference 2) not a compact section.

Therefore AISC allowable bending stress:

$$F_b = 0.60 s_y \qquad F_b = 22,800 \text{ psi}$$

Conservatively model as a simply supported beam with a concentrated load at the cg.




Figure 1

Load due to lifting: $W_{lift} = g_{lift} W_{pack}$

Length between supports is assumed as the length of the package without top caps:

$$M_{max} = [W_{lift} \text{ cg}_{pack} (l_{pack} - \text{cg}_{pack})]/l_{pack}$$

$$M_{max} = 2.7 \times 10^6 \text{ ft lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-LIFT-01 Page 4 of 6
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Package Lifting Evaluation
 Originator S. S. Shiraga Date 07/30/94
 Checker P. M. Nguyen *PMN* Date 08/03/94

Bending at cg of package:

$$\sigma_{b1} = \frac{M_{max} \frac{od_{sh1}}{2}}{I_{p1}}$$

$$\sigma_{b1} = 12,435 \text{ psi}$$

Maximum shear loading at cg:

$$P_1 = [W_{lift} (l_{pack} - cg_{pack})] / l_{pack}$$

$$P_1 = 84,602 \text{ lbs}$$

$$\tau_{max1} = (2 P_1) / A_{sh1}$$

$$\tau_{max1} = 2,523 \text{ psi}$$

Maximum total stress:

$$\sigma_{totl} = \sigma_{b1} + \tau_{max1} \quad \sigma_{totl} = 14,958 \text{ psi}$$

Margin of Safety:

$$MS_{lift} = (F_b / \sigma_{totl}) - 1 \quad MS_{lift} = 0.52 \quad \text{OK}$$

Evaluate Lifting Lug:




Figure 2

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-LIFT-01 Page 5 of 6
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Package Lifting Evaluation
 Originator S. S. Shiraga Date 07/30/94
 Checker P. M. Nguyen *PMN* Date 08/03/94

Material yield strength, (Reference 1): $s_{yl} = 36,000$ psi

AISC shear allowable (Reference 2):

$$F_v = 0.33 s_{yl} \quad F_v = 11,880 \text{ psi}$$

Load per lifting lug with entire load at cg:

$$W_{lugs1} = (W_{lift} \text{ cg}_{pack}) / l_{pack} \quad W_{lugs1} = 132,898 \text{ lbs}$$

$$W_{lugs2} = [W_{lift} (l_{pack} - \text{cg}_{pack})] / l_{pack} \quad W_{lugs2} = 84,602 \text{ lbs}$$

Largest lifting load on lug: $W_{lug} = W_{lugs1} / 2 \quad W_{lug} = 66,449 \text{ lbs}$

Shear tearout of material:

Hole material: $d_{hole} = 2.5625$ in

Lug thickness: $t_{lug} = 2.0$ in

Distance from edge: $a_{hole} = 4.75$ in - $d_{hole} / 2$

$$\tau_{tearout} = W_{lug} / (2 a_{hole} t_{lug})$$

$$\tau_{tearout} = 4,789 \text{ psi}$$

Margin of Safety:

$$MS_{lug} = F_v / \tau_{tearout} - 1 \quad MS_{lug} = 1.48 \quad \text{OK}$$

Weld evaluation:

Weld size: $w_w = 0.75$ in

For conservatism assume welds on front side only and loaded in shear.

Length of welds per side: $l_w = 1$ ft + 2.625 in

AWS allowable for welds in shear (Reference 5): $F_w = 0.4 s_{yl} \quad F_w = 14,400$ psi

Assuming fillet weld throat are of 1 inch of weld at 45°:

$$A_t = 0.707 w_w$$

Allowable load per inch of weld:

$$f_w = F_w A_t \quad f_w = 7,636 \text{ lbs/in}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-LIFT-01 Page 6 of 6
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Package Lifting Evaluation
 Originator S. S. Shiraga Date 07/30/94
 Checker P. M. Nguyen Date 08/03/94

Load on welds:

$$f_l = W_{lug} / (2 l_w) \quad f_l = 2,272 \text{ lbs/in}$$

Margin of Safety:

$$MS_w = (f_w / f_l) - 1 \quad MS_w = 2.36 \quad \text{OK}$$

6.4.6 Penetration Evaluation

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-PEN-01 Page 1 of 3
Building Tank 241-SY-101 Rev. 0 Job No. _____
Subject Penetration Evaluation
Originator S. S. Shiraga Date 07/26/94
Checker M. D. Clements Date 07/30/94

I. Objectives:

The objective of this evaluation is to determine the ability of the HMMP package to withstand the stress induced by the dropping of a 13 lbs steel bar onto the packaging as required by Reference 1 and 2.

II. References:

1. US-NRC, 10 CFR Part 71, "Packaging and Transportation of Radioactive Materials".
2. WHC-SD-TP-PDC-019, Rev. 0, "Packaging Design Criteria Transfer and Disposal of Hydrogen Mitigation Mixer Pump".
3. WHC Drawing No. H-2-83734.
4. "Structures to Resist the Effects of Accidental Explosion-Department of the Army, Navy, and Air Force", PM 5-1300 June 1969.
5. "Fundamentals of Protective Design", US Army Corp of Engineers (1943).

III. Results and Conclusions:

The penetration evaluation is performed for the thinnest outer shield retaining shell of the package. As required by Reference 1 and 2, this has been determined as the weakest exposed part of the package.

The evaluation is based on empirical projectile penetration data provided in References 4 and 5. The analysis shows the thinnest section of the package resists penetration by 13 lbs projectile falling onto it from a height of 40 inches. The calculated margin of safety is 0.92 or 92%. It is concluded that the package design is adequate in meeting the requirements of Reference 1 and 2.

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-PEN-01 Page 2 of 3
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Penetration Evaluation
 Originator S. S. Shiraga Date 07/26/94
 Checker M. D. Clements *MDC* Date 07/30/94


IV. Engineering Evaluation:

Figure 1

Diameter of projectile (Reference 1): $d = 1.25$ inches
 Height of projectile fall (Reference 1): $h = 40$ inches
 Mass of projectile (Reference 1): $w_p = 13$ lbs
 Outer shell thickness (thinnest section): $t_{sh} = 0.3125$ inch
 Velocity of free fall:

$$v_p = \sqrt{2gh}$$

$$v_p = 14.65 \text{ ft/sec}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-PEN-01 Page 3 of 3
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Penetration Evaluation
 Originator S. S. Shiraga Date 07/26/94
 Checker M. D. Clements Date 07/30/94

Penetration distance into reinforced concrete (Reference 4):

$$s_{con} = \frac{5.423 w_p \left[\frac{v_p}{(ft/sec)} \right]^{1.33}}{10^4 lbs/inch \left(\frac{d}{inch} \right)^{1.8}}$$

$$s_{con} = 0.168 \text{ inch}$$

The penetration distance calculated above is the penetration into reinforced concrete, this can be translated into the perforation limit for steel according to Reference 5, by the following equation:

$$t_{pen} = \frac{1.216 s_{con} + 1.4 d}{12}$$

$$t_{pen} = 0.163 \text{ inch}$$

Margin of Safety:

$$MS_{pen} = \frac{t_{sb}}{t_{pen}} - 1$$

$$MS_{pen} = 0.92 \text{ Therefore OK}$$

6.4.7 Low Temperature Brittle Fracture Evaluation

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-BRF-01 Page 1 of 3
Building Tank 241-SY-101 Rev. 0 Job No. _____
Subject Low Temperature Brittle Fracture Evaluation.
Originator S. S. Shiraga Date 07/27/94
Checker M. D. Clements Date 07/31/94

I. Objectives:

The objective of this evaluation is to verify that the containment materials used in the fabrication of the disposal packaging meets the brittle fracture requirements of Reference 2 at the design temperature range of -10°F to 115°F in order to satisfy the requirements of Reference 1.

II. References:

1. WHC-SD-TP-PDC-019, Rev. 0, "Packaging Design Criteria Transfer and Disposal of Hydrogen Mitigation Mixer Pump".
2. ASME, American Society of Mechanical Engineers, Boiler and Pressure Vessels, Section VIII, Division 1, 1989.
3. WHC Drawing No. H-2-83734, "Hydrogen Mixer Pump Storage Container".

III. Results and Conclusions:

The results of this evaluation shows that major portions of the packaging containment boundary materials used in the the design do not meet all the requirements for extreme low temperature service identified in Reference 2. Specifically the primary containment flanges have nominal thickness in excess of 1.75 inch, which is the limiting exemption thickness at the operating temperature of -10°F. By Reference 2, this would require impact testing of the material to insure safe operation. However, an essential component of low temperature brittle fracture is stress. When not in use and with no internal pressure only the primary containment piping and Inner Top Cap Flange bolts are under load. These component are well within the requirements for exemption from impact testing. And since the containment flanges would not be under any significant loads, this would allow the flanges to exceed the thickness limits specified in Reference 2, without impact testing of the material. However, it is imperative that the Safety Evaluation for Packaging (SEP) states that no movement or handling of the container or application of any external load is allowed for temperatures below 0°F, as a safety precaution. Also, since the contents of the packaging may generate hydrogen gas, the package must be vented to prevent pressurization at extreme low temperatures, to prevent significant loading of the flanges.

ENGINEERING ANALYSIS

Drawing	H-2-83734	Doc. No.	101-SY-BRF-01	Page	2 of 3
Building	Tank 241-SY-101	Rev.	0	Job No.	
Subject	Low Temperature Brittle Fracture Evaluation				
Originator	S. S. Shiraga	Date	07/27/94		
Checker	M. D. Clements	Date	07/31/94		

IV. Engineering Evaluation:

Containment component materials of construction (Reference 3):

- 1) Inner Top Cap 1 inch bolts: ASTM-A 307, Grade B
- 2) Containment and shielding piping 0.500 and 0.3125 inch thick: ASTM-A 516, Grade 70 (Normalized)
- 3) Inner Top Cap Material, (thickest) 2.25 inch: ASTM-A 516, Grade 70 (Normalized)
- 4) Inner Hub Flange, 2.25 inch thick: ASTM-A 516, Grade 70 (Normalized)
- 5) Bottom Outer End Flange, 2 inch thick: ASTM-A 516, Grade 70 (Normalized)

Section UG-20 Design Temperatures (Reference 2, page 20), states that the requirements for exemption from Impact Testing are:

- Paragraph (1)(b): Nominal thickness for noted materials in Curve D of Figure UCS-66.
- Paragraph (2): Hydrostatic testing, since package primary containment is not under pressure, none required. Outer shell is decay pressure tested.
- Paragraph (3): Design temperatures no warmer than 650°F nor colder than -20°F. Design temperatures as specified in Reference 1 are -10°F and 115°F.
- Paragraph (4): No shock or mechanical loading at low temperatures extreme.
- Paragraph (5): Since one way transport and no movement at extreme low temperatures, no cyclic loads.

Based on containment boundary material thicknesses and data from Curve D of Figure UCS-66, operation or use of the packaging under temperatures less than 0°F requires that the material be impact tested per the requirements of Reference 2. The flange thickness specified would require impact testing of the material at the low temperature specified in Reference 1.

Components which are normally under constant load, whether in use or not, are; the bolts, containment piping and shielding shells. From the data on Figure UCS-66, the containment piping and shielding shells are capable for use to temperatures of -40°F without the requirement for impact testing. The Inner Top Cap containment bolts, from the notes on page 172 of Reference 2, are exempt from

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-BRF-01 Page 3 of 3
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Low Temperature Brittle Fracture Evaluation
 Originator S. S. Shiraga Date 07/27/94
 Checker M. D. Clements *MDC* Date 07/31/94

impact testing to -20°F. Both these temperatures are below the low temperature requirement stated in Reference 1. Therefore OK.

Curve From UCS-66:




FIG. UCS-66 IMPACT TEST EXEMPTION CURVES (SEE UCS-66(a))

Figure 1

6.4.8 Vibration Evaluation (Induced by Peak Shock Loading)

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 1 of 24
Building Tank 241-SY-101 Rev. 0 Job No. _____
Subject Vibration Evaluation (Induced by Peak Shock Loading)
Originator S. S. Shiraga Date 07/31/94
Checker H. E. Adkins Jr. *Arnold E. Adkins Jr.* Date 09/14/94

I. Objectives:

The objective of this vibration evaluation is to determine the stresses induced by peak shock loading during peak shock loading during transportation of the 101-SY package.

II. References:

1. ANSI 14.23, "Draft American National Standard Design Basis for Resistance to Shock and Vibration of Radioactive Material Packages Greater than One Ton in Truck Transport", 1987.
2. ASME, American Society of Mechanical Engineers, Boiler and Pressure Vessels, Section VIII, Division 2, 1989.
3. Industrial Press, Machinery's Handbook, 20th Edition.
4. WHC, Drawing No. H-2-83734, "Hydrogen Mixer Pump Storage Container".
5. Church, A. H., Mechanical Vibrations, 2nd Edition.

III. Results and Conclusions:

Both the vertical and longitudinal peak shock loads are taken from data developed in Reference 1. (Since this is a one-time transfer cyclic fatigue stresses are not evaluated.) The vertical and longitudinal shock loadings are modeled in three sections based on the method of tie-down. The package restraints are modeled in two cases with clamped and fixed boundary conditions at each end and one as a cantilevered section. The maximum total stress in all cases occurred at the tied-down stiffener rings. For this evaluation only the vertical and longitudinal directions are evaluated, since the package is radially symmetrical and in the lateral direction, loading is less than for vertical loading. For conservatism the peak shock load stresses were combined with external pressure reduction stresses.

The results show that all stresses are well under the material strength allowables established in Reference 2. Consequently, the package design is adequate to withstand the combined effects of peak shock loads induced during transport as characterized in Reference 1 and external pressure reduction.

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 2 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

IV. Engineering Evaluation:

Transportation Peak Vertical Shock Loading on 101 SY:

Since the package is restrained by the strongback and tie-downs at the supports, the system can be modeled as a series of clamped and fixed beams between the supports and as cantilevered sections on the outside. With the sections clamped and fixed, each unit is assumed to be independent of the other. Assume that each section is loaded with a pulsing sinusoidal force, acting at the center of the clamped and fixed sections and at the ends on the cantilevered section. Assume the package sections are of uniform sections, by assuming the weight is uniformly smeared over the length of the section. Assume that all materials are homogeneous, isotropic and obey Hooke's law.

The peak shock load is taken from data developed in Reference 1. The peak vertical shock load was loaded as:

$$g_{ps} = 3.5 \quad \text{at} \quad \omega = 4\pi/\text{sec} \quad \text{for a duration of } T_p = 2\pi/\omega$$

Container Parameters:

Material Modulus at 115°F $E_{cstl} = 29.1 \times 10^6 \text{ psi}$

Pipe OD: $dp_{od} = 64 \text{ in}$ Pipe thickness: $t_{pw} = 0.500 \text{ in}$

Pipe ID: $dp_{id} = dp_{od} - 2t_{pw}$

Assume all outer skin dimensions are the same:

Skin ID: $id_{sk} = 5 \text{ ft} + 8 \text{ in}$ Skin thickness: $t_{s1} = 0.3125 \text{ in}$

Skin OD: $od_{sk} = id_{sk} + 2t_{s1}$

Total Area:

$$A_p = \pi \frac{dp_{od}^2 - dp_{id}^2}{4} + \pi \frac{dp_{sk}^2 - id_{sk}^2}{4}$$

Total moment of inertia:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 3 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

$$I_p = \pi \frac{dp_{od}^4 - dp_{id}^4}{64} + \pi \frac{od_{sk}^4 - id_{sk}^4}{64}$$

Package Empty full shielded weight: $W_{pac} = 130,000 \text{ lbs}$

Weight of top caps: $W_{tc} = 2,400 \text{ lbs}$

Weight of package without top caps: $W_{con} = W_{pac} - W_{tc}$

Package payload: $W_{pc} = 20,000 \text{ lbs}$

Length of container without top cap: $L_{con} = 626.75 \text{ in}$

Total weight of package: $W_{pack} = W_{con} + W_{pc}$ $W_{pack} = 147,600 \text{ lbs}$

Load per unit length: $w_{con} = W_{pack}/L_{con}$

Pulsating sinusoidal force: $F_v = g_{ps} w_{con} l \sin(\omega t)$

Where l is defined as the length of the section.




Figure 1

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 4 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

Response equations for the clamped and fixed sections on strongback:

Length of section between supports:

Location of first support:

$$l_{s1} = \frac{9.75}{2} \text{ inches}$$

Location of second support:

$$l_{s2} = (24 \text{ ft} + 0.25 \text{ in}) + \frac{(24 \text{ ft} + 9.750 \text{ in}) - (24 \text{ ft} + 0.25 \text{ in})}{2}$$

$$l_b = l_{s2} - l_{s1} \quad l_b = 24.01 \text{ ft}$$

Location where beam to be evaluated: $x = l_b$

Assume when the beam vibrates vertically in one of its natural modes, the deflection at any location varies harmonically with time as:

$$y = X(A \cos(\Omega t) + B \sin(\Omega t))$$

The general partial differential equation for free vibration then becomes:

$$d^4X/dx^4 - (k)^4X = 0$$

The general solution for the normal function of deflection then becomes:

$$X = C_1(\cos(kx) + \cosh(kx)) + C_2(\cos(kx) - \cosh(kx)) + C_3(\sin(kx) + \sinh(kx)) + C_4(\sin(kx) - \sinh(kx))$$

The boundary conditions for a clamped and fixed beam are:

$$\text{At } x = 0: \quad X = 0 \quad \text{and} \quad dX/dx = 0$$

$$\text{At } x = l_b; \quad X = 0 \quad \text{and} \quad dX/dx = 0$$

$$dX/d_x = C_1(-\sin(kx)k + \sinh(kx)k) + C_2(-\sin(kx)k - \sinh(kx)k) + C_3(\cos(kx)k + \cosh(kx)k) + C_4(\cos(kx)k - \cosh(kx)k)$$

$$X = C_2(\cos(kx) - \cosh(kx)) + C_4(\sin(kx) - \sinh(kx))$$

$$dX/d_x = C_2(-\sin(kx)k - \sinh(kx)k) + C_4(\cos(kx)k - \cosh(kx)k)$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 5 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

From $x = 0$: $C_1 = C_3 = 0$

So that:

From $x = l_b$:

$$C_2(\cos(kl_b) - \cosh(kl_b)) + C_4(\sin(kl_b) - \sinh(kl_b)) = 0$$

$$C_2(\sin(kl_b) + \sinh(kl_b)) + C_4(-\cos(kl_b) + \cosh(kl_b)) = 0$$

A solution for the constants C_2 and C_4 are only obtained in the case where the determinant of the above equations equal zero. From the determinant:

$$\cos(kl_b)(\cosh(kl_b)) = 1$$

The non-zero roots of the above equation is approximated by:

$$k_i = \frac{\left(i + \frac{1}{2}\right) \pi}{l_b}$$

The normal function becomes:

$$X_i = \cosh(k_i x) - \cos(k_i x) - \alpha_i(\sinh(k_i x) - \sin(k_i x))$$

Where α_i is defined as:

$$\alpha_i = \frac{\cos(k_i l_b) - \cosh(k_i l_b)}{\sinh(k_i l_b) - \sin(k_i l_b)}$$

The response for a steady state forced vibration of a clamped and fixed beam is:

$$y = \frac{2F_v l_b^3}{E_{cstl} I_p} \sum_i \frac{X_i X_{load_i}}{(k_i l_b)^4} \beta_i \left(\sin(\omega t) - \frac{\omega}{\Omega_i} \sin(\Omega_i t) \right)$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 6 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

Where X_{load} is defined as the normal function at the load.

$$X_{load_i} = \cosh\left(k_i \frac{l_b}{2}\right) - \cos\left(k_i \frac{l_b}{2}\right) - \alpha_i \left(\sinh\left(k_i \frac{l_b}{2}\right) - \sin\left(k_i \frac{l_b}{2}\right) \right)$$

Since: $M = E_{cstl} I_p d^2y/dx^2$

$$X_i = \cosh(k_i x) - \cos(k_i x) - \alpha_i (\sinh(k_i x) - \sin(k_i x))$$

$$d^2X_i/dx^2 = X''_i = (k_i)^2 [\cosh(k_i x) + \cos(k_i x) - \alpha_i (\sinh(k_i x) + \sin(k_i x))]$$

$$d^3X_i/dx^3 = X'''_i = -(k_i)^3 (-\sinh(k_i x) + \sin(k_i x) + \alpha_i \cosh(k_i x) + \alpha_i \cos(k_i x))$$

$$\sigma_b = \frac{2 F_v l_b^3}{I_p} \frac{dp_{od}}{2} \sum_i \frac{X_{load_i} X'''_i}{(k_i l_b)^4} \beta_i \left(\sin(\omega t) - \frac{\omega}{\Omega_i} \sin(\Omega_i t) \right)$$

$$V_b = 2 F_v l_b^3 \sum_i \frac{X_{load_i} X''''_i}{(k_i l_b)^4} \beta_i \left(\sin(\omega t) - \frac{\omega}{\Omega_i} \sin(\Omega_i t) \right)$$

Determine stress, deflection and shear load for the first 5 modes at $x = l_b$ for one full period.

$$i = 1 \dots 5$$

Natural Frequency:

$$\Omega_i = \left[\left(i + \frac{1}{2} \right) \pi \right]^2 \sqrt{\frac{g E_{cstl} I_p}{w_{con} l_b^4}} \quad k_i = \frac{\left(i + \frac{1}{2} \right) \pi}{l_b}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 7 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

Frequency ratio:

$$\beta_i = \frac{1}{\left[1 - \left(\frac{\omega}{\Omega_i}\right)^2\right]}$$

Normal function coefficient:

$$\alpha_i = \frac{\cosh(k_i l_b) - \cos(k_i l_b)}{\sinh(k_i l_b) - \sin(k_i l_b)}$$

Normal function at load:

$$X_{load_i} = \left(\cosh\left(k_i \frac{l_b}{2}\right) - \cos\left(k_i \frac{l_b}{2}\right) \right) - \alpha_i \left(\sinh\left(k_i \frac{l_b}{2}\right) - \sin\left(k_i \frac{l_b}{2}\right) \right)$$

Normal function of the section:

$$X_i = (\cosh(k_i x) - \cos(k_i x)) - \alpha_i (\sinh(k_i x) - \sin(k_i x))$$

Evaluation time intervals: $n = 0 \dots 8$ $t_n = n/8 T_p$

Pulsating function magnitude: $F_v = g_{ps} w_{con} l_b$

Deflection:

$$y_n = \frac{2 F_v l_b^3}{E_{cst1} I_p} \sum_i \frac{X_i X_{load_i}}{(k_i l_b)^4} \beta_i \left(\sin(\omega t_n) - \frac{\omega}{\Omega_i} \sin(\Omega_i t_n) \right)$$

Moment normal function:

$$X''_i = (k_i)^2 [\cosh(k_i x) + \cos(k_i x) - \alpha_i (\sinh(k_i x) + \sin(k_i x))]$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 8 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

Bending stress:

$$\sigma_{b_n} = \frac{2 F_v l_b^3 \frac{dp_{od}}{2}}{I_p} \sum_i \frac{X_{load_i} X''''_i}{(k_i l_b)^4} \beta_i \left(\sin(\omega t_n) - \frac{\omega}{\Omega_i} \sin(\Omega_i t_n) \right)$$

Shear normal function:

$$X''''_i = -(k_i)^3 (-\sinh(k_i x) + \sin(k_i x) + \alpha_i (\cosh(k_i x) + \cos(k_i x)))$$

Shear load:

$$V_{b_n} = 2 F_v l_b^3 \sum_i \frac{X_{load_i} X''''_i}{(k_i l_b)^4} \beta_i \left(\sin(\omega t_n) - \frac{\omega}{\Omega_i} \sin(\Omega_i t_n) \right)$$

Maximum shear stress:

$$\tau_{shmax} = 2 V_b / A_p$$

Total stress:

$$\sigma_{btot} = \sigma_b + \tau_{shmax}$$

t _n /sec	y _n /in	σ _b /psi	τ _{shmax}	σ _{btot} /psi
0	0	0	0	0
0.063	0	4,387	2,293	6,680
0.125	0	6,219	3,251	9,470
0.188	0	4,375	2,285	6,660
0.25	0	15	5	20
0.313	0	-4,420	-2,315	-6,735
0.375	0	-6,186	-3,236	-9,422
0.438	0	-4,425	-2,314	-6,739
0.5	0	41	25	66

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 9 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. *H. E. Adkins Jr.* Date 09/14/94

Maximum stress: $\sigma_{\max bt} = 9,470$ psi

ASME Maximum allowable from ASME data of ASTM A-516: $s_a = 23,270$ psi

Pressure reduction stress in pipe: $s_{\text{tot}} = 1,058$ psi

Total stress on pipe: $\sigma_{\max 1} = \sigma_{\max bt} + s_{\text{tot}}$ $\sigma_{\max 1} = 10,528$ psi

Margin of Safety:

$$MS_{b1} = (s_a / \sigma_{\max 1}) - 1 \quad MS_{b1} = 1.21 \quad \text{OK}$$

Response equations for the clamped and fixed sections from strongback:

Length of section between supports:

Length to trailer support: $l_{s3} = 51$ ft + 2.750 in

$$l_{1b} = l_{s3} - l_{s2} \quad l_{1b} = 26.81$$
 ft

Location where beam to be evaluated: $x1 = l_{1b}$

Determine loading using same methodology as above.

Determine stress, deflection and shear load for the first 5 modes at $x1 = l_{1b}$ for one full period.

Natural frequency:

$$\Omega 1_i = \left[\left(i + \frac{1}{2} \right) \pi \right]^2 \sqrt{\frac{g E_{cst1} I_P}{w_{con} I_{1b}^4}} \quad k 1_i = \frac{\left(i + \frac{1}{2} \right) \pi}{l_{1b}}$$

Frequency ratio:

$$\beta 1_i = \frac{1}{\left[1 - \left(\frac{\omega}{\Omega 1_i} \right)^2 \right]}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 10 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

Normal function coefficient:

$$\alpha_{1_i} = \frac{\cosh(k l_i l_{1b}) - \cos(k l_i l_{1b})}{\sinh(k l_i l_{1b}) - \sin(k l_i l_{1b})}$$

Normal function at load:

$$X_{1_{load_i}} = \left(\cosh\left(k l_i \frac{l_{1b}}{2}\right) - \cos\left(k l_i \frac{l_{1b}}{2}\right) \right) - \alpha_{1_i} \left(\sinh\left(k l_i \frac{l_{1b}}{2}\right) - \sin\left(k l_i \frac{l_{1b}}{2}\right) \right)$$

Normal function of the section:

$$X_{1_i} = (\cosh(k l_i x_i) - \cos(k l_i x_i)) - \alpha_{1_i} (\sinh(k l_i x_i) - \sin(k l_i x_i))$$

Pulsating function magnitude: $F_{1_v} = g_{ps} w_{con} l_{1b}$

Deflection:

$$y_{1_n} = \frac{2 F_{1_v} l_{1b}^3}{E_{cst1} I_p} \sum_i \frac{X_{1_i} X_{1_{load_i}}}{(k l_i l_{1b})^4} \beta_{1_i} \left(\sin(\omega t_n) - \frac{\omega}{\Omega_{1_i}} \sin(\Omega_{1_i} t_n) \right)$$

Moment normal function:

$$X_{1''_i} = (k l_i)^2 [\cosh(k l_i x_i) + \cos(k l_i x_i) - \alpha_{1_i} (\sinh(k l_i x_i) + \sin(k l_i x_i))]$$

Bending stress:

$$\sigma_{1_{b_n}} = \frac{2 F_{1_v} l_{1b}^3}{I_p} \frac{d p_{od}}{2} \sum_i \frac{X_{1_{load_i}} X_{1''_i}}{(k l_i l_{1b})^4} \beta_{1_i} \left(\sin(\omega t_n) - \frac{\omega}{\Omega_{1_i}} \sin(\Omega_{1_i} t_n) \right)$$

Shear normal function:

$$X_{1'''_i} = -(k l_i)^3 (\sinh(k l_i x_i) + \sin(k l_i x_i) + \alpha_{1_i} \cosh(k l_i x_i) + \alpha_{1_i} \cos(k l_i x_i))$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 11 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. *[Signature]* Date 09/14/94

Shear load:

$$Vl_{bn} = 2 Fl_v l_{1b}^3 \sum_i \frac{Xl_{load_i} Xl_{''''_i}}{(kl_i l_{1b})^4} \beta l_i \left(\sin(\omega t_n) - \frac{\omega}{\Omega l_i} \sin(\Omega l_i t_n) \right)$$

Maximum shear stress:

$$\tau l_{shmax} = 2 Vl_b / A_p$$

Total stress:

$$\sigma l_{btot} = \sigma l_b + \tau l_{shmax}$$

t _n /sec	yl _n /in	σl _v /psi	τl _{shmax} /psi	σl _{btot} /psi
0	0	0	0	0
0.063	0	5,344	2,498	7,842
0.125	0	7,974	3,739	11,713
0.188	0	5,241	2,450	7,691
0.25	0	173	84	256
0.313	0	-5,534	-2,596	-8,130
0.375	0	-7,843	-3,677	-11,520
0.438	0	-5,281	-2,469	-7,751
0.5	0	-246	-122	-369

Maximum stress: σ_{maxblt} = 11,713 psi

Total Pressure on pipe: σ_{max2} = σ_{maxblt} + S_{tot} σ_{max2} = 12,771 psi

Margin of Safety:

$$MS_{b2} = (s_y / \sigma_{max2}) - 1 \quad MS_{b2} = 0.82 \quad \text{OK}$$

Response equations for the cantilevered sections:

Using the same method as above determine the response of the long cantilevered section.

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 12 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

Length of top cap: $l_{\text{tcap}} = (2 \text{ ft} + 1.875 \text{ in}) + 0.375 \text{ in} + 2.25 \text{ in}$

Length of section between supports:

Length from support to top end flange:

$$l_{s4} = (52 \text{ ft} + 0.750 \text{ in}) - (51 \text{ ft} + 2.750 \text{ in})$$

$$l_c = l_{s4} + 1 \text{ in} + l_{\text{tcap}}$$

Location where beam to be evaluated: $x_c = 0 \text{ in}$

Additional weight due to top cap: $W_{\text{tcap}} = W_{\text{tc}}$

$$W_{\text{con1}} = W_{\text{con}}/L_{\text{con}} + W_{\text{tcap}}/l_{\text{tcap}}$$

Determine stress and deflection for the first 5 modes at $x = 0$ for one full period.

Natural Frequency:

$$\Omega_{c_i} = \left[\left(i - \frac{1}{2} \right) \pi \right]^2 \sqrt{\frac{g E_{\text{cst1}} I_P}{W_{\text{con1}} l_c^4}} \quad k_{c_i} = \frac{\left(i - \frac{1}{2} \right) \pi}{l_c}$$

Frequency ratio:

$$\beta_{c_i} = \frac{1}{\left[1 - \left(\frac{\omega}{\Omega_{c_i}} \right)^2 \right]}$$

Normal function coefficient:

$$\alpha_{c_i} = \frac{\cosh(k_{c_i} l_c) + \cos(k_{c_i} l_c)}{\sinh(k_{c_i} l_c) + \sin(k_{c_i} l_c)}$$

Normal function at load:

$$X_{\text{cload}} = (\cosh(k_c l_c) - \cos(k_c l_c)) - \alpha_c (\sinh(k_c l_c) - \sin(k_c l_c))$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 13 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject: Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

Normal function of the section:

$$X_c = (\cosh(k_c x_c) - \cos(k_c x_c)) - \alpha_c (\sinh(k_c x_c) - \sin(k_c x_c))$$

Pulsating function magnitude: $F_{vc} = g_{ps} W_{cont} l_c$

Deflection:

$$y_{c_n} = \frac{2 F_{vc} l_c^3}{E_{cst1} I_p} \sum_I \frac{X_{c1} X_{cload1}}{(k_{c1} l_c)^4} \beta_{c1} \left(\sin(\omega t_n) - \frac{\omega}{\Omega_{c1}} \sin(\Omega_{c1} t_n) \right)$$

Normal function of bending stress:

$$X''_c = (k_c)^2 [\cosh(k_c x_c) + \cos(k_c x_c) - \alpha_c (\sinh(k_c x_c) + \sin(k_c x_c))]$$

Bending stress:

$$\sigma_{cb_n} = \frac{2 F_{vc} l_c^3}{I_p} \frac{dp_{od}}{2} \sum_I \frac{X_{cload1} X''_{c1}}{(k_{c1} l_c)^4} \beta_{c1} \left(\sin(\omega t_n) - \frac{\omega}{\Omega_{c1}} \sin(\Omega_{c1} t_n) \right)$$

Normal function of shear load:

$$X'''_c = (k_c)^3 [\sinh(k_c x_c) - \sin(k_c x_c) - \alpha_c (\cosh(k_c x_c) + \cos(k_c x_c))]$$

Shear load:

$$V_{cb_n} = 2 F_{vc} l_c^3 \sum_I \frac{X_{cload1} X'''_{c1}}{(k_{c1} l_c)^4} \beta_{c1} \left(\sin(\omega t_n) - \frac{\omega}{\Omega_{c1}} \sin(\Omega_{c1} t_n) \right)$$

Maximum shear stress:

$$\tau_{cshmax} = 2 V_{cb} / A_p$$

Total stress:

$$\sigma_{ctot} = \sigma_b - \sigma_{cshmax}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 14 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

t _p /sec	y _c /in	σ _{ct} /psi	τ _{ctshmax} /psi	σ _{cttot} /psi
0	0	0	0	0
0.063	0	872	-683	1,555
0.125	0	1,244	-977	2,221
0.188	0	871	-682	1,552
0.25	0	2	-2	4
0.313	0	-873	685	-1,558
0.375	0	-1,243	977	-2,221
0.438	0	-870	681	-1,551
0.5	0	-3	4	7

Maximum stress: σ_{maxct} = 2,221 psi

Total stress on pipe: σ_{max3} = σ_{maxct} + S_{tot} σ_{max3} = 3,279 psi

Margin of Safety:

$$MS_{c1} = (s_e / \sigma_{max3}) - 1 \quad \cdot MS_{c1} = 6.1 \quad OK$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 15 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. *H. E. Adkins Jr.* Date 09/14/94

Transportation longitudinal peak shock loading on 101SY:

Model as individual clamped and fixed beams between the supports and as a cantilever at the ends. Assume that load is pulsating sinusoidal force at mid span on the clamped and fixed beams and on the ends for the cantilever.




Figure 2

The peak shock load is taken from data developed in the ANSI 14.23 draft. The peak vertical shock load was defined as:

$g_{ps1} = 2.3$ at $\omega = (4\pi)/\text{sec}$ for a duration of $T_p = (2\pi)/\omega$

Container Parameters, Reference 4:

Material Modulus of 115°F: $E_{cstl} = 29.1 \times 10^6$ psi

Density of carbon steel (Reference 3, pg. 2269): $\rho_{cstl} = 0.2835$ lbs/in³

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 16 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. *Harold E. Adkins Jr.* Date 09/14/94

Acoustic velocity in carbon steel:

$$a_{cst1} = \sqrt{\frac{g E_{cst1}}{\rho_{cst1}}} \quad a_{cst1} = 16,589 \text{ ft sec}^{-1}$$

Pipe OD: $dp_{od} = 64 \text{ in}$ Pipe thickness: $t_{pw} = 0.500 \text{ in}$

Pipe ID: $dp_{id} = dp_{od} - 2 t_{pw}$

Cross sectional area of pipe: $A_p = \pi(dp_{od}^2 - dp_{id}^2)/4$

Pipe cross sectional moment of inertia: $I_p = \pi(dp_{od}^4 - dp_{id}^4)/64$

Weight of top caps: $W_{tc} = 2,400 \text{ lbs}$

Package empty fully shielded weight: $W_{pac} = 130,000 \text{ lbs}$

Weight of package without top caps: $W_{con} = W_{pac} - W_{tc}$

Container payload: $W_{pc} = 20,000 \text{ lbs}$

Length of container without top caps: $L_{con} = 626.75 \text{ in}$

Total weight of container: $W_{pack} = W_{con} + W_{pc} \quad W_{pack} = 147,600 \text{ lbs}$

Load per unit length: $W_{con} = W_{pack}/L_{con}$

Pulsating sinusoidal force: $F_1 = g_{psl} W_{con} l \sin(\omega t)$

Where l is defined as the length of the section.

Differential Equation of motion for longitudinal vibration:

$$\frac{d^2 u}{d t^2} = a_{cst1}^2 \frac{d^2 u}{d x^2}$$

Where u is defined as the displacement of the cross section.

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 17 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

General solution is given as:

$$u(x, t) = \sum_n (A \cos(\Omega t) + B \sin(\Omega t)) \left(C \cos\left(\frac{\Omega x}{a_{cstl}}\right) + D \sin\left(\frac{\Omega x}{a_{cstl}}\right) \right)$$

Where A, B, C, and D are constants to be determined by the boundary and initial conditions. Ω is defined as the natural frequency. It is assumed that all materials are homogenous, isotropic, and obey Hooke's law.

Derivation of normal function for clamped and fixed section:

Since the beam is assumed to be clamped and fixed, the displacement is equal to zero at the ends. The boundary conditions are $u_{x=0} = u_{x=1} = 0$. Substituting these into the above equation:

$$u_{x=0} = \sum_n f(t) \left(C \cos\left(\frac{\Omega x}{a_{cstl}}\right) + D \sin\left(\frac{\Omega x}{a_{cstl}}\right) \right) = 0$$

Where $f(t)$ is defined as time dependent function.

Then $C=0$ and:

$$u_{x=1} = \sum_n f(t) D \sin\left(\frac{\Omega x}{a_{cstl}}\right) = 0$$

Then: $\sin[(\Omega l)/a] = 0$ and $\Omega = (n\pi a_{cstl})/l$

Therefore the normal function then becomes:

$$\chi(x) = D \sin[(n \pi x)/l]$$

Clamped and fixed supported section between strongback:

Length of section between supports:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 18 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

Location of first support:

$$l_{s1} = \frac{9.75}{2} \text{ inches}$$

Location of second support:

$$l_{s2} = (24 \text{ ft} + 0.25 \text{ in}) + \frac{(24 \text{ ft} + 9.750 \text{ in}) - (24 \text{ ft} + 0.25 \text{ in})}{2}$$

$$l_b = l_{s2} - l_{s1} \quad l_b = 24.01 \text{ ft}$$

Evaluation time intervals: $j = 0..8$ $t_j = j/8(T_p)$

Location of evaluation: $x_b = l_b$

Odd number node locations: $n = 1..5$ $i_n = 2n - 1$

Magnitude of pulsating force: $F_l = g_{psl} w_{con} l_b$ $F_l = 124,580 \text{ lbs}$

Solve for time dependent function for forced vibration:

Since any displacement can be obtained by superposition of corresponding displacements to the normal modes of vibration, vibration by a disturbing force can be represented by a series:

$$u = \sum_n \psi X(x)$$

Where ψ is an unknown function of time.

By virtual work: $\delta u = X(x) = D \sin(n\pi x/l)$

Since the mass of an element between adjacent cross sections of the bar is $\rho A_p dx$, the virtual work done by the inertial force on the virtual displacement is:

$$\delta W_I = \int_0^l (-\rho A_p \ddot{u} dx) \frac{d^2 u}{dx^2} \delta u = -\rho A_p \int_0^l \left(\frac{d^2 u}{dx^2} \right) D \sin\left(\frac{n\pi x}{l}\right) dx$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 19 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject: Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

Substituting for u with the series:

$$\delta W_I = \frac{-\rho A_p l}{2} D \frac{d^2 \psi}{d t^2}$$

Virtual work produced by the elastic force is:

$$\delta W_E = \int_0^l \left(E_{cstl} A_p \frac{d^2 u}{d x^2} \right) dx \delta u$$

By substituting in for the above series:

$$\delta W_E = \frac{-n^2 \pi^2 E_{cstl} A_p}{8 l} D \psi$$

Virtual work of the disturbing force where: $x = l/2$

$$\delta W_F = F(t) D \sin\left(\frac{n \pi}{2}\right) = F(t) D (-1)^{\frac{i-1}{2}}$$

Second term is a Fourier Series form.

Summing the above expressions gives the total virtual work:

$$\frac{\rho A_p l}{2} \frac{d^2}{d t^2} \psi + \frac{n^2 \pi^2 E_{cstl} A_p}{8 l} \psi = F(t) (-1)^{\frac{i-1}{2}}$$

$$\frac{d^2}{d t^2} \psi + [\Omega_{(i)}]^2 \psi = \frac{2}{\rho_{cstl} A_p l_b} (-1)^{\frac{i-1}{2}} F_i \sin(\omega t)$$

The natural frequency is defined as: $\Omega_i = (i_n \pi a_{cstl})/l_b$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 20 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

Using Duhamel integral (Reference 5, page 43):

$$\psi = \frac{2 F_1 (-1)^{\frac{i_n-1}{2}}}{A_p \rho_{cstl} l_b \Omega_i} \int_0^t \sin(\omega (t-z)) \sin[\Omega_i (t-z)] dz$$

$$\psi_{(i_n, j)} = \frac{2 F_1 (-1)^{\frac{i_n-1}{2}}}{A_p \frac{\rho_{cstl}}{g} l_b \Omega_{(i_n)}} \cdot \frac{\begin{bmatrix} -\omega \cos(\omega t_j) \sin[\Omega_{i_n} t_j] \\ + \Omega_{i_n} \sin(\omega t_j) \cos[\Omega_{i_n} t_j] \end{bmatrix}}{[-\omega^2 + [\Omega_{(i_n)}]^2]}$$

Deflection:

$$u_j = \sum_n \psi_{(i_n, j)} \sin\left(\frac{i_n \pi x_b}{l_b}\right)$$

If du/dx is defined as the strain, then by Hooke's Law, axial stress = $E du/dx$.

Axial stress:

$$s_{b_j} = E_{cstl} \left[\sum_n \psi_{(i_n, j)} \left(\cos\left(\frac{i_n \pi x_b}{l_b}\right) \frac{i_n \pi}{l_b} \right) \right]$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 21 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

t _i /sec	u _i /in	s _b /psi
0	0	0
0.063	0	588
0.125	0	855
0.188	0	470
0.25	0	4
0.313	0	-521
0.375	0	731
0.438	0	-509
0.5	0	7

Maximum axial stress at stiffener ring interface:

$$\sigma_{l_{bmax}} = 855 \text{ psi}$$

Pressure reduction stress in pipe: $s_{tot} = 1,085 \text{ psi}$

Total stress on pipe: $\sigma_{l_{bmax1}} = \sigma_{l_{bmax}} + s_{tot}$ $\sigma_{l_{bmax1}} = 1,913 \text{ psi}$

ASME allowable from previous date: $s_b = 23,270 \text{ psi}$

Margin of Safety:

$$MS_{bmax} = (s_b / \sigma_{l_{bmax1}}) - 1 \quad MS_{bmax} = 11.16 \quad \text{OK}$$

Clamped and fixed supported section outside of strongback:

Length of section between supports:

Length to trailer support: $l_{s3} = 51 \text{ ft} + 2.750 \text{ in}$

$$l_{lb} = l_{s3} - l_{s2} \quad l_{lb} = 26.81 \text{ ft}$$

Location of evaluation: $x_{lb} = l_{lb}$

Magnitude of pulsating force: $F_{l_i} = g_{psl} w_{con} l_{lb}$ $F_{l_i} = 174,276 \text{ lbs}$

The natural frequency is defined as: $\Omega_{l_i} = (i_n \pi a_{cstl}) / l_{lb}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 22 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

Using the same logic as above:

$$\psi_{1(i_n, j)} = \frac{2 F I_1 (-1)^{\frac{i_n - 1}{2}}}{A_p \frac{\rho c s t l}{g} \cdot l l_b \Omega_{1(i_n)}} \cdot \frac{-\omega \cos(\omega t_j) \sin[\Omega_{1(i_n)} t_j] + \Omega_{1(i_n)} \sin(\omega t_j) \cos[\Omega_{1(i_n)} t_j]}{[-\omega^2 + [\Omega_{1(i_n)}]^2]}$$

Deflection:

$$u_{1j} = \sum_n \psi_{1(i_n, j)} \sin\left(\frac{i_n \pi x l_b}{l l_b}\right)$$

Axial stress:

$$s_{1b_j} = E c s t l \left[\sum_n \psi_{1(i_n, j)} \left(\cos\left(\frac{i_n \pi x l_b}{l l_b}\right) \frac{i_n \pi}{l l_b} \right) \right]$$

t _i /sec	u _{1j} /in	s _{1b} /psi
0	0	0
0.063	0	-588
0.125	0	-857
0.188	0	655
0.25	0	6
0.313	0	628
0.375	0	-918
0.438	0	553
0.5	0	6

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 23 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

Maximum axial stress at stiffener rings:

$$\sigma_{l_{bmax}} = 918 \text{ psi}$$

Total stress on pipe: $\sigma_{l_{maxt}} = \sigma_{l_{bmax}} + s_{tot}$ $\sigma_{l_{maxt}} = 1,976 \text{ psi}$

Margin of Safety:

$$MS_{b1max} = (s_e / \sigma_{l_{maxt}}) - 1 \quad MS_{b1max} = 10.78 \quad \text{OK}$$

Cantilevered section:

Length of top cap: $l_{tc} = (2 \text{ ft} + 1.875 \text{ in}) + 0.375 \text{ in} + 2.25 \text{ in}$

Length from support to top end flange:

$$l_{s4} = (52 \text{ ft} + 0.750 \text{ in}) - (51 \text{ ft} + 2.750 \text{ in})$$

Length of cantilevered section: $l_c = l_{s4} + l_{tc} + 1 \text{ in}$

Location of evaluation: $x_c = 0 \text{ in}$

Add in additional length and weight of top hat: $W_{hat} = W_{tc}$

Assume additional weight distributed along axis: $W_{con1} = W_{con} + (W_{hat} / l_{tc})$

Magnitude of pulsating force: $F_{lc} = g_{psl} W_{con1} l_c$ $F_{lc} = 29,046 \text{ lbs}$

The natural frequency is defined as: $\Omega_{c(i)} = (i_n \pi a_{cstl}) / (2l_c)$

From the same logic as above, the response equation becomes:

$$\phi_{(i_n, j)} = \frac{2 \cdot F_{lc}}{\frac{\rho_{cstl}}{g} A_p l_c} \left[\frac{(-1)^{\left(\frac{i_n - 1}{2}\right)} \sin(\omega t_j)}{[\Omega_{c(i_n)}]^2 - \omega^2} \right]$$

Deflection:

$$u_{c_j} = \sum_n \phi_{(i_n, j)} \sin\left(\frac{i_n \pi x_c}{2 l_c}\right)$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-VIB-01 Page 24 of 24
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Vibration Evaluation (Induced by Peak Shock Loading)
 Originator S. S. Shiraga Date 07/31/94
 Checker H. E. Adkins Jr. Date 09/14/94

Axial stress:

$$s_{c_j} = E_{cstl} \left[\sum_n \phi_{(i_n, j)} \left(\frac{1}{2} \cos \left(\frac{1}{2} \frac{i_n \pi x_c}{l_c} \right) \frac{i_n \pi}{l_c} \right) \right]$$

t _i /sec	u _c /in	s _c /psi
0	0	0
0.06	0	55
0.13	0	77
0.19	0	55
0.25	0	0
0.31	0	-55
0.38	0	-77
0.44	0	-55
0.5	0	-0

Maximum axial stress at stiffener ring:

$$\sigma_{cmax} = 77 \text{ psi}$$

Total stress on pipe: $\sigma_{cmaxt} = \sigma_{cmax} + s_{tot}$ $\sigma_{cmaxt} = 1,135 \text{ psi}$

Margin of Safety:

$$MS_{cmax} = (s_s / \sigma_{cmaxt}) - 1 \quad MS_{cmax} = 19.5 \quad \text{OK}$$

6.4.9 Drop Evaluation Loaded with No Shielding (101-SY Package)

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 1 of 34
Building Tank 241-SY-101 Rev. 0 Job No. _____
Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
Originator S. S. Shiraga Date 07/30/94
Checker S. R. Crow Date 08/31/94

I. Objectives:

The objective of this evaluation is to assess the ability of the 101SY packaging without shielding to maintain leak tightness and structural integrity after a 1 foot flat drop onto a horizontal 12 thick concrete surface (References 1 and 2). Maintenance of leak tightness and structural integrity after a 1 foot drop is demonstrated by confirming the stresses in critical components and at critical locations of the package are adequately below the values established in Reference 8.

II. References:

1. WHC-SD-TP-019, Rev 0, "Packaging Design Criteria Transfer and Disposal of Hydrogen Mixer Pump".
2. WHC, Engineering Change Notice 606676, dated June 27, 1994.
3. American Institute of Steel Construction, Steel Construction Manual, 9th Edition.
4. US-NRC, 10 CFR Part 71, "Packaging and Transportation of Radioactive Materials".
5. WHC Drawing, No. H-2-83734, "Hydrogen Mixer Pump Storage Container".
6. EPRI NP-4830, "The Effect of Target Hardness on the Structural Design of Concrete Storage Pads for Spent Fuel Casks".
7. Roark, Formulas for Stress and Strain, 4th Edition.
8. American Society of Mechanical Engineers, Boiler and Pressure Vessels, Section VIII, Division 2, 1989.
9. American Society of Mechanical Engineers, Boiler and Pressure Vessels, Section VIII, Division 1, 1989.
10. American Welding Society, AWS/ANSI D 1.1, "Structural Welding Code".
11. Blodgett, O. W., Design of Welded Structures, 1976.
12. ASTM, American Society of Testing and Materials, Annual Book of ASTM Standards, Volume 15.08.
13. Industrial Press, Machinery's Handbook, 19th Edition.

ENGINEERING ANALYSIS

Drawing	H-2-83734	Doc. No.	101-SY-DROP-01	Page	2 of 34
Building	Tank 241-SY-101	Rev.	0	Job No.	
Subject	Drop Evaluation Loaded With No Shielding (101-SY Package)				
Originator	S. S. Shiraga	Date	07/30/94		
Checker	S. R. Crow	Date	08/31/94		

III. Results and Conclusions:

This engineering evaluation is based upon classical methods, which models the dynamic loads of impact as static equivalents. The calculations are based on the assumption that the time of loading is long as compared to the natural period of the package. The calculations are also based on elastic behavior of the material.

As stated in the G loading determination calculations, alternate criteria were developed to evaluate package integrity in Reference 1. Under these new criteria based upon Reference 6, the drop G loading is developed to determine the equivalent static loadings to be applied to the package. To insure adequate conservatism, all containment boundary allowables are based on the allowable strength criteria established in Reference 8. Allowables for other critical non-containment boundary components are based on either References 3 or 10 allowables.

The results show that with the new G loadings, for an unshielded package, all the components, materials and welds have adequate margins of safety to insure that the package will not loss containment in the event of a 1 foot drop. Flange and bolt margins are adequate based on Reference 2 allowables, to state with confidence that after a 1 foot drop the package will not leak or expose any portion of the payload to the environs. The structural evaluation also show that shield integrity will be maintained after a drop. This is indicated by the analysis which shows the thinnest section of the Outer Shell has sufficient strength to maintain structural integrity after a drop.

An analysis on the structural capability of the Outer Top Cap was not performed, since this not considered a transportation containment boundary. However, from the configuration as depicted in Reference 5, it is assumed that after a drop the Outer Top Cap will not maintain structural integrity or confinement and will require repair prior to use.

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 3 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

IV. Engineering Evaluation:

As per the PDC (References 1 and 2), assume a perfectly flat horizontal drop onto a concrete as specified in the References 1 and 2. Assume the package impacts on all stiffener rings and exterior flanges simultaneously. This analysis models a non-shielded loaded container.

Model drop loading as a beam with multiple supports using the three moment theorem in AISC, Reference 3. Assume package is uniformly loaded, except for payload and rings, as shown in Figure 1. The payload is modeled as a concentrated load with loading at the center of gravity and the rings are modeled as concentrated loads at the supports.




Figure 1

Dimensional parameters Reference 5:

Inner containment pipe:

OD: $od_{pipe} = 64$ in

Wall thickness:

$t_{pipe} = 0.500$ in

ID: $id_{pipe} = od_{pipe} - 2 t_{pipe}$

Length of pipe: $l_{pipe} = 52$ ft + 0.75 in

Outer shell thin section:

ID: $id_{shell} = 5$ ft + 8 in

Wall thickness:

$t_{shell1} = 0.3125$ in

OD: $od_{shell1} = id_{shell} + 2 t_{shell1}$
 Outer shell thick section:

Wall thickness: $t_{shell2} = 0.5$ in

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 4 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

$$OD: \quad od_{shell2} = id_{shell} + 2 t_{shell2}$$

$$G \text{ loading from EPRI drop data (Reference 6):} \quad g_{dec} = 33.4$$

Data from weight and center of gravity calculations:

Weight of package (except stiffeners and payload) uniformly distributed:

$$W_{base} = 39,000 \text{ lbs}$$

$$\text{Uniform distributed weight of package:} \quad W_{base} = (g_{dec} W_{base}) / l_{pipe}$$

$$\text{Weight of stiffener and outer flanges rings:} \quad W_{base} = 2,085 \text{ lbs}$$

$$\text{Bottom end flange:} \quad W_4 = 2,600 \text{ lbs}$$

$$\text{Type 1 stiffener rings:} \quad W_2 = 450 \text{ lbs}$$

$$\text{Type 2a stiffener rings:} \quad W_{3a} = 525 \text{ lbs}$$

$$\text{Type 2b stiffener rings:} \quad W_{3b} = 600 \text{ lbs}$$

$$\text{Weight of payload:} \quad W_{21} = 20,000 \text{ lbs}$$

$$\text{CG of payload from center of bottom flange:} \quad cg_{pay} = 32.56 \text{ ft}$$

This puts it between Columns 15 and 16.

Moment of inertia and cross sectional area of pipe:

$$\text{Moment of inertia:} \quad I_{pipe} = \pi(od_{pipe}^4 - id_{pipe}^4)/64$$

$$\text{Cross sectional area:} \quad A_{pipe} = \pi(od_{pipe}^2 - id_{pipe}^2)/4$$

Moment of inertia and cross sectional area of thin outer shell:

$$\text{Moment of inertia:} \quad I_{os1} = \pi(od_{shell1}^4 - id_{shell}^4)/64$$

$$\text{Cross sectional area:} \quad A_{os1} = \pi(od_{shell1}^2 - id_{shell}^2)/4$$

Moment of inertia and cross sectional area of thick outer shell:

$$\text{Moment of inertia:} \quad I_{os2} = \pi(od_{shell2}^4 - id_{shell}^4)/64$$

$$\text{Cross sectional area:} \quad A_{os2} = \pi(od_{shell2}^2 - id_{shell}^2)/4$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 5 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Moment of inertia and cross sectional area of composites:

Pipe with thin outer shell:

$$\text{Moment of inertia: } I_1 = I_{\text{pipe}} + I_{\text{os1}}$$

$$\text{Cross sectional area: } A_1 = A_{\text{pipe}} + A_{\text{os1}}$$

Pipe with thick outer shell:

$$\text{Moment of inertia: } I_2 = I_{\text{pipe}} + I_{\text{os2}}$$

$$\text{Cross sectional area: } A_2 = A_{\text{pipe}} + A_{\text{os2}}$$

Length between centerline of supports:

$$l_1 = 9.750 \text{ in}$$

$$l_2 = (2 \text{ ft} + 10 \text{ in}) - l_1$$

$$l_3 = (4 \text{ ft} + 10.250 \text{ in}) - (2 \text{ ft} + 10 \text{ in})$$

$$l_4 = (5 \text{ ft} + 7.750 \text{ in}) - (4 \text{ ft} + 10.250 \text{ in})$$

$$l_5 = (8 \text{ ft} + 3.250 \text{ in}) - (5 \text{ ft} + 7.750 \text{ in})$$

$$l_6 = (10 \text{ ft} + 10.750 \text{ in}) - (8 \text{ ft} + 3.250 \text{ in})$$

$$l_7 = (13 \text{ ft} + 6.25 \text{ in}) - (10 \text{ ft} + 10.750 \text{ in})$$

$$l_8 = (16 \text{ ft} + 1.750 \text{ in}) - (13 \text{ ft} + 6.25 \text{ in})$$

$$l_9 = (18 \text{ ft} + 9.250 \text{ in}) - (16 \text{ ft} + 1.750 \text{ in})$$

$$l_{10} = (21 \text{ ft} + 4.750 \text{ in}) - (18 \text{ ft} + 9.250 \text{ in})$$

$$l_{11} = (24 \text{ ft} + 0.250 \text{ in}) - (21 \text{ ft} + 4.750 \text{ in})$$

$$l_{12} = (24 \text{ ft} + 9.750 \text{ in}) - (24 \text{ ft} + 0.250 \text{ in})$$

$$l_{13} = (27 \text{ ft} + 5.25 \text{ in}) - (24 \text{ ft} + 9.750 \text{ in})$$

$$l_{14} = (30 \text{ ft} + 0.750 \text{ in}) - (27 \text{ ft} + 5.25 \text{ in})$$

$$l_{15} = (32 \text{ ft} + 8.250 \text{ in}) - (30 \text{ ft} + 0.750 \text{ in})$$

$$l_{16} = (35 \text{ ft} + 3.750 \text{ in}) - (32 \text{ ft} + 8.250 \text{ in})$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 6 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow *SCC* Date 08/31/94

$$l_{17} = (37 \text{ ft} + 11.750 \text{ in}) - (35 \text{ ft} + 3.750 \text{ in})$$

$$l_{18} = (40 \text{ ft} + 6.750 \text{ in}) - (37 \text{ ft} + 11.750 \text{ in})$$

$$l_{19} = (43 \text{ ft} + 2.250 \text{ in}) - (40 \text{ ft} + 6.750 \text{ in})$$

$$l_{20} = (45 \text{ ft} + 9.750 \text{ in}) - (43 \text{ ft} + 2.250 \text{ in})$$

$$l_{21} = (48 \text{ ft} + 5.25 \text{ in}) - (45 \text{ ft} + 9.750 \text{ in})$$

$$l_{22} = (49 \text{ ft} + 2.750 \text{ in}) - (48 \text{ ft} + 5.25 \text{ in})$$

$$l_{23} = (51 \text{ ft} + 2.750 \text{ in}) - (49 \text{ ft} + 2.750 \text{ in})$$

$$l_{24} = (52 \text{ ft} + 0.750 \text{ in}) - (51 \text{ ft} + 2.750 \text{ in})$$

CG of pump locations relative to Column 15 and 16:

$$\text{Distance from Column 15: } d_a = cg_{\text{pay}} - (30 \text{ ft} + 0.750 \text{ in})$$

$$\text{Distance from Column 16: } d_b = (32 \text{ ft} + 8.25 \text{ in}) - cg_{\text{pay}}$$

Using the Three Moment Theorem, determine moments at the supports:

End Conditions assuming simply supported:

$$\text{At bottom end flange end: } M_a = 0.0 \text{ lbs-in}$$

At top end moments due to top caps exists, model as uniform cantilevered load of combined weight of both inner and outer top caps.

$$\text{Weight of outer top cap: } W_{19} = 1,900 \text{ lbs}$$

$$\text{Weight of inner top cap: } W_{20} = 1,500 \text{ lbs}$$

$$\text{Total weight: } W_{\text{tcap}} = W_{19} + W_{20}$$

$$\text{Length of outer top cap: } l_{\text{tcap}} = (2 \text{ ft} + 1.875 \text{ in}) + 2.25 \text{ in}$$

Assume load is distributed in a triangular shape along the length:

$$M_y = - \left(\frac{1}{2} g_{\text{dec}} W_{\text{tcap}} l_{\text{tcap}} \right)$$

$$\text{End Constraints: } M_a = 0.0 \text{ lbs-in} \quad M_y = - \left(\frac{1}{2} g_{\text{dec}} W_{\text{tcap}} l_{\text{tcap}} \right)$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 7 of 34
 Building Tank 241-SY-101 Rev. 0 Job No.
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow *SR* Date 08/31/94

Span 1 and 2

$$M_a \frac{l_1}{I_1} + 2 M_b \left(\frac{l_1}{I_1} + \frac{l_2}{I_1} \right) + M_c \frac{l_2}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_1^3}{I_1} + \frac{l_2^3}{I_1} \right)$$

Span 2 and 3

$$M_b \frac{l_2}{I_1} + 2 M_c \left(\frac{l_2}{I_1} + \frac{l_3}{I_1} \right) + M_d \frac{l_3}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_2^3}{I_1} + \frac{l_3^3}{I_1} \right)$$

Span 3 and 4

$$M_c \frac{l_3}{I_1} + 2 M_d \left(\frac{l_3}{I_1} + \frac{l_4}{I_1} \right) + M_e \frac{l_4}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_3^3}{I_1} + \frac{l_4^3}{I_1} \right)$$

Span 4 and 5

$$M_d \frac{l_4}{I_1} + 2 M_e \left(\frac{l_4}{I_1} + \frac{l_5}{I_1} \right) + M_f \frac{l_5}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_4^3}{I_1} + \frac{l_5^3}{I_1} \right)$$

Span 5 and 6

$$M_e \frac{l_5}{I_1} + 2 M_f \left(\frac{l_5}{I_1} + \frac{l_6}{I_1} \right) + M_g \frac{l_6}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_5^3}{I_1} + \frac{l_6^3}{I_1} \right)$$

Span 6 and 7

$$M_f \frac{l_6}{I_1} + 2 M_g \left(\frac{l_6}{I_1} + \frac{l_7}{I_1} \right) + M_h \frac{l_7}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_6^3}{I_1} + \frac{l_7^3}{I_1} \right)$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 8 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Span 7 and 8, Transition from thin to thick outer shell:

$$M_g \frac{l_7}{I_1} + 2 M_h \left(\frac{l_7}{I_1} + \frac{l_8}{I_2} \right) + M_i \frac{l_8}{I_2} = -\frac{w_{base}}{4} \left(\frac{l_7^3}{I_1} + \frac{l_8^3}{I_2} \right)$$

Span 8 and 9

$$M_h \frac{l_8}{I_2} + 2 M_j \left(\frac{l_8}{I_2} + \frac{l_9}{I_2} \right) + M_j \frac{l_9}{I_2} = -\frac{w_{base}}{4} \left(\frac{l_8^3}{I_2} + \frac{l_9^3}{I_2} \right)$$

Span 9 and 10

$$M_i \frac{l_9}{I_2} + 2 M_j \left(\frac{l_9}{I_2} + \frac{l_{10}}{I_2} \right) + M_k \frac{l_{10}}{I_2} = -\frac{w_{base}}{4} \left(\frac{l_9^3}{I_2} + \frac{l_{10}^3}{I_2} \right)$$

Span 10 and 11

$$M_j \frac{l_{10}}{I_2} + 2 M_k \left(\frac{l_{10}}{I_2} + \frac{l_{11}}{I_2} \right) + M_l \frac{l_{11}}{I_2} = -\frac{w_{base}}{4} \left(\frac{l_{10}^3}{I_2} + \frac{l_{11}^3}{I_2} \right)$$

Span 11 and 12

$$M_k \frac{l_{11}}{I_2} + 2 M_l \left(\frac{l_{11}}{I_2} + \frac{l_{12}}{I_2} \right) + M_m \frac{l_{12}}{I_2} = -\frac{w_{base}}{4} \left(\frac{l_{11}^3}{I_2} + \frac{l_{12}^3}{I_2} \right)$$

Span 12 and 13

$$M_l \frac{l_{12}}{I_2} + 2 M_m \left(\frac{l_{12}}{I_2} + \frac{l_{13}}{I_2} \right) + M_n \frac{l_{13}}{I_2} = -\frac{w_{base}}{4} \left(\frac{l_{12}^3}{I_2} + \frac{l_{13}^3}{I_2} \right)$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 9 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Span 13 and 14

$$M_m \frac{l_{13}}{I_2} + 2 M_n \left(\frac{l_{13}}{I_2} + \frac{l_{14}}{I_2} \right) + M_o \frac{l_{14}}{I_2} = - \frac{w_{base}}{4} \left(\frac{l_{13}^3}{I_2} + \frac{l_{14}^3}{I_2} \right)$$

Span 14 and 15, Transition from thick to thin outer shell and pump cg location:

$$M_n \frac{l_{14}}{I_2} + 2 M_o \left(\frac{l_{14}}{I_2} + \frac{l_{15}}{I_1} \right) + M_p \frac{l_{15}}{I_1} = - \frac{w_{base}}{4} \left(\frac{l_{14}^3}{I_2} + \frac{l_{15}^3}{I_1} \right) + - \frac{g_{dec} w_{21} d_a (l_{15}^2 - d_a^2)}{l_{15} I_1}$$

Span 15 and 16, pump cg location:

$$M_o \frac{l_{15}}{I_1} + 2 M_p \left(\frac{l_{15}}{I_1} + \frac{l_{16}}{I_1} \right) + M_q \frac{l_{16}}{I_1} = - \frac{w_{base}}{4} \left(\frac{l_{15}^3}{I_1} + \frac{l_{16}^3}{I_1} \right) + - \frac{g_{dec} w_{21} d_b (l_{15}^2 - d_b^2)}{l_{15} I_1}$$

Span 16 and 17

$$M_p \frac{l_{16}}{I_1} + 2 M_q \left(\frac{l_{16}}{I_1} + \frac{l_{17}}{I_1} \right) + M_r \frac{l_{17}}{I_1} = - \frac{w_{base}}{4} \left(\frac{l_{16}^3}{I_1} + \frac{l_{17}^3}{I_1} \right)$$

Span 17 and 18

$$M_q \frac{l_{17}}{I_1} + 2 M_r \left(\frac{l_{17}}{I_1} + \frac{l_{18}}{I_1} \right) + M_s \frac{l_{18}}{I_1} = - \frac{w_{base}}{4} \left(\frac{l_{17}^3}{I_1} + \frac{l_{18}^3}{I_1} \right)$$

Span 18 and 19

$$M_r \frac{l_{18}}{I_1} + 2 M_s \left(\frac{l_{18}}{I_1} + \frac{l_{19}}{I_1} \right) + M_t \frac{l_{19}}{I_1} = - \frac{w_{base}}{4} \left(\frac{l_{18}^3}{I_1} + \frac{l_{19}^3}{I_1} \right)$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 10 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Span 19 and 20

$$M_s \frac{l_{19}}{I_1} + 2 M_c \left(\frac{l_{19}}{I_1} + \frac{l_{20}}{I_1} \right) + M_u \frac{l_{20}}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_{19}^3}{I_1} + \frac{l_{20}^3}{I_1} \right)$$

Span 20 and 21

$$M_c \frac{l_{20}}{I_1} + 2 M_u \left(\frac{l_{20}}{I_1} + \frac{l_{21}}{I_1} \right) + M_v \frac{l_{21}}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_{20}^3}{I_1} + \frac{l_{21}^3}{I_1} \right)$$

Span 21 and 22

$$M_u \frac{l_{21}}{I_1} + 2 M_v \left(\frac{l_{21}}{I_1} + \frac{l_{22}}{I_1} \right) + M_w \frac{l_{22}}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_{21}^3}{I_1} + \frac{l_{22}^3}{I_1} \right)$$

Span 22 and 23

$$M_v \frac{l_{22}}{I_1} + 2 M_w \left(\frac{l_{22}}{I_1} + \frac{l_{23}}{I_1} \right) + M_x \frac{l_{23}}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_{22}^3}{I_1} + \frac{l_{23}^3}{I_1} \right)$$

Span 23 and 24

$$M_w \frac{l_{23}}{I_1} + 2 M_x \left(\frac{l_{23}}{I_1} + \frac{l_{24}}{I_1} \right) + M_y \frac{l_{24}}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_{23}^3}{I_1} + \frac{l_{24}^3}{I_1} \right)$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 11 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow *Sec* Date 08/31/94

Table I

Moments	lbs·in
M _a	0
M _b	-73,228
M _c	-121,109
M _d	-55,388
M _e	-126,800
M _f	-184,611
M _g	-169,175
M _h	-173,106
M _i	-173,306
M _j	-168,088
M _k	-188,760
M _l	-111,291
M _m	-175,496
M _n	-40,985
M _o	-694,981
M _p	-304,407
M _q	-141,437
M _r	-181,906
M _s	-166,535
M _t	-170,304
M _u	-186,666
M _v	-117,448
M _w	-129,289
M _x	88,562
M _y	-1 x 10 ⁶

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 12 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow *SR* Date 08/31/94

Maximum moments between supports and reactions at supports:

Span 1, $M_a < M_b$:

$$M_1 = \frac{w_{base} l_1^2}{8} - \frac{M_a + M_b}{2} + \frac{(M_a - M_b)^2}{2 w_{base} l_1^2}$$

$$M_1 = 74,917 \text{ lbs-in}$$

$$R_a = \frac{w_{base} l_1}{2} - \frac{M_a - M_b}{l_1} + g_{dec} W_4$$

$$R_a = 89,494 \text{ lbs}$$

Span 2, $M_b < M_c$:

$$M_2 = \frac{w_{base} l_2^2}{8} - \frac{M_b + M_c}{2} + \frac{(M_b - M_c)^2}{2 w_{base} l_2^2}$$

$$M_2 = 251,367 \text{ lbs-in}$$

$$R_b = \left(\frac{w_{base} l_1}{8} + \frac{M_a - M_b}{l_1} \right) + \left(\frac{w_{base} l_2}{8} - \frac{M_b - M_c}{l_2} \right) + g_{dec} W_{3a}$$

$$R_b = 31,932 \text{ lbs}$$

Span 3, $M_c > M_d$:

$$M_3 = \frac{w_{base} l_3^2}{8} - \frac{M_c + M_d}{2} + \frac{(M_c - M_d)^2}{2 w_{base} l_3^2}$$

$$M_3 = 243,273 \text{ lbs-in}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 13 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow *SR* Date 08/31/94

$$R_c = \left(\frac{w_{base} l_2}{8} + \frac{M_b - M_c}{l_2} \right) + \left(\frac{w_{base} l_3}{8} + \frac{M_c - M_d}{l_3} \right) + g_{dec} W_2$$

$$R_c = 26,935 \text{ lbs}$$

Span 4, $M_d < M_e$:

$$M_4 = \frac{w_{base} l_4^2}{8} - \frac{M_d + M_e}{2} + \frac{(M_d - M_e)^2}{2 w_{base} l_4^2}$$

$$M_4 = 128,166 \text{ lbs-in}$$

$$R_d = \left(\frac{w_{base} l_3}{8} - \frac{M_c - M_d}{l_3} \right) + \left(\frac{w_{base} l_4}{8} - \frac{M_d - M_e}{l_4} \right) + g_{dec} W_{3b}$$

$$R_d = 24,029 \text{ lbs}$$

Span 5, $M_e < M_f$:

$$M_5 = \frac{w_{base} l_5^2}{8} - \frac{M_e + M_f}{2} + \frac{(M_e - M_f)^2}{2 w_{base} l_5^2}$$

$$M_5 = 415,117 \text{ lbs-in}$$

$$R_e = \left(\frac{w_{base} l_4}{8} + \frac{M_d - M_e}{l_4} \right) + \left(\frac{w_{base} l_5}{8} - \frac{M_e - M_f}{l_5} \right) + g_{dec} W_{3b}$$

$$R_e = 36,407 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 14 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Span 6, $M_f > M_g$:

$$M_6 = \frac{w_{base} l_6^2}{8} - \frac{M_f + M_g}{2} + \frac{(M_f - M_g)^2}{2 w_{base} l_6^2}$$

$$M_6 = 435,555 \text{ lbs-in}$$

$$R_f = \left(\frac{w_{base} l_5}{8} + \frac{M_e - M_f}{l_5} \right) + \left(\frac{w_{base} l_6}{8} - \frac{M_f - M_g}{l_6} \right) + g_{dec} W_2$$

$$R_f = 33,775 \text{ lbs}$$

Span 7, $M_g < M_h$:

$$M_7 = \frac{w_{base} l_7^2}{8} - \frac{M_g + M_h}{2} + \frac{(M_g - M_h)^2}{2 w_{base} l_7^2}$$

$$M_7 = 429,749 \text{ lbs-in}$$

$$R_g = \left(\frac{w_{base} l_6}{8} - \frac{M_f - M_g}{l_6} \right) + \left(\frac{w_{base} l_7}{8} - \frac{M_g - M_h}{l_7} \right) + g_{dec} W_2$$

$$R_g = 31,815 \text{ lbs}$$

Span 8, $M_h < M_i$:

$$M_8 = \frac{w_{base} l_8^2}{8} - \frac{M_h + M_i}{2} + \frac{(M_h - M_i)^2}{2 w_{base} l_8^2}$$

$$M_8 = 431,811 \text{ lbs-in}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 15 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

$$R_h = \left(\frac{w_{base} l_7}{8} + \frac{M_g - M_h}{l_7} \right) + \left(\frac{w_{base} l_8}{8} - \frac{M_g - M_h}{l_8} \right) + g_{dec} W_2$$

$$R_h = 31,449 \text{ lbs}$$

Span 9, $M_i > M_j$:

$$M_9 = \frac{w_{base} l_9^2}{8} - \frac{M_i + M_j}{2} + \frac{(M_i - M_j)^2}{2 w_{base} l_9^2}$$

$$M_9 = 429,308 \text{ lbs-in}$$

$$R_i = \left(\frac{w_{base} l_8}{8} + \frac{M_h - M_i}{l_8} \right) + \left(\frac{w_{base} l_9}{8} + \frac{M_i - M_j}{l_9} \right) + g_{dec} W_2$$

$$R_i = 31,290 \text{ lbs}$$

Span 10, $M_j < M_k$:

$$M_{10} = \frac{w_{base} l_{10}^2}{8} - \frac{M_j + M_k}{2} + \frac{(M_j - M_k)^2}{2 w_{base} l_{10}^2}$$

$$M_{10} = 437,132 \text{ lbs-in}$$

$$R_j = \left(\frac{w_{base} l_9}{8} - \frac{M_i - M_j}{l_9} \right) + \left(\frac{w_{base} l_{10}}{8} - \frac{M_j - M_k}{l_{10}} \right) + g_{dec} W_2$$

$$R_j = 30,959 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 16 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Span 11, $M_k > M_l$:

$$M_{11} = \frac{w_{base} l_{11}^2}{8} - \frac{M_k + M_l}{2} + \frac{(M_k - M_l)^2}{2 w_{base} l_{11}^2}$$

$$M_{11} = 410,080 \text{ lbs-in}$$

$$R_k = \left(\frac{w_{base} l_{10}}{8} + \frac{M_j - M_k}{l_{10}} \right) + \left(\frac{w_{base} l_{11}}{8} + \frac{M_k - M_l}{l_{11}} \right) + G_{dec} W_2$$

$$R_k = 29,646 \text{ lbs}$$

Span 12, $M_l < M_m$:

$$M_{12} = \frac{w_{base} l_{12}^2}{8} - \frac{M_l + M_m}{2} + \frac{(M_l - M_m)^2}{2 w_{base} l_{12}^2}$$

$$M_{12} = 177,869 \text{ lbs-in}$$

$$R_l = \left(\frac{w_{base} l_{11}}{8} - \frac{M_k - M_l}{l_{11}} \right) + \left(\frac{w_{base} l_{12}}{8} - \frac{M_l - M_m}{l_{12}} \right) + G_{dec} W_{3a}$$

$$R_l = 23,921 \text{ lbs}$$

Span 13, $M_m > M_n$:

$$M_{13} = \frac{w_{base} l_{13}^2}{8} - \frac{M_m + M_n}{2} + \frac{(M_m - M_n)^2}{2 w_{base} l_{13}^2}$$

$$M_{13} = 371,218 \text{ lbs-in}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 17 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

$$R_m = \left(\frac{w_{base} l_{12}}{8} + \frac{M_l - M_m}{l_{12}} \right) + \left(\frac{w_{base} l_{13}}{8} + \frac{M_m - M_n}{l_{13}} \right) + g_{dec} W_{3a}$$

$$R_m = 30,709 \text{ lbs}$$

Span 14, $M_n < M_o$:

$$M_{14} = \frac{w_{base} l_{14}^2}{8} - \frac{M_n + M_o}{2} + \frac{(M_n - M_o)^2}{2 w_{base} l_{14}^2}$$

$$M_{14} = 729,957 \text{ lbs-in}$$

$$R_n = \left(\frac{w_{base} l_{13}}{8} - \frac{M_m - M_n}{l_{13}} \right) + \left(\frac{w_{base} l_{14}}{8} - \frac{M_j - M_k}{l_{14}} \right) + g_{dec} W_2$$

$$R_n = 35,063 \text{ lbs}$$

Span 15, $M_o > M_p$, Span where pump is located:

$$\text{Location of maximum moment: } x_{max} = l_{15}/2 + [(M_o - M_p)/(w_{base} l_{15})]$$

$$\text{Moment due to pump at location: } M_{pump} = (g_{dec} W_{21} d_b x_{max})/l_{15}$$

$$\text{Reaction at o due to pump: } R_{po} = (g_{dec} W_{21} d_b)/l_{15}$$

$$M_{15} = \frac{w_{base} l_{15}^2}{8} - \frac{M_o + M_p}{2} + \frac{(M_o - M_p)^2}{2 w_{base} l_{15}^2} + M_{pump}$$

$$M_{15} = 1,113,236 \text{ lbs-in}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DR0P-01 Page 18 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

$$R_o = \left(\frac{w_{base} l_{14}}{8} + \frac{M_n - M_o}{l_{14}} \right) + \left(\frac{w_{base} l_{15}}{8} + \frac{M_o - M_p}{l_{15}} \right) + R_{po} + g_{dec} W_2$$

$$R_o = 72,258 \text{ lbs}$$

Span 16, $M_p > M_q$:

$$M_{16} = \frac{w_{base} l_{16}^2}{8} - \frac{M_p + M_q}{2} + \frac{(M_p - M_q)^2}{2 w_{base} l_{16}^2}$$

$$M_{16} = 487,945 \text{ lbs-in}$$

Reaction at p due to pump: $R_{pp} = (g_{dec} W_{21} d_a) / l_{15}$

$$R_p = \left(\frac{w_{base} l_{15}}{8} - \frac{M_o - M_p}{l_{15}} \right) + R_{pp} + \left(\frac{w_{base} l_{16}}{8} + \frac{M_p - M_q}{l_{16}} \right) + g_{dec} W_2$$

$$R_p = 674,229 \text{ lbs}$$

Span 17, $M_q < M_r$:

$$M_{17} = \frac{w_{base} l_{17}^2}{8} - \frac{M_q + M_r}{2} + \frac{(M_q - M_r)^2}{2 w_{base} l_{17}^2}$$

$$M_{17} = 428,935 \text{ lbs-in}$$

$$R_q = \left(\frac{w_{base} l_{16}}{8} - \frac{M_p - M_q}{l_{16}} \right) + \left(\frac{w_{base} l_{17}}{8} - \frac{M_q - M_r}{l_{17}} \right) + g_{dec} W_2$$

$$R_q = 35,489 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 19 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Span 18, $M_r > M_s$:

$$M_{18} = \frac{w_{base} l_{18}^2}{8} - \frac{M_r + M_s}{2} + \frac{(M_r - M_s)^2}{2 w_{base} l_{18}^2}$$

$$M_{18} = 424,740 \text{ lbs-in}$$

$$R_r = \left(\frac{w_{base} l_{17}}{8} + \frac{M_q - M_r}{l_{17}} \right) + \left(\frac{w_{base} l_{18}}{8} + \frac{M_r - M_s}{l_{18}} \right) + g_{dec} W_2$$

$$R_r = 32,218 \text{ lbs}$$

Span 19, $M_s < M_t$:

$$M_{19} = \frac{w_{base} l_{19}^2}{8} - \frac{M_s + M_t}{2} + \frac{(M_s - M_t)^2}{2 w_{base} l_{19}^2}$$

$$M_{19} = 427,028 \text{ lbs-in}$$

$$R_s = \left(\frac{w_{base} l_{18}}{8} - \frac{M_r - M_s}{l_{18}} \right) + \left(\frac{w_{base} l_{19}}{8} - \frac{M_s - M_t}{l_{19}} \right) + g_{dec} W_2$$

$$R_s = 31,695 \text{ lbs}$$

Span 20, $M_t < M_u$:

$$M_{20} = \frac{w_{base} l_{20}^2}{8} - \frac{M_t + M_u}{2} + \frac{(M_t - M_u)^2}{2 w_{base} l_{20}^2}$$

$$M_{20} = 437,154 \text{ lbs-in}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 20 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

$$R_c = \left(\frac{w_{base} l_{19}}{8} + \frac{M_g - M_c}{l_{19}} \right) + \left(\frac{w_{base} l_{20}}{8} - \frac{M_c - M_u}{l_{20}} \right) + g_{dec} W_2$$

$$R_c = 31,050 \text{ lbs}$$

Span 21, $M_u > M_v$:

$$M_{21} = \frac{w_{base} l_{21}^2}{8} - \frac{M_u + M_v}{2} + \frac{(M_u - M_v)^2}{2 w_{base} l_{21}^2}$$

$$M_{21} = 411,820 \text{ lbs-in}$$

$$R_u = \left(\frac{w_{base} l_{20}}{8} + \frac{M_c - M_u}{l_{20}} \right) + \left(\frac{w_{base} l_{21}}{8} + \frac{(M_u - M_v)}{l_{21}} \right) + g_{dec} W_2$$

$$R_u = 29,771 \text{ lbs}$$

Span 22, $M_v < M_w$:

$$M_{22} = \frac{w_{base} l_{22}^2}{8} - \frac{M_v + M_w}{2} + \frac{(M_v - M_w)^2}{2 w_{base} l_{22}^2}$$

$$M_{22} = 147,263 \text{ lbs-in}$$

$$R_v = \left(\frac{w_{base} l_{21}}{8} - \frac{M_u - M_v}{l_{21}} \right) + \left(\frac{w_{base} l_{22}}{8} - \frac{M_v - M_w}{l_{22}} \right) + g_{dec} W_{3b}$$

$$R_v = 31,677 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 21 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow *SR* Date 08/31/94

Span 23, $M_w > M_x$:

$$M_{23} = \frac{w_{base} l_{23}^2}{8} - \frac{M_w + M_x}{2} + \frac{(M_w - M_x)^2}{2 w_{base} l_{23}^2}$$

$$M_{23} = 190,242 \text{ lbs-in}$$

$$R_w = \left(\frac{w_{base} l_{22}}{8} + \frac{M_v - M_w}{l_{22}} \right) + \left(\frac{w_{base} l_{23}}{8} + \frac{(M_w - M_x)}{l_{23}} \right) + g_{dec} W_{3b}$$

$$R_w = 20,940 \text{ lbs}$$

Span 24, $M_x < M_y$:

$$M_{24} = \frac{w_{base} l_{24}^2}{8} - \frac{M_x + M_y}{2} + \frac{(M_x - M_y)^2}{2 w_{base} l_{24}^2}$$

$$M_{24} = 3,703,167 \text{ lbs-in}$$

$$R_x = \left(\frac{w_{base} l_{23}}{8} - \frac{M_w - M_x}{l_{23}} \right) + \left(\frac{w_{base} l_{24}}{8} - \frac{(M_x - M_y)}{l_{24}} \right) + g_{dec} W_2$$

$$R_x = -82,350 \text{ lbs}$$

Reaction at Column 25:

$$R_y = \frac{w_{base} l_{24}}{8} + \frac{M_x - M_y}{l_{24}} + g_{dec} W_{tcap}$$

$$R_y = 231,485 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 22 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Maximum loading on ring:

Maximum loading on ring at Column 16, R_p . Model as combined loading of Ring loaded as loading smeared over entire volume of the ring Reference 7, pages 176 and 178, Case 22 and opposed by a reactive load transferred by tangential shear Roark Case 24. Also assume ring acts as a curved beam (shown Figures 2 and 3).




Figure 2




Figure 3

Nominal radius of ring:

OD of ring: $od_{ring} = 5 \text{ ft} + 11.625 \text{ in}$

$R_{ring} = od_{ring} / 2$ $R_{ring} = 2.98 \text{ ft}$

Width of ring: $b_{ring} = 1.5 \text{ in}$

Distributed weight of ring throughout cross section:

$w_{ring} = R_p / (\pi R_{ring}^2 b_{ring})$ $w_{ring} = 112 \text{ lbs-in}^3$

Case 20 Maximum Loading at bottom of ring:

$\alpha = 0 \text{ deg}$ $\theta = 0 \text{ deg}$

$u = \cos(\alpha)$ $s = \sin(\theta)$ $c = \cos(\theta)$ $z = \sin(\alpha)$

Maximum moment loading: $M_{1ring} = \frac{1}{2} w_{ring} R_{ring}^3$ $M_{1ring} = 3.84 \times 10^6 \text{ lbs}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 23 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Circumferential Tension:

$$T_{1ring} = w_{ring} R_{ring}^2 (1 + \frac{1}{2} u - \frac{1}{2} \pi z + \frac{1}{2} \alpha z)$$

$$T_{1ring} = 178,845 \text{ lbs/in}$$

Radial Shear:

$$V_{1ring} = w_{ring} R_{ring}^2 (\frac{1}{2} \alpha u + \frac{1}{2} z - \frac{1}{2} \pi u)$$

$$V_{1ring} = -224,743 \text{ lbs/in}$$

Case 25, Opposing moment at bottom of ring, $\theta = 0^\circ$, $\alpha = 0^\circ$

Counteracting Moment:

$$M_{2ring} = - [R_p R_{ring} [0.23868 u - \frac{1}{2} s + 0.15915 (a z + \theta s + c - u c^2)]]$$

$$M_{2ring} = -5.76 \times 10^6 \text{ lbs-in}$$

Circumferential Tension:

$$T_{2ring} = R_p [0.15915 (\alpha z - u c^2) - 0.07958 u]$$

$$T_{2ring} = -160,959 \text{ lbs}$$

Radial Shear:

$$V_{2ring} = - [R_p [0.15915 (\alpha u - \frac{1}{2} z + z c^2) - \frac{1}{2} u]]$$

$$V_{2ring} = 337,115 \text{ lbs}$$

Resultant loading:

Maximum Moment:

$$M_{rring} = M_{1ring} b_{ring} + M_{2ring}$$

$$M_{rring} = 1,266 \text{ lbs-in}$$

Circumferential Tension:

$$T_{rring} = T_{1ring} b_{ring} + T_{2ring}$$

$$T_{rring} = 107,309 \text{ lbs}$$

Radial Shear:

$$V_{rring} = V_{1ring} b_{ring} + V_{2ring}$$

$$V_{rring} = 0 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 24 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow *SR* Date 08/31/94

Geometric parameters of pipe:

Inside radius of ring is id of pipe: $r_{ring} = (od_{pipe} - t_{pipe})/2$

Normal depth of ring including pipe thickness:

$$h_{ring} = R_{ring} - r_{ring} \quad h_{pipe} = 4.06 \text{ in}$$

Neutral axis of ring:

$$I_{na} = \frac{h_{ring}}{\ln\left(\frac{R_{ring}}{r_{ring}}\right)}$$

CG of ring:

$$r_{cg} = r_{ring} + (h_{ring}/2)$$

Eccentricity: $ecc = r_{cg} - r_{na}$

Cross sectional area: $A_{ring} = h_{ring} b_{ring}$

Stresses in ring:

Bending stress:

$$\sigma_{bottom} = \frac{M_{ring} (I_{na} I_{ring})}{A_{ring} ecc I_{ring}}$$

$$\sigma_{bottom} = 320 \text{ psi}$$

Tangential stress:

$$\sigma_{tan} = T_{ring}/A_{ring} \quad \sigma_{tan} = 17,610 \text{ psi}$$

Maximum shear stress:

$$\tau_{ring} = 2 V_{ring}/A_{ring} \quad \tau_{ring} = 0 \text{ psi}$$

Total stress:

$$\sigma_{tot} = \sigma_{bottom} + \sigma_{tan} + \tau_{ring} \quad \sigma_{tot} = 17,929 \text{ psi}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 25 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

ASME allowable from previous data: $s_a = 23,270$ psi

Margin of Safety on inner pipe:

$$MS_{pipe} = (s_a / \sigma_{tot}) - 1 \qquad MS_{pipe} = 0.3 \qquad \text{OK}$$

Maximum loading on inner containment pipe between rings:




Figure 4

Maximum bending between Columns 24 and 25:

$$\sigma_{bmax} = \frac{M_{24} \left(\frac{od_{pipe}}{2} \right)}{I_{pipe}}$$

$$\sigma_{bmax} = 2,357 \text{ psi}$$

Short beam criteria applies here, therefore must consider maximum shear.

Maximum shear: $\tau_{ymax} = 2 R_y / A_{pipe} \qquad \tau_{ymax} = 4,642 \text{ psi}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 26 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Bending at support:

$$\sigma_{by} = \frac{|M_y| \frac{od_{pipe}}{2}}{I_{pipe}}$$

$\sigma_{by} = 678 \text{ psi}$

Total stress at pipe section:

$$\sigma_{ytot} = \sigma_{bmax} + \tau_{ymax} \qquad \sigma_{ytot} = 6,998 \text{ psi}$$

Margin of Safety:

$$MS_{ypipe} = (s_a / \sigma_{ytot}) - 1 \qquad MS_{ypipe} = 2.33 \quad \text{OK}$$

Loading on Inner Blind Flange Plate:

Assuming inside pipe welds carry the entire load determine weld strength.




Figure 5

Plate thickness: $t_{bef} = 2.0 \text{ in}$

From ASME, allowable at joint discontinuities: $1.5 s_a = 34,905 \text{ psi}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 27 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Since welds are 100% radiographed assume full strength of fillets.

Weld size, assuming on one weld: $w_w = 0.500$ in

Weld diameter is assumed as same size as pipe: $d_w = id_{pipe}$

Circumference of weld (one side only): $c_w = \pi d_w$

Pressure loading from pressure calculations at pipe joint discontinuity:

$$s_{btot} = 10,929 \text{ psi}$$

Shear area of weld: $A_w = 0.707 w_w c_w$

Maximum shear due to deflection of pipe during drop:

Weight of inner blind flange: $W_6 = 1,800$ lbs

$$\tau_{drop} = (2 g_{dec} W_6) / A_w \quad \tau_{drop} = 1,719 \text{ psi}$$

Total stress on weld:

$$\sigma_{wtot} = \tau_{drop} + s_{btot} \quad \sigma_{wtot} = 12,648 \text{ psi}$$

Margin of Safety:

$$MS_{befw} = (1.5 s_w / \sigma_{wtot}) - 1 \quad MS_{befw} = 1.76 \quad \text{OK}$$

Top Cap Loading:

Retaining Ring Loading:

Since fitup tolerance of retaining ring is tighter than for bolts, retaining ring takes up all shear loading from the drop.

Weight of inner top cap: $W_{20} = 1,500$ lbs

ID of retaining ring: $id_{itcrr} = 5 \text{ ft} + 3 \text{ in}$

Wall thickness: $t_{itcrr} = 0.375$ in

OD of retaining ring: $od_{itcrr} = id_{itcrr} + 2 t_{itcrr}$

Cross sectional area of ring:

$$A_{itcrr} = \pi (od_{itcrr}^2 - id_{itcrr}^2) / 4$$

Maximum shearing load on the ring cross section:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 28 of 34
 Building Tank 241-SY-101 Rev. 0 Job No.
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

$$\tau_{rrmax} = (2 g_{dec} W_{20}) / A_{itcrr}$$

$$\tau_{rrmax} = 1,342 \text{ psi}$$

Margin of Safety:

$$MS_{rrs} = (s_y / \tau_{rrmax}) - 1 \quad MS_{rrs} = 16.34 \quad \text{OK}$$

Loading on the bolts:




Figure 6

CG of top cap from inner flange face: $cg_{itc} = 1.39 \text{ ft}$

Bolt parameters:

Number of bolts: $n_{bitc} = 28$

Nominal diameter of bolts: $d_{bitc} = 1 \text{ in}$

Tensile stress area of each bolt (Reference 12, page 1278):

$$A_b = 0.7854 (d_{bitc} - 0.9743 \text{ in}/8)^2$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 29 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Allowable tensile strength of bolts: $\sigma_{\text{bten}} = 55,000$ psi

Total preload and pressure load per bolt from ASME evaluation:

$$w_{\text{btot}} = 19,696 \text{ lbs}$$

Angle from vertical flange axis: $\theta_1 = 6.43$ deg

Angle of bolt spacing: $\theta_2 = 12.83$ deg

Diameter of bolt circle: $d_{\text{bc}} = 61$ in

Diameter of flange: $d_{\text{flange}} = id_{\text{iterr}}$

Distance from Pivot to bolts 14 to 1:

$$r_{\text{bc}} = d_{\text{bc}}/2 \quad r_{\text{flange}} = d_{\text{flange}}/2$$

Perpendicular distance:

Distance from pivot to centerline of bolt 14:

$$r_{14} = r_{\text{flange}} - r_{\text{bc}} \cos(\theta_1)$$

Distance from pivot to centerline of bolt 13:

$$r_{13} = r_{\text{flange}} - r_{\text{bc}} \cos(\theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 12:

$$r_{12} = r_{\text{flange}} - r_{\text{bc}} \cos(2 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 11:

$$r_{11} = r_{\text{flange}} - r_{\text{bc}} \cos(3 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 10:

$$r_{10} = r_{\text{flange}} - r_{\text{bc}} \cos(4 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 9:

$$r_9 = r_{\text{flange}} - r_{\text{bc}} \cos(5 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 8:

$$r_8 = r_{\text{flange}} - r_{\text{bc}} \cos(6 \theta_2 + \theta_1)$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 30 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Distance from pivot to centerline of bolt 7:

$$r_7 = r_{flange} + r_{bc} \sin(\theta_1)$$

Distance from pivot to centerline of bolt 6:

$$r_6 = r_{flange} + r_{bc} \sin(\theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 5:

$$r_5 = r_{flange} + r_{bc} \sin(2 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 4:

$$r_4 = r_{flange} + r_{bc} \sin(3 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 3:

$$r_3 = r_{flange} + r_{bc} \sin(4 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 2:

$$r_2 = r_{flange} + r_{bc} \sin(5 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 1:

$$r_1 = r_{flange} + r_{bc} \sin(6 \theta_2 + \theta_1)$$

By symmetry bolts distances 15 to 28 are equal to 14 to 1, respectively.

Moment due to drop due to eccentric loading of bolts:

$$M_{bitc} = g_{dec} W_{20} cg_{itc}$$

Tensile load on bolt 1 (highest loading):

$$F_{bitc1} = \frac{r_1 M_{bitc}}{2 \left(r_1^2 + r_2^2 + r_3^2 + r_4^2 + r_5^2 + r_6^2 + r_7^2 + r_8^2 + r_9^2 + r_{10}^2 + r_{11}^2 + r_{12}^2 + r_{13}^2 + r_{14}^2 \right)}$$

$$F_{bitc1} = 1,285 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 31 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Total bolt load:

$$W_{itcb} = W_{btot} + F_{bitct} \quad W_{itcb} = 20,981 \text{ lbs}$$

Tensile stress on bolt:

$$\sigma_{bolt} = W_{itcb}/A_b \quad \sigma_{bolt} = 34,637 \text{ psi}$$

Margin of Safety based on bolt ultimate:

$$MS_{bolt} = (\sigma_{bten}/\sigma_{bolt}) - 1 \quad MS_{bolt} = 0.59 \quad \text{OK}$$

Outer Shell Loading from lead:

Model longest thinnest section only:




Figure 7

ID of shell: $id_{shell} = 5 \text{ ft} + 8 \text{ in}$

Wall thickness: $t_{516sh} = 0.3125 \text{ in}$

OD of shell: $od_{shell} = id_{shell} + 2 t_{516sh}$

Inner cross sectional void area of shell:

$$A_{crsh} = \pi(id_{shell}^2 - od_{pipe}^2)/4$$

Longest length between supports: $15_6 = 2.5 \text{ ft}$

Mid point of length: $z_{sh} = 15_6/2$

Gap of void: $gap = (id_{shell} - od_{pipe})/2 \quad gap = 2 \text{ in}$

Radius of lead: $r_{pb} = od_{pipe}/2 + gap$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 32 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Angle of evaluation: $\theta_{pb} = 180$ deg

Poissin's ratio for carbon steel (Reference 8): $\nu_{cstl} = 0.3$

Density of lead (Reference 13, page 398): $\rho_{pb} = 0.4096$ lbs/in³

Assume 65% density of shot: $\rho_{shot} = 0.65 \rho_{pb}$

Weight of lead between supports:

$$W_{spb} = A_{crsh} \rho_{shot} 15_6$$

$$W_{spb} = 3,312 \text{ lbs}$$

Assume weight of lead smeared over the entire cross sectional area:

$$\text{Cross sectional area: } A_{smr} = (\pi/4)od_{shell}^2$$

$$\text{Smear density: } \rho_{smr} = W_{spb} / (A_{smr} 15_6)$$

Load between supports at angle of evaluation, stress due to lead slump modeled using membrane theory of pipe filled between supports with a flowable material.

Tangential stress:

$$\sigma_t = \frac{g_{dec} \rho_{smr} r_{pb}^2}{t_{516} sh} (1 - \cos(\theta_{pb}))$$

$$\sigma_t = 7,376 \text{ psi}$$

Longitudinal stress:

$$\sigma_l = \frac{g_{dec} \rho_{smr}}{t_{516} sh} \left(\frac{z_{sh}^2}{2} \right) \cos(\theta_{pb}) + \rho_{cstl} \sigma_t$$

$$\sigma_l = 1,854 \text{ psi}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 33 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Shear stress:

$$\sigma_{shr} = \frac{-\mathcal{G}_{dec} P_{smr}}{t_{s16} sh} \left(\frac{z_{sh}^2}{2} \right) \sin(\theta_{pb})$$

$$\sigma_{shr} = 0 \text{ psi}$$

Total stress at maximum deflection (at center of length):

$$\sigma_{pbtot} = \sigma_t + \sigma_l + \sigma_{shr}$$

$$\sigma_{pbtot} = 9,230 \text{ psi}$$

Margin of Safety:

$$MS_{pb} = (s_e / \sigma_{pbtot}) - 1$$

$$MS_{pb} = 1.52 \text{ OK}$$

Weld on Stiffener Rings:

Evaluate circumferential fillet welds joining the stiffening rings and end plates to the inner containment pipe. Assume welds are 1/2 inch fillets both sides.

Weld size: $w_{srw} = 0.500 \text{ in}$

Diameter of weld is OD of pipe: $od_{pipe} = 64 \text{ in}$

Largest moment on outer top end plate, model as pipe welded to stiffening ring with no support from outer shell or top cap flange.

Evaluate weld per AWS, Reference 11, page 7.4-7.




Figure 8

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-01 Page 34 of 34
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded With No Shielding (101-SY Package)
 Originator S. S. Shiraga Date 07/30/94
 Checker S. R. Crow Date 08/31/94

Treat the welds as a line in bending:

$$S_{weld} = \pi \frac{od_{pipe}^2}{4}$$

Linear Force on welds, assuming welds equally share the load:

$$f_b = \left| \frac{M_y}{2 S_{weld}} \right|$$

$$f_b = 165 \text{ lbs/in}$$

AWS allowable for fillet welds used in Bridge Construction for ASTM A-36 material with thickness greater than 1 inch using E60 or SAW-1 Electrodes and assuming parallel loading, Reference 10 and Reference 11, page 7.4-8.

$$s_{aws} = 8,800 \text{ psi}$$

Allowable line load:

$$f_{aws} = s_{aws} (0.707 w_{srw}) \quad f_{aws} = 3,111 \text{ lbs/in}$$

Margin of Safety:

$$MS_{srw} = (f_{aws}/f_b) - 1 \quad MS_{srw} = 17.8 \quad \text{OK}$$

6.4.10 Drop Evaluation Loaded and Fully Shielded (101-SY)

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 1 of 32
Building Tank 241-SY-101 Rev. 0 Job No. _____
Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
Originator S. S. Shiraga Date 07/31/94
Checker S. R. Crow Date 08/31/94

I. Objectives:

The objective of this evaluation is to assess the ability of the 101-SY fully shielded packaging to maintain leak tightness and structural integrity after a 1 foot flat drop onto a horizontal 12 inch thick concrete surface (Reference 1 and 2). Maintenance of leak tightness and structural integrity are demonstrated by confirming the stresses in critical components and at critical locations of the package are adequately below the values established in Reference 8.


II. References:

1. WHC-SD-TP-019, Rev 0, "Packaging Design Criteria Transfer and Disposal of Hydrogen Mixer Pump".
2. WHC, Engineering Change Notice 606676, dated June 27, 1994.
3. American Institute of Steel Construction, Steel Construction Manual, 9th Edition.
4. US-NRC, 10 CFR Part-71, "Packaging and Transportation of Radioactive Materials".
5. WHC Drawing, No. H-2-83734, "Hydrogen Mixer Pump Storage Container".
6. EPRI NP-4830, "The Effect of Target Hardness on the Structural Design of Concrete Storage Pads for Spent Fuel Casks".
7. Roark, Formulas for Stress and Strain, 4th Edition.
8. American Society of Mechanical Engineers, Boiler and Pressure Vessels, Section VIII, Division 2, 1989.
9. American Society of Mechanical Engineers, Boiler and Pressure Vessels, Section VIII, Division 1, 1989.
10. American Welding Society, AWS/ANSI D 1.1, "Structural Welding Code".
11. Blodgett, O. W., Design of Welded Structures, 1976.
12. ASTM, American Society of Testing and Materials, Annual Book of ASTM Standards, Volume 15.08.
13. Industrial Press, Machinery's Handbook, 20th Edition.

III. Results and Conclusions:

As with the results for an unshielded package, results for a fully shielded package show that all components, materials and welds have adequate margins of

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 2 of 32
Building Tank 241-SY-101 Rev. 0 Job No. _____
Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
Originator S. S. Shiraga Date 07/31/94
Checker S. R. Crow  Date 08/31/94

safety to insure that the package will not lose containment in the event of a 1 ft drop. In most cases the stresses are somewhat lower since with the heavier package the deceleration factors are less (shown in the G loading evaluation). This is due primarily to the fundamental axioms in Reference 6. The EPRI report (Reference 6) considers that due to the hardness and stiffness of a cask, the concrete pad will fail absorbing most of the energy of impact. Subsequently, the heavier the cask the more the concrete fails absorbing more energy. This results in lower deceleration loads being transmitted to the package or cask. Consequently, since the fully shielded package is heavier than the unshielded package less deceleration loading is experienced by the fully shielded package which results in lower stress values.

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 3 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

IV. Engineering Evaluation:

As per the PDC (Reference 1), assume a perfectly flat horizontal drop onto a concrete as specified in the Reference 1. Assume the package impacts on all stiffener rings and exterior flanges simultaneously. This analysis models a fully shielded loaded container.

Model drop loading as a beam with multiple supports using the three moment theorem in AISC, Reference 2. Assume package is uniformly loaded, except for payload and rings. The payload is modeled as a concentrated load with loading at the center of gravity and the rings are modeled as concentrated loads at the supports.




Figure 1

Pipe and shell parameters, Reference 5:

Inner containment pipe:

OD: $od_{pipe} = 64$ in Wall thickness: $t_{pipe} = 0.500$ in

$$ID: id_{pipe} = od_{pipe} - (2 t_{pipe})$$

Length of pipe: $l_{pipe} = 52$ ft + 0.75 in

Outer shell thin section:

ID: $id_{shell} = 5$ ft + 8 in Wall thickness: $t_{shell} = 0.3125$ in

$$OD: od_{shell1} = id_{shell} + 2 (t_{shell1})$$

Outer shell thick section:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 4 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Wall thickness: $t_{shell2} = 0.5$ in

OD: $od_{shell2} = id_{shell} + 2(t_{shell2})$

G loading from EPRI drop data (Reference 6): $g_{dec} = 25.3$

Data from weight and center of gravity calculations:

Weight of shielding: $W_{18b} = 66,000$ lbs

Weight of package (except stiffeners and payload) uniformly distributed:

$$W_{base} = 39,000 \text{ lbs} + W_{18b}$$

Uniform distributed weight of package:

$$W_{base} = (g_{dec} W_{base})/l_{pipe} \quad W_{base} = 4,252 \text{ lbs/in}$$

Weight of stiffener rings:

Bottom end flange: $W_4 = 2,600$ lbs

Type 1 stiffener rings: $W_2 = 450$ lbs

Type 2a stiffener rings: $W_{3a} = 525$ lbs

Type 2b stiffener rings: $W_{3b} = 600$ lbs

Weight of payload: $W_{21} = 20,000$ lbs

CG of payload from center of bottom flange: $cg_{pay} = 32.56$ ft

Putting it between Columns 15 and 16.

Moment of inertia and cross sectional area of pipe:

Moment of inertia: $I_{pipe} = \pi(od_{pipe}^4 - id_{pipe}^4)/64$

Cross sectional area: $A_{pipe} = \pi(od_{pipe}^2 - id_{pipe}^2)/4$

Moment of inertia and cross sectional area of thin outer shell:

Moment of inertia: $I_{os1} = \pi(od_{shell1}^4 - id_{shell}^4)/64$

Cross sectional area: $A_{os1} = \pi(od_{shell1}^2 - id_{shell}^2)/4$

Moment of inertia and cross sectional area of thick outer shell:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 5 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Moment of inertia: $I_{os2} = \pi(od_{shell2}^4 - id_{shell}^4)/64$

Cross sectional area: $A_{os2} = \pi(od_{shell2}^2 - id_{shell}^2)/4$

Moment of inertia and cross sectional area of composites:

Pipe with thin outer shell:

Moment of inertia: $I_1 = I_{pipe} + I_{os1}$

Cross sectional area: $A_1 = A_{pipe} + A_{os1}$

Pipe with thick outer shell:

Moment of inertia: $I_2 = I_{pipe} + I_{os2}$

Cross sectional area: $A_2 = A_{pipe} + A_{os2}$

Length between centerline of supports:

$l_1 = 9.750 \text{ in}$

$l_2 = (2 \text{ ft} + 10 \text{ in}) - l_1$

$l_3 = (4 \text{ ft} + 10.250 \text{ in}) - (2 \text{ ft} + 10 \text{ in})$

$l_4 = (5 \text{ ft} + 7.750 \text{ in}) - (4 \text{ ft} + 10.250 \text{ in})$

$l_5 = (8 \text{ ft} + 3.250 \text{ in}) - (5 \text{ ft} + 7.750 \text{ in})$

$l_6 = (10 \text{ ft} + 10.750 \text{ in}) - (8 \text{ ft} + 3.250 \text{ in})$

$l_7 = (13 \text{ ft} + 6.25 \text{ in}) - (10 \text{ ft} + 10.750 \text{ in})$

$l_8 = (16 \text{ ft} + 1.750 \text{ in}) - (13 \text{ ft} + 6.25 \text{ in})$

$l_9 = (18 \text{ ft} + 9.250 \text{ in}) - (16 \text{ ft} + 1.750 \text{ in})$

$l_{10} = (21 \text{ ft} + 4.750 \text{ in}) - (18 \text{ ft} + 9.250 \text{ in})$

$l_{11} = (24 \text{ ft} + 0.250 \text{ in}) - (21 \text{ ft} + 4.750 \text{ in})$

$l_{12} = (24 \text{ ft} + 9.750 \text{ in}) - (24 \text{ ft} + 0.250 \text{ in})$

$l_{13} = (27 \text{ ft} + 5.25 \text{ in}) - (24 \text{ ft} + 9.750 \text{ in})$

$l_{14} = (30 \text{ ft} + 0.750 \text{ in}) - (27 \text{ ft} + 5.25 \text{ in})$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 6 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

$$l_{15} = (32 \text{ ft} + 8.250 \text{ in}) - (30 \text{ ft} + 0.750 \text{ in})$$

$$l_{16} = (35 \text{ ft} + 3.750 \text{ in}) - (32 \text{ ft} + 8.250 \text{ in})$$

$$l_{17} = (37 \text{ ft} + 11.750 \text{ in}) - (35 \text{ ft} + 3.750 \text{ in})$$

$$l_{18} = (40 \text{ ft} + 6.750 \text{ in}) - (37 \text{ ft} + 11.750 \text{ in})$$

$$l_{19} = (43 \text{ ft} + 2.250 \text{ in}) - (40 \text{ ft} + 6.750 \text{ in})$$

$$l_{20} = (45 \text{ ft} + 9.750 \text{ in}) - (43 \text{ ft} + 2.250 \text{ in})$$

$$l_{21} = (48 \text{ ft} + 5.25 \text{ in}) - (45 \text{ ft} + 9.750 \text{ in})$$

$$l_{22} = (49 \text{ ft} + 2.750 \text{ in}) - (48 \text{ ft} + 5.25 \text{ in})$$

$$l_{23} = (51 \text{ ft} + 2.750 \text{ in}) - (49 \text{ ft} + 2.750 \text{ in})$$

$$l_{24} = (52 \text{ ft} + 0.750 \text{ in}) - (51 \text{ ft} + 2.750 \text{ in})$$

CG of pump locations relative to Column 15 and 16:

$$\text{Distance from Column 15: } d_a = cg_{\text{pay}} - (30 \text{ ft} + 0.750 \text{ in})$$

$$\text{Distance from Column 16: } d_b = (32 \text{ ft} + 8.25 \text{ in}) - cg_{\text{pay}}$$

Using the Three Moment Theorem, determine moments at the supports:

End Conditions assuming simply supported:

$$\text{At bottom end flange end: } M_a = 0.0 \text{ lbs-in}$$

At top end moments due to top caps exists, model as uniform cantilevered load of combined weight of both inner and outer top caps.

$$\text{Weight of outer top cap: } W_{19} = 1,900 \text{ lbs}$$

$$\text{Weight of inner top cap: } W_{20} = 1,500 \text{ lbs}$$

$$\text{Total weight: } W_{\text{tcap}} = W_{19} + W_{20}$$

$$\text{Length of outer top cap: } l_{\text{tcap}} = (2 \text{ ft} + 1.875 \text{ in}) + 2.25 \text{ in}$$

Assume load is distributed in a triangular shape along the length:

$$M_y = - (1/3 g_{\text{dec}} W_{\text{tcap}} l_{\text{tcap}})$$

$$\text{Constraints: } M_a = 0.0 \text{ lbs-in} \quad M_y = - (1/3 g_{\text{dec}} W_{\text{tcap}} l_{\text{tcap}})$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 7 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow *SR* Date 08/31/94

Span 1 and 2:

$$M_a \frac{l_1}{I_1} + 2 M_b \left(\frac{l_1}{I_1} + \frac{l_2}{I_1} \right) + M_c \frac{l_2}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_1^3}{I_1} + \frac{l_2^3}{I_1} \right)$$

Span 2 and 3:

$$M_b \frac{l_2}{I_1} + 2 M_c \left(\frac{l_2}{I_1} + \frac{l_3}{I_1} \right) + M_d \frac{l_3}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_2^3}{I_1} + \frac{l_3^3}{I_1} \right)$$

Span 3 and 4:

$$M_c \frac{l_3}{I_1} + 2 M_d \left(\frac{l_3}{I_1} + \frac{l_4}{I_1} \right) + M_e \frac{l_4}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_3^3}{I_1} + \frac{l_4^3}{I_1} \right)$$

Span 4 and 5:

$$M_d \frac{l_4}{I_1} + 2 M_e \left(\frac{l_4}{I_1} + \frac{l_5}{I_1} \right) + M_f \frac{l_5}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_4^3}{I_1} + \frac{l_5^3}{I_1} \right)$$

Span 5 and 6:

$$M_e \frac{l_5}{I_1} + 2 M_f \left(\frac{l_5}{I_1} + \frac{l_6}{I_1} \right) + M_g \frac{l_6}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_5^3}{I_1} + \frac{l_6^3}{I_1} \right)$$

Span 6 and 7:

$$M_f \frac{l_6}{I_1} + 2 M_g \left(\frac{l_6}{I_1} + \frac{l_7}{I_1} \right) + M_h \frac{l_7}{I_1} = -\frac{w_{base}}{4} \left(\frac{l_6^3}{I_1} + \frac{l_7^3}{I_1} \right)$$

Span 7 and 8:, Transition from thin to thick outer shell:

$$M_g \frac{l_7}{I_1} + 2 M_h \left(\frac{l_7}{I_1} + \frac{l_8}{I_2} \right) + M_i \frac{l_8}{I_2} = -\frac{w_{base}}{4} \left(\frac{l_7^3}{I_1} + \frac{l_8^3}{I_2} \right)$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 8 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Span 8 and 9:

$$M_h \frac{l_8}{I_2} + 2 M_i \left(\frac{l_8}{I_2} + \frac{l_9}{I_2} \right) + M_j \frac{l_9}{I_2} = - \frac{w_{base}}{4} \left(\frac{l_8^3}{I_2} + \frac{l_9^3}{I_2} \right)$$

Span 9 and 10:

$$M_i \frac{l_9}{I_2} + 2 M_j \left(\frac{l_9}{I_2} + \frac{l_{10}}{I_2} \right) + M_k \frac{l_{10}}{I_2} = - \frac{w_{base}}{4} \left(\frac{l_9^3}{I_2} + \frac{l_{10}^3}{I_2} \right)$$

Span 10 and 11:

$$M_j \frac{l_{10}}{I_2} + 2 M_k \left(\frac{l_{10}}{I_2} + \frac{l_{11}}{I_2} \right) + M_l \frac{l_{11}}{I_2} = - \frac{w_{base}}{4} \left(\frac{l_{10}^3}{I_2} + \frac{l_{11}^3}{I_2} \right)$$

Span 11 and 12:

$$M_k \frac{l_{11}}{I_2} + 2 M_l \left(\frac{l_{11}}{I_2} + \frac{l_{12}}{I_2} \right) + M_m \frac{l_{12}}{I_2} = - \frac{w_{base}}{4} \left(\frac{l_{11}^3}{I_2} + \frac{l_{12}^3}{I_2} \right)$$

Span 12 and 13:

$$M_l \frac{l_{12}}{I_2} + 2 M_m \left(\frac{l_{12}}{I_2} + \frac{l_{13}}{I_2} \right) + M_n \frac{l_{13}}{I_2} = - \frac{w_{base}}{4} \left(\frac{l_{12}^3}{I_2} + \frac{l_{13}^3}{I_2} \right)$$

Span 13 and 14:

$$M_m \frac{l_{13}}{I_2} + 2 M_n \left(\frac{l_{13}}{I_2} + \frac{l_{14}}{I_2} \right) + M_o \frac{l_{14}}{I_2} = - \frac{w_{base}}{4} \left(\frac{l_{13}^3}{I_2} + \frac{l_{14}^3}{I_2} \right)$$

Span 14 and 15:, Transition from thick to thin outer shell and pump cg location:

$$M_n \frac{l_{14}}{I_2} + 2 M_o \left(\frac{l_{14}}{I_2} + \frac{l_{15}}{I_1} \right) + M_p \frac{l_{15}}{I_1} = - \frac{w_{base}}{4} \left(\frac{l_{14}^3}{I_2} + \frac{l_{15}^3}{I_1} \right) + - \frac{G_{dec} w_{21} d_1 (l_{15}^2 - d_1^2)}{l_{15} I_1}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 9 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Span 15 and 16:, pump cg location:

$$M_o \frac{I_{15}}{I_1} + 2 M_p \left(\frac{I_{15}}{I_1} + \frac{I_{16}}{I_1} \right) + M_q \frac{I_{16}}{I_1} = - \frac{w_{base}}{4} \left(\frac{I_{15}^3}{I_1} + \frac{I_{16}^3}{I_1} \right) + - \frac{g_{dec} W_{21} d_b (I_{15}^2 - d_b^2)}{I_{15} I_1}$$

Span 16 and 17:

$$M_p \frac{I_{16}}{I_1} + 2 M_q \left(\frac{I_{16}}{I_1} + \frac{I_{17}}{I_1} \right) + M_r \frac{I_{17}}{I_1} = - \frac{w_{base}}{4} \left(\frac{I_{16}^3}{I_1} + \frac{I_{17}^3}{I_1} \right)$$

Span 17 and 18:

$$M_q \frac{I_{17}}{I_1} + 2 M_r \left(\frac{I_{17}}{I_1} + \frac{I_{18}}{I_1} \right) + M_s \frac{I_{18}}{I_1} = - \frac{w_{base}}{4} \left(\frac{I_{17}^3}{I_1} + \frac{I_{18}^3}{I_1} \right)$$

Span 18 and 19:

$$M_r \frac{I_{18}}{I_1} + 2 M_s \left(\frac{I_{18}}{I_1} + \frac{I_{19}}{I_1} \right) + M_c \frac{I_{19}}{I_1} = - \frac{w_{base}}{4} \left(\frac{I_{18}^3}{I_1} + \frac{I_{19}^3}{I_1} \right)$$

Span 19 and 20:

$$M_s \frac{I_{19}}{I_1} + 2 M_c \left(\frac{I_{19}}{I_1} + \frac{I_{20}}{I_1} \right) + M_u \frac{I_{20}}{I_1} = - \frac{w_{base}}{4} \left(\frac{I_{19}^3}{I_1} + \frac{I_{20}^3}{I_1} \right)$$

Span 20 and 21:

$$M_c \frac{I_{20}}{I_1} + 2 M_u \left(\frac{I_{20}}{I_1} + \frac{I_{21}}{I_1} \right) + M_v \frac{I_{21}}{I_1} = - \frac{w_{base}}{4} \left(\frac{I_{20}^3}{I_1} + \frac{I_{21}^3}{I_1} \right)$$

Span 21 and 22:

$$M_u \frac{I_{21}}{I_1} + 2 M_v \left(\frac{I_{21}}{I_1} + \frac{I_{22}}{I_1} \right) + M_w \frac{I_{22}}{I_1} = - \frac{w_{base}}{4} \left(\frac{I_{21}^3}{I_1} + \frac{I_{22}^3}{I_1} \right)$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 10 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Span 22 and 23:

$$M_v \frac{I_{22}}{I_1} + 2 M_w \left(\frac{I_{22}}{I_1} + \frac{I_{23}}{I_1} \right) + M_x \frac{I_{23}}{I_1} = - \frac{w_{base}}{4} \left(\frac{I_{22}^3}{I_1} + \frac{I_{23}^3}{I_1} \right)$$

Span 23 and 24:

$$M_w \frac{I_{23}}{I_1} + 2 M_x \left(\frac{I_{23}}{I_1} + \frac{I_{24}}{I_1} \right) + M_y \frac{I_{24}}{I_1} = - \frac{w_{base}}{4} \left(\frac{I_{23}^3}{I_1} + \frac{I_{24}^3}{I_1} \right)$$

	lbs-in		lbs-in
M _a	0	M _b	-149,340
M _c	-246,988	M _d	-112,957
M _e	-258,592	M _e	-376,495
M _f	-345,001	M _f	-353,073
M _g	-353,258	M _g	-343,470
M _h	-382,435	M _h	-236,365
M _i	-285,116	M _i	-270,229
M _j	-743,542	M _j	-451,199
M _k	-333,590	M _k	-358,760
M _l	-342,684	M _l	-347,218
M _m	-378,018	M _m	-250,282
M _n	-179,627	M _n	-49,748
M _v	-806,438		

Maximum moments between supports and reactions at supports:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 11 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Span 1, $M_a < M_b$:

$$M_1 = \frac{w_{base} l_1^2}{8} - \frac{M_a + M_b}{2} + \frac{(M_a - M_b)^2}{2 w_{base} l_1^2}$$

$$M_1 = 152,784 \text{ lbs-in}$$

$$R_a = \frac{w_{base} l_1}{2} - \frac{M_a - M_b}{l_1} + G_{dec} W_4$$

$$R_a = 71,192 \text{ lbs}$$

Span 2, $M_b < M_c$:

$$M_2 = \frac{w_{base} l_2^2}{8} - \frac{M_b + M_c}{2} + \frac{(M_b - M_c)^2}{2 w_{base} l_2^2}$$

$$M_2 = 512,633 \text{ lbs-in}$$

$$R_b = \left(\frac{w_{base} l_1}{8} + \frac{M_a - M_b}{l_1} \right) + \left(\frac{w_{base} l_2}{8} - \frac{M_b - M_c}{l_2} \right) + G_{dec} W_{3a}$$

$$R_b = 42,644 \text{ lbs}$$

Span 3, $M_c > M_d$:

$$M_3 = \frac{w_{base} l_3^2}{8} - \frac{M_c + M_d}{2} + \frac{(M_c - M_d)^2}{2 w_{base} l_3^2}$$

$$M_3 = 496,128 \text{ lbs-in}$$

$$R_c = \left(\frac{w_{base} l_2}{8} + \frac{M_b - M_c}{l_2} \right) + \left(\frac{w_{base} l_3}{8} + \frac{M_c - M_d}{l_3} \right) + G_{dec} W_2$$

$$R_c = 35,663 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 12 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Span 4, $M_d < M_e$:

$$M_d = \frac{w_{base} l_4^2}{8} - \frac{M_d + M_e}{2} + \frac{(M_d - M_e)^2}{2 w_{base} l_4^2}$$

$$M_d = 261,378 \text{ lbs-in}$$

$$R_d = \left(\frac{w_{base} l_3}{8} - \frac{M_c - M_d}{l_3} \right) + \left(\frac{w_{base} l_4}{8} - \frac{M_d - M_e}{l_4} \right) + G_{dec} W_{3b}$$

$$R_d = 23,316 \text{ lbs}$$

Span 5, $M_e < M_f$:

$$M_e = \frac{w_{base} l_5^2}{8} - \frac{M_e + M_f}{2} + \frac{(M_e - M_f)^2}{2 w_{base} l_5^2}$$

$$M_e = 846,584 \text{ lbs-in}$$

$$R_e = \left(\frac{w_{base} l_4}{8} + \frac{M_d - M_e}{l_4} \right) + \left(\frac{w_{base} l_5}{8} - \frac{M_e - M_f}{l_5} \right) + G_{dec} W_{3b}$$

$$R_e = 48,559 \text{ lbs}$$

Span 6, $M_f > M_g$:

$$M_f = \frac{w_{base} l_6^2}{8} - \frac{M_f + M_g}{2} + \frac{(M_f - M_g)^2}{2 w_{base} l_6^2}$$

$$M_f = 888,259 \text{ lbs-in}$$

$$R_f = \left(\frac{w_{base} l_5}{8} + \frac{M_e - M_f}{l_5} \right) + \left(\frac{w_{base} l_6}{8} - \frac{M_f - M_g}{l_6} \right) + G_{dec} W_2$$

$$R_f = 49,613 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 13 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Span 7, $M_g < M_h$:

$$M_7 = \frac{w_{base} l_7^2}{8} - \frac{M_g + M_h}{2} + \frac{(M_g - M_h)^2}{2 w_{base} l_7^2}$$

$$M_7 = 876,438 \text{ lbs-in}$$

$$R_g = \left(\frac{w_{base} l_6}{8} - \frac{M_f - M_g}{l_6} \right) + \left(\frac{w_{base} l_7}{8} - \frac{M_g - M_h}{l_7} \right) + \mathcal{G}_{dec} W_2$$

$$R_g = 45,614 \text{ lbs}$$

Span 8, $M_h < M_i$:

$$M_8 = \frac{w_{base} l_8^2}{8} - \frac{M_h + M_i}{2} + \frac{(M_h - M_i)^2}{2 w_{base} l_8^2}$$

$$M_8 = 880,559 \text{ lbs-in}$$

$$R_h = \left(\frac{w_{base} l_7}{8} + \frac{M_g - M_h}{l_7} \right) + \left(\frac{w_{base} l_8}{8} - \frac{M_g - M_h}{l_8} \right) + \mathcal{G}_{dec} W_2$$

$$R_h = 44,870 \text{ lbs}$$

Span 9, $M_i > M_j$:

$$M_9 = \frac{w_{base} l_9^2}{8} - \frac{M_i + M_j}{2} + \frac{(M_i - M_j)^2}{2 w_{base} l_9^2}$$

$$M_9 = 875,769 \text{ lbs-in}$$

$$R_i = \left(\frac{w_{base} l_8}{8} + \frac{M_h - M_i}{l_8} \right) + \left(\frac{w_{base} l_9}{8} + \frac{M_i - M_j}{l_9} \right) + \mathcal{G}_{dec} W_2$$

$$R_i = 44,565 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 14 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Span 10, $M_j < M_k$:

$$M_{10} = \frac{w_{base} l_{10}^2}{8} - \frac{M_j + M_k}{2} + \frac{(M_j - M_k)^2}{2 w_{base} l_{10}^2}$$

$$M_{10} = 890,526 \text{ lbs-in}$$

$$R_j = \left(\frac{w_{base} l_9}{8} - \frac{M_i - M_j}{l_9} \right) + \left(\frac{w_{base} l_{10}}{8} - \frac{M_j - M_k}{l_{10}} \right) + g_{dec} W_2$$

$$R_j = 43,944 \text{ lbs}$$

Span 11, $M_k > M_l$:

$$M_{11} = \frac{w_{base} l_{11}^2}{8} - \frac{M_k + M_l}{2} + \frac{(M_k - M_l)^2}{2 w_{base} l_{11}^2}$$

$$M_{11} = 839,322 \text{ lbs-in}$$

$$R_k = \left(\frac{w_{base} l_{10}}{8} + \frac{M_j - M_k}{l_{10}} \right) + \left(\frac{w_{base} l_{11}}{8} + \frac{M_k - M_l}{l_{11}} \right) + g_{dec} W_2$$

$$R_k = 41,470 \text{ lbs}$$

Span 12, $M_l < M_m$:

$$M_{12} = \frac{w_{base} l_{12}^2}{8} - \frac{M_l + M_m}{2} + \frac{(M_l - M_m)^2}{2 w_{base} l_{12}^2}$$

$$M_{12} = 311,806 \text{ lbs-in}$$

$$R_l = \left(\frac{w_{base} l_{11}}{8} - \frac{M_k - M_l}{l_{11}} \right) + \left(\frac{w_{base} l_{12}}{8} - \frac{M_l - M_m}{l_{12}} \right) + g_{dec} W_{3a}$$

$$R_l = 34,580 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 15 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Span 13, $M_m > M_n$:

$$M_{13} = \frac{w_{base} l_{13}^2}{8} - \frac{M_m + M_n}{2} + \frac{(M_m - M_n)^2}{2 w_{base} l_{13}^2}$$

$$M_{13} = 805,092 \text{ lbs-in}$$

$$R_m = \left(\frac{w_{base} l_{12}}{8} + \frac{M_l - M_m}{l_{12}} \right) + \left(\frac{w_{base} l_{13}}{8} + \frac{M_m - M_n}{l_{13}} \right) + g_{dec} W_{3a}$$

$$R_m = 39,734 \text{ lbs}$$

Span 14, $M_n < M_o$:

$$M_{14} = \frac{w_{base} l_{14}^2}{8} - \frac{M_n + M_o}{2} + \frac{(M_n - M_o)^2}{2 w_{base} l_{14}^2}$$

$$M_{14} = 1,060,827 \text{ lbs-in}$$

$$R_n = \left(\frac{w_{base} l_{13}}{8} - \frac{M_m - M_n}{l_{13}} \right) + \left(\frac{w_{base} l_{14}}{8} - \frac{M_j - M_k}{l_{14}} \right) + g_{dec} W_2$$

$$R_n = 44,106 \text{ lbs}$$

Span 15, $M_o > M_p$, Span where pump is located:

Location of maximum moment: $x_{max} = l_{15}/2 + [(M_o - M_p)/(w_{base} l_{15})]$

Moment due to pump at location: $M_{pump} = (g_{dec} W_{21} d_b x_{max})/l_{15}$

Reaction at o due to pump: $R_{po} = (g_{dec} W_{21} d_b)/l_{15}$

$$M_{15} = \frac{w_{base} l_{15}^2}{8} - \frac{M_o + M_p}{2} + \frac{(M_o - M_p)^2}{2 w_{base} l_{15}^2} + M_{pump}$$

$$M_{15} = 1,468,339 \text{ lbs-in}$$

$$R_o = \left(\frac{w_{base} l_{14}}{8} + \frac{M_n - M_o}{l_{14}} \right) + \left(\frac{w_{base} l_{15}}{8} + \frac{M_o - M_p}{l_{15}} \right) + R_{po} + g_{dec} W_2$$

$$R_o = 75,193 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 16 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Span 16, $M_p > M_q$:

$$M_{16} = \frac{w_{base} l_{16}^2}{8} - \frac{M_p + M_q}{2} + \frac{(M_p - M_q)^2}{2 w_{base} l_{16}^2}$$

$$M_{16} = 921,427 \text{ lbs-in}$$

Reaction at p due to pump: $R_{pp} = (g_{dec} W_{21} d_a) / l_{15}$

$$R_p = \left(\frac{w_{base} l_{15}}{8} - \frac{M_o - M_p}{l_{15}} \right) + R_{pp} + \left(\frac{w_{base} l_{16}}{8} + \frac{M_p - M_q}{l_{16}} \right) + g_{dec} W_2$$

$$R_p = 531,840 \text{ lbs}$$

Span 17, $M_q < M_r$:

$$M_{17} = \frac{w_{base} l_{17}^2}{8} - \frac{M_q + M_r}{2} + \frac{(M_q - M_r)^2}{2 w_{base} l_{17}^2}$$

$$M_{17} = 890,516 \text{ lbs-in}$$

$$R_q = \left(\frac{w_{base} l_{16}}{8} - \frac{M_p - M_q}{l_{16}} \right) + \left(\frac{w_{base} l_{17}}{8} - \frac{M_q - M_r}{l_{17}} \right) + g_{dec} W_2$$

$$R_q = 48,083 \text{ lbs}$$

Span 18, $M_r > M_s$:

$$M_{18} = \frac{w_{base} l_{18}^2}{8} - \frac{M_r + M_s}{2} + \frac{(M_r - M_s)^2}{2 w_{base} l_{18}^2}$$

$$M_{18} = 861,537 \text{ lbs-in}$$

$$R_r = \left(\frac{w_{base} l_{17}}{8} + \frac{M_q - M_r}{l_{17}} \right) + \left(\frac{w_{base} l_{18}}{8} + \frac{M_r - M_s}{l_{18}} \right) + g_{dec} W_2$$

$$R_r = 45,138 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 17 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Span 19, $M_s < M_t$:

$$M_{19} = \frac{w_{base} l_{19}^2}{8} - \frac{M_s + M_t}{2} + \frac{(M_s - M_t)^2}{2 w_{base} l_{19}^2}$$

$$M_{19} = 872,347 \text{ lbs-in}$$

$$R_s = \left(\frac{w_{base} l_{18}}{8} - \frac{M_t - M_s}{l_{18}} \right) + \left(\frac{w_{base} l_{19}}{8} - \frac{M_s - M_t}{l_{19}} \right) + g_{dec} W_2$$

$$R_s = 44,979 \text{ lbs}$$

Span 20, $M_t < M_u$:

$$M_{20} = \frac{w_{base} l_{20}^2}{8} - \frac{M_t + M_u}{2} + \frac{(M_t - M_u)^2}{2 w_{base} l_{20}^2}$$

$$M_{20} = 890,124 \text{ lbs-in}$$

$$R_t = \left(\frac{w_{base} l_{19}}{8} + \frac{M_s - M_t}{l_{19}} \right) + \left(\frac{w_{base} l_{20}}{8} - \frac{M_t - M_u}{l_{20}} \right) + g_{dec} W_2$$

$$R_t = 44,036 \text{ lbs}$$

Span 21, $M_u > M_v$:

$$M_{21} = \frac{w_{base} l_{21}^2}{8} - \frac{M_u + M_v}{2} + \frac{(M_u - M_v)^2}{2 w_{base} l_{21}^2}$$

$$M_{21} = 843,477 \text{ lbs-in}$$

$$R_u = \left(\frac{w_{base} l_{20}}{8} + \frac{M_t - M_u}{l_{20}} \right) + \left(\frac{w_{base} l_{21}}{8} + \frac{(M_u + M_v)}{l_{21}} \right) + g_{dec} W_2$$

$$R_u = 41,793 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 18 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Span 22, $M_v > M_w$:

$$M_{22} = \frac{w_{base} I_{22}^2}{8} - \frac{M_v + M_w}{2} + \frac{(M_v - M_w)^2}{2 w_{base} I_{22}^2}$$

$$M_{22} = 269,428 \text{ lbs-in}$$

$$R_v = \left(\frac{w_{base} I_{21}}{8} - \frac{M_u - M_v}{I_{21}} \right) + \left(\frac{w_{base} I_{22}}{8} + \frac{M_v - M_w}{I_{22}} \right) + g_{dec} W_{3b}$$

$$R_v = 33,590 \text{ lbs}$$

Span 23, $M_w > M_x$:

$$M_{23} = \frac{w_{base} I_{23}^2}{8} - \frac{M_w + M_x}{2} + \frac{(M_w - M_x)^2}{2 w_{base} I_{23}^2}$$

$$M_{23} = 424,283 \text{ lbs-in}$$

$$R_w = \left(\frac{w_{base} I_{22}}{8} + \frac{M_v - M_w}{I_{22}} \right) + \left(\frac{w_{base} I_{23}}{8} + \frac{(M_w - M_x)}{I_{23}} \right) + g_{dec} W_{3b}$$

$$R_w = 20,137 \text{ lbs}$$

Span 24, $M_x < M_y$:

$$M_{24} = \frac{w_{base} I_{24}^2}{8} - \frac{M_x + M_y}{2} + \frac{(M_x - M_y)^2}{2 w_{base} I_{24}^2}$$

$$M_{24} = 1,154,534 \text{ lbs-in}$$

$$R_x = \left(\frac{w_{base} I_{23}}{8} - \frac{M_w - M_x}{I_{23}} \right) + \left(\frac{w_{base} I_{24}}{8} - \frac{(M_x - M_y)}{I_{24}} \right) + g_{dec} W_2$$

$$R_x = -40,801 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 19 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Reaction at Column 25:

$$R_y = \frac{W_{base} l_{24}}{8} + \frac{M_x - M_y}{l_{24}} + g_{desc} W_{ccap}$$

$$R_y = 167,004 \text{ lbs}$$

Maximum loading on ring:

Maximum loading on ring at Column 16, R_p . Model as combined loading of Ring loaded as loading smeared over entire volume of the ring Reference 7, pages 176 and 178; Case 22 and opposed by a reactive load transferred by tangential shear Roark Case 24. Also assume ring acts as a curved beam (shown Figures 2 and 3).




Figure 2




Figure 3

Nominal radius of ring:

OD of ring: $od_{ring} = 5 \text{ ft} + 11.625 \text{ in}$

$$R_{ring} = od_{ring}/2 \quad R_{ring} = 2.98 \text{ ft}$$

Width of ring: $b_{ring} = 1.5 \text{ in}$

Distributed weight of ring throughout cross section:

$$w_{ring} = R_p / (\pi R_{ring}^2 b_{ring}) \quad w_{ring} = 88 \text{ lbs/in}^3$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 20 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow *SR* Date 08/31/94

Case 20 Maximum Loading at bottom of ring:

$$\alpha = 0 \text{ deg} \quad \theta = 0 \text{ deg}$$

$$u = \cos(\alpha) \quad s = \sin(\theta) \quad c = \cos(\theta) \quad z = \sin(\alpha)$$

$$\text{Maximum moment loading: } M_{1ring} = 3/4 w_{ring} R_{ring}^3 \quad M_{1ring} = 3.03 \times 10^6 \text{ lbs}$$

Circumferential Tension:

$$T_{1ring} = w_{ring} R_{ring}^2 (1 + 1/4 u - 1/2 \pi z + 1/2 \alpha z)$$

$$T_{1ring} = 141,075 \text{ lbs/in}$$

Radial Shear:

$$V_{1ring} = w_{ring} R_{ring}^2 (1/2 \alpha u + 1/4 z - 1/2 \pi u)$$

$$V_{1ring} = -177,280 \text{ lbs/in}$$

Case 25, Opposing moment' at bottom of ring, $\theta = 0^\circ$, $\alpha = 0^\circ$

Counteracting Moment:

$$M_{2ring} = - [R_p R_{ring} [0.23868 u - 1/2 s + 0.15915 (\alpha z + \theta s + c - u c^2)]]$$

$$M_{2ring} = -4.55 \times 10^6 \text{ lbs-in}$$

Circumferential Tension:

$$T_{2ring} = R_p [0.15915 (\alpha z - u c^2) - 0.07958 u]$$

$$T_{2ring} = -126,966 \text{ lbs}$$

Radial Shear:

$$V_{2ring} = - [R_p [0.15915 (\alpha u - 1/2 z + z c^2) - 1/2 u]]$$

$$V_{2ring} = 265,920 \text{ lbs}$$

Resultant loading:

Maximum Moment:

$$M_{rring} = M_{1ring} b_{ring} + M_{2ring} \quad M_{rring} = 998 \text{ lbs-in}$$

Circumferential Tension:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 21 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

$$T_{r\text{ring}} = T_{1\text{ring}} b_{\text{ring}} + T_{2\text{ring}} \quad T_{r\text{ring}} = 84,646 \text{ lbs}$$

Radial Shear:

$$V_{r\text{ring}} = V_{1\text{ring}} b_{\text{ring}} + V_{2\text{ring}} \quad V_{r\text{ring}} = 0 \text{ lbs}$$

Geometric parameters of pipe:

Inside radius of ring is id of pipe: $r_{\text{ring}} = (\text{od}_{\text{pipe}} - t_{\text{pipe}})/2$

Normal depth of ring including pipe thickness:

$$h_{\text{ring}} = R_{\text{ring}} - r_{\text{ring}} \quad h_{\text{ring}} = 4.06 \text{ in}$$

Neutral axis of ring:

$$I_{na} = \frac{h_{\text{ring}}}{\ln\left(\frac{R_{\text{ring}}}{r_{\text{ring}}}\right)}$$

CG of ring:

$$r_{\text{cg}} = r_{\text{ring}} + (h_{\text{ring}}/2)$$

Eccentricity: $\text{ecc} = r_{\text{cg}} - r_{na}$

Cross sectional area: $A_{\text{ring}} = h_{\text{ring}} b_{\text{ring}}$

Stresses in ring:

Bending stress:

$$\sigma_{\text{bottom}} = \frac{M_{r\text{ring}} (I_{na} - I_{\text{ring}})}{A_{\text{ring}} \text{ecc} r_{\text{ring}}}$$

$$\sigma_{\text{bottom}} = 252 \text{ psi}$$

Tangential stress:

$$\sigma_{\text{tan}} = T_{r\text{ring}}/A_{\text{ring}} \quad \sigma_{\text{tan}} = 13,891 \text{ psi}$$

Maximum shear stress:

$$\tau_{\text{ring}} = 2 V_{r\text{ring}}/A_{\text{ring}} \quad \tau_{\text{ring}} = 0 \text{ psi}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 22 of 32
 Building Tank 241-SY-101 .Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow *SKC* Date 08/31/94

Total stress:

$$\sigma_{tot} = \sigma_{bottom} + \sigma_{tan} + \tau_{ring} \quad \sigma_{tot} = 14,143 \text{ psi}$$

ASME allowable from previous data: $s_a = 23,270 \text{ psi}$

Margin of Safety on inner pipe:

$$MS_{pipe} = (s_a / \sigma_{tot}) - 1 \quad MS_{pipe} = 0.65 \quad \text{OK}$$

Maximum Loading on inner containment pipe between rings:




Figure 4

Maximum bending between Columns 15 and 16:

$$\sigma_{bmax} = \frac{M_{15} \left(\frac{od_{pipe}}{2} \right)}{I_{pipe}}$$

$$\sigma_{bmax} = 935 \text{ psi}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 23 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Short beam criteria applies here, therefore must consider maximum shear at support.

Maximum shear: $\tau_{y\max} = 2 R_y / A_{\text{pipe}}$ $\tau_{y\max} = 3,349 \text{ psi}$

Bending at support:

$$\sigma_{by} = \frac{|M_y| \frac{od_{\text{pipe}}}{2}}{I_{\text{pipe}}}$$

$\sigma_{by} = 513 \text{ psi}$

Total stress at pipe section:

$\sigma_{ytot} = \sigma_{b\max} + \tau_{y\max}$ $\sigma_{ytot} = 4,283 \text{ psi}$

Margin of Safety:

$MS_{ypipe} = (s_a / \sigma_{ytot}) - 1$ $MS_{ypipe} = 4.43 \text{ OK}$

Loading on Inner Blind Flange Plate:

Assuming inside pipe welds carry the entire load determine weld strength.




Figure 5

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 24 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow *dec* Date 08/31/94

Plate thickness: $t_{bef} = 2.0$ in

From ASME, allowable at joint discontinuities: $1.5 s_a = 34,905$ psi

Since welds are 100% radiographed assume full strength of fillets.

Weld size, assuming on one weld: $w_w = 0.500$ in

Weld diameter is assumed as same size as pipe: $d_w = id_{pipe}$

Circumference of weld (one side only): $c_w = \pi d_w$

Pressure loading from pressure calculations at pipe joint discontinuity:

$$s_{btot} = 10,929 \text{ psi}$$

Shear area of weld: $A_w = 0.707 w_w c_w$

Maximum shear due deflection of pipe during drop:

Weight of inner blind flange: $W_b = 1,800$ lbs

$$\tau_{drop} = (2 g_{dec} \cdot W_b) / A_w \quad \tau_{drop} = 1,302 \text{ psi}$$

Total stress on weld:

$$\sigma_{wtot} = \tau_{drop} + s_{btot} \quad \sigma_{wtot} = 12,231 \text{ psi}$$

Margin of Safety:

$$MS_{befw} = (1.5 s_a / \sigma_{wtot}) - 1 \quad MS_{befw} = 1.85 \quad \text{OK}$$

Top Cap Loading:

Retaining Ring Loading:

Since fitup tolerance of retaining ring is tighter than for bolts, retaining ring takes up all shear loading from the drop.

Weight of inner top cap: $W_{20} = 1,500$ lbs

ID of retaining ring: $id_{iterr} = 5 \text{ ft} + 3 \text{ in}$

Wall thickness: $t_{iterr} = 0.375$ in

OD of retaining ring: $od_{iterr} = id_{iterr} + 2(t_{iterr})$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 25 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Cross sectional area of ring:

$$A_{itcrr} = \pi (od_{itcrr}^2 - id_{itcrr}^2) / 4$$

Maximum shearing load on the ring cross section:

$$\tau_{rrmax} = (2 g_{dec} W_{20}) / A_{itcrr}$$

$$\tau_{rrmax} = 1,017 \text{ psi}$$

Margin of Safety:

$$MS_{rrs} = (s_s / \tau_{rrmax}) - 1 \quad MS_{rrs} = 21.89 \quad \text{OK}$$

Loading on the bolts:




Figure 6

CG of top cap from inner flange face: $cg_{itc} = 1.39 \text{ ft}$

Bolt parameters:

Number of bolts: $n_{bitc} = 28$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 26 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow *SC* Date 08/31/94

Nominal diameter of bolts: $d_{bitc} = 1$ in

Tensile stress area of each bolt (Reference ASTM, page 1278):

$$A_b = 0.7854 (d_{bitc} - 0.9743 \text{ in}/8)^2$$

Allowable tensile strength of bolts: $\sigma_{bten} = 55,000$ psi

Total preload and pressure load per bolt from ASME evaluation:

$$W_{btot} = 19,696 \text{ lbs}$$

Angle from vertical flange axis: $\theta_1 = 6.43$ deg

Angle of bolt spacing: $\theta_2 = 12.83$ deg

Diameter of bolt circle: $d_{bc} = 61$ in

Diameter of flange: $d_{flange} = id_{itcr}$

Distance from Pivot to bolts 14 to 8:

$$r_{bc} = d_{bc}/2 \quad r_{flange} = d_{flange}/2$$

Perpendicular distance:

Distance from pivot to centerline of bolt 14:

$$r_{14} = r_{flange} - r_{bc} \cos(\theta_1)$$

Distance from pivot to centerline of bolt 13:

$$r_{13} = r_{flange} - r_{bc} \cos(\theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 12:

$$r_{12} = r_{flange} - r_{bc} \cos(2 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 11:

$$r_{11} = r_{flange} - r_{bc} \cos(3 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 10:

$$r_{10} = r_{flange} - r_{bc} \cos(4 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 9:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 27 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow *SR* Date 08/31/94

$$r_9 = r_{flange} - r_{bc} \cos(5 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 8:

$$r_8 = r_{flange} - r_{bc} \cos(6 \theta_2 + \theta_1)$$

Distance from Pivot to bolts 7 to 1:

Distance from pivot to centerline of bolt 7:

$$r_7 = r_{flange} + r_{bc} \sin(\theta_1)$$

Distance from pivot to centerline of bolt 6:

$$r_6 = r_{flange} + r_{bc} \sin(\theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 5:

$$r_5 = r_{flange} + r_{bc} \sin(2 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 4:

$$r_4 = r_{flange} + r_{bc} \sin(3 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 3:

$$r_3 = r_{flange} + r_{bc} \sin(4 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 2:

$$r_2 = r_{flange} + r_{bc} \sin(5 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 1:

$$r_1 = r_{flange} + r_{bc} \sin(6 \theta_2 + \theta_1)$$

By symmetry bolts 15 to 28 are equal to 14 to 1, respectively.

Moment due to drop due to eccentric loading of bolts:

$$M_{bitc} = g_{dec} W_{20} CG_{itc}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 28 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation-Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Tensile load on bolt 1 (highest loading):

$$F_{bitc1} = \frac{r_1 M_{bitc}}{2 \left(r_1^2 + r_2^2 + r_3^2 + r_4^2 + r_5^2 + r_6^2 + r_7^2 + r_8^2 + r_9^2 + r_{10}^2 + r_{11}^2 + r_{12}^2 + r_{13}^2 + r_{14}^2 \right)}$$

$F_{bitc1} = 960 \text{ lbs}$

Total bolt load:

$W_{itcb} = W_{btot} + F_{bitc1}$

$W_{itcb} = 20,656 \text{ lbs}$

Tensile stress on bolt:

$\sigma_{bolt} = W_{itcb}/A_b$

$\sigma_{bolt} = 34,100 \text{ psi}$

Margin of Safety based on bolt ultimate:

$MS_{bolt} = (\sigma_{bten}/\sigma_{bolt}) - 1$

$MS_{bolt} = 0.61 \quad \text{OK}$

Outer Shell Loading from lead:

Model longest thinnest section only:




Figure 7

ID of shell: $id_{shell} = 5 \text{ ft} + 8 \text{ in}$

Wall thickness: $t_{516sh} = 0.3125 \text{ in}$

OD of shell: $od_{shell} = id_{shell} + 2(t_{516sh})$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 29 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94

Inner cross sectional void area of shell:

$$A_{crsh} = \pi(id_{shell}^2 - od_{pipe}^2)/4$$

Longest length between supports: $15_6 = 2.5$ ft

Mid point of length: $z_{sh} = 15_6/2$

Gap of void: $gap = (id_{shell} - od_{pipe})/2$ $gap = 2$ in

Radius of lead: $r_{pb} = od_{pipe}/2 + gap$

Angle of evaluation: $\theta_{pb} = 180$ deg

Poisson's ratio for carbon steel (Reference 8): $\nu_{cstl} = 0.3$

Density of lead (Reference 13, page 398): $\rho_{pb} = 0.4096$ lbs/in³

Assume 65% density of shot: $\rho_{shot} = 0.65 \rho_{pb}$

Weight of lead between supports:

$$W_{spb} = A_{crsh} \rho_{shot} 15_6$$

$$W_{spb} = 3,312 \text{ lbs}$$

Assume weight of lead smeared over the entire cross sectional area:

$$\text{Cross sectional area: } A_{smr} = \pi/4 od_{shell}^2$$

$$\text{Smear density: } \rho_{smr} = W_{spb}/(A_{smr} 15_6)$$

Load between supports at angle of evaluation, stress due to lead slump modeled using membrane theory of pipe filled between supports with a flowable material.

Tangential stress:

$$\sigma_c = \frac{g_{dec} \rho_{smr} r_{pb}^2}{t_{s16} sh} (1 - \cos(\theta_{pb}))$$

$$\sigma_c = 5,587 \text{ psi}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 30 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow *SR* Date 08/31/94

Longitudinal stress:

$$\sigma_l = \frac{g_{dec} \rho_{smr}}{t_{s16} sh} \left(\frac{z_{sh}^2}{2} \right) \cos(\theta_{pb}) + \nu_{cstl} \sigma_c$$

$$\sigma_l = 1,404 \text{ psi}$$

Shear stress:

$$\sigma_{shr} = \frac{-g_{dec} \rho_{smr}}{t_{s16} sh} \left(\frac{z_{sh}^2}{2} \right) \sin(\theta_{pb})$$

$$\sigma_{shr} = 0 \text{ psi}$$

Total stress at maximum deflection (at center of length):

$$\sigma_{pbtot} = \sigma_c + \sigma_l + \sigma_{shr}$$

$$\sigma_{pbtot} = 6,992 \text{ psi}$$

Margin of Safety:

$$MS_{pb} = (s_u / \sigma_{pbtot}) - 1$$

$$MS_{pb} = 2.33 \text{ OK}$$

Weld on Stiffener Rings:

Evaluate circumferential fillet welds joining the stiffening rings and end plates to the inner containment pipe. Assume welds are 1/2 inch fillets both sides.

Weld size: $w_{srw} = 0.500 \text{ in}$

Diameter of weld is OD of pipe: $od_{pipe} = 64 \text{ in}$

Largest moment on outer top end plate, model as pipe welded to stiffening ring with no support from outer shell or top cap flange.

Evaluate weld per AWS, Reference 11, page 7.4-7.

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 31 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow Date 08/31/94




Figure 8

Treat the welds as a line in bending:

$$S_{weld} = \pi \frac{od_{pipe}^2}{4}$$

Linear Force on welds, assuming welds equally share the load:

$$f_b = \left| \frac{M_y}{2 S_{weld}} \right|$$

$$f_b = 125 \text{ lbs/in}$$

AWS allowable for fillet welds used in Bridge Construction for ASTM A-36 material with thickness greater than 1 inch using E60 or SAW-1 Electrodes and assuming parallel loading, Reference 10 and Reference 11, page 7.4-8.

$$s_{aws} = 8,800 \text{ psi}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-02 Page 32 of 32
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Fully Shielded (101-SY)
 Originator S. S. Shiraga Date 07/31/94
 Checker S. R. Crow *SR* Date 08/31/94

Allowable line load:

$$f_{aws} = s_{aws} (0.707 w_{srw})$$

$$f_{aws} = 3,111 \text{ lbs/in}$$

Margin of Safety:

$$MS_{srw} = (f_{aws}/f_b) - 1$$

$$MS_{srw} = 23.82 \quad \text{OK}$$

6.4.11 Drop Evaluation Loaded and Partially Shielded (101-SY)

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 1 of 31
Building Tank 241-SY-101 Rev. 0 Job No. _____
Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
Originator S. S. Shiraga Date 08/01/94
Checker S. R. Crow Date 08/31/94

I. Objectives:

The objective of this evaluation is to assess the ability of the 101-SY partially shielded packaging (shielding up to Column 14) to maintain leak tightness and structural integrity after a 1 foot flat drop onto a horizontal 12 inch thick concrete surface (Reference 1 and 2). Maintenance of leak tightness and structural integrity are demonstrated by confirming the stresses in critical components and at critical locations of the package are adequately below the values established in Reference 8.

II. References:

1. WHC-SD-TP-019, Rev 0, *Packaging Design Criteria Transfer and Disposal of Hydrogen Mixer Pump.*
2. WHC, *Engineering Change Notice 606676*, dated June 27, 1994.
3. American Institute of Steel Construction, *Steel Construction Manual, 9th Edition.*
4. US-NRC, 10 CFR Part 71, *Packaging and Transportation of Radioactive Materials.*
5. WHC Drawing, No. H-2-83734, *Hydrogen Mixer Pump Storage Container.*
6. EPRI NP-4830, *The Effect of Target Hardness on the Structural Design of Concrete Storage Pads for Spent Fuel Casks.*
7. Roark, *Formulas for Stress and Strain*, 4th Edition.
8. American Society of Mechanical Engineers, *Boiler and Pressure Vessels, Section VIII, Division 2, 1989.*
9. American Society of Mechanical Engineers, *Boiler and Pressure Vessels, Section VIII, Division 1, 1989.*
10. American Welding Society, AWS/ANSI D 1.1, *Structural Welding Code.*
11. Blodgett, O. W., *Design of Welded Structures*, 1976.
12. ASTM, American Society of Testing and Materials, *Annual Book of ASTM Standards, Volume 15.08.*
13. Industrial Press, *Machinery's Handbook, 20th Edition.*

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 2 of 31
Building Tank 241-SY-101 Rev. 0 Job No. _____
Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
Originator S. S. Shiraga Date 08/01/94
Checker S. R. Crow Date 08/31/94

III. Results and Conclusions:

As with the results for an unshielded package, results for a partially shielded package show that all components, materials and welds have adequate margins of safety to insure that the package will not lose containment in the event of a 1 ft drop. In most cases the stresses are somewhat lower, than the unshielded package, since with the heavier package the deceleration factors are less (shown in the G loading evaluation). This is due primarily to the fundamental axioms in Reference 6. The EPRI report (Reference 6) considers that due to the hardness and stiffness of a cask, the concrete pad will fail absorbing most of the energy of impact. Subsequently, the heavier the cask the more the concrete fails absorbing more energy. This results in lower deceleration loads being transmitted to the package or cask with increasing weight. Consequently, since the partially shielded package is heavier than the unshielded package less deceleration loading is experienced by the package which results in lower stress values.

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 3 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

IV. Engineering Evaluation:

As per the PDC (Reference 1), assume a perfectly flat horizontal drop onto a concrete as specified in the Reference 1. Assume the package impacts on all stiffener rings and exterior flanges simultaneously. This analysis models a partially shielded and loaded container.

Model drop loading as a beam with multiple supports using the three moment theorem in AISC, Reference 2. Assume package is uniformly loaded, except for payload and rings. The payload is modeled as a concentrated load with loading at the center of gravity and the rings are modeled as concentrated loads at the supports.




Figure 1

Pipe and shell parameters from H-2-83734, Reference 2:

Inner containment pipe:

OD: $od_{pipe} = 64$ in Wall thickness: $t_{pipe} = 0.500$ in

ID: $id_{pipe} = od_{pipe} - 2(t_{pipe})$

Length of pipe: $l_{pipe} = 52$ ft + 0.75 in

Outer shell thin section:

ID: $id_{shell} = 5$ ft + 8 in Wall thickness: $t_{shell1} = 0.3125$ in

OD: $od_{shell1} = id_{shell} + 2 t_{shell1}$

Outer shell thick section:

Wall thickness: $t_{shell2} = 0.5$ in

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 4 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

$$OD: \quad od_{shell2} = id_{shell} + 2(t_{shell2})$$

G loading from EPRI drop data (Reference 6): $g_{dec} = 32.3$

Data from weight and center of gravity calculations:

Weight of shielding up Column 14: $W_{18a} = 32,000$ lbs

Length of shielding: $l_{sh} = (30 \text{ ft} + 0.75 \text{ in}) - 1.75 \text{ in}$

Weight of package (except stiffeners and payload) uniformly distributed:

From Column 14: $W_{base1} = 39,000$ lbs

Up to Column 14: $W_{base2} = 39,000 \text{ lbs} + W_{18a}$

Uniform distributed weight of package:

Up to Column 14: $W_{base2} = g_{dec} (W_{base1}/l_{pipe} + W_{18a}/l_{sh})$

$W_{base2} = 4,895$ lbs/in

From Column 14: $W_{base1} = (g_{dec} W_{base1})/l_{pipe}$
 lbs/in

$W_{base} = 2,016$

Weight of stiffener rings:

Bottom end flange: $W_4 = 2,600$ lbs

Type 1 stiffener rings: $W_2 = 450$ lbs

Type 2a stiffener rings: $W_{3a} = 525$ lbs

Type 2b stiffener rings: $W_{3b} = 600$ lbs

Weight of payload: $W_{21} = 20,000$ lbs

CG of payload from center of bottom flange: $cg_{pay} = 32.56$ ft
 Putting it between Columns 15 and 16.

Moment of inertia and cross sectional area of pipe:

Moment of inertia: $I_{pipe} = \pi(od_{pipe}^4 - id_{pipe}^4)/64$

Cross sectional area: $A_{pipe} = \pi(od_{pipe}^2 - id_{pipe}^2)/4$

Moment of inertia and cross sectional area of thin outer shell:

Moment of inertia: $I_{os1} = \pi(od_{shell1}^4 - id_{shell}^4)/64$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 5 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

Cross sectional area: $A_{os1} = \pi(od_{shell1}^2 - id_{shell}^2)/4$

Moment of inertia and cross sectional area of thick outer shell:

Moment of inertia: $I_{os2} = \pi(od_{shell2}^4 - id_{shell}^4)/64$

Cross sectional area: $A_{os2} = \pi(od_{shell2}^2 - id_{shell}^2)/4$

Moment of inertia and cross sectional area of composites:

Pipe with thin outer shell:

Moment of inertia: $I_1 = I_{pipe} + I_{os1}$

Cross sectional area: $A_1 = A_{pipe} + A_{os1}$

Pipe with thick outer shell:

Moment of inertia: $I_2 = I_{pipe} + I_{os2}$

Cross sectional area: $A_2 = A_{pipe} + A_{os2}$

Length between centerline of supports:

$$l_1 = 9.750 \text{ in}$$

$$l_2 = (2 \text{ ft} + 10 \text{ in}) - l_1$$

$$l_3 = (4 \text{ ft} + 10.250 \text{ in}) - (2 \text{ ft} + 10 \text{ in})$$

$$l_4 = (5 \text{ ft} + 7.750 \text{ in}) - (4 \text{ ft} + 10.250 \text{ in})$$

$$l_5 = (8 \text{ ft} + 3.250 \text{ in}) - (5 \text{ ft} + 7.750 \text{ in})$$

$$l_6 = (10 \text{ ft} + 10.750 \text{ in}) - (8 \text{ ft} + 3.250 \text{ in})$$

$$l_7 = (13 \text{ ft} + 6.25 \text{ in}) - (10 \text{ ft} + 10.750 \text{ in})$$

$$l_8 = (16 \text{ ft} + 1.750 \text{ in}) - (13 \text{ ft} + 6.25 \text{ in})$$

$$l_9 = (18 \text{ ft} + 9.250 \text{ in}) - (16 \text{ ft} + 1.750 \text{ in})$$

$$l_{10} = (21 \text{ ft} + 4.750 \text{ in}) - (18 \text{ ft} + 9.250 \text{ in})$$

$$l_{11} = (24 \text{ ft} + 0.250 \text{ in}) - (21 \text{ ft} + 4.750 \text{ in})$$

$$l_{12} = (24 \text{ ft} + 9.750 \text{ in}) - (24 \text{ ft} + 0.250 \text{ in})$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 6 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

$$l_{13} = (27 \text{ ft} + 5.25 \text{ in}) - (24 \text{ ft} + 9.750 \text{ in})$$

$$l_{14} = (30 \text{ ft} + 0.750 \text{ in}) - (27 \text{ ft} + 5.25 \text{ in})$$

$$l_{15} = (32 \text{ ft} + 8.250 \text{ in}) - (30 \text{ ft} + 0.750 \text{ in})$$

$$l_{16} = (35 \text{ ft} + 3.750 \text{ in}) - (32 \text{ ft} + 8.250 \text{ in})$$

$$l_{17} = (37 \text{ ft} + 11.750 \text{ in}) - (35 \text{ ft} + 3.750 \text{ in})$$

$$l_{18} = (40 \text{ ft} + 6.750 \text{ in}) - (37 \text{ ft} + 11.750 \text{ in})$$

$$l_{19} = (43 \text{ ft} + 2.250 \text{ in}) - (40 \text{ ft} + 6.750 \text{ in})$$

$$l_{20} = (45 \text{ ft} + 9.750 \text{ in}) - (43 \text{ ft} + 2.250 \text{ in})$$

$$l_{21} = (48 \text{ ft} + 5.25 \text{ in}) - (45 \text{ ft} + 9.750 \text{ in})$$

$$l_{22} = (49 \text{ ft} + 2.750 \text{ in}) - (48 \text{ ft} + 5.25 \text{ in})$$

$$l_{23} = (51 \text{ ft} + 2.750 \text{ in}) - (49 \text{ ft} + 2.750 \text{ in})$$

$$l_{24} = (52 \text{ ft} + 0.750 \text{ in}) - (51 \text{ ft} + 2.750 \text{ in})$$

CG of pump locations relative to Column 15 and 16:

$$\text{Distance from Column 15: } d_a = cg_{\text{pay}} - (30 \text{ ft} + 0.750 \text{ in})$$

$$\text{Distance from Column 16: } d_b = (32 \text{ ft} + 8.25 \text{ in}) - cg_{\text{pay}}$$

Using the Three Moment Theorem, determine moments at the supports:

End Conditions assuming simply supported:

$$\text{At bottom end flange end: } M_a = 0.0 \text{ lbs-in}$$

At top end moments due to top caps exists, model as uniform cantilevered load of combined weight of both inner and outer top caps.

$$\text{Weight of outer top cap: } W_{19} = 1,900 \text{ lbs}$$

$$\text{Weight of inner top cap: } W_{20} = 1,500 \text{ lbs}$$

$$\text{Total weight: } W_{\text{tcap}} = W_{19} + W_{20}$$

$$\text{Length of outer top cap: } l_{\text{tcap}} = (2 \text{ ft} + 1.875 \text{ in}) + 2.25 \text{ in}$$

Assume load is distributed in a triangular shape along the length:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 7 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

$$M_y = - (1/3 g_{dec} W_{tcap} l_{tcap})$$

Constraints: $M_a = 0.0 \text{ lbs-in}$ $M_y = - (1/3 g_{dec} W_{tcap} l_{tcap})$

Span 1 and 2:

$$M_a \frac{l_1}{I_1} + 2 M_b \left(\frac{l_1}{I_1} + \frac{l_2}{I_1} \right) + M_c \frac{l_2}{I_1} = - \frac{w_{base2}}{4} \left(\frac{l_1^3}{I_1} + \frac{l_2^3}{I_1} \right)$$

Span 2 and 3:

$$M_b \frac{l_2}{I_1} + 2 M_c \left(\frac{l_2}{I_1} + \frac{l_3}{I_1} \right) + M_d \frac{l_3}{I_1} = - \frac{w_{base2}}{4} \left(\frac{l_2^3}{I_1} + \frac{l_3^3}{I_1} \right)$$

Span 3 and 4:

$$M_c \frac{l_3}{I_1} + 2 M_d \left(\frac{l_3}{I_1} + \frac{l_4}{I_1} \right) + M_e \frac{l_4}{I_1} = - \frac{w_{base2}}{4} \left(\frac{l_3^3}{I_1} + \frac{l_4^3}{I_1} \right)$$

Span 4 and 5:

$$M_d \frac{l_4}{I_1} + 2 M_e \left(\frac{l_4}{I_1} + \frac{l_5}{I_1} \right) + M_f \frac{l_5}{I_1} = - \frac{w_{base2}}{4} \left(\frac{l_4^3}{I_1} + \frac{l_5^3}{I_1} \right)$$

Span 5 and 6:

$$M_e \frac{l_5}{I_1} + 2 M_f \left(\frac{l_5}{I_1} + \frac{l_6}{I_1} \right) + M_g \frac{l_6}{I_1} = - \frac{w_{base2}}{4} \left(\frac{l_5^3}{I_1} + \frac{l_6^3}{I_1} \right)$$

Span 6 and 7:

$$M_f \frac{l_6}{I_1} + 2 M_g \left(\frac{l_6}{I_1} + \frac{l_7}{I_1} \right) + M_h \frac{l_7}{I_1} = - \frac{w_{base2}}{4} \left(\frac{l_6^3}{I_1} + \frac{l_7^3}{I_1} \right)$$

Span 7 and 8, Transition from thin to thick outer shell:

$$M_g \frac{l_7}{I_1} + 2 M_h \left(\frac{l_7}{I_1} + \frac{l_8}{I_2} \right) + M_i \frac{l_8}{I_2} = - \frac{w_{base2}}{4} \left(\frac{l_7^3}{I_1} + \frac{l_8^3}{I_2} \right)$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 8 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow *Sec* Date 08/31/94

Span 8 and 9:

$$M_h \frac{l_8}{I_2} + 2 M_i \left(\frac{l_8}{I_2} + \frac{l_9}{I_2} \right) + M_j \frac{l_9}{I_2} = - \frac{w_{base2}}{4} \left(\frac{l_8^3}{I_2} + \frac{l_9^3}{I_2} \right)$$

Span 9 and 10:

$$M_i \frac{l_9}{I_2} + 2 M_j \left(\frac{l_9}{I_2} + \frac{l_{10}}{I_2} \right) + M_k \frac{l_{10}}{I_2} = - \frac{w_{base2}}{4} \left(\frac{l_9^3}{I_2} + \frac{l_{10}^3}{I_2} \right)$$

Span 10 and 11:

$$M_j \frac{l_{10}}{I_2} + 2 M_k \left(\frac{l_{10}}{I_2} + \frac{l_{11}}{I_2} \right) + M_l \frac{l_{11}}{I_2} = - \frac{w_{base2}}{4} \left(\frac{l_{10}^3}{I_2} + \frac{l_{11}^3}{I_2} \right)$$

Span 11 and 12:

$$M_k \frac{l_{11}}{I_2} + 2 M_l \left(\frac{l_{11}}{I_2} + \frac{l_{12}}{I_2} \right) + M_m \frac{l_{12}}{I_2} = - \frac{w_{base2}}{4} \left(\frac{l_{11}^3}{I_2} + \frac{l_{12}^3}{I_2} \right)$$

Span 12 and 13:

$$M_l \frac{l_{12}}{I_2} + 2 M_m \left(\frac{l_{12}}{I_2} + \frac{l_{13}}{I_2} \right) + M_n \frac{l_{13}}{I_2} = - \frac{w_{base2}}{4} \left(\frac{l_{12}^3}{I_2} + \frac{l_{13}^3}{I_2} \right)$$

Span 13 and 14:

$$M_m \frac{l_{13}}{I_2} + 2 M_n \left(\frac{l_{13}}{I_2} + \frac{l_{14}}{I_2} \right) + M_o \frac{l_{14}}{I_2} = - \frac{w_{base2}}{4} \left(\frac{l_{13}^3}{I_2} + \frac{l_{14}^3}{I_2} \right)$$

Span 14 and 15, Transition from thick to thin outer shell and pump cg location:

$$M_n \frac{l_{14}}{I_2} + 2 M_o \left(\frac{l_{14}}{I_2} + \frac{l_{15}}{I_1} \right) + M_p \frac{l_{15}}{I_1} = - \frac{1}{4} \left(\frac{w_{base2} l_{14}^3}{I_2} + \frac{w_{base1} l_{15}^3}{I_1} \right) + \frac{g_{dec} w_{21} d_a (l_{15}^2 - d_a^2)}{l_{15} I_1}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 9 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow *SC* Date 08/31/94

Span 15 and 16, pump cg location:

$$M_o \frac{l_{15}}{I_1} + 2 M_p \left(\frac{l_{15}}{I_1} + \frac{l_{16}}{I_1} \right) + M_q \frac{l_{16}}{I_1} = - \frac{w_{base1}}{4} \left(\frac{l_{15}^3}{I_1} + \frac{l_{16}^3}{I_1} \right) + - \frac{g_{dec} w_{21} d_b (l_{15}^2 - d_b^2)}{l_{15} I_1}$$

Span 16 and 17:

$$M_p \frac{l_{16}}{I_1} + 2 M_q \left(\frac{l_{16}}{I_1} + \frac{l_{17}}{I_1} \right) + M_r \frac{l_{17}}{I_1} = - \frac{w_{base1}}{4} \left(\frac{l_{16}^3}{I_1} + \frac{l_{17}^3}{I_1} \right)$$

Span 17 and 18:

$$M_q \frac{l_{17}}{I_1} + 2 M_r \left(\frac{l_{17}}{I_1} + \frac{l_{18}}{I_1} \right) + M_s \frac{l_{18}}{I_1} = - \frac{w_{base1}}{4} \left(\frac{l_{17}^3}{I_1} + \frac{l_{18}^3}{I_1} \right)$$

Span 18 and 19:

$$M_r \frac{l_{18}}{I_1} + 2 M_s \left(\frac{l_{18}}{I_1} + \frac{l_{19}}{I_1} \right) + M_t \frac{l_{19}}{I_1} = - \frac{w_{base1}}{4} \left(\frac{l_{18}^3}{I_1} + \frac{l_{19}^3}{I_1} \right)$$

Span 19 and 20:

$$M_s \frac{l_{19}}{I_1} + 2 M_t \left(\frac{l_{19}}{I_1} + \frac{l_{20}}{I_1} \right) + M_u \frac{l_{20}}{I_1} = - \frac{w_{base1}}{4} \left(\frac{l_{19}^3}{I_1} + \frac{l_{20}^3}{I_1} \right)$$

Span 20 and 21:

$$M_t \frac{l_{20}}{I_1} + 2 M_u \left(\frac{l_{20}}{I_1} + \frac{l_{21}}{I_1} \right) + M_v \frac{l_{21}}{I_1} = - \frac{w_{base1}}{4} \left(\frac{l_{20}^3}{I_1} + \frac{l_{21}^3}{I_1} \right)$$

Span 21 and 22:

$$M_u \frac{l_{21}}{I_1} + 2 M_v \left(\frac{l_{21}}{I_1} + \frac{l_{22}}{I_1} \right) + M_w \frac{l_{22}}{I_1} = - \frac{w_{base1}}{4} \left(\frac{l_{21}^3}{I_1} + \frac{l_{22}^3}{I_1} \right)$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 10 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow *SR* Date 08/31/94

Span 22 and 23:

$$M_v \frac{I_{22}}{I_1} + 2 M_w \left(\frac{I_{22}}{I_1} + \frac{I_{23}}{I_1} \right) + M_x \frac{I_{23}}{I_1} = - \frac{w_{base1}}{4} \left(\frac{I_{22}^3}{I_1} + \frac{I_{23}^3}{I_1} \right)$$

Span 23 and 24:

$$M_w \frac{I_{23}}{I_1} + 2 M_x \left(\frac{I_{23}}{I_1} + \frac{I_{24}}{I_1} \right) + M_y \frac{I_{24}}{I_1} = - \frac{w_{base1}}{4} \left(\frac{I_{23}^3}{I_1} + \frac{I_{24}^3}{I_1} \right)$$

	lbs-in		lbs-in
M _a	0	M _b	-171,934
M _c	-284,357	M _d	-130,047
M _e	-297,716	M _f	-433,459
M _g	-397,198	M _h	-406,497
M _i	-406,682	M _j	-395,521
M _k	-439,982	M _l	-273,298
M _m	-319,179	M _n	-334,384
M _o	-772,032	M _p	-267,615
M _q	-143,906	M _r	-173,979
M _s	-161,566	M _t	-164,557
M _u	-180,557	M _v	-113,565
M _w	-125,034	M _x	85,646
M _y	-1 x 10 ⁶		

Maximum moments between supports and reactions at supports:

Span 1, M_a < M_b:

$$M_1 = \frac{w_{base2} I_1^2}{8} - \frac{M_a + M_b}{2} + \frac{(M_a - M_b)^2}{2 w_{base2} I_1^2}$$

$$M_1 = 175,900 \text{ lbs-in}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 11 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

$$R_a = \frac{w_{base2} l_1}{2} - \frac{M_a - M_b}{l_1} + g_{dec} W_4$$

$$R_a = 90,211 \text{ lbs}$$

Span 2, $M_b < M_c$:

$$M_2 = \frac{w_{base2} l_2^2}{8} - \frac{M_b + M_c}{2} + \frac{(M_b - M_c)^2}{2 w_{base2} l_2^2}$$

$$M_2 = 590,194 \text{ lbs-in}$$

$$R_b = \left(\frac{w_{base2} l_1}{8} + \frac{M_a - M_b}{l_1} \right) + \left(\frac{w_{base2} l_2}{8} - \frac{M_b - M_c}{l_2} \right) + g_{dec} W_{3a}$$

$$R_b = 50,761 \text{ lbs}$$

Span 3, $M_c > M_d$:

$$M_3 = \frac{w_{base2} l_3^2}{8} - \frac{M_c + M_d}{2} + \frac{(M_c - M_d)^2}{2 w_{base2} l_3^2}$$

$$M_3 = 571,191 \text{ lbs-in}$$

$$R_c = \left(\frac{w_{base2} l_2}{8} + \frac{M_b - M_c}{l_2} \right) + \left(\frac{w_{base2} l_3}{8} + \frac{M_c - M_d}{l_3} \right) + g_{dec} W_2$$

$$R_c = 42,486 \text{ lbs}$$

Span 4, $M_d < M_e$:

$$M_4 = \frac{w_{base2} l_4^2}{8} - \frac{M_d + M_e}{2} + \frac{(M_d - M_e)^2}{2 w_{base2} l_4^2}$$

$$M_4 = 300,923 \text{ lbs-in}$$

$$R_d = \left(\frac{w_{base2} l_3}{8} - \frac{M_c - M_d}{l_3} \right) + \left(\frac{w_{base2} l_4}{8} - \frac{M_d - M_e}{l_4} \right) + g_{dec} W_{3b}$$

$$R_d = 28,747 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 12 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow *SRC* Date 08/31/94

Span 5, $M_e < M_f$:

$$M_5 = \frac{w_{base2} l_5^2}{8} - \frac{M_e + M_f}{2} + \frac{(M_e - M_f)^2}{2 w_{base2} l_5^2}$$

$$M_5 = 974,671 \text{ lbs-in}$$

$$R_e = \left(\frac{w_{base2} l_4}{8} + \frac{M_d - M_e}{l_4} \right) + \left(\frac{w_{base2} l_5}{8} - \frac{M_e - M_f}{l_5} \right) + \mathcal{G}_{dec} W_{3b}$$

$$R_e = 57,809 \text{ lbs}$$

Span 6, $M_f > M_g$:

$$M_6 = \frac{w_{base2} l_6^2}{8} - \frac{M_f + M_g}{2} + \frac{(M_f - M_g)^2}{2 w_{base2} l_6^2}$$

$$M_6 = 1 \times 10^6 \text{ lbs-in}$$

$$R_f = \left(\frac{w_{base2} l_5}{8} + \frac{M_e - M_f}{l_5} \right) + \left(\frac{w_{base2} l_6}{8} - \frac{M_f - M_g}{l_6} \right) + \mathcal{G}_{dec} W_2$$

$$R_f = 58,547 \text{ lbs}$$

Span 7, $M_g < M_h$:

$$M_7 = \frac{w_{base2} l_7^2}{8} - \frac{M_g + M_h}{2} + \frac{(M_g - M_h)^2}{2 w_{base2} l_7^2}$$

$$M_7 = 1 \times 10^6 \text{ lbs-in}$$

$$R_g = \left(\frac{w_{base2} l_6}{8} - \frac{M_f - M_g}{l_6} \right) + \left(\frac{w_{base2} l_7}{8} - \frac{M_g - M_h}{l_7} \right) + \mathcal{G}_{dec} W_2$$

$$R_g = 53,942 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 13 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

Span 8, $M_h < M_i$:

$$M_8 = \frac{w_{base2} l_8^2}{8} - \frac{M_h + M_i}{2} + \frac{(M_h - M_i)^2}{2 w_{base2} l_8^2}$$

$$M_8 = 1 \times 10^6 \text{ lbs-in}$$

$$R_h = \left(\frac{w_{base2} l_7}{8} + \frac{M_g - M_h}{l_7} \right) + \left(\frac{w_{base2} l_8}{8} - \frac{M_g - M_h}{l_8} \right) + G_{dec} W_2$$

$$R_h = 53,087 \text{ lbs}$$

Span 9, $M_i > M_j$:

$$M_9 = \frac{w_{base2} l_9^2}{8} - \frac{M_i + M_j}{2} + \frac{(M_i - M_j)^2}{2 w_{base2} l_9^2}$$

$$M_9 = 1 \times 10^6 \text{ lbs-in}$$

$$R_i = \left(\frac{w_{base2} l_8}{8} + \frac{M_h - M_i}{l_8} \right) + \left(\frac{w_{base2} l_9}{8} + \frac{M_i - M_j}{l_9} \right) + G_{dec} W_2$$

$$R_i = 52,738 \text{ lbs}$$

Span 10, $M_j < M_k$:

$$M_{10} = \frac{w_{base2} l_{10}^2}{8} - \frac{M_j + M_k}{2} + \frac{(M_j - M_k)^2}{2 w_{base2} l_{10}^2}$$

$$M_{10} = 1 \times 10^6 \text{ lbs-in}$$

$$R_j = \left(\frac{w_{base2} l_9}{8} - \frac{M_i - M_j}{l_9} \right) + \left(\frac{w_{base2} l_{10}}{8} - \frac{M_j - M_k}{l_{10}} \right) + G_{dec} W_2$$

$$R_j = 52,029 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 14 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

Span 11, $M_k > M_l$:

$$M_{11} = \frac{w_{base2} l_{11}^2}{8} - \frac{M_k + M_l}{2} + \frac{(M_k - M_l)^2}{2 w_{base2} l_{11}^2}$$

$$M_{11} = 966,687 \text{ lbs-in}$$

$$R_k = \left(\frac{w_{base2} l_{10}}{8} + \frac{M_l - M_k}{l_{10}} \right) + \left(\frac{w_{base2} l_{11}}{8} + \frac{M_k - M_l}{l_{11}} \right) + G_{dec} W_2$$

$$R_k = 49,206 \text{ lbs}$$

Span 12, $M_l < M_m$:

$$M_{12} = \frac{w_{base2} l_{12}^2}{8} - \frac{M_l + M_m}{2} + \frac{(M_l - M_m)^2}{2 w_{base2} l_{12}^2}$$

$$M_{12} = 353,847 \text{ lbs-in}$$

$$R_l = \left(\frac{w_{base2} l_{11}}{8} - \frac{M_k - M_l}{l_{11}} \right) + \left(\frac{w_{base2} l_{12}}{8} - \frac{M_l - M_m}{l_{12}} \right) + G_{dec} W_{3a}$$

$$R_l = 42,509 \text{ lbs}$$

Span 13, $M_m > M_n$:

$$M_{13} = \frac{w_{base2} l_{13}^2}{8} - \frac{M_m + M_n}{2} + \frac{(M_m - M_n)^2}{2 w_{base2} l_{13}^2}$$

$$M_{13} = 933,992 \text{ lbs-in}$$

$$R_m = \left(\frac{w_{base2} l_{12}}{8} + \frac{M_l - M_m}{l_{12}} \right) + \left(\frac{w_{base2} l_{13}}{8} + \frac{M_m - M_n}{l_{13}} \right) + G_{dec} W_{3a}$$

$$R_m = 46,393 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 15 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

Span 14, $M_n < M_o$:

$$M_{14} = \frac{w_{base2} l_{14}^2}{8} - \frac{M_n + M_o}{2} + \frac{(M_n - M_o)^2}{2 w_{base2} l_{14}^2}$$

$$M_{14} = 1,180,111 \text{ lbs-in}$$

$$R_n = \left(\frac{w_{base2} l_{13}}{8} - \frac{M_m - M_n}{l_{13}} \right) + \left(\frac{w_{base2} l_{14}}{8} - \frac{M_j - M_k}{l_{14}} \right) + g_{dec} W_2$$

$$R_n = 51,192 \text{ lbs}$$

Span 15, $M_o > M_p$, Span where pump is located:

$$\text{Location of maximum moment: } x_{max} = l_{15}/2 + [(M_o - M_p)/(w_{base} l_{15})]$$

$$\text{Moment due to pump at location: } M_{pump} = (g_{dec} W_{21} d_b x_{max})/l_{15}$$

$$\text{Reaction at o due to pump: } R_{po} = (g_{dec} W_{21} d_b)/l_{15}$$

$$M_{15} = \frac{w_{base1} l_{15}^2}{8} - \frac{M_o + M_p}{2} + \frac{(M_o - M_p)^2}{2 w_{base1} l_{15}^2} + M_{pump}$$

$$M_{15} = 1,078,497 \text{ lbs-in}$$

$$R_o = \left(\frac{w_{base2} l_{14}}{8} + \frac{M_n - M_o}{l_{14}} \right) + \left(\frac{w_{base1} l_{15}}{8} + \frac{M_o - M_p}{l_{15}} \right) + R_{po} + g_{dec} W_2$$

$$R_o = 71,008 \text{ lbs}$$

Span 16, $M_p > M_q$:

$$M_{16} = \frac{w_{base1} l_{16}^2}{8} - \frac{M_p + M_q}{2} + \frac{(M_p - M_q)^2}{2 w_{base1} l_{16}^2}$$

$$M_{16} = 459,673 \text{ lbs-in}$$

$$\text{Reaction at p due to pump: } R_{pp} = (g_{dec} W_{21} d_a)/l_{15}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 16 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow *SR* Date 08/31/94

$$R_p = \left(\frac{w_{base1} l_{15}}{8} - \frac{M_o - M_p}{l_{15}} \right) + R_{pp} + \left(\frac{w_{base1} l_{16}}{8} + \frac{M_p - M_q}{l_{16}} \right) + \mathcal{G}_{dec} W_2$$

$$R_p = 657,122 \text{ lbs}$$

Span 17, $M_q > M_r$:

$$M_{17} = \frac{w_{base1} l_{17}^2}{8} - \frac{M_q + M_r}{2} + \frac{(M_q - M_r)^2}{2 w_{base1} l_{17}^2}$$

$$M_{17} = 417,251 \text{ lbs-in}$$

$$R_q = \left(\frac{w_{base1} l_{16}}{8} - \frac{M_p - M_q}{l_{16}} \right) + \left(\frac{w_{base1} l_{17}}{8} - \frac{M_q - M_r}{l_{17}} \right) + \mathcal{G}_{dec} W_2$$

$$R_q = 33,527 \text{ lbs}$$

Span 18, $M_r > M_s$:

$$M_{18} = \frac{w_{base1} l_{18}^2}{8} - \frac{M_r + M_s}{2} + \frac{(M_r - M_s)^2}{2 w_{base1} l_{18}^2}$$

$$M_{18} = 410,023 \text{ lbs-in}$$

$$R_r = \left(\frac{w_{base1} l_{17}}{8} - \frac{M_q - M_r}{l_{17}} \right) + \left(\frac{w_{base1} l_{18}}{8} + \frac{M_r - M_s}{l_{18}} \right) + \mathcal{G}_{dec} W_2$$

$$R_r = 30,953 \text{ lbs}$$

Span 19, $M_s < M_c$:

$$M_{19} = \frac{w_{base1} l_{19}^2}{8} - \frac{M_s + M_c}{2} + \frac{(M_s - M_c)^2}{2 w_{base1} l_{19}^2}$$

$$M_{19} = 413,151 \text{ lbs-in}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 17 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

$$R_s = \left(\frac{w_{base1} l_{18}}{8} - \frac{M_r - M_s}{l_{18}} \right) + \left(\frac{w_{base1} l_{19}}{8} - \frac{M_g - M_c}{l_{19}} \right) + G_{dec} W_2$$

$$R_s = 30,593 \text{ lbs}$$

Span 20, $M_c < M_u$:

$$M_{20} = \frac{w_{base1} l_{20}^2}{8} - \frac{M_c + M_u}{2} + \frac{(M_c - M_u)^2}{2 w_{base1} l_{20}^2}$$

$$M_{20} = 422,708 \text{ lbs-in}$$

$$R_t = \left(\frac{w_{base1} l_{19}}{8} + \frac{M_s - M_c}{l_{19}} \right) + \left(\frac{w_{base1} l_{20}}{8} - \frac{M_c - M_u}{l_{20}} \right) + G_{dec} W_2$$

$$R_t = 30,001 \text{ lbs}$$

Span 21, $M_u > M_v$:

$$M_{21} = \frac{w_{base1} l_{21}^2}{8} - \frac{M_u + M_v}{2} + \frac{(M_u - M_v)^2}{2 w_{base1} l_{21}^2}$$

$$M_{21} = 398,270 \text{ lbs-in}$$

$$R_u = \left(\frac{w_{base1} l_{20}}{8} + \frac{M_c - M_u}{l_{20}} \right) + \left(\frac{w_{base1} l_{21}}{8} + \frac{(M_u + M_v)}{l_{21}} \right) + G_{dec} W_2$$

$$R_u = 28,795 \text{ lbs}$$

Span 22, $M_v < M_w$:

$$M_{22} = \frac{w_{base1} l_{22}^2}{8} - \frac{M_v + M_w}{2} + \frac{(M_v - M_w)^2}{2 w_{base1} l_{22}^2}$$

$$M_{22} = 142,407 \text{ lbs-in}$$

$$R_v = \left(\frac{w_{base1} l_{21}}{8} - \frac{M_u - M_v}{l_{21}} \right) + \left(\frac{w_{base1} l_{22}}{8} - \frac{M_v - M_w}{l_{22}} \right) - G_{dec} W_{3b}$$

$$R_v = 30,633 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 18 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

Span 23, $M_w > M_x$:

$$M_{23} = \frac{w_{base1} l_{23}^2}{8} - \frac{M_w + M_x}{2} + \frac{(M_w - M_x)^2}{2 w_{base1} l_{23}^2}$$

$$M_{23} = 183,978 \text{ lbs-in}$$

$$R_w = \left(\frac{w_{base1} l_{22}}{8} + \frac{M_w - M_x}{l_{22}} \right) + \left(\frac{w_{base1} l_{23}}{8} + \frac{(M_w - M_x)}{l_{23}} \right) + g_{dec} W_{3b}$$

$$R_w = 20,252 \text{ lbs}$$

Span 24, $M_x < M_y$:

$$M_{24} = \frac{w_{base1} l_{24}^2}{8} - \frac{M_x + M_y}{2} + \frac{(M_x - M_y)^2}{2 w_{base1} l_{24}^2}$$

$$M_{24} = 3,581,211 \text{ lbs-in}$$

$$R_x = \left(\frac{w_{base1} l_{23}}{8} - \frac{M_w - M_x}{l_{23}} \right) + \left(\frac{w_{base1} l_{24}}{8} - \frac{(M_x - M_y)}{l_{24}} \right) + g_{dec} W_2$$

$$R_x = -79,638 \text{ lbs}$$

Reaction at Column 25:

$$R_y = \frac{w_{base1} l_{24}}{8} + \frac{M_x - M_y}{l_{24}} + g_{dec} W_{tcap}$$

$$R_y = 223,861 \text{ lbs}$$

Maximum loading on ring:

Maximum loading on ring at Column 15, R_p . Model as combined loading of Ring loaded as loading smeared over entire volume of the ring Reference 7, pages 176 and 178, Case 22 and opposed by a reactive load transferred by tangential shear Case 24. Also assume ring acts as a curved beam (shown Figures 2 and 3).

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 19 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94




Figure 2




Figure 3

Nominal radius of ring:

OD of ring: $od_{ring} = 5 \text{ ft} + 11.625 \text{ in}$

$R_{ring} = od_{ring}/2$ $R_{ring} = 2.98 \text{ ft}$

Width of ring: $b_{ring} = 1.5 \text{ in}$

Distributed weight of ring throughout cross section:

$w_{ring} = R_p / (\pi R_{ring}^2 b_{ring})$ $w_{ring} = 109 \text{ lbs/in}^3$

Case 20 Maximum Loading at bottom of ring:

$\alpha = 0 \text{ deg}$ $\theta = 0 \text{ deg}$

$u = \cos(\alpha)$ $s = \sin(\theta)$ $c = \cos(\theta)$ $z = \sin(\alpha)$

Maximum moment loading: $M_{1ring} = \frac{1}{4} w_{ring} R_{ring}^3$ $M_{1ring} = 3.75 \times 10^6 \text{ lbs}$

Circumferential Tension:

$T_{1ring} = w_{ring} R_{ring}^2 (1 + 1/4 u - 1/2 \pi z + 1/2 \alpha z)$

$T_{1ring} = 174,307 \text{ lbs/in}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 20 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

Radial Shear:

$$V_{1ring} = W_{ring} R_{ring}^2 (1/2 \alpha u + 1/4 z - 1/2 \pi u)$$

$$V_{1ring} = -219,041 \text{ lbs/in}$$

Case 25, Opposing moment at bottom of ring, $\theta = 0^\circ$, $\alpha = 0^\circ$:

Counteracting Moment:

$$M_{2ring} = - [R_p R_{ring} [0.23868 u - 1/2 s + 0.15915 (a z + \theta s + c - u c^2)]]$$

$$M_{2ring} = -5.62 \times 10^6 \text{ lbs-in}$$

Circumferential Tension:

$$T_{2ring} = R_p [0.15915 (\alpha z - u c^2) - 0.07958 u]$$

$$T_{2ring} = -156,875 \text{ lbs}$$

Radial Shear:

$$V_{2ring} = - [R_p [0.15915 (\alpha u - 1/2 z + z c^2) - 1/2 u]]$$

$$V_{2ring} = 328,561 \text{ lbs}$$

Resultant loading:

Maximum Moment:

$$M_{rring} = M_{1ring} b_{ring} + M_{2ring} \quad M_{rring} = 1,233 \text{ lbs-in}$$

Circumferential Tension:

$$T_{rring} = T_{1ring} b_{ring} + T_{2ring} \quad T_{rring} = 104,586 \text{ lbs}$$

Radial Shear:

$$V_{rring} = V_{1ring} b_{ring} + V_{2ring} \quad V_{rring} = 0 \text{ lbs}$$

Geometric parameters of pipe:

$$\text{Inside radius of ring is id of pipe: } r_{ring} = (od_{pipe} - t_{pipe})/2$$

Normal depth of ring including pipe thickness:

$$h_{ring} = R_{ring} - r_{ring} \quad h_{ring} = 4.06 \text{ in}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 21 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

Neutral axis of ring:

$$r_{na} = \frac{h_{ring}}{\ln\left(\frac{R_{ring}}{r_{ring}}\right)}$$

CG of ring:

$$r_{cg} = r_{ring} + (h_{ring}/2)$$

Eccentricity: $ecc = r_{cg} - r_{na}$

Cross sectional area: $A_{ring} = h_{ring} b_{ring}$

Stresses in ring:

Bending stress:

$$\sigma_{bottom} = \frac{M_{rring} (r_{na} r_{ring})}{A_{ring} ecc r_{ring}}$$

$$\sigma_{bottom} = 311 \text{ psi}$$

Tangential stress:

$$\sigma_{tan} = T_{rring}/A_{ring} \quad \sigma_{tan} = 17,163 \text{ psi}$$

Maximum shear stress:

$$\tau_{ring} = 2 V_{rring}/A_{ring} \quad \tau_{ring} = 0 \text{ psi}$$

Total stress:

$$\sigma_{tot} = \sigma_{bottom} + \sigma_{tan} + \tau_{ring} \quad \sigma_{tot} = 17,474 \text{ psi}$$

ASME allowable from previous data: $s_a = 23,270 \text{ psi}$

Margin of Safety on inner pipe:

$$MS_{pipe} = (s_a/\sigma_{tot}) - 1 \quad MS_{pipe} = 0.33 \quad \text{OK}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 22 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

Maximum Loading on inner containment pipe between rings:




Figure 4

Maximum bending between Columns 24 and 25:

$$\sigma_{bmax} = \frac{M_{24} \left(\frac{od_{pipe}}{2} \right)}{I_{pipe}}$$

$$\sigma_{bmax} = 2,279 \text{ psi}$$

Short beam criteria applies here, therefore must consider maximum shear at support.

Maximum shear: $\tau_{ymax} = 2 R_y / A_{pipe}$ $\tau_{ymax} = 4,489 \text{ psi}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 23 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

Bending at support:

$$\sigma_{by} = \frac{|M_y| \frac{od_{pipe}}{2}}{I_{pipe}}$$

$$\sigma_{by} = 655 \text{ psi}$$

Total stress at pipe section:

$$\sigma_{ytot} = \sigma_{bmax} + \tau_{ymax}$$

$$\sigma_{ytot} = 6,768 \text{ psi}$$

Margin of Safety:

$$MS_{ypipe} = (s_a / \sigma_{ytot}) - 1$$

$$MS_{ypipe} = 2.44 \quad \text{OK}$$

Loading on Inner Blind Flange Plate:

Assuming inside pipe welds carry the entire load determine weld strength.




Figure 5

Plate thickness: $t_{bef} = 2.0$ in

From ASME, allowable at joint discontinuities: $1.5 s_a = 34,905$ psi

Since welds are 100% radiographed assume full strength of fillets.

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 24 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

Weld size, assuming on one weld: $w_w = 0.500$ in

Weld diameter is assumed as same size as pipe: $d_w = id_{pipe}$

Circumference of weld (one side only): $c_w = \pi(d_w)$

Pressure loading from pressure calculations at pipe joint discontinuity:

$$s_{btot} = 10,929 \text{ psi}$$

Shear area of weld: $A_w = 0.707 w_w c_w$

Maximum shear due deflection of pipe during drop:

Weight of inner blind flange: $W_g = 1,800$ lbs

$$\tau_{drop} = (2 g_{dec} W_g)/A_w \quad \tau_{drop} = 1,662 \text{ psi}$$

Total stress on weld:

$$\sigma_{wtot} = \tau_{drop} + s_{btot} \quad \sigma_{wtot} = 12,591 \text{ psi}$$

Margin of Safety:

$$MS_{befw} = (1.5 s_w/\sigma_{wtot}) - 1 \quad MS_{befw} = 1.77 \quad \text{OK}$$

Top Cap Loading:

Retaining Ring Loading:

Since fitup tolerance of retaining ring is tighter than for bolts, retaining ring takes up all shear loading from the drop.

Weight of inner top cap: $W_{20} = 1,500$ lbs

ID of retaining ring: $id_{itcrr} = 5 \text{ ft} + 3 \text{ in}$

Wall thickness: $t_{itcrr} = 0.375$ in

OD of retaining ring: $od_{itcrr} = id_{itcrr} + 2 t_{itcrr}$

Cross sectional area of ring:

$$A_{itcrr} = \pi (od_{itcrr}^2 - id_{itcrr}^2)/4$$

Maximum shearing load on the ring cross section:

$$\tau_{rmax} = (2 g_{dec} W_{20})/A_{itcrr}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 25 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

$$\tau_{rrmax} = 1,298 \text{ psi}$$

Margin of Safety:

$$MS_{rrs} = (s_y / \tau_{rrmax}) - 1 \quad MS_{rrs} = 16.93 \quad \text{OK}$$

Loading on the bolts:




Figure 6

CG of top cap from inner flange face: $cg_{itc} = 1.39 \text{ ft}$

Bolt parameters:

Number of bolts: $n_{bitc} = 28$

Nominal diameter of bolts: $d_{bitc} = 1 \text{ in}$

Tensile stress area of each bolt (Reference ASTM, page 1278):

$$A_b = 0.7854 (d_{bitc} - 0.9743 \text{ in}/8)^2$$

Allowable tensile strength of bolts: $\sigma_{bten} = 55,000 \text{ psi}$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 26 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

Total preload and pressure load per bolt from ASME evaluation:

$$W_{btot} = 19,696 \text{ lbs}$$

Angle from vertical flange axis: $\theta_1 = 6.43 \text{ deg}$

Angle of bolt spacing: $\theta_2 = 12.83 \text{ deg}$

Diameter of bolt circle: $d_{bc} = 61 \text{ in}$

Diameter of flange: $d_{flange} = id_{itcrr}$

Distance from Pivot to bolts 14 to 8:

$$r_{bc} = d_{bc}/2 \quad r_{flange} = d_{flange}/2$$

Perpendicular distance:

Distance from pivot to centerline of bolt 14:

$$r_{14} = r_{flange} - r_{bc} \cos(\theta_1)$$

Distance from pivot to centerline of bolt 13:

$$r_{13} = r_{flange} - r_{bc} \cos(\theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 12:

$$r_{12} = r_{flange} - r_{bc} \cos(2 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 11:

$$r_{11} = r_{flange} - r_{bc} \cos(3 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 10:

$$r_{10} = r_{flange} - r_{bc} \cos(4 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 9:

$$r_9 = r_{flange} - r_{bc} \cos(5 \theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 8:

$$r_8 = r_{flange} - r_{bc} \cos(6 \theta_2 + \theta_1)$$

Distance from Pivot to bolts 7 to 1:

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 27 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow *SR* Date 08/31/94

- Distance from pivot to centerline of bolt 7:

$$r_7 = r_{flange} + r_{bc} \sin(\theta_1)$$

Distance from pivot to centerline of bolt 6:

$$r_6 = r_{flange} + r_{bc} \sin(\theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 5:

$$r_5 = r_{flange} + r_{bc} \sin(2\theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 4:

$$r_4 = r_{flange} + r_{bc} \sin(3\theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 3:

$$r_3 = r_{flange} + r_{bc} \sin(4\theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 2:

$$r_2 = r_{flange} + r_{bc} \sin(5\theta_2 + \theta_1)$$

Distance from pivot to centerline of bolt 1:

$$r_1 = r_{flange} + r_{bc} \sin(6\theta_2 + \theta_1)$$

By symmetry bolts 15 to 28 are equal to 14 to 1, respectively.

Moment due to drop due to eccentric loading of bolts:

$$M_{bitc} = g_{dec} W_{20} cg_{itc}$$

Tensile load on bolt 1 (highest loading):

$$F_{bitc1} = \frac{r_1 M_{bitc}}{2 \left(r_1^2 + r_2^2 + r_3^2 + r_4^2 + r_5^2 + r_6^2 + r_7^2 + r_8^2 + r_9^2 + r_{10}^2 + r_{11}^2 + r_{12}^2 + r_{13}^2 + r_{14}^2 \right)}$$

$$F_{bitc1} = 1,225 \text{ lbs}$$

Total bolt load:

$$W_{itcb} = W_{btot} + F_{bitc1}$$

$$W_{itcb} = 20,921 \text{ lbs}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 28 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow *sc* Date 08/31/94

Tensile stress on bolt:

$$\sigma_{\text{bolt}} = W_{\text{itcb}}/A_b \quad \sigma_{\text{bolt}} = 34,538 \text{ psi}$$

Margin of Safety based on bolt ultimate:

$$MS_{\text{bolt}} = (\sigma_{\text{bten}}/\sigma_{\text{bolt}}) - 1 \quad MS_{\text{bolt}} = 0.59 \quad \text{OK}$$

Outer Shell Loading from lead:

Model longest thinnest section only:




Figure 7

ID of shell: $id_{\text{shell}} = 5 \text{ ft} + 8 \text{ in}$

Wall thickness: $t_{516\text{sh}} = 0.3125 \text{ in}$

OD of shell: $od_{\text{shell}} = id_{\text{shell}} + 2(t_{516\text{sh}})$

Inner cross sectional void area of shell:

$$A_{\text{crsh}} = \pi(id_{\text{shell}}^2 - od_{\text{pipe}}^2)/4$$

Longest length between supports: $15_6 = 2.5 \text{ ft}$

Mid point of length: $z_{\text{sh}} = 15_6/2$

Gap of void: $\text{gap} = (id_{\text{shell}} - od_{\text{pipe}})/2 \quad \text{gap} = 2 \text{ in}$

Radius of lead: $r_{\text{pb}} = od_{\text{pipe}}/2 + \text{gap}$

Angle of evaluation: $\theta_{\text{pb}} = 180 \text{ deg}$

Poisson's ratio for carbon steel (Reference 8): $\nu_{\text{cstl}} = 0.3$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 29 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

Density of lead (Reference 13, page 398): $\rho_{pb} = 0.4096 \text{ lbs/in}^3$

Assume 65% density of shot: $\rho_{shot} = 0.65 \rho_{pb}$

Weight of lead between supports:

$$W_{spb} = A_{crsh} \rho_{shot} 15_6$$

$$W_{spb} = 3,312 \text{ lbs}$$

Assume weight of lead smeared over the entire cross sectional area:

$$\text{Cross sectional area: } A_{smr} = \pi/4 \text{ od}_{shell}^2$$

$$\text{Smear density: } \rho_{smr} = W_{spb} / (A_{smr} 15_6)$$

Load between supports at angle of evaluation, stress due to lead slump modeled using membrane theory of pipe filled between supports with a flowable material.

Tangential stress:

$$\sigma_t = \frac{g_{dec} \rho_{smr} r_{pb}^2}{t_{516} sh} (1 - \cos(\theta_{pb}))$$

$$\sigma_t = 7,133 \text{ psi}$$

Longitudinal stress:

$$\sigma_l = \frac{g_{dec} \rho_{smr}}{t_{516} sh} \left(\frac{z_{sh}^2}{2} \right) \cos(\theta_{pb}) + v_{cstl} \sigma_t$$

$$\sigma_l = 1,793 \text{ psi}$$

Shear stress:

$$\sigma_{shr} = \frac{-g_{dec} \rho_{smr}}{t_{516} sh} \left(\frac{z_{sh}^2}{2} \right) \sin(\theta_{pb})$$

$$\sigma_{shr} = 0 \text{ psi}$$

Total stress at maximum deflection (at center of length):

$$\sigma_{pbtot} = \sigma_t + \sigma_l + \sigma_{shr}$$

$$\sigma_{pbtot} = 8,926 \text{ psi}$$

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 30 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow Date 08/31/94

Margin of Safety:

$$MS_{pb} = (s_a / \sigma_{pbtot}) - 1 \qquad MS_{pb} = 1.61 \text{ OK}$$

Weld on Stiffener Rings:

Evaluate circumferential fillet welds joining the stiffening rings and end plates to the inner containment pipe. Assume welds are 1/2 inch fillets both sides.

Weld size: $w_{srw} = 0.500$ in .

Diameter of weld is OD of pipe: $od_{pipe} = 64$ in

Largest moment on outer top end plate, model as pipe welded to stiffening ring with no support from outer shell or top cap flange.

Evaluate weld per AWS, Reference 11, page 7.4-7.




Figure 8

ENGINEERING ANALYSIS

Drawing H-2-83734 Doc. No. 101-SY-DROP-03 Page 31 of 31
 Building Tank 241-SY-101 Rev. 0 Job No. _____
 Subject Drop Evaluation Loaded and Partially Shielded (101-SY)
 Originator S. S. Shiraga Date 08/01/94
 Checker S. R. Crow *SR* Date 08/31/94

Treat the welds as a line in bending:

$$S_{weld} = \pi \frac{od_{pipe}^2}{4}$$

Linear Force on welds, assuming welds equally share the load:

$$f_b = \left| \frac{M_y}{2 S_{weld}} \right|$$

$$f_b = 160 \text{ lbs/in}$$

AWS allowable for fillet welds used in Bridge Construction for ASTM A-36 material with thickness greater than 1 inch using E60 or SAW-1 Electrodes and assuming parallel loading, Reference 10 and Reference 11, page 7.4-8.

$$s_{aws} = 8,800 \text{ psi}$$

Allowable line load:

$$f_{aws} = s_{aws} (0.707 w_{srw})$$

$$f_{aws} = 3,111 \text{ lbs/in}$$

Margin of Safety:

$$MS_{srw} = (f_{aws}/f_b) - 1$$

$$MS_{srw} = 18.44 \quad \text{OK}$$

6.5 TIEDOWN ANALYSIS

DON'T SAY IT --- Write It!

DATE: 7/25/94

TO: Richard F. Carlstrom G2-02FROM: Harold E. Adkins, Jr. G2-03Telephone: 376-9703

cc: J. W. Thornton G2-03
S. R. Crow G2-03
M. J. Ostrom H5-68
T. C. Mackey S2-03
C. E. Brewer S3-15

SUBJECT: 101-SY TRANSPORT PACKAGING TIEDOWN ANALYSIS

The 101-SY tiedown analysis has been completed based on a tiedown configuration which is shown in figure 1. All analysis was based on a fully lead shielded 101-SY package containing a 19,427 lb payload (approximate total weight = 138,800 lbs).

The results of the analysis indicate that the cables for this tiedown configuration must have a minimum load capability of 15,430 lbs for each of the sixteen (16) cable legs. These cable legs are approximately 81 inches in length. To remain consistent with the analysis performed on the rip-out capability of the container tiedown tabs, shackles with a pin diameter of 1-5/8 inches, must be used. It is suggested by the analyst to implement a double jaw end turnbuckle to minimize exposure time and to aid in pre-tensioning the tiedowns. These such devices must meet or exceed the working load limit of the cables they are being used with. It is important for interested parties to note that all of the tiedown components mentioned above are available through McMaster-Carr supply company and photocopies of these components are attached at the end of the analysis. Pre-tensioning procedures are left to the discretion of the rigging crew responsible.

An important note that should be brought to the readers attention is as follows. In light of the fact that the container stiffness exceeds that of the main transport trailer and the manner in which the container is being restrained (tie-downs), a low-cycle fatigue failure analysis of the main transport trailer is recommended.

The analysis, consisting of hand calculations, were checked by S. R. Crow and are attached.




FIGURE 1. TILT-TRAILER TIEDOWN CONFIGURATION.

DESIGN CALCULATIONS

(1) Drawing _____ (2) Doc. No. _____ (3) Page 1 of 16
 (4) Building General (5) Rev. Zero (6) Job No. N2B6D
 (7) Subject 101-SY TILT-TRAILER TIEDOWN ANALYSIS
 (8) Originator Harold E. Adkins, Jr. *HA* Date 7/25/94
 (9) Checker Stan R. Crow *SR* Date 7-25-94
 (10)

101-SY TILT-TRAILER TIEDOWN ANALYSIS**Phase I of bearing load analysis:**

- Determine bearing load capability of container strongback-attachment points

Assumptions:

- To meet the requirements of 10 CFR 71.45 (b)(1), only the rigid mount points that mate with the strongback are considered for calculating critical bearing stress. This will give a conservative approximation considering the fact that the container will also be tied down using cables that directly attach from container tiedown points to the trailer.

$W_c = 138800\text{-lbf}$ Maximum weight of fully shielded container (Shielded to column line 25 w/Lead on Drawing # H-2-83734) & (19,427 lbf payload - pump)

- Calculation of this value attached at the end of this analysis

$W_s = 30000\text{-lbf}$ Maximum weight of strongback

$S_y = 36000\text{-psi}$ Yield Strength of ASTM A-36 (From ASME Section VIII, Div 1)

$S_u = 58000\text{-psi}$ Ultimate Strength of ASTM A-36 (From ASME Section VIII, Div 1)

Critical Bearing Stress Of Strongback Mounting Points:

$F_{pcr} / F_y = l_e / d$ (C-J3-1 AISC - Steel Construction)

$l_e = 4.5\text{-in}$ Minimum distance from free edge (including ring thickness)

$d = 2.257\text{-in}$ Minimum accountable bolt diameter for a 2.5 inch diameter bolt (From "AN INTRODUCTION TO THE DESIGN AND BEHAVIOR OF BOLTED JOINTS" - John H. Bickford)

$F_y = S_y$ ASTM A-36 yield strength

$F_{pcr} = \frac{F_y \cdot l_e}{d}$ Critical bearing stress

$F_{pcr} = 7.178 \cdot 10^4 \text{ psi}$

$t_{lug} = 2.0\text{-in}$ Thickness of attachment lug

DESIGN CALCULATIONS

(1) Drawing _____ (2) Doc. No. _____ (3) Page 2 of 16
 (4) Building General (5) Rev. Zero (6) Job No. _____
 (7) Subject 101-SY TILT-TRAILER TIEDOWN ANALYSIS
 (8) Originator Harold E. Adkins, Jr. *HEA Jr.* Date 7/25/94
 (9) Checker Stan R. Crow *SR* Date 7-25-94
 (10)

$a_{lug} := t_{lug} \cdot d$ Projected stress area

$Load_{max} := F_{pcr} \cdot a_{lug}$ Maximum load capability

$Load_{max} = 3.24 \cdot 10^5 \cdot lbf$

- From 10 CFR 71.45 (b)(1), the attachment points on the container must be capable of withstanding w/o exceeding yield:

- 10 X weight Longitudinal
- 5 X weight Lateral
- 2 X weight Vertical

$G_{Long} := 10 \quad G_{Lat} = 5 \quad G_{Vert} = 2$

Longitudinal Loading Case:

$N_{Long} := 4$ Number of effective longitudinal load bearing points (Strongback mount points)

$Load_{Long} := \frac{G_{Long} \cdot W_c}{N_{Long}} \quad Load_{Long} = 3.47 \cdot 10^5 \cdot lbf$

$MS_{Long} := \left(\frac{Load_{max}}{Load_{Long}} - 1 \right)$

$MS_{Long} = -0.066$

Alternate Assumption: (More realistic)

- For the longitudinal load case, the load capability of the tiedown points on the container can be incorporated.
- The trailer and strongback are rigid fixtures.
- Aggregate load condition.

Critical Bearing Stress Of Tiedown Points:

DESIGN CALCULATIONS

- (1) Drawing _____ (2) Doc. No. _____ (3) Page 3 of 16
 (4) Building General (5) Rev. Zero (6) Job No. _____
 (7) Subject 101-SY TILT-TRAILER TIEDOWN ANALYSIS
 (8) Originator Harold E. Adkins, Jr. *HEA* Date 7/25/94
 (9) Checker Stan R. Crow *SR* Date 7-25-94
 (10)

$$F_{pcr} / F_y = l_e / d \quad (\text{C-J3-1 AISC - Steel Construction})$$

$$l_e := 2.156\text{-in} \quad \text{Minimum distance from free edge (including ring thickness)}$$

$$d := \left(1 + \frac{5}{8}\right) \cdot \text{in} \quad \text{Hardware diameter}$$

$$F_y := S_y \quad \text{ASTM A-36 yield strength}$$

$$F_{pcr} := \frac{F_y \cdot l_e}{d} \quad \text{Critical bearing stress}$$

$$F_{pcr} = 4.776 \cdot 10^4 \text{ psi}$$

$$t_{lug} = 1.5\text{-in} \quad \text{Thickness of attachment lug}$$

$$a_{lug} := t_{lug} \cdot d \quad \text{Projected stress area}$$

$$\text{Load}_{Max} := F_{pcr} \cdot a_{lug} \quad \text{Maximum load capability}$$

$$\text{Load}_{Max} = 1.164 \cdot 10^5 \text{ lbf}$$

$$M_{Long} := 8 \quad \text{Number of effective longitudinal load bearing points (Tiedown points)}$$

$$\text{Load}_{Long} := \frac{G_{Long} \cdot W_c}{N_{Long} + M_{Long}} \quad \text{Load}_{Long} = 1.157 \cdot 10^5 \text{ lbf}$$

$$MS_1 = \left(\frac{\text{Load}_{max}}{\text{Load}_{Long}} - 1 \right) \quad MS_1 = 1.801 \quad \text{(Strongback mount points)}$$

$$MS_2 = \left(\frac{\text{Load}_{Max}}{\text{Load}_{Long}} - 1 \right) \quad MS_2 = 0.007 \quad \text{(Tiedown points)}$$

* All of these points would behave in an aggregate fashion anyway.

DESIGN CALCULATIONS

(1) Drawing _____ (2) Doc. No. _____ (3) Page 4 of 16
 (4) Building General (5) Rev. Zero (6) Job No. _____
 (7) Subject 101-SY TILT-TRAILER TIEDOWN ANALYSIS
 (8) Originator Harold E. Adkins, Jr. *H. Adkins, Jr.* Date 7/25/94
 (9) Checker Stan R. Crow *SR* Date 7-25-94
 (10)

Vertical Loading Case:

$l_e := 4.094 \cdot \text{in}$ Minimum distance from free edge

$d := 2.0 \cdot \text{in}$ Hardware diameter

$F_y := 36000 \cdot \text{psi}$ ASTM A-36 yield strength

$F_{\text{pcr}} := \frac{F_y \cdot l_e}{d}$ Critical bearing stress

$F_{\text{pcr}} = 7.369 \cdot 10^4 \cdot \text{psi}$

$t_{\text{lug}} := 2.0 \cdot \text{in}$ Thickness of attachment lug

$a_{\text{lug}} = t_{\text{lug}} \cdot d$ Projected stress area

$\text{Load}_{\text{max}} := F_{\text{pcr}} \cdot a_{\text{lug}}$ Maximum load capability

$\text{Load}_{\text{max}} = 2.948 \cdot 10^5 \cdot \text{lb} \cdot \text{f}$

$N_{\text{Vert}} := 4$ Number of effective vertical load bearing points

$\text{Load}_{\text{Vert}} := \frac{G_{\text{Vert}} \cdot W_c}{N_{\text{Vert}}}$ $\text{Load}_{\text{Vert}} = 6.94 \cdot 10^4 \cdot \text{lb} \cdot \text{f}$

$\text{MS}_{\text{Vert}} = \left(\frac{\text{Load}_{\text{max}}}{\text{Load}_{\text{Vert}}} - 1 \right)$

$\text{MS}_{\text{Vert}} = 3.247$

Lateral Loading Case:

- For the lateral case, in light of the fact that the container is fixed in the strongback, only a shear load on the connecting welds of two of the attachment points will be considered. This load will be applied to the welds connecting the mounting plates to the stiffening rings

DESIGN CALCULATIONS

- (1) Drawing _____ (2) Doc. No. _____ (3) Page 5 of 16
 (4) Building General (5) Rev. Zero (6) Job No. _____
 (7) Subject 101-SY TILT-TRAILER TIEDOWN ANALYSIS
 (8) Originator Harold E. Adkins, Jr. *H.E. Adkins, Jr.* Date 7/25/94
 (9) Checker Stan R. Crow *S.R.C.* Date 7-25-94
 (10)

weld_{eff} := 0.3 Weld efficiency based on AWS D1.1 (Shear load)

$$\text{Area}_{\text{weld}} := (2) \cdot (2) \cdot \left[\left(11 + \frac{5}{8} \right) \cdot 1 \right] \cdot (\text{weld}_{\text{eff}}) \cdot \text{in}^2$$

$$\sigma_{\text{weld}} := \frac{G_{\text{Lat}} \cdot W_c}{\text{Area}_{\text{weld}}}$$

$$\sigma_{\text{weld}} = 4.975 \cdot 10^4 \text{ psi}$$

$$\text{MS}_{\text{Lat}} := \left(\frac{S_u}{\sigma_{\text{weld}}} - 1 \right)$$

$$\text{MS}_{\text{Lat}} = 0.166$$

Stiffening Ring Weld Strength:

- Determine stress in stiffening ring welds.

The stiffening rings were welded to the 64" diameter pipe using a 5/16" weld on both sides of the ring as per AWS D1.1. The allowable load on the fillet welds shall be equal to the product of the weld area (based on minimum leg dimension) the allowable stress value in shear of the material being welded and a joint efficiency of 30 % of ultimate.

- Taking only the attachment point stiffening ring welds into account.

N_{weld} := 2 Number of welds per stiffening ring

$$\text{weld}_{\text{leg}} := \frac{5}{16} \text{ in}$$

$$\text{pipe}_{\text{diam}} := 64.0 \text{ in}$$

$$\text{Ring}_{\text{weld}} = N_{\text{weld}} \left[\frac{\pi}{4} \left[\left(\text{pipe}_{\text{diam}} + 2 \cdot (\text{weld}_{\text{leg}}) \right)^2 - \text{pipe}_{\text{diam}}^2 \right] \right] \text{ Stiffening ring weld}$$

DESIGN CALCULATIONS

- (1) Drawing _____ (2) Doc. No. _____ (3) Page 6 of 16
- (4) Building General (5) Rev. Zero (6) Job No _____
- (7) Subject 101-SY TILT-TRAILER TIEDOWN ANALYSIS
- (8) Originator Harold E. Adkins, Jr. *H. Adkins, Jr.* Date 7/25/94
- (9) Checker Stan R. Crow *SRC* Date 7-25-94
- (10)

$$End_{weld} := \left[\frac{\pi}{4} \cdot \left[\left(pipe\ diam + 2 \cdot (weld\ leg) \right)^2 - pipe\ diam^2 \right] \right] \quad \text{End-cap weld}$$

$$weld_{eff} = 0.3$$

$$Area_{Weld} := (weld_{eff}) \cdot \left[(3) \cdot Ring_{weld} + End_{weld} \right]$$

$$\sigma_{weld\ long} := \frac{G_{Long} \cdot W_c}{Area_{Weld}} \quad MS_{Long} = \left(\frac{S_u}{\sigma_{weld\ long}} - 1 \right) \quad MS_{Long} = 4.541$$

$$\sigma_{weld\ lat} = \frac{G_{Lat} \cdot W_c}{Area_{Weld}} \quad MS_{Lat} = \left(\frac{S_u}{\sigma_{weld\ lat}} - 1 \right) \quad MS_{Lat} = 10.081$$

$$\sigma_{weld\ vert} = \frac{G_{Vert} \cdot W_c}{Area_{Weld}} \quad MS_{Vert} = \left(\frac{S_u}{\sigma_{weld\ vert}} - 1 \right) \quad MS_{Vert} = 26.703$$

The purpose for these above calculations is to show that the strongback attachments are able to carry portions of the tiedown load if needed.

Phase II of bearing load analysis:

- Determine bearing load capability of stiffening ring tiedown tabs

Assumptions:

- To meet the requirements of 10 CFR 71.45 (b)(1), only points at which the cables attach to the container will be analyzed using moment combinations taking in to account the weight of the strongback at its CG wise location. The pivot point will be the pivot-pins on the
- Four attachment points per side will be used [Eight cables per side in a "V" configuration as shown in figure 1 (TILT-TRAILER TIEDOWN CONFIGURATION) presented before this analysis]
- The container is fully shielded to column line 25 in reference to drawing number H-2-83734
- The container behaves as a rigid body.
- From 10 CFR 71.45 (b)(1), the attachment points on the container must be capable of withstanding w/o exceeding yield:

DESIGN CALCULATIONS

(1) Drawing _____ (2) Doc. No. _____ (3) Page 7 of 16
 (4) Building General (5) Rev. Zero (6) Job No. _____
 (7) Subject 101-SY TILT-TRAILER TIEDOWN ANALYSIS
 (8) Originator Harold E. Adkins, Jr. *HEA Jr.* Date 7/25/94
 (9) Checker Stan R. Crow *SRC* Date 7-25-94
 (10)

- 10 X weight Longitudinal
- 5 X weight Lateral
- 2 X weight Vertical

$$G_{Long} := 10 \quad G_{Lat} := 5 \quad G_{Vert} := 2$$

Longitudinal Loading Case:

This load case was analyzed and it was determined that the attachment points were adequate. The load case results are presented in Phase I above.

Vertical Loading Case:

Using the free-body diagram on the next page (Section A) and implementing a summation of moments and forces, the maximum subjected force to the tiedown lugs is determined to be,

$$Vertload_{max} = 34816 \cdot lbf$$

$$Load_{Max} = 1.164 \cdot 10^5 \cdot lbf \quad \text{Critical bearing load capability of tiedown points from above}$$

$$MS_{vert} := \left(\frac{Load_{Max}}{Vertload_{max}} - 1 \right)$$

$$MS_{vert} = 2.344$$

Lateral Loading Case:

This loading case will be ignored due to two facts. The strongback connections provided on the container alone were found to be adequate in reference to withstanding the total subjected load. These results are shown in phase I of this analysis. Also, a lateral restraint/support device will be provided on the trailer coming in contact with the container at column line 24. This is shown in figure 1 (TILT-TRAILER TIEDOWN CONFIGURATION) presented before this analysis. However, the stiffening ring welds needs to be check for the possibility of failure. This verification follows.

Using a summation of moments around the strongback pivot-pin,

$$Moment_{sum} = 0 = G_{Lat} * (Length_{CGcont} * W_c + Length_{CGstrongback} * W_s) - Length_{latload} * Force_{Lat}$$


..** Continue to page 9 **

DESIGN CALCULATION

- (1) Drawing _____ (2) Doc. No. _____ (3) Page 8 of 16
 (4) Building General (5) Rev. Zero (6) Job No. N2B6D
 (7) Subject 101-SY Tilt-Trailer Tiedown Analysis
 (8) Originator Harold E. Adams, Jr. Date 7-21-94
 (9) Checker JRCrow Date 7-25-94

(10)

Section A - Vertical Rip-out - 2G Loading



$$\sum F = 0 = 2(30,000 + 138,800) - [PF_0 + CF_1 + CF_2 + CF_3 + CF_4]$$

$$\sum M_0 = 0 = 2[(30,000)(15) + (138,800)(26.92)] - [(CF_1)(30.06) + (CF_2)(35.31) + (CF_3)(40.56) + (CF_4)(45.81)]$$

Where,

$$CF_2 = \left(\frac{30.06}{35.31}\right) CF_1, \quad CF_3 = \left(\frac{30.06}{40.56}\right) CF_1$$

$$\& CF_4 = \left(\frac{30.06}{45.81}\right) CF_1 \quad PF_0 = 111,395 \text{ lbf}$$

$$CF_1 = 69,631 \text{ lbf}$$

$$CF_2 = 59,278 \text{ lbf}$$

$$CF_3 = 51,605 \text{ lbf}$$

$$CF_4 = 45,691 \text{ lbf}$$

- But, we have 2 attachment points on the container at CF_1 locations.

$$\text{Vert load max} = \left(\frac{69,631}{2}\right) \text{ lbf @ } CF_1$$

$$\text{Vert load max} = \underline{\underline{34,816 \text{ lbf}}}$$

DESIGN CALCULATIONS

- (1) Drawing _____ (2) Doc. No. _____ (3) Page 9 of 16
 (4) Building General (5) Rev. Zero (6) Job No. _____
 (7) Subject 101-SY TILT-TRAILER TIEDOWN ANALYSIS
 (8) Originator Harold E. Adkins, Jr. H. E. Adkins, Jr. Date 7/25/94
 (9) Checker Stan R. Crow SRC Date 7-25-94
 (10)

where

$G_{Lat} = 5$ Lateral G-load value based on 10 CFR 71.45(b)(1)

$W_c = 1.388 \cdot 10^5 \cdot \text{lb}$ Total container weight

$W_s = 3 \cdot 10^4 \cdot \text{lb}$ Strongback weight

Length_{CGcont} = 26.918-ft Distance from pivot-pin to container CG

Length_{CGstrongback} = 15.0-ft Distance from pivot-pin to strongback CG

Length_{latload} = 51.23-ft Distance from pivot-pin to column line 24 (where lateral load restraint/support device comes in contact with container stiffening ring)

$$\text{Force}_{Lat} := \frac{G_{Lat} \cdot (\text{Length}_{CGcont} \cdot W_c + \text{Length}_{CGstrongback} \cdot W_s)}{\text{Length}_{latload}}$$

$$\text{Force}_{Lat} = 4.086 \cdot 10^5 \cdot \text{lb}$$

The stiffening rings were welded to the 64" diameter pipe using a 5/16" weld on both sides of the ring as per AWS D1.1. The allowable load on the fillet welds shall be equal to the product of the weld area (based on minimum leg dimension) the allowable stress value in shear of the material being welded and a joint efficiency of 30 % of ultimate.

- Taking only the attachment point stiffening ring welds into account,

$N_{weld} = 2$ Number of welds per stiffening ring

weld_{leg} = 0.313-in

pipe_{diam} = 64-in

DESIGN CALCULATIONS

- (1) Drawing _____ (2) Doc. No. _____ (3) Page 10 of 16
 (4) Building General (5) Rev. Zero (6) Job No _____
 (7) Subject 101-SY TILT-TRAILER TIEDOWN ANALYSIS
 (8) Originator Harold E. Adkins, Jr. HEA Jr. Date 7/25/94
 (9) Checker Stan R. Crow SRCrow Date 7-25-94
 (10)

$$\text{Ring weld} := N_{\text{weld}} \left[\frac{\pi}{4} \left[\left(\text{pipe diam} + 2 \cdot (\text{weld leg}) \right)^2 - \text{pipe diam}^2 \right] \right] \text{ Area of stiffening ring welds}$$

$$\text{weld}_{\text{eff}} = 0.3$$

$$\text{Area Weld} := (\text{weld}_{\text{eff}}) \cdot \text{Ring weld}$$

$$\sigma_{\text{weld}} := \frac{\text{Force Lat}}{\text{Area Weld}}$$

$$\sigma_{\text{weld}} = 1.079 \cdot 10^4 \text{ psi}$$

$$\text{MS Weld} = \left(\frac{S_u}{\sigma_{\text{weld}}} - 1 \right)$$

$$\text{MS Weld} = 4.378$$

Cable Analysis:

- Determine the minimum load carrying capability that the cables must display

Assumptions:

- The container, trailer and strongback behave as rigid bodies.
- The pivot point will be the pivot-pins on the strongback.
- The elevational difference between the pins and the CG of the container is of no significance.
- The tiedown system must be capable of retaining the payload when subjected to a 1.5 G acceleration in the lateral, longitudinal, or vertical direction.

Longitudinal Loading Case:

- If we assume a yield strength of 108,000 psi for the AISI 4340 3 inch diameter steel strongback pivot-pins (which is highly conservative), the maximum load carrying capability (in shear) of the two pin is,

DESIGN CALCULATIONS

- (1) Drawing _____ (2) Doc. No. _____ (3) Page 11 of 16
 (4) Building General (5) Rev. Zero (6) Job No. _____
 (7) Subject 101-SY TILT-TRAILER TIEDOWN ANALYSIS
 (8) Originator Harold E. Adkins, Jr. *HEA Jr.* Date 7/25/94
 (9) Checker Stan R. Crow *SRC* Date 7-25-94
 (10)

Acc := 1.5 Subjected G-load
 N_{shear} := 4 Number of shear planes
 Diam_{pin} := 3-in Pivot-pin Diameter
 $Area_{pin} := \frac{\pi \cdot Diam_{pin}^2}{4}$ X-sectional area of pin
 Sy_{pin} := 108000-psi Yield Strength of pin
 $\tau_{pin} = \frac{Sy_{pin}}{2}$ Shear capability of pin
 LOAD_{max} = N_{shear} · τ_{pin} · Area_{pin}
 LOAD_{max} = 1.527 · 10⁶ · lbf

- If the pivot-pins are relied upon to restrain the load of the container and strongback, and considered as the tiedown system in the longitudinal loading direction,

W_c = 1.388 · 10⁵ · lbf Total container weight
 W_s = 3 · 10⁴ · lbf Strongback weight
 LOAD_{lat} = Acc · (W_c + W_s)
 $MS_{pin} = \left(\frac{LOAD_{max}}{LOAD_{lat}} - 1 \right)$
 MS_{pin} = 5.03

- Now to check the strength of the strongback/container interface bolts to assure restraint capability.

N_{Shear} := 4 Number of shear planes

DESIGN CALCULATIONS

- (1) Drawing _____ (2) Doc. No. _____ (3) Page 12 of 16
 (4) Building General (5) Rev. Zero (6) Job No. _____
 (7) Subject 101-SY TILT-TRAILER TIEDOWN ANALYSIS
 (8) Originator Harold E. Adkins, Jr. *H.E.A. Jr.* Date 7/25/94
 (9) Checker Stan R. Crow *src* Date 7-25-94
 (10)

Diam_{bolt} := 2.257-in Minimum accountable bolt diameter for a 2.5 inch diameter bolt
 (From "AN INTRODUCTION TO THE DESIGN AND BEHAVIOR OF BOLTED JOINTS" - John H. Bickford)

Area_{bolt} := $\frac{\pi}{4} \cdot \text{Diam}_{\text{bolt}}^2$ X-sectional area of each bolt

Sy_{bolt} := 58000-psi Yield Strength of bolts - ASTM A-449, Type 1
 (From ASME Section VIII, Div. 1)

$\tau_{\text{bolt}} := \frac{S_y_{\text{bolt}}}{2}$ Shear capability of each bolt

LOAD_{Max} = N_{Shear} τ_{bolt} Area_{bolt}

LOAD_{Max} = 4.641 · 10³ · lbf

LOAD_{Lat} := Acc · (W_c + W_s)

MS_{bolt} = $\left(\frac{\text{LOAD}_{\text{Max}}}{\text{LOAD}_{\text{Lat}}} - 1 \right)$

MS_{bolt} = 0.833 Obviously, the pivot-pins will restrain the load

Lateral Loading Case:

The transport trailer to be used is again shown in figure 1. It has been equipped with a lateral restraint/support device which is shown supporting the container at the tractor-end of the trailer. It was specified that the trailer manufacturer must design and build this device to withstand a 150,000 lb force acting laterally. This device in conjunction with the pivot-pin platform, was meant to provide container restraint in the lateral direction.

- Keeping in mind that the pivot-pin platform must withstand a load subjected to it by a wind-loaded, unshielded 72,927 lb container (including payload), the platform structure is assumed to be adequate for providing its portion of lateral restraint.

- Now, to check if the lateral restraint/support device can withstand the subjected loads.

Using a summation of moments around the strongback pivot-pin,

DESIGN CALCULATIONS

- (1) Drawing _____ (2) Doc. No. _____ (3) Page 13 of 16
 (4) Building General (5) Rev. Zero (6) Job No _____
 (7) Subject 101-SY TILT-TRAILER TIEDOWN ANALYSIS
 (8) Originator Harold E. Adkins, Jr. Date 7/25/94
 (9) Checker Stan R. Crow Date 7-25-94
 (10)

$$\text{Moment}_{\text{sum}} = 0 = G_{\text{Lat}} * (\text{Length}_{\text{CGcont}} * W_c + \text{Length}_{\text{CGstrongback}} * W_s) - \text{Length}_{\text{latload}} * \text{Load}_{\text{subjected}}$$

where

$\text{Load}_{\text{capability}} := 150000 \cdot \text{lb} \cdot \text{f}$ Load capability of lateral restraint/support device

$G_{\text{Lat}} := 1.5$ Lateral G-load value

$W_c = 1.388 \cdot 10^5 \cdot \text{lb} \cdot \text{f}$ Total container weight

$W_s = 3 \cdot 10^4 \cdot \text{lb} \cdot \text{f}$ Strongback weight

$\text{Length}_{\text{CGcont}} = 26.918 \cdot \text{ft}$ Distance from pivot-pin to container CG

$\text{Length}_{\text{CGstrongback}} = 15.0 \cdot \text{ft}$ Distance from pivot-pin to strongback CG

$\text{Length}_{\text{latload}} = 51.23 \cdot \text{ft}$ Distance from pivot-pin to column line 24 (where lateral load restraint/support device comes in contact with container stiffening ring)

$$\text{Load}_{\text{subjected}} := \frac{G_{\text{Lat}} * (\text{Length}_{\text{CGcont}} * W_c + \text{Length}_{\text{CGstrongback}} * W_s)}{\text{Length}_{\text{latload}}}$$

$$\text{Load}_{\text{subjected}} = 1.226 \cdot 10^5 \cdot \text{lb} \cdot \text{f}$$

$$\text{MS}_{\text{restraint}} = \left(\frac{\text{Load}_{\text{capability}}}{\text{Load}_{\text{subjected}}} - 1 \right)$$

$$\text{MS}_{\text{restraint}} = 0.224$$


Vertical Loading Case:

Using a free-body diagram and implementing a summation of moments and forces, the maximum subjected load at a cable connection can be determined. Taking all cable angles in to consideration, this value can then be used to determine the maximum cable load. These calculations follow. (Section B)

DESIGN CALCULATION

- (1) Drawing _____ (2) Doc. No. _____ (3) Page 14 of 16
 (4) Building General (5) Rev. Zero (6) Job No. _____
 (7) Subject 101-SY Tilt-Trailer Tiedown Analysis
 (8) Originator Harold E. Adkins, Jr. AdP, Date Feb. 7-21-94
 (9) Checker J.R. Crow Date 7-25-94

(10) Section B - Vertical Cable Connection Load
 - 1.5 G loading



$$\sum F = 0 = 1.5(30,000 + 138,800) - [PF_0 + CF_1 + CF_2 + CF_3 + CF_4]$$

$$\sum M = 0 = 1.5 [(30,000)(15) + (138,800)(26.92)] - [(CF_1)(30.06) + (CF_2)(35.31) + (CF_3)(40.56) + (CF_4)(45.81)]$$

Where,

$$CF_2 = \left(\frac{30.06}{35.31}\right) CF_1, \quad CF_3 = \left(\frac{30.06}{40.56}\right) CF_1$$

$$+ CF_4 = \left(\frac{30.06}{45.81}\right) CF_1$$

$$\begin{cases} CF_1 = 52,223 \text{ lbf} & PF_0 = 83,546 \text{ lbf} \\ CF_2 = 44,459 \text{ lbf} \\ CF_3 = 38,704 \text{ lbf} \\ CF_4 = 34,268 \text{ lbf} \end{cases}$$

- But, we have 2 attachment points on the container at CF_1 locations and 2 cables connecting to these attachment points.

$$\text{Vert load}_{max} = \left(\frac{52,223}{(2)(2)}\right) \text{ lbf @ } CF_1$$

$$\text{Vert load}_{max} = \underline{13,056 \text{ lbf}} \text{ load acting vertically on cables @ } CF_1.$$


DESIGN CALCULATION

(1) Drawing _____ (2) Doc. No. _____ (3) Page 15 of 16
 (4) Building General (5) Rev. Zero (6) Job No. _____
 (7) Subject 101-5Y Tilt-Trailer Tiedown Analysis
 (8) Originator Harold E. Atkins, Jr. M.D. Dr. Date: 7-21-94
 (9) Checker AR Crow Date 7-25-94



(10)

Section B (Continued)

Cable Configuration



Rear View →



$Vertload_{max} = 13,056 \text{ lbf}$ (from above)

DESIGN CALCULATIONS

- (1) Drawing _____ (2) Dbc. No. _____ (3) Page 16 of 16
 (4) Building General (5) Rev. Zero (6) Job No. _____
 (7) Subject 101-SY TILT-TRAILER TIEDOWN ANALYSIS
 (8) Originator Harold E. Adkins, Jr. *H.E. Adkins, Jr.* Date 7/25/94
 (9) Checker Stan R. Crow *SRC* Date 7-25-94
 (10)

From Section B it is shown that,

$$\text{adj}_1 := 67.73 \cdot \text{in}$$

$$\text{Vertload}_{\max} := 13056 \cdot \text{lbf}$$

$$\theta_1 := 23 \cdot \text{deg}$$

$$\theta_2 := 23.18 \cdot \text{deg}$$

$$\text{Cable}_{\text{leg}} := \frac{\text{adj}_1}{(\cos(\theta_1)) \cdot (\cos(\theta_2))}$$

each cable leg length is

$$\text{Cable}_{\text{leg}} = 80.041 \cdot \text{in} \quad \checkmark$$

and the maximum subjected cable load, that each particular cable leg must withstand, is

$$\text{MaxLoad}_{\text{cable}} := \frac{\text{Vertload}_{\max}}{(\cos(\theta_1)) \cdot (\cos(\theta_2))}$$

$$\text{MaxLoad}_{\text{cable}} = 1.543 \cdot 10^4 \cdot \text{lbf} \quad \checkmark$$

All cable material and cabling apparatus must be chosen to meet or exceed this value.

101-SY CG Calculations for various shielding conditions

Analysis by: Tim Saffell

Date: July 18, 1994

Weight of Container(no shielding, no pump)

$$w_{\text{cont}} := 53500 \cdot \text{lb} \cdot \text{f} \quad (\text{Weight plus } 800 \text{ lb} \cdot \text{f} \text{ for the additional saddle plate support})$$

$$\text{CG}_{\text{noshield}} := 311.54 \cdot \text{in} \quad (\text{of container wo/pump from Ansys})$$

$$w_{\text{pump}} := 19427 \cdot \text{lb} \cdot \text{f}$$

$$w_{\text{pay}} := w_{\text{cont}} + w_{\text{pump}}$$

$$w_{\text{pay}} = 7.293 \cdot 10^4 \cdot \text{lb} \cdot \text{f} \quad (\text{no shielding})$$

Annulus Area for Shielding

$$A_{\text{ann}} := \frac{\pi}{4} \cdot (68^2 - 64^2) \cdot \text{in}^2 \qquad A_{\text{ann}} = 2.88 \cdot \text{ft}^2$$

Lengths for shielding

$$l_{14} := 27 \cdot \text{ft} + 5.25 \cdot \text{in} - 12 \cdot 1.5 \cdot \text{in} - 1.75 \cdot \text{in} \qquad l_{14} = 25.792 \cdot \text{ft}$$

$$l_{\text{full}} := 52 \cdot \text{ft} + .75 \cdot \text{in} - 23 \cdot 1.5 \cdot \text{in} - 1.75 \cdot \text{in} \qquad l_{\text{full}} = 49.042 \cdot \text{ft}$$

Mass of shielding(lead shielding, density=0.270 lbf/in^3)

$$\rho = 0.27 \frac{\text{lb} \cdot \text{f}}{\text{in}^3}$$

$$W_{14} = l_{14} \cdot A_{\text{ann}} \cdot \rho \qquad W_{14} = 3.465 \cdot 10^4 \cdot \text{lb} \cdot \text{f}$$

$$W_{\text{full}} = l_{\text{full}} \cdot A_{\text{ann}} \cdot \rho \qquad W_{\text{full}} = 6.589 \cdot 10^4 \cdot \text{lb} \cdot \text{f}$$

Moments

$$M_{\text{tot}14} = w_{\text{cont}} \cdot \text{CG}_{\text{noshield}} + W_{14} \cdot \frac{l_{14} + 12 \cdot 1.5 \cdot \text{in} + 1.75 \cdot \text{in}}{2} + w_{\text{pump}} \cdot 390.75 \cdot \text{in}$$

$$M_{\text{totfull}} = w_{\text{cont}} \cdot \text{CG}_{\text{noshield}} + W_{\text{full}} \cdot \frac{l_{\text{full}} + 23 \cdot 1.5 \cdot \text{in} + 1.75 \cdot \text{in}}{2} + w_{\text{pump}} \cdot 390.75 \cdot \text{in}$$

Total Weight

$$w_{14} := w_{\text{cont}} + W_{14} + w_{\text{pump}} \qquad w_{14} = 1.076 \cdot 10^5 \cdot \text{lb} \cdot \text{f}$$

$$w_{\text{full}} = w_{\text{cont}} + W_{\text{full}} + w_{\text{pump}} \qquad w_{\text{full}} = 1.388 \cdot 10^5 \cdot \text{lb} \cdot \text{f}$$

CGs

$$\text{CG}_{14} = \frac{M_{\text{tot}14}}{w_{14}} \qquad \text{CG}_{14} = 23.21 \cdot \text{ft}$$

$$\text{CG}_{\text{full}} = \frac{M_{\text{totfull}}}{w_{\text{full}}} \qquad \text{CG}_{\text{full}} = 26.918 \cdot \text{ft}$$

596

Hoisting Wire Rope

Wire Rope Selection Guide

We offer wire rope in a wide range of sizes, constructions, and materials. The information provided with each rope classifies construction and material for abrasion resistance and flexibility. Rating for each characteristic and application is relative to all the items listed.

Choose from three core styles: (1) Fiber core—a flexible sisal, cotton, manila, jute or polypropylene rope; (2) Strand core—an arrangement of wires helically laid around an axis which comprises a rigid center; (3) IWRC—an Independent Wire Rope Core that is ideal for high strength and crush resistance.

Wire rope construction refers to the number of wires used in the rope fabrication and where those wires are placed.

The first number indicates the quantity of strands, and the second specifies the approximate number of individual wires in each strand.

Lastly, the style of core is indicated. Example: 6 x 19 IWRC wire rope is comprised of six strands with approximately 19 wires in each strand wrapped around an Independent Wire Rope Core.

Unless otherwise indicated, wire rope is lubricated and laid to the right (right lay).

Hoisting Wire Rope


Hoisting wire rope is available in the following materials: Improved Plow Steel (IPS) with fiber core, Improved Plow Steel with IWRC (Independent Wire Rope Core) and Extra Improved Plow

Steel (XIPS) with IWRC Extra Improved Plow Steel (XIPS) is approximately 15% stronger than standard IPS of same size and construction.

Stan-Flex and Hi-Flex Preformed Hoisting Rope

STAN-FLEX 6 x 19 FIBER CORE OR IWRC—Rope has moderate flexibility and high strength. Breaking strength conforms to latest revision of applicable Federal Specification RR-W-410.

HI-FLEX 6 x 37 FIBER CORE OR IWRC—Rope is fatigue-resistant with superior bending ability. Use where crushing on a drum is not a factor. Breaking strength conforms to latest revision of applicable Federal Specification RR-W-410.



6 x 19 Fiber Core



6 x 19 IWRC



8 x 37 Fiber Core



6 x 37 IWRC

Dia.	Breaking Strength Lbs.	Stan-Flex 6 x 19 Hoisting Rope NET/FOOT			Hi-Flex 6 x 37 Hoisting Rope NET/FOOT				
		No.	1-49	50-99	100-Up	No.	1-49	50-99	100-Up
IMPROVED PLOW STEEL—FIBER CORE									
1/4"	3,100	3440T15	\$0.43	\$0.37	\$0.34	3441T15	\$0.98	\$0.84	\$0.77
5/16"	5,480	3440T16	.71	.64	.58	3441T16	1.02	.92	.84
3/8"	8,520	3440T17	.81	.72	.64	3441T17	1.20	1.06	.97
7/16"	12,200	3440T18	.91	.82	.74	3441T18	1.33	1.18	1.08
1/2"	16,540	3440T19	1.14	.98	.85	3441T19	1.54	1.33	1.21
5/8"	21,400	3440T21	1.17	1.06	.95	3441T21	1.54	1.33	1.21
3/4"	27,000	3440T22	1.32	1.13	1.02	3441T22	2.03	1.82	1.53
7/8"	33,400	3440T23	1.60	1.44	1.21				
IMPROVED PLOW STEEL—IWRC									
1/4"	3,340	3440T35	.50	.44	.40	3441T35	1.04	.94	.84
5/16"	5,880	3440T36	.82	.73	.66	3441T36	1.14	1.01	.92
3/8"	9,100	3440T37	.91	.83	.75	3441T37	1.31	1.17	1.04
7/16"	13,120	3440T38	1.04	.95	.87	3441T38	1.46	1.29	1.18
1/2"	17,780	3440T39	1.27	1.14	1.05	3441T39	1.69	1.50	1.38
5/8"	23,000	3440T41	1.26	1.15	1.06	3441T41	1.69	1.50	1.38
3/4"	29,000	3440T42	1.49	1.36	1.26	3441T42	2.22	1.95	1.74
7/8"	35,800	3440T43	1.71	1.57	1.45	3441T43			
EXTRA IMPROVED PLOW STEEL—IWRC									
1/4"	8,800	3440T56	.92	.82	.74	3441T56	1.08	.97	.87
5/16"	10,540	3440T57	1.10	.96	.86	3441T57	1.17	1.09	1.00
3/8"	15,100	3440T58	1.15	.93	.86	3441T58	1.32	1.21	1.11
7/16"	20,400	3440T59	1.27	1.13	1.02	3441T59	1.51	1.38	1.27
1/2"	26,600	3440T61	1.64	1.29	1.20	3441T61	1.69	1.54	1.42
5/8"	33,600	3440T62	1.71	1.32	1.28	3441T62	2.07	1.89	1.75
3/4"	41,200	3440T63	1.95	1.51	1.44	3441T63			



8 x 19 Fiber Core

- Abrasion Resistance—Low
- Flexibility—Very Good

8 x 19 FIBER CORE—IMPROVED PLOW STEEL—This is the preferred construction where maximum flexibility is required. It is ideal for comparatively small sheaves and drums. This highly flexible rope is commonly used on shop cranes and bridge cranes which have grooved drums and multiple part reeving.

Extra-flex rope should not be used where it will be subjected to heavy crushing or overwinding upon itself.

Extra-Flex Hoisting Rope

Breaking strength conforms to the latest revision of applicable Federal Specification RR-W-410.

Dia.	Breaking Strength Lbs.	No.	NET/FOOT		
			1-49	50-99	100-Up
1/4"	4,700	3442T33	\$0.83	\$0.76	\$0.64
5/16"	7,300	3442T34	1.10	1.00	.85
3/8"	10,340	3442T35	1.15	1.05	.88
7/16"	18,600	3442T37	1.53	1.39	1.17
1/2"	25,000	3442T39	1.88	1.71	1.44



6 x 26 IWRC

- Abrasion Resistance—Excellent
- Flexibility—Very Good

6 x 19 IWRC FOR 1/4" AND 5/16" DIA., 6 x 26 IWRC FOR 3/8" DIA.—EXTRA IMPROVED PLOW STEEL—High density rope has excellent crush resistance for long service life, especially in applications which have multiple layers on the drum. Special construction enhances flexibility, eases installation and increases durability.

This rope is excellent for applications where increased

Long Wear Hi-Density Wire Rope

strength and long service life are desired such as boom hoisting and winches.

Dia.	Breaking Strength Lbs.	No.	NET/FOOT		
			1-49	50-99	100-Up
1/4"	17,500	3321T11	\$1.34	\$1.65	\$1.51
5/16"	23,800	3321T12	2.24	2.06	1.87
3/8"	30,600	3321T13	2.52	2.31	2.03

All descriptions of wire rope applications listed above are general and are provided to help you choose the proper wire rope for your individual needs. To select wire rope correctly, be sure to use sound engineering practices.

McMASTER-CARR

These ropes are minimal rotation is a resistant properties to counterclockwise to clockwise twist. The ing torques which m NOTE: For the 8 x lion may occur if the this, these ropes sh of 1/2 of breaking st 8 x 19 IWRC—EXTR are preformed. Use l drums and sheaves. cranes with extend cranes.

Breaking strength applicable Federal S 19 x 7 STRAND C Wires are preforme mines where a free l and as lines for s strength conforms ic cation RR-W-410. 18 x 18 HIGH-STRE has superior rotatio strength than conven steel wire rope. Hig distance to crushin single-part hoist line sheave and drum we

Pressure bonded craft wire features on in each strand which the other wires. This around wires to shov (locking) bond betwe fiber and outer steel

NOTE: Since they specified for broken rated wire ropes, mended where failur injury or property da

Non

Nonsparking, nonr volatile atmospher water plus atmosper 6 x 7 FIBER COR • Abrasion Resistan • Flexibility—Good

Dia.	Breaking Strength Lbs.
1/4"	40
5/16"	55
3/8"	150
7/16"	340
1/2"	600
5/8"	2,230

6 x 19 FIBER CO

• Abrasion Resistan • Flexibility—Very Go

Dia.	Breaking Strength Lbs.
1/4"	815
5/16"	1,370
3/8"	2,380
7/16"	5,240
1/2"	9,210

- Abrasion Resistan
- Flexibility—Very Gu

7 STRAND IWRC—c This wire rope combin fatigue resistance of 8 x 19 rope. It is ideal withstand heavy crush

All descriptions of y individual needs. T

624

Anchor & Twisted Shackles

Shackle Information

Shackles are excellent for attaching and suspending rope and chain rigging lines. Only shackle pins that fit properly should be used. Substitutes are not intended to withstand the bending that is normally applied to the pin.

Shackles should never be pulled at an angle—this greatly reduces the capacity. Instead, littings and hoist lines should be centered on the pin with suitable washers or spacers.

Choose from three shackle styles:

ANCHOR—Open throat design allows free line movement without undue wear. Wide bow allows ample clearance for thumbs and turnbuckles.

CHAIN—Also known as D-Style. Flat-throat design restricts

movement of rigging chain lines. This reduces chain wear and prevents kinking and fouling.

TWISTED—Spiral design accommodates two-plane movement. Shackles come with one of three pin styles:

SCREW PINS—Shackles with captive screw pins need no special tools to assemble. Slip a screwdriver blade or hand punch through pin eye and tighten. **CAUTION:** Screw pin shackles should not be used where load shifting might unscrew the shackle pin.

BOLT PINS—Also known as safety shackles. Bolt pins with threaded ends accommodate nuts as well as locking cotter pins.

LOOSE PINS—Unthreaded pins are locked with cotter pins except Type 305 stainless steel.



Chain Shackle with Screw Pin




Anchor Shackle with Screw Pin



Anchor Shackle with Bolt Pin



Anchor Shackle with Loose Pin



Twisted Shackle with Screw Pin

GALVANIZED ALLOY STEEL—Great for marine and heavy-lift construction operations. Bodies and pins are forged, high-strength alloy steel with a galvanized finish. Shackles meet physical requirements of MIL-S-24214 (SHIPS), Type I, Class 2 or Class 3, Grade A or B.

GALVANIZED STEEL—Heat-treated, tempered, forged steel shackles have a galvanized finish and alloy steel pins. They meet the

requirements of federal specifications RR-C-271b, MIL-S-24214 Grade A, and ASTM A153.

STAINLESS STEEL—Excellent for chemical, marine, and other industries where corrosive conditions exist. Anchor shackles are forged of Type 316 or Type 305 Cu stainless steel. Twisted shackles are forged of Type 304 stainless steel.

Stock Dia.	SCREW PINS			BOLT PINS			LOOSE PINS					
	A	B	C	Brkn Full	NET EACH	Load Limit, Lbs.*	Brkn Full	NET EACH	Load Limit, Lbs.*			
1/2"	1/2"	1/2"	1/2"	10	4,000	3663T51	53.53	32.11	6,500	8966T51	112.28	110.78
3/4"	3/4"	3/4"	3/4"	10	8,500	3663T42	5.33	4.70	10,000	8966T52	17.28	15.33
1"	1"	1"	1"	10	10,000	3663T43	7.56	6.70	14,000	8966T53	25.90	22.72
1 1/4"	1 1/4"	1 1/4"	1 1/4"	5	14,000	3663T44	10.38	9.22	19,000	8966T54	27.26	24.71
1 1/2"	1 1/2"	1 1/2"	1 1/2"	5	13,000	3663T45	11.04	12.45	25,000	8966T55	34.37	31.91
2"	2"	2"	2"	5	25,000	3663T46	19.37	17.22	42,000	8966T56	55.12	50.39
2 1/2"	2 1/2"	2 1/2"	2 1/2"	5	30,000	3663T47	24.19	24.28	60,000	8966T57	75.51	67.33
3"	3"	3"	3"	5	50,000	3663T48	75.39	66.52	80,000	8966T12	161.78	144.62
3 1/2"	3 1/2"	3 1/2"	3 1/2"	5	86,000	3663T49	176.31	157.33	100,000	8966T14	224.10	200.69

GALVANIZED STEEL ANCHOR SHACKLE

Stock Dia.	A	B	C	Qty.	Std. Pkg. Limit, Lbs.*	Lead Qty.	NET EACH Brkn Full Pkg.	NET EACH Full Pkg.
1/2"	1/2"	1/2"	1/2"	25	566	3558T44	32.22	32.00
3/4"	3/4"	3/4"	3/4"	25	1,000	3558T45	2.34	1.97
1"	1"	1"	1"	25	1,500	3558T46	3.03	2.57
1 1/4"	1 1/4"	1 1/4"	1 1/4"	25	2,000	3558T47	3.28	2.77
1 1/2"	1 1/2"	1 1/2"	1 1/2"	25	3,000	3558T48	3.67	3.11
2"	2"	2"	2"	25	4,000	3558T49	4.40	3.76
2 1/2"	2 1/2"	2 1/2"	2 1/2"	25	6,500	3558T51	7.82	6.43
3"	3"	3"	3"	10	9,500	3558T52	11.00	9.26
3 1/2"	3 1/2"	3 1/2"	3 1/2"	10	13,000	3558T53	15.42	13.13
4"	4"	4"	4"	10	17,000	3558T54	20.28	17.36
4 1/2"	4 1/2"	4 1/2"	4 1/2"	10	19,000	3558T55	26.95	24.54
5"	5"	5"	5"	10	24,000	3558T56	38.43	32.94
5 1/2"	5 1/2"	5 1/2"	5 1/2"	10	27,000	3558T57	57.11	50.47
6"	6"	6"	6"	5	34,000	3558T58	78.95	65.40
6 1/2"	6 1/2"	6 1/2"	6 1/2"	5	50,000	3558T59	125.15	108.28
7"	7"	7"	7"	5	70,000	3558T61	153.00	137.70

TYPE 316 STAINLESS STEEL ANCHOR SHACKLE

Stock Dia.	A	B	C	Qty.	NET EACH Brkn Full Pkg.	NET EACH Full Pkg.	Load Limit, Lbs.*	
1/2"	1/2"	1/2"	1/2"	10	450	3583T34	315.73	313.78
3/4"	3/4"	3/4"	3/4"	10	650	3583T38	17.45	15.62
1"	1"	1"	1"	10	1,000	3583T38	18.82	16.85
1 1/4"	1 1/4"	1 1/4"	1 1/4"	10	1,375	3583T53	26.73	23.64
1 1/2"	1 1/2"	1 1/2"	1 1/2"	10	1,990	3583T39	27.94	24.83
2"	2"	2"	2"	5	3,050	3583T41	48.36	43.71
2 1/2"	2 1/2"	2 1/2"	2 1/2"	5	4,475	3583T43	66.64	60.10
3"	3"	3"	3"	5	6,000	3583T45	82.25	75.92
3 1/2"	3 1/2"	3 1/2"	3 1/2"	5	7,950	3583T47	95.36	86.37

TYPE 305 STAINLESS STEEL ANCHOR SHACKLE

Stock Dia.	A	B	C	Qty.	NET EACH Brkn Full Pkg.	NET EACH Full Pkg.	Load Limit, Lbs.*	
1/2"	1/2"	1/2"	1/2"	10	397	3797T41	38.01	36.41
3/4"	3/4"	3/4"	3/4"	10	662	3797T42	9.47	7.58
1"	1"	1"	1"	10	326	3797T43	12.56	10.04
1 1/4"	1 1/4"	1 1/4"	1 1/4"	10	1,032	3797T44	18.54	14.83
1 1/2"	1 1/2"	1 1/2"	1 1/2"	10	2,293	3797T45	29.68	23.74

TYPE 304 STAINLESS STEEL TWISTED SHACKLE

Stock Dia.	A	B	C	Qty.	NET EACH Brkn Full Pkg.	NET EACH Full Pkg.	Load Limit, Lbs.*	
1/2"	1/2"	1/2"	1/2"	10	860	33845T91	34.60	34.09
3/4"	3/4"	3/4"	3/4"	10	880	33845T92	3.83	3.40
1"	1"	1"	1"	10	1,540	33845T93	5.59	4.97
1 1/4"	1 1/4"	1 1/4"	1 1/4"	10	2,970	33845T94	10.16	9.03
1 1/2"	1 1/2"	1 1/2"	1 1/2"	10	4,350	33845T95	19.22	17.08
2"	2"	2"	2"	10	8,250	33845T96	22.07	19.61

* WARNING: DO NOT EXCEED WORK LOAD LIMITS

McMASTER-CARR

GALVANIZED STEEL CHAIN SHACK that has a galvanized finish, with alloy steel and tempered. Shackles meet requirements RR-C-271b, MIL-S-24214 Grade A.

Stock Dia.	A	B	C	Qty.	NET EACH Brkn Full Pkg.	NET EACH Full Pkg.	Load Limit, Lbs.*	
1/2"	1/2"	1/2"	1/2"	25	1,500	3559T44	32.22	31.89
3/4"	3/4"	3/4"	3/4"	25	1,500	3559T45	2.94	2.52
1"	1"	1"	1"	25	2,000	3559T46	3.17	2.65
1 1/4"	1 1/4"	1 1/4"	1 1/4"	25	3,000	3559T47	3.36	3.03
1 1/2"	1 1/2"	1 1/2"	1 1/2"	25	4,000	3559T48	4.38	3.72
2"	2"	2"	2"	25	6,500	3559T49	7.78	6.51
2 1/2"	2 1/2"	2 1/2"	2 1/2"	25	9,500	3559T51	10.76	9.16
3"	3"	3"	3"	10	13,000	3559T52	16.68	13.55
3 1/2"	3 1/2"	3 1/2"	3 1/2"	10	17,000	3559T53	19.09	16.23
4"	4"	4"	4"	10	19,000	3559T54	24.67	20.71
4 1/2"	4 1/2"	4 1/2"	4 1/2"	10	24,000	3559T55	36.43	30.83
5"	5"	5"	5"	10	28,000	3559T56	61.02	69.45
5 1/2"	5 1/2"	5 1/2"	5 1/2"	10	34,000	3559T59	92.17	82.57
6"	6"	6"	6"	5	50,000	3559T61	149.59	134.01
6 1/2"	6 1/2"	6 1/2"	6 1/2"	5	70,000	3559T62	194.95	174.45
7"	7"	7"	7"	5	100,000	3559T59	359.75	319.22

TYPE 305 STAINLESS STEEL

Stock Dia.	A	B	C	Qty.	NET EACH Brkn Full Pkg.	NET EACH Full Pkg.	Load Limit, Lbs.*	
1/2"	1/2"	1/2"	1/2"	25	1,500	3559T44	32.22	31.89
3/4"	3/4"	3/4"	3/4"	25	1,500	3559T45	2.94	2.52
1"	1"	1"	1"	25	2,000	3559T46	3.17	2.65
1 1/4"	1 1/4"	1 1/4"	1 1/4"	25	3,000	3559T47	3.36	3.03
1 1/2"	1 1/2"	1 1/2"	1 1/2"	25	4,000	3559T48	4.38	3.72
2"	2"	2"	2"	25	6,500	3559T49	7.78	6.51
2 1/2"	2 1/2"	2 1/2"	2 1/2"	25	9,500	3559T51	10.76	9.16
3"	3"	3"	3"	10	13,000	3559T52	16.68	13.55
3 1/2"	3 1/2"	3 1/2"	3 1/2"	10	17,000	3559T53	19.09	16.23
4"	4"	4"	4"	10	19,000	3559T54	24.67	20.71
4 1/2"	4 1/2"	4 1/2"	4 1/2"	10	24,000	3559T55	36.43	30.83
5"	5"	5"	5"	10	28,000	3559T56	61.02	69.45
5 1/2"	5 1/2"	5 1/2"	5 1/2"	10	34,000	3559T59	92.17	82.57
6"	6"	6"	6"	5	50,000	3559T61	149.59	134.01
6 1/2"	6 1/2"	6 1/2"	6 1/2"	5	70,000	3559T62	194.95	174.45
7"	7"	7"	7"	5	100,000	3559T59	359.75	319.22

Forged S

Easy-to-grip, tee-handle pins are held fast by hairpin locks. Perfect for hitching and towing that require rapid hookup and release. Forged from high-strength carbon steel. Pins are heat treated and zinc plated. Color is orange.

The extra width you need for work Clavis features a bolt-style pin that alloy steel with a zinc chromate finish. Units meet military specific load limit is the load the clavis can support without permanent deformation. Do not exceed.

7.0 THERMAL EVALUATION

7.1 INTRODUCTION

Internal heat generation of the contents shall not prevent the package from maintaining its integrity during the specified lifetime of the waste package. Evaluation of heat transfer data will include information or assumptions as required to determine if the package is capable of passively transferring the heat load to the environment or if specific cooling devices are necessary.

7.2 THERMAL SOURCE SPECIFICATION

From a waste generation study (WHC 1994a), Table B2-1 in Part B, Section 2.1, provides the activity of radionuclides estimated to be attached to the mixer pump based on an estimated 3 mm thick film of tank waste material attached to specific areas of the pump and liquid holdup of 68 gallons inside the pump. This is considered the "worst case" waste that will be attached to and contained inside the pump and will be used for calculation of the internal thermal heat load (decay heat) for the shipping container.

7.3 SUMMARY OF THERMAL PROPERTIES OF MATERIALS

The absorption factors for yellow and white paint which may be used to coat the shipping container are 0.8 and 0.15, respectively.

7.4 THERMAL EVALUATION FOR NORMAL TRANSFER CONDITIONS

7.4.1 Conditions to be Evaluated

The thermal evaluation for the HMMP Package is provided in Part B, Section 7.6. The evaluation examined the thermal characteristics of loading and storing of the HMMP in the shipping container. Steady state and transient temperatures were calculated for combined heat sources from internal decay heat and external solar heating using the TAP-A computer code (WHC-SD-FF-ER-050). Thermal predictions were obtained for a relatively high absorption factor that is typical for standard yellow paint used for shipping containers. Additional predictions were obtained using a relatively low absorption factor that is available in a white paint. Figure 1 in Part B, Section 7.6, describes the pump and container arrangement.

Three conditions were examined for a yellow painted container with decay heat and solar insolation, a yellow painted container with no decay heat and only solar insolation, and a white painted container with both solar insolation and decay heat.

7.4.2 Acceptance Criteria

The maximum allowable temperature for the shipping container surface is 180 °F.

7.4.3 Thermal Model

The thermal model of the pump and shipping container is a one dimensional cylindrical radial section using dimensions taken at the maximum pump diameter at the volute region. Figure 2 in Part B, Section 7.6, illustrates the model. Combined decay heat from 68 gallons of retained tank waste and surface film was assumed as uniformly distributed length wise and amounted to 6.4×10^{-4} W/in (0.88 W). This was converted to a volumetric value in the model. Solar heat is applied to the external surface of the model in the form of tabulated surface heat fluxes for specific times in a 24 hour period. Values of hourly solar insolation were obtained from WHC-SD-TP-RPT-005 as recommended for the Hanford Site (Table 1 in Part B, Section 7.6). Thermal radiation and convection heat losses are calculated relative to the standard Hanford ambient temperature 24 hour variation.

7.4.4 Thermal Analysis

Transient temperatures were calculated for the pump and shipping container which has two heat sources:

1. Daily variations of ambient temperature and solar insolation.
2. Constant decay heat from 68 gallons of tank waste that is retained inside the pump and a film on the external surfaces of the pump.

The distribution of decay heat from 68 gallons of retained tank waste and film was coordinated with the shielding evaluation and is the same basis used in this thermal evaluation, namely, the combined decay heat source is uniformly distributed along the length which amounts to a relatively small value of 6.4×10^{-4} W/in (0.88 W). Table 2 in Part B, Section 7.6, shows these calculations.

Three conditions were examined as follows:

1. A yellow painted container (0.8 absorption factor) with decay heat and solar insolation.
2. A yellow painted container with no decay heat and only solar insolation.
3. A white painted container (0.15 absorption factor) with solar insolation and decay heat.

7.5 THERMAL EVALUATIONS AND CONCLUSIONS

The maximum allowable temperature for the container external surface is 180 °F. Peak temperatures for a yellow painted container with solar insolation and decay heating are predicted to exceed the allowable limit of 180 °F as shown in Figure 3 (Part B, Section 7.6). Removal of the uniformly distributed decay heat has no discernable influence on reducing the peak temperature for the yellow painted container as shown in Figure 4 (Part B, Section 7.6). Solar heating is the dominant heat source. Reducing solar absorption can significantly reduce peak temperatures. Figure 5 (Part B, Section 7.6) shows results of transient predictions for a white painted container having an absorption factor of 0.15 with peak temperatures under 125 °F. The internal temperature of the pump is seen to rise slowly, but is not expected to exceed approximately 105 °F.

Per Drawing H-2-83734, the shipping container external surface is painted with a top coat of Ameron 450 HS White. The peak temperature of this external surface related to solar heating will not exceed 125 °F, hence the temperature limit of 180 °F is satisfied. Pressure increase inside the shipping container will be insignificant with the internal temperature not exceeding 105 °F.

7.6 THERMAL ANALYSIS

**Westinghouse
Hanford Company**
**Internal
Memo**

From: TWRS Thermal Hydraulics 7E870-JCG-94-057
 Phone: 376-6588 HO-33
 Date: July 12, 1994
 Subject: THERMAL EVALUATION SY101 HYDROGEN MITIGATION MIXER PUMP (HMMP)
 CONTAINER

To: R. F. Carlstrom G2-02

cc: J. G. Fadeff HO-33*
 J. J. Irwin HO-33*
 T. B. McCall HO-33
 JCG File/LB
 *w/o attachment

Attached is a description of the thermal evaluation of a proposed shipping container for the SY101 Hydrogen Mitigation Mixer Pump (HMMP). The pump is 60 feet long, has a maximum diameter of 53 inches, and weighs about 20,000 pounds. The container design is 65 feet long and uses concentric cylinders to form an annulus for shielding material (lead balls). The outer diameter of the carbon steel container is 6 feet. When the pump is removed from SY101 it retains about 68 gallons of radioactive liquid in addition to an external covering of film. These relate to a linear decay heat value of 3.3×10^{-3} watts/in for a total of 0.88 watts.

The container will have two sources of heat, namely, decay heat and solar heat. For this container solar heating dominates temperatures. The evaluation includes temperature predictions for high solar absorption that is common with standard yellow paint and significantly lower absorptions by using a white painted exterior.

All results and related information have been stored in the Task Record THA-94-012.

J. C. Guzek

J. C. Guzek, Fellow Engineer
 TWRS Thermal Hydraulics

skw

Attachment

T. B. McCall

CONCURRENCE:


 T. B. McCall, Manager
 TWRS Thermal Hydraulics

THERMAL EVALUATION SY101 HYDROGEN MITIGATION
MIXER PUMP (HMMP) SHIPPING CONTAINER



Prepared by:

J. C. Guzek, Fellow Engineer
TWRS Thermal Hydraulics



Reviewed by:

J. J. Irwin, Principal Engineer
TWRS Thermal Hydraulics

FIGURES

- Figure 1. SY101 Mixer Pump (HMMP) Storage Container.
- Figure 2. TAP-A Thermal Model.
- Figure 3. HMMP Container Solar and Internal Decay Heat.
- Figure 4. HMMP Container Solar and No Internal Heat.
- Figure 5. HMMP Container Decay and Solar Heat - White Paint.

TABLES

- Table 1. Solar Insolation for An Average July Day at Hanford Site.
- Table 2. HMMP Container Decay Heat Calculation

THERMAL EVALUATION SY101 HYDROGEN MITIGATION
MIXER PUMP (HMMP) SHIPPING CONTAINER

- SCOPE** This evaluation examined the thermal characteristics of loading and storage of the SY101 HMMP in a container. Steady state and transient temperatures were calculated for combined heat sources from internal decay heat and external solar heating using the TAP-A computer code (Reference 1). Thermal predictions were obtained for a relatively high absorption factor of 0.8 that is typical of the standard yellow paint generally used for shipping containers. Additional predictions were obtained using a relatively low absorption factor of 0.15 that is available in a white paint. Figure 1 describes the HMMP and container arrangement.
- MODEL** The thermal model of the Pump/Container is a one dimensional cylindrical radial section using dimensions taken at the maximum pump diameter location at the volute region. Figure 2 illustrates the model. Combined decay heat from 68 gal of retained tank liquid and surface film was assumed as uniformly distributed length wise and amounted to 3.3×10^{-3} W/in. This was converted to a volumetric value in the model. Solar heat is applied to the external surface of the model in the form of tabulated surface heat fluxes for specific times in a 24 hour period. Values of hourly solar insolation were obtained from Reference 2 as recommended for the Hanford site (Table 1). Thermal radiation and convection heat losses are calculated relative to the standard Hanford ambient temperature 24-hour variation (See Table 1).
- METHOD** Transient temperatures were calculated for the pump-container configuration which has two heat sources: a) daily variations of ambient temperature and solar insolation; b) constant decay heat from 68 gal of tank fluid that is retained in the pump a film on the external surfaces of the pump.
- The distribution of decay heat from 68 gal of retained tank fluid and film was coordinated with the shielding evaluation and is the same basis used in this thermal evaluation, namely, the combined decay heat source is uniformly distributed along the length which amounts to a relatively small value of 3.3×10^{-3} watts/inch. Table 2 shows these calculations.
- Three conditions were examined as follows: 1) a yellow painted container (0.8 absorption factor) with decay heat and solar heat, 2) a yellow painted container with no decay heat and only insolation, and 3) a white painted container (0.15 absorption factor) with both solar and decay heat.

RESULTS

The maximum allowable temperature for the container external surface is 180 °F. Peak temperatures for a yellow painted container with solar and decay heating are predicted to exceed the allowable of 180 °F as shown in Figure 3. Removal of the uniformly distributed decay heat has no discernable influence on reducing peak temperature for the yellow painted container as shown in Figure 4. Solar heating is the dominant heat source. Therefore, reducing solar absorption can significantly reduce peak temperatures. Figure 5 shows results of transient predictions for a white painted container having an absorption factor of 0.15 with peak temperatures under 125 °F. The internal temperature of the pump is seen to rise slowly, but is not expected to exceed approximately 105 ° F.

REFERENCES

1. WHC-SD-FF-ER-050, *TAP-A Code Notebook*, 1990.
2. WHC-SD-50-RPT-005, *Thermal Analysis Methods for Safety Analysis Reports for Packaging*, 1993, Westinghouse Hanford Company, Richland, Washington.

Figure 1. SY101 Mixer Pump (HMMP) Storage Container.




Figure 2. TAP-A Thermal Model.




Figure 3. HMMP Container Solar and Internal Decay Heat.




Figure 4. HMMP Container Solar No Internal Heat.





Figure 5. HMMP Container Decay Heat - White Paint.



a) Recommended for Hanford Site.
 b) Hanford Site Insolation Normalized to 10CFR71 Requirements.
 c) Recommended off-site case, meets 10CFR71 Requirements.
 d) A Langley is defined as 1 gram calorie per square centimeter.

Hour-PST	WMC-1992B ^a			10CFR71 ^b			COSINE			ASHRAE OFF-SITE ^c		
	Langley/s ^d	Btu/ft ²	Langley/s	Btu/ft ²	Langley/s	Btu/ft ²	Btu/ft ²	Langley/s	Btu/ft ²	Langley/s	Btu/ft ²	
12-01 AM	0	0	0	0	0	0	0	0	0	0	0	
01-02 AM	0	0	0	0	0	0	0	0	0	0	0	
02-03 AM	0	0	0	0	0	0	0	0	0	0	0	
03-04 AM	0	0	0	0	0	0	0	0	0	0	0	
04-05 AM	2.5	9.2	3.1	11.4	13.6	50.1	0	0	0	0	0	
05-06 AM	9.8	36.1	12.1	44.7	26.8	98.8	0	0	0	0	0	
06-07 AM	22.1	81.5	27.3	100.7	39.0	143.8	18.3	42.3	156.0	67.3	235.5	
07-08 AM	36.6	134.9	45.2	166.8	49.9	184.0	42.3	156.0	67.3	235.5	300.4	
08-09 AM	49.9	184.0	61.7	227.5	59.2	218.3	43.9	156.0	67.3	235.5	300.4	
09-10 AM	60.7	223.8	75.0	276.7	66.4	244.8	81.5	300.4	346.0	300.4	300.4	
10-11 AM	68.3	251.8	84.4	311.3	71.3	262.9	93.9	346.0	370.0	370.0	370.0	
11-12 AM	72.1	265.8	89.1	328.6	73.8	272.1	100.4	370.0	370.0	370.0	370.0	
12-01 PM	71.9	265.1	88.9	327.7	73.8	272.1	100.4	370.0	370.0	370.0	370.0	
01-02 PM	67.8	250.0	83.8	309.0	71.3	262.9	93.9	346.0	370.0	370.0	370.0	
02-03 PM	60.5	223.1	74.8	275.8	66.4	244.8	81.5	300.4	346.0	346.0	346.0	
03-04 PM	49.9	184.0	61.7	227.5	59.2	218.3	43.9	156.0	235.5	235.5	235.5	
04-05 PM	37.2	137.2	46.0	169.6	49.9	184.0	42.3	156.0	156.0	156.0	156.0	
05-06 PM	23.6	87.0	29.2	107.6	39.0	143.8	18.3	47.3	47.3	47.3	47.3	
06-07 PM	11.3	41.7	14.0	51.5	26.8	98.8	0	0	0	0	0	
07-08 PM	2.9	10.7	3.6	13.2	13.6	50.1	0	0	0	0	0	
08-09 PM	0	0	0	0	0	0	0	0	0	0	0	
09-10 PM	0	0	0	0	0	0	0	0	0	0	0	
10-11 PM	0	0	0	0	0	0	0	0	0	0	0	
11-12 PM	0	0	0	0	0	0	0	0	0	0	0	
SUM	647.1	2386.	800.0	2950.	800.	2950.	800.	2950.	2950.	2950.	2950.	

Table 1. Solar Insolation for an Average July Day at Hanford Site.

8.0 GAS GENERATION EVALUATION

8.1 GENERAL INFORMATION

Packages of radioactive waste with the potential for gas generation or with the potential to reach explosive concentrations of hydrogen and oxygen or other explosive gases may require vents or catalyst packs to deplete free oxygen and prevent explosive concentrations. A gas generation study (Part B, Section 8.3) was completed to determine the estimated extent of hydrogen gas or other explosive gas build-up in the HMMP Package. Based on results of the study, vents or other methods were evaluated to ensure that estimated gas build-up will not result in unsafe conditions. The study also identified the estimated pressure build-up and thermal loading of the HMMP Package due to waste contents.

8.2 GAS GENERATION EVALUATION AND CONCLUSIONS

Results of a gas generation study indicated that hydrogen gas buildup will exceed the U.S. Nuclear Regulatory Commission (NRC) limit of 2½% (NRC 1992) for transportation within 13.2 years and the Westinghouse Hanford Company (WHC) limit of 5% within 26.3 years (WHC 1993). To assure that hydrogen build-up will not exceed the acceptable limits during the 20 year service life of the package, the primary containment barrier of the package is vented. The study also indicated that the estimated maximum internal pressure build-up in the package at the 5% hydrogen level would be 0.77 psi. Considering this low rate (0.77 psi) of pressure build-up combined with the requirement that the package be vented and the high packaging design pressure ratings, extensive pressure leak testing analysis is not required for the package described in this SEP.

Relating to a postulated accident scenario during the pump lifting operation (Benegas 1994), release of liquid from the pump legs could interact with impact blocks inside the pump which contain a crushed material (aluminum compounds). Contact of liquid with the crushed material may cause hydrogen generation within the flexible bag. Due to the physical location and makeup of the pump and shipping container, the designed and planned use of the shipping container, and the worst case projected waste filled pump scenario, the potential of waste contacting the aluminum crushed material was deemed extremely unlikely. This scenario was not considered in the gas generation analysis.

8.3 HYDROGEN GAS GENERATION ANALYSIS

ENGINEERING ANALYSIS

Building: 1100/MO-404 Rev.: _____ Page: 1 of 2
 Subject: Gas Generation for HMMP
 Originator: J. R. Green ~~J. R. Green~~ Date: 6/3/94
 Checker: J.E. Merriello ~~J.E. Merriello~~ Date: 6/6/94

Subject: Determination of hydrogen gas generation and pressure buildup in packaging containing a pump removed from Tank 101-SY. In addition estimate the thermal output of the defined source terms.

- References:** (1) GEND-041, "A Calculation Technique to Predict Combustible Gas Generation in Sealed Radioactive Waste Containers," May 1986
- (2) WHC-SD-TP-PDC-019, "Packaging Design Criteria Transfer and Disposal of Hydrogen Mitigation Mixer Pump," Rev. 0, January 1994.

Determination:

The methodology described in Reference 1 was used to perform the analysis for packaging containing pumps removed from Tank 101-SY. The Lotus 1-2-3[®] spreadsheet provided with Reference 1 was used for the analysis. This spreadsheet has been approved by the U.S. Nuclear Regulatory Commission (NRC) for use in the determination of hydrogen generation in low-level waste.

The following table contains data used for input to the spreadsheet.

Input:

Pump Assembly Dimensions	47 ft long
	53 in. diameter
Package Dimensions (Interior)	62 ft long
	63.25 in. diameter
Est. Package Volume	647.2 ft ³
Est. Container Void Volume	632.75 ft ³
Waste Weight	1569 lb
Waste Volume	14.45
Waste Density	108.6 lb/ft ³

The following table contains the results obtained from spreadsheet calculations.

ENGINEERING ANALYSIS

Building: 1100/MO-404 Rev.: _____ Page: 2 of 2
 Subject: Gas Generation for HMMP
 Originator: J. R. Green J.R. Green Date: 6/5/94
 Checker: J. J. Marcano J. J. Marcano Date: 6/10/94

Results:

Initial Gas Generation Rate	5.503 cc/h
Gas Generation Rate at 5% Hydrogen Concentration	4.095 cc/h
Days (yrs) to 5% Concentration	9587 (26.27)
Pressure at 5% Concentration	0.77 psi
Max Decay Heat Watts (BTU/h)	1.441 (4.92)

See spreadsheets and data library attached.

PROGRAM to CLASSIFY RADIOACTIVE WASTE CONTAINERS for TRANSPORTATION and DISPOSAL		FILE REF:
CP Debris - Analytical Resources, Inc., 2/83 & 6/90 (Modified for DOE Radonucleides and Thermal Wastes... RP Genom/KI Field, Westinghouse-Manford Co., 6/88)	DATE:	5/23/94
Originally Published by the Electric Power Research Institute in NP-4938 and NP-4757	BY:	JRO JRG/aw... 6/3/94
	CHECKED:	JF/M... 1/12/94
*** WASTE GENERAL INFORMATION ***		
Enter waste description	>	
Enter waste form ("Special" or "Normal")	>	normal >> Recd input for DOT calculations
Enter physical form ("Solid", "Liquid" or "Gas")	>	liquid >> Recd input for DOT calculations
Is waste Activated Metal? ("Yes", or "No")	>	no >> Recd input for 10CFR61 calculations
Enter container type (1=55 gal. drum, 2=4x4 liter, 3=5x5 liter, 4=6x6 liter)	>	4 >> Recd input for H2 calculations
Is container a vented HIC? ("Yes", or "No")	>	no "Note: For a vented HIC, assume "Date sealed" is date shipped in Cask
Enter date of cask calculations	>	05/23/94
Enter date last sealed	>	05/23/94 >>
Enter date to be shipped	>	05/24/94 >> Must be later than CI date
Enter date of shipment receipt	>	05/24/94
CALCULATED Decay before sealing (years)	=	0.00 Days= 0
CALCULATED Decay before shipment (years)	=	0.00 Days= 1
CALCULATED Duration package as sealed (years)	=	0.00 Days= 1
Enter package exterior volume	>	647.2 H3
Enter waste volume	>	14.5 F11
CALCULATED Container void volume	=	632.8 F13
Enter estimated waste void volume	>	F13
Enter waste true density (vendor data)	>	108.6 Lbw/F13
CALCULATED Waste void fraction	=	0.000
CALCULATED Waste void volume	=	0.00 F13
CALCULATED Package interior volume	=	1.833E+07 cc
CALCULATED Waste volume	=	4.092E+05 cc
CALCULATED Total void volume	=	1.792E+07 cc
Enter waste weight	>	1569 Lbs
CALCULATED Weight	=	7.123E+05 gms
CALCULATED Waste bulk density	=	1.7409 gms/cc
Enter G-H2 (molecules/100 cv)	>	0.50
OR	>	
Enter volume carbon resin (cu ft)	>	
Enter volume resin resin (cu ft)	>	
Enter volume max bed resin (cu ft)	>	
Enter volume other resin (cu ft)	>	
Enter G-H2 of other resin	>	
CALCULATED G-H2 for waste	=	0.00
*** CALCULATED RESULTS ***		
H2 Concentration Summary:		
Total Integrated Dose	=	1.591E+04 Rads
H2 Volume	=	1.321E+02 cc-ft
H2 Concentration	=	0.00 %
H2 Generation Rate	=	3.503E+00 cc/hr
Pressure Buildup Rate	=	1.084E-04 psi/day
Pressure (lead to ship)	=	0.00 psi

Enter Measured H2 Concentration (if known)	>	0.00	%	
Ratio Measured to Calculated H2 Concentrations	=	0.00		
Activity Summary @ Shipment				
Total Activity*	=	2.891E+02	Cl	(*Excludes Daughters)
Specific Activity, Total*	=	0.706	nCi/oz	with T 1/2 < 10 days
Specific Activity*, T 1/2 < 3 Years	=	6.649E+02	µCi/oz	
T 1/2 > 3 Years	=	7.065E+02	µCi/oz	>> Verify Disposal License
Decay Heat @ Shipment				
Decay Heat @ Shipment*	=	1.441	Watts	
or	=	4.920	BTU/hr	
Radioactive Material				
Radioactive Material (49 CFR 173 & 10 CFR 71)	=	1.926	gms	
Other DOE Radioactive Material (DOE 5480.1A)	=	38.531	gms	>> Isotope list is incomplete
Special Nuclear Material				
Special Nuclear Material (SNM)	=	1.933	gms	
Other DOE Accountable Material (DOE 5433.3)	=	38.602	gms	>> Isotope list is incomplete
Transuranic				
Specific Activity, Transuranic	=	312.256	nCi/gms	>> Potential GTOC
10 CFR 61.35 Classification				
Unity Fraction				Classification
Table 1 Isotopes (Long Lived)		33.622	A	Class > C
		N/A	B	
		3.362	C	Long-lived isotopes
Table 2 Isotopes (Short Lived)		2431.262	A	Am-241
		14.706	H	Miscellaneous
		0.146	C	
Transportation Classification				
Unity Fraction				
LSA Determination	=	1.248E+01	> LSA	
Type Determination	=	1.328E+02	Type 'B'	
Highway Route Control (HRC) Determination	=	4.426E-02	Non HRC	
Limited Quantity (LQ) Determination	=	1.328E+06	> LQ	
Advance Notification Query?	=	Yes		
EPA Reportable Quantity (RQ) Determination	=	3.852E+02	Reportable Quantity	

INPUT: LISTED ISOTOPES					
(**** = Daughter Product)					
	Curies	or	%	Curies when Sealed	Curies when Shipped
Total Curies				xxxxx	xxxxx
	(ONLY if entering %)				
H-3	0.000E+00			0.000E+00	0.000E+00
C-14	6.170E-04			6.170E-04	6.170E-04
N-22				0.000E+00	0.000E+00
Cr-51	0.000E+00			0.000E+00	0.000E+00
Mn-54	0.000E+00			0.000E+00	0.000E+00
Fe-55	0.000E+00			0.000E+00	0.000E+00
Co-57				0.000E+00	0.000E+00
Co-58				0.000E+00	0.000E+00
Fe-59				0.000E+00	0.000E+00
Ni-59	8.380E-05			8.380E-05	8.380E-05
Co-60	3.330E-01			3.330E-01	3.329E-01
Ni-63	1.370E-02			1.370E-02	1.370E-02
Zn-65				0.000E+00	0.000E+00
Se-79	2.140E-04			2.140E-04	2.140E-04
Kr-83				0.000E+00	0.000E+00
R-89				0.000E+00	0.000E+00
Zr-90	2.990E+01			2.990E+01	2.990E+01
Y-90	****		****	2.990E+01	2.990E+01
Y-91				0.000E+00	0.000E+00
Zr-93				0.000E+00	0.000E+00
Nb-93m	2.500E-03			2.500E-03	2.500E-03
Nb-94	2.990E-03			2.990E-03	2.990E-03
Zr-95				0.000E+00	0.000E+00
Nb-95				0.000E+00	0.000E+00
Nb-95m				0.000E+00	0.000E+00
Tc-99	2.400E-01			2.400E-01	2.400E-01
Ru-103				0.000E+00	0.000E+00
Rh-103m	****		****	0.000E+00	0.000E+00
Ru-106				0.000E+00	0.000E+00
Rh-106	****		****	0.000E+00	0.000E+00
Pd-107				0.000E+00	0.000E+00
Cd-109				0.000E+00	0.000E+00
Ag-110m				0.000E+00	0.000E+00
Ag-110	****		****	0.000E+00	0.000E+00
Sr-113				0.000E+00	0.000E+00
In-113m	****		****	0.000E+00	0.000E+00
Cd-113m				0.000E+00	0.000E+00
Cd-115m				0.000E+00	0.000E+00
Sa-119m				0.000E+00	0.000E+00
Sa-121m				0.000E+00	0.000E+00
Sb-123				0.000E+00	0.000E+00
Te-123m				0.000E+00	0.000E+00
Sb-124				0.000E+00	0.000E+00
Sb-125				0.000E+00	0.000E+00
Te-125m				0.000E+00	0.000E+00
Sa-126				0.000E+00	0.000E+00
Sb-126m	****		****	0.000E+00	0.000E+00
Sb-126				0.000E+00	0.000E+00
Te-127m				0.000E+00	0.000E+00
Te-127	****		****	0.000E+00	0.000E+00
Te-129m				0.000E+00	0.000E+00
Te-129	****		****	0.000E+00	0.000E+00
I-129	9.420E-03			9.420E-03	9.420E-03
I-131				0.000E+00	0.000E+00
Os-134				0.000E+00	0.000E+00
Os-135				0.000E+00	0.000E+00
Os-136				0.000E+00	0.000E+00
Os-137	2.560E+02			2.560E+02	2.560E+02
Ra-137m	****		****	2.422E+02	2.422E+02
Ba-140				0.000E+00	0.000E+00
La-140	****		****	0.000E+00	0.000E+00
Ce-141				0.000E+00	0.000E+00
Pr-143				0.000E+00	0.000E+00
Ce-144				0.000E+00	0.000E+00

PROGRAM to CLASSIFY RADIOACTIVE WASTE CONTAINERS for TRANSPORTATION and DISPOSAL		FILE REF:	HMMP.XLS
CP DeWitt Analytical Resources, Inc., 2/85 & 6/90 (Modified for DOE Radionuclides and Thermal Wastes... RP Oconnor/KJ Field, Westinghouse-Hanford Co., 6/88)		DATE:	5/23/94
Originally Published by the Electric Power Research Institute in NP-4938 and NP-4757		BY:	IRG JRG 6/3/94
		CHECKED:	J. J. M... 6/6/94
*** WASTE GENERAL INFORMATION ***			
Enter waste description	>		
Enter waste form ("Special" or "Normal")	>	normal	>> Req'd input for DOT calculations
Enter physical form ("Solid", "Liquid" or "Gas")	>	liquid	>> Req'd input for DOT calculations
Is waste Activated Metal? ("Yes", or "No")	>	no	>> Req'd input for 10CFR61 calculations
Enter container type (1=55 gal. drum, 2=64 liter 3=325 liter, 4=666 liter)	>	4	>> Req'd input for HZ calculations
Is container a vented HIC? ("Yes", or "No")	>	no	*Note: For a vented HIC, assume "Date sealed" is date shipped in Cask
Enter date of cask calculations	>	05/23/94	
Enter date last sealed	>	05/23/94	>>
Enter date to be shipped	>	08/21/20	>> Must be later than CI onset
Enter date of shipment receipt	>	08/21/20	
CALCULATED Decay before sealing (years)	=	0.00	Days 0
CALCULATED Decay before shipment (years)	=	26.27	Days 9387
CALCULATED Duration package is sealed (years)	=	26.27	Days 9387
Enter package exterior volume	>	547.2	ft ³
Enter waste volume	>	14.5	ft ³
CALCULATED Container void volume	=	532.8	ft ³
Enter estimated waste void volume	>		ft ³
** OR **			
Enter waste true density (vendor data)	>	108.6	Lbs/ft ³
CALCULATED Waste void fraction	=	0.000	
CALCULATED Waste void volume	=	0.00	ft ³
CALCULATED Package exterior volume	=	1.803E+07	cc
CALCULATED Waste volume	=	4.092E+03	cc
CALCULATED Total void volume	=	1.792E+07	cc
Enter waste weight	>	1569	Lbs
CALCULATED Weight	=	7.123E+03	gms
CALCULATED Waste bulk density	=	1.7409	gms/cc
Enter O-15 (molecules/100 av)	>	0.50	
OR			
Enter volume carbon resin (cu ft)	>		
Enter volume silicon resin (cu ft)	>		
Enter volume wax bed resin (cu ft)	>		
Enter volume other resin (cu ft)	>		
Enter O-15 of other resin	>		
CALCULATED O-15 for waste	=	0.00	
*** CALCULATED RESULTS ***			
H2 Generation Summary			
Total Integrated Dose	=	1.135E+08	Rads
H2 Volume	=	9.421E+03	cm ³
H2 Concentration	=	5.00	%
H2 Generation Rate	=	4.095E+00	cc/hr
Pressure Buildup Rate	=	8.067E-03	psi/day
Pressure (sent to ship)	=	0.77	psi

Enter Measured H2 Concentration (if known)	>	0.00	%	
Ratio Measured to Calculated H2 Concentration	=	0.00		
Activity Summary @ Shipment:				
Total Activity*	=	1.566E+02	Ci	(*Excludes Decayers)
Specific Activity, Total*	=	0.383	mCi/cc	with T 1/2 < 10 days
Specific Activity*, T 1/2 < 3 Years	=	3.624E+02	µCi/cc	
T 1/2 > 3 Years	=	3.828E+02	µCi/cc	>> Verify Disposal License
Decay Heat @ Shipment	=			
Decay Heat @ Shipment	=	0.776	Watts	
or	=	2.649	BTU/hr	
Flammable Material:				
Flammable Material (49 CFR 173 & 10 CFR 71)	=	1.926	grams	
Other DOE Flammable Material (DOE 5480.1A)	=	38.331	grams	>> Isotope list is incomplete
Special Nuclear Material:				
Special Nuclear Material (SNM)	=	1.933	grams	
Other DOE Accountable Material (DOE 5403.3)	=	38.399	grams	>> Isotope list is incomplete
Transuranics:				
Specific Activity, Transuranics	=	312.256	mCi/gram	>> Potential GTCC
10 CFR 61.35 Classification:				
		Urnity Fraction		Class/Condition
Table 1 Isotopes (Long Lived)	=	32.309	A	Class > C
	=	N/A	B	
	=	3.231	C	Limiting Isotope Am-241
Table 2 Isotopes (Short Lived)	=	1.00451	A	
	=	8.036	B	Microencapsulated
	=	0.090	C	
Transportation Classification:				
		Urnity Fraction		
LSA Determination	=	7.847E+00	> LSA	
Type Determination	=	8.432E+01	Type 'F'	
Highway Route Control (HRC) Determination	=	2.811E-02	Not HRC	
Limited Quantity (LQ) Determination	=	8.432E+03	> LQ	
Advance Notification Quantity?	=	Yes		
EPA Reportable Quantity (RQ) Determination	=	3.273E+02	Reportable Quantity	

INPUT LISTED ISOTOPES					
(* ** * = Daughter Product)					
	Curies	or	%	Curies when Sealed	Curies when Shipped
Total Curies	(ONLY if entering %)				

H-3	0.000E+00			0.000E+00	0.000E+00
C-14	6.170E-04			6.170E-04	6.150E-04
Na-22				0.000E+00	0.000E+00
Cr-51	0.000E+00			0.000E+00	0.000E+00
Mn-54	0.000E+00			0.000E+00	0.000E+00
Fe-55	0.000E+00			0.000E+00	0.000E+00
Co-57				0.000E+00	0.000E+00
Co-58				0.000E+00	0.000E+00
Fe-59				0.000E+00	0.000E+00
Ni-59	8.580E-03			8.580E-03	8.578E-03
Co-60	3.330E-01			3.330E-01	1.054E-02
Ni-63	1.370E-02			1.370E-02	1.142E-02
Zn-65				0.000E+00	0.000E+00
Sr-79	2.140E-04			2.140E-04	2.139E-04
Kr-83				0.000E+00	0.000E+00
Sr-89				0.000E+00	0.000E+00
Sr-90	1.990E+01			2.990E+01	1.582E+01
Y-90	****		****	2.990E+01	1.582E+01
Y-91				0.000E+00	0.000E+00
Zr-93				0.000E+00	0.000E+00
Nb-93m	2.500E-03			2.500E-03	7.184E-04
Nb-94	2.990E-03			2.990E-03	2.987E-03
Zr-95				0.000E+00	0.000E+00
Nb-95				0.000E+00	0.000E+00
Nb-95m				0.000E+00	0.000E+00
Ta-99	2.400E-01			2.400E-01	2.400E-01
Ra-103				0.000E+00	0.000E+00
Rh-103m	****		****	0.000E+00	0.000E+00
Rh-106				0.000E+00	0.000E+00
Rh-106m	****		****	0.000E+00	0.000E+00
Pd-107				0.000E+00	0.000E+00
Cd-109				0.000E+00	0.000E+00
Ag-110m				0.000E+00	0.000E+00
Ag-110	****		****	0.000E+00	0.000E+00
Sr-113				0.000E+00	0.000E+00
Ir-113m	****		****	0.000E+00	0.000E+00
Cd-113m				0.000E+00	0.000E+00
Cd-113n				0.000E+00	0.000E+00
Sr-119m				0.000E+00	0.000E+00
Sr-121m				0.000E+00	0.000E+00
Sr-123				0.000E+00	0.000E+00
Te-123m				0.000E+00	0.000E+00
Sr-124				0.000E+00	0.000E+00
Sr-125				0.000E+00	0.000E+00
Te-125m				0.000E+00	0.000E+00
Sr-126				0.000E+00	0.000E+00
Sr-126m	****		****	0.000E+00	0.000E+00
Sr-126n				0.000E+00	0.000E+00
Te-127m				0.000E+00	0.000E+00
Te-127	****		****	0.000E+00	0.000E+00
Te-129m				0.000E+00	0.000E+00
Te-129	****		****	0.000E+00	0.000E+00
I-129	9.420E-03			9.420E-03	9.420E-03
I-131				0.000E+00	0.000E+00
Cs-134				0.000E+00	0.000E+00
Cs-135				0.000E+00	0.000E+00
Cs-136				0.000E+00	0.000E+00
Cs-137	2.560E+02			2.560E+02	1.409E+02
Ba-137m	****		****	2.422E+02	1.323E+02
Ba-140				0.000E+00	0.000E+00
La-140	****		****	0.000E+00	0.000E+00
Ce-141				0.000E+00	0.000E+00
Pr-143				0.000E+00	0.000E+00
Ce-144				0.000E+00	0.000E+00

9.0 APPENDIX

9.1 REFERENCES

- 49 CFR 173, 1992, "Radioactive Materials," *Code of Federal Regulations*, as amended.
- 49 CFR 393, "Part and Accessories Necessary for Safe Operation," *Code of Federal Regulations*, as amended.
- 10 CFR 71, "Packaging and Transportation of Radioactive Materials," *Code of Federal Regulations*, as amended.
- Benegas, T. R., 1994, *Impact Material Concerns in Pump Disposal Containers*, (internal letter MIT94-2062 to Distribution, July 29, 1994), Westinghouse Hanford Company, Richland, Washington.
- Holman, W. R., and R. T. Langland, 1981, *Recommendations for Protecting Against Failure by Brittle Fracture in Ferritic Steel Shipping Containers Up to Four Inches Thick*, NUREG/CR-1815, (under Lawrence Livermore National Laboratory contract to the NRC), U.S. Nuclear Regulatory Commission, Washington, D.C., August 1981.
- WHC-CM-1-3, *Management Requirements and Procedures*, Westinghouse Hanford Company, Richland, Washington.
- WHC-CM-2-14, *Hazardous Material Packaging and Shipping*, Westinghouse Hanford Company, Richland, Washington.
- WHC-CM-4-2, *Quality Assurance Manual*, Westinghouse Hanford Company, Richland, Washington.
- WHC-CM-4-9, *Radiological Design*, Westinghouse Hanford Company, Richland, Washington.
- WHC-CM-4-11, *ALARA Program Manual*, Westinghouse Hanford Company, Richland, Washington.
- WHC-CM-7-5, *Environmental Compliance*, Westinghouse Hanford Company, Richland, Washington.
- WHC, 1994a, *Packaging Design Criteria for Transfer and Disposal of Hydrogen Mitigation Mixer Pump*, WHC-SD-TP-PDC-019, Westinghouse Hanford Company, Richland, Washington.
- WHC, 1994b, *Report on Equivalent Safety for Transportation and Packaging of Radioactive Materials*, WHC-SD-TP-RPT-001, Westinghouse Hanford Company, Richland, Washington, January 1994.

Willis N. P., and G. C. Triner, 1993, *Hanford Site Solid Waste Acceptance Criteria*, WHC-EP-0063-4, Rev. 4, Westinghouse Hanford Company, Richland, Washington, September 1993.