

# Recommendations for Erosion-Corrosion Allowance for Multi- Function Waste Tank Facility Tanks

Prepared for the U.S. Department of Energy  
Office of Environmental Restoration and  
Waste Management



**Westinghouse**  
**Hanford Company** Richland, Washington

Hanford Operations and Engineering Contractor for the  
U.S. Department of Energy under Contract DE-AC06-87RL10930

Copyright License By acceptance of this article, the publisher and/or recipient acknowledges the  
U.S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this paper.

Approved for Public Release

**DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED**

# Recommendations for Erosion-Corrosion Allowance for Multi-Function Waste Tank Facility Tanks

W. F. Brehm  
W. C. Carlos  
A. P. Larrick  
Westinghouse Hanford Company

J. R. Divine  
ChemMet Ltd

Date Published  
October 1994

To Be Presented at  
CORROSION/95  
National Association of Corrosion Engineers (NACE)  
Orlando, Florida  
March 26-31, 1995

Prepared for the U.S. Department of Energy  
Office of Environmental Restoration and  
Waste Management



**Westinghouse**  
**Hanford Company**

P.O. Box 1970  
Richland, Washington

Hanford Operations and Engineering Contractor for the  
U.S. Department of Energy under Contract DE-AC06-87RL10930

Copyright License By acceptance of this article, the publisher and/or recipient acknowledges the U.S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this paper.

Approved for Public Release

**MASTER**

*als*  
DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

**LEGAL DISCLAIMER**

---

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or any third party's use or the results of such use of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

---

This report has been reproduced from the best available copy.

Printed in the United States of America

DISCLM-2.CHP (1-91)

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

## RECOMMENDATIONS FOR EROSION-CORROSION ALLOWANCE FOR MULTI-FUNCTION WASTE TANK FACILITY TANKS

W. C. Carlos, W. F. Brehm, A. P. Larrick  
Westinghouse Hanford Company  
P.O. Box 1970  
Richland, Washington 99352

J. R. Divine  
ChemMet, Ltd., P.C.  
P.O. Box 4068  
West Richland, Washington, 99352

### ABSTRACT

*The Multi-Function Waste Tank Facility carbon steel tanks will contain mixer pumps that circulate the waste. On the basis of flow characteristics of the system and data from the literature, an erosion allowance of 0.075 mm/y (3 mil/year) was recommended for the tank bottoms, in addition to the 0.025 mm/y (1 mil/year) general corrosion allowance.*

**Keywords:** corrosion, erosion, carbon steel, MWTF, double-shell tank, DST, pump, corrosion allowance.

### INTRODUCTION

The U.S. Department of Energy (DOE) Hanford Site near Richland, Washington is planning the construction of six 1.1-million gallon (4163 m<sup>3</sup>) carbon steel high-level radioactive waste double-shell storage tanks (DSTs), called the Multi-Function Waste Tank Facility (MWTF) project<sup>(1)</sup>.

### BACKGROUND

The waste will be continuously mixed with a mixing pump. The requirements for the mixing system were based on what was deemed necessary for effective waste transfer and storage. The mixing requires two 150-hp (112-kw) pumps to be installed and 90% homogeneity in waste density established<sup>(2)(3)</sup>. Planned operation is to operate one of these pumps at a time. Also, as the pumps are variable speed pumps, the majority of operation will most likely be less than at maximum speed. Figure 1 shows the jet pump flow pattern in the tank.

SA 516 carbon steel has been selected as the material of construction for the MWTF tanks. Carbon steel tanks have been used successfully for many years to store high-level radioactive wastes both at Hanford and at other U.S. Department of Energy (DOE) sites. Compatibility of the nitrate wastes with carbon steel is assured by inhibiting the wastes with sodium hydroxide to a pH above 12. Above a pH of 10, a passive film forms on the surfaces of exposed carbon steel, prevents stress corrosion cracking, and controls the corrosion rates to values below 1.0 mil/year (0.025 mm/y)<sup>(4)(5)</sup>. This passive film, which is a corrosion product layer, is responsible for the low corrosion rates of carbon steel observed in double-shell tank (DST) waste. Disturbing or removing this layer results in substantial increases in the corrosion rates of the carbon steel surfaces. This passive layer tenaciously adheres to the carbon steel surface.

The mixing pumps in the MWTF tanks will produce flows, currents, and/or eddies on the bottom of the tank that will probably remove the passive layer or will increase the rate of transport of chemical species to or away from the metal surface and increase the corrosion rate<sup>(6)</sup>. Removal of the passive layer or increasing specie transport by the action of the flowing waste is called erosion-corrosion. Because removal of the passive layer by the mixing pumps cannot be prevented, an erosion-corrosion allowance will be considered to be added to the ASME design requirements for minimum wall thickness of the tank. This erosion allowance is in addition to the 1 mil/year (0.025 mm/y) general corrosion allowance added to the design requirements for minimum tank wall thickness.

### EVALUATION

A review of Corrosion Abstracts, the on-line databases at the Pacific Northwest Laboratory (PNL) library, and various DOE reports was performed. The abstracts provided no hard data. The on-line search similarly did not provide significant additional information. The DOE reports noted were more informative.

A brief summary of the abstracted and on-line information is:

As anticipated, the erosion rates are a function of the hardness and roughness of the abrasive, its particle size, velocity, corrosiveness of the solution, and the type of inhibitors<sup>(7)</sup>. It also has been noted however, that there appears to be critical velocity above which inhibitors lose their effectiveness<sup>(8)</sup>. Though the actual value of the critical velocity is not known, it is estimated to be about 65 fps (20 m/s), which is approximately the maximum tested in Smith and Elmore's work<sup>(9)</sup>.

Coatings are also effective<sup>(10)(11)</sup>. The presence of additional silicon may also be useful in some alloy compositions<sup>(12)</sup>. Davis, in his lecture notes<sup>(13)</sup>, points out that having as little as 0.2% chromium (Cr) in a mild steel reduces the wear rate by about 80%. (Note that A-537 carbon steel can have a maximum of 0.25% Cr [heat analysis or 0.29% by product analysis] whereas A-516 has no specified amount. If ASTM A 20 is applied, then the Cr content of A-516 can be specified at a maximum of 0.30%, heat analysis, or 0.34%, product analysis.) He also notes that the erosion rate is nearly directly proportional to the fluid flow rate.

In liquid systems it has been found that the maximum erosion occurs at impact angles of 40° and 90°<sup>(14)</sup>.

Blackburn<sup>(15)</sup> suggested the maximum erosion rate in the Hanford grout system should be considered to be about 20 to 40 mil/year (0.5 to 1.0 mm/y) rather than the 1 to 4 mil/year (0.1 mm/y) observed by Smith & Elmore in their study<sup>(9)</sup>. The rationale for the higher rates is that the grout is more abrasive than the NCAW and the NCRW slurries Smith & Elmore studied. They noted that erosion-corrosion rates of 3 to 4 mil/year (0.075 to 0.1 mm/y) were observed at jet velocities of about 15 fps (4.6 m/s).

Zapp at the Savannah River Site (SRS)<sup>(16)</sup> notes that erosion-corrosion rates as high as about 800 mil/year (0.8 in./y or 20 mm/y) have been observed in uninhibited coal and sand slurries. The addition of inhibitors reduced these rates to approximately 20 mil/year (0.5 mm/y). He also references work that states sand slurries have a critical velocity of 3 to 8 fps (0.1 to 2.4 m/s) above which erosion increases. Zapp concluded that for SRS purposes, even Smith & Elmore's data were high and that SRS could expect erosion-corrosion rates of less than 1 mil/year (0.025 mm/y).

Roco and Cader<sup>(17)</sup>, after reviewing slurry pipeline data and performing laboratory testing and modeling, reported on the effects of velocity ( $V$ ), particle size ( $d_p$ ), and particle concentration ( $C_p$ ). They note that the erosion rate varies:

In proportion to  $V^n$  where  $n = 0.73$  to  $<1.70$ ; the value of  $n$  cannot be easily predicted because it is a function of the flow pattern and the various wear mechanisms,

In proportion to  $d_p^m$  where  $m \approx 0.875$ , and

Linearly with  $C_p$  in the range of 5 to 35% solids.

They also noted that in phosphate slurry pipelines with a velocity of about 5.2 m/s (17 fps) an average particle size of 0.5 mm, and a concentration of 13%, the erosion rate was about 1.32  $\mu\text{m}/\text{h}$  (455 mil/year [11.8 mm/y]). There was no discussion about the effect of inhibitors.

In discussions with T. R. Beaver<sup>(3)</sup>, it was determined that the present plans for the pumps provide for nozzle velocities of up to 100 fps (30.5 m/s). At closest approach of about 25 ft (7.6 m) (the pump will be offset 13 ft (4 m) from the center), the impingement flow rate is estimated at approximately 2 to 4 fps (0.6 to 1.2 m/s) at a maximum, a value that is negligible compared to the maximum in Smith & Elmore's work. However, at a distance of about 4 ft (1.2 m) from the nozzle<sup>(3)</sup>, the jet stream is expected to intercept the bottom of the tank. At those distances, a maximum velocity of about 25 fps (7.6 m/s) adjacent to the bottom could be expected. This will be "parallel" to the bottom though and not direct impingement as in Smith & Elmore's work. However, at the location where the jet actually attaches itself to the bottom, there may be fluctuations that approximate direct impingement.

Waters<sup>(18)</sup> confirmed that the velocities used by Smith & Elmore still encompass the expected velocity profile in the proposed MWTF. Further, Waters alleviated a concern that sand could be a problem if it was present in the bottom of the tanks. He said that if sand is present, and it is likely to be, it will be blown away from the region of the pump and nozzles and not be entrained by the flow. Hence, except for a possible short period at start-up, the slurry should consist only of waste that, as shown by Smith & Elmore, is not highly abrasive.

### CONCLUSIONS

Based on the evaluation of the literature, laboratory testing, and past experience the MWTF tanks require a corrosion-erosion allowance on the tank bottom to maintain the required ASME minimum wall thickness during its 50 year design service life.

### RECOMMENDATIONS

The following recommendations are presented to address the erosion-corrosion concerns in the MWTF tanks.

- Inside the MWTF tanks on the bottom, a 3 mil/year (0.075 mm/y) erosion-corrosion allowance should be added to the 1 mil/year (0.025 mm/y) general corrosion allowance which is added to the minimum wall thickness calculations from the design. Thus a 4 mil/year (0.1 mm/y [0.2 in. or 9 mm]) total thickness for the 50-year design life) is required to be added on the bottom of the tank to the minimum wall thickness resulting from the analysis performed to the requirements of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section III, Division 1, NC-3900<sup>(19)</sup>.

OR

Inside the MWTF tank, on the bottom over a radius of 15 ft (4.6 m) centered under each mixer pump, 3 mil/year (0.075 mm/y [0.15 in. or 6.8 mm]) total thickness for the 50-year design life) of carbon steel erosion-corrosion allowance should be added to that required by the ASME design calculations for minimum wall thickness and general corrosion allowance.

- No erosion-corrosion allowances are required for the MWTF tank walls.
- A supplemental purchase requirement to specify chromium levels between 0.20% and the maximum allowed by the ASME SA 516 specification is recommended in order to obtain maximum erosion-corrosion resistance.


### REFERENCES

1. B. D. Groth, *Functional Design Criteria, Multi-Function Waste Tank Facility Project W-236*, WHC-SD-W236A-FDC-001, Rev. 1, Westinghouse Hanford Company, Richland, Washington, 1993.
2. B. D. Groth, *Memo to File/Position Paper on Project W236A - Tank Heat Loading*, Rev. 1, Westinghouse Hanford Company, Richland, Washington, 1994.
3. T. R. Beaver, S. C. Chang, *Multi-Function Waste Tank Facility Sub-scale Mixing*


- Report, WHC-SD-W236A-ER-005, Westinghouse Hanford Company, Richland, Washington, 1994.
4. N. W. Kirch, *Technical Basis for Waste Tank Corrosion Specifications*, WHC-SD-WM-TI-150, Westinghouse Hanford Company, Richland, Washington, 1984.
  5. J. R. Divine et al., *Prediction Equations for Corrosion Rates of A-537 and A-516 Steels in Double-Shell Slurry, Future PUREX and Hanford Facilities Wastes*, Pacific Northwest Laboratory, Richland, Washington, 1985.
  6. M. R. Elmore, C. L. Trow, *Erosion-Corrosion of Tanks During Solid Waste Retrieval*, PNL-SA-17300, Pacific Northwest Laboratory, Richland, Washington, 1990.
  7. G. R. Hoey and others, *Test Installation for Studying Erosion-Corrosion of Metals for Coal Washing Plants*, Ottawa, Canada, 1979.
  8. G. V. Balashov and others, *Effectiveness of Anodic Corrosion Inhibitors in Corrosion-Erosion Wear of Carbon Steel*, Volume 18, No. 3, pg 371-373, 1982.
  9. H. D. Smith, M. R. Elmore, *Corrosion Studies of Carbon Steel Under Impinging Jets of Simulated Slurries of Neutralized Current Acid Waste (NCAW) and Neutralized Cladding Removal Waste (NCRW)*, PNL-7816, Pacific Northwest Laboratory, Richland, Washington, 1992.
  10. G. H. Kock, J. A. Beavers, *Corrosion/Erosion Laboratory and Field Testing*, Battelle Columbus, Columbus, Ohio, 1981.
  11. H. Johns, *Erosion Studies of Pipelining Materials - Fifth Progress Report*, Bureau of Reclamation, Denver, Colorado, 1984.
  12. B. Q. Wang, G. Q. Geng, A. V. Levy, W. Mack, "The Erosion-Corrosion of Additional Silicon, Low Alloy Steel," *Corrosion 90/293*, NACE, Houston, Texas, 1990.
  13. R. B. Davis, *Erosion-Corrosion of Nuclear Plant Materials*, Richland, Washington, 1990.
  14. A. V. Levy, L. Ka-Keung, J. A. Humphrey, *Erosion Wear of Ductile Metals by a Particle-Laden High Velocity Liquid Jet*, Lawrence Berkeley Laboratory, University of California, Berkeley, California, *Wear*, Volume 73, No.2, pp. 295-309, November 1981.
  15. L. D. Blackburn to S. H. Rifaey, Internal Memo, "Erosion-Corrosion in Grout Distribution Pipeline," Westinghouse Hanford Company, Richland, Washington, January 18, 1991.
  16. P. E. Zapp, *Potential for Erosion Corrosion in SRS High Level Waste Tanks*, WSRC-TR-93-595, Westinghouse Savannah River Company, Aiken, South Carolina, 1993.

17. M. C. Roco, T. Cader, *Numerical Method to Predict Wear Distribution in Slurry Pipelines*, Paper 8 in "Advances in Pipeline Protection," G. Jones and J. Thorn, Gulf Publishing Co., Houston, Texas, 1988.
18. E. D. Waters and J. R. Divine, Westinghouse Hanford Company, Telephone discussion on "Expected Flow Behavior in the MWTF," March 1994.
19. ASME 1992, American Society of Mechanical Engineers, Boiler & Pressure Vessel Code, Section III, New York, New York, 1992.

Figure 1. MWTF Tank Flow Pattern Jet Velocity



# Figure 2. MWTF Tank Plate Sizes



Wall thicknesses include:

0.050 inch (0.13 cm) (0.001inch/year (0.025 mm/yr)) general corrosion allowance around entire tank interior.

0.150 inch (0.38 cm) (0.003 inch/year(0.075 mm/yr)) erosion - corrosion allowance on tank bottom.

Date Received by IRA

9/30/94/RS

# INFORMATION RELEASE REQUEST - (Long Form)

(GRAY SHADED AREAS NOT TO BE FILLED IN BY INITIATOR)

## 1. COMPLETE THIS SECTION FOR ALL DOCUMENTS

**RECEIVED**  
NOV 18 1994

A. Information Category

Speech or Presentation

Full Paper       Journal Article

Summary       Multimedia Presentation

Abstract       Software

Visual Aid

Other \_\_\_\_\_

B. Document ID Number (include rev., vol., etc.)

WHC-SA-2539-FP

C. List attachments (i.e., copyright permission, copyright transfer)

**OSTI**  
INFORMATION

D. Document Title

Recommendations for Erosion-Corrosion Allowance for Multi-Function Waste Tank Facility Tanks

E. WHC Project or Program

MWTF

F. New or novel (patentable) subject matter?  
If "Yes", has disclosure been submitted by WHC?  No or Yes

No or Yes    If "Yes", Disclosure No(s): \_\_\_\_\_

G. Information received from others in confidence, such as proprietary data, and/or inventions?  
 No or Yes    If "Yes", contact WHC General Counsel.

H. Copyrights?  No or Yes    If "Yes", attach permission.

I. Trademarks?  No or Yes    If "Yes", identify in document.

## 2. COMPLETE THIS SECTION FOR ALL DOCUMENTS REQUIRING SUBMISSION TO OSTI

A. Unclassified Category      UC - 604

B. Budget & Reporting Code      B&R - 39EW31301

## 3. COMPLETE THIS SECTION ONLY FOR A JOURNAL SUBMISSION

A. Title of Journal

## 4. COMPLETE THIS SECTION ONLY FOR A SPEECH OR PRESENTATION

A. Title for Conference or Meeting  
NACE CORROSION/95

B. Group or Society Sponsoring  
National Association of Corrosion Engineers

C. Date(s) of Conference or Meeting  
03/26-31/95

D. City/State  
Orlando, Florida

E. Will material be published in proceedings?  No or Yes  
Will material be handed out?  No or Yes

## 5. REVIEWS


Reviewers	Yes	Signature indicates Approval as Requested unless otherwise indicated Name (print)	Signature/Date	Limited-Use Info.
General Counsel	<input checked="" type="checkbox"/>	S.W. Berghin	<i>[Signature]</i> 10/6/94	<input type="checkbox"/>
DOE-RL	<input checked="" type="checkbox"/>	G. R. Konzek	<i>[Signature]</i>	<input type="checkbox"/>
Communications	<input checked="" type="checkbox"/>	W.P. Whiting	<i>[Signature]</i> 10-5-94	<input type="checkbox"/>
Applied Technology-Export Controlled Information or International Program	<input type="checkbox"/>			<input type="checkbox"/>
Other	<input type="checkbox"/>			<input type="checkbox"/>
Other	<input type="checkbox"/>			<input type="checkbox"/>

6. Applied Technology Material Referenced  
 No       Yes

**INFORMATION RELEASE ADMINISTRATION APPROVAL**  
IRA Approval is required before release. Release is contingent upon resolution of mandatory comments. NOTE: This block for IRA use only.

7. Release Level  
 Public       Limited Distribution

8. Author/Requestor  
*[Signature]* 9/20/94  
W. C. Carlos  
(Print and Sign)      Date



9. Responsible Manager  
*[Signature]* 10/27/94  
W. F. Brehm  
(Print and Sign)      Date

Date Cancelled      Date Disapproved

