



## COMMISSIONING TEST RESULTS

FOR


## D-ZERO'S HELIUM REFRIGERATOR

D-ZERO ENGINEERING NOTE # 3823.115 - EN - 457

June 30, 1997

Russ Rucinski  
PPD/ETT/D-Zero Mechanical

Approved:

  
Head PPD/ETT/D-Zero Mechanical group

## TEST OBJECTIVES

1. Make liquid helium and measure refrigerator capacity.
2. Measure liquid helium dewar heat leak, transfer line heat leak, and liquid nitrogen consumption rates.
3. Operate all cryogenic transfer lines.
4. Get some running time on all components.
5. Debug mechanical components, instrumentation, DMACs user interface, tune loops, and otherwise shake out any problems.
6. Get some operating time in to get familiar with system behavior.
7. Revise and/or improve operating procedures to actual practice.
8. Identify areas for future improvement.

## SUMMARY OF RESULTS

D-Zero's stand alone helium refrigerator (STAR) liquified helium at a rate of 114 L/hr. This is consistent with other STAR installations. Refrigeration capacity was not measured due to lack of a calibrated heat load.

Measured heat leaks were within design values. The helium dewar loss was measured at 2 to 4 watts or 9% per day, the solenoid and VLPC helium transfer lines had a heat leak of about 20 watts each. The liquid nitrogen consumption rates of the mobile purifier, STAR, and LN2 subcooler were measured at 20 gph, 20 to 64 gph, and 3 gph respectively.

All cryogenic transfer lines including the solenoid and visible light photon counter (VLPC) transfer lines were cooled to their cryogenic operating temperatures. This included independent cooling of nitrogen shields and liquid helium components. No major problems were observed.

The system ran quite well. Many problems were identified and corrected as they came up. Areas for improvement were noted and will be implemented in the future. The instrumentation and control system operated commendably during the test. The commissioning test run was a worthwhile and successful venture.

## DETAILS

### Cool down

The system was cooled from room temperature to liquid helium production temperatures in 34 hours.

Cool down was initiated on Monday June 9 at 10:30. Gaseous helium (GHe) flow was heat exchanged with LN2 in HTX 1, flowed through the helium dewar, west VLPC transfer line, and was returned directly to suction. For the first four hours, a secondary cool down flow on the shell side of the heat exchanger was also used. GHe flowed through the external GHe to LN2 cooldown heat exchanger, through the east VLPC transfer line and then through the shell side of the heat exchanger back to suction. By 17:00 that evening the gas

exiting the LHe dewar was down to 140 Kelvin (TR-4054-H, TR-4056-H). The expansion engines were started at 8:00 the next day. Liquid began to accumulate in the bottom of the LHe dewar at 20:00. That evening, liquid was added to the dewar at a rate of 113 liquid liters per hour.

### STAR performance

A generic STAR performance curve exists that describes the nominal capacity in terms of liquification (L/hr) rate and refrigeration (watts). See the figure numbered 7.3 in the appendix. The maximum liquification rate at no refrigeration load is given as 125 liters/hour. The maximum refrigeration load with no liquefaction is given as about 620 watts. During the commissioning test the liquification rate was measured. The liquification rate is defined as the rate that the STAR can change warm gaseous helium into liquid. Numerically, the liquification rate is slightly less than the rate at which liquid accumulates into the liquid helium storage dewar due to the fact that cold saturated helium is returned to the STAR at the same volumetric rate as the liquid accumulation. This lessens the rate at which room temperature gas helium is withdrawn from storage and added to the system. The returned cold saturated gas is considered a refrigeration component of the capacity. At the time of the test run, the dewar heater which we could have used for a refrigeration test, was not ready.

	Data used	Liquification + Refrig.
Very first time	6/11 0:00 thru 8:00	89.3 L/hr + 13.6 watts
Optimized	6/18 14:20 thru 14:50	113.8 L/hr + 17.3 watts
<i>For comparison:</i>	<i>ideal, <math>mdot = 58 \text{ g/s}</math></i>	<i>122 L/hr + 20 watts</i>

### Heat loads, consumption rates

The heat leak of the liquid helium storage dewar was calculated using the boil-off rate of the liquid in the dewar while the dewar pressure was held steady. The refrigerator did not add any inventory to the dewar during the test. The wet expansion engine was off, EVXJT was closed and valve EVXBY was open. The measured heat load was very close to what was expected. The design calculations considering the transfer lines and GHe conduction down the neck was 1.8 watts. The dewar itself was specified to be less than 0.5 %/day.

Dewar level	Time period	Boil-off rate = Watts = % per day
1047 to 1017 liters	6.5 hours, 6/13	4.62 L/hr = 2.1 w = 10.8 %/day
1913 to 1853 liters	9 hours, 6/18	6.67 L/hr = 3.9 watts = 8.5 %/day
<i>For comparison:</i>	<i>Conduction in neck</i>	<i>1.8 watts</i>

The transfer line heat leak of the VLPC and solenoid helium transfer lines was calculated. The data was collected while flowing He through the lines along with LN2 cooling the radiation shields and valve stem intercepts. The method of calculation was simply multiplying the helium mass flowrate by it's change

in enthalpy inlet to outlet. Keep in mind that there is some uncertainty in the measurements and interpretation of the measurements.

The VLPC line measured was the 'east' supply and return piping. The 'west' piping was cold but stagnant. The mass flow rate through the VLPC line was obtained from the flow venturi, FT-4052-H. The inlet state of the fluid was saturated liquid helium as it was drawn from the bottom of liquid helium storage dewar. The exit state was vapor at an average temperature of 15.5 Kelvin measured by the Cernox temperature sensor TR-4056-H. The VLPC 'east' line heat load was measured to be 21.4 watts.

The mass flow rate for the solenoid transfer line had to be calculated from the LHe dewar level drop. The inlet state was saturated liquid and the outlet state was determined from Cernox temperature sensor TR-3007-H in the solenoid valve box. By this method, the solenoid heat load was measured to be 39 watts.

Line	Measured	Comparison, expected
VLPC 'east'	21.4 watts	20 watts
Solenoid	39 watts	18 watts

The liquid nitrogen consumption rates of the mobile purifier and STAR were measured from data for the liquid level in LN2 dewar 39. The subcooler consumption was very small and was calculated from thermodynamic considerations.

Component	Consumption rate	Expected, from EN-421
Mobile purifier	20 gph LN2	35 gph
STAR, liquification mode	20 to 64 gph LN2	10 gph refriger. mode
Subcooler	small	1 to 3 gph LN2

### Transfer line tests

The VLPC transfer lines were used quite a bit during the commissioning test because of their versatility. The valving allowed the helium lines to be supplied from either the GHe cooldown heat exchanger or from the liquid helium dewar. The return flow can be sent back to the shell side of the heat exchanger or bypassed to the suction header through the cooldown return line. The VLPC helium line experienced all combinations of the 'east' helium piping, 'west' helium piping and nitrogen piping, in the cold (80K or below) and warm states. The vacuum jacket pressure was checked and remained about the same before and after the commissioning run. No temperature depression was observed at the tee to the assembly hall feed can or elsewhere on the line. One problem that was discovered was a leak at the TR-4101-H electrical connector on the west end feed can. The couple inch area at the connector frosted up overnight. Cold snoop indicated a leak. The area was warmed up with a heat gun and the leak went away without even tightening the connector flange screws. A couple of times during the commissioning test, liquid helium was dumped from the dewar to suction through the VLPC line. It

took about 40 minutes for the line to get cold, after which liquid could be dumped at 400 liters/hour. The dumping rate was high enough to heavily frost the suction header all the way to the DA compressor building (50 feet) during a warm sunny day.

The solenoid transfer helium line was cooled with and without flow through the nitrogen shield. Also the nitrogen shield was cooled with the helium system warm. No problems with vacuum or cold spots on the vacuum jacket were observed.

Important things learned:

1. If you don't want the Mycom fully loaded, you should leave it in automatic and then lock the minimum and maximum valve position settings to the amount of loading. If you put it in manual at a fixed position, it will slowly drift up. The hydraulics leak causing the valve position to change. When in manual mode there is no feed back to correct for this. For instance if you put it in manual at 50%, it may drift up to 90% in 24 hours. Future operators need to know this.
2. We can conveniently take gas from the TEV header using the EVCL control loop controlled through ACNET. The loop is on ACNET page "F8", House "DA", loop 10. D-Zero obtained approval from the Beams division (Jay Theilacker) and central helium liquifier (CHL, x 4191 ) prior to doing this.
3. Valve EVXJT leaks through slightly when closed. It was zeroed, but still leaks enough such that if the heat exchanger is at operating pressures, 265 psig and EVXBY is closed, and the wet expansion engine is off, the gas will leak past EVXJT and into the LHe dewar. This will cause the LHe dewar to experience higher than necessary boil-off rate. The solution is to open EVXBY when in such an operating state.
4. The LN2 subcooler/ GHe heat exchanger fill valve, PV-2713-N leaks a little bit even after zeroing. This is only a problem if there is no load on the subcooler. It can cause the subcooler to overfill, which is indicated by about 13.1" on LI-2726-N. At this level, any excess liquid nitrogen will go out the vent line and soon vaporize. The top plate of the subcooler will also become cold enough to condense water and drip.
5. A large 8" butterfly valve, MV-491-H, which isolates D-Zero from the TEV suction header leaks through a little. [Actually at the start of our run the valve was discovered to be a half notch from fully closed. We lost about half a tube trailer to the TEV before finding the problem.] Even in the fully closed position is suspected that some leakage occurs if D-Zero's system pressure is much different than the TEV's. The TEV was operating around 1.4 psig, so we put our operating suction pressure just below it so we didn't lose inventory.
6. Acnet is pretty awkward to use. We learned that since our training lesson one now needs to first go to the 'Utilities' page and 'enable' the console before Acnet will allow changes. It takes some practice to get the right sequencing of entering data and clicking in the proper spots to get Acnet to do what you want.

7. We discovered that the wet expansion engine we have is one of the few ones at the lab that does not have it's pressure transducer ports moved to a less vulnerable (to grease clogging) location. It is noted that modified engines have bolted on lids. Ours is still the welded lid variety.

8. The suction header main relief valve (2" x 3" AGCO series 93) originally leaked under vacuum. A check valve on the pilot sensing line alleviated that problem. A tee and valve was also added to allow us to remotely apply pressure to the pilot. It was then discovered that the main valve leaked when in service at inlet pressures under 1 psig. It was bench tested and confirmed to leak below 0.9 psig. The main valve seat o-ring looked fine but was replaced. The valve then leaked below 0.4 psig. The manufacturer could not offer an explanation of the leaks and suggested providing 2 to 3 psig of source gas to the pilot dome through the remote sensing line. That extra pressure in the dome would increase the sealing force on the main valve's o-ring. The final solution to the problem was to add a light spring in the dome of the main valve. Calculations were done to assure the spring did not defeat the valve. It was field tested in place and was found to relieve at 6.3 psig.

### Improvements to be made

1. The most serious improvement that needs to be made is the re-routing of the heat exchanger's gaseous nitrogen exhaust line to a less restrictive vent path. The current configuration was an oversight on my part. It can be changed without much effort. The problem was discovered by observations that the LN2 supply pressure downstream of the heat exchanger's control valve got quite high. I saw it up to 30 psig at times (PT-2708-N). The exiting vent line from the heat exchanger is a non-vacuum jacketed 1 1/2" pipe size. The mistake was to reduce this into a 1/2" pipe size and combine it with the nitrogen return flow from the solenoid and VLPC transfer lines. The combined flow must pass through an equivalent of about 40 feet of 1/2" pipe before it is expanded back to 1 1/2" pipe size. At a maximum flow of 70 gph from the heat exchanger, this section of pipe is calculated to develop 14 psid. The solution is to cut and then extend the 1 1/2" non-vacuum jacketed piping about 30 feet and tee it into the existing 1" pipe size non-vacuum jacketed vent tie in. The 1" pipe size flow path is a few feet long at which point it expands to 1 1/2" inside the vacuum jacketed vent.
2. The line leading to the pressure transducer on the wet expansion engine is clogged. It is the cylinder on the east side. It needs to be blown out or in by the engine group.
3. The intake VPT on the dry expansion engine has a leak in it. The external tubing was leak checked before the commissioning test and no leaks were found. It was bled down to atmosphere before the test began.
4. The pressure transducers for the hydrogen VPT's need to be changed out to the absolute type. The VPT's give useful temperature indications at less than gage pressure. The transmitters that were originally installed were 0 to 100 psig.
5. The arc cell sampling line from the LHe storage dewar seems to have a contamination problem. The arc cell reading which should be negligible,

reads high, on the order of 40 ppm N2. The reading drops if the flow rate through the sample line is increased using the purge line that is in parallel with the analyzer to take the excess flow.

6. Many of the threaded piping connections on the tube trailer fill station leak and need to be re-made with epoxy. On this panel only, many of the threaded connections were made up with a red colored hydraulic fitting type sealant. At the time of make up the joints that leaked (detected with snoop) were re-made and tested tight. Over time, and with pressure, snoop detectable leaks have been discovered. The quantity of sealant also appears to be less than what was originally installed.

7. It is very easy to frost up the warm helium and nitrogen exhaust piping on the heat exchanger. The drip trays under these pipes don't extend far enough to catch all the condensing/melting water. The water from these pipes can fall on several flow transmitters, D0FSTOR, FT-2040-H, D0FX1HP. These transmitters stopped working when they got wet. They probably need to be sent back to Hastings for repair.

8. I would like to add Cernox temperature sensors to u-tubes of the dry and wet expansion engines. The temperature indications from the VPT's are questionable. This addition will allow us to better understand how the engines are operating. By observing these temperatures during a long operating run, we will be able to foresee engine problems before they get obvious.

9. I would like to add a platinum temperature sensor in the nitrogen return vent line. a convenient place will be where the heat exchanger vent currently ties into the vent. This location is a low spot, trap so to speak that will accumulate liquid should the nitrogen control be poor. The information from this sensor will be useful in conjunction with the temperature control points on the solenoid and VLPC systems.

10. We have plans to put a heater in the liquid helium storage dewar. This has many benefits. It will give an easy way to keep the refrigerator in a steady state operating mode under changes in liquification and refrigeration requirements. It will also give an indication of our refrigerator's excess capacity in the form of power draw of the heater. A notable decrease in the heater power could indicate a developing problem with the refrigerator during a long operating run.

11. Ideally D-Zero would like to have a dedicated helium purifier. If this is not realized, D-Zero can share the existing RD/Cryo mobile purifier with CDF, and beamlines. The documentation for either purifier (flow schematic, procedures) needs to be gathered and kept at D-Zero.

## • REFRIGERATION & LIQUIFICATION TEST:

1<sup>st</sup> DEWAR FILL: 6/10 → 6/11 6/11/97 0:00 300 LITERS  
6/11/97 08:00 1200 LITERS

$$P_{DEW} = 6.2 \text{ PSIG} = 0.144 \text{ MPa}$$

$$\Delta V_{\text{LIQUID}} = 112.50 \frac{\text{LITERS}}{\text{HR.}}$$

$$\rho_{liq} = 116.8 \text{ kg/m}^3 \quad \rho_{gas} = 24.09 \text{ kg/m}^3$$

$$\dot{m}_{\substack{\text{VAPOR} \\ \text{RETURNED} \\ \text{TO } HX}} = 24.09 \frac{\text{kg}}{\text{m}^3} \left( 112.5 \frac{\text{LITERS}}{\text{HR}} \right) \left( \frac{1 \text{ m}^3}{1000 \text{ L}} \right) \left( \frac{1000 \text{ g}}{1 \text{ kg}} \right) \left( \frac{\text{HR}}{3600} \right)$$

$$= 0.75281 \frac{\text{g/s}}{\substack{\text{WET INLET} \\ \text{VAPOR}}}$$

$$M_1 = \left[ (300 \text{ liters}) (116.8 \frac{\text{kg}}{\text{m}^3}) + (3000 \text{ liters}) (24.09 \frac{\text{kg}}{\text{m}^3}) \right] \left[ \frac{1 \text{ m}^3}{1000 \text{ L}} \right] = 107.310 \text{ kg}$$

$$M_2 = \left[ (1200)(116.8) + (2100)(24.09 \frac{\text{kg}}{\text{m}^2}) \left( \frac{1}{1000} \right) \right] = 190.749 \text{ kg}$$

$$\dot{M}_{\text{TOTAL}} = \frac{190.749 \text{ kg} - 107.310 \text{ kg}}{(8 \text{ min})(3600 \text{ s/min})} \times \frac{1000 \text{ g}}{1 \text{ kg}} = 2.89719 \frac{\text{g}}{\text{s}} \quad - \text{RATE OF MASS DEPLETION}$$

$$\dot{m}_{\text{LIQUID}_{\text{NET}}} = (112.5 \frac{\text{L}}{\text{min}}) \left( 116.3 \frac{\text{kg}}{\text{m}^3} \right) \left( \frac{1 \text{m}^3}{1000 \text{L}} \right) \left( \frac{1000 \text{g}}{1 \text{kg}} \right) \left( \frac{1 \text{Hz}}{3600 \text{s}} \right) = 3.65 \frac{\text{g}}{\text{s}}$$

$$m_{in} = ? \text{ (9.0 K, 500 RPM)} \quad x_{out} = .86 \text{ FDRM chamber}$$

## REFRIGERATION

$$Q = m \Delta h_{fg}^{\text{VAPOR RETURN}}$$

$$Q = (-.75281 \frac{9}{10}) (30.28 - 12.2 \frac{3}{9})$$

$$Q = 13.61 \text{ WATTS}$$

## TRUE UNIFICATION :

$$R = \left( 2.89719 \frac{g}{s} \right) \left( \frac{1}{116.8 \frac{kg}{m^3}} \right) \left( \frac{1 kg}{1000g} \right) \left( \frac{1000 L}{1 m^3} \right) \left( \frac{3600 s}{hr} \right)$$

$$R = 89.30 \text{ L}_{\text{H}_2\text{O}}$$

DATA PT. = 89.30  $\frac{L}{hr}$  + 13.6 WATTS.

$$X_{\text{WET OUT}} = \frac{m_3}{m_{\text{TOTAL}}} = \frac{0.75281 \frac{g}{s} - 0.14026 \frac{g}{s}}{3.650 \frac{g}{s}} = 0.16782$$

↑ FROM DEWAR, MT. LEAK

LHe MAKE RATE #2

6/18/97 14:20:00

LHe DEWAR LEVEL = 2148.7

\* WET ENGINE INLET TEMP = 9.1 K , 550 RPM

\* DRY ENGINE INLET = 35 K , 1400 RPM

\* DRY OUT = 23 K

14:49:00

2218 LIQUID LITERS

\* LHe DEWAR PRESSURE = 5.5 PSIG

\* DISCHARGE PRESSURE = 265 EXIT 3 MP.

\* CONSTANT .

$$\frac{\Delta V}{t} = \frac{69.3 \text{ L}}{29 \text{ MIN}} \times \frac{60 \text{ min}}{1 \text{ HR}} = 143.38 \text{ L/HR}$$

$$P = 0.14 \text{ MPa} , T_{SAT} = 4.584 \text{ K}$$

$$S_1 = 116.8 \frac{\text{kg}}{\text{m}^3} \quad \rho_v = 24.09 \frac{\text{kg}}{\text{m}^3}$$

$$M_1 = \left[ (2148.7 \text{ LITERS}) \left( 116.8 \frac{\text{kg}}{\text{m}^3} \right) + (1151.3 \text{ LITERS}) \left( 24.09 \frac{\text{kg}}{\text{m}^3} \right) \right] \left[ \frac{1 \text{ m}^3}{1000 \text{ L}} \right]$$

$$M_1 = 278.703 \text{ kg}$$

$$M_2 = \left[ (2218 \text{ LITERS}) (116.8) + (1082) (24.09) \right] \left[ \frac{1}{1000} \right] = 285.128 \text{ kg}$$

$$\dot{M}_{TOTAL} = \frac{285.128 \text{ kg} - 278.703 \text{ kg}}{(29 \text{ MIN}) \frac{60 \text{ s}}{\text{MIN}}} \times \frac{1000 \text{ g}}{\text{kg}} = 3.6924 \frac{\text{g}}{\text{s}}$$

LIQUIFICATION :

$$R = 3.6924 \frac{\text{g}}{\text{s}} \left( \frac{1}{116.8 \frac{\text{kg}}{\text{m}^3}} \right) \left( \frac{1 \text{ kg}}{1000 \text{ g}} \right) \left( \frac{1000 \text{ L}}{1 \text{ m}^3} \right) \left( \frac{3600 \text{ s}}{1 \text{ HR}} \right)$$

$$R = 113.8 \text{ L/HR}$$

REFRIGERATION :

$$\dot{m}_{RETURNED} = 24.09 \frac{\text{kg}}{\text{m}^3} (143.38 \frac{\text{L}}{\text{HR}}) \left( \frac{1 \text{ m}^3}{1000 \text{ L}} \right) \left( \frac{1000 \text{ s}}{1 \text{ HR}} \right) \frac{1 \text{ HR}}{3600 \text{ s}}$$

$$\dot{m}_{RETURNED} = 0.95945 \frac{\text{g}}{\text{s}} + \dot{m}_{VAPOR} \frac{\text{WET OUT}}$$


$$Q = \dot{m}_{RETURNED} \Delta h_{fg} = 0.95945 \frac{\text{g}}{\text{s}} (30.28 \frac{\text{J}}{\text{g}} - 12.2 \frac{\text{J}}{\text{g}})$$

$$Q = 17.35 \text{ WATTS}$$

2:38:28 PM  
6/18/82

## D-ZERO HEAT-EXCHANGER AND LHE DEWAR

608/93



MAXIMUM LIQUIFICATION TEST 6/18/97

$$\frac{\Delta V}{dt} = 143.4 \text{ V/HR}$$

TRUE LIQUIFICATION = 113.8 L/H<sub>R</sub>

R. RUCINSKI  
6/19/97

$$28.8 \frac{L_{10} L}{hr} = 1 \frac{^{\circ}S}{s}$$

CHAF

VACU

### 8.1 Gen

An existing vacuum heat utility header purging. It nitrogen. The calorimeter of the pump

The vac at all times. Figure 8.1. pumping sp speed of 500

### 8.2 Ins

A simplified cleanup and tions would will be used layer insula vacuum heat the lowest : between the mounted lo could interi

The pri ney in the c pumping sp solenoid op calculated i pump with




Figure 7.3: Capacity of star refrigerator and (1) identified steady state heat load, (2) max. expected charging heat load

DATA FROM 6/13/97

$$P = 9.8 \text{ PSIG}$$


$$= 0.1689 \text{ MPa}$$

$$\text{USE } P = 0.17 \text{ MPa}$$

$$\Delta V_{\text{Liq.}} = \frac{1047 \text{ LITERS} - 1017 \text{ LITERS}}{6.5 \text{ HRS}}$$

$$\Delta V_{\text{Liq.}} = 4.61538 \frac{\text{LITERS}}{\text{HR}}$$

$$\text{ROUGH: } Q = m \Delta h_{fg}$$



$$V_{\text{total}} = 3300 \text{ LITERS.}$$

$$m = 4.61538 \frac{\text{LITERS}}{\text{HR}} \times 109.4 \frac{\text{kg}}{\text{m}^3} \times \frac{1 \text{ m}^3}{1000 \text{ L}} \times \frac{1000 \text{ s}}{1 \text{ kg}} \times \frac{1 \text{ HR}}{3600 \text{ s}} = 0.14026 \frac{\text{kg}}{\text{s}}$$

$$h_{fg} = h_g - h_f = 29.295 \frac{\text{J}}{\text{g}} - 14.025 \frac{\text{J}}{\text{g}} = 15.27 \frac{\text{J}}{\text{g}}$$

$$Q = (0.14026 \frac{\text{kg}}{\text{s}})(15.27 \frac{\text{J}}{\text{g}}) = \underline{2.14 \text{ W}}$$

MODEL AS FORMAL UNIFORM STATE, UNIFORM FLOW PROCESS (USUF)

$$\begin{aligned} \text{1ST LAW: } m_1 (u + \frac{v^2}{2} + gz)_1 + \sum m_i (h + \frac{v^2}{2} + gz)_i + Q_{cv} + W_{cv} &= \\ &= m_2 (u + \frac{v^2}{2} + gz)_2 + \sum m_e (h + \frac{v^2}{2} + gz)_e \end{aligned}$$

$$m_1 = V_{\text{gas}} \cdot \rho_g = (3300 \text{ LITERS}) (31.29 \frac{\text{kg}}{\text{m}^3}) \times \frac{1 \text{ m}^3}{1000 \text{ L}} = 70.4964 \text{ kg}$$

$$m_{\text{Liq.}} = (1047 \text{ LITERS}) (109.4 \frac{\text{kg}}{\text{m}^3}) \times \frac{1 \text{ m}^3}{1000 \text{ L}} = 114.5418 \text{ kg}$$

$$u_{\text{gas}} = 23.845 \frac{\text{J}}{\text{g}}$$

$$u_{\text{liq.}} = 12.47 \frac{\text{J}}{\text{g}}$$

Assumptions - NEGLECT  $v^2$  TERMS,  $z$  TERMS - SHOULD BE  
 ASSUME DEWAR MASS DOES NOT CHANGE TEMPERATURE  
 OR ENERGY CONTENT.

$$W_{cv} = 0 \rightarrow m_i = 0 \therefore m_e = m_1 - m_2$$

$$m_2 = (3300 - 1017) (31.29) \left( \frac{1}{1000} \right) = 71.43507 \text{ kg}$$

$$m_{\text{Liq.}} = (1017 \text{ LITERS}) (109.4) \left( \frac{1}{1000} \right) = 111.2598 \text{ kg}$$

$$\begin{aligned} m_e &= m_1 - m_2 = (70.4964 + 114.5418 \text{ kg}) - (71.43507 + 111.2598) \\ &= 2.3433 \text{ kg} \end{aligned}$$

SUBST. INTO 1<sup>ST</sup> LAW.

$$Q_{cv} = m_2 u_2 + \sum m_e h_e - m_1 u_1$$

$$Q_{cv} = \frac{m_2 u_2}{\text{GAS}} + \frac{m_2 u_2}{\text{LIQ.}} + m_e h_{\text{gas}} - \frac{m_1 u_1}{\text{GAS}} - \frac{m_1 u_1}{\text{LIQ.}}$$

$$\text{NOTE: } \frac{u_1}{\text{GAS}} = \frac{u_2}{\text{GAS}} \quad \frac{u_1}{\text{LIQ.}} = \frac{u_2}{\text{LIQ.}}$$

$$Q_{cv} = u_{\text{gas}} \left( \frac{m_2}{\text{gas}} - \frac{m_1}{\text{gas}} \right) + u_{\text{liq.}} \left( \frac{m_2}{\text{liq.}} - \frac{m_1}{\text{liq.}} \right) + m_e h_{\text{gas}}$$

$$Q_{cv} = \left\{ 23.845 \frac{\text{J}}{\text{g}} (71.43507 \text{ kg} - 70.4964 \text{ kg}) + 12.47 \frac{\text{J}}{\text{g}} (111.2598 - 114.5418 \text{ kg}) \right. \\ \left. + 2.3433 \text{ kg} (29.295 \frac{\text{J}}{\text{g}}) \right\} \times \frac{1000 \text{ g}}{1 \text{ kg}}$$

$$Q_{cv} = 50,103.0 \text{ JOULES}$$

$$\dot{Q} = \frac{50,103.0 \text{ JOULES}}{6.5 \text{ HRS}} \times \frac{1 \text{ HR}}{3600 \text{ S}} = \underline{2.14 \text{ WATTS}}$$

## ADDITIONAL HEAT LEAK TEST, BOIL OFF

DATA: 6/18/97 21:00 1913 LITERS  
 6/19/97 6:00 1853 LITERS

$$P = 5.5 \text{ PSIG.} \approx 0.14 \text{ MPa}$$

$$\Delta V_{\text{liq.}} = \frac{60 \text{ LITERS}}{9 \text{ HOURS}} = 6.67 \frac{\text{L}}{\text{HR.}}$$

$$\dot{m} = 6.67 \frac{\text{L}}{\text{HR}} \times 116.8 \frac{\text{kg}}{\text{m}^3} \times \frac{1 \text{ m}^3}{1000 \text{ L}} \times \frac{1000 \text{ g}}{1 \text{ kg}} \times \frac{1 \text{ HR}}{3600 \text{ S}} = 0.2164 \frac{\text{kg}}{\text{S}}$$

$$Q = \dot{m} \Delta h = (0.2164 \frac{\text{kg}}{\text{S}}) \left[ 30.28 \frac{\text{J}}{\text{g}} - 12.20 \frac{\text{J}}{\text{g}} \right]$$


$$\underline{\underline{Q = 3.913 \text{ W}}}$$

SHOULD EXPECT MORE  
 HEAT LEAK @ FULLER,  
 HIGHER LIQUID LEVEL.

% PER DAY:

$$\frac{6.67 \frac{\text{L}}{\text{HR}} \times 24 \text{ HRS}}{1883 \text{ LITERS}} \times 100 = \boxed{8.5 \%}$$

$$\frac{4.6154 \frac{\text{kg}}{\text{HRS}} \times 24}{1022 \text{ L}} \times 100 = \boxed{10.8 \%}$$



FILE CALCS  
LHe DEWAR LID DESIGN

DESIGN / R-  
LHe DEWAR HEAT  
LEAK CALCS.

R. RUCINSKI 8/28/96

(1)

LHe LID: CONDUCTION CONTRIBUTIONS

$$4 \times 1\frac{3}{8}'' \text{OD} \times .035 = 4 (.15119 \text{ in}^2) = .60476 \text{ in}^2$$

$$2 \times \frac{3}{4}'' \text{OD} \times .035 = 2 (.08247 \text{ in}^2) = .16493 \text{ in}^2$$

$$2 \times \frac{1}{2}'' \text{OD} \times .035 = 2 (.05498 \text{ in}^2) = .10996 \text{ in}^2$$

$$4 \times \frac{1}{4}'' \text{ -20 THREADED ROD} = 4 (.0318 \text{ in}^2) = .12720 \text{ in}^2$$

$$\underline{1.00685 \text{ in}^2}$$

$$\text{THREADED RODS} = \frac{.1272}{1.00685} (100) = \underline{\underline{12.6\%}}$$

$$\frac{1}{4}'' \text{OD} \times .035 \rightarrow A = .02364 \text{ in}^2$$

$$Q_{\text{conduction}} = \frac{A}{L} \int_{-4}^{300} K_{ss} dT = \frac{1.00685 \text{ in}^2}{36 \text{ in}} (3060 \frac{\text{W}}{\text{m}}) \left( \frac{.02364 \text{ in}^2}{1 \text{ in}} \right)$$

$$Q = 2.174 \text{ WATTS}$$

$$Q_{\text{NECK}} = 1.8 \text{ WATTS} @ 5K \text{ TEMP. DEPRESSION.}$$

THREADED RODS NEED TO SUPPORT SAY, 100\*'S EACH  
W/ 0 BREAKING.

$$G_u = \frac{P}{A} \quad A_{\text{REQ'D}} = \frac{-100 \text{*'S}}{80,000 \text{ psi}} = .00125 \text{ in}^2$$

$$\frac{\pi D^2}{4} = A_{\text{REQ'D}} \Rightarrow D = .0399 \text{ in.}$$

↑  
very small.

SAY 4-40 NC

$$A_{\text{STRESS}} = .0060 \text{ in}^2$$

$$G_{\text{yield}} = 35 \text{ ksi}$$

$$\underline{P_{\text{YIELD}} = 210 \text{ lbs}}$$

$$A_{\text{req'd}} = 4(-.006) = -.024 \text{ in}^2 \rightarrow 2.7\% \checkmark$$

(15)

< DESIGN >

LHe DEWAR

FINAL BAFFLE ASSY HEAT LEAK CALCS.

R. RUCINSKI 8/29/96

4

$$A_{ss} = .94325 \text{ in}^2 \quad \text{Go with only 2 in } \frac{1}{4} - 20 \text{ THREADED ROD.}$$

$$Q_{ss \text{ convection}} = \frac{.94325 \text{ in}^2}{48 \text{ in.}} (3060 \text{ W}) \left( \frac{.0254 \text{ m}}{1 \text{ in.}} \right)$$

$$= \underline{1.527 \text{ WATTS.}}$$

$$A_{GHe} = \frac{\pi (5.9 \text{ in})^2}{4} - 4 \frac{\pi (1.375 \text{ in})^2}{4} - 2 (.0318 \text{ in}^2) = 21.337 \text{ in}^2$$

$$Q_{GHe \text{ cond}} = \frac{21.337 \text{ in}^2}{48 \text{ in.}} (23 \text{ W/m}) \left( \frac{.0254 \text{ m}}{1 \text{ in.}} \right) = \underline{.26 \text{ W}}$$

$$Q_{\text{TOTAL}} = \underline{1.8 \text{ WATTS}}$$

16

$$PV-3035-N = 35\%$$

$$PV-3062-H = 25\%$$

$$PT 3006-H = 1.7 \text{ psig}$$

SOLENOID X-FER LINE,

6/19 - 6/20 RUNNING LINE @ LN<sub>2</sub>

INLET TEMP. = ~~7.5~~ K TR 3027-H 7:17 6/20

OUTLET TEMP. = ~~19~~ K.

LHe LEVEL = 737 L @ 7:17

853 L @ 0:17

$$\frac{116 \text{ L}}{7 \text{ HRS}} = 16.57 \text{ L/Hr}$$

DEWAR PRESS = 5.9 D<sub>6</sub> EVDEW CLOSED  $\approx$  1.7 HRS @ A TIME  
THEN SWING OPEN, MAX. 35.5 %

LN<sub>2</sub> USED

8:45 7831 GALLONS

3:00 7977 GALLON

8:00 7855 GALLON  $\frac{122 \text{ GALLONS}}{5 \text{ HRS}} = 24.4 \text{ GPH}$

PURIFIER ON LINE USING 20 ~ 24 GPH.

NO CONCLUSIVE DATA FOR N<sub>2</sub> HEAT LOAD.

HEAT LEAK CALC.

$$Q = m \Delta h$$

$$\dot{m}_{\text{MAX}} = 16.57 \text{ L/Hr} \times 116.8 \frac{\text{kg}}{\text{m}^3} \times \frac{1000 \text{ g}}{1 \text{ kg}} \times \frac{1 \text{ m}^3}{1000 \text{ L}} \times \frac{1 \text{ hr}}{3600 \text{ s}} = 0.5376 \frac{\text{g}}{\text{s}}$$

\* NOTE: THIS IS CONSERVATIVELY HIGH SINCE SOME OF THIS  
FLOW WENT OUT EVDEW.

$$\dot{m}_{\text{TO REPLACE LIQUID IN DEWAR}} = 16.57 \frac{\text{L}}{\text{Hr}} \times 24.09 \frac{\text{kg}}{\text{m}^3} \times \frac{1}{3600} = 0.11088 \frac{\text{g}}{\text{s}}$$

$$Q = (0.5376 - 0.11088 \frac{\text{g}}{\text{s}}) [113.10 \frac{\text{J}}{\text{g}} - 50.66 \frac{\text{J}}{\text{g}}]$$

$$Q = 26.65 \text{ WATTS} \quad * \text{MAXIMUM}$$

QUICK ESTIMATE WAS 18 WATTS

SO REASONABLE.

CONSIDERING DEWAR HEAT LEAK @ 4.6 L/Hr  $\rightarrow \dot{m}_{\text{XFER LINE}} = 12 \frac{\text{L}}{\text{Hr}} = 0.3893 \frac{\text{g}}{\text{s}}$

$$Q_{\text{EST}} = 0.3893 \frac{\text{g}}{\text{s}} [113.10 \frac{\text{J}}{\text{g}} - 50.66 \frac{\text{J}}{\text{g}}] = 24.3 \text{ WATTS}$$

→ REQ'D HEAT LOAD IN SOLENOID LHe SUPPLY  
U-TUBE HE-320-H UP TO TR3027-H?

$$m = 0.3893 \frac{\text{g}}{\text{s}}$$

$$h_{\text{INLET}} = h_{\text{DEWAR}} = 12.20 \frac{\text{J}}{\text{g}}$$

$$h_{\text{DEWAR}} = 50.66 \frac{\text{J}}{\text{g}} \\ = 7.5 \text{K}$$

$$\omega = 0.3893 \frac{\text{g}}{\text{s}} [50.66 \frac{\text{J}}{\text{g}} - 12.20 \frac{\text{J}}{\text{g}}] = 14.97 \text{ WATTS}$$


EXCESSIVE, TR3027-H MUST BE READING HIGH.

TOTAL HEAT LEAK, LHe DEWAR TO TR3007-H

$$= 24.3 + 15 \text{ W} = \boxed{\underline{\underline{39.3 \text{ WATTS}}}}$$

DISCREPANCY:

WHY WOULD D<sub>0</sub>ENDEW OPEN IF THE RATE OF LIQUID  
WITHDRAWAL EXCEEDED BOIL-OFF RATE OF  
ISOLATED DEWAR? ... DEWAR HEAT LEAK  
MUST HAVE BEEN HIGHER? ? ...



DO\_CCRS2::DO\_CCRS2:TR3007H::T.F\_CV Temperature for X03953 (TR-3007-H) RTD 16.1  
 DO\_CCRS2::DO\_CCRS2:TR3027H::T.F\_CV Temperature for X03536 (TR-3027-H) RTD 7.5  
 DO\_CCRS2::DO\_CCRS2:LHB-VOL.F\_CV LHe Dewar volume based on diff. pressure 793  
 DO\_CCRS2::DO\_CCRS2:D0EVDEW.F\_CV Helium Dewar Bypass Return Control Valve 33.4

SOLENOID HELIUM TRANSFER LINE  
HEAT LEAK TEST DATA

R. RUCINSKI  
6/30/97

VLPC EAST HE LINE, HEAT LEAK.

DATA FROM 6/18/97 0:00 -  $m = 0.26 \text{ g/s}$   
 THRU 4:00  
 STEAM STATE  $TR-4054-H = 16.0 \text{ K} \pm 4 \text{ K}$

$$\text{AVG.} = \overline{TR-4054-H} = 15.5 \text{ K} \pm 0.8 \text{ K}$$

$$P_{DEW} = 5.5 \text{ PSIG.} = 0.14 \text{ MPa}$$

$$h_f = 12.20 \text{ J/g}$$

$$T = 16.5 \quad h = 99.8 \\ T = 14.5 \quad h = 89.2$$


$$h_{out} = 94.532 \text{ J/g} \quad (T = 15.5 \text{ K}, P = 0.14 \text{ MPa})$$

$$Q = m \Delta h = [ -0.26 \text{ g/s} ] [ 94.53 - 12.20 ]$$

$$Q = \underline{\underline{21.4 \text{ WATTS}}}$$

ESTIMATED HEAT LOAD = 20 WATTS

→ IN GOOD AGREEMENT!



VLPC EAST HELIUM TRANSFER LINE

HEAT LEAK TEST DATA

R. RUCINSKI  
 6/30/97



FERMILAB

## ENGINEERING NOTE

SECTION

PROJECT

SERIAL-CATEGORY

PAGE

SUBJECT

TRANSFER LINE HEAT LOAD  
ESTIMATES

NAME

RUSS RUCINSKI

DATE

6/13/97

REVISION DATE

ESTIMATE X-FER LINE LOADS w/ w/o SHIELD.

SOLENOID X-FER LINE: 3 VALVES, 3 U-TUBES, 150 FT. X-FER LINE

w/o LN<sub>2</sub> 3 WATTS, 15 W, +5 WATTSw/ LN<sub>2</sub> 1.5 WATTS, 15 W, 1.5 WATTVLPC X-FER LINE: 3 VALVES, 3 U-TUBES, 300 FT X-FER LINE  
\* 2 LINESw/o LN<sub>2</sub> 6 WATTS, 30 WATTS, 60 WATTSw/ LN<sub>2</sub> 3 WATTS, 30 WATTS, 6 WATTS.

	w/o LN <sub>2</sub>	w/ LN <sub>2</sub>
SOL.	33 W	18 W
VLPC	96 WATTS	39 WATTS.
	129 WATTS.	57 WATTS.

INSIGNIFICANT  
HEAT LOAD.SLIP w/o LN<sub>2</sub> 3 SHIELD  
TEST.HOW MUCH LHe NEEDED w/ LN<sub>2</sub>  $\approx$  57 WATTS

80 LITER ROUGHLY

FRI, SAT., SUN, MON.

15 hrs 24 24 8  $\rightarrow$  72 hrs5746 LITERS?

LHe DEBOAR WILL GO EMPTY.

VLPC  $\sim$  28 WATTS

(22)

4 TURNS ON

$$h_{fg} = \frac{Q}{m \Delta h}$$

10 psi

$$Q = m \Delta h \quad \text{let } T_{out} = 10K$$

$$h_{fg} = 13.43 \frac{J}{g}$$

$$\text{hour} = 65.5 \frac{J}{g}$$

$$m = \frac{28 \frac{J}{g}}{65.5 - 13.43 \frac{J}{g}} = 0.54 \frac{g}{J}$$

LN<sub>2</sub> CONSUMPTION RATES

MOBILE PURIFIER ALONE: 6/11/97 17:00 4363 GALLONS  
 6/12/97 9:00 3974 GALLONS

$$\frac{389 \text{ GALLONS}}{16 \text{ HRS.}} = \boxed{24.3125 \text{ GPH}} = 0.4052 \text{ GPM}$$

PURIFIER + STAR + SUBCOOLER: 6/10/97 20:00 5166 GALLONS  
 ↳ LIQUIFICATION MODE 6/11/97 8:00 4668 GALLONS

$$\frac{498 \text{ GALLONS}}{12 \text{ HRS}} = \boxed{41.50 \text{ GPH}} = 0.6917 \text{ GPM}$$

MOBILE PURIFIER ALONE: 6/12/97 17:00 7770 GALLONS  
 6/13/97 5:00 7563 GALLONS

$$\frac{207 \text{ GALLONS}}{12 \text{ HRS}} = \boxed{17.25 \text{ GPH}} = 0.2875 \text{ GPM}$$

MOBILE PURIFIER + STAR + SUBCOOLER 6/16/97 19:30 4834 GALLONS  
 ↳ STEADY STATE LIQUIF. MODE 6/17 9:30 3548 GALLONS

NO!  
 EVX2 CLOSED TOO  
 FAR, HTX1 WORKING  
 TOO HARSH. STAR NOT IN GOOD RUNNING MODE

$$\frac{1286 \text{ GALLONS}}{14 \text{ HRS}} = \boxed{91.86 \text{ GPH}} = 1.53 \text{ GPM}$$

MOBILE PURIFIER + STAR + SUBCOOLER 6/15/97 10:00 6087 GALLONS  
 ↳ LN<sub>2</sub> TEMP. HOLDING 6/16/97 10:00 5572 GALLONS

$$\frac{515 \text{ GALLONS}}{24 \text{ HRS}} = \boxed{21.46 \text{ GPH}} = 0.3576 \text{ GPM}$$

Avg. MOBILE PURIFIER ≈ 20 GPH

SUBCOOLER ≈ 1 TO 3 GPH

STAR 20 GPH TO 64 GPH

23

FLOW RATE OF GN<sub>2</sub> &  $\Delta P$ 

$$Q \approx 20 \text{ GPH} \times \frac{93.11 \text{ SCF}}{1 \text{ GALLON LIQUID}} \times \frac{1 \text{ hr}}{60 \text{ min}} = 31.0 \text{ scfm} \text{ N}_2$$

CV-2710-N, P/N 1016 CHECK VALVE BIVCO

@ 31 scfm, AIR@70°F  $\Delta P = < 1.5$ LOWEST POINT ON CURVE,  $\Delta P = 1.5 \text{ psi}$  @ 60 scfm AIR

$$\text{SUBCOOLER PRESSURE } P1-2717-N = 3 \text{ PSI}$$

$$P2-2708-N = 11.3 \text{ PSI}$$

ESTIMATE OF SUBCOOLER FLOW;

344 SUBCOOL 30 GPH  $T_{SAT} = 34 \text{ PSIG}$

250 FT. X-FER LINE X 1.75/FT  $T = 80 \text{ K SUBCOOLED}$

25 WATTS DEWAR TO SUBCOOLER.

344 3 ATM

$T_{SAT} = 88.077 \text{ K}$

$h_f = -98.938 \text{ J/g}$

$h_g = 84.167 \text{ J/g}$

$T = 80 \text{ K}$

$h_{sc} = -115.815 \text{ J/g}$

$\dot{m} = 30 \frac{\text{GALLONS}}{\text{HR}} \times \frac{3060 \text{ g}}{\text{GALLON LIQ}} \times \frac{1 \text{ hr}}{3600 \text{ s}} = 25.5 \text{ g/s}$

$h_{in} = -98.938 \text{ J/g} + 25 \frac{1}{5} \times \left( \frac{1}{25.5 \text{ g/s}} \right) = -97.96 \text{ J/g}$

$Q_{SUBCOOL} = 25.5 \text{ g/s} \left[ -115.815 - (-97.96 \text{ J/g}) \right]$

$Q_{SUBCOOL} = -455.4 \text{ WATTS}$

$\dot{m}_{RECOOL} = \frac{455.4 \text{ J/s}}{78.415 \text{ J/g} - (-97.96)} = 2.58 \text{ g/s}$   
 $\hookrightarrow 1.2 \text{ ATM}$

$$\approx 3 \text{ gph}$$

LN<sub>2</sub> CONSUMPTION;

$$6/18/97 \quad 10:29:34 \quad 1662.1 \text{ Gallons} \quad \rightarrow \quad \frac{344.5 \text{ Gallons}}{5.5 \text{ Hrs}} \\ 15:59:13 \quad 1317.6 \text{ Gallons}$$

MAX. LIQUIF. TESTS.

$$\underline{62.6 \text{ GPH}}$$

STAR + MOBILE PURIFIER + SUBCOOLER.

$$62.6 - \cancel{20}^{\text{mobile purifier}} = \underline{42.6 \text{ GPH}} \\ - 2.6 \approx \text{SUBCOOLER} \\ \underline{40. \text{ GPH} - \text{STAR.}}$$

$$6/17 \quad 14:32:25 \quad 3394.1 \text{ Gallons} \quad \rightarrow \quad \frac{1732 \text{ Gallons}}{20 \text{ HOURS}} \\ 6/18/97 \quad 10:29:34 \quad 1662.1 \text{ gallons}$$

$$= \underline{86.6 \text{ GPH}}$$

$$\begin{array}{r} 86.6 \\ - 2.6 \\ \hline 84 \\ \hline 20 \\ \hline 64 \text{ GPH.} \end{array} \quad \text{STAR}$$

FERMILAB  
ENGINEERING NOTE

RD/DO

HC  
REFRIG.

50-2-1

LN<sub>2</sub> STORAGE REQUIREMENTS

FROM  
EN-421

NAME RUSS RUCINSKI

DATE 3-31-95

REVISION DATE

CHECKED: Todd Leicht 4/4/95

CURRENTLY @ DO WE HAVE A 20,000 GAL LN<sub>2</sub> STORAGE DEWAR THAT FULL CAN HOLD 12,000 GAL. DUE TO SAFETY ISSUES.

EXISTING USAGE: 44 gal/hr FOR AR DEWAR, 3 CALORIMETER (STEADY STATE) + BOTTLE OFF

$$\text{TIME BUFFER IS } \approx \frac{8000 \text{ gal}}{44 \text{ gal/hr}} \times \frac{1 \text{ DAY}}{24 \text{ HRS}} \approx 7.6 \text{ DAYS}$$

SOLENOID USE: PER FERMI DESIGN REPORT; 281.1 WATTS

REFRIGERATOR: COLD & RUNNING 38 LITERS/HR = 10 gal/HR  
COOLDOWN 300K TO 90K 23.3 g/s, 105 LITERS/HR  
STEADY STATE 65 lb/HR = 9.63 gal/HR

\* FROM SATELLITE REFRIGERATOR DESIGN MANUAL.

$$\dot{m} = \frac{281.1 \text{ WATTS}}{200 \text{ J/g}} = 1.4 \text{ g/s} \quad \left\{ \text{BID SPEC MAX ALLOW} = 8 \text{ g/s} \right\}$$

$$= 1.4 \text{ g/s} \times \frac{1 \text{ kg}}{1000 \text{ g}} \times \frac{3262 \text{ gal LIQUID}}{1 \text{ kg}} \times \frac{3600 \text{ s}}{1 \text{ HR}} = 1.65 \text{ gal/HR}$$

FOR  
SOLENOID

VLPC USE:

ESTIMATE HEAT LOAD TO LN<sub>2</sub> IS IN SAME RATIO THAT IT IS FOR THE SOLENOID, A FACTOR OF 10.

$$Q_{LN_2} \approx 10 \times 200 \text{ WATTS} = 2000 \text{ WATTS}$$


$$\dot{m} = 11.74 \text{ gal/HR.}$$

BETTER ESTIMATE PER TED GASTEYER. PHONE CONVERSATION

$$Q_{LN_2} = 3000 \text{ WATTS} \quad \text{or} \quad \dot{m} = \frac{17.6 \text{ gal}}{LN_2} \quad (26)$$

CHECKED: Todd Zeicht 4/4/95

- PURIFIER FOR He STREAM:



PER RICH SCHMITT, HEAT EXCHANGER IS PRETTY GOOD.

TO FIGURE CONSIDER 100 K GHe IN 80 K GHe OUT,  $m = 57 \text{ g/s}$

PRESSURE = 20 ATM = 2 MPa

$$Q = m (h_w - h_{out}) = 57 \frac{\text{g}}{\text{s}} [540.3 \frac{\text{J}}{\text{g}} - 435.7 \frac{\text{J}}{\text{g}}] \\ = 5962 \text{ WATTS}$$

$$Q_{1 \frac{\text{gal}}{\text{hr}}} = 1 \frac{\text{gal}}{\text{hr}} \times \frac{1 \text{ hr}}{3600 \text{ s}} \times \frac{6.745 \text{ lbs}}{1 \text{ gal}} \times \frac{200 \text{ Joules}}{1 \text{ gram}} \times \frac{1000 \text{ grams}}{2.2 \text{ lbs}} \\ = 170.33 \text{ WATTS FROM } 1 \frac{\text{gal}}{\text{hr}} \text{ OF LN}_2$$

FOR PURIFIER. =  $35 \frac{\text{gal}}{\text{hr}}$

- TOTAL ADDED LN<sub>2</sub> USE:

$$m_{\text{use}} = 1.7 \frac{\text{gal}}{\text{hr}} \underset{\text{SOLENOID}}{+} 10 \frac{\text{gal}}{\text{hr}} \underset{\text{REFRIGERATOR}}{+} 17.6 \frac{\text{gal}}{\text{hr}} \underset{\text{VPC}}{+} 35 \frac{\text{gal}}{\text{hr}} \underset{\text{PURIFIER}}{=} 64.3 \frac{\text{gal}}{\text{hr}}$$

$\Delta P$  HX EXIT TO VENT LINE:

1/2" SCH. 10 x 40 ft., FLOW = 70 GPH MAX.

REF. Pg. 7 cales.

FOR 250 ft 1 1/2" PIPE, 30 gph,  $W = 202.35 \frac{lb}{hr}$ .

$$Re = 6.31 \frac{W}{\mu} = 6.31 \frac{(202.35 \frac{lb}{hr})}{(.674 \text{ in})(.0178 \text{ cp})} = 1.064 \times 10^5$$

$$\mu = 178 \text{ MICRO POISES} = 178 \times 10^{-6} \text{ Poises} \times \frac{100 \text{ cp}}{1 \text{ Poise.}}$$

$$\mu = .0178 \text{ cp.}$$

$$\Delta P = 3.36 \times 10^{-6} \frac{FLW^2}{gds}$$

$$= 3.36 \times 10^{-6} \frac{(.026)(40 \text{ ft})(202.35 \frac{lb}{hr})^2}{(.07245 \frac{lb}{ft^3})(.674 \text{ in})^5}$$

$$\boxed{\Delta P = 14.2 \text{ psi}}$$

RECALCULATE ASSUMING PIPE IS MOVED SO THAT  
FLOW MUST TRAVEL THRU 40 FEET OF 1 1/2" PIPE  
+ 10 FT 1" PIPE.

$$\Delta P = 3.36 \times 10^{-6} \frac{(202.35 \frac{lb}{hr})^2}{.07245 \frac{lb}{ft^3}} \left[ \frac{40 \text{ ft} (.021)}{(1.682)^5} + \frac{10 \text{ ft} (.023)}{(1.097)^5} \right]$$


$$\Delta P = 1.899 \left[ 0.06239 + 1448 \right]$$

$$= 0.393 \text{ psi}$$

SOLUTION: MOVE HX GN<sub>2</sub> VENT TO 1" TEE  
IMMEDIATELY UPSTREAM OF 1 1/2" VENT  
PIPE. LESS  $\Delta P$ , BETTER  
PERFORMANCE. ON HX LN<sub>2</sub> POT  
CONTROL.

8:16:48 AM  
6/17/97

# D-ZERO HEAT-EXCHANGER AND LF



## LIQUIFICATION MODE:

NOTE: HX HIGH PRESSURE  
TOO LOW DUE TO EVX2  
- MIN. POSITION = 30%.

CORRECT BY RAISING ENX2 LOW  
LIMIT TO 50%.