

Experimental Correlation of an RPCSIM Model

Matt Carlson – University of Wisconsin, Madison

Keith Mount – Sandia National Laboratories

Ross Radel – Sandia National Laboratories

Steve Wright –Sandia National Laboratories



Sandia National Laboratories is a multi program laboratory operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000.




Experimental Correlation of an RPCSIM Model

FSP BACKGROUND





Fission Surface Power System



FSP Overview^[4,5]

- UO₂ Fuel
- Liquid-Metal Cooled Rx
- Modular 40 kWe System
- Stirling Power Conversion
- 8-Year Design Life
- Regolith Shielded





Experimental Correlation of an RPCSIM Model


RPCSIM BACKGROUND





RPCSIM Concept

- Reactor, Power, and Control SIMulation
 - Modern set of components to solve time dependant state flow systems





Advantages of RPCSIM

SPEED Quickly simulate reactor and power system transient behavior

FLEXIBILITY Object-oriented structure for rapid iteration of system components and layout

EASE OF USE Low barrier-to-entry coding environment

SUPPORTED Uses a commercially-supported simulation program and code base

EXPANDABLE Ability to run on massively parallel machines




Experimental Correlation of an RPCSIM Model

PTC BACKGROUND



Primary Test Circuit - Reality





Primary Test Circuit – Test Data

Run ID #	Run Date	Run Description
1	7/13/2009	75% Flow, 500C
2	7/8/2009	75% Flow, 375 C
3	6/24/2009	100% Flow, 200C
4	6/25/2009	100% Flow, 375C
5	7/6/2009	100% Flow, 500C
6	6/24/2009	Stirling Engine Stall
7	7/13/2009	Loss of ALIP
8	6/24/2009	Loss of Heat
9	7/7/2009	Simulated Reactivity Feedback, - 1 mm Stirling Stroke
10	7/7/2009	Simulated Reactivity Feedback, + 1 mm Stirling Stroke
11	7/14/2009	Simulated Reactivity Feedback, - 2 mm Stirling Stroke
12	7/14/2009	Simulated Reactivity Feedback, + 2 mm Stirling Stroke
13	7/7/2009	Simulated Reactivity Insertion, Steady Stirling Stroke
14	7/8/2009	Simulated Reactivity Feedback, Decreasing Mass Flow
15	7/8/2009	Simulated Reactivity Feedback, Increasing Mass Flow
16	7/8/2009	Simulated Reactivity Feedback, Stirling Engine Stall



Experimental Correlation of an RPCSIM Model

COMPARISON STRATEGY



Comparison Strategy

COMPONENTS Assemble and / or develop generic components.

MODIFY Modify the geometric and other parameters of the generic components to estimate real-world system characteristics.

CORRELATE Simulate components in isolation and use correlation coefficients to match output measurements based on input signals.

SIMULATE Use the correlated RPCSIM model to simulate additional runs and characterize error to identify areas for improvement in both modeling and testing procedures.




Experimental Correlation of an RPCSIM Model

ASSEMBLING COMPONENTS




Primary Test Circuit - Diagram



Primary Test Circuit - Diagram

Reactor Power and Control Simulator
Marshall Space Flight Center Primary Test Loop
Version 01a
Simulink Simulation
(October 19, 2010)
RPC-SIM
Copyright Sandia National Laboratories
PO Box 5800
Albuquerque, NM 87185
Contact: S. Wright 505 845 3014
sawright@sandia.gov

Legend
Input 
Output 
Monitor 
Control 




Primary Test Circuit - Diagram

Reactor Power and Control Simulator
Marshall Space Flight Center Primary Test Loop
Version 01a
Simulink Simulation
(October 19, 2010)
RPC-SIM
Copyright Sandia National Laboratories
PO Box 5800
Albuquerque, NM 87185

Contact: S. Wright 505 845 3014
sawright@sandia.gov

Legend
Input 
Output 
Monitor 
Control 







Experimental Correlation of an RPCSIM Model

COMPONENT CORRELATION



General Heat Exchanger Model




- Counter Flow
- Liquid Metal (Mixed, Shell-side)
- Gas (Un-Mixed, Tube Side)
- Divided axially into “n” nodes
- Assumptions
 - End effects neglected
 - Accounts for convection between fluids and structure as well as radiative loss
 - Conductive thermal resistance perpendicular to flow direction is negligible
 - All **Structure and Fluid** elements have thermal mass



Matlab™ Implementation

Fluid 1 to Fluid 2 Counter-Flow Heat Exchanger with Fluid 1 Radiative Loss
[Maximum number of nodes = 50]




- Structured for quick comprehension
- Modular and scalable
- Simulated “Test Points” routed to clarify program flow
- Calls C functions fitting fluid equations of state
- Calls C functions of various heat transfer correlations






Correlation In Isolation

Existing PTC Test Points





Isolated Model







Correlation Results

Variable	Value	Description
LMGashX_ff_adj_1	1	Correction multiplier for local NaK friction factors
LMGasHX_Nu_adj_1	1	Correction multiplier for local NaK heat transfer coefficients
LMGasHX_ff_adj_2	95	Correction multiplier for local GN2 friction factors
LMGasHX_Nu_adj_2	0.85	Correction multiplier for local GN2 heat transfer coefficients





Correlation Results






Experimental Correlation of an RPCSIM Model

SIMULATION RESULTS





Primary Test Circuit - Diagram

Reactor Power and Control Simulator
Marshall Space Flight Center Primary Test Loop
Version 01a
Simulink Simulation
(October 19, 2010)
RPC-SIM
Copyright Sandia National Laboratories
PO Box 5800
Albuquerque, NM 87185
Contact: S. Wright 505 845 3014
sawright@sandia.gov





Legend
Input 
Output 
Monitor 
Control 



Simulation Results – Stirling Power



Simulation Results – Fuel Pin Temp





Experimental Correlation of an RPCSIM Model

CONCLUSIONS



Conclusions - Modeling

NUMERICS A numerical analysis should be carried out on the current RPCSIM methods to understand the accuracy and stability of the code.

CORRELATIONS The correlation functions used need to be expanded to include more specific correlations such as ones intended for fuel-pin geometries, and to handle varying flow regimes.

EQUATIONS OF STATE Current property-fitting equations should be replaced with equations of state suitable to the fluid regimes modeled.

VALIDATION Individual components should be validated using more detailed numerical analysis.



References

1. D. I. POSTON et. al., "Dynamic Characteristics of Compact Fast-Spectrum Reactors," *Nuclear Technology*, **166**, NT 6-08029 (2009).
2. J. SIAMIDIS, "FISSION SURFACE POWER SYSTEM (FSPS) Preliminary Thermal Analysis – RDU 2nd GEN Test Support," Material Innovations Inc., Pres. (March 6 2009). Contact john.siamidis-1@nasa.gov
3. J.M. Tournier and M.S. El-Genk. (Dec 2009). *Improvement to Sandia's Reactor, Power, and Control Simulator (RPCSIM) Code: RPCSIM-33-UNM*. Institute for Space and Nuclear Power Studies, Department of Chemical and Nuclear Engineering ,University of New Mexico. Produced under Project and Task: 127006 0.02 ARS II-Z; PR 1105132 for Dr. Steven A. Wright 6771.
4. L. Mason (February 2009). *FSP and TDU Overview*. NASA Glenn Research Center TDU Component Final Design Review Presentation
5. R. Radel and S. A. Wright (2008). *Dynamic Modeling of a Lunar Fission Surface Power System*. Radel Sandia National Laboratories Recruiting Presentation
6. Dallas, T; Diaguila, A. J.; Saltsman, J. F. (1971). *Design Studies on the Effects of Orientation, Lunation, and Location On the Performance of Lunar Radiators*. NASA TM X-1846.
7. R. Radel and S. A Wright (February 2009). TDU RxSim Control Options. TDU Preliminary Design Review Presentation given in Salt Lake City, Utah.



Questions?

Acknowledgements:

Sandia National Lab

Ross Radel

Steve Wright

Los Alamos National Lab

Dave Poston

Oak Ridge National Lab

Lou Qualls

Idaho National Lab

Jim Werner

NASA – Glenn Research Center

Lee Mason

NASA – Marshall Space Flight Center

Mike Houts

Department of Energy

Ryan Bechtel





Improvements to RPNSIM Model Components


ADDITIONAL SLIDES

Correlation of RPC-SIM Models Using MSFC Primary Test Circuit Data


ALIP



Heat Flow Sim vs. Relative Time for Run 1






- Data correlated to allow for estimate of cooling flow along ALIP (unmeasured by experiment)





Correlation of RPC-SIM Models Using MSFC Primary Test Circuit Data

RX
Simulator



Correlation of RPC-SIM Models Using MSFC Primary Test Circuit Data

Free Piston Stirling Engines





Stirling engine
electrical power
output vs. time



Correlation of RPC-SIM Models Using MSFC Primary Test Circuit Data

Accumulator

- Inadequate instrumentation for detailed analysis of accumulator, though data indicates that system was not filled enough for liquid to reach beyond the riser, into the accumulator volume.





Correlation of RPC-SIM Models Using MSFC Primary Test Circuit Data

Piping System

- Inadequate instrumentation for detailed analysis of losses through system piping.

