



*Exceptional service in the national interest*



# A Systems Approach for CO<sub>2</sub> Sequestration & Saline Water Utilization

Geoff Klise  
Earth Systems Analysis Department

October 18, 2011





Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000.

# Today's Talk


- Brief Sandia Labs overview
- Why is Sandia involved in CO<sub>2</sub> sequestration?
  - Climate change – national security implications
  - Addresses the Water-Energy nexus
  - Systems modeling expertise
- Evolution of CO<sub>2</sub> and saline water systems model
  - What is carbon capture and sequestration (CCS)?
  - What is a 'Systems Approach'?
  - Importance of this work
  - Early Results

# Sandia's History



# Sandia's Sites

Albuquerque,  
New Mexico



Waste Isolation Pilot Plant,  
Carlsbad, New Mexico



Livermore,  
California



Tonopah, Nevada



Pantex, Texas



# Why is Sandia in this business?

*National Security is intimately linked with Energy, Climate, & Infrastructure Security Challenges.*

## Prosperity



**“Without energy,  
there is no economy.”**

## National Security



**“Without energy and environment,  
there is no security.”**

John Holdren

Director of the White House Office of  
Science and Technology Policy

## Environmental Stewardship




**“Without climate,  
there is no environment.”**

# Geologic CO<sub>2</sub> Sequestration - Why?



- Engineering response to reducing GHG emissions
  - Allows for gradual phasing out of high CO<sub>2</sub> emitting technologies
  - It will take time for low and no-carbon generating sources of electricity to come on-line
  - Electrical generating sources account for 60 percent of all CO<sub>2</sub> emissions
  - Theoretically sequesters CO<sub>2</sub> for long time-horizons (100 to 1000s of years)

# Geologic CO<sub>2</sub> Sequestration - How?




- Essentially, injecting supercritical CO<sub>2</sub> (>100 bar and > 300 K) at depths > 2500 ft into saline sink, coal seam or oil and gas reservoir
- Currently employed using naturally occurring CO<sub>2</sub> for Enhanced Oil Recovery (EOR)

Credit: NETL

# Challenges

- Keeping CO<sub>2</sub> in the ground
  - Verification and Validation
- Cost
- No real carbon market / no tax
- Increased water demand for new parasitic energy production
- Restricted to injection zone, and water use zone
  - TDS of water greater than 20,000 ppm
  - Depth > 2500 ft

# What is a Systems Approach?



What is the feasibility of storing CO<sub>2</sub> in a saline sink, while extracting that same water for power plant cooling, or other uses?


# Overall goals

- Determine Levelized Cost of Energy (LCOE) for different CO<sub>2</sub> storage and water extraction options
- Develop cost curves for different scenarios for national-scale comparison

*Price where the electricity generated will break even, as a function of the lifetime system cost*

*How much low-cost storage exists in the U.S.? Where are these sinks located?*


# Conceptual Framework



# WECS model


- Funded by the National Energy Technology Laboratory (NETL)
- Started with San Juan Basin - NW New Mexico
  - 1 power plant – 1 saline basin with multiple sinks
  - Plant size 1.8 GW, water demand 20 MGD
- Geochemistry Analysis using REACT
  - Sink water chemistries most suitable for reverse osmosis
  - Water chemistry from long-term reaction with CO<sub>2</sub>
- Feasibility study for CO<sub>2</sub> injection, water extraction, treatment and use at power plant

# WECS model



San Juan Power Plant


Morrison  
Formation



# WECS model - Dashboard

Power Plant
CCS Assumptions
CO2 Sink
Displaced Water
 Sandia  
National  
Laboratories

*i*
Saline Aquifers for Combined Thermoelectric Power Plant Water Needs and Carbon Sequestration at a Regional-Scale



<b>Base Cost</b>	
<b>Carbon Capture and Sequestration (CCS)</b>	
<b>Water Treatment (WT)</b>	

Input Variable	
Power Plant Emissions (CO2)	14,512,417 ton/yr
% CO2 Sequestered	50 %
Formation Depth	4,725 ft
Formation Size	5,000 mmt
Power Plant Water Demand	6.90 cubic ft/s
	6,421,612,530 gallon/yr
	17.84 MGD
High-Level Results	
CO2 Sink Longevity	760 yr
Displaced Water	625,809,605 gallon/yr
% of Annual Plant Demand Met	9.75 %
Years Worth of H2O in Formation	74 yr
Electricity Cost	4.50 cents/kWh
Water Treatment Costs	\$7.37 per thousand gallons
Electricity Cost, CO2 Seq & H2O Treatment	8.95 cents/kWh

**CO2 per year**

ton/yr

20,000,000 ↑  
10,000,000  
0 ↓

**% CO2 Captured**

90%  
70%  
50%  
30%  
0%

**Geological Formation (ft deep)**

Morrison (4750)

**CO2 Density to H2O**

Handbook of Phys Const

1.20 cubic cm/gram

**% H2O Recovery**

%  
100 ↑  
0  
0 ↓

30 %

**San Juan MGD**

MGD  
15 ↑  
0  
0 ↓

17.84 MGD

**Base Cost of Electricity**

cents/kWh  
20 ↑  
0  
0 ↓

4.50 cents/kWh

# WECS model - Results



- Modeled 700 years of potential CO<sub>2</sub> storage in all sinks within San Juan basin
- Up to 200 years worth of saline water for meeting existing cooling needs, if power plant is still operating
  - Pumping, reverse osmosis treatment = \$5.00/1000 gallon

\*\*Conceptual framework established for regional analysis

- Next steps:
  - More detailed CO<sub>2</sub> storage and transport processes
  - Address costs in a more integrated way


# WECS II Model

- Focused on southeast U.S.
- Carrizo-Wilcox saline sink – geomodeling
- Water treatment costs at power plants




# WECS II model - Geomodeling


- Dipping saline sink – no structural closure
  - Potential migration pathway for CO<sub>2</sub>
- TOUGH2
  - Numerical Model
  - Determine migration rates and paths over 1000 and 5000 years



# WECS II model - Geomodeling



3D and “slice” view of CO<sub>2</sub> plume after 5000 years



# WECS II model - Results

- Uncertainty in vertical conductivity drove whether CO<sub>2</sub> gas/liquid migrates under or through caprock
  - Some leakage or no leakage at all
  - Forced to model using homogeneous permeability
  - Next efforts will focus on heterogeneous permeability
- Desalination costs for reverse osmosis
  - From \$5.50 to \$9.00/1000 gallon depending on disposal method. Included evaporation and brine injection

Kobos et al. (2011) Combining power plant water needs and carbon dioxide storage using saline formations: Implications for carbon dioxide and water management policies. *Int J Greenhouse Gas Control* 5:899-910

# WECSSim - National Effort




- Utilize NatCarb data for saline sinks
  - 325 saline sinks identified for this model
- National modeling platform
- Develop cost curves for cost of storing CO<sub>2</sub> and cost of avoided emissions
- Emphasize the saline water link as competing demands for water in the future will make the cost of freshwater highly variable

# WECSsim - Dashboard



WECSsim: a dynamic analysis tool



The dashboard interface features a top navigation bar with six tabs: Summary, Power Plant, CO<sub>2</sub> Capture, Carbon Sequestration, Extracted Water, and Power Costs. The Power Plant tab is currently selected. The interface includes the Sandia National Laboratories logo on the left and the NETL logo on the right. A central box contains the title 'The National Water, Energy and Carbon Sequestration Simulation (WECSsim) Model'. Below the title, the 'Model Development Authors' are listed: P.H. Kobos, J.D. Roach, G.T. Klise, T. Dewers, J.L. Krumhansl, and D.J. Borns. A note at the bottom left states: 'Sandia is a multiprogram laboratory operated by Sandia Corporation, a Lockheed Martin Company, for the United States Department of Energy under Contract DE-AC04-94AL85000.' At the bottom, three buttons allow users to 'Evaluate a single powerplant', 'Evaluate 2005 U.S. powerplant fleet', or 'Evaluate time based scenarios (disabled)'. A note at the bottom right indicates that users can choose from three simulation types, currently shared and limited to a run count of 556 for the power plant fleet.

WECSsim: a dynamic analysis tool

Summary Power Plant CO<sub>2</sub> Capture Carbon Sequestration Extracted Water Power Costs

**Sandia National Laboratories**

**NETL**

*The National Water, Energy and Carbon Sequestration Simulation (WECSsim) Model*

**Model Development Authors:**  
**P.H. Kobos, J.D. Roach, G.T. Klise**  
**T. Dewers, J.L. Krumhansl, D.J. Borns**

Sandia is a multiprogram laboratory operated by Sandia Corporation, a Lockheed Martin Company, for the United States Department of Energy under Contract DE-AC04-94AL85000.

Evaluate a single powerplant

Evaluate 2005 U.S. powerplant fleet

Evaluate time based scenarios (disabled)

From here go to any of the three simulation types. Eventually may need 3 separate interfaces. For now they are shared, and can only tell the difference based on run count (556 for power plant fleet).

Version 1.1, June 2011

# WECSsim - Dashboard

WECSsim: a dynamic analysis tool

Summary
Power Plant
CO<sub>2</sub> Capture
Carbon Sequestration
Extracted Water
Power Costs

Module Input
Cooling Technology
Base Water Use
Withdrawal
Consumption

Once through
 Cooling tower(s)
 Cooling pond(s)
 Dry cooling

Use default:
670 gal/MWh
520 gal/MWh

Use custom:  
(click # to change)
25,361 gal/MWh
17 gal/MWh

Defaults based on Tables D-1 and D-4 of [NETL 400/2008/1339](#) and Figure 4-2 and B-1 of [NETL 402/08018](#)

Total
Fuel Costs
Cooling
All Other
\$ Year:

Default:
6.7 cents/kWh
=
2.1 cents/kWh
+
0.3 cents/kWh
+
4.4 cents/kWh
2010

Custom:  
(changeable)
6.4 cents/kWh
=
2 cents/kWh
+
0.2 cents/kWh
+
4.2 cents/kWh
2007

Defaults based on Exhibits ES-2, 3-29, 3-62, 3-95, 4-12, 4-33, 5-12 in [NETL 2007/1281](#) and Figure 13 of Tawney, Khan, Zachary, Journal of Engineering for Gas Turbines and Power, April 2005, V 127

Output
Power Plant Location

**Key Information from Power Plant Module**
Change to LCOE

Plant type	Pulverized coal subcritical
Base electricity generation	14.4 TWh/yr
Base CO <sub>2</sub> generation	12.3 Mmt/yr
Cooling type	Cooling tower
Base water withdrawals	26.8 MGD
Base water consumption	20.8 MGD



cents/kWh

10

5

0

H2O

CCS

Base

Scale

0


# WECSSim - Challenges

- Data issues
  - 325 saline formations
- National modeling platform
- Geomodeling done on a few sinks, but not all
  - Sink water chemistries most suitable for reverse osmosis
  - Water chemistry from long-term reaction with CO<sub>2</sub>
- Feasibility study for CO<sub>2</sub> injection, water extraction, treatment and use at power plant


# Assessing U.S. deep saline formations

## Data and Analysis


## Product




# WECSsim - Challenges



# Rock Type Classification



Injectivity equation: permeability sampled from 4 Rock Types




# Uncertainty and the Well Injectivity Index

- $I$  well injectivity index; measure of the “ease” of injecting  $\text{CO}_2$  into the well
- $q$  volumetric injection rate
- $\Delta P$  the pressure gradient

$$I = \frac{4\pi k k_r H}{\mu \left( \ln \left( \frac{4A}{1.781 C_A r_w^2} \right) + 2s \right)}$$

$$I \equiv \frac{q}{\Delta P}$$



Reservoir volume


Radial flow from the well

(Bryant and Lake, 2005)

# WECSSim Results:

## *Permeability and Costs*


Injection costs as a function of injection well permeabilities



# WECSSim Results:


## *Injection Costs and Formation Types*

Injection costs for geologic storage of 11 million tonnes CO<sub>2</sub> per year




# WECSsim Results:

## *Injection Costs Relative to Total Costs*



# WECSsim Results:


*Similar Full Economic Analysis Underway*



**Note: Illustrative Example at this time**

# WECSsim – Results

## The water withdrawal cost of 90% CCS at US coal fired power plants



# Conclusions

- Low CO<sub>2</sub> injection rates results in higher costs
  - Low injectivity requires more injection wells and therefore higher costs
  - Accurate Site Permeability Characterization is key
- Importance of High Quality Saline Reservoirs
  - High permeability reservoirs with low injection costs (< \$1/tonne) represent < ~10% of the 325 formations
  - Scale-up challenge: What is your willingness to pay?
- Using a national-level systems approach
  - The mix of reservoirs of different quality is a major factor that will control 'supply' of CO<sub>2</sub> storage

# On going and Future Work

- CO<sub>2</sub> injectivity-brine extractivity and heterogeneity
  - i.e., “How do injection rates improve with brine extraction?”
- Spatial distribution of CO<sub>2</sub> sources to sinks
  - i.e., “Are the high quality sinks accessible to large sources?”
- National Level Supply Assessment
  - i.e., “How much low-cost CO<sub>2</sub> storage exists in the U.S.?”
- Develop integrated geospatial output with WECSSim model

# Thank you


Geoff Klise  
Sandia National Laboratories  
PO Box 5800, MS 0735  
Albuquerque, NM 87185-0735

505-284-2500

[gklise@sandia.gov](mailto:gklise@sandia.gov)


# Gulf coast outliers

## Injection costs as a function of injection well permeabilities




# Gulf coast outliers

## Injection costs as a function of injection well permeabilities



# Gulf coast outliers



# Gulf coast outliers

## Injection costs

