

Electrical Energy Storage

SAND2014-2145C

Projects, Applications & Research Challenges for Grid Support



Daniel Borneo, P.E.

Presentation for
NM Energy, Minerals & Natural Resources Department



*Exceptional
service
in the
national
interest*

March 2014



Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000.

SAND Number

SAND Document

AGENDA –

Presentation Outline

- Sandia's Energy Storage Program
- Energy Storage Industry
 - Grid Problems Mitigated by Energy Storage
 - Projects and Applications
 - Summary – Challenges and Gaps

Innovation: Something to Consider



One of the first gasoline powered cars
~1891 by Henry Nadig of Allentown, Pa.

Courtesy of American Automobile Museum, Allentown, Pa.



Courtesy of American Automobile Museum, Allentown, Pa.

Innovation: Something to Consider

*Quotes about the Nadig in 1891**


- Blasted as a “**dangerous device**” – backfiring caused **FIREs!**
- Car **not allowed** on the **streets during the day** as it “**frightened**” the horses
- Constable served notice; drivers/operators could be **arrested**, held liable for creating a “**public nuisance**”
- “Shouts of ‘Get a horse!’ were followed by the grand insult of the day - “***Flying Cabbages***” that were thrown at the hapless Nadig.”

* Whelan, Frank “Did Auto Age First Dawn in the Valley? Allentown Mechanic Built One of Country’s First Gas-powered Cars” Sept, 14, 1989 The Morning Call



DOE/Sandia's Energy Storage Mission

DOE Office of Electricity (OE) drives **electric grid modernization for the nation's energy infrastructure**, and Sandia National Laboratories (SNL) manages the majority of OE's Stationary Energy Storage program. SNL accomplishes this mission through **R&D, applied engineering, analysis, testing & demonstrations** and partnering with Industry and academia.



Sandia's ES Program



U.S. DEPARTMENT OF
ENERGY



Sandia
National
Laboratories

Energy storage is an enabling technology that:

1. Improves grid *efficiency*
2. Improves grid *reliability and resilience*

DOE - Identified Key Challenges:

1. Lifetime return on investment (**cost** / performance)
2. Validated **Reliability** and **Safety**
3. **Regulatory** environment
4. **Market** acceptance

Five Sandia Thrust Areas to Meet Grid Challenges



- **Materials and Systems Development**
 - Leading the **development** of next-generation technologies
 - Improving current **technology** (flow batteries, flywheels, etc.)
- **Power Electronics**
 - **Developing** and testing new wide-bandgap power-electronic devices
- **ES Systems Demonstrations and Testing**
 - Laboratory **testing and analysis** from individual cells to 1MW systems
 - **Field** deployments
 - State-Initiated Demonstration Project Development
- **Grid Analytics and Policy**
 - Providing **assessments** of the impact of storage placement
- **Outreach** - Leading publications and meetings to **help** educate the Grid Energy community

Nanoscopic



Macroscopic

Materials and Systems R&D



U.S. DEPARTMENT OF
ENERGY




Sandia
National
Laboratories

Improving the cost, performance and reliability of energy storage systems.

Near term – *Improvement* of existing energy storage technologies:



- Flow Batteries (separators, electrolytes, etc.)
- Flywheels (Carbon composites, new lift magnets)
- New Capacitor materials



New low-cost flow battery separator materials

NaSICON - sodium super ionic conductor (& separator)

$\text{Na}_3\text{Zr}_2\text{Si}_2\text{PO}_{12}$



Longer term – *Revolutionary* new energy storage systems:

- Nitrogen - air batteries (high energy density)
- Sodium-iodide batteries (low cost)


Power Electronics

Use of wide bandgap semiconductor devices, advanced topologies, and controls significantly reduce installed cost and footprint, improve control capability, and increase reliability of ES devices and equipment.

$P_{dis} = 200 \text{ W}$, Max Temperature = 166 °C



Arkansas Power Electronics
International
15kV Discrete SiC Package



Recent Recognition

- Four R&D100 Awards
- Three U.S. Patents
- Over 40 technical publications
- DR. Stan Atcitty received Presidential Early Career Award for Scientists and Engineers

Demonstrations and Testing



Assist the Industry in determining how to maximize return on investment (ROI). These projects help to ensure ROI and facilitate adoption via improving confidence in safety, reliability, system performance and cost-effectiveness.

Two Pronged Approach



Energy Storage Test Pad (ESTP) – 1MW test pad at SNL used to test and evaluate the safety, reliability and performance of ES systems.

Battery Test Lab – Battery Cell and module testing for safety and performance.



Field Demonstrations - Assist in the selection, installation, optimization and performance analysis of ES systems while providing verified technical and economic evaluations of technologies.

CESA-ESTAP Program – Work with State Energy Offices to advance the use of Energy Storage through state led initiatives.

SNL Industry Collaborations



Beacon Power

- SNL partnering with Beacon Power on advanced flywheel and magnetic materials.

SunEdison

- Committed \$224K for a 24 month collaboration with SNL to demonstrate laboratory-scale prototype of SNL ionic liquid flow batteries.

Arkansas Power Electronics International

- Phase I SBIR project to design and demonstrated a high voltage discrete package capable of housing a 15 kV silicon carbide device.

Southern Company

- A production cost model of the business case for additional bulk electric energy storage in the Southern Company service territory for 2020.

Green Mountain Power, Vermont Dept. Of Energy

- SNL partnering with the state of Vermont and GMP to install a 2MW/3.4MWh ES system with 2MW PV.

Hawaiian Electric Company / Maui Electric Company (HECO/MECO)

SAND production cost model report, entitled "Maui Energy Storage Study," released in December 2012.

Connecticut, Massachusetts, New York, New Jersey, Maryland, Vermont

- SNL partnering with various state energy departments to develop projects and provide technical consulting.

Aquion Energy, SustainX, SEEO, EnerVault, Primus Power.

- ARRA program to develop, test and deploy a ES systems.

Kodiak Electric Association (KEA)

- Project undertaken to maximize the benefit of a 9MW wind system and 3MW ES at Kodiak Electric Association.

DoD

- Support testing of BCIL systems at ESTP - Three out of five systems have been tested.

Duke Energy, Fiamm

- DUKE in collaboration with DOE/SNL is working to further research in optimizing energy storage for utility grid applications.

PNM, NEDO, MDS, East Penn

- Verify the benefit of combined ES / PV at PNM's Prosperity site.

CPUC, SunPower/DNV-KEMA/UCSD, ICE

- Sunpower Corp under a grant from the California Public Utility Commission (CPUC) engaged in work to demonstrate an ES / PV system with SNL's assistance..



SNL University Collaborations

Colorado School of Mines University of Maryland

- Scale-up and production of SNL ceramic, and supplying the engineered ceramic in the format necessary for use in the battery.

Oregon State University

- Co-developing ultra-capacitors with SNL; OSU is focused on the roll of defects in the SNL material.

Iowa State University

- Collaboration with SNL to compare and contrast how reserve markets are structured in the (seven) wholesale power markets in the U.S.

University of California San Diego

- SNL/UCSD collaboration to develop and deploy MW-scale energy storage system on the UCSD campus.

Case Western Reserve University

- SNL-managed, university-guided project researching the negative electrode materials.

The State University of New York

- SNL-managed university-directed project to develop synthesis pathways for cathode oxides.

Arizona State University Iowa State University

- SNL-managed, university-led project to demonstrate composite non-brittle solid electrolytes.

University of California/Los Angeles; Drexel University

- SNL-managed, joint-university project to test prototype devices with integrated mesoporous electrode architectures.

Texas Tech University

Partnering with University and others to evaluate ES in a wind application.

Grid Analytics and Policy




U.S. DEPARTMENT OF
ENERGY



Sandia
National
Laboratories

Motivation

- Determine where and how to implement storage with the greatest benefits to the utilities, regulators and consumers, e.g. grid resilience, frequency regulation, peak shifting
- Explore grid-level storage cost effectiveness in actual markets:
 - Evaluate impact to the delivered cost of electricity, especially with *projected increases in renewable deployment*;
 - Study pumped-storage hydro, flywheels, and batteries as well as combinations of these options.



Recent Accomplishments

- Published 5 reports – two on a new wholesale market design, and three storage valuation studies (on Maui, NV Energy, and Southern Company).
 - Maui study provided additional evidence that storage ameliorates wind curtailment and is an economic option
 - NV Energy study showed that new storage deployments can be cost effective when pay-for-performance is enacted.

Outreach

- **Electrical Energy Storage Applications and Technology Conference (EESAT)**
 - The international conference disseminates the latest advances in storage technology, analytic and economic methods and demonstrations
- **DOE Online Energy Storage Database**
 - Disseminates project information on active energy storage projects worldwide.
energystorageexchange.org
- **Handbook**
 - Provides a comprehensive guide for energy storage: Details the current state of commercially available energy storage technologies. Matches applications to technologies. Info on sizing, siting, interconnection. Includes cost database.
sandia.gov/ess/publications/SAND2013-5131.pdf



The image contains two parts. On the left is a screenshot of the 'DOE Energy Storage Database' website. The main view shows a world map with several yellow dots representing active projects. A detailed view of a specific project, '300MW Covel Loop Pumped Storage Scheme', is shown with its description, location (Covel, West Virginia, United States), and technical details like Pumped Storage, Capacity (300,000), and Efficiency (90%). On the right is a thumbnail image of the 'DOE/EPRI 2012 Electricity Storage Handbook in Collaboration with NRECA'. The thumbnail shows the title at the top, followed by a list of authors (Abbas A. Akhil, Georgianne Huff, Aileen B. Currier, and William D. Gunnett, Benjamin C. Kauh, Dan M. Rastler, Stella Bingsu Chen, Andrew L. Coker, Dale T. Bradshaw) and a note about the report being a SANDIA REPORT.



U.S. DEPARTMENT OF
ENERGY



Sandia
National
Laboratories

What Problems Can ES Help Alleviate?

Electrical Energy Storage Overview



- Electrical Energy storage decouples generation from demand:
 - Adds **reliability** to the nation's electricity power grid
 - The lights are on when you flip the switch, even in an emergency
- Electrical energy storage makes **renewable energy resources more dispatchable**
- Electrical energy storage can support an **aging** or **overloaded** grid
- Energy storage faces unique *technical and market challenges*:
 - Nascent industry
 - Reliability of systems
 - Cost of systems
 - Regulatory policies

Energy Storage Applications

POWER

<15min

ENERGY

>1hr

LOAD


PQ, Digital Reliability, UPS	Spinning Reserve/ Load Following, UPS	Peak Shaving, Load Shifting
Voltage Support, Transients, Regulation	Dispatchability for Renewable Energy Resources	T&D Congestion Mitigation, Time of Use Arbitrage, Upgrade Deferral

seconds


minutes

hours

Role Electrical Energy Storage On the Electricity Grid



BPA Generation and Load Profile



Lanai- PV




U.S. DEPARTMENT OF
ENERGY



Sandia
National
Laboratories


Power and Voltage



Variable Energy Resources Create More Demand for Balancing




Wind



Solar

Solar energy sources are highly variable



Bonneville Power: Wind data for one month


- Power range >1200 MW
- Fluctuations for 5 minute and 6 hour time frames

Typical daily solar power output pattern

- Fluctuations can be >80% rated power in 5 minutes
- Can continuously fluctuate on partially cloudy days

Renewables need all three time scales of storage


Fast Response: Speed Matters



ES Attributes

- Storage has a near instantaneous response
- Only need enough for gen to catch up
- Works with slower, more efficient generators
- Helps firm variable generation like wind & solar

Significance of ES Contribution
Generators are slower than load changes



Storage for Load/Power balancing is new state of the art


Storage Applications – Load Leveling



U.S. DEPARTMENT OF
ENERGY



Sandia
National
Laboratories



Ameren: Taum Sauk, Missouri
440MW re-commissioned May, 2010




Arbitrage has difficult economics today

Microgrid Applications –

i.e. Disconnected Distribution Line



Microgrid Network



NY Revisited – 2012 Super Storm Sandy Natural Disasters, Power Outages, & ES

The New York Times

N.Y. / Region

Search All NYTimes.com

Go

WORLD U.S. N.Y. / REGION BUSINESS TECHNOLOGY SCIENCE HEALTH SPORTS OPINION ARTS STYLE TRAVEL JOBS REAL ESTATE AUTOS

UPDATED October 30, 2012

 FACEBOOK

 TWITTER


 GOOGLE+

 E-MAIL

 SHARE

A Close Look at Power Failures in New York City 5:45 P.M. ET Nov. 8

Hurricane Sandy knocked out power to hundreds of thousands of people in the area. Data updated every 15 minutes.



Major outages can last for 5-7 days in some disasters; but backup systems are not commonly designed for that type of duration.

Is Storage Expensive?

(The Ugly Truth)



\$/kW?



\$/kWh?

What is in the “kW”?

What is in the “kWh”?

Total System Cost?

Environmental conditions?

Life Cycle Cost?

System losses?

Balance of Plant Cost?

KWh Stored?

Installation Cost?

KWh Delivered?

Replacement Cost?

Number of cycles?

Disposal Cost?

Cost of operations?

Maintenance Cost?

Cost metric must include a variety of important elements.

Several Available



U.S. DEPARTMENT OF
ENERGY



Sandia
National
Laboratories

Storage Varieties/Options

Type	Storage Mechanism	Common Duration	Cycles
Capacitor	Electrical charge	Seconds (minutes)	100,000's
Flywheel	Kinetic energy	Seconds / Minutes	1000's - 100,000's
Battery	Electro-chemical	Minutes (hours)	100's- 1000's
Pumped Hydro	Potential energy	Hours	1000's
Thermal	Ice, Molten Salts	Hours	1000's

Decreasing cost per kWh

World-Wide Energy Storage Projects

What's happening in the Industry -

(www.energystorageexchange.org)



U.S. DEPARTMENT OF
ENERGY






Sandia
National
Laboratories

Projects




Mesa del Sol PV Output Smoothing Demonstration Project

- Goal: Smooth 500 kW PV output with distributed resources (i.e., natural gas gen set, battery, and fuel cell)
 - Sandia has optimized a PV smoothing control algorithm to minimize power output variability and battery use.
 - Field demonstration began in the summer of 2013.



PNM Prosperity Project

Evening Peak Shaving & Simultaneous Smoothing



NEDO/- LOS ALAMOS New Mexico

Smart Grid Demonstration Project



New Energy and Industrial Technology Development Organization (NEDO) has commissioned a Demonstration Project in Los Alamos County, New Mexico (USA):

- 800 kW/1-hr Lead Acid Battery (VRLA)
- 500-kVA PCS for storage batteries.
 - two circuits of DC/DC converters that can be connected to storage batteries and photovoltaic cells.

Demonstration of suppressing short-term output fluctuations in photovoltaic power generation through the charging and discharging of lead-acid batteries. More information at:

<http://www.hitachi.com/New/cnews/1209...>

Lanai- PV & Micro grid



BACKGROUND INFO

- 1.2-MW photovoltaic (PV) power plant in Lanai, Hawaii
- Operating since December 2009 on a 5 MW grid
- An interconnection study concluded that PV output ramps had the potential to negatively impact system frequency.
- System output curtailed to 50%



- In 2011, a 1.5MW 40 min energy storage system was installed and allowed the PV system to operate at rated output.



Kodiak -System Modeling & Simulation

Enhance system
frequency and
voltage stability.



BACKGROUND

Kodiak Electric Association, Inc. (KEA) is a **rural electric cooperative** located in Kodiak, Alaska. Generation comes from a mix of hydroelectric turbines, diesel generators and wind turbines. An XP 3MW 0.25h LA ESS was installed to mitigate the variability of the 9MW wind system.

Laurel Mountain Energy Storage Project



- The 32 MW 0.25hr Li-ion ES system is a fully-integrated portion of the Laurel Mountain Wind Farm developed by AES Wind.
- Provides frequency regulation in the PJM market and ramp rate control for wind variability.
- Operational Q3 of 2011.

Location

Belington, West Virginia (PJM)



With 150 MW of resources online, AES Energy Storage operates the largest fleet of battery-based storage assets in commercial operation today.

SMUD -High Penetration Solar Portal

Sacramento Municipal Utility District (SMUD) piloted both residential energy storage (RES) units and community energy storage (CES) systems in Anatolia. Thus far, the research team has installed 15 RES units in the garages of volunteers.

In February 2012, the team planned to set up three additional CES systems in the neighborhood with each CES connected to the pad-mounted transformers on distribution feeders – all sized to work with the group of homes serviced by each transformer. These are about three times larger than the residential units, but can be shared between five to ten homes.

SMUD pioneered this technology as part of the [Photovoltaic \(PV\) and Smart Grid Pilot project](#), which was funded by the SunShot Initiative of the U.S. Department of Energy (DOE), the American Recovery and Reinvestment Act of 2009 (ARRA), and industry partners. The utility company also planned to develop two-way communication capabilities and analyzing production characteristics of distributed PV systems (with a \$5.96 million award; \$4.3 million from DOE and \$1.66 million from SMUD and partners).



Turlock Water District



Enervault Fe-Cr Redox Flow Battery 1 MW·hr_{AC}



- DOE ARRA Storage and CEC funding
- Began commissioning January 2014
- Co-located with a PV solar system driving water pumping at an almond farm in Turlock, CA

Largest Iron-Chromium Redox Flow Battery Installed Globally

- ENERVAULT - 250 kW_{AC}, 4-hour Iron Chrome
- Inherently safe system design based on NASA science
- Grid-scale EnerVault systems advertised to meet DOE cost targets and deliver 4-12 hrs of energy

EaglePicher Demonstration

Joplin, Missouri



U.S. DEPARTMENT OF
ENERGY



Sandia
National
Laboratories



EP POWERPYRAMID™ INSTALLATION,
Project Commissioned June 2012

- EPT's PowerPyramid™ hybrid energy storage
 - 1 MW/2 hr ES
 - Consists of three systems:
 - Li-ion, tubular Pb-Acid and AGM Pb-Acid
 - Peak Shaving and UPS

View real-time operational statistics and monitoring at: www.eptpowerpyramid.com

- Multiple energy inputs and storage tiers housed in 4 - 40 foot containers
 - Tier #1 provides rapid response to short duration load changes and high cycle count
 - Tier #2 can provide medium-duration load support for longer duration load fluctuation and Medium cycle count
 - Tier #3 can provide long-duration load support for extended load fluctuations and low cycle count

Closing Technical & Economic Gaps

Key ES Challenging Questions

- How do we **design** and **correctly size** Energy Storage Systems?
- How do we **utilize and control ES** so the system performs multiple functions to get the most value for the least cost?
- ES is like a life insurance policy: **term life** - no value until a disaster hits; or **whole life** – you can utilize the assets (for a price). What capability can be built into an ESS to access the service during normal operation and in emergency? **How do you monetize that capability?**



U.S. DEPARTMENT OF
ENERGY



Sandia
National
Laboratories

Thank You and a mention of SNL Sponsor –
DOE/OE - Grid Energy Storage program
managed by Dr. Gyuk

Questions?

Contact Information:

Dan Borneo - drborne@sandia.gov



For more information, visit the website at:
www.sandia.gov/batterytesting



**2014 Call:
January 16 - July 15, 2014.**

The database will be open for FAST-Track Proposals. These should be limited in scope and have strong justification for expedited processing.

Contact: Summer Ferreira
srferre@sandia.gov
or David Rose
dmrose@sandia.gov



Advanced Energy Storage Device Testing
Reliable independent evaluation of energy storage solutions.



Resources



U.S. DEPARTMENT OF
ENERGY



Sandia
National
Laboratories

- www.cleanenergystates.org/projects/energy-storage-technology-advancement-partnership/
- www.electricitystorage.org
- <http://energy.gov/oe/services/electricity-advisory-committee-eac>