



# Pilot Tests of CBM Produced Water Desalination: Navajo Dam, NM

---

**Malynda Cappelle, Randy Everett, William Holub, and Allan Sattler**  
**Sandia National Laboratories**

**Rebekah Miller, ConocoPhillips San Juan Business Unit**

**Frank McDonald, Biosphere Environmental Sciences & Technology**

**Rick Arnold, NMSU Ag Science Center, Farmington**

2008 New Mexico Water Research Symposium

12 August 2008



# Water Disposal from Coal-Bed Methane Wells is Costly

---

- Coal bed methane (CBM) supplies ~7% of US natural gas; expected to double in next decade
- To access methane, large volumes of brackish water must be removed (*water must be disposed of or treated*)
- Disposal Cost: \$3-4+/bbl for producers in northern NM due to remoteness, lack of infrastructure, away from the electric grid
- To lower cost, methods for treating/reclaiming water sought





## ***Primary Project Goal***


---

- Desalinate produced water from a ConocoPhillips coal bed natural gas well in the San Juan Basin, using optimum technology, and, at the same time provide desalinated water for beneficial use meant for:
  - Riparian improvement (Joel Brown/USDA, Jornada Experimental Range, Las Cruces)
  - Rangeland improvement/Revegetation of Disturbed Land (Rick Arnold, Agricultural Science Center, Farmington)
- Produced water from the Coal Bed Methane Natural Gas will be desalinated by reverse osmosis in a pilot operation.



## Equipment & Layout at ConocoPhillips CBM Well Pad

---





## Equipment at ConocoPhillips CBM Well Pad





# Produced Water Chemistry

Analyte	Units	average
Specific Conductance	µS/cm	17,326
Total Dissolved Solids (@ 180 °C)	mg/L	10,696
TDS (calculation)	mg/L	14,468
pH	units	8
Temperature	deg C	16
Total Suspended Solids	mg/L	150
Chloride	mg/L	2,087
Fluoride	mg/L	1
Nitrate	mg/L	1
OrthoPhosphate, as P	mg/L	13
Phosphorous, Total as P	mg/L	13
Sulfate	mg/L	3
Silica	mg/L	10
Total Alkalinity	mg/L	7,785
Calcium	mg/L	27
Iron	mg/L	0
Magnesium	mg/L	6
Potassium	mg/L	23
Sodium	mg/L	4,515




# 2007 Simplified Pilot Flow Diagram

Untreated CBM Produced Water

3 gpm

Gravity Separation &  
Cyclonic Filtration




Ultrafiltration



To Brine Tank  
0.75 gpm

4.75 gpm

Reverse Osmosis




## Proof Of Concept Pilot

- 10% overall efficiency (more membrane surface area required to improve)
- UF system: 75% efficiency
- RO system: 15-20% efficiency

# 2007 Pilot Data: Turbidity Removal


## RO Turbidity Monitoring






# 2007 Pilot Data: Turbidity Removal

---





# 2007 Pilot Data: Reverse Osmosis Summary

Analyte	RO Concentration Factor (Conc/Raw)		RO Removal Efficiency	
	10/9/07	11/28/07	10/9/07	11/28/07
Specific Conductance (@ 25°C)	1.14	1.18	98%	98%
Total Dissolved Solids (@ 180°C)	1.11	1.22	98%	98%
TDS (calculation)	1.20	1.26	98%	98%
Total Suspended Solids	0.67	1.07	27%	53%
Chloride	1.06	1.48	98%	97%
Sulfate	1.00	0.67	100%	44%
Silica	1.10	0.76	97%	88%
Total Alkalinity	1.26	1.23	98%	99%
Calcium	0.80	1.15	100%	98%
Iron	3.96	1.68	96%	74%
Magnesium		0.21		100%
Potassium	0.90	1.26	100%	99%




## **NMSU/USDA *Rangeland & Riparian Improvement Study (2007 & 2008)***

---

**Existing grasses on the San Juan well pad to be treated  
in the following manner:**


- ~ 1/3 will spot watered with treated/desalinated water**
- ~ 1/3 will spot watered with untreated produced water**
- ~ 1/3 will receives no additional watering**

# Salinity Tolerance of Crops



Modified from: Ayers and Westcott 1994, "Water Quality for Agriculture"

# Infiltration Effects: SAR & TDS



Modified from: Ayers and Westcott 1994, "Water Quality for Agriculture"



**Watering grasses of COPC San Juan Well Pad with  
Untreated Water**




# 2007 Simplified Pilot Flow Diagram

Untreated CBM Produced Water

3 gpm

Ultrafiltration




To Brine Tank  
0.75 gpm

Reverse Osmosis

4.75 gpm

To Rangeland &  
Riparian Study  
0.30 gpm




To Brine Tank  
1.25 gpm

## Proof Of Concept Pilot

- 10% overall efficiency (more membrane surface area required to improve)
- UF system: 75% efficiency
- RO system: 15-20% efficiency

# 2007 Simplified Pilot Flow Diagram



## 2008 Pilot

- 50% overall efficiency (more membrane surface area required to improve)
- UF system: 75% efficiency
- RO system: 33% efficiency



Recreation Hall, Sauna, Hot Showers and Club Room