


Exceptional service in the national interest



Sandia National Laboratories Photovoltaic and Grid Integration Dept. Capabilities

**UVIG Solar O&M Roundtable
San Antonio, TX**

Geoffrey T. Klise
October 2, 2014




Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000.

Capabilities


- O&M and Reliability
- Grid Integration
- Technology Validation
- *Facilities*
 - Photovoltaic Systems Evaluation Laboratory (PSEL)
 - Distributed Energy Test Laboratory (DETL)
 - Regional Test Centers (New)
 - New Mexico (at PSEL)
 - Vermont
 - Nevada
 - Florida
 - Colorado

Sandia PV Reliability Program

PV reliability program spans the spectrum from materials to systems
Focus on Balance of Systems (BOS)



Solder Joint
Degradation



Connector
Reliability



Ground Fault

Advanced Inverter
Function

Arc Fault

Materials

Components



Sub-system

System

Capacitor, IGBT, WBG

Future of Inverter Reliability



High DC/AC Ratios



- Less irradiance variation during daytime “peak” hours
- Power output profile looks more like base generation


Future of Inverter Reliability

High DC/AC Ratios




- DC/AC Ratios have been climbing in new PV installations (~125%)
- High DC/AC Ratios can be very challenging inverter reliability environments
- Inverter at **maximum power, high voltage state** for many hours during the day
- Lifetimes will become **shorter** due to high power/high voltage environments

System Level Reliability Research



- System level measurements of advanced inverter functionality show that **operation at non-unity power factor decreases the real efficiency of the inverter**



- The decreased efficiency results in higher internal heating, accelerating component degradation and overall system aging

Arc-Fault Prediction Modelling



- Development of a Transient 2D FEA PV Arc-Fault Model capable of predicting electrical-thermal performance thresholds for Arc-Fault trip thresholds
- Model validation with experimental studies has been confirmed for various materials and geometries




Selected Fundamental Modelling

$$\frac{1}{r} \frac{\partial}{\partial r} \left(kr \frac{\partial T}{\partial r} \right) + \frac{\partial}{\partial z} \left(k \frac{\partial T}{\partial z} \right) + \dot{Q}_{Plasma} = \rho C_p \frac{\partial T}{\partial t}$$

$$\dot{Q}_{Plasma} = jE - U(T)$$


$$F = j_i V_i + j_e \left(\phi_w + \frac{2k_b T}{e} \right)$$

$$j_{rich} = \xi T^2 e^{\frac{-\phi_e}{k_b T}}$$



*1Current UL1699B Standard

	Arc Duration Time [sec.]										
	0.20	0.40	0.63	0.83	1.15	1.50	2.00	4.00	6.00	8.00	10.00
100	25.79	27.03	33.06	41.94	61.23	86.90	128.03	297.40	425.27	499.96	538.53
300	25.91	28.87	40.87	58.66	98.42	153.16	242.46	556.19	694.35	743.50	760.65
500	26.05	30.78	49.15	76.87	140.46	229.68	372.76	754.14	861.42	890.81	898.93
650	26.13	32.00	54.49	88.81	168.60	280.93	455.90	846.23	936.74	958.79	964.23
900	26.27	33.99	63.38	108.97	216.57	367.08	584.86	961.27	1031.54	1046.20	1049.29
1200	26.44	36.37	74.23	133.93	276.20	470.04	719.73	1062.64	1116.78	1126.49	1128.25



$$T_{melt} = 155^\circ\text{C}$$

$$T_{ignition} = 450^\circ\text{C}$$

Improve PV System Reliability, by:


Developing PV Reliability Operations Maintenance (PVROM) *process* into a Best Practice

- Failure Reporting, Analysis, and Corrective Action (FRACAS) methodology
- Reveals reliability improvement or decline over time
- Relies on industry participation (data) to demonstrate value

Facilitating working group to tackle topics on improving PV *system* reliability


- O&M Practices and Standards – gaps analysis
- Key Performance Indicators – definitions and applications
- Availability states – Definitions and examples
- Preventative Maintenance

Prediction of O&M Performance




90% double-sided
confidence bounds
shown by red curves

- Using the data from PVROM we can “fit” statistical models




Prediction of O&M Performance

Probability Plot - Matrix Board Failures



- With more data, model confidence increases

Probability Plot - PLC Repairs



Sparing Analysis


- How many spares do we need (on-site or at a depot) to ensure that we are likely not to run out?
- A risk management approach is employed
 - How many hydraulic cylinder spares should we buy to run less than a 10% risk of having no spares?

Year	Expected Number of Failures (in year)	Required Spares (for year)	Risk of Not Having a Spare
1	3.5	6	9.4%
2	18.7	23	9.4%
3	20.1	24	9.2%
4	18.4	22	9.1%
5	19.5	23	9.0%


Recommended spares will vary due to the wear-out failure mode of the component in question

Availability Flow Charting



- PV system “Availability” – where reliability engineering and PV system performance meet
- Goal is to simplify and standardize Availability definition
- Sub-group is working to define terms and relationships



PV Grid Integration at Sandia




Grid compatibility characterization




Technology development and demonstration

Standards, Guidelines, and Procedures



Grid Integration modeling and analysis



Facilities

PSEL & DETL

Photovoltaic Systems Evaluation Laboratory (PSEL) Mission

- Supports Sandia's DOE Program Areas
 - Emerging Technologies
 - Modeling and Analysis
 - Derates
 - Reliability
 - Regional Test Center
- Outdoor and Indoor Module Characterization Facilities
- Outdoor Small Systems Characterization
- Focus on DC measurements



Distributed Energy Test Laboratory (DETL) Array



Table 1: DETL Array Field Overview

Array #	Tech.	Strings	Modules /Str	Instl. Date	Name Plate Rating (kW)
1	a-Si	70	1	2002	3.06
2	c-Si	4	20	2004	6.00
3	mc-Si	4	22	2005	7.04
4	mc-Si	4	22	2005	7.04
5	c-Si	6	7	2005	9.31
6	c-Si	3	28	2005	7.04
7	a-Si	3	2	2006	3.26
8	c-Si	3	21	2006	7.92
9	c-Si	24	12	2008	50.50

Sandia-owned PV Array

- Approximately 95 kW. Used to test fielded performance and reliability of inverters
- Strings are reconfigurable to test various inverter sizes and configurations
- All but one system at fixed latitude tilt
- PSEL performs initial DC acceptance test, and periodic DC performance assessments
- Conducted power degradation analysis in 2008, now looking at backsheet degradation

Thank you

Geoff Klise
gklise@sandia.gov