SAND2015-9889C

Results of Partially-Reflected Critical Experiments in Square-Pitched Arrays of Water-Moderated 6.9 Percent Enriched Fuel Rods

American Nuclear Society

Winter Meeting and Expo

Washington, D.C.

November 10, 2015

Gary A. Harms, John T. Ford, and Rafe D. Campbell
Sandia National Laboratories

SAND2015-XXXX C

Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000.

What's ahead

- This is an account of work at the Sandia Critical Experiments (SCX) completed over past couple of years
- The work was supported by the DOE Nuclear Criticality Safety Program (NCSP)
- The critical experiments were part of NCSP Integral Experiment Request (IER) 208
  - Requests for other critical experiments by the NCSP may be submitted at: http://ncsp.llnl.gov/IERMain.html
- The experiments are evaluated in LEU-COMP-THERM-096 in the *International Handbook of Evaluated Criticality Safety Benchmark Experiments* (Sept. 2015)

Sandia National Laboratories

An overall view of the critical assembly

A cross section of the critical assembly



Sandia National Laboratories

Full vs partial reflection





“Fully-Reflected”

“Partially-Reflected”

A look into the core tank of the assembly



Sandia National Laboratories

The moderator/reflector level in the assembly is controlled by two overflow standpipes



The level of the moderator is measured by a set of four ultrasonic transducers



A look at a different configuration



The core of the critical assembly was simplified for the benchmark model



Sandia National Laboratories

Case 1 – 2025 Fuel Rods
36.54 cm critical water height



Sandia National Laboratories

Case 2 – 2024 Fuel Rods
36.49 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Source Location

Case 3 – 1836 Fuel Rods
31.55 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 4 – 1977 Fuel Rods
37.12 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 5 – 1873 Fuel Rods
38.65 cm critical water height



Sandia National Laboratories

Case 6 – 1781 Fuel Rods
40.39 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 7 – 1673 Fuel Rods
43.10 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 8 – 1573 Fuel Rods
46.57 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 9 – 1525 Fuel Rods
48.70 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 10 – 1600 Fuel Rods
46.79 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 11 – 1600 Fuel Rods
42.19 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 12 – 1600 Fuel Rods
39.60 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 13 – 1600 Fuel Rods
39.03 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 14 – 1600 Fuel Rods
39.98 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 15 – 1600 Fuel Rods
42.57 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 16 – 1600 Fuel Rods
38.69 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 17 – 1600 Fuel Rods
35.31 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 18 – 1600 Fuel Rods
35.10 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Case 19 – 1600 Fuel Rods
37.50 cm critical water height



- Fuel Rod
- Control/Safety Rod
- Empty Grid Location
- Source Location

Reactivity Offset – Multi-group KENOV.a



Code: KENOV.a (SCALE6.1.3)
Cross Sections: 238-group ENDF/B-VII.0

$$\Delta\rho = \frac{k_c - k_e}{k_c k_e}$$

Reactivity Offset – Continuous-Energy KENOV.a



Code: KENOV.a (SCALE6.1.3)
Cross Sections: Continuous-energy ENDF/B-VII.0

$$\Delta\rho = \frac{k_c - k_e}{k_c k_e}$$

Reactivity Offset – Continuous-Energy MCNP6.1



Code: MCNP6.1
Cross Sections: Continuous-energy ENDF/B-VII.1

$$\Delta\rho = \frac{k_c - k_e}{k_c k_e}$$

Our current experiment (1)



Our current experiment (2)



Sandia National Laboratories

What's behind

- This is an account of work at the Sandia Critical Experiments (SCX) completed over past couple of years
- The work was supported by the DOE Nuclear Criticality Safety Program (NCSP)
- The critical experiments were part of NCSP Integral Experiment Request (IER) 208
  - Requests for other critical experiments by the NCSP may be submitted at: http://ncsp.llnl.gov/IERMain.html
- The experiments are evaluated in LEU-COMP-THERM-096 in the *International Handbook of Evaluated Criticality Safety Benchmark Experiments* (Sept. 2015)

Critical Experiments at Sandia