

*Exceptional service in the national interest*



# Load Verification of the ABL Friction Tester



Energetics Characterization, Org. 2555

Jason J. Phillips



Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000.

# Load Variability



## Photos used with permission from:

Hernandez, D., *ABL Friction Tester: Testing Below Self-Correcting Pressure*. 2013  
Presented at the 2013 ET User's Group meeting: Park City, UT.

# Load Variability (cont.)

- An internal SNL customer requested that the displayed load levels be verified.
- How closely do display values match actual loads? How much variance exists?

## ➤ Accepted factory stimulus levels


\*Equivalent to the electronic display value (psi) due to the diameter of the ram

†Based on contact surface area of wheel/anvil, according to the instrument manual

Displayed Load* (lbf)	Actual Pressure†	
	Pa	psi
10	$0.96 \times 10^8$	13,900
13	$1.17 \times 10^8$	17,000
18	$1.48 \times 10^8$	20,700
24	$1.68 \times 10^8$	24,400
32	$1.96 \times 10^8$	28,500
42	$2.31 \times 10^8$	33,300
56	$2.60 \times 10^8$	37,700
75	$2.96 \times 10^8$	43,000
100	$3.36 \times 10^8$	48,600
130	$3.86 \times 10^8$	55,000
180	$4.52 \times 10^8$	65,500
240	$5.17 \times 10^8$	75,000
320	$5.96 \times 10^8$	86,500
420	$6.82 \times 10^8$	99,000
560	$7.93 \times 10^8$	115,000
750	$9.17 \times 10^8$	133,000
1000	$10.5 \times 10^8$	152,000


# Pre-verification

- Zeroing procedure (from the manual) was completed prior to taking measurements.
- Machine was broken-in enough that the ram self-retracted when the bypass valve was opened.
- A calibrated load cell and digital display were acquired to measure the load (lbf) at each stimulus level.



- High accuracy compression load button (model LBMU - Interface, Inc.)
- Model 9320 indicator (Interface, Inc.) was used to take measurements in lbf

# Load Measurement Setup





- 1in x 1in x 3/16in soft steel loading block (Morehouse Instrument Company, Inc.)

# Pre-Adjustment Load Measurements


Displayed Load (lbf)	Measured Load (lbf) - Trial #										Mean	$\sigma$ (95%)
	1	2	3	4	5	6	7	8	9	10		
10	24.5	24.4	26.1	28.4	25.4	28.2	26.5	24.8	27.5	28.1	26.4	3.2
13	26.6	25.4	25.4	30.6	25.5	29.0	28.7	29.3	29.0	30.8	28.0	4.2
18	29.9	27.9	30.6	33.3	28.3	32.1	33.8	31.5	28.7	32.6	30.9	4.2
24	34.5	31.7	31.9	41.1	37.2	33.0	44.6	32.4	33.0	34.9	35.4	8.6
32	37.0	38.6	39.1	44.6	39.0	37.7	46.1	38.3	40.0	39.5	40.0	5.9
42	44.0	45.7	44.1	53.4	44.8	44.1	54.4	42.2	44.1	45.3	46.2	8.3
56	50.7	54.2	51.5	66.1	53.1	51.6	67.1	50.1	57.2	53.6	55.5	12.4
75	64.0	65.4	65.0	81.7	64.8	63.3	83.3	61.9	77.6	66.5	69.4	16.3
100	80.8	109.2	80.6	101.0	85.7	79.6	104.2	78.6	88.8	82.2	89.1	22.8
130	116.2	114.7	109.8	126.5	108.2	103.6	130.9	102.4	113.2	105.3	113.1	19.0
180	152.8	152.2	150.8	168.0	148.4	146.4	173.1	148.8	155.9	146.4	154.3	18.3
240	200.0	201.3	197.1	218.8	199.1	192.7	229.8	192.7	207.0	196.2	203.5	24.1
320	261.6	264.9	284.7	287.2	263.2	255.4	297.5	254.2	275.5	259.2	270.3	30.0
420	347.6	345.1	351.7	366.9	342.0	342.0	375.7	345.7	351.1	340.3	350.8	23.2
560	484.0	480.6	480.3	481.1	478.2	477.8	482.1	478.3	495.4	475.6	481.3	11.0
750	663.0	665.5	668.0	662.4	664.2	661.0	663.1	663.0	669.1	660.0	663.9	5.8
1000	908.7	909.4	914.4	908.8	906.0	905.3	894.6	905.2	914.3	903.4	907.0	11.4

- Trials were split among 3 different operators to maximize the included variability.



Ideal Machine  
vs.  
Pre-adjustment Machine

# Measured Load Error (% Full Scale)





**Note:** Only 8 of 10 trials of data were able to be plotted by the data analysis program.

# Causes of Variability

- Lead cause believed to be excessive mechanical play, or “slop”, present in the system. Each mechanical linkage contributes variability:
  - Wheel-pin
  - Wheel housing-track
  - Wheel housing-ram
  - Anvil carriage-rollers
  - Etc.
- Since multiple mechanical linkages are located between the pressure transducer and the sample interface, all of the variance is incorporated into the displayed load simultaneously.

# Excessive Mechanical Play Reduction







1. Remove the lift arm to prevent damage from over-travel.
2. Remove the wheel and stop block. Slide the anvil carriage to the left to gain clearance. One or both of the guide blocks should be removed, also.
3. Extend the ram downward until the wheel housing clears the track (to allow for rotation).
4. Loosen the bolts, and tighten the wheel housing onto the end of the ram to reduce wobble.
5. Retighten bolts, attempting to minimize the spacing in the gap without severely restricting track motion.
6. Reinstall the guide blocks per the manual, as well as the stop block and wheel.

# Balancing Act: Sloppy vs. Smooth


- Do not overtighten the bolts
  - Track Issues
    - If the left bolt is overtightened, it will restrict ease of motion in the track, contributing to excessively high pressure readings
    - This will also hinder self-retracting of the ram upon opening of the bypass valve.
    - The wheel housing should be snug, yet still slide freely in the track.
    - Light lubrication of the track would be beneficial. A dry lubricant would reduce contamination buildup.
  - Wheel Issues
    - If the right bolt is overtightened, it will increase the difficulty of rotating the wheel between trials
    - This will also increase the difficulty of removing/installing wheels
    - Lubrication is not recommended due to proximity to the sample interface

# Post-Adjustment Load Measurements

Displayed Load (lbf)	Measured Load (lbf) - Trial #										Mean	$\sigma$ (95%)
	1	2	3	4	5	6	7	8	9	10		
10	16.1	11.9	9.5	16.3	8.8	7.8	14.3	10.3	10.9	9.8	11.6	6.0
13	17.1	15.3	16.4	16.7	16.2	11.0	15.5	17.5	14.2	11.7	15.2	4.5
18	20.0	16.7	22.8	21.9	16.8	16.1	20.2	20.0	16.8	17.2	18.9	4.8
24	26.7	20.1	23.9	26.7	26.9	20.2	24.8	25.1	24.4	22.6	24.1	5.0
32	31.9	23.1	30.5	31.5	31.9	25.2	30.5	32.0	31.8	29.4	29.8	6.2
42	39.8	35.9	33.6	40.3	41.1	36.3	40.9	38.0	36.8	35.5	37.8	5.2
56	54.0	45.6	48.8	50.5	45.9	54.7	51.9	51.9	48.7	49.5	50.2	6.1
75	73.4	70.3	61.5	70.1	69.0	73.4	70.5	70.3	67.1	67.0	69.3	7.0
100	92.5	90.8	88.4	91.9	86.5	97.5	91.5	93.6	89.1	90.7	91.3	6.1
130	124.1	119.3	118.0	122.7	114.2	122.8	122.9	119.3	120.1	116.4	120.0	6.4
180	172.8	170.4	164.4	166.4	164.3	166.0	170.8	170.1	170.2	168.6	168.4	5.9
240	222.6	224.6	219.4	218.0	218.6	218.4	232.0	234.5	227.1	224.4	224.0	11.6
320	299.5	297.2	292.1	294.5	296.2	290.4	309.0	307.8	301.2	302.5	299.0	12.4
420	382.1	382.7	384.3	379.0	384.9	376.4	395.6	395.8	391.2	394.2	386.6	14.1
560	523.4	513.4	512.0	509.8	507.9	508.5	524.8	518.9	518.0	518.4	515.5	12.1
750	704.5	700.3	691.9	693.4	694.1	696.6	705.8	701.3	702.3	700.6	699.1	9.6
1000	948.7	945.2	940.8	943.9	943.6	946.0	948.7	947.8	949.4	946.8	946.1	5.5



# Measured Load Error (% Full Scale)



**Note:** Only 8 of 10 trials of data were able to be plotted by the data analysis program.

# Conclusions

- Complete instrument redesign?
  - This would require a large undertaking and much vetting to gain viability and acceptance. This would also require much time and capital.
  - A more practical approach is to improve the existing procedures.
  - Modifying the existing design may be possible to reduce variances.
- A simple procedure to quickly calibrate the hydraulic pressure transducer to more closely match measured load values would be beneficial.
- Remove of as much mechanical play as possible without compromising the instrument functions:
  - Raising/lowering of the wheel carriage, smoothly with minimal binding
  - Rotating/removal and installation of friction wheels

# Acknowledgements

- Jason Ford and Rusty Christensen
- David Hernandez of the Explosive Effects Laboratory, Transportation Security Laboratory, Science & Technology Directorate
- Tom Massis and Rachel Carlson of the Energetics Characterization group at SNL
- Ricky Mertes and Hy Tran of the SNL Primary Standards Laboratory

