



LAWRENCE
LIVERMORE
NATIONAL
LABORATORY

LLNL-TR-728326

Characterization Report for the Demolition and Remodel of B151 Rooms 1318, 1322 and 1326

J. L. Sexton, G. Won

March 31, 2017

Disclaimer

This document was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor Lawrence Livermore National Security, LLC, nor any of their employees makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or Lawrence Livermore National Security, LLC. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States government or Lawrence Livermore National Security, LLC, and shall not be used for advertising or product endorsement purposes.

This work performed under the auspices of the U.S. Department of Energy by Lawrence Livermore National Laboratory under Contract DE-AC52-07NA27344.



Mail Station L-509

Extension 3-8336

March 29, 2017
ESH-T2-17-14511

MEMORANDUM

To: George Kan, Project Manager
From: Jenna Sexton, Geoffrey Won
Subject: *Characterization Report for the Demolition and Remodel of Building 151 Rooms 1318, 1322, and 1326*

Purpose

In support of a remodel for rooms 1318, 1322, and 1326 in building 151, the Environmental Safety and Health (ES&H) team has worked to develop a detailed characterization of contaminants in each room. This report serves as a summary of the results for all radioactive material and Industrial Hygiene (IH) metals sampling performed of accessible areas.

Background

ES&H has performed and supported minor demolition of cabinetry and casework in B151 rooms 1318, 1322, and 1326. Sampling and monitoring for radioactive material and IH metals was performed. In addition to surveying cabinetry, casework, and various laboratory equipment removed from the room, detailed swipe sampling and monitoring of the twelve fume hoods and ventilation ducts for these three labs have been performed.

Currently, all casework, cabinetry, hoods and ventilation ducts in rooms 1318 and 1322 have been swipe sampled and/or directly monitored for various contaminants. Only the fume hoods and ventilation ducts have been sampled and/or directly monitored in room 1326. Since historically all three laboratories have been used for various similar research activities, the results from the casework and cabinetry in 1318 and 1322 can be assumed to closely represent room 1326 as well.

Results

Radioactive Material Characterization

For detection of radioactive material in the laboratories, the following sampling plan was performed:

- Cabinetry and casework
 - 100% direct contamination (i.e. total contamination) for alpha and beta was performed for rooms 1318 and 1322.
 - Composite swipe samples (i.e. removable contamination) for alpha, beta and tritium was performed representing approximately 100% of surfaces for rooms 1318 and 1322.
- Fume Hoods and duct work
 - Large area wipes (i.e. removable contamination) for alpha and beta were performed on the hoods in 1318, 1322, and 1326.
 - Composite swipe samples for alpha, beta, and tritium were performed to represent 100% of accessible areas in the hoods for 1318, 1322, and 1326.
 - Spectroscopy was performed for isotopic identification on elevated swipe results.
 - Direct contamination surveys for alpha and beta were performed on majority of the accessible areas of the hoods in 1318, 1322, and 1326. Survey emphasis was given to areas where large area wipes indicated removable contamination.
 - Two inch holes were cut from each ventilation duct for each hood. A swipe was taken on the inside of the ductwork. Direct contamination readings for alpha and beta were performed on the discs removed from the duct work.
 - Spectroscopy was performed for isotopic identification on elevated swipes and removed metal discs.

Results from all swipe samples, direct readings and isotopic analysis are given below by room and summarized in Table 1:

- Room 1318
 - Floors and walls were not surveyed. However, removable contamination results from cabinetry and casework are indicative of the levels that could be found on the surface of the walls and floors. Based on the history of the room, there is known americium-241 contamination fixed in the floor in front of hood FHE-25. The maximum current fixed contamination level reading is 14,176 dpm alpha. These levels are possibly higher when floor is removed.
 - Majority of the cabinetry and casework surveys indicated little to no contamination. However, two spots were identified with a maximum removable contamination level of 14 dpm/100cm² alpha, 46 dpm/100cm² beta and a direct contamination reading of 1,928 dpm/100 cm² alpha. These items have been removed from room 1318 and properly disposed.
 - As expected, contamination was found in hoods FHE-24 and FHE 25 in room 1318. Figure 1 shows a typical hood with labeled areas to help identify where contamination was found. The main isotope found in these hoods was identified to be americium-241 based on spectroscopy results.



Figure 1: Typical hood for rooms 1318, 1322, and 1326

Below is a breakdown of maximum contamination levels found:

- Fume Hood FHE-25
 - Large area wipe on the bottom plenum indicated 8,183 dpm alpha and 17,219 dpm beta. A follow up swipe indicated 1,270 dpm/100cm² alpha and 1,200 dpm/100cm² beta.
 - Maximum direct contamination readings in accessible areas was found to be 229 dpm/100cm² alpha on the middle plenum and 5,532 dpm/100cm² beta on the bottom plenum. It is important to note that direct alpha contamination measurements in inaccessible areas (eg. plenums) could be lower than actual levels.
 - Removable contamination levels on the ductwork were 158 dpm/100cm² alpha and 204 dpm/100cm² beta.
- Fume Hood FHE-24
 - Large area wipe on the top plenum indicated 320 dpm alpha and 834 dpm beta on the left wall. A follow up swipe indicated 23 dpm/100cm² alpha and 183 dpm/100cm² beta.
 - Maximum direct contamination readings in accessible areas was found to be 2,032 dpm/100cm² beta on the bottom plenum. It is important to note that direct alpha contamination measurements in inaccessible areas (eg. plenums) could be lower than actual levels.
 - Removable contamination levels on the ductwork were 86 dpm/100cm² alpha and 133 dpm/100cm² beta.
- Fume Hood FHE-26 and FHE-27
 - No detectable activity was found for these two hoods or ductwork.

- Room 1322
 - Floors and walls were not surveyed. However, removable contamination results from cabinetry and casework are indicative of the levels that could be found on the surface of the walls and floors.
 - Majority of the cabinetry and casework surveys indicated little to no contamination. However two spots were identified with a maximum removable contamination level of 8 dpm/100cm² alpha and 23 dpm/100cm² beta. A direct contamination reading of 74 dpm/100 cm² alpha and 3,261 dpm/100 cm² was detected. These items have been removed from room 1322 and properly disposed.
 - Contamination was found in the hoods in room 1322. The main isotopes found in these hoods were identified to be americium-241, plutonium-239 and possibly uranium 235 based on spectroscopy results. Below is a breakdown of maximum contamination levels found:
 - Fume Hood FHE-34
 - Large area wipe on the bottom plenum indicated 850 dpm alpha. Swipe results indicated 412 dpm/100cm² alpha and 971 dpm/100cm² beta.
 - Removable contamination levels on the ductwork were 177 dpm/100cm² alpha and 76 dpm/100cm² beta.
 - Fume Hood FHE-35
 - Maximum removable contamination was found to be 3,140 dpm/cm² tritium in the trough.
 - Removable contamination levels on the ductwork were found to be 36 dpm/100cm² tritium.
 - Fume Hood FHE-33
 - Large area wipe on the top plenum indicated 2,176 dpm alpha and 1,968 dpm beta. Swipe results on the trough indicated 1,180 dpm/100cm² alpha and 1,480 dpm/100cm² beta.
 - Maximum direct contamination readings in accessible areas was found to be 111 dpm/100cm² alpha on the bottom plenum. It is important to note that direct alpha contamination measurements in inaccessible areas (eg. plenums) could be lower than actual levels. Significant visible residue also could attenuate any radioactive material present.
 - Removable contamination levels on the ductwork was 21 dpm/100cm² alpha.
 - Fume Hood FHE-32
 - Swipe results on the bottom plenum indicated 9 dpm/100cm² alpha and 13 dpm/100cm² beta.
 - Maximum direct contamination readings in accessible areas was found to be 797 dpm/100cm² beta on the shelf. It is important to note that direct alpha contamination measurements in inaccessible areas (eg. plenums) could be lower than actual levels.
 - No detectable activity was found on the ductwork for this hood.

- Room 1326
 - Floors, walls and cabinetry were not surveyed for this room. As previously stated, results for rooms 1318 and 1322 will be used to represent the levels of contamination.
 - Contamination was found in all four hoods in this room. High levels of contamination were found in hood FHE-45. The trough, plenum, and back wall were not surveyed due to high levels. The main isotopes found in these hoods were identified to be americium-241 and plutonium-239:
 - Fume Hood FHE-42
 - Swipe results indicated 10 dpm/100cm² alpha and 5 dpm/100cm² beta on the back wall.
 - Removable contamination levels on the ductwork was 53 dpm/100cm² alpha.
 - Fume Hood FHE-43
 - Swipe results indicated 3 dpm/100cm² alpha and 4 dpm/100cm² beta on the trough.
 - Removable contamination levels on the ductwork was 7 dpm/100cm² alpha.
 - Fume Hood FHE-44
 - Large area wipes indicated 634 dpm alpha on the hood floor. Swipe results indicated 9 dpm/100cm² alpha and 18 dpm/100cm² beta on the back wall.
 - Removable contamination levels on the ductwork was 12 dpm/100cm² alpha.
 - Fume Hood FHE-45
 - Large area wipes indicated 86,588 dpm alpha and 10,599 dpm beta on the upper ledge of the left wall. Swipe results indicated 13,500 dpm/100cm² alpha, 7,390 dpm/100cm² beta, and 2,900 dpm/100cm² tritium on the same location.
 - Maximum direct contamination readings in accessible areas before surveying stopped were 10,641 dpm/100cm² alpha on the left wall and 4,770 dpm/100cm² beta on the back wall.
 - Removable contamination levels on the ductwork were 1,900 dpm/100 cm² alpha and 2,030 dpm/100 cm².

Table 1: Summary of radioactive contamination results for hoods and ductwork.

Industrial Hygiene Metals Characterization

- Room 1318

Wood casework:

- For some wood casework (four out of twelve sampling batches), lead contamination above the Lead Equipment Release Limit of 0.21 ug/ cm² was detected. The levels ranged from 0.21 to 5.6 ug/ cm².

Fume Hood FHE 24, 25, 26 & 27:

- Lead contamination above the Lead Equipment Release Limit of 0.21 ug/ cm² was detected on the fume hood ducting interior and most trough and plenum surfaces and the levels ranged from 0.21 to 1.5 ug/ cm². Inside of the fume hood FHE-26 trough, beryllium contamination above the release criteria is possible.

- Room 1322

Wood casework:

- For several of the wood casework (one out of seventeen sampling batches), lead contamination above the Lead Equipment Release Limit of 0.21 ug/ cm² was detected. The levels ranged from 0.21 to 0.27 ug/ cm².

Fume Hood FHE 32, 33, 34 & 35:

- Lead contamination above the Lead Equipment Release Limit of 0.21 ug/ cm² was detected on the fume hood ducting interior and most trough and plenum surfaces. The levels ranged from 0.22 to 1.9 ug/ cm².

- Room 1326

Wood casework:

- For most wood casework (six out of nine sampling batches), lead contamination above the Lead Equipment Release Limit of 0.21 ug/ cm² was detected. The levels ranged from 0.22 to 0.65 ug/ cm².
- North lower casework drawers #23 and 25 are considered as contaminated with beryllium above the Release Criteria and were properly disposed.

Fume Hood FHE 42, 43, 44 & 45*:

- Lead contamination above the Lead Equipment Release Limit of 0.21 ug/ cm² was detected on the fume hood ducting interior and most trough surfaces. The levels ranged from 0.22 to 0.61 ug/ cm².
- Cadmium levels of 5.2 ug/ cm², above the cadmium Screening Criteria for Metals Reference Values were detected on the fume hood FHE-42 centrifuge basin/ lid surfaces which are part of the fume hood.
- *Fume hood FHE 45 interior surfaces were not IH Metals surveyed due to high radioactive contamination levels.

Conclusion

ES&H has supported the minor demolition of cabinetry and casework inside building 151 rooms 1318, 1322, and 1326. During the demolition and removal of items from these labs, detailed sampling and monitoring for contaminants was performed in order to develop a characterization report. To date, cabinetry and casework contamination has been primarily lead with some isolated spots of radioactive contamination and beryllium. The maximum level of lead was 5.6 ug/ cm².

Fume hoods and associated duct work were also sampled. The maximum contamination for radioactive materials was found to be approximately 13,500 dpm/100cm² alpha, 7,390 dpm/100cm² beta, and 2,900 dpm/100 cm² tritium in hood FHE-45 in room 1326. The identified isotopes were americium-241, plutonium-239, plutonium-240, and uranium-235. The majority of radioactive contamination levels were found to be in room 1318 hood FHE-25 and room 1326 hood FHE-45. The maximum levels of contamination for IH characterization were 1.9 ug/ cm² of lead inside fume hood trough surfaces, possible above Beryllium Release Criteria levels on fume hood trough surfaces in FHE-26 in room 1318, and 5.2 ug/ cm² of cadmium on the fume hood centrifuge basin/ lid surface.

Detailed surveys of results are available upon request.

Jenna Sexton, Health Physicist
ES&H Team 2

Geoffrey Won, Industrial Hygienist
ES&H Team 2

Copy:

Aiello, Vince	aiello8@llnl.gov
Aldrich, Gwynn	aldrich5@llnl.gov
Borenstein, Paul	borenstein1@llnl.gov
Dell'Acqua, Reno	dellacqua1@llnl.gov
Kan, George	kan2@llnl.gov
Reyes, Myron	reyes31@llnl.gov
Simpson, Tracey	simpson9@llnl.gov
Sutton, Mark	sutton18@llnl.gov
Vellinger, Rob	vellinger1@llnl.gov