

REACTOR OPERATIONS
BROOKHAVEN MEDICAL RESEARCH REACTOR
BROOKHAVEN HIGH FLUX BEAM REACTOR

H. M. Hauptman, Group Leader, Medical Reactor
J. N. Petro, Group Leader, Instrumentation
O. Jacobi, Group Leader, Maintenance
V. Lettieri, Group Leader, Cold Neutron Facility
N. Holden, Research Coordinator
D. Ports, Group Leader, Operations
R. Petricek, Group Leader, Compliance
Approved: David C. Rorer, Manager, Reactor Division

MAY 1995
INFORMAL REPORT

BROOKHAVEN NATIONAL LABORATORY
ASSOCIATED UNIVERSITIES, INC.
UPTON, NEW YORK 11973-5000

under contract No. DE-AC02-76CH00016 with the
United States Department of Energy

Disclaimer

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owed rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

Part I

Brookhaven Medical Research Reactor

1. **Reactor**

The reactor ran for 16 days with 24 startups during the month of May. A total of 131.15 Mwhrs of thermal energy were produced bringing the total to date to 21,939.25 Mwhrs.

2. **Instrumentation**

There were no reportable instrumentation events during the month of May.

3. **Mechanical Maintenance**

All scheduled tickler card maintenance was completed.

4. **Occurrence Reports**

There were no reportable occurrences for the month of May, 1995.

5. **Safety**

There were no reportable first aid or lost time due to accidents reported for the month of May 1995.

BMRR TECHNICAL SPECIFICATION SURVEILLANCE REQUIREMENTS RECORD

MONTH May YEAR 1995

| <u>Requirement</u> | <u>Period</u> | <u>Previous Completion Date</u> | <u>Scheduled Date</u> | <u>Completion Date</u> | <u>Deadline if Not Completed</u> |
|---|---------------|---|---------------------------|----------------------------|--------------------------------------|
| Operations | | | | | |
| Confinement System | | | | | |
| a. Nuclear Incident System (M-4.2.4) | M | 04/17/95 | 05/15/95 | 05/18/95 | |
| b. Bldg. Relief Valves (M-4.2.2) | M | 04/01/95 | 05/01/95 | 05/06/95 | |
| c. Control Rod Seating Lights Battery Check | M | 04/01/95 | 05/01/95 | 05/06/95 | |

Instrumentation

None

Itsrrr/maytechs]

M = Monthly
Q = Quarterly
() = Date of the month in which card is issued
A/2 = Semi-Annually
A = Annually

SUMMARY OF BMRR IRRADIATIONS
05/01/95 TO 05/31/95

| DATE | PROJECT | HOURS | FACILITY | DESCRIPTION OF SAMPLE |
|----------|---------------------|-------|-------------------|-----------------------|
| 05/02/95 | MEDICAL | 0.367 | TREATMENT ROOM #1 | FILMS |
| 05/02/95 | MEDICAL | 0.125 | Pn-TUBE | In-115 |
| 05/02/95 | MEDICAL | 6.050 | RADIAL | CELLS W/B-10 |
| 05/03/95 | MEDICAL | 2.533 | TREATMENT ROOM #2 | TLD's/Au FOILS |
| 05/03/95 | MEDICAL | 2.583 | RADIAL | CELLS W/B-10 |
| 05/04/95 | MEDICAL | 2.617 | RADIAL | CELLS W/B-10 |
| 05/04/95 | DAT | 2.500 | Pn-TUBE | SiO2 SLIDES |
| 05/05/95 | MEDICAL | 5.417 | TREATMENT ROOM #1 | RATS |
| 05/09/95 | MEDICAL | 6.583 | TREATMENT ROOM #1 | RATS |
| 05/10/95 | MEDICAL | 0.250 | Pn-TUBE | Gd-158 |
| 05/12/95 | MEDICAL | 5.483 | RADIAL | CELLS w/B-10 |
| 05/15/95 | MEDICAL | 3.750 | TREATMENT ROOM #1 | RATS |
| 05/16/95 | MEDICAL | 2.333 | TREATMENT ROOM #1 | RATS |
| 05/17/95 | MEDICAL | 5.000 | TREATMENT ROOM #1 | RATS |
| 05/19/95 | MEDICAL | 6.367 | RADIAL | CELLS w/B-10 |
| 05/19/95 | MEDICAL | 0.125 | Pn-TUBE | In-115 STANDARDS |
| 05/19/95 | DAT | 3.750 | Pn-TUBE | SiO2 SLIDES |
| 05/22/95 | INEL & WASH. ST. U. | 5.217 | TREATMENT ROOM #2 | DOGS w/DOSIMETRY |
| 05/23/95 | MEDICAL | 1.700 | RADIAL | CELLS w/B-10 |
| 05/23/95 | INEL & WASH. ST. U. | 5.250 | TREATMENT ROOM #2 | DOGS w/DOSIMETRY |
| 05/24/95 | INEL & WASH. ST. U. | 6.533 | TREATMENT ROOM #2 | DOGS w/DOSIMETRY |
| 05/25/95 | INEL & WASH. ST. U. | 5.633 | TREATMENT ROOM #2 | DOGSw/DOSIMETRY |
| 05/26/95 | INEL & WASH. ST. U. | 1.067 | TREATMENT ROOM #2 | DOGS w/DOSIMETRY |
| 05/26/95 | MEDICAL | 3.033 | RADIAL | CELLS w/B-10 |

TOTAL NO. OF HOURS: 84.26667

TOTAL NO. OF SAMPLE CAPSULES LOADED: 5

PART II

Brookhaven High Flux Beam Reactor


May

31 Days

10776 - 10806

| | | |
|--|---------------------------|------------|
| Reactor Operation to Date | 277,671.30 | MWD |
| Reactor Operation for Month | 814.13 | MWD |
| Hours of Operation | 651.30 | HRS |
| Average Power Level ((MWDx24) / Hours of Operation) | 30.00 | MW |
| Maximum Power Level | 30.00 | MW |
| Downtime | 12.45 | % |
| Electrical Energy Consumed within HFBR Bldg. | 1,038,000. | KWH |
| Electrical Energy Consumed by Sec. Water Pumps | 257,500. | KWH |
| Electrical Energy Consumed in Pumphouse 440V System | 3,300. | KWH |
| Total Electrical Energy Consumed within HFBR Complex | 1,298,800. | KWH |
| Electrical Energy Consumed by CNF Compressor | 261,600. | KWH |
| Elements Charged this Month | 7 | |
| Elements Discharged this Month | 7 | |
| Reactor D ₂ O Inventory (within 200 pounds) | 103,073.00 (46,753.91) | LBS KG) |
| Reactor D ₂ O Isotopic Purity (Average All Systems) | 99.52 | % |
| Helium Consumed (NTP) | 26,734. (756. | CF CM) |
| CO ₂ Consumed | 13,600. (6,168. | LBS KG) |

MAY 1995
HFBR
MAXIMUM POWER LEVEL 30.00 MW
AVERAGE POWER LEVEL 30.00 MW



POWER LEVEL, MEGAWATTS

DATE

2. Explanation of Histogram

Operating Cycle No. 280 was in progress at the beginning of this report period. The reactor was shutdown at 0318 hours on May 28, 1995 for scheduled maintenance and refueling.

3. Operating Difficulties:

None.

4. Reactivity Comments:

The excess reactivity at the end of Operating Cycle No. 280 was 0.0\$.

5. Building Confinement - Test and Changes

A planned building confinement break was initiated May 31, 1995 by placing the Exit Air Bypass Filters in bypass mode to permit painting within the building confinement.

6. Changes to Reactor or Process Systems

Maintenance Replacement Approval (MRA) #94-09 "Inlet Air Handling units AC-1 & AC-2 Removal" was completed in May.

7. Instrumentation

There were no reportable instrumentation events during the month of May.

8. Mechanical Maintenance

All scheduled tickler card maintenance was performed and completed.

9. Occurrence Reports

There was one reportable occurrence during the month of May, 1995.

CH-BH-BNL-HFBR-1995-0004, Personnel Radioactive Contamination, Particle on Vest Button. - 5/3/95.

10. Experimental Facilities

Experimental work was in progress on the following beam lines from May 1 - 28, 1995. The reactor was shutdown for maintenance on May 28, 1995.

H-1B Physics Department - Nuclear Structure Group - work in progress.

H-1A Powder diffractometer in service.

H-2 Physics Department - TRISTAN Experiment Dismantled

H-3 Biology Department - On 5/15 experiment shutdown for modification work.

H-3A Experimental work in progress.

H-3B Experimental work in progress.

H-4 Physics Department - Neutron Scattering Group.

H-4M Experimental work in progress.

H-4S Experimental work in progress.

H-5 Chemistry Department - Chemistry Department Neutron Scattering Group.

H-6 Chemistry Department - Chemical Crystallography Group.

H-6M & H-6S - Experimental work in progress.

H-7 Physics Department - Neutron Scattering Group.

H-8 Physics Department - Neutron Scattering Group.

H-9 Reactor Division - Cold Neutron Facility.

H-9A Physics - Experimental work in progress.

H-9B Biology - Experimental work in progress.

H-9R Physics - Neutron Reflectometer in-service.

11. Cold Neutron Facility

Operating History

The CNF was operating at the beginning of the reporting period. The CNF shutdown with the reactor on May 28th at 0318 hours for scheduled maintenance. The CNF remained shutdown for the remainder of the reporting period.

The CNF operated 651.3 hours during May and produced cold neutrons 100% of the time that the reactor was at full power.

Operating Difficulties

None.

Maintenance Activities

All required maintenance and surveillance testing was completed. Hardware installation and acceptance testing for MRA 95-05, Redesign of Valve N501 and Relocating PIAN501 Pressure Tap, was completed.

12. Safety

There were no reportable first aid accidents for the month of May.

13. Fuel Element Inventory

Elements in Use as of May 31, 1995

| | | | |
|---------------|---------|---------|----|
| In Reactor(s) | HFBR 28 | BMRR 36 | 64 |
|---------------|---------|---------|----|

Element Movement during the Month

| | |
|--------------------|---|
| Charged to reactor | 0 |
|--------------------|---|

| | |
|-------------------------|---|
| Discharged from reactor | 0 |
|-------------------------|---|

**HFBR TECHNICAL SAFETY
SURVEILLANCE REQUIREMENTS RECORD**

May 1995.

| Requirement | Tech Spec Period | Previous Completion Date | Current Completion Date | Tech Spec Deadline |
|---|------------------|--------------------------|-------------------------|--------------------|
| IC 2.1.exp Chloride Content in Experimental System BIMONTHLY | M | 05/02/95 | 05/17/95 | 06/24/95 |
| IC 2.1.pri Chloride Content in Primary System BIMONTHLY | M | 05/09/95 | 05/17/95 | 06/24/95 |
| IR 2.exp Isotopic Purity of Experimental System WEEKLY | M | 05/09/95 | 05/17/95 | 06/24/95 |
| IR 2.pri Isotopic Purity of Primary System WEEKLY | M | 05/09/95 | 05/17/95 | 06/24/95 |
| MIS 1.1 Determination of pD with Orion pH meter (Primary System) WEEKLY | M | 05/09/95 | 05/26/95 | 07/03/95 |
| TC 302 Criticality Alarm System Operability Test MONTHLY | M | 04/01/95 | 05/01/95 | 06/08/95 |
| TC 310 SPAM Station Checks MONTHLY | M | 04/25/95 | 05/15/95 | 06/22/95 |
| TC 175 Main Control Rod SCRAM Times (Digital System) JAN/APR/JUL/OCT | 3M | 04/15/95 | 05/28/95 | 09/17/95 |
| TC 117 Bldg. Confinement Leak Rate MAR/SEP | 2y/6M DUE | 09/25/94 | 01/28/95 | 09/09/95 |
| TC 131 Poison Water Chemical Content MAY | A DUE | 06/13/94 | 01/10/95 | 04/10/96 |

| Requirement | Tech Spec Period | Previous Completion Date | Current Completion Date | Tech Spec Deadline |
|--|---------------------|--------------------------------|-------------------------------|-----------------------|
| TC 225 HFBR Technical Specification Review APR | A DUE | | 04/29/94 | 07/29/95 |
| TC 325 Line Management Responsibilities/ Authority at BNL Reacto MAY | A | 05/20/94 | 05/19/95 | 08/19/96 |
| TC 163 Test & Inspection of Poison Water Dump Valves MAY 1995 | 2Y DUE | 04/09/91 | 05/13/93 | 11/13/95 |
| TC 307 SPAM Drum Station Gadolinium Content MAY 1995 | 2Y | 05/27/93 | 05/31/95 | 11/30/97 |
| TC 308 SPAM Flexible Hose Pressure Test MAY 1995 | 2Y | 04/30/93 | 05/30/95 | 11/30/97 |
| TC 309 SPAM Station Operability Check MAY 1995 | 2Y | 05/19/93 | 05/31/95 | 11/30/97 |
| TC 205A.5Y Load Test - 250V DC Batteries NO. 1 APR 1995 | 5Y DUE | | 02/21/91 | 08/21/96 |
| TC 205B.5Y Load Test - 250V DC Batteries NO. 2 APR 1995 | 5Y DUE | | 02/25/91 | 08/25/96 |
| HE 3&11(A) 24 VDC Battery Float Voltage MONTHLY | M DUE | 03/31/95 | 04/28/95 | 06/05/95 |
| HB 26 RRa-100 Calibration MAY | A DUE | 05/03/93 | 04/27/94 | 07/27/95 |
| HB 27 RRa-105 Calibration APR | A | 04/22/94 | 05/04/95 | 08/04/96 |

| Requirement | Tech Spec Period | Previous Completion Date | Current Completion Date | Tech Spec Deadline |
|---|--|--------------------------|-------------------------|--------------------|
| HB 39 RRA-306 Calibration APR | A | 04/15/94 | 05/05/95 | 08/05/96 |
| HC 1&5 Count Rate Ch 7&8 Calibration MAY | A | | 05/10/95 | 08/10/96 |
| HE 14 Electronic Alarm Module Calibration (24VDC Annun Relay) MAY | A DUE | | | 09/30/95 |
| HP 36 LI-107 Calibration FEB | A OVERDUE <i>NOTE: LI107 is out of service</i> | 02/02/93 | 02/10/94 | 05/10/95 |
| HT 27 FRa-201 Calibration MAY | A DUE | 05/12/93 | 04/25/94 | 07/25/95 |
| HT 28 FI-202 Calibration MAY | A DUE | 05/11/93 | 04/26/94 | 07/26/95 |
| HT 47 FI-207 Calibration MAY | A DUE | 05/11/93 | 04/28/94 | 07/28/95 |
| TC 627E 250V Monthly Battery Inspection MONTHLY | M | 04/03/95 | 05/02/95 | 06/09/95 |
| TC 632E Monthly Pony Motor Battery Inspection MONTHLY | M | 04/03/95 | 05/02/95 | 06/09/95 |

...end...

SUMMARY OF HFBR IRRADIATIONS
05/01/95 TO 05/31/95

| DATE | PROJECT | HOURS | FACILITY | DESCRIPTION OF SAMPLE |
|----------|-------------------|----------|----------|---------------------------------------|
| 05/02/95 | MEDICAL | 96.000 | V-16 | TiO2 (Ti-47) |
| 05/08/95 | PHYSICS | 70.900 | V-14 | Cu-63 |
| 05/09/95 | DAT | 0.333 | V-11 | SiO2 SLIDES |
| 05/16/95 | CHEMISTRY | 20.000 | V-10 | LIMESTONE |
| 05/22/95 | UNIV. OF MARYLAND | 4.000 | V-14 | TEFLON FILTERS |
| 05/22/95 | TEL AVIV UNIV. | 8.000 | V-11 | Au/Ir ON SILICON & GRAPHITE WAFERS |
| 05/23/95 | CHEMISTRY | 20.617 | V-10 | LIMESTONE |
| 05/24/95 | LOS ALAMOS | 2661.700 | V-12 | Mg3Te06 (Te-128) |
| 05/25/95 | DAT | 0.333 | V-11 | SiO2 SLIDES |

TOTAL NO. OF HOURS: 2881.883

TOTAL NO. OF SAMPLE CAPSULES LOADED: 9

Page 1

End of Report