


Exceptional service in the national interest



CONTAIN-LMR Sodium Fire Benchmarking

JAEA Pool Fire Experiments F7-1 and F7-2

Andrew J. Clark & Matthew R. Denman

Civil Nuclear Energy Research and Development Working Group

January 16th, 2017

Objectives


- Review JAEA Pool Fire Experiments
- Discuss modeling results for F7-1 experiment
- Discuss modeling results for F7-2 experiment

Test Matrix

Test ID	Test Originator	Open or Closed to the Environment	Pool/Spray	Amount of Sodium (kg)	Thickness Ratio (liquid sodium/stainless steel)	Average Peak Temperature at bottom of pan (°C)
P1	SNL	Open	Pool	2.6	0.7	320
P2	SNL	Open	Pool	2.6	0.7	320
P3	SNL	Open	Pool	4.4	11.5	800
P4	SNL	Open	Pool	1.0	5.9	780
P5	SNL	Open	Pool	-	-	-
P6	SNL	Open	Pool	4.8	1.3	480
P7	SNL	Open	Pool	7.8	2.0	600
P8	SNL	Open	Pool	1.6	0.4	220
P9	SNL	Open	Pool	6.0	1.6	490
P10	SNL	Open	Pool	11.6	3.0	746
P11	SNL	Open	Pool	9.6	2.5	648
T3	SNL	Closed	Spray	20	-	259 (atmosphere)
T4	SNL	Closed	Spray	20	-	1205 (atmosphere)
F7-1	JAEA	Closed	Pool	4.94	?	616
F7-2	JAEA	Closed	Pool	4.94	?	675


JAEA Sodium Pool Fire Experiments

- F7-1:
 - Nozzle elevation: 0.1 m
 - Leakage Rate: 11.8 kg/hr
 - Leakage Mass: 4.94 kg
 - Initial Sodium Temperature: 507°C
- F7-2:
 - Nozzle elevation: 1.5 m → Spray fire?
 - Leakage Rate: 11.9 kg/hr
 - Leakage Mass: 4.94 kg
 - Initial Sodium Temperature: 507°C




Questions about Experiment

- Area or diameter of outlet duct?
 - Clarify vessel volume: 2.65 m³ or 3.0 m³?
- Steel liner thickness?
 - Thickness of vessel?
 - Is the vessel insulated?
- Does elevated F7-2 nozzle height cause any spray fire phenomena?
 - What is the expected droplet diameter coming out of the nozzle?
- Is there a catch pan in vessel for sodium?
 - Are thermocouples on top or bottom of liner?



JAEA F7-1 Experiment

Contain-LMR



*Exceptional
service
in the
national
interest*



Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000. SAND NO. 2011-XXXXP

SAND20XX-XXXX


F7-1 Preliminary Results

Terms	CONTAIN-LMR
Vessel free volume	2.65m ³
Vessel thickness	0.05m(5.0cm)
Vessel wall emissivity	0.9 [-]
Droplet height	0.1m
Leak Rate	3.3g/s
Initial Sodium temperature	505°C
Sodium pool fire	Activated
Pool fire ratios (<i>f1, f2, f3, f4, f5</i>)	0.5, 0.7, 0.9, 0.9, 1510
★ Atmospheric chemistry	Deactivated
Initial gas temperature	17.5°C
Initial gas pressure	101.3kPa A
Oxygen concentration (molar fraction)	0.21 [-]

- Pool fire ratio *f5* signals when the pool fire model should be turned off [seconds].


Vessel Temperature

- Vessel temperature poorly predicted.
 - Specifically, poor prediction of steady vessel heat up as seen in data.




Catch Pan Temperature

- Poor estimation of catch pan and sodium pool temperature.
 - Investigate the heat conduction parameters from pool to catch pan.
- CLMR does not model pool spreading and thus, cannot model catch pan temperatures at different positions.





Oxygen Concentration

- Initial spike is most likely due to the air flowrate through vessel.
 - For CLMR, we will consider letting vessel equalize for some time before initiating pool fire.
- New input for turning off pool fire → set to 1505 s.
 - Large increase due to termination of pool burning;
 - No more oxygen being consumed.




Aerosol Concentration

- Aerosol concentrations for Test Section do not follow trend, but approximately match the peak concentration.
- Aerosol concentration for Outlet Duct are off by several orders of magnitude. Most likely due to aerosol deposition inside vessel.



Test Section




Outlet Duct

Questions about F7-1 and F7-2

- Data is labeled as “[g-Na/m³]”, but aerosols will consist of all Na byproducts?
- For “Test Section”, is this data for airborne concentration or deposited?
 - Similarly for “Outlet Duct”.
- Area/diameter of outlet nozzle?



F7-1 Sensitivity – Vessel Volume

- Vessel heat up is more relaxed; i.e., no initial spike in temperature.




Future F7-1 Sensitivities

- Pool fire ratios
 - f1 → investigate effect oxygen concentration.
 - f2 → investigate effect on vessel temperature and catch pan temperature.
 - f3 and f4 → investigate effect on aerosol concentrations.
- Atmospheric chemistry
 - Investigate effect on all data.



JAEA F7-2 Experiment

Contain-LMR



*Exceptional
service
in the
national
interest*



Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000. SAND NO. 2011-XXXXP

SAND20XX-XXXX


F7-2 Preliminary Results

Terms	CONTAIN-LMR
Vessel free volume	2.65m ³
Vessel thickness	0.05m(5.0cm)
Vessel wall emissivity	0.9 [-]
Spray height	1.5m
Leakage Rate	3.3g/s
Initial Sodium temperature	505°C
Mean droplet diameter (volumetric mean)	10mm
Sodium pool fire	Activated
Pool fire ratios (<i>f1, f2, f3, f4, f5</i>)	0.5, 0.7, 0.9, 0.9, 1510
Atmospheric chemistry	Deactivated
Initial gas temperature	17.5°C
Initial gas pressure	101.3kPa A
Oxygen concentration (molar fraction)	0.21 [-]


- Implement sodium source as a sodium spray fire.

F7-2 Preliminary Results

- Behavior during first 400 seconds is different. That is, following the initial depressurization, it takes longer for vessel to heat up.



F7-2



F7-1

Future F7-2 Sensitivities

- Spray fire parameters
- Pool fire ratios
 - f1 → investigate effect oxygen concentration.
 - f2 → investigate effect on vessel temperature and catch pan temperature.
 - f3 and f4 → investigate effect on aerosol concentrations.
- Atmospheric chemistry
 - Investigate effect on all data.

- Predictions for both experiments are inaccurate.
 - All results follow the same general trend; i.e., rapid increase, followed by result plateau, and rapid decrease to zero.
- Volume sensitivity possibly points to unrealistic sodium pool influence.
 - Attempt to delay sodium pool source to see how vessel responds without initial sodium source.
- Aerosol concentrations in outlet duct off by several orders of magnitude.
 - Possible that significant deposition is occurring inside the vessel.
- Pool spreading not modeled.

Future Work for F7-1 and F7-2

- Run models using CONTAIN2-LMR.
- Perform thorough sensitivity analysis and deliver results in letter report (end of February).
- Use SNL Surtsey Outdoor pool fire test for further sodium pool fire investigations.
- Compare CONTAIN-LMR and SPHINCS models with burning rate equations developed by Tara Olivier¹.
- Setup CONTAIN-LMR with DAKOTA².

¹T.J. Olivier, et al., "Metal Fires and Their Implications for Advance Reactors Part 3: Experimental and Modeling Results", SAND2010-7113, Sandia National Laboratories, Albuquerque, NM, (2010).

²Adams, B.M., Bauman, L.E., Bohnhoff, W.J., Dalbey, K.R., Ebeida, M.S., Eddy, J.P., Eldred, M.S., Hough, P.D., Hu, K.T., Jakeman, J.D., Stephens, J.A., Swiler, L.P., Vigil, D.M., and Wildey, T.M., "[Dakota. A Multilevel Parallel Object-Oriented Framework for Design Optimization, Parameter Estimation, Uncertainty Quantification, and Sensitivity Analysis: Version 6.0 User's Manual](#)," Sandia Technical Report SAND2014-4633, July 2014. Updated November 2016 ([Version 6.5](#)).