

Exceptional service in the national interest




2.1
MELCOR Computer Code
Application Guidance for
Leak Path Factor in
Documented Safety Analysis

Final Report



U.S. Department of Energy
Office of Environment, Safety and Health
U.S. Department of Energy
1000 Independence Ave., S.W.
Washington, DC 20585-2040

—May 2004— 2016



NSRD-10: Leak Path Factor Guidance Using MELCOR

Acknowledgement

We are grateful that DOE consistently fund Sandia to work on Nuclear Safety Research & Development (NSR&D) Program at DOE Office of Nuclear Safety under Dr. Alan Levin and Mr. Patrick Frias. This work is funded under WAS Project# 2015-AU30-SNL-MELCOR.

Presented by David Louie , Ph.D.
dlouie@sandia.gov

2017 EFCOG NFS Workshop – NSR&D Subgroup

March 14, 2017

SAND2017-XXXX




Sandia National Laboratories is a multi-mission laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000.

MELCOR Code Development




- MELCOR is developed by SNL for
 - US Nuclear Regulatory Commission
 - Division of Systems Analysis
 - Since early 1980s
- MELCOR Development is also strongly influenced by the participation of many International Partners through CSARP
 - Development Contributions – New models
 - Development Recommendations
 - Validation
- Other cooperation also may influence the development of MELCOR:
 - Sodium fast reactors – CONTAIN-LMR implementation, TerraPower
 - Small moderator reactors – NuScale
 - Source term Spent Fuel Reprocessing Project



- MELCOR code version:
 - 1.8.5, 1.8.6 – Legacy
 - 2.x – Current
 - 3 – Coming soon

MELCOR Workshops & Meetings



- 2016 European MELCOR User Group (EMUG)

- Hosted by Imperial College London & AMEC
- April 6-7, 2016

- MELCOR User's Workshop in Ukraine

- Hosted by SSTC in Kiev
- April 25-28, 2016

- 2016 CSARP/MCAP

- September 12, 2016
- Bethesda, MD
- No Workshop

- 2016 Asian MELCOR User Group (AMUG)


- Hosted by SPICRI & NRSC (Beijing)
- October 17-21, 2016
- MELCOR/MACCS Workshop

Major Objectives

- Replace the obsolete MELCOR 1.8.5 LPF Guidance Report in the DOE Repository
 - MELCOR 1.8.5 or 1.8.6 is not supported by Sandia
 - Only verification tests included
- 2016 MELCOR Guidance Report development include:
 - Validation tests
 - reactor and non-reactor experiments, particularly for aerosol physics
 - Analytical tests
 - Verification tests
 - Version to version comparison - MELCOR 1.8.5, 1.8.6 and 2.1
 - Additional verifications other than those in MELCOR 1.8.5 guidance report
 - Best practices for common accident scenarios encountered at DOE facilities

MELCOR Code Validation




- Separate effects tests
 - More tightly controlled conditions
 - Limited or specific range of phenomena
- Integral tests
 - Combine many simultaneous physics aspects
 - Often less precisely characterized test conditions
 - Broader range of phenomena investigated
- Actual Accident Studies: TMI-2, Fukushima
 - Combines all relevant physics at full scale
 - Least well instrumented and characterized “experiment”
 - An ultimate basis for code validation
 - Bearing in mind, not every accident should be expected to be the same as TMI-2
- Participation in multiple International Standard Problems
- SAND2016 6693R MELCOR 2.1 Assessment Report has been published



Verification and Validation Tests

- In addition to those identified from MELCOR Assessment Report
- We have identified:
 - Fire test –LLNL Enclosure Fire – from Validation document of CFAST
 - Aerosol resuspension test – STORM SR-11 Test
 - Additional experiments from DOE-HDBK-3010-94
 - Wind Tunnel Gasoline pool fire tests conducted at the RART facility
 - Spills and Pressurized Release Tests conducted in RART
- Verification tests
 - Sample problems in Obsolete MELCOR 1.8.5 guidance report
 - Version-to-version comparison: MELCOR 1.8.5, 1.8.6 and 2.1

LLNL Enclosure Fire Test (CFAST)



*The burner is located in this volume. The external sources (CO₂ and H₂O) and sink (O₂) will be modeled. Appropriate control functions to model the combustion are modeled in addition to the specific flow rate of the air flow and combustible power for the tests.

LLNL_Enclosure_Exp_Flow_Diagram_v2.vsd

Test 9

Time (s)	Air Flow (kg/s)	Fuel Flow (kg.s)	O ₂ Fraction	ΔP (Pa)	CO ₂ Fraction	West Upper TC (K)	West Middle TC (K)	West Bottom TC (K)
0	0.565	0.0	0.208	-398	0.0005	302.15	302.15	302.15
500	0.491	0.0041	0.185	-297	0.0140	399.15	386.15	332.15
1000	0.474	0.0040	0.1822	-292	0.0156	413.15	398.15	339.15
2000	0.463	0.0042	0.1809	-287	0.0159	425.15	413.15	346.15
3000	0.464	0.0039	0.1824	-278	0.0154	427.15	413.15	399.15
4000	0.461	0.0040	0.1819	-261	0.0157	434.15	419.15	405.15



Test 11

Time (s)	Air Flow (kg/s)	Fuel Flow (kg.s)	O ₂ Fraction	ΔP (Pa)	CO ₂ Fraction	West Upper TC (K)	West Middle TC (K)	West Bottom TC (K)
0	0.240	0.0	0.2098	-75	0.0004	292.15	292.15	292.15
500	0.222	0.0040	0.1705	-42	0.0220	408.15	394.15	339.15
1000	0.221	0.0040	0.1546	-39	0.0289	422.15	408.15	349.15
2000	0.210	0.0040	0.1486	-45	0.0325	437.15	421.15	360.15
3000	0.207	0.0040	0.1473	-38	0.0326	444.15	429.15	366.15
4000	0.204	0.0040	0.1460	-31	0.0335	452.15	436.15	373.15





LLNL Fire Test Results




Test 9



Test 11





STORM SR-11 Resuspension Test




MELCOR predicted ~80 g versus experimental result of 113.3 g for SnO₂

Gasoline Pool Fire in Wind Tunnel



Tunnel_fire_ver0.vsd



Gasoline Pool Fire Results


- 19.5 g UO₂ in 1 Gallon gasoline
 - 6% sourced into tunnel at 0 s according to Fuego
 - 94% sourced into pan before start of resuspension phase

Bin #	Mass Fraction
1	0.008086
2	0.051213
3	0.09973
4	0.107817
5	0.161725
6	0.161725
7	0.107817
8	0.107817
9	0.086253
10	0.107817


Experimental Data	MELCOR 2.1
During Fire – ARF=0.0012 Mass=2.34E-05 kg	During Fire – ARF= 0.0606 1.1836E-03 kg (Adjust to total area of the sampling*) Mass=2.94E-05 kg
During Resuspension- ARF=9.0E-4 Mass=1.755E-05 kg	During Resuspension (after fire gone) ARF=0.0 Mass=0.0 kg

*Total sampling cross section fraction to the wind tunnel cross section area of 0.025


UO₂ Airborne Release Masses in Volumes



Power Release Experiment from PNL




[Sutter 1981]




[Sutter 1983]

Parameter	MELCOR
<u>Dimension</u>	
<u>PARE or beaker volume</u>	862 cm ³
<u>RART model</u>	3 m × 2.9 m dia.
1-volume (1V)	1V
5-vol: A1 to A5 in Fig. 1	5V
15-vol: A1 to A5 × R1 to R3 in Fig. 1	15V
<u>Assumptions</u>	
<u>Aerosol min and max diameters</u>	0.8 and 50 µm
<u>Pressurized Case</u>	
Rupture disk timing	0.001 s
Aerosol source timing	< 0.001 s
<u>Spill Case</u>	
Aerosol source timing	0.05 s




Spill_15V_model_rev2.vsd

PARE*




Pressurized_release_15V_model_rev1.vsd




[Sutter 1983]

Power Release Results

Gravitational Spill at 3 m



Pressurized Release at 50 psig (0.345 MPa), 250 psig (1.72 MPa) and 500 psig (3.45 MPa)





Best Practices

- Cover major accident scenarios in using MELCOR
 - Explosions
 - Analytical approach using control functions
 - Computational approach using BLASTX
 - Proper accounting for product gas generation and energies
 - Fires
 - Use Control function package to fire (demonstrated in here)
 - Results are encouraging, compared well with CFAST
 - Inadvertent of nuclear criticality
 - Similar approach as in explosion, except no by-product gas generation
 - 10^{18} fissions ~ 32 MJ.
 - Spills
 - Demonstrated in the validation tests shown here
- Specified models
 - Default values
 - Environment volume modeling – time-independent volume
 - Aerosol modeling
 - Counter-Current Flow Model for Fire

Counter Current Flow Model Applications

- It has been applied to model natural recirculation of hot and cold gas exchange during a severe accident condition
 - With the use of CFD results, the results should match better
- Similarly, it can be applied to model the doorway between the fire room and a cooler corridor
 - It is only applicable for the horizontal flow paths



Summary

- A draft report of MELCOR 2.1 guidance for LPF applications has been completed, and has been reviewed externally.
 - Document applicable reactor experiment data, and additional validation experiments from DOE-HDBK-3010
 - Provide additional specific validations:
 - Fire experiment with CFAST – LLNL Enclosure Fire
 - STORM Resuspension Phase Experiment
 - Gasoline pool fire experiment at PNL
 - Powder release experiments
 - Develop a number best practice on modeling explosion, fire, nuclear criticality and spill accidents

Future Expectations



- MELCOR 2.X is ready to be used in DOE LPF analysis, replacing the old LPF analysis using obsolete versions of MELCOR
- Create DMUG (DOE LPF MELCOR user group)
 - Conduct MELCOR workshop
 - MELCOR 1.8.5/1.8.6 conversion to MELCOR 2.1 or later version
 - LPF analysis exchange
 - Any Question????

Back up slides or hyperlink




Visualization and Graphical Interface

- Visualization is important for improving quality of calculations
 - Identification of modeling errors and issues
- Graphical user interface
 - Can reduce input errors
 - Simplifies input for new users
- SNAP MELCOR 2.1 Plugin
 - Version 1.0.0 - Released 7/17/09
 - Current version 2.1.1 – Released 2/24/12
 - Will convert a 1.8.6 input deck to 2.1 and back to 1.8.6
 - Sandia is working with SNAP developers to recommend enhancements for MELCOR plugin
- 2011 workshop focused on the use of SNAP
- Model Editor -Components
 - Tree Structure organization
 - Arranged according to MELCOR package
 - ASCII view of object available
 - Organize components
 - DIFF capability for components
- Views
 - Trend plots
 - Custom animations
 - Others



Gasoline Pool Fire MELCOR Model



Tunnel_fire_ver0.vsdx



20