

# Reliability Impacts to PV Plant Performance: Methods and Tools for O&M Insight

*EPRI Generation Advisory and Council Meeting*

Geoffrey T. Klise  
Sandia National Laboratories  
February 7, 2017

SAND2016-XXXXC

# Acknowledgements


- Michael Bolen – EPRI, for the invitation to present Sandia's research efforts in PV system reliability
- Olga Lavrova from Sandia for reliability analysis
- Janine Freeman from NREL for implementing Sandia's PV-RPM algorithm into SAM
- DOE SunShot PV and Soft Costs Programs for funding this research

# Outline


- EPRI and Sandia Relationship
- What does reliability help provide insight to?
- Process for evaluating reliability impacts to performance
- Levels of Data Collection & Storage efforts
- Data Analysis
  - Summary Statistics
  - Energy Impacts from Inverter Events
- Data Application – Further Analysis
  - PV Performance Modeling
  - Proforma O&M Cost Modeling

# EPRI and Sandia Relationship

- Formal CRADA agreement from 2012 through June 2017 in the area of Reliability and O&M. Collaborative research includes:
  - Budgeting for Solar PV Plant O&M: Practices and Pricing
  - PVROM effort, laying foundation for best practices in reliability data collection



2013  
EPRI/Sandia  
Project Report



2014  
EPRI/Sandia  
Project Report



# EPRI and Sandia Relationship

## Additional CRADA activities:

- 2016 PV Systems Symposium
  - PV Performance Modeling Workshop
  - PV Life Cycle Reliability Workshop
- 2014 PV Systems Symposium
  - PV Performance Modeling Workshop
  - PV Distribution System Modeling Workshop
  - PV Operations & Maintenance Workshop
  - EPRI Smart Inverter Workshop
- 2013 PV Systems Symposium
  - Operations and Maintenance Workshop
  - Inverter Reliability Workshop
  - PV Performance Modeling Workshop

**All held in Santa Clara, CA**

*Events well attended each year and received positive feedback from industry participants*

# EPRI and Sandia Relationship

## Other Projects:

- PREDICTS 2 Project (DOE funded, EPRI Awardee, SNL partner)
  - EPRI led with SNL as the sub. Goal: validate a new Qual+ Accelerated lifetime testing protocol to improve IEC 61215
  - No CRADA
- California Solar Initiative (EPRI Awardee, SNL partner)
  - CSI 3: Screening Distribution Feeders: Alternatives to the 15% Rule
  - CSI 4: Analysis to Inform California Grid Integration Rules for PV
  - All Under different CRADA
- SUNRISE (DOE funded, SNL partner)
  - Transmission and Distribution Grid Integration
  - Under different CRADA


# Process for Evaluating Reliability Impacts to Performance

Raw Data Generation

Data Collection & Storage

Data Analysis

Data Application and Further Analysis



# Reliability Spectrum of Data Collection & Storage Efforts


*Designed for Reliability Analysis*

Yes

Somewhat

No

## PVROM



- Highly structured series-parallel component dependencies
- Allows for less data manipulation for reliability analysis
- Component downtime and energy lost

## Event Database

A	B	C	D	E	F	G
Level	Part Number	Part Description	Part Ref.	Serial Number	Quantity	Notes
1	1	PERF	Performance System	BO_PVTS	1	12/30/2011
2	2	ECON	Electrical Connections	BO_ECON	1	12/30/2011
2	2	CIVL	Structure Components	BO_CIVL	1	12/30/2011
3	3	FENCE	Perimeter Fences	BO_FENCE	1	12/30/2011
3	3	PERIM	All perimeter fence inside perimeter	BO_PERIM	1	12/30/2011
4	4	AC-EQUIPMENT	AC Protection Equipment	BO_AC-PRO	1	12/30/2011
5	5	BATTERY	Battery Banks	BO_BATBANK	1	12/30/2011
5	5	BATCHG	Battery Charger	BO_BATCHG	1	12/30/2011
5	5	AC-OTHER	Other AC Electrical Components	BO_AC-OTHER	1	12/30/2011
5	5	AC-S-OTHER	Other AC Structure Components	BO_S-OTHER	1	12/30/2011
5	5	AC-M-OTHER	Other AC Miscellaneous Components	BO_M-OTHER	1	12/30/2011
5	5	AC-SCADA	Substation SCADA Equipment	BO_AC-SCADA	1	12/30/2011
5	5	DISCON	DC Disconnect Boxes	BO_DISCON	1	12/30/2011
5	5	TXS120V	Padmount 12kV Transformer	BO_TXS120V-01	1	12/30/2011
5	5	TXS120V	Padmount 12kV Transformer	BO_TXS120V-02	1	12/30/2011
5	5	TXS120V	Padmount 12kV Transformer	BO_TXS120V-03	1	12/30/2011
5	5	DISCON	DC Disconnect Boxes	BO_DISCON	1	12/30/2011
5	5	SWITCHGEAR	Metal Clad Switchgear	BO_SWITCHGEAR	1	12/30/2011
5	5	SEL351	SEL 351 Relay	BO_SEL351	1	12/30/2011
5	5	MET	MET	BO_MET	1	12/30/2011
5	5	TC42	Microflame SM-13-72 Pyrometer	BO_TC42	1	12/30/2011
5	5	LO00K	Lector U-2000 Pyrometer	BO_LO00K_POA	1	12/30/2011
5	5	LO00K	Lector U-2000 Pyrometer	BO_LO00K_GHE	1	12/30/2011
5	5	CT225	Ambient Temperature/Humidity Sensor	BO_CT225	1	12/30/2011
5	5	SP2000	Amber Solar Panel Sensors	BO_SP2000	1	12/30/2011
5	5	TRIB	Tipping Hail Bucket	BO_TRIB	1	12/30/2011
5	5	CR3K	Cambridge Scientific CR3000 DataLogger	BO_CR3K	1	12/30/2011
5	5	TR02	Back of Module Temperature	BO_TR02	1	12/30/2011
5	5	TRM2	Back of Module Temperature	BO_TRM2	1	12/30/2011
5	5	MISC	Miscellaneous Supporting Structures	BO_METMISC	1	12/30/2011
5	5	ITD	IT Devices	BO_ITD	1	12/30/2011
5	5	SHAK300	End Sack 300 Meter	BO_SHAK300	1	12/30/2011

- Somewhat structured based on component tickets
- Dependent tickets
- Component downtime and energy lost

## Event Logs

Visually inspect all feeder terminations for corrosion.

No corroded feeder terminations were observed.

Check 10% of all power terminations/connections associated with the system e.g. DC combiner boxes, disconnects, surge arrestors, inverters and PV modules and re-torque as necessary.

Terminations were checked and found to be within manufacturer's specifications.

Test ground continuity, lightning protection and overall system safety, and correct any unsafe or abnormal issues.

No abnormal or unsafe conditions observed.

Inspect/survey the combiner boxes, disconnects (AC&DC), switchgear and inverters with an infrared camera, in order to detect hotspots, bad connections, etc.

Upon examining connections throughout the system, both visually and with an infrared camera, no significant hot spots, loose connections or other trouble indicators were observed. Example photos are shown below.

- Not structured
- Monthly reports and event details are compiled into database
- Incomplete information for downtime and energy lost

# PV Reliability Operations & Maintenance (PVROM)



- Pros
  - Component downtime and energy lost
  - Highly structured series-parallel component dependencies
  - Allows for less data manipulation for reliability analysis
- Cons
  - Resides on a Sandia Server (security protocols for partner entering data)
  - Serializing PV system is not a trivial effort
  - Time and effort for entering data into PVROM forms, outside of data partner's own ticketing system
- 13.2 MW in the PVROM highly structured category
  - 4.7 MW is older data – fixed tilt (AZ)
  - 1.75 MW is older data – tracking system (AZ)
  - 0.45 MW is newer, DG data – fixed tilt (AZ)
  - 6.3 MW with new IPP partner (*240 MW potential*), soon to be entering event data (East Coast)

# PVROM Input and Output Data Fields

Base Installation Detail	
PV System Owner	
PV System Installer	
PV System Location	
As-built drawing	
Commissioning Date	
In Service Date	
O&M Contract	
dc Nameplate Capacity	
Array Size	
Array Operating Voltage	
Configuration/Application	
Utility/Grid Details	
BOS components	
Component Bill-of-Materials	

PV System Performance	Reliability Metrics	Incident Categories
Measured site solar insolation	Incident Title	Hardware failure
Estimated site solar insolation	Incident Description	Software problem
Weather data	Occurrence Date	Hardware upgrade required to operate
dc kWh production	Creation Date	Software upgrade required to operate
ac kWh production	Warranty Repair	Equipment installation problem
Other test data	Service Response Date	Grid-induced failure/suspension
Energy Yields	Incident Status	Lightning-induced failure/suspension
Yield Losses	Service Response Date	Environment-induced failure/suspension
Performance Ratio	System Status	Hardware application problem
Efficiencies (array, BOS and plant)	Incident Report Type	Vandalism
Model used for developing lifetime performance estimates	Incident Categories	Unknown
Degradation rates of components	Restored to Duty	Hardware upgrade
	Active repair duration	Software upgrade
	Incident Resolution	Planned maintenance
	Initiating Event	Troubleshooting issue
	System Hours	System upgrade
	Operating Time Prior to Failure	End of useful life failure
	Severity to System	
	System Down Event	
	Warranty Repair	
	ac kWh Loss	
	Tables of Reliability Data	
	Availability	
	Logistical Downtime	
	Failure Modes	
	Incident Frequency	
	Repair Duration	
	Downtime	
	Service Downtime	
	Component Labor Hours	
	Component Contribution to Energy Loss	

# Additional PVROM Output

## Component Metric Summary - Example

	Summary Maintenance Metrics				Summary Availability Metrics		Failure Metrics in Percentile - Failure Time			Repair Metrics in Percentile – Repair Time		
	Component	CUM. MTBM	CUM. MTBF	Avg. Active Repair Time	Total Comp. Downtime	Total Power Lost (kWh)	Total Comp. Downtime	10th	50th	90th	10th	50th
Inverters	18,500	140,000	0.75	400	26	50	1,550	10,220	33,950	0.2	0.5	1.4
Photovoltaic Modules	54M	54M	4	10	4	0	5.7 E+06	3.7 E+07	1.2 E+08	0.4	2.8	9.2
Hydraulic Cylinders	10,560	10,560	4.5	0	80	0	6,500	12,680	16,000	3.6	4.4	5.2
Programmable Logic Controller	20.5 M	20.5 M	1.2	0	15	0	2,590	274,200	2.9 E+07	0.2	0.8	2.6
Data Acquisition system	14,112	21,168	0.3	0	1	0	1,490	9,780	32,490	N/A	N/A	N/A

Component	Beta (Shape)	Lambda (Scale)
DC Disconnect Switch	0.470	0.0496
Array Electrical Connections	1.239	$3.486 \times 10^{-5}$
Inverter – Corrective and Preventative Maintenance	1.029	$2.264 \times 10^{-3}$
Inverter - Induced Outages	1.041	$4.799 \times 10^{-3}$

Component	Distribution	1 <sup>st</sup> Model Parameter	2 <sup>nd</sup> Model Parameter
AC Disconnect Switch	Lognormal	$\mu = 7.048$	$\sigma = 3.863$
Photovoltaic Modules	Weibull	$\beta = 0.825$	$\eta = 4.498 \times 10^6$
480/34.5 kV Transformer	Weibull	$\beta = 0.668$	$\eta = 2,554$

Repairable failure distribution parameters

Non-repairable failure distribution parameters



# Structured Event Database

- Pros
  - Somewhat structured based on component tickets
  - Dependent tickets
  - Component downtime and energy lost
  - Can be analyzed in different platforms
- Cons
  - Only two years of data
  - Not serialized for component dependency
- 570 MW in the Structured Event Database category
  - Mixed between Utility-scale and DG. Mostly Utility Scale
  - Located in AZ, CA, CT, IN, MA, NC, NJ, NY
  - Primarily inverter events under analysis

# Event Logs

- Pros
  - Not structured
  - Incomplete information for downtime and energy lost
- Cons
  - Monthly reports and event details are compiled into database
  - Not serialized for component dependency
  - Most time consuming process for reliability data set-up
- 29 MW in the Event Log category
  - 15 MW (commercial DG) under this system
  - 14 MW (commercial and industrial DG) to be added shortly in Hawaii

# Data Analysis – Summary Statistics



→ **Portfolio A – “Structured Event Database”**

- 570 MW<sub>dc</sub>
- Snow, water, lightning
- Utility planned/unplanned repair & grid disturbance
- Annual PM, coolant check, filter cleaning, module replacement, thermal imaging


↓  
**Data Reduction – 374 to 187 short descriptions**

Event Name Modified	New Order by Event Frequency	Event Name Original	Original Order by Event Frequency
Unknown Fault	1	Unknown Reason & Unknown Fault	5 and 16
Fan Failure	2	Fan Failure	1
DCS Fault	3	DCS Fault & DC Subsystem Fault	4 and 14
Preventative Maintenance	4	Due to and for Preventative Maintenance	9 and 12
Grid Fault	5	Grid Disturbance	20
LVRT Fault	6	LVRT Fault	3
Engine Failure	7	Engine Failure	2
Critical Faults	8	Critical faults	6
Cycling Fault	9	Cycling Fault	7
Array Fault	10	Array Fault	8


# Data Analysis – Summary Statistics

## Portfolio B – “Event logs”


- 14 MW<sub>dc</sub>
- 32 DG sites, distribution below
- Compilation of events is currently underway



All DG sites, by Inverter Brand



All DG sites, by Module Brand




# Data Analysis – Summary Statistics


## Portfolio C – “Structured Event Database & PVROM Database”

- 240 MW<sub>dc</sub>
- 47 Utility and DG sites, distribution below
- PVROM Bill of Materials development (6 MW system)
- Compilation of events is currently underway


Histogram of all sites



All sites, by Inverter Brand




All sites, by Module Brand



# Data Analysis – Specific Component

## Inverter Fan Analysis


- 78 fan events over two-year period (17 locations, 3 states)
- 49 inverters (out of 222) with events representing *potential* to impact 160 MW<sub>ac</sub>
- 3 different model numbers
- In-service dates primarily 2013-2015 (~2 years of data)
- **11 faults – power cycle**
- **67 faults leading to failure – replaced**



# Data Analysis – Specific Component

## Inverter Fan Analysis

Downtime Hours per Month vs. Total MWh Lost due to Fan Faults and Failures




- Data can be analyzed for Total Downtime or Sun Hour Downtime
- Sun Hour Downtime correlates better with energy loss
- Use of one or the other depends on the research question
- `pvlib.solarposition*` used to estimate Sun Hours at each site (not a function of inverter start threshold)

\*[http://pvlib-python.readthedocs.io/en/latest/\\_modules/pvlib/solarposition.html](http://pvlib-python.readthedocs.io/en/latest/_modules/pvlib/solarposition.html)

# Data Analysis – Specific Component

## Inverter Fan Analysis




- Normalizing fan energy losses by inverter nameplate separates the losses by inverter size
- When considering the same loss amount, impact is greater for the smaller inverter (Inverter Model 1)



# Data Analysis – Specific Component

## Inverter Fan Analysis

### Reliability Distributions



# Data Analysis – Developing Reliability Distributions




## Database of Stored Incidents

Results based on the following qualifier(s):								
Entity = SANDIA PVROM DATABASE								
Assigned To Problem = No								
Report Generated: 02/19/2016 10:59 AM								
Incident Number	Serial Number	Occurrence Date	State	Responsible Part	Category	Creator	Incident Owner	
SAN-18	SGS-3	02/10/2003 05:00 PM	Closed	MOD: PV Module	Hardware Failure	SYSTEM ADMIN	SYSTEM ADMIN	
SAN-24	SGS-12	06/28/2003 08:44 AM	Closed	INV: Inverter	Hardware Failure	SYSTEM ADMIN	SYSTEM ADMIN	
SAN-25	SGS-8	06/30/2003 05:00 PM	Closed	MOD: PV Module	Hardware Failure	SYSTEM ADMIN	SYSTEM ADMIN	
SAN-52	SGS-32	09/29/2003 05:46 AM	Closed	INV: Inverter	Hardware Failure	SYSTEM ADMIN	SYSTEM ADMIN	
SAN-54	SGS-31	10/18/2003 06:10 AM	Closed	INV: Inverter	Hardware Failure	SYSTEM ADMIN	SYSTEM ADMIN	
SAN-55	SGS-9	12/19/2003 05:25 AM	Closed	TXL: 480V/34.5kV Transformer	Hardware Failure	SYSTEM ADMIN	SYSTEM ADMIN	
SAN-58	SGS-2	01/25/2004 05:00 PM	Closed	INV: Inverter	Hardware Failure	SYSTEM ADMIN	SYSTEM ADMIN	
SAN-61	SGS-23	04/19/2004 12:48	Closed	INV: Inverter	Hardware	SYSTEM	SYSTEM ADMIN	




## Inverter Parametric Recurrence Data Analysis – Cumulative Failures vs. Time

- Power law analysis of inverter failure data indicates reliability growth
- Red markers are observed cumulative times, and solid line is power law fit using Maximum Likelihood Estimation



## Inverter Down Time Data Analysis

- Inverter downtime analysis performed for corrective maintenance and grid-induced shutdowns, for example




## Development of Failure and Repair Distributions for Components

Component	Distribution	1 <sup>st</sup> Model Parameter	2 <sup>nd</sup> Model Parameter
Inverter Corrective Maintenance	Lognormal	$\mu = -4.25$	$\sigma = 2.27$
Grid Effects	Weibull-2 parameter	$\beta = 1.07$	$h = 0.16$


- Data can then be used in O&M cost model or other model, such as the new Reliability feature currently under development in the System Advisor Model

# Data Application – Further Analysis

- 5-year dataset used in proof-of-concept and new System Advisor Model (SAM) version to validate implementation of representative failure distributions
- Proof-of-concept results generally fall within or near the 95% confidence interval from the newer SAM implementation (Mean 10 of Realizations)




# Data Application – Further Analysis




- Top green diamonds are system total 5-year cumulative energy results from 10 realizations when inverter fails and is repaired based on a failure and repair distribution
- Bottom orange circles represent the range of results from the same failure distribution, but inverter is not repaired after lightning event

# Data Application – Further Analysis



- Graph at bottom is the energy production range between No Failures & Fail and Repair. Results won't show on same graph



# Data Application – Further Analysis



## System Advisor Model

- Tracker Failure

1. Worst case scenario- tracker is assumed to fail at its rotation limit facing north. In the case of a north-south axis, facing west
2. Average case scenario- tracker is assumed to fail flat

- Module Degradation


- When running a reliability scenario, module degradation changes can be analyzed as a result of different failure and replacement rates



# Data Application – Further Analysis

## PV O&M Cost Model

- Project led by NREL, with SunSpec and Sandia as partners
- Started as Spreadsheet model
- Currently testing Beta of online O&M cost model





# Thank You

Geoff Klise

[gklise@sandia.gov](mailto:gklise@sandia.gov)