

## **SANDIA REPORT**

SAND2016-9180

Supersedes **SAND2013-5131**

Unlimited Release

September 2016

# **DOE/EPRI Electricity Storage Handbook in Collaboration with NRECA**

Abbas A. Akhil, Georgianne Huff, Aileen B. Currier, Benjamin C. Kaun, Dan M. Rastler, Stella Bingqing Chen, Andrew L. Cotter, Dale T. Bradshaw, William D. Gauntlett, Donald Bender, Daniel R. Borneo, James Eyer, Michelle Ellison, Todd Olinsky-Paul, Susan Schoenung, and Jacquelynne Hernández

Prepared by  
Sandia National Laboratories  
Albuquerque, New Mexico 87185 and Livermore, California 94550

Sandia National Laboratories is a multi-mission laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000.

Approved for public release; further dissemination unlimited.



**Sandia National Laboratories**

Issued by Sandia National Laboratories, operated for the United States Department of Energy by Sandia Corporation.

**NOTICE:** This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government, nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors, or their employees, make any warranty, express or implied, or assume any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represent that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government, any agency thereof, or any of their contractors or subcontractors. The views and opinions expressed herein do not necessarily state or reflect those of the United States Government, any agency thereof, or any of their contractors.

Printed in the United States of America. This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from

U.S. Department of Energy  
Office of Scientific and Technical Information  
P.O. Box 62  
Oak Ridge, TN 37831

Telephone: (865) 576-8401  
Facsimile: (865) 576-5728  
E-Mail: [reports@adonis.osti.gov](mailto:reports@adonis.osti.gov)  
Online ordering: <http://www.osti.gov/bridge>

Available to the public from

U.S. Department of Commerce  
National Technical Information Service  
5285 Port Royal Rd.  
Springfield, VA 22161

Telephone: (800) 553-6847  
Facsimile: (703) 605-6900  
E-Mail: [orders@ntis.fedworld.gov](mailto:orders@ntis.fedworld.gov)  
Online order: <http://www.ntis.gov/help/ordermethods.asp?loc=7-4-0#online>



SAND2016-9180  
Supersedes **SAND2013-5131**  
Unlimited Release  
September 2016

## DOE/EPRI Electricity Storage Handbook in Collaboration with NRECA

Abbas A. Akhil, Georgianne  
Huff, Aileen B. Currier,  
Jacquelynne Hernández  
Energy Storage Technology  
and Systems  
Sandia National Laboratories  
P.O. Box 5800, MS1140  
Albuquerque, New Mexico  
87185-1140

Donald Bender  
Sandia National Laboratories  
P.O. Box 969, MS9154  
Livermore, CA 94551-0969

Benjamin C. Kaun, Dan M.  
Rastler, Stella Bingqing Chen  
Electric Power Research  
Institute  
Palo Alto, CA 94303-8013

Andrew L. Cotter, Dale T.  
Bradshaw  
National Rural Electric  
Cooperative Association  
Arlington, VA 22203

William D. Gauntlett  
AECOM Technical Services,  
Inc.  
Albuquerque, NM 87102

James Eyer and Todd  
Olinsky-Paul  
Clean Energy States Alliance  
50 State Street, Suite 1  
Montpelier, VT 05602

Michelle Ellison  
E&I Consulting  
3727 Ardley Avenue  
Oakland, CA 94602

Susan Schoenung  
Longitude 122 West, Inc.  
885 Oak Grove Ave. #304  
Menlo Park, CA 94025

### Abstract

The Electricity Storage Handbook (Handbook) is a how-to guide for utility and rural cooperative engineers, planners, and decision makers to plan and implement energy storage projects. The Handbook also serves as an information resource for investors and venture capitalists, providing the latest developments in technologies and tools to guide their evaluations of energy storage opportunities. It includes a comprehensive database of the cost of current storage systems in a wide variety of electric utility and customer services, along with interconnection schematics. A list of significant past and present energy storage projects is provided for a practical perspective. This Handbook, jointly sponsored by the U.S. Department of Energy and the Electric Power Research Institute in collaboration with the National Rural Electric Cooperative Association, is published in electronic form at [www.sandia.gov/ess](http://www.sandia.gov/ess).

This Handbook is best viewed online.

## Revision Log

Comments, inquiries, corrections, and suggestions can be submitted via the website [www.sandia.gov/ess/](http://www.sandia.gov/ess/), beginning August 1, 2013.

## REVISION LOG

Rev. Number	Date	Purpose of Revision	Document Number	Name or Org.
Rev. 0	July 2013	Update and revise the 2003 EPRI-DOE Handbook of Energy Storage for Transmission and Distribution Applications to provide how-to information for various stakeholders.	SAND2013-5131	DOE (SNL), EPRI, NRECA
Rev. 1	Sept. 2014	<p>Chapter 2:</p> <ul style="list-style-type: none"> <li>Added information highlighting thermal storage solution.</li> </ul> <p>Chapter 3:</p> <ul style="list-style-type: none"> <li>Added subchapter highlighting tools available to use to evaluate a Storage solution from a modeling and simulation standpoint.</li> <li>Added new Subsections 3.3.1 through 3.3.6.</li> </ul> <p>Chapter 4:</p> <ul style="list-style-type: none"> <li>With respect to the "AC battery" system: <ul style="list-style-type: none"> <li>Added a reference to the patent #4,894,764.</li> <li>Added a picture of an AC battery.</li> </ul> </li> <li>Added information about KIUC and the RFI and RFP.</li> </ul> <p>Appendix A:</p> <ul style="list-style-type: none"> <li>Added information regarding ES models and tools.</li> </ul> <p>Appendix B:</p> <ul style="list-style-type: none"> <li>Expanded on three energy and power cost components. <ul style="list-style-type: none"> <li>Calculation of the sum of the energy and power components.</li> <li>How these costs are highly system dependent and do not scale linearly.</li> </ul> </li> <li>Expanded on derivation of the Total Plant Cost (TPC) and referenced costs that are components of the TPC.</li> <li>Added explanation of equipment costs.</li> </ul> <p>Appendix F:</p> <ul style="list-style-type: none"> <li>Added introductory text.</li> </ul> <p>Appendix G:</p> <ul style="list-style-type: none"> <li>Added reference to AC battery patent.</li> <li>Removed Hawaii battery projects information.</li> </ul>	SAND2014-XXXX	

Acknowledgments

## ACKNOWLEDGMENTS

Without the work of the Energy Storage Handbook (Handbook) Advisory Panel and contributors, this Handbook could neither have been completed nor would it have the credibility or value to the energy storage community that the authors intend.

Acknowledgment is given to the emeritus authors from the 2015 Handbook, Abbas A. Akhil, Georgianne Huff, Aileen B. Currier, Benjamin C. Kaun, Dan M. Rastler, Stella Bingqing Chen, Andrew L. Cotter, Dale T. Bradshaw, and William D. Gauntlett; and the new contributing authors for the 2016 Handbook update: Donald Bender, Daniel R. Borneo, Dale T. Bradshaw, James Eyer, Michelle Ellison, Todd Olinsky-Paul, and Susan Schoenung.

The authors are very grateful to the Advisory Panel, who diligently reviewed this Handbook for technical accuracy and content and contributed their unique perspectives. The Panel members include: Eva Gardow, FirstEnergy; Steve Willard, Public Service Company of New Mexico; Naum Pinsky, Southern California Edison; Rick Winter, UniEnergy Technologies; Mike Jacobs, Xtreme Power; Kimberly Pargoff, A123; Pramod Kulkarni, Customized Energy Solutions; Chet Sandberg, Electricity Storage Association; Janice Lin, California Energy Storage Association; and Ali Nourai, DNV-KEMA. Their guidance has been invaluable in ensuring that the Handbook can meet the needs of a broad audience.

The authors would also like to thank Ray Byrne, Verne Loose, Dhruv Bhatnagar, Ben Schenkman, Jason Neely, and Anthony Menicucci, Sandia National Laboratories, for their many hours of writing and numerous reviews to prepare the content for the Handbook.

Thanks are also due to Jim Eyer, Distributed Utility Associates, and Garth Corey, who not only provided reviews but also shared insights from their deep experiences of the storage community.

Special thanks are due to editors Barbara Haschke and Debra Rivard of Raytheon Company and chief editor Jaci Hernández of Sandia National Laboratories, and ROJOFOTO for compilation of documents.

Finally, the authors wish to express their appreciation to the U.S. Department of Energy's Office of Electricity and Dr. Imre Gyuk, Energy Storage Program Manager; Haresh Kamath, Electric Power Research Institute; and Robbin K. Christianson, National Rural Electric Cooperative Association, for their vision and collaboration through all phases in the development and compilation of the Handbook.

## FOREWORD

### From: Dr. Imre Gyuk

I am most proud to introduce the 2016 edition of the DOE/EPRI Electricity Storage Handbook prepared in collaboration with the National Rural Electric Cooperative Association.

When we put together the first EPRI/DOE Energy Storage Handbook some 10 years ago, the field was very much in its infancy. There were only a few demonstrations and almost no commercially viable deployment. The Handbook consisted mostly of a survey of available storage technologies and analysis of potential applications. Things are vastly different now. There are dozens of demonstrations of manifold technologies in a wide spectrum of applications. Sizes vary from tens of kW to 20-30MW. Storage for frequency regulation has become fully commercial and facilities are being built to explore renewable integration, PV smoothing, peak shifting, load following and the use of storage for emergency preparedness. Important policy decisions are being made in the regulatory arena to pave the way for an equitable deployment of storage. This is happening not only in the U.S. but round the globe: Among others, Germany, Japan, and China are all becoming strong advocates of energy storage.

Now, in 2016, it is time to publish a new Handbook. It will fill an industry-wide need for a single-point resource to describe the services and applications of energy storage in the grid, the current storage technologies and their commercial status, system costs, and performance metrics. DOE has taken the lead to fill this industry need by partnering with the Electric Power Research Institute (EPRI) to produce this Handbook.

I want to recognize the tremendous cooperation and sharing of data by EPRI to make this happen. This effort brought together the resources of two leading authorities in the Energy Storage field to produce a landmark work that will greatly benefit the storage industry. Collaboration with NRECA additionally ensures that the Handbook is available to the widest possible audience of storage users including the investor-owned utilities who are members of EPRI and the large community of rural cooperatives across the Nation who are members of NRECA.

Lastly, this is a free, publicly available resource downloadable through the internet by any interested reader. We hope that it will lead to more technology, more deployment, and a structured regulatory environment, putting energy storage well on the road to full commercialization.

*Dr. Imre Gyuk  
US DOE/OE Energy Storage Program*

**From: Haresh Kamath**

I am very pleased to join my friend and colleague Dr. Imre Gyuk in introducing the 2016 edition of the DOE/EPRI Electricity Storage Handbook, prepared in collaboration with the National Rural Electric Cooperative Association.

The first edition of the Handbook, a collaborative effort between EPRI and DOE, was released in 2003, just in time to address the growing need for data and insight on energy storage technologies in transmission and distribution applications. The opportunities for improving asset utilization of transmission and distribution through the strategic use of storage, as well as the various dynamic operating benefits of storage, were already well-recognized. The Handbook was an early attempt to quantify the benefits from storage systems used in multiple applications. In 2004, the Handbook was further enhanced through the publication of a supplement that addressed the use of storage in increasing grid flexibility in a world with rapidly increasing penetrations of variable renewable energy sources.

Since then, the field of energy storage has moved forward at an incredible pace, on both the application and technology fronts. This progress has come about through the tireless work of a remarkable community of scientists, engineers, economists, and businesspeople from across the world, representing diverse organizations including utilities, generation companies, universities, national laboratories, consulting organizations, technology developers, and government agencies.

The accomplishments of the last decade are due in no small part to the leadership and vision of DOE and its partners, particularly at Sandia National Laboratory, as well as to organizations such as NRECA. EPRI has been proud to collaborate with these visionary partners in exploring the performance and applications of energy storage technologies for the grid.

While much work is yet required before storage technologies become commonplace, it is important to recognize the distance we have come towards achieving this goal, and the experience and knowledge gained in the journey. This Handbook serves as a distillation of this knowledge, which will hopefully facilitate the broader use of utility energy storage in maintaining the reliability and affordability of the modern grid in an environmentally responsible way.

We at EPRI would like to thank DOE and NRECA for their interest and commitment in producing this publicly-available resource for those pursuing the use of energy storage in grid applications.

*Haresh Kamath  
EPRI Program Manager for Energy Storage*

# CONTENTS

GLOSSARY .....	xv
Preface.....	xxi
Introduction.....	xxiii
Handbook Roadmaps .....	xxv
Energy Storage 101.....	xxx
 CHAPTER 1. ELECTRICITY STORAGE SERVICES AND BENEFITS .....	
1.1 General Information.....	1
1.2 Approach.....	1
1.3 Data Bulk Energy Services .....	2
1.3.1 Electric Energy Time-Shift (Arbitrage).....	2
1.3.2 Electric Supply Capacity.....	3
1.4 Ancillary Services .....	4
1.4.1 Regulation .....	4
1.4.2 Spinning, Non-Spinning, and Supplemental Reserves.....	7
1.4.3 Voltage Support .....	9
1.4.4 Black Start.....	9
1.4.5 Other Related Uses.....	10
1.4.6 Frequency Response .....	13
1.5 Transmission Infrastructure Services .....	14
1.5.1 Transmission Upgrade Deferral .....	14
1.5.2 Transmission Congestion Relief .....	16
1.5.3 Other Related Uses.....	17
1.6 Distribution Infrastructure Services .....	18
1.6.1 Distribution Upgrade Deferral and Voltage Support .....	18
1.7 Customer Energy Management Services .....	20
1.7.1 Power Quality .....	20
1.7.2 Power Reliability.....	21
1.7.3 Retail Energy Time-Shift .....	22
1.7.4 Demand Charge Management.....	23
1.8 Stacked Services—Use Case Combinations .....	25
1.9 Summary .....	27
1.10 Extended Technical Discussion .....	27
 CHAPTER 2 ELECTRICITY STORAGE TECHNOLOGIES: COST, PERFORMANCE, AND Maturity .....	
2.1 General Information.....	29
2.2 Approach.....	29
2.3 Data Mature Electricity Storage Technologies .....	29
2.4 Pumped Hydro .....	32
2.4.1 Additional Pumped Hydro Resources.....	35
2.5 Compressed Air Energy Storage .....	35

## Contents/Figures/Tables

2.6	2.5.1 Technical Description .....	35
	Sodium-sulfur Battery Energy Storage .....	37
2.6.1	Technical Description .....	37
2.7	Sodium-nickel-chloride Batteries.....	43
	2.7.1 Technical Description .....	43
2.8	Vanadium Redox Batteries.....	45
	2.8.1 Technical Description .....	45
2.9	Iron-chromium Batteries .....	49
	2.9.1 Technical Description .....	49
	2.9.2 Performance Characteristics .....	49
2.10	Zinc-bromine Batteries .....	51
	2.10.1 Technical Description .....	51
2.11	Zinc-air Batteries.....	56
	2.11.1 Technical Description .....	56
2.12	Lead-acid Batteries .....	60
	2.12.1 Technical Description .....	60
2.13	Flywheel Energy Storage .....	67
	2.13.1 Flywheels Basics.....	67
2.14	Lithium-ion Family of Batteries.....	74
2.15	Emerging Technologies .....	81
	2.15.1 General Technology Overview .....	83
2.16	Summary .....	84
2.17	Extended Technical Discussion .....	85
CHAPTER 3.	METHODS AND TOOLS FOR EVALUATING ELECTRICITY STORAGE .....	87
3.1	General Information.....	87
3.2	Approach.....	87
3.3	Data .....	88
3.4	Modeling Tools .....	97
	3.4.1 DOE SNL Tools.....	99
	3.4.2 Other Evaluation Tools .....	100
3.5	Summary .....	102
3.6	Extended Technical Discussion .....	102
CHAPTER 4.	STORAGE SYSTEMS PROCUREMENT .....	105
4.1	General Information.....	105
4.2	Approach.....	105
4.3	Data .....	105
	4.3.1 Third-party Ownership .....	106
	4.3.2 Outright Purchase and Full Ownership .....	106
	4.3.3 Procurement Guidance for Energy Storage Projects .....	111
4.4	Summary .....	167
4.5	Extended Technical Discussion .....	167
Chapter 5 :	Thermal Energy Storage – A Case Study .....	169
5.1	Generation Information.....	169
5.2	Approach.....	169
5.3	Data .....	169

## Contents/Figures/Tables

5.3.1	Background: The DOE NRECA Smart Grid Demonstration Project.....	169
5.3.2	Project Implementation and Results – Thermal Energy Storage.....	170
5.3.3	Conclusions.....	181
5.3.4	Recommendation for Further Study.....	183
5.4	Summary .....	183
5.5	<b>Extended Technical Discussion A</b> .....	183
5.5.1	Project Implementation and Results — Battery Energy Storage.....	185
5.5.2	Operation.....	191
5.5.3	Conclusions.....	198
5.5.4	Recommendation for Further Study.....	201
5.6	Extended Discussion B .....	201
CHAPTER 6:	ENERGY STORAGE SYSTEMS COST UPDATE.....	203
6.1	General Information.....	203
6.2	Approach.....	203
6.3	Data .....	203
6.3.1	Technologies and Application Categories .....	204
6.3.2	Cost Calculations .....	205
6.3.3	Results and Observations .....	209
6.4	Summary .....	212
6.5	Extended Technical Discussion .....	212
Chapter 7.	The Characteristics of and Process for Updating the Next DOE/EPRI/SNL/NRECA Electricity Storage Handbook.....	213
7.1	General Information.....	213
7.2	Approach.....	213
7.3	Data .....	213
7.3.1	Mission for the Handbook .....	213
7.3.2	Audience for the Handbook .....	214
7.3.3	Handbook Development Approach.....	215
7.3.4	The Handbook Scope .....	218
7.3.5	Notable Challenges and Considerations .....	221
7.3.6	Terms and Acronyms .....	224
7.3.7	Exhibit 1. Preliminary Handbook Outline .....	226
7.3.8	Exhibit 2. ESIC Scope Overview.....	228
7.4	Summary .....	229
7.5	Extended Discussion.....	230
LIST OF APPENDICES	.....	231
DISTRIBUTION	.....	Dist-1

## FIGURES

Figure 1. Schematic of a Battery Energy Storage System .....	xxxi
Figure 2. Storage for Electric Supply Capacity .....	4
Figure 3. System Load Without and With Regulation.....	5
Figure 4. Storage and Generation Operation for Regulation .....	6
Figure 5. Storage for Regulation.....	7
Figure 6. Storage for Reserve Capacity .....	8
Figure 7. Storage for Voltage Support Service.....	9
Figure 8. Black Start Service by Storage .....	10
Figure 9. Electric Supply Resource Stack.....	11
Figure 10. The Sequential Actions of Primary, Secondary, and Tertiary Frequency Controls Following the Sudden Loss of Generation and Their Impacts on System Frequency .....	14
Figure 11. Storage for Transmission and Distribution Deferral .....	16
Figure 12. Storage for Transmission Congestion Relief.....	17
Figure 13. Storage for Customer-side Power Quality.....	18
Figure 14. Storage for Distribution Upgrade Deferral.....	20
Figure 15. Storage for Customer-side Power Quality.....	21
Figure 16. Time of Use Summer Energy Prices for Small Commercial/Industrial Users .....	22
Figure 17. On-peak Demand Reduction Using Energy Storage .....	24
Figure 18. Storage for Customer-side Demand Management .....	25
Figure 19. Positioning of Energy Storage Technologies .....	30
Figure 20. Cutaway Diagram of a Typical Pumped Hydro Plant .....	33
Figure 21. Man-made Upper Reservoir of TVA's Raccoon Mountain Pumped Hydro Plant.....	33
Figure 22. Pumped Storage Preliminary Permits/Proposed Projects in the United States .....	34
Figure 23. Schematic of Compressed Air Energy Storage Plant with Underground Compressed Air Storage.....	35
Figure 24. Chemical Structure of a Sodium-sulfur Cell .....	38
Figure 25. Sodium-sulfur Battery Module Components.....	39
Figure 26. Xcel Battery Supplementing Wind Turbines, Lucerne, MN .....	41
Figure 27. Design and Principal Features of Sodium-nickel-chloride Batteries .....	43
Figure 28. FIAMM 222-kWh System Site at the Duke Energy Rankin Substation .....	44
Figure 29. Containerized 25-kW/50-kWh FIAMM Battery Unit (large green housing) on Concrete Pad, Next to S&C PureWave CES (small green housing) .....	44
Figure 30. Construction of a Vanadium Redox Cell Stack.....	46
Figure 31. Principles of the Vanadium Redox Battery .....	47
Figure 32. Prudent Energy 600-kW/3,600-kWh VRB-ESS Installed at Gills Onions, Oxnard, CA.....	48
Figure 33. Principles of Operation for an Iron-chromium Battery Energy Storage System.....	49

## Contents/Figures/Tables

Figure 34. Typical Iron-chromium Battery System .....	50
Figure 35. Iron-chromium Battery Storage System Concepts .....	51
Figure 36. Zinc-bromine Cell Configuration .....	52
Figure 37. A 90-kW/180-kWh Zinc-bromine Energy Storage System by RedFlow .....	54
Figure 38. Zinc-air Battery Functional Schematic .....	57
Figure 39. 1-kW Zinc-air Prototype .....	59
Figure 40. Illustration of 1-MW/6/MWh Eos Aurora Zinc-air Design .....	59
Figure 41. 1-MW/1.5-MWh Lead-acid Carbon System at Metlakatla, AK .....	63
Figure 42. Acid Battery Installation at Tappi Wind Park .....	64
Figure 43. 1.5-MW/1-MWh Advanced Lead-acid Dry Cell Systems by Xtreme Power in a Maui Wind Farm ( <i>Source: Xtreme Power</i> ) .....	65
Figure 44. 500-kW/1-MWh Advanced Lead-acid Battery for Time-shifting and 900-kWh Advanced Carbon Valve-regulated Battery for Photovoltaic Smoothing .....	65
Figure 45. Historic Flywheel Technology .....	68
Figure 46. Modern Flywheel Technology .....	68
Figure 47. Integrated Flywheel System Package Cutaway Diagram .....	70
Figure 48. 1-MW Smart Energy Matrix Plant .....	73
Figure 49. Principles of a Li-ion Battery .....	75
Figure 50. Illustrative Types of Li-ion Cells .....	76
Figure 51. Locations of Current and Planned U.S. Li-ion System Grid Demonstrations .....	77
Figure 52. AES Storage LLC's Laurel Mountain Energy Storage .....	79
Figure 53. A 2-MW/4-MWh Li-ion Energy Storage System .....	79
Figure 54. A 30-kW/34-kWh Distributed Energy Storage Unit .....	80
Figure 55. Residential Energy Storage and Energy Management Systems .....	80
Figure 56. Key Emerging Technologies .....	83
Figure 57. Rechargeable Battery Energy Storage Currently Available .....	84
Figure 58. Steps in Electricity Storage Evaluation .....	88
Figure 59. Decision Diagram for Step 1a: Opportunity/Solution Concepts .....	89
Figure 60. Decision Diagram for Step 1b: Define Grid Service Requirements .....	90
Figure 61. Decision Diagram for Step 2: Feasible Use Cases .....	91
Figure 62. Case 1: Coincident Transformer and System Load Peaks .....	92
Figure 63. Case 2: Partially Overlapping Transformer and System Load Peaks .....	93
Figure 64. Case 3: Non-overlapping Transformer and System Load Peaks .....	93
Figure 65. Decision Diagram for Step 3: Grid Impacts and Incidental Benefits .....	95
Figure 66. Decision Diagram for Step 4: Electricity Storage Business Cases .....	96
Figure 67. Business Models for Storage Systems .....	105
Figure 68. First AC Battery PM250 Modular Battery System Installed at Pacific Gas & Electric's Modular Generation Test Facility, San Ramon, CA, in 1993 .....	108

Figure 69. A Process for Storage System Acquisition.....	109
Figure 70. Typical summer PV variability .....	154
Figure 71. Typical Example of a GETS System Integrated with a 105-Gallon Marathon Hot Water Heater, on display at the PJM RTO (courtesy of Steffes Corporation) .....	173
Figure 72. Steffes Data on Temperature, Power, and Energy for an Individual Water Heater ...	174
Figure 73. Steffes Corporation Valley-Filling Input Strategy (x-axis is time of day and y-axis is kW).....	175
Figure 74. Near Coincidence of Requested vs. Reported Load from GETS System Aggregated Group in Response to Simulated ACE Signals for Frequency Regulation.....	176
Figure 75. Detailed Steffes GETS System Load Response .....	177
Figure 76. Average Hourly Prices in MISO in 2013 for LMP, RMCP, and LMP Minus RMCP or Effective Net ost.....	178
Figure 77. PJM Regulation Market Clearing Price, October 2012 through September 2013. (Source: October 14, 2013, PJM RTO report to FERC on analysis of performance-based regulation for frequency regulation.).....	179
Figure 78. PJM RTO LMP, RMCCP, and RMPCP as a Function of the Time-of-Day Average for FY 2013 .....	180
Figure 79. Simplified SP Installation Wiring Diagram .....	188
Figure 80. 9.2-kW SP Unit with Cover Removed .....	190
Figure 81. Display on SP Appliance.....	190
Figure 82. Cost-Shifting from Solar without Storage.....	197
Figure 83. Lead Acid Battery Cycle vs. DOD .....	197
Figure 84. Energy Storage System Components .....	206
Figure 85. Graphic Representation of 10-year Present Worth Cost .....	211

## TABLES

Table 1. Electric Grid Energy Storage Services Presented in This Handbook .....	2
Table 2. Confidence Rating Based on Cost and Design Estimate .....	32
Table 3. Accuracy Range Estimates for Technology Screening Data* .....	32
Table 4. Technology Dashboard: Pumped Hydro.....	33
Table 5. Technology Dashboard: Compressed Air Energy Storage .....	36
Table 6. Performance Characteristics of NaS Batteries.....	40
Table 7. Technology Dashboard: Sodium-sulfur Battery Systems.....	41
Table 8. Advantages and Limitations of Sodium/Sulfur Battery Technology, from <i>Handbook of Batteries</i> , Third Edition, by David Linden .....	42
Table 9. Technology Dashboard for Sodium-nickel-chloride Batteries .....	45
Table 10. Technology Dashboard: Vanadium Flow-Type Battery Systems .....	48
Table 11. Technology Dashboard: Iron-chromium Battery Systems .....	51
Table 12. Technology Dashboard: Zinc-bromine Flow-type Battery Systems .....	54
Table 13. Table 39.1 Major Advantages and Disadvantages of Zinc/Bromine Battery Technology, from <i>Handbook of Batteries</i> , Third Edition, by David Linden .....	55
Table 14. Technology Dashboard: Zinc-air Battery Systems .....	58
Table 15. Table 13.4 Strengths and Weaknesses of Zinc/Air Batteries, from <i>Handbook of     Batteries</i> , Fourth Edition, by David Linden .....	60
Table 16. Technology Dashboard: Advanced Lead-acid Battery Systems.....	66
Table 17. Major Advantages and Disadvantages of Lead-Acid Batteries, from <i>Handbook of     Batteries</i> , Third Edition, by David Linden .....	66
Table 18. Flywheel Applications .....	69
Table 19. Technology Dashboard: Flywheel Energy Storage Systems .....	73
Table 20. Advantages and Disadvantages of Li-ion Batteries, from <i>Handbook of Batteries     by David Linden</i> .....	78
Table 21. Technology Dashboard: Lithium-ion Battery Systems .....	81
Table 22. Emerging Storage Options Research and Development Timelines for Emerging Energy Storage Options.....	82
Table 23. Recommended Energy Storage System Parameters .....	103
Table 24. Storage System Characteristics for Select Services .....	110
Table 25. BESS Proposal Evaluation Matrix.....	162
Table 26. OnDemand™ Energy Appliance Specifications .....	186
Table 27. Installation Details for the Units Purchased .....	189
Table 28. Battery Energy Storage Project Detailed Payback Analysis for WHCEA, Assuming 2-Hour Discharge, 5 Cycles per Month, 60% DOD .....	194
Table 29. Battery Energy Storage Project Detailed Payback Analysis for MVEC, Assuming 1-Hour Discharge, 8 Cycles per Month, 80% DOD.....	195

Table 30. Operation/Use Categories .....	204
Table 31. Technologies Considered.....	205
Table 32. Assumptions for Life-cycle Benefit and Cost Analysis.....	208
Table 33. Cost and Performance Assumptions .....	209
Table 34. Present Worth Cost of 10-year Operation in Year 1 (\$/kw) <sup>1</sup> .....	210

**GLOSSARY**

- A -	
<b>ac</b>	alternating current
<b>ACE</b>	area control error
<b>AEP</b>	American Electric Power
<b>AFUDC</b>	Allowance for Funds Used During Construction
<b>AGC</b>	automatic generation control
<b>AGM</b>	Absorbed glass mat
<b>AMI</b>	Automated metering infrastructure
<b>APP</b>	American Public Power Association
<b>ARRA</b>	American Recovery and Reinvestment Act of 2009
<b>AS</b>	ancillary service
- B -	
<b>BESS</b>	Battery Energy Storage System
<b>BEWAG</b>	Berliner Kraft and Licht
<b>BPA</b>	Bonneville Power Authority
- C -	
<b>CAES</b>	compressed air energy storage
<b>CAISO</b>	California Independent System Operator
<b>Calculator</b>	Lifecycle Analysis Calculator (EPRI)
<b>CCGT</b>	Combined-cycle gas turbine
<b>CES</b>	Community Energy Storage
<b>CESA</b>	Clean Energy States Alliance or California Energy Storage Alliance
<b>CO<sub>2</sub></b>	carbon dioxide
<b>CONE</b>	cost of new entry
<b>Co-op(s)</b>	Rural electric cooperative(s)
<b>CPUC</b>	California Public Utility Commission
<b>CT</b>	combustion turbine
- D -	
<b>DAS</b>	Data Acquisition System
<b>dc</b>	direct current
<b>DESS</b>	Distributed Energy Storage System
<b>DETL</b>	Distributed Energy Technologies Laboratory
<b>DOD</b>	depth of discharge
<b>DOE</b>	U.S. Department of Energy
<b>\$/kW-month</b>	dollars per kilowatt per month
<b>DR</b>	demand response
<b>DSA</b>	Dynamic Security Assessment
<b>DSCR</b>	Debt Service Coverage Ratio
<b>DSM</b>	Demand-side Management

## Glossary

- E -	
<b>EAG</b>	Executive Advisory Group
<b>EEI</b>	Edison Electric Institute
<b>EES</b>	Electric Energy Storage
<b>EESAT</b>	Electrical Energy Storage Applications and Technologies
<b>EIA</b>	Energy Information Administration
<b>EMC</b>	electromagnetic compatibility
<b>EOC</b>	Executive Oversight Committee
<b>EPRI</b>	Electric Power Research Institute
<b>ERCOT</b>	Electric Reliability Council of Texas
<b>ESA</b>	Electricity Storage Association
<b>ESAL</b>	Energy Storage Analysis Laboratory
<b>ESCO</b>	energy service company
<b>ESCT</b>	Energy Storage Computational Tool
<b>ESHB</b>	Electricity Storage Handbook
<b>ESIC</b>	Energy Storage Integration Council
<b>ESIF</b>	Energy Systems Integration Facility
<b>ESPTL</b>	Energy Storage Performance Test Laboratory
<b>ESS</b>	Energy Storage Systems or Electricity Storage Systems
<b>ESTF</b>	Energy Storage Test Facility
<b>ESTP</b>	Energy Storage Test Pad
<b>ESVT</b>	Energy Storage Valuation Tool
<b>ETT</b>	Electric Transmission Texas
<b>EV</b>	Electric Vehicle
- F -	
<b>Fe-Cr</b>	Iron-chromium
<b>FERC</b>	Federal Energy Regulatory Commission
<b>FY</b>	Fiscal Year
- G -	
<b>G &amp; T</b>	generation and transmission
<b>GE</b>	General Electric
<b>GETS</b>	Grid-interactive Electric Thermal Storage
<b>GHG</b>	greenhouse gas
<b>GRE</b>	Great River Energy
<b>GST</b>	Grid Storage Technologies
<b>GVEA</b>	Golden Valley Electric Association
<b>GW</b>	gigawatts
- H -	
<b>H-APU</b>	Hybrid Ancillary Power Unit
<b>Handbook</b>	Electricity Storage Handbook
<b>HCEI</b>	Hawaii Clean Energy Initiative
<b>hr</b>	hour
<b>Hz</b>	hertz

## Glossary

- I -	
<b>ICAES</b>	isothermal compressed air energy storage
<b>IDC</b>	Interest During Construction
<b>IEA</b>	International Energy Agency
<b>IEEE</b>	Institute of Electrical and Electronics Engineers
<b>ILZRO</b>	International Lead Zinc Research Organization
<b>IOU</b>	Investor Owned Utility
<b>IP</b>	Internet Protocol
<b>IPP</b>	Independent Power Producer
<b>IR</b>	infrared
<b>ISO</b>	Independent System Operator
<b>ISO-NE</b>	Independent System Operator – New England
- J -	
<b>JCP&amp;L</b>	Jersey Central Power and Light Company
- K -	
<b>KIUC</b>	Kauai Island Utility Cooperative
<b>kW</b>	kilowatt
<b>kWh</b>	kilowatt hour
- L -	
<b>LA</b>	lead-acid
<b>LCOE</b>	levelized cost of energy
<b>LEED</b>	Leadership in Energy and Environmental Design
<b>Li</b>	lithium
<b>LMP</b>	locational marginal pricing
<b>LMS</b>	load management system
<b>LP</b>	Liquefied petroleum
<b>LSE</b>	load-serving entity
- M -	
<b>MISO</b>	Midcontinent Independent System Operator
<b>MLD</b>	Modular Living Document
<b>MMBtu</b>	one million Btu
<b>MP&amp;L</b>	Metlakatla Power and Light
<b>Muni</b>	municipal electric utility
<b>MVAR</b>	mega volt-ampere reactive
<b>MVEC</b>	Minnesota Valley Electric Cooperative
<b>MW</b>	megawatt
<b>MWh</b>	megawatt hour
- N -	
<b>Na</b>	sodium
<b>Na<sub>2</sub>S<sub>5</sub></b>	sodium pentasulfide
<b>NaCl</b>	salt
<b>NaAlCl<sub>4</sub></b>	sodium ion conductive salt

## Glossary

<b>NaNiCl<sub>2</sub></b>	sodium nickel chloride
<b>NARUC</b>	National Association of Regulatory Utility Commissioners
<b>NaS</b>	sodium sulfur
<b>NAS™</b>	registered trademark for NGK Insulators, Ltd. sodium sulfur batter
<b>NEC</b>	National Electrical Code
<b>NEDO</b>	New Energy Development Organization
<b>NERC</b>	North American Electric Reliability Council
<b>NESC</b>	National Electric Safety Code
<b>NETL</b>	National Energy Technology Laboratory
<b>NFPA</b>	National Fire Protection Association
<b>Ni</b>	nickel
<b>NiCd</b>	nickel cadmium
<b>NiCl<sub>2</sub></b>	nickel chloride
<b>NIST</b>	National Institute of Standards and Technology
<b>NISTIR</b>	National Institute of Standards and Technology Interagency Report
<b>Ni-MH</b>	nickel metal-hydride
<b>NO<sub>x</sub></b>	nitrogen oxides
<b>NPV</b>	Net Present Value
<b>NRECA</b>	National Rural Electric Cooperative Association
<b>NREL</b>	National Renewable Energy Laboratory
<b>NYISO</b>	New York Independent System Operator
<b>NYSERDA</b>	New York State Energy and Development Authority

## - O -

<b>O&amp;M</b>	Operations and Maintenance
<b>OE (DOE)</b>	Office of Electricity Delivery and Energy Reliability
<b>OEM</b>	original equipment manufacturer
<b>OIR</b>	

## - P -

<b>PbO<sub>2</sub></b>	lead dioxide
<b>PCS</b>	power conversion system or power conditioning system
<b>PCT</b>	Patent Cooperation Treaty
<b>PG&amp;E</b>	Pacific Gas and Electric
<b>PEV</b>	plug-in electric vehicle
<b>PHEV</b>	plug-in hybrid electric vehicle
<b>PHES</b>	pumped hydroelectric energy storage
<b>PJM</b>	PJM Interconnection, LLC
<b>PNM</b>	Public Service Company of New Mexico
<b>PNNL</b>	Pacific Northwest National Laboratory
<b>PQ</b>	power quality
<b>PREPA</b>	Puerto Rico Electric Power Authority
<b>PSLF</b>	Positive Sequence Load Flow
<b>PUC</b>	Public Utility Commission
<b>PV</b>	Photovoltaic or present value
<b>Pb-acid</b>	Lead Acid Battery

## Glossary

- Q -	
<b>No “Q” terms</b>	
- R -	
<b>R&amp;D</b>	research and development
<b>Redox</b>	reduction and oxidation
<b>RFI</b>	Request for Information
<b>RFP</b>	Request for Proposals
<b>RFQ</b>	Request for Quote
<b>RMCCP</b>	regulation market capability clearing price
<b>RMCP</b>	regulation market clearing price
<b>RMPCP</b>	regulation market performance clearing price
<b>RPS</b>	Renewable Portfolio Standards
<b>RTO</b>	Regional Transmission Organization
- S -	
<b>SCADA</b>	Supervisory Control and Data Acquisition
<b>SCE</b>	Southern California Edison
<b>SCR</b>	Selective Catalytic Reduction
<b>SDG&amp;E</b>	San Diego Gas and Electric
<b>SGDP</b>	Smart Grid Demonstration Project
<b>SGIP</b>	Self-generating Incentive Program
<b>SMD</b>	Standard Market Design
<b>SNL</b>	Sandia National Laboratories
<b>SOC</b>	state of charge
<b>SP</b>	Silent Power
<b>STATCOM</b>	Status Synchronous Compensator
<b>SVC</b>	Static VAR Compensator
- T -	
<b>T&amp;D</b>	transmission and distribution
<b>TAG</b>	Technical Advisory Group
<b>TCOS</b>	transmission cost of service
<b>TEPCO</b>	Tokyo Electric Power Company
<b>TES</b>	thermal energy storage
<b>TESA</b>	Texas Energy Storage Alliance
<b>TIEC</b>	Texas Industrial Energy Consumers
<b>TOU</b>	time of use
<b>TPC</b>	total plant cost
<b>TSO</b>	Transmission System Operator
<b>TSP</b>	Tehachapi Wind Energy Storage
<b>TVA</b>	Tennessee Valley Authority
- U -	
<b>UBG</b>	Utility Battery Groups
<b>UPS</b>	uninterruptible power supply
<b>UTC</b>	Universal Coordinated Time

## Glossary

- V -	
<b>V</b>	volts
<b>VAR</b>	reactive power and volt-ampere reactive
<b>VLA</b>	vented lead-acid
<b>VPS</b>	VRB Power Systems
<b>VRLA</b>	valve-regulated lead-acid
- W -	
<b>WACC</b>	weighted average cost of capital
<b>WECC</b>	Western Electric Coordinating Council
<b>WHCEA</b>	Wright-Hennepin Cooperative Electric Association
- X -	
<b>No "X" terms</b>	
- Y -	
<b>No "Y" terms</b>	
- Z -	
<b>ZnBr<sub>2</sub></b>	zinc bromine

## PREFACE

When the first , U.S. Department of Energy (DOE)/ Electric Power Research Institute (EPRI) Electricity Storage Handbook (ESHB) was issued, readers wanted to have access to a single resource that shared general information on a variety of subjects: existing and emerging technologies, life cycle costs, evaluation tools, and procurement. The developments in energy storage over the last 15 years have begun to change the electricity delivery business.

Electrical energy storage is still an enabling technology. Storage still makes delivery of electricity a just-in-time commodity. But storage now effectively helps to manage peak load demand, match generation and load, provide more reliable power supply to high-tech industrial needs, and make intermittent renewable energy resources smoother and more dispatchable.

The 2016 version of the ESHB includes a new approach, format, and additional information. Each chapter is divided into background information, the approach taken to present the information, data specific to the topic areas, and an extended technical discussion.

Two years of readers' feedback was taken into account for this ESHB edition. The first audience wanted generic information that was verifiable through a third party, like a national laboratory. Over time, the Handbook users requested more practical hands-on or use case information so that they could compare, make better technical decisions, or create metrics to measure their own project's status.

The chart below describes the changes made to the previous Handbook.

Chapter 2	Eliminates levelized cost of energy, yet adds the advantages and disadvantages associated with the featured existing energy storage technologies.
Chapter 3	Adds online tools for evaluating energy storage systems that are provided by the DOE/ <b>OE</b> Energy Storage Program.
Chapter 4	Focuses on the Procurement Process and eliminates the installation discussion.
Chapter 5	Introduces thermal energy storage as installed by rural electric cooperatives and <b>MISO</b> .
Chapter 6	Provides a methodology on estimating energy storage costs over time.
Chapter 7	Identifies the next steps for the ESHB – a movement from the paper copy to an online, modular, living document.



## Introduction

# INTRODUCTION

Publication of the Electricity Storage Handbook (ESHB or Handbook) is funded through Dr. Imre Gyuk, U.S. Department of Energy (DOE), and Haresh Kamath, Electric Power Research Institute (EPRI), in collaboration with the National Rural Electric Cooperative Association (NRECA). Development of the Handbook's content was originally guided by a 10-member Advisory Panel representing system vendors, electric utilities, regulators, and trade associations.<sup>1</sup>

The Handbook includes discussion of stationary energy storage systems (ESSs) that use batteries, flywheels, compressed air energy storage (CAES), and pumped hydropower. The 2016 update includes a discussion of thermal energy storage (TES) and an application of a TES installation provided by NRECA. It excludes hydrogen and other forms of energy storage that could also support the grid, such as plug-in electric vehicles (PEVs) or electric vehicles (EVs). Both DOE and EPRI have separate programs that support PEVs and EVs.

This edition of the Handbook builds primarily upon the EPRI/DOE Handbook of Energy Storage for Transmission and Distribution Applications, released in December 2003 – a landmark collaboration between EPRI and DOE. The first Handbook presented a broad perspective on the potential of energy storage in the national grid, comparative storage technology and benefits assessments, and a review of 10 different storage technologies in 14 transmission and distribution (T&D) categories.

This edition of the Handbook is a one-stop resource guide for electric systems engineers/planners, ESS vendors, and investors to aid in the selection, procurement, installation, and/or operation of stationary ESSs in today's electric grid. Various perspectives of grid electricity storage are presented for different stakeholders: generators and system operators, load-serving entities (LSEs) with various ownership structures, and customers. The Handbook includes a review of the current status of technical, regulatory, and ownership issues that impact energy storage adoption, primarily with a U.S.-centric focus. Much of the material presented in this edition of the Handbook has been condensed and updated from existing reports from Sandia National Laboratories (SNL), EPRI, NRECA, other national laboratories, and industry sources published from the mid-1980s to the present. This edition presents updated information on storage technologies and their benefits in an operational and regulatory environment and recognizes energy storage as a grid component in further detail than the 2003 and 2013 Handbooks.

The 2016 ESHB update is laid out more uniformly with common elements – general information, approach to the topic, relevant data, summary, and an extended discussion. Levelized cost has been discontinued in most chapters, but is included graphically in the appendices. Two additional topics have been added – TES and an approach to energy storage system (ESS) cost methodology. There is a brief reference to ESS safety. Lastly, this edition is a virtual tool with links to major topical area resources. Appendices have been adjusted accordingly. A **glossary of select terms** and an extensive reference database of reports published

<sup>1</sup> The advisory panel members for ESHB 2003 and 2013 are Eva Gardow, FirstEnergy; Steve Willard, Public Service Company of New Mexico; Naum Pinsky, Southern California Edison; Rick Winter, UniEnergy Technologies; Mike Jacobs, Xtreme Power; Kimberly Pargoff, A123; Pramod Kulkarni, Customized Energy Solutions; Chet Sandberg (representing Electricity Storage Association); Janice Lin, California Energy Storage Association; and Ali Nourai, DNV-KEMA.

**Introduction**

by DOE, EPRI, NRECA, and industry sources are among the supporting appendices provided at the end of the Handbook. References for material in the text are provided in footnotes.

## **HANDBOOK ROADMAPS**

This Handbook addresses the what, why, and how of electricity energy storage for grid and stand-alone applications. It is intended for an audience that falls broadly into three groups: utility and co-operative (co-op) engineers/system planners; system vendors and investors; and regulators and policy makers. The authors have developed roadmaps that guide the reader to the relevant sections of the Handbook based on their perceived needs in their exploration of electricity storage. These audiences each have different questions of significance to them, and each roadmap is organized to suit their needs. The following roadmaps provide a suggested navigation of the four chapters and their corresponding appendices providing additional detail and references on each topic of interest.



## SUGGESTED GUIDE FOR UTILITY AND CO-OP ENGINEERS/SYSTEM PLANNERS

### What are the relevant use cases for electricity storage?

*Chapter 1 identifies storage services and functional uses including storage for renewable integration and provides ranges and minimum requirements for storage systems with illustrative examples. The use cases and applications span generation, transmission and distribution (T&D), and customer-side applications.*

### What are the technology options and how can use cases of interest be assessed?

*Chapter 2 describes current storage technologies and their high-level performance characteristics and maturity.*

*Chapter 4 identifies various technology-assessment tools from preliminary screening to more detailed analysis. Selected tools are described in Appendix A.*

### What are the costs and important procurement and installation issues?

*Chapter 4 presents two different system procurement/ownership options for investor-owned utilities (IOUs) and co-ops. It addresses practical safety, interconnection, warranty, and codes issues to guide successful project completion.*

*Appendix B gives detailed system and component cost information organized by storage technology. These data were obtained from system vendors for the various technologies currently in use for stationary applications and were used to derive the capital costs.*

*Appendix C provides sample Requests for Information (RFIs) and Requests for Proposals (RFPs) that can be modified to suit specific needs and serve as guidelines for the system procurement process.*

*Appendix D illustrates interconnection configurations for selected storage systems and gives representative interconnection equipment costs. These configurations can be changed to meet more specific site needs as necessary.*

*Appendix E contains a sample specification for cyber security guidance specific to Li-ion battery systems that can serve as a guideline for other storage technology systems.*

### How have public utility commissions (PUCs) treated storage and what are the regulatory drivers for storage?

*Appendix F provides a comprehensive review PUC cases where storage was included and their outcomes.*

*Chapter 4 summarizes enacted and pending Federal Energy Regulatory Commission (FERC) and State regulatory initiatives that promote storage.*

**Which trade associations are promoting storage and what are the venues for networking in this community?**

*Chapter 4 identifies those industry groups and not-for-profit conferences that provide networking opportunities with system vendors, technology developers, and other utilities that use or are considering storage, as well as a window into Federal and State programs that promote storage deployment.*

## Suggested Guide for System Vendors and Investors

**How do utilities and co-ops purchase electricity storage systems?**

*Chapter 4 presents two different ownership options for electricity storage systems and provides a high-level discussion of safety, interconnection, warranty, and codes that are important from the customer perspective.*

*Appendix C shows sample RFI and RFP documents that are representative of the terms and conditions that utilities and co-ops will likely seek in the procurement process.*

**Which industry trade groups promote electricity storage?**

*Chapter 4 identifies those industry groups that actively promote electricity storage and not-for-profit conferences that provide networking opportunities with a wide spectrum of the storage community.*

**What are the policy and regulatory drivers that impact electricity storage?**

*Appendix E provides a comprehensive review of past PUC cases that included electricity storage and their outcomes.*

*Chapter 4 lists enacted and pending FERC and State regulatory initiatives that promote electricity storage.*

**What are the relevant codes, interconnection, and safety issues?**

*Chapter 4 discusses safety, interconnection, communication, and warranty issues that are important to prospective customers in the utility sector.*

**Where can full systems be tested and what are the test standards/protocols?**

*Appendix F identifies several test facilities and capabilities that can test fully configured systems and discusses the test protocols and standards being formulated to govern standardized performance testing of storage systems.*

## Suggested Guide for Regulators and Policy Makers

### **What are the services and functional uses of electricity storage?**

*Chapter 1 describes various services and functional uses of electricity storage in the grid with illustrative charts, including the use of electricity storage to support renewable resource integration.*

### **What are the current electricity storage technologies?**

*Chapter 2 describes current electricity storage technologies, their high-level performance characteristics, and their maturities. Additional detail on cost is provided in Appendix B and Appendix D.*

### **How has storage been addressed by other PUCs?**

*Appendix E presents a summary of regulatory cases and the outcomes in several State PUC filings that address electricity storage.*

## ENERGY STORAGE 101

What is energy storage? Energy storage mediates between variable sources and variable loads. Without storage, energy generation must equal energy consumption. Energy storage works by moving energy through time. Energy generated at one time can be used at another time through storage. Electricity storage is one form of energy storage. Other forms of energy storage include oil in the Strategic Petroleum Reserve and in storage tanks, natural gas in underground storage reservoirs and pipelines, thermal energy in ice, and thermal mass/adobe.

Electricity storage is not new. In the 1780s, Galvani demonstrated “animal electricity” and in 1799 Volta invented the modern battery. In 1836, batteries were adopted in telegraph networks. In the 1880s, lead-acid batteries were the original solution for nighttime load in the private New York City area direct current (dc) systems. The batteries were used to supply electricity to the load during high-demand periods and to absorb excess electricity from generators during low-demand periods for sale later. The first U.S. large-scale electricity storage system was 31 megawatts (MW) of pumped storage in 1929 at the Connecticut Light & Power Rocky River Plant. As of 2011, 2.2%<sup>2</sup> of electricity was stored worldwide, mostly in pumped storage.

In this Handbook, a complete electricity storage system (that can connect to the electric grid or operate in a stand-alone mode) comprises two major subcomponents: storage and the power conversion electronics. These subsystems are supplemented by other balance-of-plant components that include monitoring and control systems that are essential to maintain the health and safety of the entire system. These balance-of-plant components include the building or other physical enclosure, miscellaneous switchgear, and hardware to connect to the grid or the customer load. A schematic representation of a complete ESS is shown in Figure 1 with a generic storage device representing a dc storage source, such as a battery or flywheel.

In battery and flywheel storage systems, the power conversion system (PCS) is a bidirectional device that allows the dc to flow to the load after it is converted to alternating current (ac) and allows ac to flow in the reverse direction after conversion to dc to charge the battery or flywheel. The monitoring and control subcomponents may not be a discrete box, as shown in Figure 1, but could be integrated within the PCS itself.


Compressed air energy storage (CAES) systems involve high-pressure air stored in underground caverns or above-ground storage vessels (for example, high-pressure pipes or tanks). In pumped hydroelectric energy storage (PHES), energy is stored by pumping water to an upper reservoir at a higher elevation than the system’s lower reservoir.

For a broader overview, Dr. Ray Byrne has created a presentation called Energy Storage 101 at the link below.

[http://www.sandia.gov/ess/docs/swpuc/Byrne\\_Energy\\_storage\\_101\\_SAND2016-4387.pdf](http://www.sandia.gov/ess/docs/swpuc/Byrne_Energy_storage_101_SAND2016-4387.pdf)

---

<sup>2</sup> Source: *Annual Electric Generator Report*, 2011 EIA – Total Capacity 2009; U.S. Energy Information Administration, Form EIA-860, 2011.



**Figure 1. Schematic of a Battery Energy Storage System**  
(Source: Sandia National Laboratories)

# CHAPTER 1. ELECTRICITY STORAGE SERVICES AND BENEFITS

## 1.1 General Information

Operational changes to the grid, caused by restructuring of the electric utility industry and electricity storage technology advancements, have created an opportunity for storage systems to provide unique services to the evolving grid. Regulatory changes in T&D grid operations, for instance, impact the implementation of electricity storage into the grid as well as other services that storage provides. Although electricity storage systems provide services similar to those of other generation devices, their benefits vary and are thoroughly discussed in this chapter.

Until the mid-1980s, energy storage was used only to time-shift from coal off-peak to replace natural gas on-peak so that the coal units remained at their optimal output as system load varied. These large energy storage facilities stored excess electricity production during periods of low energy demand and price and discharged it during peak load times to reduce the cycling or curtailment of the coal load units. This practice not only allowed the time-shifting of energy but also reduced the need for peaking capacity that would otherwise be provided by combustion turbines. The operational and monetary benefits of this strategy justified the construction of many pumped hydro storage facilities. From the 1920s to the mid-1980s, more than 22 gigawatts (GW) of pumped hydro plants were built in the United States. After this period, the growth in pumped hydro capacity stalled due to environmental opposition<sup>3</sup> and the changing operational needs of the electric grid, triggered by the deregulation and restructuring of the electric utility industry.

By the mid-1980s, the push was stronger to develop battery and other storage technologies to provide services to the electric grid. However, these technologies could not match the ability of pumped hydro to provide large storage capacities. In the late 1980s, researchers at DOE/SNL and at EPRI were identifying other operational needs of the electric grid that could be met in shorter storage durations of 1 to 6 hours rather than the 8 to 10+ hours that pumped hydro provided.

## 1.2 Approach

Two SNL reports<sup>4,5</sup> in the early 1990s identified and described 13 services that these emerging storage technologies could provide. A more recent report<sup>6</sup> expanded the range of the grid services and provided significantly more detail on 17 services and guidance on estimating the

<sup>3</sup> From the 2003 Handbook: “The addition of pumped hydro facilities is very limited, due to the scarcity of further cost-effective and environmentally acceptable sites in the U.S.” *EPRI-DOE Handbook of Energy Storage for Transmission and Distribution Applications*, L. D. Mears, H. L. Gotschall – Technology Insights; T. Key, H. Kamath – EPRI PEAC Corporation; EPRI ID 1001834, EPRI, Palo Alto, CA, and the U.S. Department of Energy, Washington, DC, 2003.

<sup>4</sup> *Battery Energy Storage: A Preliminary Assessment of National Benefits (The Gateway Benefits Study)*, Abbas Ali Akhil; Hank W Zaininger; Jonathan Hurwitch; Joseph Badin, SAND93-3900, Albuquerque, NM, December 1993.

<sup>5</sup> *Battery Energy Storage for Utility Applications: Phase I Opportunities Analysis*, Butler, Paul Charles, SAND94-2605, Albuquerque, NM, October 1994.

<sup>6</sup> *Energy Storage for the Electricity Grid: Benefits and Market Potential Assessment Guide*, Eyer, James M. – distributed Utility Associates, Inc., Garth Corey – Ktech Corporation, SAND2010-0815, Albuquerque, NM and Livermore, CA, February 2010.

## Chapter 1. Electricity Storage Services and Benefits

benefits accrued by these services.<sup>7</sup> Other works have also documented use cases and services that storage provides to the grid. Most notably, EPRI's Smart Grid Resource Center Use Case Repository contains over 130 documents that discuss various aspects of storage.<sup>8</sup> Similarly, California Independent System Operator (CAISO) also describes eight scenarios supplemented by activity diagrams to demonstrate the use of storage for grid operations and control.

This Handbook combines that knowledge base and includes the description and service-specific technical detail of 18 services and applications in five umbrella groups, as listed in Table 1.

**Table 1. Electric Grid Energy Storage Services Presented in This Handbook**

Bulk Energy Services		Transmission Infrastructure Services
Electric Energy Time-Shift (Arbitrage)		Transmission Upgrade Deferral
Electric Supply Capacity		Transmission Congestion Relief
Ancillary Services		Distribution Infrastructure Services
Regulation		Distribution Upgrade Deferral
Spinning, Non-Spinning and Supplemental Reserves		Voltage Support
Voltage Support		Customer Energy Management Services
Black Start		Power Quality
Other Related Uses		Power Reliability
		Retail Electric Energy Time-Shift
		Demand Charge Management

## 1.3 Data Bulk Energy Services

### 1.3.1 Electric Energy Time-Shift (Arbitrage)

Electric energy time-shift involves purchasing inexpensive electric energy, available during periods when prices or system marginal costs are low, to charge the storage system so that the stored energy can be used or sold at a later time when the price or costs are high. Alternatively, storage can provide similar time-shift duty by storing excess energy production, which would otherwise be curtailed, from renewable sources such as wind or photovoltaic (PV). The functional operation of the storage system is similar in both cases, and they are treated interchangeably in this discussion.

<sup>7</sup> An application, or grid service, is a use whereas a benefit connotes a value. A benefit is generally quantified in terms of the monetary or financial value.

<sup>8</sup> EPRI Smartgrid Resource Center: Use Case Repository, <http://smartgrid.epri.com/Repository/Search.aspx?search=storage>, last accessed May 9, 2013.

<sup>9</sup> "IS-1 ISO Uses Energy Storage for Grid Operations and Control," Ver 2.1, California ISO, Folsom, CA, November 2010, <http://www.caiso.com/285f/285fb7964ea00.pdf>, last accessed May 9, 2013.

### 1.3.1.1 Technical Considerations

*Storage System Size Range: 1 – 500 MW*

*Target Discharge Duration Range: <1 hour*

*Minimum Cycles/Year: 250 +*

Storage used for time-shifting energy from PV or smaller wind farms would be in the lower end of the system storage size and duration ranges shown above, whereas storage for arbitrage in large utility applications or in conjunction with larger wind farms or groups of wind and/or PV plants would fall in the upper end of these ranges.

Both storage variable operating cost (non-energy-related) and storage efficiency are especially important for this service. Electric energy time-shift involves many possible transactions with economic merit based on the difference between the cost to purchase, store, and discharge energy (discharge cost) and the benefit derived when the energy is discharged.

Any increase in variable operating cost or reduction of efficiency reduces the number of transactions for which the benefit exceeds the cost. That number of transactions is quite sensitive to the discharge cost, so a modest increase may reduce the number of viable transactions considerably. Two performance characteristics that have a significant impact on storage variable operating cost are round-trip efficiency of the storage system and the rate at which storage performance declines as it is used.

In addition, seasonal and diurnal electricity storage can be considered as a bulk service. It can be very useful for wind or PV if there are significant seasonal and diurnal differences.

### 1.3.2 Electric Supply Capacity

Depending on the circumstances in a given electric supply system, energy storage could be used to defer and/or to reduce the need to buy new central station generation capacity and/or purchasing capacity in the wholesale electricity marketplace.

The marketplace for electric supply capacity is evolving. In some cases, generation capacity cost is included in wholesale energy prices (as an allocated cost per unit of energy). In other cases, market mechanisms may allow for capacity-related payments.

#### 1.3.2.1 Technical Considerations

*Storage System Size Range: 1 – 500 MW*


*Target Discharge Duration Range: 2 – 6*

*hours Minimum Cycles/Year: 5 – 100*

The operating profile for storage used as supply capacity (characterized by annual hours of operation, frequency of operation, and duration of operation for each use) is location-specific. Consequently, it is challenging to make generalizations about storage discharge duration for this service. Another key criterion affecting discharge duration for this service is the way that generation capacity is priced. For example, if capacity is priced per hour, then storage plant duration is flexible. If prices require that the capacity resource be available for a specified duration for each occurrence (for example, 5 hours), or require operation during an entire time

period (for example, 12:00 p.m. to 5:00 p.m.), then the storage plant discharge duration must accommodate those requirements.

The two plots in Figure 2 illustrate the capacity constraint and how storage acts to compensate the deficit. The upper plot shows the three weekdays when there is need for peaking capacity. The lower plot shows storage discharge to meet load during those three periods and also shows that the storage is charged starting just before midnight and ending late at night during the times when system load is lower.



**Figure 2. Storage for Electric Supply Capacity**

## 1.4 Ancillary Services


### 1.4.1 Regulation

Regulation is one of the ancillary services for which storage is especially well suited. Regulation involves managing interchange flows with other control areas to match closely the scheduled interchange flows and momentary variations in demand within the control area. The primary reasons for including regulation in the power system are to maintain the grid frequency and to comply with the North American Electric Reliability Council's (NERC's) Real Power Balancing Control Performance (BAL001) and Disturbance Control Performance (BAL002) Standards.

Regulation is used to reconcile momentary differences caused by fluctuations in generation and loads. Regulation is used for damping of that difference. Consider the example shown in Figure 3. The load demand line in Figure 3 shows numerous fluctuations depicting the imbalance between generation and load without regulation. The thicker line in the plot shows a smoother system response after damping of those fluctuations with regulation.


Generating units that are online and ready to increase or decrease power as needed are used for regulation and their output is increased when there is a momentary shortfall of generation to provide up regulation. Conversely, regulation resources' output is reduced to provide down regulation when there is a momentary excess of generation.

An important consideration in this case is that large thermal base-load generation units in regulation incur significant wear and tear when they provide variable power needed for regulation duty.



**Figure 3. System Load Without and With Regulation**  
(Source: Sandia National Laboratories)

Two possible operational modes for 1 MW of storage used for regulation and three possible operational modes for generation used for regulation are shown in Figure 4. The leftmost plot shows how less-efficient storage could be used for regulation. In that case, increased storage discharge is used to provide up regulation and reduced discharge is used to provide down regulation. In essence, one-half of the storage's capacity is used for up regulation and the other half of the storage capacity is used for down regulation (similar to the rightmost plot, which shows how 1 MW of generation is often used for regulation service). Next, consider the second plot, which shows how 1 MW of efficient storage can be used to provide 2 MW of regulation – 1 MW up and 1 MW down – using discharging and charging, respectively.



**Figure 4. Storage and Generation Operation for Regulation**  
(Source: E&I Consulting)

When storage provides down regulation by charging, it absorbs energy from the grid; the storage operator must pay for that energy. That is notable – especially for storage with lower efficiency – because the cost for that energy may exceed the value of the regulation service.

#### 1.4.1.1 Technical Considerations

*Storage System Size Range: 10 – 40 MW*


*Target Discharge Duration Range: 15 minutes to 60 minutes*

*Minimum Cycles/Year: 250 – 10,000*

The rapid-response characteristic (that is, fast ramp rate) of most storage systems makes it valuable as a regulation resource. Storage used for regulation should have access to and be able to respond to the area control error (ACE) signal or an automatic generation control (AGC) signal if one is available from the Balancing Authority in which the storage system is located, as opposed to conventional plants, which generally follow an AGC signal. The equivalent benefit of regulation from storage with a fast ramp rate (for example, flywheels, capacitors, and some battery types) is on the order of two times that of regulation provided by conventional generation<sup>10</sup> because it can follow the signal more accurately and thus reduce the total wear and tear on other generation.

<sup>10</sup> “Assessing the Value of Regulation Resources Based on Their Time Response Characteristics,” Y.V. Makarov, S. Lu, J. Ma, T.B. Nguyen, PNNL-17632, Pacific Northwest National Laboratory, Richland, WA, June 2008.

Figure 5 shows two plots to illustrate the storage response for a regulation requirement. The upper plot is an exaggerated illustration of the generation variance in response to fluctuating loads. The lower plot shows storage either discharging or charging to inject or absorb the generation as needed to eliminate the need for cycling of the generation units.



**Figure 5. Storage for Regulation**

#### 1.4.2 Spinning, Non-Spinning, and Supplemental Reserves

Operation of an electric grid requires reserve capacity that can be called upon when some portion of the normal electric supply resources becomes unavailable unexpectedly.

Generally, reserves are at least as large as the single largest resource (for example, the single largest generation unit) serving the system and reserve capacity is equivalent to 15% to 20% of the normal electric supply capacity. NERC and FERC define reserves differently based on different operating conditions. For simplicity, this Handbook discusses three generic types of reserve to illustrate the role of storage in this service:

**Spinning Reserve<sup>11</sup> (Synchronized)** – Generation capacity that is online but unloaded and that can respond within 10 minutes to compensate for generation or transmission outages. “Frequency-responsive” spinning reserve responds within 10 seconds to maintain system frequency. Spinning reserves are the first type used when a shortfall occurs.

<sup>11</sup> Spinning reserve is defined in the NERC Glossary as “Unloaded generation that is synchronized and ready to serve additional demand.”

**Non-Spinning Reserve<sup>12</sup> (Non-synchronized)** – Generation capacity that may be offline or that comprises a block of curtailable and/or interruptible loads and that can be available within 10 minutes.

**Supplemental Reserve** – Generation that can pick up load within 1 hour. Its role is, essentially, to be a backup for spinning and non-spinning reserves. Backup supply may also be used as backup for commercial energy sales. Unlike spinning reserve capacity, supplemental reserve capacity is not synchronized with grid frequency. Supplemental reserves are used after all spinning reserves are online.

Importantly for storage, generation resources used as reserve capacity must be online and operational (that is, at part load). Unlike generation, in almost all circumstances, storage used for reserve capacity does not discharge at all; it just has to be ready and available to discharge when needed.


#### 1.4.2.1 Technical Considerations

*Storage System Size Range: 10 – 100 MW*

*Target Discharge Duration Range: 15 minutes – 1 hour*

*Minimum Cycles/Year: 20 – 50*

Reserve capacity resources must receive and respond to appropriate control signals. Figure 6 shows how storage responds to spinning reserve requirements. The upper plot shows a loss of generation and the lower plot shows the immediate response with a 30-minute discharge to provide the reserve capacity until other generation is brought online.



**Figure 6. Storage for Reserve Capacity**

<sup>12</sup> Non-spinning reserve is not uniformly the same in different reliability regions. It generally consists of generation resources that are offline, but could be brought online within 10 to 30 minutes and could also include loads that can be interrupted in that time window.

### 1.4.3 Voltage Support

A requirement for electric grid operators is to maintain voltage within specified limits. In most cases, this requires management of reactance, which is caused by grid-connected equipment that generates, transmits, or uses electricity and often has or exhibits characteristics like those of inductors and capacitors in an electric circuit. To manage reactance at the grid level, system operators need voltage support resources to offset reactive effects so that the transmission system can be operated in a stable manner.

Normally, designated power plants are used to generate reactive power (VAR) to offset reactance in the grid. These power plants could be displaced by strategically placed energy storage within the grid at central locations or taking the distributed approach and placing multiple VAR-support storage systems near large loads.

#### 1.4.3.1 Technical Considerations


*Storage System Size Range: 1 – 10 mega volt-ampere reactive (MVAR)*

*(MVAR) Target Discharge Duration Range: Not Applicable*

*Minimum Cycles/Year: Not Applicable*

The PCS of the storage systems used for voltage support must be capable of operating at a non-unity power factor, to source and sink reactive power or volt-ampere reactive (VARs). This capability is available in all PCSs used in today's storage systems. Real power is not needed from the battery in this mode of operation and thus discharge duration and minimum cycles per year are not relevant in this case.

The nominal time needed for voltage support is assumed to be 30 minutes—time for the grid system to stabilize and, if necessary, to begin orderly load shedding to match available generation. Figure 7 shows three discharges of storage: with active injection of real power and VARs, with absorbing power to balance voltage while providing VARs, and providing VARs only without real power injection or absorption as needed by the grid.



**Figure 7. Storage for Voltage Support Service**

### 1.4.4 Black Start

Storage systems provide an active reserve of power and energy within the grid and can be used to energize transmission and distribution lines and provide station power to bring power plants

on line after a catastrophic failure of the grid. Golden Valley Electric Association uses the battery system in Fairbanks for this service when there is an outage of the transmission intertie with Anchorage. The operation of the battery is illustrated in Figure 8, which shows its discharge to provide charging current to two transmission paths as needed, and startup power to two diesel power plants that serve Fairbanks until the intertie is restored.


Storage can provide similar startup power to larger power plants, if the storage system is suitably sited and there is a clear transmission path to the power plant from the storage system's location.

#### 1.4.4.1 Technical Considerations

*Storage System Size Range: 5 – 50 MW*

*Target Discharge Duration Range: 15 minutes – 1*

*hour Minimum Cycles/Year: 10 – 20*



**Figure 8. Black Start Service by Storage**  
(Courtesy: Golden Valley Electric Association)

#### 1.4.5 Other Related Uses


##### 1.4.5.1 Load Following/Ramping Support for Renewables

Electricity storage is eminently suitable for damping the variability of wind and PV systems and is being widely used in this application. Technically, the operating requirements for a storage system in this application are the same as those needed for a storage system to respond to a rapidly or randomly fluctuating load profile. Most renewable applications with a need for storage will specify a maximum expected up- and down-ramp rate in MW/minute and the time duration of the ramp. This design guidance for the storage system is applicable for load following and renewable ramp support; this Handbook therefore treats them as the same application.

Load following is characterized by power output that generally changes as frequently as every several minutes. The output changes in response to the changing balance between electric supply and load within a specific region or area. Output variation is a response to changes in system frequency, timeline loading, or the relation of these to each other that occurs as needed to

maintain the scheduled system frequency and/or established interchange with other areas within predetermined limits.

The output of conventional generation-based load following resources *increases* to follow demand up as system load increases. Conversely, the output of load following resources *decreases* to follow demand down as system load decreases. Typically, the amount of load following needed in the up direction (load following up) increases each day as load increases during the morning. In the evening, the amount of load following needed in the down direction (load following down) increases as aggregate load on the grid drops. A simple depiction of load following is shown in Figure 9.



**Figure 9. Electric Supply Resource Stack**

Normally, generation is used for load following. For load following up, generation is operated such that its output is less than its design or rated output (also referred to as “part load operation”). Consequently, the plant heat rates, fuel cost, and emission are increased. This allows operators to increase the generator’s output, as needed, to provide load following up to accommodate increasing load. For load following down, generation starts at a high output level, perhaps even at design output, and the output is decreased as load decreases.

These operating scenarios are notable because operating generation at part load requires more fuel per megawatt hour (MWh) and results in increased air emissions per MWh relative to generation operated at its design output level. Varying the output of generators (rather than operating at constant output) will also increase fuel use and air emissions, as well as the need for generator maintenance and thus variable operations and maintenance (O&M) costs. In addition, if a fossil plant has to shut down during off-peak periods, there will be a significant increase in

fuel use, O&M, and emissions. Plant reliability will also deteriorate, resulting in the need for significant purchases of replacement energy.

Storage is well suited to load following for several reasons. First, most types of storage can operate at partial output levels with relatively modest performance penalties. Second, most types of storage can respond very quickly (compared to most types of generation) when more or less output is needed for load following. Consider also that storage can be used effectively for both load following up (as load increases) and for load following down (as load decreases), either by discharging or by charging.

In market areas, when charging storage for load following, the energy stored must be purchased at the prevailing wholesale price. This is an important consideration, especially for storage with lower efficiency and/or if the energy used for charging is relatively expensive, because the cost of energy used to charge storage (to provide load following) might exceed the value of the load following service.

Conversely, the value of energy discharged from storage to provide load following is determined by the prevailing price for wholesale energy. Depending on circumstances (that is, if the price for the load following service does not include the value of the wholesale energy involved), when discharging for load following, two benefits accrue – one for the load following service and another for the energy.

Note that in this case, storage competes with central and aggregated distributed generation and with aggregated demand response/load management resources including interruptible loads and direct load control.

#### **1.4.5.2 Technical Considerations**

*Storage System Size Range: 1 – 100 MW*

*Target Discharge Duration Range: 15 minutes –*

*1 hour Minimum Cycles/Year: Not Applicable*

Storage used for load following should be reliable or it cannot be used to meet contractual obligations associated with bidding in the load following market. Storage used for load following will probably need access to AGC from the respective independent system operator (ISO).

Typically, an ISO requires output from an AGC resource to change every minute.

Other considerations include synergies with other services. Large/central storage used for load following may be especially complementary to other services if the charging and discharging for the other services can be coordinated. For example, storage used to provide generation capacity midday could be charged in the evening, thus following diminished system demand down during evening hours.

Load following could have good synergies with renewables capacity firming, electric energy time-shift, and possibly electric supply reserve capacity applications. If storage is distributed, then that same storage could also be used for most of the distributed applications and for voltage support.

### 1.4.6 Frequency Response

Frequency response is very similar to regulation, described above, except it reacts to system needs in even shorter time periods of seconds to less than a minute when there is a sudden loss of a generation unit or a transmission line. As shown in Figure 10,<sup>13</sup> various generator response actions are needed to counteract this sudden imbalance between load and generation to maintain the system frequency and stability of the grid. The first response within the initial seconds is the primary frequency control response of the governor action on the generation units to increase their power output as shown in the lower portion of the figure. This is followed by the longer-duration secondary frequency control response by the AGC that spans the half a minute to several minutes shown by the dotted line in the lower portion of Figure 10. It is important to note that the rate at which the frequency decays after the triggering event – loss of generator or transmission – is directly proportional to the aggregate inertia within the grid at that instant. The rotating mass of large generators and/or the aggregate mass of many smaller generators collectively determines this inertia.


The combined effect of inertia and the governor actions determines the rate of frequency decay and recovery shown in the arresting and rebound periods in the upper portion of Figure 10. This is also the window of time in which the fast-acting response of flywheel and battery storage systems excels in stabilizing the frequency. The presence of fast-acting storage assures a smoother transition from the upset period to normal operation if the grid frequency is within its normal range. The effectiveness of fast-acting storage in this application has been successfully utilized by utilities<sup>14</sup> and also described in other reports and papers.<sup>15</sup>

---

<sup>13</sup> *Use of Frequency Response Metrics to Assess the Planning and Operating Requirements for Reliable Integration of Variable Renewable Generation*, Joseph H. Eto (Principal Investigator) et al., LBNL-4142E, Lawrence Berkeley National Laboratory, Berkeley, CA, December 2010, <http://www.ferc.gov/industries/electric/indus-act/reliability/frequencyresponsometrics-report.pdf>, last accessed on March 25, 2013.

<sup>14</sup> See BEWAG and PREPA projects in Appendix G: Noteworthy Projects.

<sup>15</sup> *Energy Storage – a Cheaper, Faster and Cleaner Alternative to Conventional Frequency Regulation*, a white paper by the California Energy Storage Alliance (CESA), Berkeley, CA, ([http://www.ice-energy.com/stuff/contentmgr/files/1/76d44bfc1077e7fad6425102e55c0491/download/cesa\\_energy\\_storage\\_for\\_frequency\\_regulation.pdf](http://www.ice-energy.com/stuff/contentmgr/files/1/76d44bfc1077e7fad6425102e55c0491/download/cesa_energy_storage_for_frequency_regulation.pdf)), last accessed March 25, 2013.



**Figure 10. The Sequential Actions of Primary, Secondary, and Tertiary Frequency Controls Following the Sudden Loss of Generation and Their Impacts on System Frequency**

The size of storage systems to be used in frequency response mode is proportional to the grid or balancing area in which they are needed. Generally, storage systems in the 20 MW and greater size can provide effective frequency response due to their fast action; some studies<sup>16</sup> have shown that the response is twice as effective as a conventional fossil-fueled generator, including combustion turbines (CTs) and coal units. However, location of the storage system within the grid with respect to other generation, transmission corridors, and loads plays a crucial role in the effectiveness as a frequency response resource.

## 1.5 Transmission Infrastructure Services

### 1.5.1 Transmission Upgrade Deferral

Transmission upgrade deferral involves delaying – and in some cases avoiding entirely – utility investments in transmission system upgrades, by using relatively small amounts of storage.

Consider a transmission system with peak electric loading that is approaching the system's load-carrying capacity (design rating). In some cases, installing a small amount of energy storage

<sup>16</sup> Ibid.

downstream from the nearly overloaded transmission node could defer the need for the upgrade for a few years.

The key consideration is that a small amount of storage can be used to provide enough incremental capacity to defer the need for a large lump investment in transmission equipment. Doing so reduces overall cost to ratepayers, improves utility asset utilization, allows use of the capital for other projects, and reduces the financial risk associated with lump investments.

Notably, for most nodes within a transmission system, the highest loads occur on just a few days per year, for just a few hours per year. Often, the highest annual load occurs on one specific day with a peak somewhat higher than any other day. One important implication is that storage used for this application can provide significant benefits with limited or no need to discharge. Given that most modular storage has a high variable operating cost, this may be especially attractive in such instances.

Although the emphasis for this application is on transmission upgrade deferral, a similar rationale applies to transmission equipment life extension. That is, if storage use reduces loading on existing equipment that is nearing its expected life, the result could be to extend the life of the existing equipment. This may be especially compelling for transmission equipment that includes aging transformers and underground power cables.

### **1.5.1.1 Technical Considerations**

*Storage System Size Range: 10 – 100 MW*

*Target Discharge Duration Range: 2 – 8  
hours Minimum Cycles/Year: 10 – 50*

Energy storage must serve sufficient load, for as long as needed, to keep loading on the transmission equipment below a specified maximum.

Figure 11 illustrates the use of storage for transmission deferral. The lower plot shows storage being discharged on Wednesday afternoon to compensate for the high load on the substation transformer, as shown in the upper plot. The storage is recharged when the feeder load reduces in the late evening. Alternatively, the storage can be recharged during the late night as long as it is available to serve the peak load that the transformer is likely to see the following day(s).




Figure 11. Storage for Transmission and Distribution Deferral

### 1.5.2 Transmission Congestion Relief

Transmission congestion occurs when available, least-cost energy cannot be delivered to all or some loads because transmission facilities are not adequate to deliver that energy. When transmission capacity additions do not keep pace with the growth in peak electric demand, the transmission systems become congested. Thus during periods of peak demand, the need and cost for more transmission capacity increases along with transmission access charges. Transmission congestion may also lead to increased congestion costs or locational marginal pricing (LMP) for wholesale electricity at certain transmission nodes.

Electricity storage can be used to avoid congestion-related costs and charges, especially if the costs become onerous due to significant transmission system congestion. In this service, storage systems would be installed at locations that are electrically downstream from the congested portion of the transmission system. Energy would be stored when there is no transmission congestion, and it would be discharged (during peak demand periods) to reduce peak transmission capacity requirements.

#### 1.5.2.1 Technical Considerations


*Storage System Size Range: 1 – 100 MW*

*Target Discharge Duration Range: 1 – 4 hours*  
*Minimum Cycles/Year: 50 – 100*

The discharge duration needed for transmission congestion relief cannot be generalized easily, given all the possible options. As with the transmission upgrade deferral service, it may require only a few hours of support during the year when congestion relief is required. Generally, congestion charges apply for just a few occurrences during a year when there are several consecutive hours of transmission congestion.

Figure 12 illustrates the storage response in transmission congestion relief service. The upper plot shows four instances in which load exceeds the capacity of the transmission line. The lower

plot shows storage discharge during those four events and a recharge during the late night when the system load is lower and the transmission line is lightly loaded.



**Figure 12. Storage for Transmission Congestion Relief**

### 1.5.3 Other Related Uses

Energy storage used for transmission support improves the transmission system performance by compensating for electrical anomalies and disturbances such as voltage sag, unstable voltage, and sub-synchronous resonance. The result is a more stable system. It is similar to the network stability ancillary service that is not addressed in this Handbook. Benefits from transmission support are highly situation-specific and site-specific. Two cases are briefly described:

**Transmission Stability Damping:** Increase load-carrying capacity by improving dynamic stability.

**Sub-synchronous Resonance Damping:** Increase line capacity by allowing higher levels of series compensation by providing active real and/or reactive power modulation at sub-synchronous resonance modal frequencies.

#### 1.5.3.1 Technical Considerations

*Storage System Size Range: 10 – 100 MW*

*Target Discharge Duration Range: 5 seconds – 2*

*hours Minimum Cycles/Year: 20 – 100*

Energy storage must be capable of sub-second response, partial state-of-charge operation, and many charge-discharge cycles. For storage to be most beneficial as a transmission support resource, it should provide both real and reactive power. Typical discharge durations for transmission support are between 1 and 20 seconds.

Figure 13 shows two plots that illustrate the storage response to momentary voltage sag and a deviation in the phase angle that persists for a few seconds, as shown in the upper plot. The storage response is a quick discharge and recharge to damp the oscillation caused by the voltage

sag and phase angle deviation. As shown in the lower plot, the storage response needs to be very fast and requires high-power but lower-energy capacity.




Figure 13. Storage for Customer-side Power Quality

## 1.6 Distribution Infrastructure Services

### 1.6.1 Distribution Upgrade Deferral and Voltage Support

Distribution upgrade deferral involves using storage to delay or avoid investments that would otherwise be necessary to maintain adequate distribution capacity to serve all load requirements. The upgrade deferral could be replacing an aging or over-stressed existing distribution transformer at a substation or re-conductoring distribution lines with heavier wire.

When a transformer is replaced with a new, larger transformer, its size is selected to accommodate future load growth over the next 15- to 20-year planning horizon. Thus a large portion of this investment is underutilized for most of the new equipment's life. The upgrade of the transformer can be deferred by using a storage system to offload it during peak periods, thus extending its operational life by several years. If the storage system is containerized, then it can be physically moved to other substations where it can continue to defer similar upgrade decision points and further maximize the return on its investment.

A corollary to this strategy is that it also minimizes the ever-present risk that planned load growth does not occur, which would strand the investment made in upgrading the transformer or re-conductoring the line. This could be the case when a large load, such as a shopping mall or a

residential development, did not materialize because the developer delayed or cancelled the project after the utility had performed the upgrade in anticipation of the new load. A storage system allows not only deferring the upgrade decision point, but also allows time to evaluate the certainty that planned load growth will materialize, which could be a 2- to 3-year window.

Notably, for most nodes within a distribution system, the highest loads occur on just a few days per year, for just a few hours per year. Often, the highest annual load occurs on one specific day with a peak somewhat higher than any other day. One important implication is that storage used for this application can provide significant benefits with limited or no need to discharge.

A storage system that is used for upgrade deferral could simultaneously provide voltage support on the distribution lines. Utilities regulate voltage within specified limits<sup><sup>17</sup></sup> by tap changing regulators at the distribution substation and by switching capacitors to follow load changes. This is especially important on long, radial lines where a large load such as an arc welder or a residential PV system may be causing unacceptable voltage excursions on neighboring customers. These voltage fluctuations can be effectively damped with minimal draw of real power from the storage system.

#### **1.6.1.1 Technical Considerations**

*Storage System Size Range: 500 kilowatts (kW) – 10*

*MW Target Discharge Duration Range: 1 – 4 hours*

*Minimum Cycles/Year: 50 – 100*

Figure 14 illustrates the use of storage for T&D deferral. The lower plot shows storage being discharged on Wednesday afternoon to compensate for the high load on the substation transformer, as shown in the upper plot. The storage is recharged when the feeder load reduces in the late evening. Alternatively, the storage can be recharged during the late night, as long as it is available to serve the peak load that the transformer is likely to see the following day(s).

---

<sup>17</sup> ANSI C84.1 “American National Standard for Electric Power Systems and Equipment – Voltage Ratings (60 Hz)” establishes nominal voltage ratings for utilities to regulate the service delivery and operating tolerances at the point of use.




Figure 14. Storage for Distribution Upgrade Deferral

## 1.7 Customer Energy Management Services

### 1.7.1 Power Quality

The electric power quality service involves using storage to protect customer on-site loads downstream (from storage) against short-duration events that affect the quality of power delivered to the customer's loads. Some manifestations of poor power quality include the following:

- Variations in voltage magnitude (for example, short-term spikes or dips, longer term surges, or sags).
- Variations in the primary 60-hertz (Hz) frequency at which power is delivered.
- Low power factor (voltage and current excessively out of phase with each other).
- Harmonics (that is, the presence of currents or voltages at frequencies other than the primary frequency).
- Interruptions in service, of any duration, ranging from a fraction of a second to several seconds.

#### 1.7.1.1 Technical Considerations


*Storage System Size Range: 100 kW – 10 MW*

*Target Discharge Duration Range: 10 seconds – 15 minutes*

*Minimum Cycles/Year: 10 – 200*

Typically, the discharge duration required for the power quality use ranges from a few seconds to a few minutes. The on-site storage system monitors the utility power quality and discharges to smooth out the disturbance so that it is transparent to the load.

The upper plot in Figure 15 shows a voltage spike of 50 volts (V) and the lower plot shows storage absorbing the 50V-spike to maintain a constant 480V to the load. These anomalies in the electric supply to the customer, which can occur several times in quick succession due to events in the T&D network that supplies the customer, need to be corrected to protect sensitive processes and loads at the customer site.



**Figure 15. Storage for Customer-side Power Quality**

### 1.7.2 Power Reliability


A storage system can effectively support customer loads when there is a total loss of power from the source utility. This support requires the storage system and customer loads to island during the utility outage and resynchronize with the utility when power is restored. The energy capacity of the storage system relative to the size of the load it is protecting determines the time duration that the storage can serve that load. This time can be extended by supplementing the storage system with on-site diesel gen-sets that can continue supporting the load for long-duration outages that are beyond the capacity of the storage system.

The storage system can be owned by the customer and is under customer control at all times. An alternate ownership scenario could be that the storage system is owned by the utility and is treated as a demand-side, dispatchable resource that serves the customer needs and is available to the utility as a demand reduction resource.

### 1.7.3 Retail Energy Time-Shift

Retail electric energy time-shift involves storage used by energy end users (utility customers) to reduce their overall costs for electricity. Customers charge the storage during off-peak time periods when the retail electric energy price is low, then discharge the energy during times when on-peak time of use (TOU) energy prices apply. This application is similar to electric energy time-shift, although electric energy prices are based on the customer's retail tariff, whereas at any given time the price for electric energy time-shift is the prevailing wholesale price.

For example, a hypothetical TOU tariff is shown in Figure 16. It applies to Commercial and Industrial electricity end users from May to October, Monday through Friday, whose peak power requirements are less than or equal to 500 kW.



**Figure 16. Time of Use Summer Energy Prices for Small Commercial/Industrial Users**

As shown in Figure 16, energy prices are about 32¢/kilowatt hour (kWh) on-peak (12:00 p.m. to 6:00 p.m.). Prices during partial-peak (8:30 a.m. to 12:00 p.m. and 6:00 p.m. to 9:30 p.m.) are about 15¢/kWh, and during off-peak (9:30 p.m. to 8:30 a.m.), prices are about 10¢/kWh.

### 1.7.3.1 Technical Considerations

*Storage System Size Range: 1 kW – 1 MW*

*Target Discharge Duration Range: 1 – 6*

*hours Minimum Cycles/Year: 50 – 250*

The maximum discharge duration in this case is determined based on the relevant tariff. For example, for the assumed hypothetical tariff, there are six on-peak hours (12:00 p.m. to 6:00 p.m.). The standard value assumed for this case is 5 hours of discharge duration.

### 1.7.4 Demand Charge Management

Electricity storage can be used by end users (that is, utility customers) to reduce their overall costs for electric service by reducing their demand during peak periods specified by the utility.

To avoid a demand charge, load must be reduced during all hours of the demand charge period, usually a specified period of time (for example, 11:00 a.m. to 5:00 p.m.) and on specified days (most often weekdays). In many cases, the demand charge is assessed if load is present during just one 15-minute period, during times of the day and during months when demand charges apply.

The most significant demand charges assessed are those based on the maximum load during the peak demand period (for example, 12:00 p.m. to 5:00 p.m.) in the respective month. Although uncommon, additional demand charges for (1) part peak or (partial peak) demand that occurs during times such as shoulder hours in the mornings and evenings and during winter weekdays and (2) base-load or facility demand charges that are based on the peak demand no matter what time (day and month) it occurs.

Because there is a facility demand charge assessed during charging, the amount paid for facility demand charges offsets some of the benefit for reducing demand during times when the higher peak demand charges apply. Consider a simple example: The peak demand charge (which applies during summer afternoons, from 12:00 p.m. to 5:00 p.m.) is \$10/kW-month, and the annual facility demand charge is \$2/kW-month. During the night, when charging occurs, the

\$2/kW facility demand charge is incurred; when storage discharges mid-day (when peak demand charges apply), the \$10/kW-month demand charge is avoided. The net demand charge reduction in the example is


$$\$10/\text{kW-month} - \$2/\text{kW-month} = \$8/\text{kW-month}$$

Note that the price for electric energy is expressed in \$/kWh used, whereas demand charges are denominated in \$/kW of maximum power draw. Tariffs with demand charges have separate prices for energy and for power (demand charges). Furthermore, demand charges are typically assessed for a given month; thus demand charges are often expressed using \$/kW per month (\$/kW-month).

To reduce load when demand charges are high, storage is charged when there are no or low demand charges. (Presumably, the price for charging energy is also low.) The stored energy is

discharged to serve load during times when demand charges apply. Typically, energy storage can discharge for 5 to 6 hours, depending on the provisions of the applicable tariff.

Consider the example illustrated in Figure 17. The figure shows a manufacturer's load that is nearly constant at 1 MW for three shifts. During mornings and evenings, the end user's direct load and the facility's net demand are 1 MW. At night, when the price for energy is low, the facility's net demand doubles as low-priced energy is stored at a rate of 1 MW, while the normal load from the end user's operations requires another MW of power. During peak demand times (12:00 p.m. to 5:00 p.m. in the example), storage discharges (at the rate of 1 MW) to serve the end user's direct load of 1 MW, thus eliminating the real-time demand on the grid.



**Figure 17. On-peak Demand Reduction Using Energy Storage**

In the above example, storage is 80% efficient. To discharge for 5 hours, it must be charged for

$$5 \text{ hours} \div 0.8 = 6.25 \text{ hours.}$$

The additional 1.25 hours of charging is needed to offset energy losses. If a facility demand charge applies, it would be assessed on the entire 2 MW (of net demand) used to serve both load and storage charging.

Although it is the electricity customer who internalizes the benefit, in this scenario, it may be that the design, procurement, transaction cost, and other elements could be challenging for many prospective users, especially those with relatively small peak loads.


#### 1.7.4.1 Technical Considerations

*Storage System Size Range: 50 kW – 10*

*MW Target Discharge Duration Range: 1  
– 4 hours Minimum Cycles/Year: 50 – 500*

In this example, the storage plant discharge duration is based on a hypothetical applicable tariff. For example, a hypothetical Medium General Demand-Metered TOU tariff defines six on-peak hours from 12:00 p.m. to 6:00 p.m. It is assumed that this requires 5 hours of storage duration.

Figure 18 shows an example where the peak loads exceed the threshold set by the first peak of the month on Monday afternoon. That sets the level for the remaining month; loads must remain below that threshold to avoid demand charge penalties.



**Figure 18. Storage for Customer-side Demand Management**

## 1.8 Stacked Services—Use Case Combinations

Electricity storage can be used for any of the services listed above, but it is rare for a single service to generate sufficient revenue to justify its investment. However, the flexibility of storage can be leveraged to provide multiple or stacked services, or use cases, with a single storage system that captures several revenue streams and becomes economically viable. How these services are stacked depends on the location of the system within the grid and the storage technology used. However, due to regulatory and operating constraints, stacking services is a process that requires careful planning and should be considered on a case-by-case basis.

In the California Public Utility Commission's (CPUC's) energy storage proceeding R1012007, a series of electricity storage use cases was considered and studied by multiple stakeholders.

## Chapter 1. Electricity Storage Services and Benefits

CPUC divided the use cases into three general categories based on the location of the storage as shown in Table 2. When connected to the grid at the transmission level, energy storage can provide grid-related service to ancillary markets under the control of ISOs while bidding into the energy market. Energy storage can also act as a peaker to provide system capacity. When placed on the distribution circuits, energy storage can help solve local substation-specific problems (mitigating voltage problems, deferring investment upgrades) while providing ancillary services to the grid. On the customer side of the meter, an energy storage system can shave the customer's peak load and reduce the electricity bill while improving power quality and reliability. Detailed documents about the CPUC-defined electricity storage use cases can be found on the CPUC website.<sup>18</sup> As part of the CPUC proceeding's effort to understand better the cost-effectiveness of different electricity storage use cases, EPRI conducted cost-benefit analyses using the Energy Storage Valuation Tool (ESVT), discussed in ESHB 2013 Chapter 3, for a subset of the CPUC use cases, including the bulk storage peaker substitution use case, the ancillary services only use case, and the distributed peaker use case. The results of the EPRI analyses<sup>19</sup> were presented in a public workshop in March 2013.

**Table 2. Illustration of California Public Utility Commission Use Cases**(Source: EPRI presentation in CPUC Storage OIR Workshop, March 25, 2013<sup>20</sup>)

Use Case	Categories
Transmission-Connected Energy Storage	Bulk Storage System
	Ancillary Services
	On-Site Generation Storage
	On-Site Variable Energy Resource Storage
Distributed-Level Energy Storage	Distributed Peaker
	Distributed Storage Sited at Utility Substation
	Community Energy Storage
Demand-Side (Customer-Sited) Energy Storage	Customer Bill Management
	Customer Bill Management w/ Market Participation
	Behind the Meter Utility Controlled
	Permanent Load Shifting
	EV Charging

A detailed discussion of the methodology to determine and evaluate viable electricity storage use cases can be found in Chapter 3 of this Handbook. Various business models for acquiring storage systems can be found in Chapter 4.

<sup>18</sup> <http://www.cpuc.ca.gov/PUC/energy/electric/storage.htm>, last accessed March 15, 2013.

<sup>19</sup> Energy Storage Valuation Tool Draft Results—Investigation of Cost Effectiveness Potential for Select CPUC Inputs and Storage Use Cases in 2015 and 2020, EPRI Energy Storage Program, CPUC Storage OIR Workshop (R.10-12-007), <http://www.cpuc.ca.gov/PUC/energy/electric/storage.htm>; last accessed March 25, 2013.

<sup>20</sup> Ibid.

## 1.9 Summary

The first chapter reviews 14 services and functional uses, including electricity storage services to the grid, ancillary services, grid system services and functional uses, end user/utility customer functional services, and renewables integration that electricity storage provides to the grid as a generation, T&D, and customer-side resource. The chapter also provides a brief review of simultaneous use of electricity storage for multiple applications (stacked).

## 1.10 Extended Technical Discussion

Nevada's Energy Electricity Valuation study examines how grid-level electricity storage may benefit from the operations of NV Energy, and assesses whether those benefits are likely to justify the cost of the storage system. To determine the impact of grid-level storage, an hourly production cost model of the Nevada Balancing Authority as projected for 2020 was created.

Storage was found to add value primarily through the provision of regulating reserve. Certain storage resources were found likely to be cost-effective even without considering their capacity value, as long as their effectiveness in providing regulating reserve was taken into account. Giving fast resources credit for their ability to provide regulating reserve is reasonable, given the adoption of FERC Order 755 ("Pay-for-performance"). Using a traditional 5-minute test to determine how much a resource can contribute to regulating reserve does not adequately value fast-ramping resources, as the regulating reserve these resources can provide is constrained by their installed capacity. While an approximation was made to consider the additional value provided by a fast-ramping resource, a more precise valuation requires an alternate regulating reserve methodology.

<http://www.sandia.gov/ess/publications/SAND2013-4902.pdf>



## CHAPTER 2    **ELECTRICITY STORAGE TECHNOLOGIES: COST, PERFORMANCE, AND MATURITY**

### **2.1 General Information**


This chapter presents currently available and emerging electricity storage technologies that can be used for services to the electric grid. The sections in this chapter are organized by technology and provide a general technical description, design features, performance characteristics, applications and example installations. The first section includes existing grid-scale electricity storage technologies and applications. Emerging technologies that may have an impact on the electric grid and are still at the early stages of research and development (R&D) are presented last, primarily using a summary chart format.

### **2.2 Approach**

Chapter 2 contains the technical description, design features, and performance characteristics of mature and emerging energy storage technologies. Grid-scale applications of each existing technology are defined along with installation considerations. Summary charts provide the reader a means to compare and contrast the various technologies: applications, challenges, advantages, and disadvantages. Finally, a comprehensive discussion of selected mature technologies is included.

### **2.3 Data Mature Electricity Storage Technologies**

The portfolio of electricity storage technologies can be considered for providing a range of services to the electric grid and can be positioned around their power and energy relationship. This relationship is illustrated in Figure 19, which shows that CAES and pumped hydro are capable of discharge times in tens of hours, with correspondingly high sizes that reach 1000 MW. In contrast to the capabilities of these two technologies, various electrochemical batteries and flywheels are positioned around lower power and shorter discharge times. In Figure 19, these comparisons are very general, intended for conceptual purposes only; many of the storage options have broader duration and power ranges than shown.



**Figure 19. Positioning of Energy Storage Technologies**

Traditionally, economies of scale have dictated that pumped hydro be sized for storage times that exceed 8 to 10 hours, which is necessary to amortize the cost of large storage reservoirs, dams, and civil engineering work that are integral to this technology. For example, Rocky Mountain Hydroelectric Plant, the last pumped storage plant built in the United States, has over 10 hours of storage capacity and is rated at 1095 MW. Similarly, CAES requires developing large underground (naturally occurring or man-made caverns) or large steel aboveground storage reservoirs to store the compressed air. In contrast to these large sizes, flywheels and the family of batteries cluster in the lower end of the discharge duration spectrum, ranging from a few seconds to 6 hours (delivered by sodium sulfur battery systems and potentially certain flow battery systems).

Storing hot or cold fluids or phase change materials provides the basis for various thermal storage technologies that provide cooling for buildings or electricity generation. Some examples of thermal storage technologies are briefly discussed below.

Ice and chilled water storage is effectively used in large and medium sized commercial buildings to reduce refrigerated air conditioning loads and is widely applied in Leadership in Energy and Environmental Design (LEED)<sup>21</sup> certified buildings. Ice or chilled water is made and stored in large indoor or outdoor tanks using low-priced off-peak energy at night. Cooling loops running

<sup>21</sup> LEED is a green building certification program that recognizes best-in-class building strategies and practices administered by The U.S. Green Building Council.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

through the ice or chilled water tanks extract the cold during daytime hours to provide cooling to the building and displace the compressor and chiller motor electric loads during peak cooling hours. This is a cost-saving strategy for the utility or co-op customer and offers a demand-side load management strategy for the serving utility.

Alternatively, large area solar collectors can heat salts or other organic oils and store these at temperatures sufficiently high to generate steam when needed to drive turbine generators to make electricity. These systems are usually economic above several hundred megawatts, with storage times exceeding 6 to 8 hours. The size of the solar collectors and storage tank capacity determines the storage times that the system can support.

More than 50 original equipment manufacturers (OEMs), power electronics system providers, and system integrators were surveyed and asked to provide performance, cost, and O&M data for energy systems they could offer for various uses of storage.

For technology screening-level studies, these cost estimates are conceptual estimates that differed from site-specific project estimates for the following reasons:

- Project estimates are more detailed and based on site-specific conditions and use cases. Individual companies' design bases may vary.
- Actual owner costs as well as site-specific costs in project estimates are generally higher.
- Site-specific requirements, such as transportation, labor, interconnection, and permitting, also have an impact.

As presented in Table 2, a rating system is used to define an overall confidence level for data presented in technology screening studies. One rating approach is based on a technology's development status; the other is based on the level of effort expended in the design and cost estimate. The confidence levels of the estimates presented in this report reflect technology development statuses ranging from early demonstration trials to mature development, with a preliminary or simplified level of effort. The rating system indicates the level of effort involved in developing the design and cost estimate.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

**Table 2. Confidence Rating Based on Cost and Design Estimate**

Letter Rating	Key Word	Description
A	Actual	Data on detailed process and mechanical designs or historical data from existing units
B	Detailed	Detailed process design (Class III design and cost estimate)
C	Preliminary	Preliminary process design (Class II design and cost estimate)
D	Simplified	Simplified process design (Class I design and cost estimate)
E	Goal	Technical design/cost goal for value developed from literature data

Estimates of the range of accuracy for the cost data presented in this section are shown in Table 3, which is based on the confidence ratings described previously.

**Table 3. Accuracy Range Estimates for Technology Screening Data\***

		Percent Accuracy in Technology Development Rating				
	Estimate Rating	A Mature	B Commercial	C Demo	D Pilot	E & F Lab & Idea
A	Actual	0	–	–	–	–
B	Detailed	-5 to +8	-10 to +15	-15 to +25	–	–
C	Preliminary	-10 to +15	-15 to +20	-20 to +25	-25 to +40	-30 to +60
D	Simplified	-15 to +20	-20 to +30	-25 to +40	-30 to +50	-30 to +200
E	Goal	–	-30 to +80	-30 to +80	-30 to +100	-30 to +200

This table indicates the overall accuracy for cost estimates. The accuracy is a function of the level of cost-estimating effort and the degree of technical development of the technology. The same ranges apply to O&M costs.

\* Ranges in percent (%).


## 2.4 Pumped Hydro

Pumped hydroelectric energy storage is a large, mature, and commercial utility-scale technology currently used at many locations in the United States and around the world. Table 4 is a technology dashboard that shows the status of technology development for pumped hydro systems. Pumped hydro employs off-peak electricity to pump water from a reservoir up to another reservoir at a higher elevation. When electricity is needed, water is released from the upper reservoir through a hydroelectric turbine into the lower reservoir to generate electricity.

Figure 20 shows a cutaway view of a typical pumped hydro plant, and Figure 21 is a picture of the upper reservoir of the Tennessee Valley Authority's (TVA's) Raccoon Mountain pumped storage facility. This storage technology has the highest capacity of all the storage technologies assessed, because its size is limited only by the size of the available upper and lower reservoirs.

**Table 4. Technology Dashboard: Pumped Hydro**

Technology Development Status	Mature	Numerous New Pumped Hydro FERC Filings in U.S.
Operating Stations	40 units (20+ GW) in U.S.	Over 129 GW in operation worldwide
Process Contingency	0%	Variable-speed drive technology being applied to new sites
Project Contingency	10 – 15%	Uncertainties in siting, permitting, environmental impact and construction


**Figure 20. Cutaway Diagram of a Typical Pumped Hydro Plant****Figure 21. Man-made Upper Reservoir of TVA's Raccoon Mountain Pumped Hydro Plant**  
(Operational in 1979, the facility can generate 1620 MW for up to 22 hours.)

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

Projects may be practically sized up to 4000 MW and operate at about 76% to 85% efficiency, depending on design. Pumped hydro plants have long lives, on the order of 50 to 60 years. As a general rule, a reservoir 1 kilometer in diameter, 25 meters deep, and having an average head of 200 meters would hold enough water to generate 10,000 MWh.

The earliest plant in the United States was built in the late 1920s, and the last pumped storage plant commissioned was in the 1980s, when environmental concerns over water and land use severely limited the ability to build additional pumped hydro capacity. Figure 22 provides a list of Pumped Storage Preliminary Permits/Proposed Projects in the United States. In Europe, over 15 GW of new pumped hydro facilities are expected to be installed by 2020, and future deployments in Asia are also expected to grow during this time period.

While the siting, permitting, and associated environmental impact processes can take many years, there is growing interest in re-examining opportunities for pumped hydro in the United States, particularly in view of the large amounts of wind generation and new nuclear power generation that may be deployed over the next few decades. A list of licensed pumped storage facilities and pending permits is maintained by FERC at <http://www.ferc.gov/industries/hydropower/gen-info/licensing/pump-storage.asp>.



**Figure 22. Pumped Storage Preliminary Permits/Proposed Projects in the United States**


## 2.4.1 Additional Pumped Hydro Resources

1. [Quantifying the Value of Hydro Power on the Electric Grid: Plant Cost Elements](#), EPRI Report 1023140, EPRI, Palo Alto, CA, November 2011.
2. [Application of Adjustable-Speed Machines in Conventional and Pumped-Storage Hydro Projects](#), EPRI ID TR-105542, EPRI, Palo Alto, CA, February 1996.
3. [Operation and Maintenance Experiences of Pumped-Storage Plants](#), EPRI ID GS-7325, EPRI, Palo Alto, CA, May 1991.
4. [Results from Case Studies of Pumped-Storage Plants](#), EPRI ID 1023142, EPRI, Palo Alto, CA, September 2012.

## 2.5 Compressed Air Energy Storage

### 2.5.1 Technical Description

CAES systems use off-peak electricity to compress air and store it in a reservoir, either an underground cavern or aboveground pipes or vessels. When electricity is needed, the compressed air is heated, expanded, and directed through an expander or conventional turbine-generator to produce electricity. Figure 23 is a schematic of a CAES plant with underground storage cavern in a salt dome.



**Figure 23. Schematic of Compressed Air Energy Storage Plant with Underground Compressed Air Storage**

CAES is the only commercial bulk energy storage plant available today, other than pumped hydro. There are two operating first-generation systems: one in Germany and one in Alabama. In the past few years, improved second-generation CAES system cycles have been defined and are

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

being designed. Second-generation CAES hold the potential for lower installed costs, higher efficiency, and faster construction time than the first-generation systems. In one type of advanced second-generation CAES plant, a natural-gas-fired CT is used to generate heat during the expansion process. In such a plant, about two-thirds of the electricity generated is produced from the expansion turbine and about one-third from the CT. New compressor designs and advanced turbo-machinery are also leading to improved non-CT-based CAES systems.

CAES plants employing aboveground air storage would typically be smaller than plants with underground storage, with capacities on the order of 3 to 50 MW and discharge times of 2 to 6 hours.

Aboveground CAES plants are easier to site but more expensive to build (on a \$/kW basis) than CAES plants using underground air storage systems, primarily due to the incremental additional cost associated with aboveground storage. CAES systems using improved first-generation designs also continue to be evaluated and are being proposed.

Underground CAES storage systems are most cost-effective with storage capacities up to 400 MW and discharge times of 8 to 26 hours. Siting such plants involves finding and verifying the air storage integrity of a geologic formation appropriate for CAES in a given utility's service territory.

### 2.5.1.1 **Maturity and Commercial Availability**

There are two operating first-generation CAES systems: one in Germany and one in the state of Alabama in the United States. The first-generation CAES plant at PowerSouth Energy Cooperative (formerly Alabama Electric Cooperative) has operated reliably for 18 years and successfully demonstrated the technical viability of this early design. A 290-MW, 4-hour CAES plant has been operating in Huntorf, Germany, since December 1978, demonstrating strong performance with 90-percent availability and 99-percent starting reliability. This plant uses two man-made, solution-mined salt caverns to store the air.

EPRI is collaborating with Pacific Gas and Electric (PG&E) in a DOE-awarded grant to support site, design, and demonstration testing of a 300-MW/10-hour CAES plant.

Table 5 is a technology dashboard that shows the status of technology development for second-generation CAES.

**Table 5. Technology Dashboard: Compressed Air Energy Storage**

<b>Technology Development Status</b>	1 <sup>st</sup> Generation Mature 2 <sup>nd</sup> Generation – Demonstration	Commercial offer possible. System to be verified by demonstration unit.
<b>Operating Field Units</b>	2 <sup>nd</sup> Generation – None	Two of first-generation type.
<b>Process Contingency</b>	15%	Key components and controls need to be verified for second-generation systems.
<b>Project Contingency</b>	10%	Plant costs will vary depending upon underground site geology.

### 2.5.1.2 Additional CAES Resources

1. [Electricity Storage Technology Options: A White Paper Primer on Applications, Costs and Benefits](#). December 2010. EPRI Report 1020676.
2. [History of First U.S. Compressed-Air Energy Storage \(CAES\) Plant \(110 MW 26h\): Volume 2: Construction](#), EPRI ID TR-101751-V2, EPRI, Palo Alto, CA, May 1994.
3. [History of First U.S. Compressed Air Energy Storage \(CAES\) Plant \(110-MW-26 h\): Volume 1: Early CAES Development](#), EPRI ID 101751-V1, EPRI, Palo Alto, CA, January 1993.
4. [Midwest Independent Transmission System Operator \(MISO\) Energy Storage Study](#), EPRI ID 1024489, EPRI, Palo Alto, CA, February 2012.
5. [Evaluation of Benefits and Identification of Sites for a CAES Plant in New York State](#), EPRI TR-104268, EPRI, Palo Alto, CA, September 1994.

## 2.6 Sodium-sulfur Battery Energy Storage

### 2.6.1 Technical Description

Sodium-sulfur (NaS) batteries are a commercial energy storage technology finding applications in electric utility distribution grid support, wind power integration, and high-value grid services. NaS battery technology holds potential for use in grid services because of its long discharge period (approximately 6 hours). Like many other storage technologies, it is capable of prompt, precise response to such grid needs as mitigation of power quality events and response to AGC signals for area regulation.<sup>22</sup>

The normal operating temperature regime of NaS cells during discharge/charge cycles is in the range of 300 °C to 350 °C. During discharge, the sodium (negative electrode) is oxidized at the sodium/beta alumina interface, forming Na<sup>+</sup> ions. These ions migrate through the beta alumina solid electrolyte and combine with sulfur that is being reduced at the positive electrode to form sodium pentasulfide (Na<sub>2</sub>S<sub>5</sub>). The Na<sub>2</sub>S<sub>5</sub> is immiscible with the remaining sulfur, thus forming a two-phase liquid mixture (Figure 24).<sup>23</sup>

After all the free sulfur phase is consumed, the Na<sub>2</sub>S<sub>5</sub> is progressively converted into single-phase sodium polysulfides with progressively higher sulfur content (Na<sub>2</sub>S<sub>5-x</sub>). Cells undergo

---


<sup>22</sup> *Electric Energy Storage Technology Options: A Primer on Applications, Costs and Benefits*, PI: Rastler, Dan, EPRI ID 1020676, EPRI, Palo Alto, CA, September 2010.

<http://www.epri.com/abstracts/Pages/ProductAbstract.aspx?ProductId=00000000001020676>.

<sup>23</sup> Courtesy of EPRI.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

exothermic and ohmic heating during discharge. Although the actual electrical characteristics of NaS cells are design-dependent, voltage behavior follows that predicted by thermodynamics.<sup>24</sup>



**Figure 24. Chemical Structure of a Sodium-sulfur Cell**

After all the free sulfur phase is consumed, the  $\text{Na}_2\text{S}_5$  is progressively converted into single-phase sodium polysulfides with progressively higher sulfur content ( $\text{Na}^2\text{S}_{5-x}$ ). Cells undergo exothermic and ohmic heating during discharge. Although the actual electrical characteristics of NaS cells are design-dependent, voltage behavior follows that predicted by thermodynamics.<sup>25</sup>

The NaS batteries use hazardous materials including metallic sodium, which is combustible if exposed to water. Therefore, construction of NaS batteries includes airtight, double-walled stainless-steel enclosures that contain the series-parallel arrays of NaS cells. Each cell is hermetically sealed and surrounded with sand both to anchor the cells and to mitigate fire, as shown in Figure 25. Other safety features include fused electrical isolation and a battery management system that monitors cell block voltages and temperature. The sodium, sulfur, beta-alumina ceramic electrolyte, and sulfur polysulfide components of the battery are disposed of by routine industrial processes or recycled at the end of the NaS battery life. NaS batteries can be

<sup>24</sup> EPRI-DOE Handbook of Energy Storage for Transmission and Distribution Applications, L. D. Mears, H. L. Gotschall - Technology Insights; T. Key, H. Kamath - EPRI PEAC Corporation; EPRI ID 1001834, EPRI, Palo Alto, CA, and the US Department of Energy, Washington, DC, 2003.

<http://www.epri.com/abstracts/Pages/ProductAbstract.aspx?ProductId=000000000001001834>.

<sup>25</sup> EPRI-DOE Handbook of Energy Storage for Transmission and Distribution Applications, L. D. Mears, H. L. Gotschall - Technology Insights; T. Key, H. Kamath - EPRI PEAC Corporation; EPRI ID 1001834, EPRI, Palo Alto, CA, and the US Department of Energy, Washington, DC, 2003.

<http://www.epri.com/abstracts/Pages/ProductAbstract.aspx?ProductId=000000000001001834>.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

installed at power generating facilities, substations, and at renewable energy power generation facilities where they are charged during off-peak hours and discharged when needed. Battery modules contain cells, a heating element, and dry sand.

NGK Insulators, Ltd., and Tokyo Electric Power Co. (TEPCO) jointly developed NaS battery technology over the past 25 years. “NAS” is a registered trademark for NGK’s sodium-sulfur battery system, while “NaS” is a generic term used to refer to sodium-sulfur based on those elements’ atomic symbols (“Na” and “S”). Standard units typically used in energy storage installations from NGK Insulators, Ltd., contain five 50-kW NaS modules that include a control unit, heater, heater controller, and voltage and current measurement sensors. Multiple, parallel standard units are used to create multi-megawatt systems.




Figure 25. Sodium-sulfur Battery Module Components<sup>26</sup>

### 2.6.1.1 Performance Characteristics

Energy density by volume for NaS batteries is 170 kWh/m<sup>3</sup> and by weight is 117 kWh/ton. NGK projects its NAS to have a cycle life of 4500 cycles for rated discharge capacity of 6 MWh per installation MW. Rated at 4500 cycles, NaS batteries are projected to have a calendar life of 15 years.

Table 6 summarizes the performance characteristics of NaS batteries provided by the manufacturer.

<sup>26</sup> 1 MW / 7.2 MWh NaS Battery Demonstration and Case Study Update, EPRI, EPRI ID: 1017814, EPRI, Palo Alto, CA: December 2009.

**Table 6. Performance Characteristics of NaS Batteries<sup>27</sup>**

Energy Density (Volume)	170 kWh/m <sup>3</sup>
Energy Density (Weight)	117 kWh/ton
Charge/Discharge Efficiency – Batteries (DC Base)	> 86 percent
Charge/Discharge Efficiency – System (AC Base)	≥ 74 percent
Maintenance	Low
Cycle Life	4,500 cycles at rated capacity
Calendar Life	15 yr

Based on vendor data the round-trip ac-to-ac efficiency of NaS systems is approximately 75%. The estimated life of a NaS battery is approximately 15 years after 4500 cycles at rated discharge.<sup>28</sup>

### **2.6.1.2 Maturity and Commercial Availability**

NaS installations providing the functional equivalent of about 160 MW of pumped hydro storage are currently deployed within Tokyo. NaS batteries are only available in multiples of MW/6-MWh units with installations typically in the range of 2 to 10 MW. The largest single installation is the 34-MW Rokkasho wind-stabilization project in Northern Japan that has been operational since August 1, 2008. At this time, about 316 MW of NaS installations have been deployed globally at 221 sites, representing 1896 MWh. Customers in the United States include American Electric Power (AEP) (11 MW deployed at five locations), PG&E (6 MW, in progress), and Xcel Energy (1 MW, deployed).

The NAS battery installation provided by NGK Insulators, Ltd., deployed at Xcel in Lucerne, MN, in 2008 contains 20 50-kW modules with 7.2 MWh of storage capacity and a charge-discharge capacity of 1 MW (Figure 26). Batteries are charged when wind turbines are operating. The batteries then provide supplemental power when the turbines are not operating. Xcel estimates the fully charged NAS facility could power 500 homes for over 7 hours.

<sup>27</sup> Performance characteristics provided by the manufacturer, NGK.

<sup>28</sup> *Electric Energy Storage Technology Options: A White Paper Primer on Applications, Costs, and Benefits*, EPRI, EPRI ID: 1020676. EPRI, Palo Alto, CA, September 2010.

<http://www.epri.com/abstracts/Pages/ProductAbstract.aspx?ProductId=00000000001020676>



**Figure 26. Xcel Battery Supplementing Wind Turbines, Lucerne, MN**

Table 7 shows the technology dashboard for NaS battery systems.

**Table 7. Technology Dashboard: Sodium-sulfur Battery Systems**

<b>Technology Development Status</b>	A	Significant recent commercial experience.
<b>Operating Field Units</b>	221 sites	306 MW installed.
<b>Process Contingency</b>	0%	Proven battery performance.
<b>Project Contingency</b>	1-5%	Depending on site conditions.

NaS technology has evolved since the 1970s and offers electrical energy storage application solutions for grid-scale systems. The advantages and disadvantages of NaS battery technologies observed by David Linden are shown in Table 8.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

**Table 8. Advantages and Limitations of Sodium/Sulfur Battery Technology, from *Handbook of Batteries, Third Edition*, by David Linden**

Characteristic	Comments
<b>Advantages</b>	
Potential low cost relative to other advanced batteries	Inexpensive raw materials, sealed, no-maintenance configuration
High cycle life	Low-density active materials, high cell voltage
High energy good power density	Cells functional over wide range of conditions (rate, depth of discharge, temperature)
Flexible operation	80+% due to 100% coulombic efficiency and reasonable resistance
High energy efficiency	Sealed high-temperature systems
Insensitivity to ambient conditions	High resistance at top of charge and straightforward current integration due to 100% coulombic operation
State-of-charge identification	
<b>Limitations</b>	
Thermal management	Effective enclosure required to maintain energy efficiency and provide adequate stand time
Safety	Reaction with molten active materials must be controlled
Durable seals	Cell hermeticity required in a corrosive environment
Free-thaw durability	Due to the use of a ceramic electrolyte with limited fracture toughness that can be subjected to high levels of thermally driven mechanical stress

**2.6.1.3 Additional Sodium-Sulfur Battery Resources**


1. [Program on Technology Innovation: Long Island Bus NaS Battery Energy Storage System](#), EPRI ID 1013248, EPRI, Palo Alto, CA, EPRI ID 1013248, March 2006.
2. [Program on Technology Innovation: New York Power Authority Advanced Sodium Sulfur \(NaS\) Battery Energy Storage System](#), EPRI ID 1023626, EPRI, Palo Alto, CA, December 2011.
3. [AEP Sodium-Sulfur \(NaS\) Battery Demonstration - 2003 Annual Report](#), EPRI ID 1009814, EPRI, Palo Alto, CA, August 2004.
4. [AEP Sodium-Sulfur \(NaS\) Battery Demonstration: Final Report](#), EPRI ID 1012049, EPRI, Palo Alto, CA, June 2005.
5. [Field Trial of AEP Sodium-Sulfur \(NaS\) Battery Demonstration Project: Interim Report - Plant Design and Expected Performance](#), EPRI ID 1001835, EPRI, Palo Alto, CA, March 2003.

6. [Functional Requirements for Electric Energy Storage Applications on the Power System Grid, What Storage Has to Do to Make Sense](#), EPRI ID 1021936, EPRI, Palo Alto, CA, December 2011.

## 2.7 Sodium-nickel-chloride Batteries

### 2.7.1 Technical Description

Sodium-nickel-chloride batteries are high-temperature battery devices like NaS. Figure 27 illustrates the design of this battery and key principles. When charging a sodium-nickel-chloride battery at normal operating temperatures, salt (NaCl) and nickel (Ni) are transformed into nickel-chloride ( $\text{NiCl}_2$ ) and molten sodium (Na). The chemical reactions are reversed during discharge, and there are no chemical side reactions. The electrodes are separated by a ceramic wall (electrolyte) that is conductive for sodium ions but an isolator for electrons. Therefore, the cell reaction can occur only if an external circuit allows electron flow equal to the sodium ion current. The porous solid  $\text{NiCl}_2$  cathode is impregnated with a sodium ion conductive salt ( $\text{NaAlCl}_4$ ) that provides a conductive path between the inside wall of the separator and the reaction zone. Cells are hermetically sealed and packaged into modules of about 20 kWh each.



**Figure 27. Design and Principal Features of Sodium-nickel-chloride Batteries**  
(Courtesy FIAMM)

The internal normal operating temperature of 270 °C to 350 °C is required to achieve acceptable cell resistance and must be thermally managed by design features.

Two battery OEM suppliers have production facilities operating and are starting to deploy systems in the size range of 50 kW to 1 MW. By the end of 2013, several fully integrated systems were expected to be deployed for utility grid support and renewable integration.

Figure 28 and Figure 29 show two FIAMM-developed containerized systems deployed at utility sites



**Figure 28. FIAMM 222-kWh System Site at the Duke Energy Rankin Substation**



**Figure 29. Containerized 25-kW/50-kWh FIAMM Battery Unit (large green housing) on Concrete Pad, Next to S&C PureWave CES (small green housing)**

### 2.7.1.1 **Maturity and Commercial Availability**

Table 9 presents the technology dashboard for NaNiCl<sub>2</sub> stationary storage systems.

**Table 9. Technology Dashboard for Sodium-nickel-chloride Batteries**

Technology Development Status	Demonstration C	Limited Field Demonstrations
Operating Field Units	2 or more	Several photovoltaic and distributed storage installations by 2012
Process Contingency	5 – 10%	Limited testing and field experience
Project Contingency	5 – 10%	Limited data on life-cycle costs; limited operation and maintenance cost data

### 2.7.1.2 **Additional Sodium-nickel-chloride Battery Resource**

1. [Technology Review and Assessment of Distributed Energy Resources](#), EPRI ID 1012983, EPRI, Palo Alto, CA, February 2006.


## 2.8 Vanadium Redox Batteries

### 2.8.1 Technical Description

Vanadium reduction and oxidation (redox) batteries are of a type known as flow batteries, in which one or both active materials is in solution in the electrolyte at all times. In this case, the vanadium ions remain in an aqueous acidic solution throughout the entire process.

The vanadium redox flow battery is a flow battery based on redox reactions of different ionic forms of vanadium. During battery charge, V<sup>3+</sup> ions are converted to V<sup>2+</sup> ions at the negative electrode through the acceptance of electrons. Meanwhile, at the positive electrode, V<sup>4+</sup> ions are converted to V<sup>5+</sup> ions through the release of electrons. Both of these reactions absorb the electrical energy put into the system and store it chemically. During discharge, the reactions run in the opposite direction, resulting in the release of the chemical energy as electrical energy.

In construction, the half-cells are separated by a proton exchange membrane that allows the flow of ionic charge to complete the electrical circuit. Both the negative and positive electrolytes (sometimes called the anolyte and catholyte, respectively) are composed of vanadium and sulfuric acid mixture at approximately the same acidity as that found in a lead-acid battery. The electrolytes are stored in external tanks and pumped as needed to the cells (see Figure 30).



**Figure 30. Construction of a Vanadium Redox Cell Stack**  
(Courtesy Sumitomo Electric Industries)

Individual cells have a nominal open-circuit voltage of about 1.4 V. To achieve higher voltages, cells are connected in series to produce cell stacks. Vanadium redox flow batteries have an important advantage among flow batteries: the two electrolytes are identical when fully discharged. This makes shipment and storage simple and inexpensive and greatly simplifies electrolyte management during operation.<sup>29</sup>

Self-discharge is typically not a problem for vanadium redox systems, because the electrolytes are stored in separate tanks. Self-discharge may occur within the cell stack if it is filled with charged electrolyte, resulting in the loss of energy and heat generation in the stacks. For this reason, the stacks are usually elevated above the tanks, so that electrolyte drains back into the tanks when the pumps are shut down. The battery will then take a short while to come back into operation again. Alternatively, the pumps can operate in an idling state, which would allow charged electrolyte to be available at all times, at the price of a slightly higher parasitic loss.<sup>30</sup>

The life of a vanadium redox system is determined by a number of components. The cell stack is probably the limited life component, with a useful life estimated at ~10 years; however, operational field data are not available to confirm these lifetimes. The tanks, plumbing, structure, power electronics, and controls have a longer useful life. The electrolytes and the active materials they contain do not degrade with time.

<sup>29</sup> VRB Energy Storage for Voltage Stabilization: Testing and Evaluation of the PacifiCorp Vanadium Redox Battery Energy Storage System at Castle Valley, Utah, EPRI ID 1008434, EPRI, Palo Alto, CA, 2005.

<sup>30</sup> EPRI-DOE Handbook of Energy Storage for Transmission and Distribution Applications, EPRI, Palo Alto, CA, and the U.S. Department of Energy, Washington, DC: 2003. 1001834. L. D. Mears, H. L. Gotschall - Technology Insights; T. Key, H. Kamath - EPRI PEAC Corporation; <http://www.epri.com/abstracts/Pages/ProductAbstract.aspx?ProductId=000000000001001834>.


## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

Vanadium redox systems are capable of stepping from zero output to full output within a few milliseconds, if the stacks are already primed with reactants. In fact, the limiting factor for beginning battery discharge is more commonly the controls and communications equipment. For short-duration discharges for voltage support, the electrolyte contained in the stacks can respond without the pumps running at all. The cell stack can produce three times the rated power output provided the state of charge is between 50% and 80%.<sup>31</sup>

The physical scale of vanadium redox systems tends to be large due to the large volumes of electrolyte required when sized for utility-scale (megawatt-hour) projects. Unlike many other battery technologies, cycle life of vanadium redox systems is not dependent on depth of discharge. Systems are rated at 10,000 cycles, although some accelerated testing performed by Sumitomo Electric Industries, Ltd., produced a battery system with one 20-kW stack for cycle testing that continued for more than 13,000 cycles over about 2 years.

When decommissioning a vanadium redox system, the solid ion exchange cell membranes may be highly acidic or alkaline and therefore toxic. They should be disposed of in the same manner as any corrosive material. If possible, the liquid electrolyte is recycled. If disposed of, the vanadium is extracted from the electrolyte before further processing of the liquid. Research is ongoing to determine the exact environmental risk factors for vanadium.

Figure 31<sup>32</sup> illustrates the schematic of a vanadium redox flow battery.



**Figure 31. Principles of the Vanadium Redox Battery**  
(Courtesy of the Pacific Northwest National Laboratory)

<sup>31</sup> Ibid.

<sup>32</sup> VRB Energy Storage for Voltage Stabilization: Testing and Evaluation of the PacifiCorp Vanadium Redox Battery Energy Storage System at Castle Valley, Utah, PI: Harash Kamath – EPRI PEAC Corporation, EPRI ID 1008434, EPRI, Palo Alto, CA, March 2005.

### 2.8.1.1 Technical Maturity

Table 10 illustrates a dashboard for a vanadium flow battery system. This type of flow battery is technically the most mature.

Vanadium redox systems have been demonstrated in a number of applications and large-scale field trials (see Figure 32).

**Table 10. Technology Dashboard: Vanadium Flow-Type Battery Systems**

Technology Development Status	Pre-Commercial C	Systems Verified in Limited Field Demonstrations
Operating Field Units	Units operating in renewable integration, end-user energy management, and telecom applications	Currently 50-kW, 100-kW, 500-kW, 600-kW, and 1000-kW systems in operation. The largest in the U.S. is a 600-kW/3600-kWh system in a customer energy-management application. A 1-MW/5-MWh system is in operation in Japan.
Process Contingency	5 – 8%	For MW-scale applications
Project Contingency	5 – 7%	For MW-scale applications Contingency will vary by size of the application. Vendors are offering 10-year energy services contracts.



**Figure 32. Prudent Energy 600-kW/3,600-kWh VRB-ESS Installed at Gills Onions, Oxnard, CA**

The system consists of 200-kW modules providing a total of 6 hours of electrochemical energy storage.


### 2.8.1.2 Additional Vanadium Redox Battery Resources

2. [VRB Energy Storage for Voltage Stabilization: Testing and Evaluation of the PacifiCorp Vanadium Redox Battery Energy Storage System at Castle Valley, Utah](#), EPRI ID 1008434, EPRI, Palo Alto, CA, March 2005.
3. [Vanadium Redox Flow Batteries](#), EPRI ID 1014836, EPRI, Palo Alto, CA, March 2007.
4. [Assessment of Advanced Batteries for Energy Storage Applications in Deregulated Electric Utilities](#), EPRI ID TR-111162, EPRI, Palo Alto, CA, December 1998.

## 2.9 Iron-chromium Batteries

### 2.9.1 Technical Description


Iron-chromium (Fe-Cr) redox flow battery systems is another type of flow battery still in the R&D stage but steadily advancing toward early field demonstrations in 2013 and 2014. The low-cost structure of these systems also makes them worth evaluating for grid-storage solutions. Given the considerable uncertainties in performance and cycle life, process and project contingencies are high. Figure 33 shows the principles of operation for this technology.



**Figure 33. Principles of Operation for an Iron-chromium Battery Energy Storage System**  
 (Source: Energy Storage Safety Responsible Installation, Use, and Disposal of Domestic and Small Commercial Systems, Task 1B, published by the Clean Energy Council, November 13, 2015.)

### 2.9.2 Performance Characteristics


Using liquid reactants, only a small volume is electrically active and the cells are hydraulically balanced. Use of dissolved reactants means there is no volume change during cycling. This is in contrast to Li-ion, lead-acid, NaS, zinc-bromine, and others, which do involve a volume change. This feature results in a less-complex design and simpler controls. The technology may also feature a lower-cost design, materials, and reactants. Figure 34 shows a typical battery Fe-Cr energy storage system concept.



**Figure 34. Typical Iron-chromium Battery System**  
(Photo courtesy EnerVault)

Fe-Cr flow battery systems can be used for time shift on either the utility or customer side of the meter, and for frequency regulation services. Figure 35 shows various Fe-Cr system concepts for these applications.

Table 11 is a technology dashboard that shows the status of technology development for Fe-Cr-chromium batteries.



**Figure 35. Iron-chromium Battery Storage System Concepts**  
(Photo courtesy EnerVault)

**Table 11. Technology Dashboard: Iron-chromium Battery Systems**

Technology Development Status	Laboratory E	Small cells and stack in a lab setting
Operating Field Units	None	None in utility-scale demonstrations; Fe-Cr in niche telecom applications
Process Contingency	15 – 20%	Efficiency and cycle-life uncertain; scale-up uncertainties
Project Contingency	10 – 15%	Limited definition of product designs

## 2.10 Zinc-bromine Batteries

### 2.10.1 Technical Description

The zinc-bromine battery is another type of flow battery in which the zinc is solid when charged and dissolved when discharged. The bromine is always dissolved in the aqueous electrolyte.


Each cell is composed of two electrode surfaces and two electrolyte flow streams separated by a micro-porous film. The positive electrolyte is called a catholyte; the negative is the anolyte. Both electrolytes are aqueous solutions of zinc bromine ( $ZnBr_2$ ).

During charge, elemental zinc is plated onto the negative electrode. Elemental bromine is formed at the positive electrode. Ideally, this elemental bromine remains only in the positive electrolyte.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

The micro-porous separator allows zinc ions and bromine ions to migrate to the opposite electrolyte flow stream for charge equalization (see Figure 36). At the same time, it inhibits elemental bromine from crossing over from the positive to the negative electrolyte, reducing self-discharge because of direct reaction of bromine with zinc.

The cell electrodes are composed of carbon plastic and are designed to be bipolar. This means that a given electrode serves both as the cathode for one cell and the anode for the next cell in series. Carbon plastic must be used because of the highly corrosive nature of bromine. The positive electrode surface is coated with a high-surface-area carbon to increase surface area. The two electrolytes differ only in the concentration of elemental bromine; both should have the same zinc and bromine ion concentrations at any given time during the charge/discharge cycle. This can best be accomplished through the use of an ion-selective membrane as the separator. This membrane would allow the passage of zinc and bromine ions without allowing the passage of elemental bromine or polybromine. In practice, such membranes have proven more costly and less durable than nonselective membranes. For these reasons, nonselective micro-porous membranes are usually used for the separator. The electrolyte is circulated for a number of reasons. Circulation serves to remove bromine (in the form of polybromine) from the positive electrode quickly, freeing up the surface area for further reaction. It also allows the polybromine to be stored in a separate tank to minimize self-discharge.



**Figure 36. Zinc-bromine Cell Configuration**  
(Courtesy ZBB Energy Corporation)<sup>33</sup>

<sup>33</sup> EPRI-DOE Handbook of Energy Storage for Transmission and Distribution Applications, EPRI ID 1001834, EPRI, Palo Alto, CA, and the U.S. Department of Energy, Washington, DC, 2003. L. D. Mears, H. L. Gotschall - Technology Insights; T. Key, H. Kamath - EPRI PEAC Corporation.

On the negative electrode, the flow inhibits the formation of zinc dendrites. Finally, the circulation simplifies thermal management through the use of a heat exchanger. The two electrolytes can flow in the same direction within a cell (co-current), or in opposite directions (counter-current), depending on the design.<sup>34</sup>

### **2.1.1.1 Performance Characteristics**

Table B-18, Table B-19, and Table B-20 in Appendix B show representative performance characteristics of zinc-bromine batteries in various storage applications. The most common factor in degradation and potential failure of zinc-bromine batteries arises from the extremely corrosive nature of the elemental bromine electrolyte. This substance tends to attack all the components of the zinc-bromine system that are exposed to it. Past failure modes have included damaged seals, corrosion of current collectors, and warped electrodes. The active materials themselves do not degrade. The significance of this fact is that the lifetime is not strongly dependent on the number of cycles or the depth of discharge, but on the number of hours that the system has been operational. During normal operation, zinc-bromine batteries do not present unusual environmental hazards. They do, however, contain materials that can become environmental contaminants. Bromine is a toxic material and should be recovered in the event of a spill or when the unit is decommissioned. Zinc-bromine is a corrosive and should be handled appropriately. Zinc is considered a transition-metal contaminant in some locales and thus should be properly recovered when the unit is decommissioned.<sup>35</sup>

### **2.1.1.1 Maturity and Commercial Availability**

Zinc-bromine batteries are in an early stage of field deployment and demonstration trials. While field experience is currently limited, vendors claim estimated lifetimes of 20 years, long cycle lives, and operational ac-to-ac efficiencies of approximately 65%. Module sizes vary by manufacturer but can range from 5 kW to 1000 kW, with variable energy storage duration from 2 to 6 hours, depending on the service requirements and need. Small projects comprising 5-kW/2-hour systems were deployed in rural Australia as an alternative to installing new power lines. In the United States, electric utilities and national laboratories planned to conduct early trials of 0.5 to 1.0 MW systems for grid support and reliability.<sup>36</sup>

Table 12 is a technology dashboard that shows the status of technology development for zinc-bromine systems.

---

<sup>34</sup> Ibid.

<sup>35</sup> Ibid.

<sup>36</sup> For further discussion on the maturity of zinc bromine and flow batteries technology, see the following:

*Flow Battery System Design for Manufacturability*, Tracy Montoya et al., SAND2014-18583, Sandia National Laboratories, Albuquerque, NM, 2014.

*Test Report: Raytheon / KTech RK30 Energy Storage System*, David Martin Rose, Benjamin Schenkman, and Dan Borneo, SAND2013-8639, Sandia National Laboratories, Albuquerque, NM, 2013.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

**Table 12. Technology Dashboard: Zinc-bromine Flow-type Battery Systems**

<b>Technology Development Status</b>	Demonstration trials	Small systems deployed in limited field demonstrations.
<b>Operating Field Units</b>	3 or more	None in utility-scale demonstrations of 500 kW or larger.
<b>Process Contingency</b>	10%	Efficiency uncertain. Limited life and operating experience at greater than 100 kW.
<b>Project Contingency</b>	10 – 15%	Transportable and small systems have lower construction and installation issues.

Figure 37 shows a containerized zinc-bromine system made by RedFlow.



**Figure 37. A 90-kW/180-kWh Zinc-bromine Energy Storage System by RedFlow**  
(Housed in a 20-foot shipping container.)

Zinc-bromine batteries have several unique characteristics that set them apart from other chemistries:

- Zinc-bromine is a normally empty system; it is fully discharged during storage and shipment and hence has zero dc voltage on its terminals.
- Charging it puts voltage on the dc bus, which it will hold until discharged again.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

- Just as lead-acid batteries need to be fully charged on a regular basis to maintain life, zinc-bromine batteries must be fully discharged every few days to maintain life.

A zinc-bromine battery saves fuel based on the runtime and efficiency of the generator. The generator runs at a higher set point, charging the battery and supporting the load, then it turns off and lets the battery support the load until it runs out of energy. Repeating this duty cycle would allow an installed generator to run at a higher power for a shorter duration, making it run more efficiently and avoid wet stacking.

The zinc-bromine coupling was patented over 100 years ago; however, its development was slowed because of some of its inherent properties. Below is a chart displaying some of this technology's. The advantages and disadvantages of zinc-bromine battery technology observed by David Linden are shown in Table 13.

**Table 13. Table 39.1 Major Advantages and Disadvantages of Zinc/Bromine Battery Technology, from *Handbook of Batteries*, Third Edition, by David Linden**

Advantages	Disadvantages
Circulating electrolyte allows for ease of thermal management and uniformity of reactant supply to each cell	Auxiliary systems are required for circulation and temperature control
Good specific energy	System design must ensure safety, as for all batteries
Good energy efficiency	Initially high self-discharge rate when shut down while being charged
Made of low-cost and readily available materials	Improvements to moderate power capability may be needed
Low-environmental-impact-recyclable/reusable components made using conventional manufacturing processes	
Flexibility in total system design	
Ambient-temperature operation	
Adequate power density for most applications	
Capable of rapid charging	
100% depth of discharge does not damage battery but improves it	
Near-term availability	

### 2.1.1.1 Additional Zinc-bromine Battery References


1. [Validated Test Data on MWh-Scale Flow and Other Battery Systems: Large Battery Installations 2003](#), EPRI ID 1005019, EPRI, Palo Alto, CA, December 2003.
2. [Electricity Energy Storage Technology Options](#), EPRI ID 1020676, EPRI, Palo Alto, CA, December 2010.

## 2.11 Zinc-air Batteries

### 2.11.1 Technical Description

Zinc-air batteries are a metal-air electrochemical cell technology. Metal-air batteries use an electropositive metal, such as zinc, aluminum, magnesium, or lithium, in an electrochemical couple with oxygen from the air to generate electricity. Because such batteries only require one electrode within the product, they can potentially have very high energy densities. In addition, the metals used or proposed in most metal-air designs are relatively low cost. This has made metal-air batteries potentially attractive for EV and power electronics applications in the past, and raise hopes for a low-cost stationary storage system for grid services. Zinc-air batteries take oxygen from the surrounding air to generate electric current. The oxygen serves as an electrode, while the battery construction includes an electrolyte and a zinc electrode that channels air inside the battery as shown in Figure 38.

The zinc-air battery produces current when the air electrode is discharged with the help of catalysts that produce hydroxyl ions in the liquid electrolyte. The zinc electrode is then oxidized and releases electrons to form an electric current. When the battery is recharged, the process is reversed, and oxygen is released into the air electrode.



**Figure 38. Zinc-air Battery Functional Schematic**  
(Courtesy ReVolt)

The challenge for researchers has been to address issues such as electrolyte management, avoiding carbon dioxide (CO<sub>2</sub>) impacts from the air on the electrolyte and cathode, thermal management, and avoiding zinc dendrite formation. Methods are also being investigated to address issues with the air electrolyte not deactivating in the recharging cycle and slowing or stopping the oxidation reaction. The cessation of the oxidation reaction reduces the number of times that a zinc-air battery can be recharged.

Despite the many advantages, metal-air batteries also pose several historical disadvantages. The batteries are susceptible to changes in ambient air conditions, including humidity and airborne contaminants. The air electrode – a sophisticated technology that requires a three-way catalytic interface between the gaseous oxygen, the liquid electrolyte, and the solid current collector – has been difficult and expensive to make. However, the technology is far more stable and less dangerous than other battery technologies.

#### 2.11.1.1 Performance Characteristics

Electric recharge has been difficult and inefficient with metal-air batteries, with typical round-trip efficiencies below 50 percent. Some developers have attempted to overcome this limitation

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

with mechanically rechargeable systems in which the discharged metal anode is replaced with a fresh metal anode and the system continues to operate.

There are currently a few early-stage companies attempting to bring energy-dense, high-operating-efficiency, better depth-of-discharge stationary systems to the market, particularly for utility T&D grid support and renewable energy integration. R&D is under way by several companies, with some research still in the university laboratory stage.

Zinc-air batteries have up to three times the energy density of Li-ion, its most competitive battery technology. Unlike Li-ion, however, zinc-air batteries neither produce potentially toxic or explosive gases, nor contain toxic or environmentally dangerous components. Zinc-oxide, which is the main material in a zinc-air battery, is 100-percent recyclable.

### **2.11.1.2 Maturity and Commercial Availability**

Zinc-air technology is still in early R&D phase for stationary storage systems for grid services markets. Despite substantial technical obstacles faced in the past, this technology holds a great deal of potential because of its low capital cost for grid support and potentially for electric transportation applications.

Table 14 illustrates the technology dashboard for Zinc-air energy storage systems.


**Table 14. Technology Dashboard: Zinc-air Battery Systems**

Technology Development Status	Laboratory E	Small cells and stacks in a lab setting; some bench scale system tests
Operating Field Units	None	None in utility-scale demonstrations
Process Contingency	15 – 20%	Efficiency and cycle life uncertain; scale-up uncertainties
Project Contingency	10 – 15%	Limited definition of product designs.

Figure 39 and Figure 40 show a 1-kW battery prototype and an artist's rendering of a 1-MW/6 MWh system.



**Figure 39. 1-kW Zinc-air Prototype**  
(Photo courtesy of EOS Energy Storage)



**Figure 40. Illustration of 1-MW/6/MWh Eos Aurora Zinc-air Design**  
(Developed by EOS Energy Storage)

Zinc-air batteries have been considered for both portable and electric-vehicle applications; however, challenges remain in its development. The chart below defines some of the strengths and weaknesses of the zinc-air battery technology observed by David Linden are shown in Table 15.

**Table 15. Table 13.4 Strengths and Weaknesses of Zinc/Air Batteries, from Handbook of Batteries, Fourth Edition, by David Linden**

Strengths	Weaknesses
High energy per unit volume	Responds to environmental conditions
Stable voltage curve	Limited shelf life after opened to air
Environmentally friendly	Flooding in high relative humidity
Economical	Poor on intermittent use
Convenient	Tape must be removed from air holes to activate cells

## 2.12 Lead-acid Batteries

### 2.12.1 Technical Description

Lead-acid batteries are the oldest form of rechargeable battery technology. Originally invented in the mid-1800s, they are widely used to power engine starters in cars, boats, and planes. All lead-acid designs share the same basic chemistry. The positive electrode is composed of lead-dioxide, PbO<sub>2</sub>, while the negative electrode is composed of metallic lead, Pb. The active material in both electrodes is highly porous to maximize surface area. The electrolyte is a sulfuric acid solution, usually around 37% sulfuric acid by weight when the battery is fully charged.

Lead-acid energy storage technologies are divided into two types: lead-acid carbon technologies and advanced lead-acid technologies. Lead-acid carbon technologies use a fundamentally different approach to lead-acid batteries through the inclusion of carbon, in one form or another, both to improve the power characteristics of the battery and to mitigate the effects of partial states of charge. Certain advanced lead-acid batteries are conventional valve-regulated lead-acid (VRLA) batteries with technologies that address the shortcomings of previous lead-acid products through incremental changes in the technology.<sup>37</sup> Other advanced lead-acid battery systems incorporate solid electrolyte-electrode configurations, while others incorporate capacitor technology as part of anode electrode design.

#### 2.12.1.1 Lead-acid Carbon

Lead-acid carbon technology can exhibit a high-rate characteristic in both charge and discharge with no apparent detrimental effects as are typically experienced in traditional vented lead-acid (VLA) and VRLA batteries. This characteristic allows the lead-acid carbon batteries to deliver and accept high current rates available only with current higher-cost nickel metal-hydride (Ni-MH) and Li-ion batteries.<sup>38</sup>

<sup>37</sup> *Energy Storage and Distributed Generation Technology Assessment: Assessment of Lead-Acid-Carbon, Advanced Lead-Acid, and Zinc-Air Batteries for Stationary Application*, EPRI, EPRI ID 1017811, EPRI, Palo Alto, CA, December 2009.

<sup>38</sup> Ibid.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

There are three major lead-acid carbon technologies currently moving into the market. The three developers working on these technologies are Ecoul/EastPenn, Axion Power International, and Xtreme Power. Each developer has a different implementation of carbon integrated with the traditional lead-acid battery negative plate. In general, each variation is targeting a specific niche market.<sup>39</sup>

According to Axion, their proprietary PbC® technology is a multi-celled asymmetrically supercapacitive lead-acid-carbon hybrid battery. The negative electrodes are five-layer assemblies that consist of a carbon electrode, a corrosion barrier, a current collector, a second corrosion barrier, and a second carbon electrode. These electrode assemblies are then combined with conventional separators and positive electrodes. The resulting battery is filled with an acid electrolyte, sealed, and connected in series to other cells. Laboratory prototypes have undergone deep-discharge testing and withstood more than 1600 cycles before failure. In comparison, most lead-acid batteries designed for deep discharges deliver 300 to 500 cycles. Application-specific prototypes may offer several performance advantages over conventional lead-acid batteries, including:

- Significantly faster recharge rates,
- Significantly longer cycle lives in deep discharge applications, and
- Minimal required maintenance.<sup>40</sup>

Xtreme Power systems are finding early uses in wind and PV smoothing applications. The Xtreme Power PowerCell™ is a 12-volt, 1-kWh, advanced dry cell battery utilizing a solid-state battery design and chemistry. The uniform characteristics of the PowerCells™ allow thousands to be assembled in massive parallel and series matrices, suited for use in large-scale utility applications requiring many megawatts of power while still maintaining a manageable footprint. Its low internal resistance results in high-power retention, as well as the ability to rapidly charge and discharge large amounts of power<sup>41</sup> (see Appendix B). The vendor reports a PowerCell™'s life is based on its depth of discharge (DOD). Cycle life is a log function of DOD and ranges from over 500,000 cycles at 1% DOD to 1,000 cycles at 100% DOD.

### 2.12.1.2 Advanced Lead-acid Technologies

While developers of lead-acid carbon technologies are improving the capability of conventional lead-acid technologies through incorporation of carbon in one or both electrodes, manufacturers such as GS Yuasa and Hitachi are taking other approaches. Advanced lead-acid products from these manufacturers focus on technology enhancements such as carbon-doped cathodes, granular silica electrolyte retention systems (GS Yuasa), high-density positive active material, and silica-based electrolytes (Hitachi).

<sup>39</sup> Ibid.

<sup>40</sup> Axion website:

<http://www.axionpower.com/profiles/investor/fullpage.asp?f=1&BzID=1933&to=cp&Nav=0&LangID=1&s=0&ID=10298>, accessed March 15, 2013.

<sup>41</sup> Xtreme Power website: [www.xtremepower.com](http://www.xtremepower.com), accessed March 15, 2013.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

Some advanced lead batteries have supercapacitor-like features that give them fast response, similar to flywheels or Li-ion batteries. Advanced lead-acid systems from a number of companies are currently in early field trial demonstrations (see Appendix G).

### 2.12.1.3 Performance Characteristics

Traditional VLA and VRLA batteries are typically designed for optimal performance in either a power application or an energy application, but not both. That is, a battery specifically designed for power applications can indeed deliver reasonable amounts of energy (for example, for operating car lights), but it is not designed to deliver substantial amounts of energy (for example, 80-percent deep discharges) on a regular basis. In comparison, a lead-acid carbon or advanced lead-acid battery specifically designed for energy applications can deliver high impulses of power if needed, although it is not specifically designed to do so.

There are several lead-acid carbon and advanced lead-acid technologies; the values are an average of currently available systems. Each system will have its own performance characteristics.<sup>42</sup>

Disposal of lead-acid batteries is an important part of the life cycle. The environmental and safety hazards associated with lead require a number of regulations concerning the handling and disposal of lead-acid batteries. Lead-acid batteries are among the most recycled products in the world. Old batteries are accepted by lead-acid manufacturers for recycling. Batteries are separated into their component parts. The lead plates and grids are smelted to purify the lead for use in new batteries. Acid electrolyte is neutralized, scrubbed to remove dissolved lead, and released into the environment. Other component parts such as plastic and metal casings are also recycled.<sup>43</sup>

### 2.12.1.4 Maturity and Commercial Availability

Lead-acid batteries are the most commercially mature rechargeable battery technology in the world. VRLA batteries are used in a variety of applications, including automotive, marine, telecommunications, and uninterruptible power supply (UPS) systems. However, there have been very few utility T&D applications for such batteries due to their relatively heavy weight, large bulk, cycle-life limitations, and perceived reliability issues (stemming from maintenance requirements).


As shown in Figure 41, a 1-MW/1.5-MWh lead-acid battery by GNB Industrial Power (now Exide) has been operating for 12 years in Metlakatla, AK. In this project, the battery system exhibited very little visible degradation upon post-test analysis and was replaced in 2008, after 12 years of continuous shallow discharge service. Other lead-acid carbon energy systems have been deployed in sizes of 10 to 20 MW.<sup>44</sup>

<sup>42</sup> *Energy Storage Market Opportunities: Application Value Analysis and Technology Gap Assessment*, EPRI ID 1017813, EPRI, Palo Alto, CA, December 2009.

<sup>43</sup> *EPRI-DOE Handbook of Energy Storage for Transmission and Distribution Application*, EPRI ID 1001834, EPRI, Palo Alto, CA, and the U.S. Department of Energy, Washington, DC, 2003.

<sup>44</sup> *Electric Energy Storage Technology Options: A White Paper Primer on Applications, Costs and Benefits*, PI: Dan Rastler, EPRI ID 1020676, EPRI, Palo Alto, CA, September 2010.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity



**Figure 41. 1-MW/1.5-MWh Lead-acid Carbon System at Metlakatla, AK<sup>45</sup>**

Many traditional suppliers and new entrants are seeking to introduce advanced lead-acid technology in U.S. utility markets through products designed for residential, commercial, and industrial use. While each of these cannot be covered in detail in this Handbook, the reader must clearly define the application use case, requirements, and life-cycle expectations during the process of review, assessment, and final selection. Some of the more notable recent field deployments are reviewed here.

Hitachi is developing its advanced lead-acid product for renewable integration and smart grid projects in Japan, with the intent of competing with NaS and Li-ion batteries. Some of its advanced lead-acid batteries have been integrated with wind-generation sites, including the well-known project at Tappi Wind Park installed in 2001 with support from the New Energy Development Organization (NEDO), a Japanese government organization that promotes the development of new energy technologies. The Tappi Wind Park battery system (Figure 42) used an earlier generation of the Hitachi advanced lead-acid battery technology. In August 2009, Hitachi completed a 10.4-MWh battery, built to stabilize a 15-MW wind facility at Goshogawara in northern Japan. A similar plant was installed in late 2010 at another wind-generation site at Yuasa. This battery is now available to companies for integration into the United States, although costing for the United States is unclear at this time.<sup>46</sup>

<sup>45</sup> Energy Storage and Distributed Generation Technology Assessment: Assessment of Lead-Acid-Carbon, Advanced Lead-Acid, and Zinc-Air Batteries for Stationary Application, EPRI ID 1017811, EPRI, Palo Alto, CA, 2009.

<sup>46</sup> Ibid.



**Figure 42. Acid Battery Installation at Tappi Wind Park**  
(Courtesy Hitachi)<sup>4749</sup>

Xtreme Power, Inc., has deployed its advanced lead-acid XP System in multiple services, including wind and PV integration, transmission and distribution applications, and smart grid applications in Hawaii. One of these systems deployed in Maui, HI, is shown in Figure 43.

Xtreme Power also plans to offer grid congestion and large-scale power management products for grid-tied services.

---

<sup>47</sup> Ibid.



**Figure 43. 1.5-MW/1-MWh Advanced Lead-acid Dry Cell Systems by Xtreme Power in a Maui Wind Farm (Source: Xtreme Power)**

Figure 44 shows another advanced lead-acid system made by Ecoul/East Penn installed at a Public Service Company of New Mexico (PNM) project site.



**Figure 44. 500-kW/1-MWh Advanced Lead-acid Battery for Time-shifting and 900-kWh Advanced Carbon Valve-regulated Battery for Photovoltaic Smoothing**

*This is a solar energy storage facility that is fully integrated into a utility's power grid.*

*(Source: PNM Resources)*

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

Table 16 is a technology dashboard that shows the status of technology development for lead-acid batteries.

**Table 16. Technology Dashboard: Advanced Lead-acid Battery Systems**

Technology Development Status	Demonstration C	Limited field demonstrations Some advanced systems can be classified as commercial
Operating Field Units	5 or more	Several wind and photovoltaic applications expected by 2013
Process Contingency	10 – 15%	Limited testing and field experience
Project Contingency	5 – 10%	Cycle life and depth of discharge for application needs careful evaluation; limited operation and maintenance cost data.

The advantages and disadvantages of lead-acid batteries with the focus on stationary storage observed by David Linden are shown in Table 17.

**Table 17. Major Advantages and Disadvantages of Lead-Acid Batteries, from *Handbook of Batteries*, Third Edition, by David Linden**

Advantages	Disadvantages
Popular low-cost secondary batter – capable of manufacture on a local basis, worldwide, from low to high rates of production	Relatively low cycle life (50-500 cycles)*
Available in large quantities and in a variety of sizes and designs – manufactured in sizes from smaller than 1 Ah to several thousand Ampere-hours	Limited energy density – typically 30 to 40 Wh/kg
Good high-rate performance – suitable for engine starting (but outperformed by some nickel-cadmium and nickel metal-hydride batteries)	Long-term storage in a discharged condition can lead to irreversible polarization of electrodes (sulfation)
Moderately good low- and high-temperature performance	Difficult to manufacture in very small sizes (it is easier to make nickel-cadmium button cells in the small than 500-mAh size)
Electrically efficient – turnaround efficiency of over 70% comparing discharge energy out with charge energy in	Hydrogen evolution in some designs can be an explosion hazard (flame arrestors are installed to prevent this hazard)
High cell voltage – open-circuit voltage of >2.0 V is the highest of all aqueous-electrolyte battery systems	Stibene and arsine evolution in designs with antimony and arsenic in grid alloys can be a health hazard
Good float service	Thermal runaway in improperly designed batteries or charging equipment
Easy state-of-charge indication	Positive post-blister corrosion with some designs
Good charge retention for intermittent charge applications (if grids are made with high-overvoltage alloys)	
Available in maintenance-free designs	

Advantages	Disadvantages
Low cost compared with other secondary batteries	
Cell components are easily recycled	

Safety problems associated with lead-acid batteries include spills of sulfuric acid, potential explosions from the generation of hydrogen and oxygen, and the generation of toxic gases such as arsine and stibine. All these problems can be satisfactorily handled with proper precautions.


#### 2.12.1.5 Additional Lead-acid Battery Resource

1. [New Industry Guidelines for the Maintenance of Stationary Valve-Regulated Lead Acid Batteries](#), EPRI ID TR-106769, EPRI, Palo Alto, CA, June 1996.
2. [Chino Battery Energy Storage Power Plant: Engineer-of-Record Report](#), EPRI ID Tr-101787, EPRI, Palo Alto, CA, March 1993.
3. [Chino Battery Energy Storage Power Plant: First Year of Operation](#), EPRI ID TR-101786, EPRI, Palo Alto, CA, February 1993.

## 2.13 Flywheel Energy Storage

### 2.13.1 Flywheels Basics

Since ancient times, the flywheel has been used to smooth the flow of energy in rotating machinery from small, hand-held devices to the largest engines (Figure 45). Today, stand-alone flywheel systems are being developed to store electrical energy for a variety of applications.



**Corliss Centennial Engine**

**Figure 45. Historic Flywheel Technology**

Since the late 20<sup>th</sup> century, a new class of stand-alone flywheel systems has emerged. The modern flywheel, developed expressly for energy storage, is housed in an evacuated enclosure to reduce aerodynamic drag (Figure 46). The flywheel is charged and discharged electrically, using a dual-function motor/generator connected to the rotor. Flywheel cycle life and calendar life are high in comparison to other energy storage solutions.



**20 MW Flywheel Frequency Regulation Plant (courtesy Beacon Power LLC)**

**Figure 46. Modern Flywheel Technology**

Applications for flywheels are viable when two conditions are met. First, the flywheel must represent a more cost-effective solution than competing forms of energy storage. Additionally, a market must exist so that the deployment of a flywheel system results in an economic return.

Flywheels are in use globally across various applications, as shown in Table 18.

**Table 18. Flywheel Applications**

<b>Grid-Connected Power Management</b>		
	<i>Frequency Regulation</i>	Flywheels are used to provide frequency regulation services at two 20-MW facilities
<b>Industrial and Commercial Power Management</b>		
	<i>Transit</i>	Flywheels produced by Calnetix and URENCO have been demonstrated in a number of transit systems for trackside energy recovery
	<i>Mining</i>	The Usibili mine in Healy, Alaska, uses a 40-ton flywheel to smooth the demand for electricity from a 6-MW dragline
<b>Pulsed Power</b>		
	<i>Electromagnetic Aircraft Launch</i>	80-MW flywheel alternators are being developed to launch aircraft from the next generation of aircraft carriers
<b>Uninterruptible Power Supplies</b>		The global market for UPS systems is on the order of \$10B per year. Rotary systems account for about 5% of the total UPS market. Among large systems (>2MW), rotary UPS account for 35% of the world market.
<b>Mobile</b>		
	<i>Materials Handling</i>	Flywheels recover energy and reduce emissions from raising and lowering loads with Rubber Tired Gantry Cranes at container terminals
	<i>Motorsport</i>	Flywheel hybrid powertrains were used successfully in the Audi R18 e-Tron LMP1s that won at Le Mans in 2012, 2013, and 2014


Through the DOE OE Energy Storage Safety program, SNL is continuing to address flywheel system design, operation, and safety. These efforts include providing subject matter expert technical support to investigate industrial incidents involving flywheels and developing best practices for safe flywheel design and operation.

### **2.13.1.1 Technical Description**

Flywheels store energy in the form of the angular momentum of a spinning mass, called a rotor. The work done to spin the mass is stored in the form of kinetic energy. A flywheel system transfers kinetic energy into ac power through the use of controls and power conversion systems.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

Most modern flywheel systems have some type of containment for safety and performance-enhancement purposes. This containment is usually a thick steel vessel surrounding the rotor, motor-generator, and other rotational components of the flywheel. If the wheel fractures while spinning, the containment vessel would stop or slow parts and fragments, preventing injury to bystanders and damage to surrounding equipment. Containment systems are also used to enhance the performance of the flywheel. The containment vessel is often placed under vacuum or filled with a low-friction gas such as helium to reduce the effect of friction on the rotor. See Figure 47.<sup>48</sup>



**Figure 47. Integrated Flywheel System Package Cutaway Diagram**  
(Courtesy Beacon Power)<sup>51</sup>

### 2.13.1.2 Performance Characteristics

Round-trip efficiency and standby power loss become critical design factors in energy flywheel design because losses represent degradation of the primary commodity provided by the storage system (energy). However, they are largely irrelevant in power flywheel design, although standby losses are a factor in operating cost in comparison with other power technologies that have significantly lower losses. For these reasons, energy flywheels usually require more advanced technologies than power flywheels. These energy flywheels usually have composite rotors enclosed in vacuum containment systems, with magnetic bearings. Such systems typically store between 0.5 kWh and 10 kWh. The largest commercially available systems of this type are

<sup>48</sup> Ibid.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

in the 2- to 6-kWh range, with plans for up to 25 kWh. All energy flywheels available today are dc output systems. Round-trip efficiencies for energy flywheels are usually between 70% and 80%. The standby losses are very small, typically less than 25 W dc per kWh of storage and in the range one to two percent of the rated output power.<sup>49</sup>

Flywheels can be charged relatively quickly. Recharge times are comparable to discharge times for both power and energy flywheels designs. High-power flywheel systems can often deliver their energy and recharge in seconds, if adequate recharging power is available. Bidirectional power conversion facilitates this two-way action.<sup>50</sup>

Flywheels generally exhibit excellent cycle life in comparison with other energy storage systems. Most developers estimate cycle life in excess of 100,000 full charge-discharge cycles. The rotor is subject to fatigue effects arising from the stresses applied during charge and discharge. The most common failure mode for the rotor is the propagation of cracks through the rotor over a period of time.<sup>51</sup>

As with any energy storage technology, hazardous conditions may exist around operating flywheels. Considerable effort has gone into making flywheels safe for use under a variety of conditions. The most prominent safety issue in flywheel design is failure of the flywheel rotor while it is rotating. In large, massive rotors, such as those made of steel, failure typically results from the propagation of cracks through the rotor, causing large pieces of the flywheel to break off during rotation. Unless the wheel is properly contained, this type of failure can cause damage to surrounding equipment and injury to people in the vicinity. Large steel containment systems are employed to prevent high-speed fragments from causing damage in the event of failure.<sup>52</sup>

In contrast to many other energy storage systems, flywheel systems have few adverse environmental effects, both in normal operation and in failure conditions. Neither low-speed nor high-speed flywheel systems use hazardous materials, and the machines produce no emissions.<sup>53</sup>

Today's flywheel systems are shorter energy duration systems and not generally attractive for large-scale grid support services that require many kWh or MWh of energy storage. Flywheels charge by drawing electricity from the grid to increase rotational speed and discharge by generating electricity as the wheel's rotation slows. They have a very fast response time of 4 milliseconds or less, can be sized between 100 kW and 1650 kW, and may be used for short durations of up to 1 hour. They have very high efficiencies of about 935, with lifetimes estimated at 20 years.

Although flywheels have power densities 5 to 10 times that of batteries—meaning they require much less space to store a comparable amount of power—there are practical limitations to the amount of energy (kWh) that can be stored. A flywheel energy storage plant can be scaled up by adding more flywheel system modules. Typical flywheel applications include power quality and

<sup>49</sup> Ibid.

<sup>50</sup> EPRI-DOE Handbook of Energy Storage for Transmission and Distribution Applications, EPRI ID 1001834, EPRI, Palo Alto, CA, and the U.S. Department of Energy, Washington, DC, 2003. L. D. Mears, H. L. Gotschall - Technology Insights; T. Key, Kamath - EPRI PEAC Corporation;

<sup>51</sup> Ibid.

<sup>52</sup> Ibid.

<sup>53</sup> Ibid.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

UPS uses, as seen in commercial products. Research is under way to develop more advanced flywheel systems that can store large quantities of energy.

Because flywheel systems are fast-responding and efficient, they are currently being positioned to provide ISO frequency-regulation services. Analysis of such flywheel services have been shown to offer system benefits, including avoiding the cycling of large fossil power systems and lower CO<sub>2</sub> emissions. Spindle Grid Regulation, LLC (formerly Beacon Power), is currently demonstrating megawatt-scale flywheel plants with cumulative capacities of 20 MW to support the frequency-regulation market needs of ISOs.<sup>54</sup>

There are also a number of applications that now propose using flywheels as an energy storage medium. These include inrush control, voltage regulation, and stabilization in substations for light rail, trolley, and wind-generation stabilization. The majority of products currently being marketed by national and international-based companies are targeted for power quality (PQ) applications. Another high-value application in PQ is short-term bridging through power disturbances or from one power source to an alternate source.<sup>55</sup>

In summary, the applications proposed for flywheel energy storage are the following:

- Power quality/regulation,
- UPS, and
- Grid frequency-regulation services.

#### 2.13.1.3 Maturity and Commercial Availability

Flywheels are currently being marketed as environmentally safe, reliable, modular, and high-cycle life alternatives to lead-acid batteries for UPS and other power-conditioning equipment designed to improve the quality of power delivered to critical or protected loads. Okinawa Power has installed a 23-MW flywheel system for frequency regulation. Fuji Electric has demonstrated the use of flywheel technology to stabilize wind power generation.<sup>56</sup>

Spindle Grid Regulation, LLC, owns a 20-MW flywheel-based frequency-regulation facility in Stephentown, NY, that commenced operations in 2011 and sells frequency-regulation services to New York Independent System Operator (NYISO) under tariff rates. According to empirical testing performed during early trials, flywheels showed that 1 MW of fast-response flywheel storage produced 20 to 30 MW of regulation service, and that flywheel regulation was two to three times better than an average Independent System Operator –New England (ISO-NE) generator.<sup>57</sup> The facility sits on five acres and comprises 200 flywheels, each with a storage capacity of 100 kW. Stephentown was originally developed and built by Beacon Power. Beacon

<sup>54</sup> *Large-Scale Energy Storage in Decarbonised Power Grids*, Inage, Shin-ichi, International Energy Agency, Paris, France, 2009.

<sup>55</sup> *EPRI-DOE Handbook of Energy Storage for Transmission and Distribution Applications*, EPRI ID 1001834, EPRI, Palo Alto, CA, and the U.S. Department of Energy, Washington, DC, 2003. L. D. Mears, H. L. Gotschall - Technology Insights; T. Key, H. Kamath - EPRI PEAC Corporation.

<sup>56</sup> *Electric Energy Storage Technology Options: A White Paper Primer on Applications, Costs and Benefits*, PI: Dan Rastler, EPRI ID 1020676, EPRI, Palo Alto, CA, 2010.

<sup>57</sup> *Application of Fast-Response Energy Storage in NYISO for Frequency Regulation Services*, Beacon Power Corporation, Portland, OR, April 2010.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

also operates the facility. Spindle is also developing a second 20-MW facility in Hazle Township, PA, with financial assistance from the DOE and the Commonwealth of Pennsylvania.

Figure 48 shows a 1-MW system installed at Beacon Power's headquarters in Tyngsboro, MA.



**Figure 48. 1-MW Smart Energy Matrix Plant**

(Photo courtesy: Beacon Power)

Table 19 is a technology dashboard that shows the status of technology development for flywheel energy storage systems.

**Table 19. Technology Dashboard: Flywheel Energy Storage Systems**

Technology Development Status	Demonstration status for Frequency Regulation C	Commercial experience in Power Quality UPS applications Pilots in ISO A/S Market applications
Operating Field Units	10 or more	In a 20-MW application. Numerous uses in power quality applications.
Process Contingency	1 – 5%	Uncertain long-term life and performance of the flywheel subsystem
Project Contingency	5 – 10%	

#### 2.13.1.4 Additional Resources for Flywheels

1. [Flywheel Energy Storage](#), EPRI ID TR-108378, September 1997.
2. [Flywheels for Electric Utility Energy Storage](#), EPRI ID TR-108889, December 1999.

## 2.14 Lithium-ion Family of Batteries

### 2.14.1 *Technical Description*


In the past 2 years, Li-ion battery technology has emerged as the fastest-growing platform for stationary storage applications. Already commercial and mature for consumer electronic applications, Li-ion is being positioned as the leading technology platform for plug-in hybrid electric vehicles (PHEVs) and all-electric vehicles, which will use larger-format cells and packs with capacities of 15 to 20 kWh for PHEVs and up to 50 kWh for all-electric vehicles.

The most common types of liquid Li-ion cells are cylindrical and prismatic cell. They are found in notebook computers and other portable power applications. Another approach, prismatic polymer Li-ion technology, is generally only used for small portable applications such as cellular phones and MP3 players. Rechargeable Li-ion batteries are commonly found in consumer electronic products, which make up most of the worldwide production volume of 10 to 12 GWh per year. Compared to the long history of lead-acid batteries, Li-ion technology is relatively new. There are many different Li-ion chemistries, each with specific power-versus-energy characteristics. Large-format prismatic cells are currently the subject of intense R&D, scale-up, and durability evaluation for near-term use in hybrid EVs, but are still only available in very limited quantities as auto equipment manufacturers gear up production of PHEVs.<sup>58</sup>

A Li-ion battery cell contains two reactive materials capable of undergoing an electron transfer chemical reaction. To undergo the reaction, the materials must contact each other electrically, either directly or through a wire, and must be capable of exchanging charged ions to maintain overall charge neutrality as electrons are transferred. A battery cell is designed to keep the materials from directly contacting each other and to connect each material to an electrical terminal isolated from the other material's terminal. These terminals are the cell's external contacts (see Figure 49).

---

<sup>58</sup> Electric Energy Storage Technology Options: A White Paper Primer on Applications, Costs and Benefits, PI: Dan Rastler, EPRI ID 1020676, EPRI, Palo Alto, CA, September 2010.



**Figure 49. Principles of a Li-ion Battery**

Inside the cell, the materials are ionically, but not electronically, connected by an electrolyte that can conduct ions, but not electrons. As shown in Figure 50, this is accomplished by building the cell with a porous insulating membrane, called the separator, between the two materials and filling that membrane with an ionically conductive salt solution. Thus this electrolyte can serve as a path for ions, but not for electrons. When the external terminals of the battery are connected to each other through a load, electrons are given a pathway between the reactive materials, and the chemical reaction proceeds with a characteristic electrochemical potential difference or voltage. Thus there is a current and voltage (that is, power) applied to the load.<sup>59</sup>

<sup>59</sup> Ibid.




Figure 50. Illustrative Types of Li-ion Cells

#### 2.14.1.1 Maturity and Commercial Availability

The large manufacturing scale of Li-ion batteries (estimated to be approximately 30 GWh by 2015) could result in potentially lower-cost battery packs – which could also be used and integrated into systems for grid-support services that require less than 4 hours of storage. Many stationary systems have been deployed in early field trials to gain experience in siting, grid integration, and operation. Li-ion systems dominate the current deployment landscape for grid-scale storage systems in the United States. Figure 51 illustrates some of the Li-ion energy storage system deployments under way that have accelerated in the past 2 years. The stars represent the most significant projects; several other Li-ion projects are under way elsewhere.



**Figure 51. Locations of Current and Planned U.S. Li-ion System Grid Demonstrations**

The advantages and disadvantages of Li-ion battery technology observed by David Linden are shown in Table 20.

**Table 20. Advantages and Disadvantages of Li-ion Batteries, from *Handbook of Batteries* by David Linden**

Advantages	Disadvantages
Sealed cells; no maintenance required	Moderate initial cost
Long cycle life	Degrades at high temperature
Broad temperature range of operation	Need for protective circuitry
Long shelf life	Capacity loss or thermal runaway when overcharged
Low-self-discharge rate	Venting and possible thermal runaway when crushed
Rapid charge capability	Cylindrical designs typically offer lower power density than nickel cadmium (NiCd) or nickel metal hydride (NiMH)
High rate and high power discharge capability	
High coulombic and energy efficiency	
High specific energy and energy density	
No memory effect	

Early system trial demonstrations are under way using small 5- to 10-kW/20-kWh distributed systems and large 1-MW/15-minute fast-responding systems for frequency regulation. Several electric utilities are also planning to deploy Distributed Energy Storage Systems (DESSs) in the 25- to 50-kW size range on the utility side of the meter with energy durations ranging from 1 to 3 hours. Some systems have islanding capability, which can keep homeowners supplied with power for 1 to 3 hours if the grid goes down. Several customer-side-of-meter commercial and residential applications are also under way. The first large commercial peak-shaving system (2 MW/4 MWh) has been deployed by Chevron Energy Solutions. AES Energy Storage LLC has deployed more than 50 MW of systems as an independent power producer (IPP) for frequency regulation and spinning reserve services. Utilities are also deploying megawatt-scale units for PV integration and distribution grid support. In addition, several vendors are implementing small residential energy storage systems that when aggregated could provide system and utility benefits. In total, more than an estimated 100 MW of grid-connected advanced Li-ion battery systems have been deployed for demonstration and commercial service.

Several representative Li-ion systems from different suppliers are shown in Figure 52, Figure 53, and Figure 54. Two residential systems are shown in Figure 55. On the left is a 5-kW/7.8-kWh residential energy storage system installed at Sacramento Municipal Utility District's Anatolia all

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

SolarSmart Homes development. The suppliers are Silent Power, GridPoint, and SAFT. On the right is a 2.7-kW 10.8-kWh system supplied by Sunverge Energy with smart grid software that enables aggregation of many units allowing utilities, end users, or third parties to buy and sell electricity and manage energy needs based on individual interests.



**Figure 52. AES Storage LLC's Laurel Mountain Energy Storage**  
(Supplies 32 MW of regulation in PJM using Li-ion batteries supplied by A123 Systems)




Photo courtesy of Chevron Energy Solutions Company

**Figure 53. A 2-MW/4-MWh Li-ion Energy Storage System**



**Figure 54. A 30-kW/34-kWh Distributed Energy Storage Unit**  
(*Being Installed and Inspected at the Sacramento Municipal Utility District's Anatolia SolarSmart Homes Development. Suppliers are SAFT, Grid Point, and Power Hub*)



**Figure 55. Residential Energy Storage and Energy Management Systems**

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

Table 21 presents a technology dashboard for Li-ion battery systems for stationary grid services.

**Table 21. Technology Dashboard: Lithium-ion Battery Systems**

Technology Development Status	Demonstration C	Systems verified in several field demonstrations in a variety of use cases.
Operating Field Units	32 MW in frequency regulation service 0.5 MW/1 MWh 25 – 50 kW <sup>2</sup> hr	Numerous small demonstrations in the 5-kW to 25-kW sizes are currently under way. MW-scale short- energy-duration systems are being operated in frequency regulation applications. MW class for grid support and PV smoothing being introduced 2-MW/4-MWh system installed in an end-use customer peak shaving application
Process Contingency	10 – 15% Depends on chemistry	Battery management system, system integration, and cooling need to be addressed. Performance in cold climate zones needs to be verified.
Project Contingency	5 – 10%	Limited experience in grid-support applications, including systems with utility grid interface. Uncertain cycle life for frequency regulation applications.

**2.14.1.2 Additional Resources for Li-ion Batteries**

1. [Technical Specification for a Transportable Energy Storage System for Grid Support Using Commercially Available Li-ion Technology](#), EPRI ID 1025573, EPRI, Palo Alto, CA, July 2012.
2. [Demonstration Initiative for a Grid Support Storage System using Li-ion Technology: Phase I Report](#), EPRI ID 1025574, EPRI, Palo Alto, CA, August 2012.
3. [Electricity Energy Storage Technology Options](#), EPRI ID 1020676, EPRI, Palo Alto, CA, December 2010.

**2.15 Emerging Technologies**

There are many other types of energy storage technologies, both mature and still in the R&D phase, that are not discussed in this report. Ni-Cd and NiMH batteries are mature and suitable for niche applications. Innovation and R&D continues in many other emerging storage technology options. Stages of R&D and timelines and field deployment timing are summarized in Table 22.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

**Table 22. Emerging Storage Options Research and Development Timelines for Emerging Energy Storage Options**

Storage Type	Status/Innovation	Estimated Deployment Timing
Liquid Air Energy Storage Systems	System studies. Low-cost bulk storage. Small demos	2013-2014 first +MW-scale demo.
Non/Low-Fuel CAES	System studies underway to optimize cycle and thermal storage system. Low-fuel and non-fuel CAES for bulk storage.	2015 pilot demonstration of 5-MW system.
Underground Pumped Hydro	System studies. New concepts under development.	Under study.
Nano-Supercapacitors	Laboratory testing. High power and energy density; very low cost.	2013-2015
Advanced Flywheels	System studies. Higher energy density.	Under development. 2015.
H <sub>2</sub> /Br Flow	Bench-scale testing. Low-cost storage.	2013-2014 pilot demo.
Advanced Lead-Acid Battery	Modules under test. Low cost; high-cycle life.	2013-2015 early field trials.
Novel Chemistries	Bench-scale testing. Very low cost; long-cycle life.	2013-2015 modules for test.
Isothermal CAES	2 MW and 1 MW System Development and Demonstration effort. Non-fuel CAES for distributed storage.	2013 pilot system tests.
Advanced Li-ion Li-air and others	Laboratory/basic science. Lower costs; high energy density.	2015-2020


This roadmap defines energy storage technologies in terms of output – **electricity** versus **thermal** (heat or cold).<sup>60</sup> Today, electricity and thermal storage technologies exist at many levels of development, from the early stages of R&D to mature, deployed technologies.<sup>61</sup> The *IEA Technology Roadmap: Energy Storage Technology Annex* includes in-depth descriptions and

<sup>60</sup> Hydrogen storage is the subject of the forthcoming International Energy Agency (IEA) technology roadmap on hydrogen storage and so will not be covered in detail here.

<sup>61</sup> This development spectrum is roughly equivalent to the concepts of “Technology Readiness Levels” (TRLs) and Manufacturing Readiness Levels (MRLs).

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

project examples for many energy storage technologies. In Figure 56, some key technologies are displayed with respect to their associated initial capital investment requirements and technology risk versus their current phase of development (that is, R&D, demonstration and deployment, or commercialization phases).<sup>62</sup>



**Figure 56. Key Emerging Technologies**

(Source: B. Decort and R Debarre, “Electricity Storage,” Factbook, Schlumberger Business Consulting Energy Institute, Paris, France, 2013, and H. Paksoy, “Thermal Energy Storage Today,” presented at the IEA Energy Storage Technology Roadmap Stakeholder Engagement Workshop, Paris, France, February 14, 2013.

### 2.15.1 General Technology Overview


The most common categories of battery storage presently available in the Australian marketplace are:

- lead-acid (advanced, flooded-cell and sealed)
- lithium (ion and polymer)
- nickel-based (metal hydrides and cadmium)
- flow (zinc bromine and vanadium redox)
- sodium-ion analogue.

<sup>62</sup> To be concise, only a limited number of energy storage technologies are included in Figure 2. This list is not meant to be comprehensive, but highlights some of the promising and successfully deployed technologies in the energy system.

## Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

Lead-acid batteries are the most common battery type in domestic and small commercial storage systems. They have a long history of use within Australia, and since the late 1980s have been used for off-grid and backup power applications. Li-ion batteries are increasing in popularity, because they have a long life and high energy density (that is, they can store a lot of energy per volume). Nickel-based, flow, and sodium-ion analogue batteries are less common, but can be useful in particular applications (for example, flow batteries can be well suited to daily energy shifting, or sodium-ion may be the best choice at certain environmental temperatures). Figure 57 shows the broad categories of rechargeable battery energy storage presently available. The list for each category is placed in order, with the safest type at the top. Also, the technologies are ordered from left to right in accordance with their technological and market maturity, with the most mature on the left.



**Figure 57. Rechargeable Battery Energy Storage Currently Available**

## 2.16 Summary

The second chapter presents the principles of operation for pumped hydro and Compressed Air Energy Storage (CAES) and the electrochemistry for a family of currently available battery technologies. Levelized cost of energy (LCOE) charts based on the responses of a first-of-a-kind,

Chapter 2. Electricity Storage Technologies: Cost, Performance, and Maturity

comprehensive survey of more than 40 storage vendors are available for each technology in Appendix H.

## **2.17 Extended Technical Discussion**

In use since ancient times, the flywheel has smoothed the flow of energy in rotating machinery from small, hand held devices to the largest engines. Today, standalone flywheel systems are being developed to store electrical energy. These systems are deployed in applications as diverse as uninterruptible power supplies, gantry cranes, and large research facilities. Don Bender's Flywheel paper presents the technical foundation of flywheel design, a comparison with other energy storage technologies, and a survey of applications where flywheel energy storage systems are currently in service.

<http://www.sandia.gov/ess/publications/SAND2015-3976.pdf>



## CHAPTER 3. METHODS AND TOOLS FOR EVALUATING ELECTRICITY STORAGE

### 3.1 General Information

There is a fundamental difference in the operational characteristics of traditional generation sources and electricity storage systems operating on the grid. Traditional generation always sends power one way, whereas electricity storage systems require a two-way power flow to function, both charging and discharging states. Other characteristics of storage systems add to this complexity. First, the charging energy could come from a single source or a variety of sources based on the generation portfolio of the grid as a whole; this characteristic could and does change over time. Second, smaller storage could be located anywhere within the grid.

While large storage resides on the transmission side, smaller systems could be embedded deep in the T&D network, creating both opportunities and grid integration impacts and concerns. Third, the inherently fast response times measured in fractions of a cycle is its strength and weakness in estimating its value. This characteristic creates a fairly complex computational task for tools and computer models that are required to analyze the financial and technical performance of electricity storage in the grid. Finally, a single storage system could provide multiple services to the grid. Stacking, as this characteristic is called, creates its own set of computational complexities for even robust models.


### 3.2 Approach

Given these characteristics, a generalized approach for evaluating energy storage includes:

- Assessing storage requirements and value originating from the locational needs of grid operators and planners;
- Avoiding conflation or double-counting of benefits;
- Drawing a distinction between quantifiable and monetizable services and direct and incidental benefits;
- Delaying resource-intensive production simulation analyses until after technically feasible, cost-effective use cases are identified; and
- Delaying deep investigation of policy and regulatory scenarios until after technically sound cost-effectiveness cases are identified and impacts modeled.

### 3.3 Data

EPRI uses the following methodology,<sup>63</sup> which provides a framework for evaluating electricity storage with the steps described below. Figure 58 provides a visual representation of the evaluation framework.




**Figure 58. Steps in Electricity Storage Evaluation**  
(Source: EPRI)

#### 3.3.1 Step 1a: Grid Opportunity/Solution Concepts (“What Electricity Storage Can Do”)

Figure 59 illustrates Step 1a.

<sup>63</sup> Bulk Energy Storage Value and Impact Analysis: Proposed Methodology and Supporting Tool, EPRI, EPRI ID: 1024288, Palo Alto, CA, December 2012.

**Figure 59. Decision Diagram for Step 1a: Opportunity/Solution Concepts**

(Source: EPRI)

### **3.3.1.1 *What Is the Grid Operational or Planning Problem?***

Grid operational or planning problems can be anything from a congested transmission line, a sharp load peak, an outage, or a voltage deviation caused by increased penetration of renewable resources. Some of the services that help relieve those issues are formally categorized in ancillary services (ASs) and can be procured through markets. Others are site-specific issues that require a unique solution.


### **3.3.1.2 *Can Electricity Storage Help?***

Electricity storage fundamentally can store, and later release, energy, - effectively moving energy from one time period to another (with losses). When technical and economic opportunities can be created by shifting energy over time periods ranging anywhere from seconds to days (or even seasons), then electricity storage may have value. Additionally, the power electronics in battery systems may have fast response and ramp capability and the ability to operate at non-unity power factors, which can be used to change ac voltage. These characteristics may provide additional opportunities to provide ASs, like frequency regulation and voltage support.

The first step of the exploration is to ask the questions: “What is the grid operational or planning issue?” and “Do the unique attributes of storage provide a potential solution?” If the answer is “yes,” the second part of the first step is to define the problem and solution with additional technical rigor in Step 1b.

## **3.3.2 *Step 1b: Define Grid Service Requirements (What Must Be Accomplished)***

A high-level decision diagram for Step 1b of the methodology is shown in Figure 60.



**Figure 60. Decision Diagram for Step 1b: Define Grid Service Requirements**  
(Source: EPRI)

### 3.3.2.1 *Define Solution Technical Criteria*

After identifying a conceptual improvement or solution that electricity storage can provide, the next analytical step is to define the grid issue technically and the technical requirements for its resolution. Historically there has been some confusion over the terms grid service and application and the terms “grid service” and “application” are sometimes used interchangeably. Grid service is used here to indicate that this step considers grid-defined operating requirements and benefits, rather than application of a specific resource.

### 3.3.2.2 *Convert to Electricity Storage Requirements*


Communicating with key stakeholders and decision-makers is critical to determining the appropriate metrics, the minimum operating criteria, and the best available alternative (non-storage) solution to the problem. The technical criteria for an electricity storage-based option can then be determined based on the case-specific information available, including load shapes, market participation rules, generation costs and other time-varying and static characteristics relevant to the grid service under investigation.

### 3.3.2.3 *Define Solution Value*

The value of the electricity storage solution can be calculated based on the avoided cost or expected revenue from the chosen grid service. This may require using engineering tools to identify the efficacy of both the electricity storage and the alternative solution to the problem in question. However, the method will be dependent on the grid service under investigation. It may also be considered and documented if either the electricity storage solution or the alternative exceeds the minimum requirements of the service, which may warrant an adjustment in the value of the electricity storage option.

## 3.3.3 *Step 2: Feasible Use Cases*

Figure 8 illustrates the generic process for Step 2: Feasible Use Cases.

**Figure 61. Decision Diagram for Step 2: Feasible Use Cases**

(Source: EPRI)

### 3.3.3.1 Assess Anchor Service

A use case is a technically feasible and monetizable combination of grid services at a particular location. Electricity storage use cases often contain a service of disproportionately high value, which is called anchor service in this Handbook. After requirements have been determined for the anchor grid service in Step 1b, storage technology and configuration options can be investigated. The relative value of the anchor service may then be investigated for different electricity storage options of interest. Assessing the intended anchor service before adding additional services may be of value.

In some cases, an anchor service may have location-specific value. For example, the value of providing a distribution upgrade deferral depends on the investment size, load growth rate, and the frequency and duration of peak load events, all of which are unique to each location. In contrast, frequency regulation service may typically be provided from many locations within a region that operates in a synchronous manner (subject to transmission constraints). The electricity storage utilization and value of this anchor service could be estimated with certain operational assumptions or simulated using a time-series simulation.

Typically, a benefit that is 25% to 50% or more of the total storage system cost is a rule of thumb for declaring the potential of a grid service to be an anchor service.

### 3.3.3.2 Define Compatible Use Case

After the anchor service has been assessed and chosen for further investigation, other compatible grid services, also called secondary services may be considered. Compatibility assessment should occur across multiple dimensions:

- Joint satisfaction of minimum requirements,
- Timing of service (identical, overlapping, or non-overlapping timing), and
- Flexibility of additional services (long-term or short-term commitment?).


### 3.3.3.3 Joint Satisfaction of Minimum Requirements

The minimum capacity, duration, and ramp rate required to perform the grid services of interest must all be met by the electricity storage system. The secondary services may require longer duration of available storage, or faster response, or another operational parameter that was not considered in the anchor service. If the minimum requirements for the secondary services add significant incremental cost, then the cost of improved electricity storage performance should be reconsidered against the incremental value expected. Identifying additional services for which the initial storage configuration satisfies all minimum requirements is the most beneficial outcome. Failing that, if the upgrade cost of the storage system is lower than the incremental benefit of adding the service, the secondary service may still be considered.

### 3.3.3.4 Frequency and Duration of Grid Services


The second issue of use-case compatibility is the timing of grid services. The timing and expected operation may coincide identically, overlap, or be non-overlapping in nature. Take, for example, a use case for which electricity storage could be jointly used to shave the transmission transformer peak (transmission upgrade deferral) and the system peak (electric supply capacity). Consider the following three cases: Case 1, in which the transformer and system peaks both occur from 2 p.m. to 6 p.m.; Case 2, in which the transformer peak is from 12 p.m. to 4 p.m. and the system peak is from 2 p.m. to 6 p.m.; and Case 3, in which the transformer peak is from 10 p.m. to 2 a.m. and the system peak is from 2 p.m. to 6 p.m.

In Case 1, shown in Figure 62, the effect of the additional electric supply capacity service to the transmission investment deferral anchor service may be minor, because the storage is performing double duty with a single dispatch, simultaneously unloading a transformer and providing peak generation. (Note that perfect correlation is unlikely between multiple services; this example illustrates an ideal case.)




**Figure 62. Case 1: Coincident Transformer and System Load Peaks**  
(Source: EPRI)

In Case 2, shown in Figure 63, the loads are overlapping but not completely coincident (as they were in Case 1). As a result, the cumulative peak that would need to be shaved to satisfy both the transmission investment deferral and system capacity services has now increased from approximately 4 hours to 6 hours, necessitating additional electricity storage duration to accomplish both services.



**Figure 63. Case 2: Partially Overlapping Transformer and System Load Peaks**  
(Source: EPRI)

Finally, in Case 3, shown in Figure 64, the peaks are fully non-coincident. As a result, it may be possible to accomplish both services by charging the electricity storage system between the peaks. Therefore, the electricity storage system may not require additional duration, but could require a technology with improved capability for multiple charge-discharge cycles per day. This scenario is possible for situations in which a transformer serves industrial or irrigation loads, which may be timed to coincide with off-peak system hours when these customer time-of-use tariffs charge a low retail price of electricity.



**Figure 64. Case 3: Non-overlapping Transformer and System Load Peaks**  
(Source: EPRI)

### **3.3.3.5 Hierarchy for Grid Services**

Flexibility measured in terms of frequency, duration, and term of commitment is an important consideration for adding secondary grid services to a use case. Certain grid services, such as transmission upgrade deferral, are inflexible. If electricity storage is installed to offset load growth on a transformer, a high degree of availability is required because it is being relied upon in lieu of a capital upgrade. System electric supply capacity may be somewhat more flexible, because there is a greater diversity of resources available to provide capacity within the bulk electricity system. However, capacity payments are often made on a monthly or yearly basis for resource availability during the system peak and penalized when not available. Therefore the flexibility is still relatively low, compared to service that can be committed the day before or even closer to the period of performance. Energy and AS scheduling typically occurs in the day-ahead or real-time, so these services are significantly more flexible and should be easier to add to a use case. When adding two services together, the storage system should always try to meet the operation requirements for the less flexible service and then use the remaining capacity for the more flexible service. Sometimes this approach can lead the value of one service to decline when combined with another service.

When considering secondary grid services, consider the duration of commitment and the control requirements for providing each service, and the hierarchy of operation across multiple services. For some technologies, such as flywheels and short-duration batteries, there may not be many choices in what services can be provided. Realistically, due to their short duration, all flywheels and short-duration batteries may be able to provide are regulation services.


After screening for compatibility and value of multi-service use cases, revisit the initial storage system options considered for the anchor service. Optimization between use cases and storage system technology characteristics is currently an iterative process.

### **3.3.3.6 Time Series Dispatch/Cost-effectiveness**

After choosing the use cases including the anchor grid service, compatible secondary services, and other electricity storage systems of interest, an analysis can be designed to quantify the benefits of grid service combinations, locations, and technologies. In some cases, a very simple analysis may be sufficient to screen out those cases with costs that are considerably higher than the benefits. However, due to the complexities of modeling limited energy resources and the importance of time-varying loads and values, more sophisticated tools may be required.

## **3.3.4 Step 3: Grid Impacts and Incidental Benefits**

The summary-level process for Step 3 is displayed in Figure 65.



**Figure 65. Decision Diagram for Step 3: Grid Impacts and Incidental Benefits**  
(Source: EPRI)

The purpose of Step 3 is to determine how the remaining electricity storage deployment scenarios affect system-wide metrics of cost, reliability, and external factors, including:

- Consumer costs,
- System flexibility,
- Transmission asset utilization and generator operation, and
- Environmental impacts, such as greenhouse gas (GHG) emissions.

Step 2 enabled the analyst to assess one or more technically feasible use cases to improve understanding of direct costs and benefits of a storage investment. Steps 1 and 2 may also enable conceptual understanding of how storage may impact the bulk electricity system. The analyst can then form hypotheses to test using production simulation tools, which have the regional perspective required to assess system impacts.


### 3.3.4.2 Assess Additional Costs/Benefits of Storage

The intent of Step 3 is to investigate impacts and incidental benefits or costs to the electricity system of electricity storage operation. Incidental benefits are not necessarily unintended, but they are not direct benefits explicitly addressed by the operation and control of the storage system. For example, the operation of storage may decrease GHG emissions by providing system capacity during peak demand periods and decreasing the usage of inefficient peaker combustion turbine units. However, if the storage is not directly dispatched with the objective of lower GHG emissions, then this is an incidental benefit. Operation of storage may actually increase the use of more carbon-intensive coal-fired base load generators, which could actually increase GHG emissions, but understanding the complex system relationships requires a production simulation. In summary, incidental benefits may result from a combination of the electricity storage system dispatch and other characteristics of the electric system.

If the production simulation shows a significant deviation in energy and AS prices compared to the inputs used in Step 2, the analyst should update the inputs and rerun the price-taker model (such as the EPRI Energy Storage Valuation Tool), as appropriate. Occasionally, the analyst may prefer to go directly to Step 3. For example, if the grid service is regulation, as regulation market is relatively small, a price-taker model may not capture the potentially sizable impact a large electricity storage system could have on a service with low demand (in MW).

### 3.3.5 Step 4: Electricity Storage Business Cases ("How Storage Can Monetize Benefits")

The simplified process for Step 4: Electricity Storage Business Cases is shown in Figure 66.



**Figure 66. Decision Diagram for Step 4: Electricity Storage Business Cases**  
(Source: EPRI)

The penultimate phase of assessing electricity storage cost-effectiveness is to investigate real-world business cases. The distinction between this stage of analysis and all previous steps is the inclusion of relevant policy and regulation scenarios, and more advanced business-model and financial-analysis considerations. Step 4 is distinct from Steps 2 and 3 in that it focuses on monetization for the energy-storage system owner, rather than considering total value aggregated across all stakeholders.

#### 3.3.5.1 Define Scenarios

Consider the example of a use case involving a transmission investment deferral, energy time-shift (arbitrage), and frequency regulation services. In Steps 2 and 3, the technical capability of the electricity storage system to provide value is evaluated, and the potential value of the electricity storage services is calculated (quantified). However, the avoided cost of the transmission deferral accrues to the transmission system, and the energy and frequency regulation benefits accrue to generation.

Depending on the objectives of the storage valuation analysis, it may be practical to perform Step 4 concurrently with Step 2 to assess both the quantifiable, aggregate value as well as the monetizable value to the storage owner. However, due to the cross-cutting nature of storage and its usefulness to provide a greater diversity of benefits than typical resources, it is important to distinguish "quantifiable value" from "monetizable value." Over longer periods of time, policies

and regulations are fluid, so the analyst considers those issues separately to support forward-looking research into electricity storage valuation.

### **3.3.5.2 Stakeholder Financial Analysis**

Once the scenarios of interest have been identified, the analyst can then review the same use case from multiple stakeholder perspectives. Some issues to consider are:

- Business model(s) of the entity,
- Cost of capital for discounting future cash flows,
- Consideration of transaction costs,
- Taxes,
- Risk appetite,
- Permitting, and
- Insurance.

This is only a partial list; many other issues can be considered for case-specific business decisions. Step 4 is the step in which all of the complex realities of investing, building, and operating an emerging technology enter the analysis.

## **3.4 Modeling Tools**

Specific tools that support energy storage evaluations span the spectrum in the level of detail and complexity – from high-level screening to detailed analysis for site- and service-specific needs. Many of these tools have been identified and are listed in Table 18.

**Table 18. Analytical Tools for Use in Electricity Storage Cost-Effectiveness Methodology**

Category	Resource Portfolio Planning	Production Simulation	Load Flow/ Stability	Dynamics Simulation	Electricity Storage Technology Screening	Electricity Storage Cost-Effectiveness
Focus	Long-term resource and capacity planning needs	Future-year transmission. Grid simulation	Near-term T&D grid resource stability/ engineering needs	Short-term variability and load-balancing	Screening storage technology and service combinations	Assessing storage project cost-effectiveness
Goals	Minimize cost and risk of resource portfolio, maximize social welfare	Least-cost unit commitment and economic dispatch with reliability/ transmission constraints to manage minutes to hours variability and uncertainty	Least-cost planning to meet reliability and tolerance thresholds	Manage seconds to minutes variability and uncertainty	Identify promising technology/ services combinations	Maximize expected net present value (NPV) of storage investment
Scope	Generation, international trading	Generation, Transmission	Transmission or Distribution	Generation	Generation, T&D, Customer	Generation, T&D, Customer
Examples	NESSIE, RETScreen, NEMS, EGEAS EMCAS	PLEXOS, UPLAN, GridView, PROMOD, Ventyx, GE-MAPS PROBE PSO	<b>Trans:</b> PSS/E, PSLF, HOMER, <b>Dist:</b> CYMDist, Open DSS, GridLab-D VSAT TSAT POM	Kermit FESTIV PSO	ES-Select ESVT ESCT	ESVT (EPRI) ESCT (Navigant)
Core Strengths	Evaluate range of future, regional scenarios and resource portfolios	One-year system dispatch with zonal/nodal model of regional grid, including market price effects	High resolution power flow, Volt/VAR and fault analysis for specific grid configurations	Short-time-scale dispatch for frequency regulation	Scoping analysis of a wide range of technologies and services	Life-cycle financial and cost-benefit analysis from owner/operator and societal perspectives

Appendix A includes a Review of Selected Tools and describes in more detail tools used for technology screening, storage valuation, production cost modeling, and load flow/stability analysis. The appendix includes a discussion of the scope of these tools, and their strengths and limitations for answering the research questions that are currently driving the electric utility industry's interest in energy storage. Reference is also made to a recently released report, *Methodology to Determine the Technical Performance and*

*Value Proposition for Grid-Scale Energy Storage Systems*,<sup>64</sup> that quantifies the technical performance required to provide different grid benefits and recommends approaches for estimating the value of grid-scale energy storage systems.

### 3.4.1 DOE SNL Tools

#### 3.4.1.1 ESS Program Tools

- [DOE/EPRI 2013 Electricity Storage Handbook in Collaboration with NRECA](http://www.sandia.gov/ess/publications/SAND2013-5131.pdf) – The DOE/EPRI 2013 Electricity Storage Handbook in Collaboration with NRECA is a how-to guide for utility and rural cooperative engineers, planners, and decision makers to plan and implement energy storage projects.  
<http://www.sandia.gov/ess/publications/SAND2013-5131.pdf>
- [PUC Handbook](http://www.sandia.gov/ess/publications/SAND2012-9422.pdf) – A perspective on issues pertaining to the deployment of utility procured electrical energy storage resources. The intended audience includes state electric utility regulatory authorities, their staffs and the planning personnel in the utilities they regulate.  
<http://www.sandia.gov/ess/publications/SAND2012-9422.pdf>
- [DOE Global Energy Storage Database](http://www.energystorageexchange.org/) – Free, up-to-date information on grid-connected energy storage projects and relevant state and federal policies. All information is vetted through a third-party verification process. All data can be exported to Excel or PDF.  
<http://www.energystorageexchange.org/>
- [ES-Select Tool™](http://www.sandia.gov/ess/tools/es-select-tool/) – The ES-Select™ Tool aims to improve the understanding of different electrical energy storage technologies and their feasibility for intended applications in a simple, visually comparative form. It treats the uncertainties in technical and financial parameters as statistical distributions.  
<http://www.sandia.gov/ess/tools/es-select-tool/>
- [Protocols](http://www.sandia.gov/ess/docs/ESS_Protocol_Rev1_with_microgrids.pdf) — A listing of DOE-published protocols available for download.  
[http://www.sandia.gov/ess/docs/ESS\\_Protocol\\_Rev1\\_with\\_microgrids.pdf](http://www.sandia.gov/ess/docs/ESS_Protocol_Rev1_with_microgrids.pdf)  
[http://www.sandia.gov/ess/docs/TSD\\_Duty\\_Cycle\\_ESS\\_Integrated\\_w\\_Microgrids\\_June\\_2014\\_with\\_Excel.pdf](http://www.sandia.gov/ess/docs/TSD_Duty_Cycle_ESS_Integrated_w_Microgrids_June_2014_with_Excel.pdf)  
<http://www.sandia.gov/ess/publications/SAND2013-7084.pdf>

---

<sup>64</sup> *Methodology to determine the technical performance and value proposition for grid-scale energy storage systems : a study for the DOE energy storage systems program*, SAND2012-10639, Sandia National Laboratories, Albuquerque, NM Verne William Loose; Matthew K Donnelly Montana Tech of The University of Montana, Butte, MT; Daniel J Trudnowski Montana Tech of The University of Montana, Butte, MT; Byrne, Raymond Harry; Montana Tech of The University of Montana, Butte, MT, December 2012.

- Strategic Safety Tools

DOE OE Strategic Plan for Energy Storage Safety

[http://www.sandia.gov/ess/docs/other/DOE\\_OE\\_Safety\\_Strategic\\_Plan\\_Dec\\_2014\\_final.pdf](http://www.sandia.gov/ess/docs/other/DOE_OE_Safety_Strategic_Plan_Dec_2014_final.pdf)

Codes, Standards, and Regulations – Overview and Inventory of Safety-related Codes and Standards

<http://www.sandia.gov/ess/resources/energy-storage-safety/current-work-to-address-safety/codes-standards-and-regulations/>

## 3.4.2 Other Evaluation Tools

### 3.4.2.1 Resource Portfolio Planning

Before embarking on any electricity storage, power generation upgrade or new construction project, an accurate assessment of the options available is crucial to the financial feasibility of the project. A resource portfolio planning simulation has two components. The first component focuses on the specific resources available subject to the operational constraints of the power grid. Inputs to this analysis are typically specific to the geographical location of the proposed project. Power reliability, voltage regulation, demand response, and other grid operational components including energy storage option are all variables that can be considered at this stage. In the second component of a resource portfolio planning analysis these variables are set as constraints and a metric to better evaluate the financial feasibility of the project. Integral to this is the pricing data required to evaluate what an actual financial return will yield relative to the operational constraints of the power grid. One example of a resource-planning model would be the analysis of how both energy storage and demand response operations would affect the financial return of the power generation system relative to a very high power reliability constraint. In short, this resource portfolio planning analysis would answer the question: If very high power reliability is required for this specific area, what is the optimal amount of energy storage and demand response needed to maximize profit? This type of analysis is done both locally at the feeder level and nationwide at the transmission and generation level for the service area under consideration.

### 3.4.2.2 Production Simulation

While resource portfolio planning focuses on the operation of the grid at a higher level, production simulation takes a much more detailed approach focusing on the actual operation of the proposed project at the minute to hourly level and then assessing the financial feasibility relative to other grid resources available at that time. Production simulation takes into account constraints such as load relative to variable generating forecasts, fuel prices, maintenance schedules, and other real-time operational costs and emission burdens. This also includes daily forecasts of price relative to congestion charges, regulatory fines, and other known parameters that may cause daily fluctuations in price. Production simulation can be evaluated at both a “zonal” level and a “nodal” level.<sup>65</sup> [bookmark287](#) At the zonal level, production simulation does not account for transmission and distribution constraints between multiple node sets. These

<sup>65</sup> Survey of Modeling Capabilities and Needs for the Stationary Energy Storage Industry, Navigant Consulting, Inc., May 2014.

nodes are set as input/output parameters such as voltage, current, and power factor, with which the transmission or distribution network is simulated. The dynamics of the system happen only within the transmission or distribution network; otherwise the nodal locations, which are typically the generation site, are either held constant or change independent of the grid operation. When evaluated at the nodal level, specific input/output parameters are simulated and vary with the operation of the transmission or distribution system. Thus, the fluctuations that occur in the transmission or distribution system are no longer decoupled from the simulation of the rest of the grid components.

#### **3.4.2.3 Load Flow/Stability**

Load flow and stability simulations of the power grid at the transmission and distribution level focus on defined “what if” scenarios of operations. This analysis is conducted to assess system reliability when sudden disturbances in the grid occur due to any number of conditions including power transfer constraints and loss of generation. It can quantify power quality violations, including voltage and frequency excursions that occur when such upsets happen. Both transmission and distribution modeling software treat power inputs from nodes as relatively constant and then apply a given disturbance scenario. At the transmission level, power input data such as voltage, frequency, and current are input to the model for selected busses. A defined scenario, such as a sudden loss of power from a fossil or photovoltaic power plant, is modeled. Some software like HOMER can simulate the interactions between busses down to the 1-minute resolution. The result is an analysis of low and high bus voltage and other voltage deviations. At the distribution level, power flow can be modeled up to the 1 millisecond resolution. Transformers are treated as the nodes to which power flow data are taken and applied. As with a transmission load flow analysis, given “what if” power scenarios such as a large solar power plant returning power to the grid after being occluded by clouds are applied. From these data, problem areas of the distribution system that experience unacceptable voltage or frequency problems can be identified and identify parts of the grid that can most effectively use a storage solution.

#### **3.4.2.4 Dynamics Simulation**

A dynamics simulation tool is used mainly for the simulation of transmission and generation systems. Its primary focus is the identification of frequency drift and power factor problems originating from the transmission system. The main characteristic of this type of tool is the high resolution (on the order of milliseconds) of the time domain, which is crucial in the identification of frequency anomalies.

#### **3.4.2.5 Electricity Storage Technology Screening**

The purpose of electricity storage technology screening software is to identify possible synergies of energy storage benefit combinations. The *Energy Storage Benefits and Market Analysis Handbook*<sup>66</sup> lists 15 distinct benefits that can be realized with an energy storage solution. However, not all benefits can be realized simultaneously, especially if the storage solution is being used at the same time to capture a different benefit. For example, the avoidance or deferral of a transmission infrastructure upgrade and reduced transmission congestion are two synergistic

---

<sup>66</sup> *Energy Storage Benefits and Market Analysis Handbook*, SAND2004-6177, Sandia National Laboratories, Albuquerque, NM, 2004.

benefits that a vertically integrated utility may realize. The addition of the benefit of transmission support to this combination may be limited by the use of the storage option for the previous two listed services as well as the systems power and energy characteristics. By exploring all possible combinations of benefits, key stakeholders can maximize their return from a proposed energy storage system by increasing asset utilization. In ES-Select, the more widely recognized electricity storage technology screening software, inputs such as location, main and secondary storage applications, and feasibility options for each proposed benefit are aggregated and assessed. Hundreds of possible combinations of storage benefits are chosen at random and presented in use case scenarios with ranges of benefits. The main goal of this analysis is a high-level overview of proposed aggregate benefits from a defined and proposed energy storage solution.

#### **3.4.2.6 Electricity Storage Cost-Effectiveness**

A crucial task before implementing a storage cost effectiveness study is the identification of key stakeholders. In a vertically integrated utility the benefits may be straightforward as all monetary gain is received by the one entity that owns the entirety of the infrastructure. However, key stakeholders can range beyond power producers from technology providers to project developers, utilities, generators and IPPs, state and federal regulators, end users, ISOs/Regional Transmission Organizations (RTOs), researchers, and financers. After identifying the aggregate of benefits that can be realized, properly identifying the key stakeholders may reveal that the benefits may not all aggregate to the same entity. This opens up both possibilities for collaboration between stakeholders and complications to energy storage project implementations. Once benefits are identified, a cost- effectiveness study will help identify the size of the system, the potential return on investment, and the optimal performance of the energy storage system based on the highest rate of return for various dispatching applications.

### **3.5 Summary**

The third chapter discusses screening-level and advanced production cost, electric stability, and financial tools that can be used to evaluate the impact of electricity storage in the grid. Appendix A provides a summary of specific evaluation tools currently available.

### **3.6 Extended Technical Discussion**

The U.S. Energy Information Administration (EIA) collects, analyzes, and disseminates independent and impartial energy information to promote sound policymaking, efficient markets, and public understanding of energy and its interaction with the economy and the environment. As part of the collection process, information is gathered from electrical generation through Form EIA-860 and Form EIA-923. The current EIA forms do not cover many parameters specific to energy storage, and energy storage is becoming more prevalent in modern power systems.

The 2015 SAND Report *Recommendations on Energy Storage for the Energy Information Agency* (SAND2015-11015) made recommendations on data that should be collected from energy storage plants in EIA surveys. The goal of this report is to make recommendations on data that should be collected from energy storage plants in EIA surveys. Table 23 identifies parameters that should be collected. Each parameter is assigned a collection priority: H-high, M-medium, and L-low.

**Table 23. Recommended Energy Storage System Parameters**

	Parameter	Priority
1	Nameplate energy capacity (MWh)	H
2	Nameplate power rating (MW)	H
3	Peak charge rate (MW)	H
4	Duration at peak charge rate (minutes)	H
5	Maximum continuous charge rate (MW)	H
6	Peak discharge rate (MW)	H
7	Duration at peak discharge rate (minutes)	H
8	Maximum continuous discharge rate (MW)	H
9	Grid voltage at point of interconnection	H
10	Primary storage technology	H
11	Energy capacity of primary storage technology (MWh)	H
12	Secondary storage technology	H
13	Energy capacity of secondary storage technology	H
14	Commissioning date	H
15	Expected retirement date	H
16	What fire suppression technologies are deployed?	H
17	Does the plant provide reactive power?	H
18	Nameplate reactive power rating (MVAR)	H
19	Reactive power ramp rate (MVAR/min) for sourcing and absorbing reactive power	H
20	Maximum ramp rate, charge (MW/min)	M
21	Maximum ramp rate, discharge (MW/min)	M
22	Enclosure type (building, containerized-stationary, containerized-transportable)	M
23	Equipment footprint (square feet)	M
24	Minimum time from 0% state of charge to 100% state of charge (min)	M
25	Minimum time from 100% state of charge to 0% state of discharge (min)	M

Source: *Recommendations on Energy Storage for the Energy Information Agency*, SAND2015-11015, Sandia National Laboratories, Albuquerque, NM, 2015, Raymond H. Byrne, Daniel R. Borneo, Cedric O. Christensen, David R. Conover, Imre Gyuk, Jacquelynne Hernandez, Georgianne Huff, Michael Kintner-Meyer, Janice Lin, David M. Rosewater, David A. Schoenwald, and Vilayanur Viswanathan.



## CHAPTER 4. STORAGE SYSTEMS PROCUREMENT


### 4.1 General Information

Storage services for the grid can be acquired through several business models, as shown in Figure 67. These business models range from contracting for services only without owning the storage system to outright purchase. The specific option chosen depends on the varying needs and preferences of the owner. This chapter provides broad guidelines for acquiring electricity storage systems using different options.

### 4.2 Approach

This chapter will discuss the process of energy storage through a business model, indicating processes and considerations for ownership of energy storage, while describing the various elements of procurement.

### 4.3 Data



**Figure 67. Business Models for Storage Systems**  
(Source: EPRI)

### 4.3.1 Third-party Ownership

In this option the storage system is owned, operated, and maintained by a third party who provides specific storage services according to a contractual arrangement. This process is very similar to fossil generating stations' IPP agreements. The key terms for fossil plants under such an operating agreement, typically of 20 to 25 years duration, generally include:

- The off taker supplies the fuel, takes the energy, and holds the dispatch rights.
- The seller earns a fixed capacity payment (that is, \$/kW-month) and a variable O&M payment per MWh delivered (\$/MWh).
- In return for the capacity payment, the seller assures a certain availability of the plant.
- The seller provides a heat rate guarantee.

The terms of the operating agreement for third-party ownership of a storage facility will be somewhat similar to that of a fossil plant, except the variables for a storage system reflect its unique differences. For example, for a battery storage system, heat rate (MBTU/kWh) is not applicable. It would instead be replaced by a range for round-trip efficiency. The “fuel” would be the cost of off-peak electricity for charging the storage. The complete contract would also include a number of other details such as frequency and number of charge/discharge cycles during the life of the contract, depth of discharge. Similarly, other storage technologies, such as CAES, flywheels and pumped hydro, will include operating parameters specific to those technologies that govern their optimal performance during the term of the contractual agreement.

The advantage of third-party ownership is that it shelters the owners – utilities and end-users – from financial and technology risks, both technological obsolescence due to rapid evolution of a particular technology and the inability of the purchased technology to meet projected performance targets. An additional consideration is that the operating costs for a third-party storage plant providing services to an IOU, co-op, municipal utility or end-use customer would be passed through a bilateral contract.

The third-party ownership model has worked successfully with renewable technologies and in traditional fossil power plant generation projects. It has not, however, been widely adopted by storage technology vendors or investors, especially new entrants to the commercial marketplace who prefer short payback and higher cash flows that outright sales generate.

### 4.3.2 Outright Purchase and Full Ownership

The alternative option to third-party ownership is full purchase and ownership of a storage system. In this option, the wide range of size and functionality between pumped hydro and CAES technologies, compared to batteries and flywheels, creates a clear distinction between their procurement and installation process. Pumped hydro and CAES are technologies that predominantly provide generation-side services due to their large sizes and long-duration discharge capability. Batteries and flywheels are technologies that predominantly provide grid

## Chapter 4. Storage Systems Procurement Installation

services that need relatively smaller storage size and shorter duration discharges, as discussed in earlier chapters of the Handbook. Thus the procurement and installation of pumped hydro and CAES is preceded by a far more rigorous analysis to justify their inclusion in the utility system expansion plans, including environmental impact assessments, orders-of-magnitude higher level of civil engineering to develop the sites, and community input in the approval process for the implementation of these projects. This pre-planning takes several years, even before the final procurement of hardware begins. Other reports have detailed the intricacies of navigating the regulatory approval and permitting process for recently proposed pumped hydro and CAES projects.<sup>67</sup> The unique path of each project renders it difficult to identify a common process for procuring and installing these two technologies. Thus the focus of this chapter is on battery and flywheel storage systems, because their procurement and installation lends itself to a more replicable process and is less project-specific.

If the battery or flywheel storage project is solely for a demonstration of the technology for the owning entity, then the procurement process is usually driven by predetermined assumptions of cost, technology preference, and location of the project. On the other hand, if the owning entity is implementing the storage project based on operational needs of the grid, then the choice of storage technology, size, location, and project schedule is governed by the results of analytical tools described in earlier chapters and influenced by system-wide grid and regulatory considerations. In both instances, the owning entity has a choice of procuring the storage system piecemeal, with each subsystem of the storage system acquired separately, or procuring the entire storage system on a turnkey basis.

The current trend in storage system acquisitions has been toward the latter option, which is also facilitated by the commercial availability of several turnkey, modular storage systems with any of the family of battery types or flywheel technology. Turnkey acquisitions relieve the owning entity from specifying each subsystem individually and managing their procurement contracts and installation separately. Before the commercial availability of modular turnkey systems, many of the early utility and cooperative-owned battery storage systems, described in Appendix G, were acquired on a piecemeal basis and assembled at the project site. The piecemeal approach of building a battery system placed the burden of managing a complex acquisition and construction project on the owning utility. The first modular, turnkey system appeared in the United States in the mid-1990s with the introduction of the Model PM250, a 250-kW battery storage system designed and built by AC Battery (see Figure 68). The PM250 was a factory-assembled, modular, turnkey battery storage system that was delivered to the site in one container-sized package. It demonstrated the advantages of a modular, factory-assembled system design over the site-assembled counterparts and laid the foundation for the subsequent availability of today's containerized storage systems.

---


<sup>67</sup> *Evaluating Utility Owned Electric Energy Storage Systems : A Perspective for State Electric Utility Regulators*, Bhatnagar, Dhruv and Loose, Verne, SAND2012-9422, Sandia National Laboratories, Albuquerque, NM, 2012,



**Figure 68. First AC Battery PM250 Modular Battery System Installed at Pacific Gas & Electric's Modular Generation Test Facility, San Ramon, CA, in 1993.**

Battery and flywheel storage system acquisitions can be managed through a two-step process that consists first of issuing an Request for Information (RFI) followed by a Request for Proposals (RFP), as illustrated in Figure 69. Executing the first step to issue an RFI only requires identifying basic functional requirements of the intended use of the energy storage system and identifying a pool of potential vendors who could supply such a system. The functional requirements described in the RFI can include as many characteristics of the desired system as can be identified at the time the RFI is prepared. These requirements usually include the power and energy size of the system, expected charge/discharge cycles, life expectancy, footprint, proposed location, and other characteristics to provide the vendors with a concept of the storage system. A guide<sup>68</sup> is available that provides information that can guide the initial identification of these system characteristics as shown in Table 24.

<sup>68</sup> *Electric Energy Storage Technology Options: A White Paper Primer on Applications, Costs, and Benefits*, PI: Dan Rastler, EPRI, EPRI ID: 1020676. EPRI, Palo Alto, CA, September 2010.  
<http://www.epri.com/abstracts/Pages/ProductAbstract.aspx?ProductId=00000000001020676>.



**Figure 69. A Process for Storage System Acquisition**  
(Source: Sandia National Laboratories)

**Table 24. Storage System Characteristics for Select Services**

Application	Description	Size	Duration	Cycles	Desired Lifetime
<b>Wholesale Energy Services</b>	Arbitrage	10-300 MW	2-10 hr	300-400/yr	15-20 yr
	Ancillary services <sup>2</sup>	See note 2	See Note 2	See Note 2	See Note 2
	Frequency regulation	1-100 MW	15 min	>8000/yr	15 yr
	Spinning reserve	10-100 MW	1-5 hr		20 yr
<b>Renewables Integration</b>	Wind integration: ramp & voltage support	1-10 MW distributed 100-400 MW centralized	15 min	5000/yr 10,000 full energy cycles	20 yr
	Wind integration: off-peak storage	100-400 MW	5-10 hr	300-500/yr	20 yr
	Photovoltaic Integration: time shift, voltage sag, rapid demand support	1-2 MW	15 min-4 hr	>4000	15 yr
<b>Stationary T&amp;D Support</b>	Urban and rural T&D deferral. Also ISO congestion mgt.	10-100 MW	2-6 hr	300-500/yr	15-20 yr
<b>Transportable T&amp;D Support</b>	Urban and rural T&D deferral. Also ISO congestion mgt.	1-10 MW	2-6 hr	300-500/yr	15-20 yr
<b>Distributed Energy Storage Systems (DESS)</b>	Utility-sponsored; on utility side of meter, feeder line, substation. 75-85% ac-ac efficient.	25-200 kW 1-phase 25-75 kW 3-phase Small footprint	2-4 hr	100-150/yr	10-15 yr
<b>C&amp;I Power Quality</b>	Provide solutions to avoid voltage sags and momentary outages.	50-500 kW	<15 min	<50/yr	10 yr
		1000 kW	>15 min		
<b>C&amp;I Power Reliability</b>	Provide UPS bridge to backup power, outage ride-through.	50-1000 kW	4-10 hr	<50/yr	10 yr
<b>C&amp;I Energy Management</b>	Reduce energy costs, increase reliability. Size varies by market segment.	50-1000 kW Small footprint	3-4 hr	400-1500/yr	15 yr
		1 MW	4-6 hr		
<b>Home Energy Management</b>	Efficiency, cost-savings	2-5 kW Small footprint	2-4 hr	150-400/yr	10-15 yr
<b>Home Backup</b>	Reliability	2-5 kW Small footprint	2-4 hr	150-400/yr	10-15 yr
1. Size, duration, and cycle assumptions are based on EPRI's generalized performance specifications and requirements for each application, and are for the purposes of broad comparison only. Data may vary greatly based on specific situations, applications, site selection, business environment, etc.					
2. Ancillary services encompass many market functions, such as black start capability and ramping services, that have a wide range of characteristics and requirements.					

The RFI does not specify a storage technology type and only includes other desired characteristics of the storage system, unless the owner has a predisposition for a particular storage technology. In the absence of such a preference, it is best to leave the technology selection up to the vendor to ensure that the most suitable storage technology that closely matches the owner's stated requirements is made available.

The complete RFI is then issued to a pool of prospective suppliers with a two-fold purpose. First, it is an opportunity for the vendors to provide feedback to the owners about how they perceive the system requirements and what other pieces of information they need to submit a full proposal when the subsequent RFP is issued. Second, the vendor feedback provides information to refine the system requirements further, based on hardware that is available or could become available within the desired time frame. This feedback leads to the development of a firm specification for

## Chapter 4. Storage Systems Procurement Installation

the system that will be part of the RFP issued later in the procurement process. Further, the RFI vendor responses are a good indicator of vendor qualifications to supply a system that meets the owner requirements. It also allows the owners to develop a short list of vendors that will subsequently be included on the RFP requestor list. The smaller pool of vendors will be more likely to have the right technology and qualifications to respond to the subsequent RFP when it is issued. Generally, only one RFI vendor feedback call is needed to move forward on developing the RFP as the next step of the procurement process. A sample RFI used by the Kauai Island Utility Cooperative (KIUC) is provided in Appendix C. (*KIUC has given permission to modify these documents to suit reader's specific needs. Text can be copied and pasted into user-generated documents to develop RFI and RFP packages by the reader.*)

Finally, the advantage of the two-step RFI/RFP process is that an RFI provides a means for a non-binding exchange of information between the owners and vendors that allows them to assess each other's needs and capabilities. This provides the basis for developing a RFP that more closely reflects the requirements of the proposed system matched to the hardware and services that vendors can offer.

Another open source document that can be used as a template for a storage system specification is available from American Electric Power (AEP). This specification for a Community Energy Storage (CES) system was written with input from vendors and other utilities, and its development was facilitated by EPRI.

AEP followed a similar RFI process to formulate a comprehensive specification set that describes the desired functionality of the system, yet leaves the selection of the specific storage technology to the vendor. The specification starts with the simple details and goes on to describe very specific features desired by the utility, including electrical requirements, interconnection, controls, and communications.

### 4.3.3 Procurement Guidance for Energy Storage Projects

The attached guidance documents were produced by Sandia National Laboratories with assistance from Clean Energy Group/Clean Energy States Alliance (CESA). Originally developed to support Massachusetts Department of Energy Resources' Community Clean Energy Resilience Initiative awardees in energy storage procurement, these materials offer useful information for other municipalities to consider as they develop solicitations for resilient, energy storage projects.

The materials included are designed to give specific examples of the elements that should be included in a solicitation for the procurement and installation of a battery energy storage project that is designed to provide backup power during outages.

Included in this package are:

1. Section A: Matrix of Elements to Include in a Request for Proposals (pages A1-A6)
2. Section B: Template for Request for Proposals for Behind-the-Meter Energy Storage Projects (pages B1-B23)

## Energy Storage Procurement Matrix

Section Topic	Section Sub-Topic	Information the Initiator should provide or ask for in RFP	Questions the Bidder should answer in proposal	Evaluation Criteria (Industry standards)
Who		<p><b>Provide:</b> Details about who is initiating project. Background of initiating organization and project.</p> <p><b>Ask:</b> Who is bidder, including subcontractors/partners</p>	Company and partners, contact information, details of experience of key participants, roles and responsibilities of all partners, resumes of principle project team.	<p>Proven track record with solar+storage projects in municipal settings including references to completed projects.</p> <p>Include safety performance record at previous projects.</p>
Why		<p><b>Provide:</b> Describe the overall goal of the project. Detail if the project fits within a larger state or municipal context; for example, state if the goal is emissions reduction, renewables integration, or resiliency.</p> <p><b>Ask:</b> How will bidder's proposed project solve the problem or help to reach the goal(s) of the project? How will it fit within the larger context?</p>	<p>How does your project provide the best solution? What are the most compelling features of the system?</p> <p>How does the project solve the problem, meet the goal, or fit within the larger context?</p>	<p>For new solar &amp; storage projects: check for monitoring systems that are able to obtain federal 30% Investment Tax Credit.</p> <p>For Behind the Meter projects: additional opportunities to monetize the project via delivery or supply rate changes or participation in specific utility or statewide incentive programs.</p> <p>For utility scale projects: scalability, replicability and LCOE/LCOS metrics</p>
What	Project description	<p><b>Provide:</b> Project description. Describe the problem that needs to be solved; include power and energy minimums throughout project (if known).</p> <p><b>Ask:</b> How will bidder solve the</p>	<p>What is the solution to the problem? What are the specifications of the system?</p> <p>Operating conditions – cycle life.</p> <p>How will the system meet the specifications and requirements set forth by the owner?</p>	Look at how available energy is specified in the response: Nameplate capacity (kWh or MWh).

Sec-A-1

## Chapter 4. Storage Systems Procurement Installation

Section Topic	Section Sub-Topic	Information the Initiator should provide or ask for in RFP	Questions the Bidder should answer in proposal	Evaluation Criteria (Industry standards)
		problem? What are the specifications of proposed system? How will proposed system meet the requirements of the project?		
	Scope of work	<p><b>Provide:</b> Detailed Statement/Scope of Work (SOW). Scope should delineate who will do what and when. Include timelines, milestones, roles, what applicant will be responsible for and what bidder will NOT be responsible for.</p> <p><b>Ask:</b> How will bidder satisfy the SOW?</p>	<p>How does applicant propose to implement scope of work and meet project requirements?</p>	<p>Make sure response contains all assumptions from provider in their plan to complete Scope of Work, including items that may warrant a Change Order.</p> <p>Make sure that scope of work and exclusions from SOW are well aligned with project type (utility-scale or behind the meter). Behind the meter projects should not include medium voltage and SCADA/data integration, but should have more specifics about utility rates, integrations with on-site generation and revenue streams.</p>
	Operational Specifications	<p><b>Provide:</b> Operational specifications – Load data, predetermined or required ramp rates, charge and discharge profiles and cycles, applications to be served and modes of operation. Control and monitoring requirements.</p> <p><b>Ask:</b> How will bidder's proposed system meet these operational requirements? Who will own and operate the system?</p>	<p>How does applicant propose to meet all operational specifications? Are there any ways in which bidder's proposed system would not meet or would exceed operational specifications? Who does the bidder propose will own and operate the system?</p>	<p>Power purchase details and permitting requirements, where applicable.</p> <p>Look for how bidder describes operational metrics and relates them to financial and warranty metrics.</p> <p>Look for applications served and if system will be serving multiple applications how they will be handled and integrated.</p>

Sec-A-2

## Chapter 4. Storage Systems Procurement Installation

Section Topic	Section Sub-Topic	Information the Initiator should provide or ask for in RFP	Questions the Bidder should answer in proposal	Evaluation Criteria (Industry standards)
	System Specifications	<p><b>Provide:</b> System requirements – System size in both power (kW) and energy (kWh), round trip efficiency, Type of energy storage technology, if it needs to be specified (not recommended), cycle life and project life required based on operational specifications, i.e. kW/kWh per year for how many years. Operating temperatures required, disposal requirements.</p> <p><b>Ask:</b> How will bidder's system meet all required system specifications? If bidder's proposed system meets operational specifications but diverges from system specifications, what are the relative costs and benefits of bidder's proposed system? Request test data.</p>	<p>How does bidder propose to meet all required system specifications? Can bidder's system meet all operational specifications if diverging from system specifications? If so, what are the relative costs and benefits of bidder's system, compared with the prescribed system specifications? Provide detailed specification of all equipment. Include any system testing and performance data and how it was acquired.</p> <p>NOTE: It is recommended that system specifications not define a specific energy storage type of technology in an RFP or other solicitation unless absolutely necessary. Bidders should be free to propose any system that meets the operational and other project requirements, to provide for competition and allow innovative solutions to come to the fore. For example, don't indicate that you want a flow battery vs. an electrochemical battery vs. a flywheel or something else.</p>	<p>Look at how round trip efficiency is defined if any kind of temperature control equipment is mentioned. For utility scale systems, be sure to double check that the proposed controls/SCADA architecture will fit well with the systems already in place.</p> <p>Make sure that testing data provided is applicable to the system/solution being proposed.</p> <p>Look for indication of energy storage degradation (number of expected cycles over ES lifetime).</p>

Sec-A-3

## Chapter 4. Storage Systems Procurement Installation

Section Topic	Section Sub-Topic	Information the Initiator should provide or ask for in RFP	Questions the Bidder should answer in proposal	Evaluation Criteria (Industry standards)
	Design Requirements	<p><b>Provide:</b> Design requirements and system/equipment parameters not covered in operational and/or system specifications. If possible, provide design package including standards and specifications for procurement and installation as required.</p> <p><b>Ask:</b> How does bidder propose to meet all design requirements?</p>	How does bidder propose to meet all design requirements? Provide shop drawings and/or schematic drawings, as necessary.	<p>If you require integration of new Solar PV and Storage, require that the type coupling (AC vs DC) be clearly indicated.</p> <p>Utility scale: make sure that a diagram detailing physical data and SCADA communication layers exist.</p> <p>Behind the Meter: one-line schematic drawing and a sequence of operations noted on a drawing or as a separate document is a plus.</p>
Where		<b>Provide:</b> The location of the work and factors such as emissions or other regulations that may be imposed upon the bidder.	How to install project at the specified location, especially if there are any constraints?	Make sure that any work necessary to prepare the location is included in the SOW.
When		<b>Provide:</b> The project timeline and completion deadline. Include RFP process, RFP review, interview, bidder selection, project timeframe including any post-commissioning period of data collection and monitoring.	Provide detailed schedule starting at award date. Include design, permitting, procurement (long lead items), engineering, construction, commissioning (DV, OAT, startup, FAT, shakedown), closeout, warranty period	<p>For labor intensive projects that include multiple sites (especially those that include solar PV), make sure that construction and commissioning are planned in phases.</p> <p>The warranty periods for various parts of the proposed solution should be clearly spelled out (workmanship, components, equipment).</p>
How		<p><b>Provide:</b> Define project deliverables and expectations.</p> <p>Address how the bidder be selected, i.e., selection criteria</p>	How will you conduct project construction contracting strategy, procurement strategy, detailed schedule, org chart including partners with detailed roles and	Operations and Maintenance strategy should be put forward with assumptions called out. O&M should be clearly priced and scoped out – approximate schedules should be provided.

Sec-A-4

## Chapter 4. Storage Systems Procurement Installation

Section Topic	Section Sub-Topic	Information the Initiator should provide or ask for in RFP	Questions the Bidder should answer in proposal	Evaluation Criteria (Industry standards)
		<p>including grading system.</p> <p>Detail the contracting strategy and timeframe.</p> <p>Include expectations for project team's experience, testing and commissioning, training, operational support and warranty. Warranty should include needed maintenance service, spare parts for project lifetime.</p>	<p>responsibilities. Provide maintenance, spare parts and warranty information.</p> <p>If appropriate, explain how the system will be operated long-term, i.e. Power Purchase Agreement (PPA); Engineer, Procure, Construct (EPC); etc.</p>	Large capital expenditures, like battery replacement, should be called out.
How Much		<p><b>Provide:</b> Include details about any budget requirements, cost share. Include WBS breakdown worksheet for bid evaluation and comparison. Define methodology for computing LCOE.</p> <p><b>Ask:</b> What are the total costs for the proposed system or services, including cost breakdown for components, subcontracting, etc? What matching/outside funds are included? Is any part of the project to be financed? If so, does the bidder have a commitment from a financier or bank?</p>	<p>Cost of total project using provided WBS; include any replacement needed to meet project life cycle. In addition, provide levelized cost of energy (LCOE) for life of project. List any and all exclusion, assumptions, and risk of cost overruns. List any matching funds, outside funds, or other resources included in the bid. If financing is included, show evidence that the project is financeable.</p>	<p>Budget breakdowns should help to gain insight into project costs as well as expected payment schedule. Items that are additional should be clearly labeled as such. Items that are estimated or not yet priced should also be clearly labeled.</p> <p>If there is a known risk with accomplishing a desired technical goal (for instance, providing backup power to loads larger than the battery capacity, or structural concerns with battery location), then an engineering phase should be clearly separated from the construction scope of work. There should be an option to exit the contract if engineering determines that the project falls outside the scope originally proposed during the bid.</p>

Sec-A-5

3. Section C: Template of a Request for Proposals for Utility-Scale Energy Storage Projects  
(pages C1-C26)

The matrix serves as a checklist of items that should be included in an energy storage RFP. It also suggests information that should be provided in the RFP and questions that should be asked of potential vendors. Finally, the matrix includes information on what to look for in vendor responses.

The two templates serve as examples of the layout, language, and specifications that could be included in an RFP. Since the details are different depending on the scale of the project, there are two templates included to address the specifics of projects at each scale.

CESA previously produced a webinar on the topic of energy storage procurement, featuring presentations by Sandia National Laboratories and Bright Power. This webinar is archived and can be reviewed at <http://www.cleaneigroup.org/webinar/procurement-guidance-energy-storage-projects-help-rfis-rfqs-rfps/>.

## BEHIND THE METER RFP TEMPLATE

### Request for Proposals Template: Behind the Meter

---

[Title and Solicitation Number]

(Organization)

for The Town of (municipality),

Community Clean Energy Resiliency Initiative

Request for Proposals

Release Date: \_\_\_\_\_, 2016

Due Date: \_\_\_\_\_, 2016

(ORGANIZATION) FOR THE (MUNICIPALITY)  
 REQUEST FOR PROPOSALS – ENERGY STORAGE SYSTEM  
 FOR THE COMMUNITY CLEAN ENERGY RESILIENCY INITIATIVE

[Title and Solicitation Number]

Table of Contents

DOE/EPRI Electricity Storage Handbook in Collaboration with NRECA .....	iii
GLOSSARY .....	xv
Preface.....	xxi
Introduction.....	xxiii
Handbook Roadmaps .....	xxv
Suggested Guide for System Vendors and Investors.....	xxviii
Suggested Guide for Regulators and Policy Makers .....	xxix
Energy Storage 101 .....	xxx
CHAPTER 1. ELECTRICITY STORAGE SERVICES AND BENEFITS .....	1
1.1 General Information.....	1
1.2 Approach.....	1
1.3 Data Bulk Energy Services .....	2
1.3.1 Electric Energy Time-Shift (Arbitrage) .....	2
1.3.2 Electric Supply Capacity.....	3
1.4 Ancillary Services .....	4
1.4.1 Regulation .....	4
1.4.2 Spinning, Non-Spinning, and Supplemental Reserves.....	7
1.4.3 Voltage Support .....	9
1.4.4 Black Start.....	9
1.4.5 Other Related Uses.....	10
1.4.6 Frequency Response .....	13
1.5 Transmission Infrastructure Services .....	14
1.5.1 Transmission Upgrade Deferral .....	14
1.5.2 Transmission Congestion Relief .....	16
1.5.3 Other Related Uses.....	17
1.6 Distribution Infrastructure Services .....	18
1.6.1 Distribution Upgrade Deferral and Voltage Support .....	18
1.7 Customer Energy Management Services .....	20
1.7.1 Power Quality .....	20
1.7.2 Power Reliability.....	21
1.7.3 Retail Energy Time-Shift .....	22
1.7.4 Demand Charge Management.....	23
1.8 Stacked Services—Use Case Combinations.....	25
1.9 Summary .....	27
1.10 Extended Technical Discussion .....	27

<b>CHAPTER 2 ELECTRICITY STORAGE TECHNOLOGIES: COST, PERFORMANCE, AND Maturity .....</b>	<b>29</b>
2.1 General Information.....	29
2.2 Approach.....	29
2.3 Data Mature Electricity Storage Technologies .....	29
2.4 Pumped Hydro .....	32
2.4.1 Additional Pumped Hydro Resources.....	35
2.5 Compressed Air Energy Storage .....	35
2.5.1 Technical Description .....	35
2.6 Sodium-sulfur Battery Energy Storage .....	37
2.6.1 Technical Description .....	37
2.7 Sodium-nickel-chloride Batteries.....	43
2.7.1 Technical Description .....	43
2.8 Vanadium Redox Batteries.....	45
2.8.1 Technical Description .....	45
2.9 Iron-chromium Batteries .....	49
2.9.1 Technical Description .....	49
2.1.1 Performance Characteristics .....	49
2.10 Zinc-bromine Batteries .....	51
2.10.1 Technical Description .....	51
2.11 Zinc-air Batteries.....	56
2.11.1 Technical Description .....	56
2.12 Lead-acid Batteries .....	60
2.12.1 Technical Description .....	60
2.13 Flywheel Energy Storage .....	67
2.13.1 Flywheels Basics.....	67
2.14 Lithium-ion Family of Batteries.....	74
2.15 Emerging Technologies .....	81
2.15.1 General Technology Overview .....	83
2.16 Summary .....	84
2.17 Extended Technical Discussion .....	85
<b>CHAPTER 3. METHODS AND TOOLS FOR EVALUATING ELECTRICITY STORAGE .....</b>	<b>87</b>
3.1 General Information.....	87
3.2 Approach.....	87
3.3 Data .....	88
3.4 Modeling Tools .....	97
3.4.1 DOE SNL Tools.....	99
3.4.2 Other Evaluation Tools .....	100
3.5 Summary .....	102
3.6 Extended Technical Discussion .....	102
<b>CHAPTER 4. STORAGE SYSTEMS PROCUREMENT .....</b>	<b>105</b>
4.1 General Information.....	105

## Chapter 4. Storage Systems Procurement Installation

4.2	Approach.....	105
4.3	Data.....	105
	4.3.1 Third-party Ownership.....	106
	4.3.2 Outright Purchase and Full Ownership .....	106
	4.3.3 Procurement Guidance for Energy Storage Projects .....	111
	Table of Contents.....	119
	PART 1: INTRODUCTION.....	124
	A: General.....	124
	PART 2: GENERAL.....	126
	Background.....	126
	Project Description.....	126
	Proposal Process and Schedule .....	126
	PART 3: SCOPE OF WORK / REQUIREMENTS .....	127
	Scope of Supply .....	127
	Documentation Deliverables.....	128
	Design Conditions.....	128
	Electrical Design Parameters .....	129
	Audible Noise .....	129
	BESS Requirements.....	129
	Modes of Operation .....	130
	Harmonics .....	131
	Protection Requirements and Balance of System Components (BOS) .....	131
	Internet connection.....	131
	Labeling .....	131
	Grounding .....	131
	Structural / Foundation Pads / Conduit.....	132
	Mounting System .....	132
	Spill Containment .....	132
	Personnel Safety.....	132
	Fire Protection.....	132
	Spare Parts and Equipment .....	132
	Battery Management System (BMS).....	133
	Factory Testing - Battery .....	133
	Commissioning - Acceptance and Performance Testing .....	133
	Warranty .....	133
	Utility Interconnection and Rates .....	134
	Modifications .....	134
	Additional Requirements .....	134
	PART 4: EXCLUSIONS .....	134
	PART 5: SCHEDULE .....	134
	PART 6: COST PROPOSAL.....	134
	PART 7: SELECTION PROCESS .....	135
	General .....	135

PART 8: SELECTION CRITERIA .....	136
Participation Requirements .....	136
Evaluation Criteria .....	136
BESS Proposal Evaluation Matrix .....	137
PART 9: GENERAL PROVISIONS .....	138
General .....	138
PART 10: SUBMISSION REQUIREMENTS .....	138
Required Materials .....	138
PART 11: ATTACHED DOCUMENTS .....	140
Exhibit A Certification .....	141
Exhibit B Cost Proposal Worksheet .....	142
Table of Contents .....	144
PART 1: INTRODUCTION .....	146
A: General .....	146
PART 2: GENERAL .....	148
Background .....	148
Project Description .....	148
Proposal Process and Schedule .....	148
PART 3: SCOPE OF WORK / REQUIREMENTS .....	149
Scope of Supply .....	149
Documentation Deliverables .....	150
Design Conditions .....	151
Electrical Design Parameters .....	151
Audible Noise .....	151
BESS Requirements <i>[ALTER TO SUIT PROJECT REQUIREMENTS]</i> .....	151
Modes of Operation .....	153
Microgrid - Resiliency for Emergency Conditions .....	153
Peak Load Reduction .....	153
3MW PV Smoothing .....	153
Automatic Scheduling .....	154
Voltage Regulation .....	154
Harmonics .....	154
Protection Requirements .....	155
SCADA Integration .....	155
Internet connection .....	156
Grounding .....	156
Structural / Foundation Pads / Conduit .....	156
Spill Containment .....	156
Personnel Safety .....	156
Fire Protection .....	156
Spare Parts and Equipment .....	157
Factory Testing - Battery .....	157
Commissioning - Acceptance and Performance Testing .....	157

Chapter 4. Storage Systems Procurement Installation

Warranty .....	157
Interconnection .....	158
Modifications .....	158
Additional Requirements .....	159
<b>PART 4: EXCLUSIONS .....</b>	<b>159</b>
<b>PART 5: SCHEDULE .....</b>	<b>159</b>
<b>PART 6: COST PROPOSAL.....</b>	<b>160</b>
<b>PART 7: SELECTION PROCESS .....</b>	<b>160</b>
General .....	160
<b>PART 8: SELECTION CRITERIA .....</b>	<b>161</b>
Participation Requirements.....	161
Evaluation Criteria .....	161
BESS Proposal Evaluation Matrix.....	162
<b>PART 9: GENERAL PROVISIONS .....</b>	<b>163</b>
General .....	163
<b>PART 10: SUBMISSION REQUIREMENTS .....</b>	<b>163</b>
Required Materials.....	163
<b>PART 11: ATTACHED DOCUMENTS.....</b>	<b>166</b>
Exhibit A Certification.....	166
Exhibit B Cost Proposal Worksheet .....	167
4.4              Summary .....	167
4.5              Extended Technical Discussion .....	167

## PART 1: INTRODUCTION

### A: General

(Organization) (ORG), as the Awarding Authority (Known as Owner), invites the submission of proposals by responsible companies (known as Vendor) to design, procure, install, test and commission a minimum of (capacity) Battery Energy Storage System (BESS) to be located at the (location). The primary purpose of this Community Clean Energy Resiliency Initiative Project being performed in part with a grant from the Massachusetts Department of Energy Resources (DOER) is to provide resiliency through the use of energy storage for the (facility) using battery technology.

The successful vendor will work with the (ORG), Owner's Project Manager (OPM) and (Name of the Project Management Firm). Respondents must demonstrate successful completion of energy storage systems using the same technology proposed.

To be considered, all submissions must be prepared in accordance with the requirements specified in this Request for Proposals (RFP) document and in accordance with applicable provisions of Massachusetts General Laws.

The cost is to be negotiated with the company with the highest-ranked proposal based on their ability to meet or exceed all requirements outlined in the attached selection criteria. Any exceptions to the requirements of this RFP are to be identified on a separate form and clearly marked exceptions. If an agreement cannot be reached with the first choice, the Awarding Authority will negotiate with the next highest ranked firm. The cost for BESS maintenance and the performance degradation over the life of the project will be considered in the selection process. This is a total cost of ownership-based selection process.

The vendor's cost proposal is to be placed in a separate sealed envelope bearing the title "(RFP Title)" and included with the proposal. Bidders shall use the Work Breakdown Structure (WBS) provided in the RFP package. The contract will be awarded to the vendor with the most advantageous and responsive submittal taking into consideration both price and non-price submittals. **Copies of the full RFP documents and required forms are available at the (Building) building and on the (ORG) website.**

Seven (7) hard copies of all Submission Requirements must be submitted to:

(Title)  
(Address)  
(Organization)

Submissions are due on or before \_\_\_\_\_ at \_\_\_\_ pm. Any submission received after this time and date will not be considered and will be returned to the respondent unopened. The clock in the (Municipality) office shall represent the official time for purposes of this determination.

Copies of Submission Forms, and any inquiries regarding the information contained in this Request for Proposals, shall be directed to the (Title) at the address above, by telephone (\_\_\_\_\_) or by email (\_\_\_\_\_\_). **The deadline for written questions will be \_\_\_\_\_ PM on \_\_\_\_\_.** **Responses to questions will be posted \_\_\_\_\_.** Interested parties are responsible for checking the website for addenda and responses to questions.

The (Organization) reserves the right to waive any informality in the submissions, to reject any or all submissions, or to accept any submission which it deems to be in the best interest of the (municipality name).

Interested parties are instructed to check the (ORG) website for addenda to this RFP. Submissions are to be sealed and properly identified on the outer envelope as "(RFP Title)" (Project Name). Price proposals are to be in a separate sealed envelope, appropriately identified.

(Name)  
(Title)  
(Organization)  
(Date)

## PART 2: GENERAL

### Background

(add project background and description of proposed sites for Behind-the-Meter battery storage systems)

### Project Description

In December, 2014 the (Organization) was awarded a grant by the Massachusetts Department of Energy Resources (DOER) Renewable and Alternative Energy Division for a project proposed in our Community Clean Energy Resiliency Initiative grant application, namely, implementing a Resiliency Plan through Clean Energy Storage for a Municipal Microgrid Project. This project looks to provide energy storage for the (Location) using battery technology. The (ORG)'s forward thinking approach is looking for ways to expand their investment into renewable energy technology solutions.

(Organization) intends to install integrated behind-the-meter (BTM) Battery Energy Storage System (BESS) to support the following facilities in the event of an extended grid outage:

(add description of existing facilities and/or solar PV)

The BESS shall be sized for a minimum (Power) capable of operating for (hours) hours at nameplate rating.

(add specific requirements)

### Proposal Process and Schedule

(Organization) is requesting proposals from qualified Battery Energy Storage System (BESS) vendors to design, procure, install, test and commission an Energy Storage System to meet the requirements as described in this request for proposals (RFP) document for the (project name) as a turnkey system.

(ORG) will select a short list of (number) vendors. Interviews will then be held between (ORG) and the vendors selected to discuss the details of each vendor's proposal and to clarify the intent of the requirements. If required, the vendors may submit revised proposals including clarifications. (ORG) will then select a vendor and enter into contract negotiations.

The desired schedule for the BESS project is shown in the below table. Reasonable alternate schedules proposed by the BESS vendor will be considered:

RFP issued	(date)
Site Visit	(date, time and place)
Questions Due	(date)
Responses to Questions Posted	(date)
Bids Due	(date)
Shortlist selected and interviews conducted	(date)
Contract awarded	(date)
BESS startup	(date)
BESS accepted	(date)

## PART 3: SCOPE OF WORK / REQUIREMENTS

The purpose of this scope of work section is to provide qualified bidders with more detail on the description of the project, explanation of how it will be managed and to clarify what deliverables are to be provided by the successful BESS vendor.

### Scope of Supply

The scope of supply for the BESS shall include the following principal elements. The vendor shall be responsible for identifying and providing any and all other additional equipment, components, and services necessary to install a fully functional BESS.

- Design, fabricate, procure, ship, assemble, test, startup, commission, warrant and make ready for service a fully functional turnkey BESS and balance of system equipment that meets or exceeds all requirements.
- All required equipment / materials labor and tools required to install, test, and commission the BESS
- Design, install and make ready for the electrical connection from the BESS to the AC point of connection as determined by the owner. Vendor is responsible for the low voltage AC connections, cable, and protection, back to BESS
- Design install and test a Human Machine Interface (HMI) onsite.
- Provide on-site training classes for (ORG) operators, engineers, technicians and maintenance personnel
- Supply any special equipment and tools required for the operation and maintenance of the project
- Supply an initial complement of spare parts
- Provide at minimum a five-year warranty for all BESS components, and a separate cost breakdown for additional years
- Submit for (ORG) review and comment all design drawings, O&M manuals, and miscellaneous documentation required to provide a complete installation. Provide all as-built documentation including calculations, software, design drawings, equipment drawings required for the BESS

- Provide and maintain a Schedule for all design, fabrication, procurement, installation and testing activities for the project

## Documentation Deliverables

The Contractor shall furnish complete documentation that will be used for determination of contract compliance, as well as, operation and maintenance of the BESS. The documentation shall be in English, well detailed and instructive.

At a minimum, the Contractor's documentation shall consist of the following:

- Conceptual design package for (ORG) review
- Stability and system integration study for the microgrid application
- ESS performance specifications and application-specific specification/operation
- Complete design package, BOM and calculations for (ORG) review
- Complete design package, BOM and calculations issued for construction
- Network diagram of the BESS system
- Complete commissioning plan including test and startup procedures for (ORG) review
- Complete set of as built drawings post construction
- Complete set of test results package for record
- Statement of completion
- Installation manuals, instruction manuals and operation guides for all equipment and subsystems. Specific instruction manuals for operation of the BESS controller are required.
- Other project documentation that would reasonably be required for (ORG) to document the construction of the BESS and operate the BESS in the future.
- BESS Control and protective settings
- Maintenance Schedule
- Project Schedule
- Software Documentation
- As-built drawing and documentation upon final Project acceptance

All documentation shall be provided in:

- Paper hard copy (two copies)
- PDF format, all documents are to be provided in PDF format
- Native file format when applicable, in addition to PDF format documents shall be provided in native file format. Drawing shall be provided in AutoCAD format. Documents that were created in Word or Excel, etc. shall also be provided in those formats in addition to PDF.

## Design Conditions

- Design Temperature Range: (insert appropriate temperature range depending on location of the ESS – inside or outside)
- Peak Wind Gust: (insert appropriate depending on location of the ESS – inside or outside)
- Seismic Zone: (insert relevant)

## Electrical Design Parameters

- Nominal voltage at (location) = (insert voltage at the building)
- Normal frequency = 60 Hz with normal deviation of +/- 0.2 Hz
- Frequency design tolerance = 59.0Hz – 61.0Hz

## Audible Noise

The maximum sound level generated from the BESS system and any associated equipment supplied by the BESS vendor under any output level within the BESS operating range, shall be limited to 65 dBA at 50 feet in any direction.

## BESS Requirements

- (Power) / capable of operating at nameplate rating for (hours) hours. The system must maintain this capability over the expected lifetime (identified in the vendor's proposal)
- Full power discharge, for (insert specific requirements)
- 50% maximum output power, for (insert specific requirements)
- Shallow discharge, 70% power for (insert specific requirements)
- BESS Efficiency –
  - o Minimum 90% AC round trip for Li-Ion and Lead Acid technologies
  - o Minimum 70% AC round trip for flow battery technology
- THD < 5% as per inverter spec 519.
- Ambient temperature range (insert appropriate temperature range, may not be necessary to include if batteries are installed inside).
  - o It is the responsibility of the BESS vendor to design all components to operate at safe rated sustainable operating temperatures over the required ambient temperature range.
- Monitoring requirements to include Voltage, Current, Power, PF. Data Acquisition System shall have (30/60/90) days on site data storage and capability to be remotely accessed and data downloaded.
- Data Acquisition / Monitoring / Alarms

The Data Acquisition/monitoring/alarm system or procedures shall have a minimum of the following capabilities

- o Alert (ORG), when the number of failed or inadequately performing cells or other vendor determined conditions indicate that;
  - Preventative maintenance should be performed to keep the BESS at the specified performance levels.
  - The BESS is in imminent danger of failing to meet specified performance levels or potential safety hazards exist.
  - The BESS can no longer meet the specified performance criteria or safety hazards exist.
  - The BESS vendor shall have the capability to remotely monitor the BESS and independently and be automatically alerted to BESS alarm conditions without relying on (ORG) personnel to communicate that such alarm conditions exist.
  - The BESS vendor shall have the capability to respond to alarm conditions and provide required service to correct such alarm

#### Chapter 4. Storage Systems Procurement Installation

conditions within four hours from the inception of the alarm condition.

- The vendor shall include, in the Operation and Maintenance Manual, the recommended corrective action and maintenance procedures for each alarm level or observed condition provided.
- Monitor Points shall include but not be limited to: AC – Voltage, Current, Power factor, KW, KVA, KVAR; DC – DC voltage and current. Points of monitoring TBD during design. Also, system temperature shall be monitored at a minimum of 2 points
  - System should have the ability to remotely access and monitor the data as well as have a 30-day on-site memory storage capacity.
  - Data points shall have the ability be recorded at a minimum of 1 minute, with the capability for instantaneous collection of data when data is outside of set parameters.
- Meet the existing (ORG) Cyber security Requirements
- The BESS control system shall be designed to provide for automatic, unattended operation of the BESS. However, the control system design shall also provide for local manual operation or remote operation.

### **Modes of Operation**

#### Microgrid - Resiliency for Emergency Conditions

In the event of an extended grid outage due to a natural disaster, the BESS shall be used to power the emergency panel of the critical load circuit.

(add specific requirements – see example below)

The BESS shall be designed to provide backup power to a set of critical loads. The BESS contractor shall include the creation of a critical power circuit, including re-wiring of the critical loads and installation of critical power switchgear, in the scope of work.

List of Critical Loads: TBD, following are some examples

- Water booster pump station
- 1x Elevator
- Fire Alarm
- Hallway and stairwell lighting
- 1<sup>st</sup> Floor Office and Lobby Lighting
- Boiler room panel

Location of New Critical Power Switchgear: Electric Room.

#### Peak Load Reduction

A promising advantage for (ORG) is the reduction of peak load. One operational mode is to have the energy storage discharge during expected peak load hours. The BESS shall have a method for forecasting the peak load and automatically dispatching the battery or scheduling the charge/discharge in advance.

(add more requirements as needed)

## Harmonics

The BESS must meet the harmonic specifications of IEEE 519.

## Protection Requirements and Balance of System Components (BOS)

The BESS system shall contain protective relaying features, circuit breakers or fuses which self-protect the BESS in the case of internal electrical faults.

BESS vendor shall procure and install BOS components with the following requirements:

- Follow requirements described on three-line diagram.
- Make and Model of BOS components is allowed to be chosen by ESS contractor.
- Provide the functionality described elsewhere in the specification documents.
- DC disconnect switches: UL listed, blade-type, heavy duty fused safety switches on the output of the Battery array in NEMA enclosure rating as required by installation location or may be integrated to the Inverters.
- AC disconnect switches: UL listed, blade-type, heavy duty fused safety switches on the output of Inverter(s) in NEMA enclosure as required by installation location or may be integrated to the Inverter.

## Internet connection

(add specific requirements)

## Labeling

Install signage posted at site, including at least the following but also any signage required by the NEC or other applicable codes:

- Laminated Diagrams including:
  - AC and DC disconnect locations for the system indicated on a site plan.
  - Electrical one-line diagram of system
  - All signage required shall be mounted in appropriate and visible locations
- All equipment shall be appropriately identified with permanent, self-adhesive labels.
  - Each DC disconnect shall be labeled with label material described above for operating DC current (Imp), system operating DC voltage (Vmp), maximum string DC voltage (Voc), and maximum system DC current (Isc).

The ESS interconnection point (as described in Single Line Diagram, attachment #2) shall be labeled as such indicating the system AC voltage, current, and the ESS rating in kW-ac and kWh.

## Grounding

A suitable equipment grounding system shall be designed and installed for the BESS system. This system shall be tied to the (location) grounding system. The grounding system shall provide personnel protection for step and touch potential in accordance with IEEE 80. The system also shall be adequate for the detection and clearing of ground faults within the BESS. The vendor shall determine, design and install the required interconnections between the BESS and (location) grounding systems.

(ORG) shall self-perform the alterations needed to the existing (location) grounding and install the connections from the existing ground grid to the external grounding locations of the BESS. The appropriate external grounding locations for the BESS shall be determined and provided by the BESS vendor.

### **Structural / Foundation Pads / Conduit**

The vendor shall furnish the design for the structural components of the BESS, concrete pads/foundations as required, and conduit required for the complete BESS. All BESS foundations and structures, if required, shall be designed by a qualified registered professional engineer licensed in the state of Massachusetts. All final (Issued for Construction) drawings, specifications and calculations shall be wet-stamped by a Registered Civil/Structural Engineer licensed in the state of Massachusetts. The vendor is responsible for Geotechnical surveying if required.

(ORG) will self-perform the installation of the concrete pad/foundation and buried conduit installation based on the design provided by the BESS vendor.

### **Mounting System**

BESS vendor shall install BESS components per manufacturer requirements:

- a. All components shall be secured to floor or walls.
- b. Include structural load design calculations signed and sealed by a qualified professional engineer licensed in the state of Massachusetts.
- c. All structural components shall be installed in a manner commensurate with attaining a minimum 25-year design life.

### **Spill Containment**

The BESS design shall mitigate against electrolyte spills that are credible for the types of cells used. The design shall include features that contain electrolyte spills (to be emptied by contracted chemical disposal company in the event of a spill) and prevent discharge to surrounding site soils.

### **Personnel Safety**

The BESS shall include eyewash stations in the battery area as applicable. In general, the BESS shall be designed with personnel safety as the top priority.

### **Fire Protection**

The vendor shall design and install a fire protection system that conforms to national and local codes. The fire protection system design and associated alarms shall take into account that the BESS will be unattended at most times. In the event that codes do not exist for the proposed BESS, current industry-accepted best practices shall be employed.

### **Spare Parts and Equipment**

The vendor shall evaluate its design with regard to failure rates, effects and BESS reliability. The vendor shall provide a recommended spare parts list, including prices and availability, as part of his proposal.

## Battery Management System (BMS)

The vendor shall install BMS capable of protecting and monitoring individual battery modules.

## Factory Testing - Battery

The vendor shall test and submit test data for the cells designated for use on this project. At a minimum, the following tests shall be performed.

- Capacities, Amp-hour and Watt-hour
- Ramp rate
- Heat Generated
- Efficiencies
- As applicable, maximum noxious and toxic material release rates
- Application simulations as required by (ORG)

The vendor shall capacity test 100% of the production cells to ensure compliance with design requirements. The vendor may propose optional alternate testing programs that result in a benefit to (ORG). However, the base proposal shall include capacity testing of 100% of the cells. All proposals for alternate testing shall include details of the proposed plan and the cost benefit to (ORG).

The vendor shall include in their proposal, factory witness testing for three (ORG) representatives at the cost of the vendor. (ORG) shall witness performance and modes of operation testing.

## Commissioning - Acceptance and Performance Testing

The vendor shall develop and perform a commissioning program that will include but not be limited to procedures for design verification, operational acceptance testing, Start-up procedures, functional acceptance testing and safety testing. This commissioning program will assure that the BESS will perform as designed and that the system meets the performance criteria specified elsewhere in these specifications. All modes of operation as described in these specifications shall be tested. The vendor shall determine that the BESS is fully operational and suitable for acceptance testing witnessed by (ORG). The vendor shall document all acceptance and performance tests performed. The vendor shall submit documentation, analyses, and a summary in a test report for (ORG)'s records. The commissioning program will be developed by the vendor (approved by (ORG) and shall demonstrate to (ORG) that the BESS is operational and performs as specified. These tests shall include, as a minimum:

- Grounding and electrical resistance testing
- Verification of sensors, metering and alarms
- Verification of all control functions, including automatic, local and remote control
- Verification of performance criteria

## Warranty

Vendor warrants (ORG) that the equipment and materials furnished hereunder and the completed BESS project are fit for the purpose of producing and storing electricity in accordance with the requirements and are free from defects in workmanship and materials. Vendor makes all such warranties for a period of five (5) years after the date of

acceptance of the project by (ORG). In addition vendor shall clearly indicate life expectancy given discharge profiles provided in this RFP.

## **Utility Interconnection and Rates**

(add specific utility interconnection/integration and rate details)

Vendor should coordinate with the (ORG's) Utility Company (name here) and file all forms required for Interconnection between the utility grid and BESS.

Contractor should coordinate with the Utility Company and be able to negotiate the rate that aligns best with BESS' capability to generate savings and/or revenue for (ORG).

Contractor should immediately notify the (ORG) if the proposed BESS design limits the site's capability to switch between utility rates.

## **Modifications**

Modifications to the (ORG) conceptual design may be made. As these changes affect the BESS vendor, they will be communicated and coordinated with the successful BESS vendor. The BESS vendor shall work in cooperation with any (ORG)-hired engineering firm to exchange information as needed so that each party can complete the design of their required scope of work.

## **Additional Requirements**

The project design shall meet all applicable industry standards and codes including but not limited to NEC, NESC, ASCE, IEEE, standard utility practice. In the event specific codes are not available for the BESS, current industry accepted best practices shall be employed.

The BESS vendor's project manager shall be asked to attend bi-weekly phone meetings with (ORG) representatives during certain portions of the design process. The purpose of these meeting is to receive a status report on the progress of the design package and to discuss any open items or requests for information each party may have submitted to the others.

## **PART 4: EXCLUSIONS**

(add specific exclusions below)

## **PART 5: SCHEDULE**

The BESS vendor shall provide a proposed schedule with their proposal. The schedule shall include design, fabrication, delivery, on site construction and testing phases with subtasks as needed. The schedule will be discussed and finalized in conjunction with the Owner's Project Manager (OPM) prior to the final award of this project.

## **PART 6: COST PROPOSAL**

- A. The Energy Storage System (BESS) contract will be paid as a fixed price contract. Travel time to and from the site will not be reimbursed.

- B. Respondent shall complete the attached Exhibit B, Cost Proposal. Clearly indicate each job category and rate on this form. All hourly rates shall meet the prevailing wage schedule that includes overhead and labor burden.
- C. The final total indicated on the cost proposal shall include all costs associated with completing the work, for the staff and manpower projections provided.
- D. The cost proposal is to be placed in a separate sealed envelope bearing the title "Cost Proposal (project title)" and included with the proposal. Respondents shall include cost proposals that as a minimum include the following line items.
  - Energy Storage system equipment itself, designed, delivered, installed, tested and commissioned
  - Maintenance service schedule and cost estimates; service contract terms
  - Extended warranty offering (in addition to 5-year base warranty)
  - Recommended spare parts, including typical replacement schedule
  - Uptime guarantee
  - Training and support for (ORG) operations personnel

Include cost for witness testing as required: "The vendor shall include in their proposal, factory witness testing for three (ORG) representatives **at the cost of the vendor**. (ORG) shall witness performance and modes of operation testing."

## PART 7: SELECTION PROCESS

### General

1. The (municipal committee), the (ORG) Chairman and General Manager in consultation with (consultant name) (the OPM) will form the ("Selection Committee"). They will utilize the SELECTION CRITERIA (see below) to evaluate submissions. The evaluation will be based upon the information submitted and information solicited by the Selection Committee from various sources and references.
2. Interviews will be held for the top three BESS providers.
3. During the evaluation or review process, the Selection Committee reserves the right to request additional information or clarification from any bidder, or to allow corrections of errors or omissions.
4. The Selection Committee shall make a recommendation to the (ORG) Board of Directors. The (ORG) reserves the right to reject any or all proposals and to waive any informalities or irregularities should it deem it to be in the best interest of the (municipality name).
5. All firms or individuals submitting proposals will be notified of the Awarding Authority's final selection.

## PART 8: SELECTION CRITERIA

### Participation Requirements

In order for a bid to be submitted, the BESS vendor must have the following minimum qualifications. Qualifications shall be included in writing as part of the vendor's proposal.

1. BESS vendor has experience successfully installing and integrating battery projects using the same or similar OEM equipment as is being proposed. References for these projects may be contacted.
2. Engineering subcontractors must have 3 years of experience on similar type projects

### Evaluation Criteria

The Selection Committee will consider the following comparative criteria provided as part of each vendor's proposal when ranking the proposals submitted.

1. Microgrid Operation - The BESS proposed must be able to satisfy the economic and critical power requirements as described in this RFP.
2. Financial Stability - The vendor and major equipment subcontractors must be financially stable companies capable of providing long term service of the BESS and meeting warrantee obligations.
3. Technical Feasibility – Points will be awarded by examining a number of factors, including technology, operational, and resource feasibility. Note: There should be adequate and appropriate data to describe the energy storage technology and its intended operation, including the physical storage mechanism, size, operational and maintenance needs of the technology, and warranties. This information should be presented in a clear and orderly fashion to demonstrate that the project is feasible.
4. Total Cost of Ownership - Total cost of ownership (5-years) of the BESS taking into consideration, initial cost, maintenance costs, warranty costs, guarantee costs, spare parts costs, and degradation over time, replacement costs and schedule, efficiencies, and other costs as identified. (Include only if this applies.)
5. Vendor DAS / HMI - Points will be awarded by examining the level of development, functionality and robustness offered by the BESS HMI and the ability for the BESS HMI.
6. Project Plan - Points will be awarded based on the completeness and description of a well thought-out and well-presented project plan tailored to the specific (ORG) project objectives. The proposal shall clearly explain that the BESS meets the (ORG) requirements and, as needed, shall explain how the requirements are met.
7. Previous Project Experience - Points will be awarded based on the amount of successfully implemented previous project experience presented that is of similar size and technology. The experience of the specific project manager and project team / subcontractors proposed will be factored into the evaluation. Feedback from past customers shall be taken into consideration. (ORG) may reach out to references provided by the vendors.
8. Service - Points will be awarded based on the vendor's ability to provide emergency response service in a short amount of time after an issue with the BESS

## Chapter 4. Storage Systems Procurement Installation

is detected. Service organization, infrastructure, location and response time will be taken into consideration.

9. Schedule - Points will be awarded based on the BESS lead time and vendor's ability to meet the (ORG) proposed schedule. Some flexibility may be taken into consideration by (ORG).
10. Interview Performance - The Vendor demonstrates an understanding of the key issues of the (ORG) project and an ability to work with (ORG) in order to successfully complete the project in the best interest of (ORG).

The following weighted evaluation matrix will be used as a tool to compare the responses to this RFP. The total weighted score calculated for each of the proposals will be compared by the selection committee to determine which proposal are classified as "highly advantageous", "advantageous", "not advantageous" or "unacceptable".

#### BESS Proposal Evaluation Matrix

Item #	Gating Criteria Description	Score (0 or 1)		
1	Microgrid Operation	1		
2	Financial Stability	1		
Item #	Evaluated Criteria Description	Assigned Weight	Score (1-10)	Weighted Score
3	Technical Feasibility	20.00%	10	2
4	Total Cost of Ownership	20.00%	10	2
5	Vendor DAS / HMI	10.00%	10	1
6	Project Plan	10.00%	10	1
7	Previous Project Experience	15.00%	10	1.5
8	Service	15.00%	10	1
9	Schedule	5.00%	10	0.5
10	Interview Performance	5.00%	10	1
	Total	100.00%	80	10

## PART 9: GENERAL PROVISIONS

### General

1. The Awarding Authority reserves the right to reject any and all proposals and to waive any informalities or irregularities as it deems in the best interest of the (municipality name).
2. All submittals, materials, drawings, plans, etc., submitted for consideration shall be considered public information unless clearly marked as PROPRIETARY by the responder.
3. The selected responder, and any sub-consultants of the selected responder, shall be expected to comply with all federal, state, and local rules, regulations, and laws applicable to the project(s) without limitation including all federal, state, and local bidding, environmental, building and safety rules, regulations, and laws in the performance of services.
4. The consideration of all submittals and the subsequent selection of the successful responder shall be made without regard to race, color, sex, age, handicap, religion, political affiliation or national origin.
5. The selected responder, and all sub-consultants of the successful respondent, shall adhere to the provisions of the Fair Employment Practices Law of the Commonwealth (Chapter 151B of the Massachusetts General Laws).
6. The successful responder, and all sub-consultants of the successful responder, shall assure the Awarding Authority that it will carry out the performance of services in full compliance with all requirements imposed by or pursuant to Title VI of the Civil Rights Act of 1964 (78 Stat.252), and any executive orders of the Governor of the Commonwealth as such may from time to time be amended.
7. The provisions related to non-discrimination and affirmative action in employment shall flow through all contracts and subcontracts that the successful responder may receive or award as a result of this contract on behalf of the Awarding Authority.

## PART 10: SUBMISSION REQUIREMENTS

### Required Materials

1. Cover letter outlining vendor's contact person including title, telephone, and e-mail address.
2. Names and addresses of all partners, officers, directors and owners, i.e., persons with an ownership interest in the firm of more than five percent.
3. A full listing of all persons to be assigned to the project, including all sub consultants, including the following:
  - a. Individuals' resumes including work performed on all projects of similar scope and scale over the past five (5) years.
  - b. Each Individual's qualifications for the project including a listing of all Massachusetts Registrations by discipline, licenses, or other documentation of qualifications. The skill sets of the engineering team should cover the entire scope of work required.

## Chapter 4. Storage Systems Procurement Installation

- c. The BESS vendor shall state which of these team members are direct employees of the vendor and which are subcontracted or casual resources. It is required that the team presented in the proposal will be the team assigned to the project if the engineering firm is awarded the project unless changes are agreed to by (ORG) in writing.
4. Respondents must demonstrate successful completion of energy storage systems using the same technology proposed. Provide a complete listing of and contact information for all similar projects performed by your firm over the past three (3) years. For each such project, provide a complete project description, including project size, completion date, major equipment vendors used, warranty claims, uptime percentage, as well as client name and contact person, including address, telephone and email addresses. The Awarding Authority reserves the right to contact any client listed for the purpose of obtaining reference information.
5. Evidence that the BESS vendor possess the knowledge and skill to:
  - a. Recommend solutions to problems encountered during the work and direct field changes.
  - b. Provide the Awarding Authority with periodic status reports, as agreed upon by the parties, with respect to the overall status of the work.
6. Completion and signing of Certification attached as Exhibit A.
7. Documentation of financial stability, documentation of bonding capacity, credit references, or other documentation to demonstrate financial solvency of the firm or individual responder.
8. Additional information related to the responder's (and subcontractors', if any) qualifications and experience to perform the work (letters of reference, description of project methods utilized for comparable projects, etc.), and similar supplementary information may be provided.
9. A cost proposal will be submitted in a separate, sealed envelope, clearly marked "(RFP Title)" (*project name*).
10. Provide list of exceptions and clarifications to the technical proposal and commercial terms and conditions, or written verification that no exceptions or clarifications are taken.
11. The BESS vendor shall provide a proposed time schedule with their proposal. The schedule shall include design, fabrication, delivery, on site construction and testing phases with subtasks as needed. The schedule shall include a two-week review duration by (ORG) for each submitted design package. The schedule shall also include the following: "The vendor shall include in their proposal, factory witness testing for three (ORG) representatives at the cost of the vendor. (ORG) shall witness performance and modes of operation testing."
12. This schedule shall be tracked and maintained by the BESS vendor throughout the project.
13. The vendor shall submit with its proposal a list of information that the firm will require from (ORG) at the kickoff of the project in order to be able to proceed with design.
14. Typical degradation curve information for the battery system proposed.
15. If it is recommended by the battery supplier that cells be changed out at regular intervals given a proposed battery replacement schedule, provide battery

replacement costs and a description of escalation factors used to determine actual battery costs at the time of replacement. Provide information on battery replacement procedure, including estimated time to complete replacement.

16. Provide warranty terms and conditions document.
17. Provide recommended spare parts list and prices.
18. Provide a description of all required maintenance activities, including estimated man-hours and frequency of occurrence and cost for each activity. Describe the service contract terms.
19. Provide information on AC/AC round trip efficiencies.
20. Provide information showing the length of time the battery can maintain constant output at demand levels less than rated output.
21. Provide information showing the length of time the battery can maintain rated output at a reduced state of charge.
22. Provide information on guaranteed life expectancy to maintain rated capacity as number of discharges or total energy delivered varies.
23. Provide information on the controlling parameters that determine life expectancy for the proposed system.
24. Provide information on required environmental conditions or maintenance procedures (if any) that performance guarantees are based on.
25. Provide Power Conversion System (PCS) manufacturer specifications.
26. Provide information on how the charging cycle changes as maximum demand is reduced.
27. Provide information on the state of charge of the battery as a function of time during the charge cycle.
28. Provide proposed factory and commissioning plans to include performance and "Modes of Operation" testing.
29. Provide a performance curve indicating # of cycles vs. depth of discharge.
30. Provide a description of the BESS vendor's remote alarm monitoring capabilities and service dispatch capability including estimated response time to (municipality name) after automatically receiving an alarm.

## PART 11: ATTACHED DOCUMENTS

1. Exhibit A Certification
2. Exhibit B Proposal Financial Worksheet
3. Exhibit C Certificate of Authority
4. Exhibit D Tax Compliance Certification
5. One Line diagram ((ORG) Conceptual design for RFP)
6. One Line relaying and metering diagram ((ORG) Conceptual design for RFP)
7. Electrical Arrangement Plan

## Exhibit A Certification

The applicant hereby certifies that:

1. The applicant has not given, offered, or agreed to give any gift, contribution, or offer of employment as an inducement for, or in connection with, the award of contract for these services.
2. No consultant to, or subcontractor for, the applicant has given, offered, or agreed to give any gift, contribution, or, offer of employment to the applicant, or, to any other person, corporation, or entity as an inducement for, or, in connection with, the award of the consultant or subcontractor of a contract by the applicant.
3. No person, corporation, or, other entity, other than a bona fide full-time employee to the applicant has been retained or hired to solicit for or in any way assist the applicant in obtaining the contract for services upon an agreement or understanding that such person, corporation, or entity be paid a fee or other compensation contingent upon the award of the contract to the applicant.

I hereby attest with full knowledge of the penalties for perjury, as in accordance with Massachusetts G.L.c.7,§ 38E, that all information provided in this application for services is correct.

---

Firm

---

Signed (Typed)

---

Signed (Written)

---

Title

---

Date

## **Exhibit B Cost Proposal Worksheet**

The vendor is to fill out and return the separate Exhibit B – Proposal Financial Worksheet as part of the cost proposal. Exhibit B is to be provided in hard copy and MS excel format. It is expected that not all line items will be required for this project by all vendors. It is acceptable and expected to have \$0 cost line items. A \$0 cost line item does not equal a formal exception taken of a requirement of this RFP. All exceptions must still be listed in an exception section.

[Add remaining attachments as applicable]

# UTILITY SCALE RFP TEMPLATE

## Request for Proposals Template: Utility Scale

---

[Title and Solicitation Number]

(Organization)  
for The Town of (municipality),  
Community Clean Energy Resiliency Initiative  
Request for Proposals

Release Date: \_\_\_\_\_, 2016

Due Date: \_\_\_\_\_, 2016

**(ORGANIZATION) FOR THE (MUNICIPALITY)**  
**REQUEST FOR PROPOSALS – ENERGY STORAGE SYSTEM**  
**FOR THE COMMUNITY CLEAN ENERGY RESILIENCY INITIATIVE**

**[Title and Solicitation Number]**

**Table of Contents**

PART 1: INTRODUCTION .....	146
A: General .....	146
PART 2: GENERAL .....	148
Background .....	148
Project Description .....	148
Proposal Process and Schedule .....	148
PART 3: SCOPE OF WORK / REQUIREMENTS .....	149
Scope of Supply .....	149
Documentation Deliverables .....	150
Design Conditions .....	151
Electrical Design Parameters .....	151
Audible Noise .....	151
BESS Requirements [ALTER TO SUIT PROJECT REQUIREMENTS] .....	151
Modes of Operation .....	153
Microgrid - Resiliency for Emergency Conditions .....	153
Peak Load Reduction .....	153
3MW PV Smoothing .....	153
Automatic Scheduling .....	154
Voltage Regulation .....	154
Harmonics .....	154
Protection Requirements .....	155
SCADA Integration .....	155
Internet connection .....	156
Grounding .....	156
Structural / Foundation Pads / Conduit .....	156
Spill Containment .....	156
Personnel Safety .....	156
Fire Protection .....	156
Spare Parts and Equipment .....	157
Factory Testing - Battery .....	157
Commissioning - Acceptance and Performance Testing .....	157
Warranty .....	157
Interconnection .....	158
Modifications .....	158
Additional Requirements .....	159
PART 4: EXCLUSIONS .....	159

PART 5: SCHEDULE .....	159
PART 6: COST PROPOSAL.....	160
PART 7: SELECTION PROCESS .....	160
General .....	160
PART 8: SELECTION CRITERIA .....	161
Participation Requirements .....	161
Evaluation Criteria .....	161
BESS Proposal Evaluation Matrix.....	162
PART 9: GENERAL PROVISIONS .....	163
General .....	163
PART 10: SUBMISSION REQUIREMENTS .....	163
Required Materials.....	163
PART 11: ATTACHED DOCUMENTS.....	166
Exhibit A Certification.....	166
Exhibit B Cost Proposal Worksheet .....	167

## PART 1: INTRODUCTION

### A: General

(Organization) (ORG), as the Awarding Authority (Known as Owner), invites the submission of proposals by responsible companies (known as Vendor) to design, procure, install, test and commission a minimum (capacity) Battery Energy Storage System (BESS) to be located at the (location). The primary purpose of this Community Clean Energy Resiliency Initiative Project, being performed in part with a grant from the Massachusetts Department of Energy Resources (DOER), is to provide resiliency through the use of energy storage at the (location) using battery technology.

The successful vendor will work with the (ORG), Owner's project Manager (OPM), (Name of the Project Management Firm). Respondents must demonstrate successful completion of energy storage systems using the same technology proposed.

All submissions, to be considered, must be prepared in accordance with the requirements specified in this Request for Proposals document and in accordance with applicable provisions of Massachusetts General Laws.

The cost is to be negotiated with the company having the number one ranked proposal based on their ability to meet or exceed all requirements outlined in the attached selection criteria. Any exceptions to the requirements of this RFP are to be identified on a separate form and clearly marked exceptions. If an agreement cannot be reached with the first choice, the Awarding Authority will negotiate with the next highest ranked firm. The cost for BESS maintenance and the performance degradation over the life of the project will be considered in the selection process. This is a total cost of ownership-based selection process.

The vendor's cost proposal is to be placed in a separate sealed envelope bearing the title "(RFP Title)" and included with the proposal. Bidders shall use the Work Breakdown Structure (WBS) provided in the RFP package. The contract will be awarded to the vendor with the most advantageous and responsive submittal taking into consideration both price and non-price submittals. **Copies of the full RFP documents and required forms are available at the (Building) building and on the (ORG) website.**

Seven (7) hard copies of all Submission Requirements must be submitted to:

(Title)  
(Address)  
(Organization)

Submissions are due on or before \_\_\_\_\_ at \_\_\_\_ pm. Any submission received after this time and date will not be considered and will be returned to the respondent unopened. The clock in the (Municipality) office shall represent the official time for purposes of this determination.

Copies of Submission Forms, and any inquiries regarding the information contained in this Request for Proposals, shall be directed to the General Manager at the address above, by telephone (\_\_\_\_\_) or by email (\_\_\_\_\_\_). **The deadline for written**

**questions will be PM on \_\_\_\_\_. Responses to questions will be posted \_\_\_\_\_.**

Interested parties are responsible for checking the website for addenda and responses to questions.

The (Organization) reserves the right to waive any informality in the submissions, to reject any or all submissions, or to accept any submission which it deems to be in the best interest of the (municipality name).

Interested parties are instructed to check the (ORG) website for addenda to this RFP. Submissions are to be sealed and properly identified on the outer envelope as "(RFP Title)" (Project Name). Price proposals are to be in a separate sealed envelope, appropriately identified, i.e., two separate envelopes for each proposal.

(Name)  
(Title)  
(Organization)  
(Date)

## PART 2: GENERAL

### Background

(add project background and description of proposed sites for Behind-the-Meter battery storage systems)

### Project Description

In December 2014 the (Organization) was awarded a grant by the Massachusetts Department of Energy Resources (DOER) Renewable and Alternative Energy Division for a project proposed in our Community Clean Energy Resiliency Initiative grant application, namely, (give name of the project). This project looks to provide energy storage for the (Location) using battery technology. The (ORG)'s forward thinking approach is looking for ways to expand their investment into renewable energy technology solutions.

(Organization) intends to install a utility scale Battery Energy Storage System (BESS) to support its distribution system in the event of an extended grid outage due to a natural disaster. (add description of existing facilities).

The BESS shall be sized for a minimum (Power) capable of operating for (hours) hours at nameplate rating. (add specific requirements)

### Proposal Process and Schedule

(Organization) is requesting proposals from qualified Battery Energy Storage System (BESS) vendors to design, procure, install, test and commission an Energy Storage System to meet the requirements as described in this request for proposals document for the (project name) as a turnkey system. Add here whether the Vendor will be expected to operate the system over X (5?) years, or to turn over operation to the utility following commissioning.

(ORG) will select a short list of three vendors. Interviews will then be held between (ORG) and the vendors selected to discuss the details of the vendor's proposal and to clarify the intent of the requirements. If required, the vendors may submit a revised proposal including clarifications. (ORG) will then select a vendor and enter into contract negotiations.

The desired schedule for the BESS project is shown in the below table. Reasonable alternate schedules proposed by the BESS vendor will be considered:

RFP issued	(date)
Site Visit	(date, time and place)
Questions Due	(date)
Responses to Questions Posted	(date)
Bids Due	(date)
Shortlist selected and interviews conducted	(date)
Contract awarded	(date)
BESS startup	(date)
BESS accepted	(date)

## PART 3: SCOPE OF WORK / REQUIREMENTS

The purpose of this scope of work section is to provide qualified bidders with more detail on the description of the project, explanation of how it will be managed and to clarify what deliverables are to be provided by the successful BESS vendor.

### Scope of Supply

The scope of supply for the BESS shall include the following principal elements. The vendor shall be responsible for identifying and providing any and all other additional equipment, components, and services necessary to install a fully functional BESS.

- Design, fabricate, procure, ship, assemble, test, startup, commission, warrant and make ready for service a fully functional turnkey BESS and balance of plant equipment that meets or exceeds all requirements delineated herein up to the BESS step-up transformer and SCADA interface. Step-up transformer and SCADA backbone will be provided by (ORG) and the connection will be completed by Vendor.
- All required equipment / materials labor and tools required to install, test, and commission the BESS
- Design, install and make ready for the electrical connection from the BESS to the AC point of connection as determined by the owner. Vendor is responsible for the low voltage AC connections, cable, and protection, back to BESS
- Design, install and make ready for the communication connection from the BESS to the (location) and (ORG) network switch located in the (location).
- Design install and test a Human Machine Interface (HMI) at the (ORG) offices which is remotely connected to the BESS over the (ORG) network that is currently extended to the (location) over fiber optic cable
- Provide on-site training classes for (ORG) operators, engineers, technicians and maintenance personnel
- Supply any special equipment and tools required for the operation and maintenance of the project

#### Chapter 4. Storage Systems Procurement Installation

- Supply an initial complement of spare parts
- Provide at minimum a five-year warranty for all BESS components, and a separate cost breakdown for additional years
- Submit for (ORG) review and comment all design drawings, O&M manuals, and miscellaneous documentation required to provide a complete installation. Provide all as-built documentation including calculations, software, design drawings, equipment drawings required for the BESS
- Provide and maintain a Schedule for all design, fabrication, procurement, installation and testing activities for the project

#### Documentation Deliverables

The vendor shall furnish complete documentation that will be used for determination of contract compliance, as well as operation and maintenance of the BESS. The documentation shall be in English, well detailed and instructive.

At a minimum, Contractor's documentation shall consist of the following:

- Conceptual design package for (ORG) review
- Stability and system integration study for the application
- ESS performance specifications and application-specific specification/operation
- Complete design package, BOM and calculations for (ORG) review
- Complete design package, BOM and calculations issued for construction
- Network diagram of the BESS system and SCADA points list
- Complete commissioning plan including test and startup procedures for (ORG) review
- Complete set of as built drawings post construction
- Complete set of test results package for record
- Statement of completion
- Installation manuals, instruction manuals and operation guides for all equipment and subsystems. Specific instruction manuals for operation of the BESS controller are required.
- Other project documentation that would reasonably be required for (ORG) to document the construction of the BESS and operate the BESS in the future.
- BESS Control and protective settings
- Maintenance Schedule
- Project Schedule
- Software Documentation
- As-built drawing and documentation upon final Project acceptance

All documentation shall be provided in:

- Paper hard copy (two copies)
- PDF format, all documents are to be provided in PDF format
- Native file format when applicable: In addition to PDF format documents shall be provided in native file format. Drawing shall be provided in AutoCAD format.

Documents that were created in Word or Excel, etc. shall also be provided in those formats in addition to PDF.

## Design Conditions

- Design Temperature Range: min -30 F, max 110 F
- Peak Wind Gust: 110 mph
- Seismic Zone: (insert appropriate)

## Electrical Design Parameters

- Nominal voltage at (location) = 13.8 kV (1.0 pu)
- Normal sustained voltage at (location) = 0.9 pu (min) and 1.1 pu (max)
- Normal frequency = 60 Hz with normal deviation of +/- 0.2 Hz
- Frequency design tolerance = 59.0Hz – 61.0Hz

## Audible Noise

The maximum sound level generated from the BESS system and any associated equipment supplied by the BESS vendor under any output level within the BESS operating range, shall be limited to 65 dBA at 50 feet in any direction from the substation fence.

## BESS Requirements *[ALTER TO SUIT PROJECT REQUIREMENTS]*

- (Power) / capable of operating at nameplate rating for \_ hours, base bid. The system must maintain this capability over the expected lifetime (identified in the vendor's proposal)
- Full power discharge, for 1.5hrs, 2 times / day, 2 days /week
- 50% maximum output power, for 2 hours, 2 times / day, 2 days/ week, 14 weeks/year
- Shallow discharge, 70% power for 2 minutes, 50 times/day
- PV and net load smoothing, partial state of charge, multiple hours per day
- BESS Efficiency –
  - o Minimum 90% AC round trip for Li-Ion and Lead Acid technologies
  - o Minimum 70% AC round trip for flow battery technology
- THD < 5% as per inverter spec 519.
- Ambient temperature range -30 degree F to 110 degree F.
  - o It is the responsibility of the BESS vendor to design all components to operate at safe rated sustainable operating temperatures over the required ambient temperature range.
- Monitoring requirements to include Voltage, Current, Power, PF. Data Acquisition System shall have 30 days on site data storage and capability to be remotely accessed and data downloaded.
- Data Acquisition / Monitoring / Alarms

The Data Acquisition/monitoring/alarm system or procedures shall have a minimum of the following capabilities

- o Alert (ORG), via SCADA, when the number of failed or inadequately performing cells or other vendor determined conditions indicate that;

Chapter 4. Storage Systems Procurement Installation

- Preventative maintenance should be performed to keep the BESS at the specified performance levels.
- The BESS is in imminent danger of failing to meet specified performance levels or potential safety hazards exist.
- The BESS can no longer meet the specified performance criteria or safety hazards exist.
- The BESS vendor shall have the capability to remotely monitor the BESS and independently and automatically be alerted to BESS alarm conditions without relying on (ORG) personnel to communicate such an alarm condition exists. The BESS vendor shall have the capability to respond to alarm conditions and provide required service to correct such alarm conditions within four hours from the inception of the alarm condition.
- The vendor shall include, in the Operation and Maintenance Manual, the recommended corrective action and maintenance procedures for each alarm level or observed condition provided.
- Monitor Points shall include but not be limited to: AC – Voltage, Current, Power factor, KW, KVA, KVAR. DC – DC voltage and current. Points of monitoring TBD during design. Also, System temperature shall be monitored at a minimum of 4 points
  - System should have the ability to remotely access and monitor the data as well as have a 30-day on-site memory storage capacity.
  - Data points shall have the ability be recorded at a minimum of 1 minute, with the capability for instantaneous collection of data when data is outside of set parameters.
- Meet the existing (ORG) Cyber security Requirements, Virtual access to the BESS by the BESS vendor will be provided by (ORG) via a virtual private network (VPN) connection.
- The ramp rate of charging and discharging of the BESS shall be programmable or set to a defined value by manually entering a value into the BESS HMI or by the (ORG) SCADA system communicating a ramp rate set point.
- The BESS control system shall be designed to provide for automatic, unattended operation of the BESS. However, the control system design also shall provide for local manual operation, remote operation, or dispatch of the BESS from (ORG)'s SCADA system or remote access point. All modes of operation and its operational set-point functionality shall be remotely adjustable from the (ORG) offices to allow change in settings and to turn on/off all controls or modes when appropriate.

## Modes of Operation

### Microgrid - Resiliency for Emergency Conditions

In the event of an extended grid outage due to a natural disaster the BESS shall be used to power the local emergency response facilities. (add specific requirements)


### Peak Load Reduction

A promising advantage for (ORG) is the reduction of peak load, which is used to calculate transmission and capacity payments to ISO-NE. The monthly peak load is used to calculate payments for using the pool transmission facilities (Regional Network Service – RNS payment). The annual peak load is used to calculate the forward capacity payment. One operational mode is to have the energy storage discharge during expected peak load hours. The BESS shall have a method for scheduling the charge/discharge hours in advance, as well as a method to quickly be commanded into full discharge mode.

(add more requirements as needed – see examples below)

### 3MW PV Smoothing

The BESS shall manage (smooth) output of the 3MW PV array. The overall net power import or export of the mutually coupled BESS and 3 MW PV array shall not adversely affect (ORG) system stability, reliability, or operational activities. Operation in this mode will be automatically initiated by detection of active power flow from 3 MW PV array. The input to the control algorithm shall be a maximum acceptable ramp rate from the PV system. The BESS shall automatically charge and discharge so that the net ramp rate of change in power consumption from the connected utility does not exceed a programmable ramp rate. Examples of typical summer variability are found in Figure 70.

**Figure 70. Typical summer PV variability**

### Automatic Scheduling

In order to take advantage of the fast response time possible with the BESS, (ORG) desires the BESS to be capable of ramping to a predetermined output level as set by a remote signal from (ORG)'s SCADA system or by entering a ramp rate into the BESS HMI. The ramp rate and output level shall be selectable and the output level shall be programmable, on a continuous real time basis, by the remote signal from (ORG)'s SCADA system. Once initiated in this operating mode, the BESS shall remain at the designated output until terminated by a remote signal or the vendor specified discharge limit is reached.

### Voltage Regulation

The BESS will be required to provide VAR support for voltage regulation at the Chocksett substation 13.8kV bus under steady state operating conditions. The BESS voltage regulator controls shall include a selectable set point, via SCADA, on the Chocksett 13.8 kV distribution bus. BESS capacity for VAR support shall be a lower priority than all other described operating modes. The VAR output of the BESS may be limited based on remaining capacity used for real power output.

### Harmonics

The BESS must meet the harmonic specifications of IEEE 519.

## Protection Requirements

The BESS system shall contain protective relaying features, circuit breakers or fuses which self-protect the BESS in the case of internal electrical faults.

## SCADA Integration

The vendor's SCADA design and BESS control system interface shall be integrated with (ORG)'s existing SCADA system and associated RTU/substation communication network. The interface point will be to an (data hub name) and a (ORG) network switch located in the (location) control house. Existing hardware is available and useful, depending on final design, for interfacing to the new BESS control system into (ORG)'s SCADA system.

The engineering tasks shall include, but not be limited to, the following:

- Communication between BESS and data concentrator will be RS-485/Serial. Depending on final design (e.g., amount of monitored devices, equipment layout, distance, etc.), other communication methods may be recommended for approval that will provide the most efficient, reliable, and secure communication network. All signal/communication cable to be shielded to ensure signal integrity.
- DNP3 protocol to be utilized for all communications between BESS control system interface and data concentrator.
- DNP3 map of all I/O points and controls on local BESS control system HMI interface must be available and inclusive to SCADA system for monitoring and control.
- Additional and identifiable points or controls, if not provided initially through BESS control system interface base offering, must be programmed into interface for serial link communications (e.g., but not limited to, fire system activation & integrity, BESS building entry, breaker status).
- A provided SCADA points list shall be prepared by the vendor and submitted to (ORG) for review and approval.
- BESS control system interface will have the ability to accept AGC control setpoint signals from SCADA master station via data concentrator.
- Vendor shall facilitate and ensure all BESS sensor calibrations and system testing to (ORG) SCADA.
- Provide monitoring access and control access to all proposed BESS modes of operation, state of charge, available duration at various output levels, kW/kVar setpoints, kW/kVar flow, local/remote control, misc BESS alarms/status.
- Work items shall include all labor, materials, test equipment, & engineering required to complete SCADA communication integration.
- The vendor shall prepare plan and section drawings for the SCADA/data concentrator integration showing the location of all equipment.
- The vendor shall provide complete testing procedures for the BESS equipment and control system and provide commissioning of the data concentrator/SCADA integration. The prepared testing procedures shall be submitted to (ORG) for review and approval before any testing work is done. A final report detailing the work completed, all test forms, and any marked-up drawings shall be submitted to (ORG).

- (ORG) to provide conduit and communication cabling from data concentrator to BESS Control.)

### **Internet connection**

(add specific requirements)

### **Grounding**

A suitable equipment grounding system shall be designed and installed for the BESS system. This system shall be tied to the (location) Substation grounding system. The grounding system shall provide personnel protection for step and touch potential in accordance with IEEE 80. The system also shall be adequate for the detection and clearing of ground faults within the BESS. The vendor shall determine, design and install the required interconnections between the BESS and (location)substation grounding systems.

(ORG) shall self-perform the alterations needed to the existing (location) Substation grounding grid and install the connections from the existing ground grid to the external grounding locations of the BESS. The appropriate external grounding locations for the BESS shall be determined and provided by the BESS vendor.

### **Structural / Foundation Pads / Conduit**

The vendor shall furnish the design for the structural components of the BESS, concrete pads/foundations as required, and buried conduit required for the complete BESS. All BESS foundations and structures, if required, shall be designed by a qualified registered professional engineer licensed in the state of Massachusetts. All final (Issued for Construction) drawings, specifications and calculations shall be wet-stamped by a Registered Civil/Structural Engineer licensed in the state of Massachusetts. The vendor is responsible for Geotechnical surveying if required.

(ORG) will self-perform the installation of the concrete pad/foundation and buried conduit installation based on the design provided by the BESS vendor.

### **Spill Containment**

The BESS design shall mitigate against electrolyte spills that are credible for the types of cells used. The design shall include features that contain electrolyte spills (to be emptied by contracted chemical disposal company in the event of a spill) and prevent discharge to surrounding site soils.

### **Personnel Safety**

The BESS shall include eyewash stations in the battery area as applicable. In general, the BESS shall be designed with personnel safety as the top priority.

### **Fire Protection**

The vendor shall design and install a fire protection system that conforms to national and local codes. The fire protection system design and associated alarms shall take into account that the BESS will be unattended at most times. In the event codes do not exists for the proposed BESS, current industry accepted best practices shall be employed.

## Spare Parts and Equipment

The vendor shall evaluate its design with regard to failure rates, effects and BESS reliability. The vendor shall provide a recommended spare parts list, including prices and availability, as part of his proposal.

## Factory Testing - Battery

The vendor shall test and submit test data for the cells designated for use on this project. At a minimum, the following tests shall be performed.

- Capacities, Amp-hour and Watt-hour
- Ramp rate
- Heat Generated
- Efficiencies
- As applicable, maximum noxious and toxic material release rates
- Application simulations as required by (ORG)

The vendor shall capacity test 100% of the production cells to ensure compliance with design requirements. The vendor may propose optional alternate testing programs that result in a benefit to (ORG). However, the base proposal shall include capacity testing of 100% of the cells. All proposals for alternate testing shall include details of the proposed plan and the cost benefit to (ORG).

The vendor shall include in their proposal factory witness testing for three (ORG) representatives at the cost of the vendor. (ORG) shall witness performance and modes of operation testing.

## Commissioning - Acceptance and Performance Testing

The vendor shall develop and perform a commissioning program that will include, but not be limited to, procedures for design verification, operational acceptance testing, Start-up procedures, functional acceptance testing and safety testing. This commissioning program will assure that the BESS will perform as designed and that the system meets the performance criteria specified elsewhere in these specifications. All modes of operation as described in these specifications shall be tested. The vendor shall determine that the BESS is fully operational and suitable for acceptance testing witnessed by (ORG). The vendor shall document all acceptance and performance tests performed. The vendor shall submit documentation, analyses, and a summary in a test report for (ORG)'s records. The commissioning program will be developed by the vendor (approved by (ORG)) and shall demonstrate to (ORG) that the BESS is operational and performs as specified. These tests shall include, as a minimum:

- Verification of sensors, metering and alarms
- Verification of all control functions, including automatic, local and remote control
- Verification of performance criteria

## Warranty

Vendor warrants (ORG) that the equipment and materials furnished hereunder and the completed BESS project are fit for the purpose of producing and storing electricity in accordance with the requirements and are free from defects in workmanship and materials. Vendor makes all such warranties for a period of five (5) years after the date of acceptance of the project by (ORG). In

addition vendor shall clearly indicate life expectancy given discharge profiles provided in this RFP.

## Interconnection

(add specific interconnection/integration details – sample below)

The BESS will be connected to the (ORG) medium voltage distribution system at Substation 13.8kV Bus #2. The (ORG) conceptual design as conceptual for bid purposes only. Please refer to the conceptual single line diagram included as part of the RFP, drawing number 8044-E101.1. The (ORG) substation is a two transformer 115kV / 13.8KV substation supplied by The Utility from two different 115kV lines. The two 13.8kV busses each currently have two medium voltage distribution circuits connected via reclosers. The substation has the ability to connect the two 13.8kV busses via a normally open bus tie recloser if one of the transformers is taken out of service. Transformers are not to be operated in parallel.

(ORG) has separately hired an independent engineering firm to design the substation modifications that will be required to interconnect the BESS to the (ORG) 13.8kV Bus #2. (ORG) will self-perform the installation of all interconnection equipment and materials required between the existing 13.8kV Bus #2 and the low voltage terminals of the step up transformer. The LV terminals of the step-up transformer will be considered the point of electrical demarcation between (ORG) and the BESS vendor for the design and supply of equipment and materials. The BESS vendor is responsible for the installation of the LVAC cables between the step-up transformer and the BESS inverter, the BESS inverter, the DC cable between the BESS inverter and the BESS trailer and a self-contained BESS. The self-contained BESS shall include the battery cells and racking, DC interconnection cabling, an AC service transformer and distribution panels, HVAC systems, energy metering, data historian server, an HMI for energy management control and monitoring / diagnostics and all other materials and equipment needed to provide a fully functional battery system capable of being integrated to the distribution grid.

The design of the foundation pads for the BESS and the buried conduit raceways for LVAC and DC cabling shall be by the BESS vendor. (ORG) will self-perform the installation of the concrete pad/foundation and buried conduit installation based on the design provided by the BESS vendor. (ORG) will self-perform the modifications required to the existing substation ground grid and the connections from the existing ground grid to the grounding points of the BESS.

## Modifications

Modifications to the (ORG) conceptual design may be made. As these changes affect the BESS vendor, they will be communicated and coordinated with the successful BESS vendor. The BESS vendor shall work in cooperation with any (ORG)-hired engineering firm to exchange information as needed so that each party can complete the design of their required scope of work. Specific interface and coordination is expected between the (ORG) SCADA system and the BESS controller and monitoring systems.

## **Additional Requirements**

The project design shall meet all applicable industry standards and codes including but not limited to NEC, NESC, ASCE, IEEE, standard utility practice. In the event specific codes are not available for the BESS, current industry accepted best practices shall be employed.

The BESS vendor shall perform a site visit shortly after the award of the project in order to become familiar with the existing (location) substation. This site meeting will also serve as an opportunity for discussions, clarifications and exploration of any proposed design alternatives. (ORG) management, operations personnel and owner's engineer for the project will be in attendance.

The BESS vendor's project manager shall be required to attend bi-weekly phone meetings with (ORG) representatives during certain portions of the design process. The purpose of these meeting is to receive a status report on the progress of the design package and to discuss any open items or requests for information each party may have submitted to the others.

## **PART 4: EXCLUSIONS**

(add specific exclusions – samples below)

The design package provided by the BESS vendor shall not include the design of the 13.8kV interconnection substation expansion. Design of all equipment upstream from the LVAC cables shall be by a third party engineering firm hired by (ORG).

Site grading design shall not be required as the project is intended to be fully installed in an existing graded substation.

Installation of concrete pad/foundations and buried conduit at the Substation shall not be included. (ORG) will self-perform the installation of the concrete pad/foundation and buried conduit installation based on the design provided by the BESS vendor.

Alterations of the existing substation grounding grid to connect to the external grounding locations of the BESS shall not be included. This work will be self-performed by (ORG).

All exceptions to the specifications and/or deviations shall be clearly and separately itemized. It shall not be necessary for (ORG) to examine the standard literature and documents of vendors to determine the existence and extent of any exceptions and/or deviations from this specification.

## **PART 5: SCHEDULE**

The BESS vendor shall provide a proposed schedule with their proposal. The schedule shall include design, fabrication, delivery, on site construction and testing phases with subtasks as needed. The schedule will be discussed and finalized in conjunction with the OPM prior to the final award of this project.

## PART 6: COST PROPOSAL

- E. The Energy Storage System (BESS) contract will be paid as a fixed price contract. Travel time to and from the site will not be reimbursed.
- F. Respondent shall complete the attached Exhibit B, Cost Proposal. Clearly indicate each job category and rate on this form. All hourly rates shall meet the prevailing wage schedule that includes overhead and labor burden.
- G. The final total indicated on the cost proposal shall include all costs associated with completing the work, for the staff and manpower projections provided.
- H. The price proposal is to be placed in a separate sealed envelope bearing the title "Price Proposal (project title)" and included with the proposal. Respondents shall include price proposals, which at a minimum include the following line items.
  - Energy Storage system equipment itself, designed, delivered, installed, tested and commissioned
  - Maintenance service schedule and cost estimates
  - Extended warranty offering (in addition to 5-year base warranty)
  - Recommended spare parts, including typical replacement schedule
  - Uptime guarantee
  - Training and support for (ORG) operations personnel

## PART 7: SELECTION PROCESS

### General

The (municipal committee), the (ORG) Chairman and General Manager in consultation with (consultant name) (the OPM) will form the ("Selection Committee"), they will utilize the SELECTION CRITERIA (see below) to evaluate submissions. The evaluation will be based upon the information submitted and information solicited by the Selection Committee from various sources and references.

Interviews will be held for the top three BESS providers.

During the evaluation or review process, the Selection Committee reserves the right to request additional information or clarification from any submitter, or to allow corrections of errors or omissions.

The Selection Committee shall make a recommendation to the (ORG) Board of Directors. The (ORG) reserves the right to reject any or all proposals and to waive any informalities or irregularities should it deem it to be in the best interest of the (municipality name).

All firms or individuals submitting proposals will be notified of the Awarding Authority's final selection.

## PART 8: SELECTION CRITERIA

### Participation Requirements

In order for a bid to be submitted the BESS vendor must have the following minimum qualifications. Qualifications shall be included in writing as part of the vendor's proposal.

BESS vendor has experience successfully installing and integrating MW scale battery projects using the same or similar OEM equipment as is being proposed. References for these projects may be contacted.

Engineering subcontractors must have 7 years of design experience on similar type projects  
Contractors proposed to perform work on site must have an EMR rating of 1 or lower

### Evaluation Criteria

The Selection Committee will consider the following comparative criteria provided as part of each vendor's proposal when ranking the proposals submitted.

1. Microgrid Operation - The BESS proposed must be able to act as the reference source in a microgrid system as described in this RFP.
2. Financial Stability - The vendor and major equipment vendors must be financially stable companies capable of providing long term service of the BESS and meeting warranty obligations
3. Technical Feasibility - Points will be awarded by examining a number of factors, including technology, operational, and resource feasibility. Note: There should be adequate and appropriate data to describe the energy storage technology and its intended operation, including the physical storage mechanism, size, operational and maintenance needs of the technology and warranties. This information should be presented in a clear and orderly fashion to demonstrate that the project is feasible.
4. Total Cost of Ownership per MW and per MWhr - Total cost of ownership of the BESS taking into consideration, initial cost, maintenance costs, warranty costs, guarantee costs, spare parts costs, and degradation over time, replacement costs and schedule, efficiencies, and other costs as identified.
5. Vendor DAS / HMI and SCADA - Points will be awarded by examining the level of development, functionality and robustness offered by the BESS HMI and the ability for the BESS HMI and SCADA system to interface with the existing (ORG) network and SCADA system.
6. Project Plan - Points will be awarded based on the completeness and description of a well thought out and well-presented project plan tailored to the specific (ORG) project objectives. The proposal shall clearly explain that the BESS meets the (ORG) requirements and, as needed, shall explain how the requirements are met.
7. Previous Project Experience - Points will be awarded based on the amount of successfully implemented previous project experience presented that is of similar size and technology. The experience of the specific project manager and project team / subcontractors proposed will be factored into the evaluation. Feedback

from past customers shall be taken into consideration. (ORG) may reach out to references provided by the vendors.

8. Service - Points will be awarded based on the vendor's ability to provide emergency response service in a short amount of time after an issue with the BESS is detected. Service organization, infrastructure, location and response time will be taken into consideration.
9. Schedule - Points will be awarded based on the BESS lead time and vendor's ability to meet the (ORG) proposed schedule. Some flexibility may be taken into consideration by (ORG).
10. Interview Performance - The Vendor demonstrates an understanding of the key issues of the (ORG) project and an ability to work with (ORG) in order to successfully complete the project in the best interest of (ORG).

The following weighted evaluation matrix will be used as a tool to compare the responses to this RFP. The total weighted score calculated for each of the proposals will be compared by the selection committee to determine which proposal are classified as “highly advantageous”, “advantageous”, “not advantageous” or “unacceptable”.

**Table 25. BESS Proposal Evaluation Matrix**

**BESS Proposal Evaluation Matrix**

Item #	Gating Criteria Description	Score (0 or 1)		
1	Microgrid Operation	1		
2	Financial Stability	1		
Item #	Evaluated Criteria Description	Assigned Weight	Score (1-10)	Weighted Score
3	Technical Feasibility	20.00%	10	2
4	Total Cost of Ownership per MW and per MWhr	20.00%	10	2
5	Vendor DAS / HMI and SCADA	10.00%	10	1
6	Project Plan	10.00%	10	1
7	Previous Project Experience	15.00%	10	1.5
8	Service	15.00%	10	1
9	Schedule	5.00%	10	0.5
10	Interview Performance	5.00%	10	1
	Total	100.00%	80	10

## PART 9: GENERAL PROVISIONS

### General

1. The Awarding Authority reserves the right to reject any and all proposals and to waive any informalities or irregularities as it deems in the best interest of the (municipality name).
2. All submittals, materials, drawings, plans, etc., submitted for consideration shall be considered public information unless clearly marked as PROPRIETARY by the responder.
3. The selected responder, and any sub-consultants of the selected responder, shall be expected to comply with all federal, state, and local rules, regulations, and laws applicable to the project(s) without limitation including all federal, state, and local bidding, environmental, building and safety rules, regulations, and laws in the performance of services.
4. The consideration of all submittals and the subsequent selection of the successful responder shall be made without regard to race, color, sex, age, handicap, religion, political affiliation or national origin.
5. The selected responder, and all sub-consultants of the successful respondent, shall adhere to the provisions of the Fair Employment Practices Law of the Commonwealth (Chapter 151B of the Massachusetts General Laws).
6. The successful responder, and all sub-consultants of the successful responder, shall assure the Awarding Authority that it will carry out the performance of services in full compliance with all requirements imposed by or pursuant to Title VI of the Civil Rights Act of 1964 (78 Stat.252), and any executive orders of the Governor of the Commonwealth as such may from time to time be amended.
7. The provisions related to non-discrimination and affirmative action in employment shall flow through all contracts and subcontracts that the successful responder may receive or award as a result of this contract on behalf of the Awarding Authority.

## PART 10: SUBMISSION REQUIREMENTS

### Required Materials

1. Cover letter outlining vendor's contact person including title, telephone, and e- mail address.
2. Names and addresses of all partners, officers, directors and owners, i.e., persons with an ownership interest in the firm of more than five percent.
3. A full listing of all persons to be assigned to the project, including all sub consultants, including the following:
  - a. Individuals' resumes including work performed on all projects of similar scope and scale over the past five (5) years.

Chapter 4. Storage Systems Procurement Installation

- b. Each Individual's qualifications for the project including a listing of all Massachusetts Registrations by discipline, licenses, or other documentation of qualifications. The skill sets of the engineering team should cover the entire scope of work required.
  - c. The BESS vendor shall state which of these team members are direct employees of the vendor and which are subcontracted or casual resources. It is required that the team presented in the proposal will be the team assigned to the project if the engineering firm is awarded the project unless changes are agreed to by (ORG) in writing.
4. Respondents must demonstrate successful completion of energy storage systems using the same technology proposed. Provide a complete listing of and contact information for all similar projects performed by your firm over the past five (5) years. For each such project, provide a complete project description, including project size, completion date, major equipment vendors used, warranty claims, uptime percentage, as well as client name and contact person, including address, telephone and email addresses. The Awarding Authority reserves the right to contact any client listed for the purpose of obtaining reference information.
5. Evidence that the BESS vendor possess the knowledge and skill to:
  - a. Recommend solutions to problems encountered during the work and direct field changes.
  - b. Provide the Awarding Authority with periodic status reports, as agreed upon by the parties, with respect to the overall status of the work.
6. Completion and signing of Certification attached as Exhibit A.
7. Documentation of financial stability, documentation of bonding capacity, credit references, or other documentation to demonstrate financial solvency of the firm or individual responder.
8. Additional information related to the responder's (and sub-consultant's, if any) qualifications and experience to perform the work (letters of reference, description of project methods utilized for comparable projects, etc.), and similar supplementary information may be provided.
9. A cost proposal will be submitted in a separate, sealed envelope, clearly marked *Proposals for Energy Storage System for the (project name)*.
10. Provide list of exceptions and clarifications to the technical proposal and commercial terms and conditions, or written verification that no exceptions or clarifications are taken.
11. The BESS vendor shall provide a proposed schedule with their proposal. The schedule shall include design, fabrication, delivery, on site construction and testing phases with subtasks as needed. The schedule shall include a two-week review duration by (ORG) for each submitted design package. This schedule shall be tracked and maintained by the BESS vendor throughout the project.

Chapter 4. Storage Systems Procurement Installation

12. The vendor shall submit with its proposal a list of information that the firm will require from (ORG) at the kickoff of the project in order to be able to proceed with design.
13. Typical degradation curve information for the battery system proposed.
14. If it is recommended by the battery supplier that cells be changed out at regular intervals, provide proposed battery replacement schedule. Provide battery replacement costs and a description of escalation factors used to determine actual battery costs at the time of replacement. Provide information on battery replacement procedure, including estimated time to complete replacement.
15. Provide warranty terms and conditions document
16. Provide recommended spare parts list and prices.
17. Provide a description of all required maintenance activities, including estimated man-hours and frequency of occurrence and cost for each activity.
18. Provide information on AC/AC round trip efficiencies (excluding step-up transformer).
19. Provide information showing the length of time the battery can maintain constant output at demand levels less than rated output.
20. Provide information showing the length of time the battery can maintain rated output at a reduced state of charge.
21. Provide information on guaranteed life expectancy to maintain rated capacity as number of discharges or total energy delivered varies.
22. Provide information on the controlling parameters that determine life expectancy for the proposed system.
23. Provide information on required environmental conditions or maintenance procedures (if any) that performance guarantees are based on.
24. Provide Power Conversion System (PCS) manufacturer specifications.
25. Provide information on how the charging cycle changes as maximum demand is reduced.
26. Provide information on the state of charge of the battery as a function of time during the charge cycle.
27. Provide proposed factory and commissioning plans to include performance and "Modes of Operation" testing.
28. Provide a performance curve indicating # of cycles vs. depth of discharge.
29. Provide a description of the BESS vendor's remote alarm monitoring capabilities and service dispatch capability including estimated response time to (municipality name) after automatically receiving an alarm.

## PART 11: ATTACHED DOCUMENTS

8. Exhibit A Certification
9. Exhibit B Proposal Financial Worksheet
10. Exhibit C Certificate of Authority
11. Exhibit D Tax Compliance Certification
12. One Line diagram ((ORG) Conceptual design for RFP)
13. One Line relaying and metering diagram ((ORG) Conceptual design for RFP)
14. Electrical Arrangement Plan

### Exhibit A Certification

The applicant hereby certifies that:

1. The applicant has not given, offered, or agreed to give any gift, contribution, or offer of employment as an inducement for, or in connection with, the award of contract for these services.
2. No consultant to, or subcontractor for, the applicant has given, offered, or agreed to give any gift, contribution, or, offer of employment to the applicant, or, to any other person, corporation, or entity as an inducement for, or, in connection with, the award of the consultant or subcontractor of a contract by the applicant.
3. No person, corporation, or, other entity, other than a bona fide full-time employee to the applicant has been retained or hired to solicit for or in any way assist the applicant in obtaining the contract for services upon an agreement or understanding that such person, corporation, or entity be paid a fee or other compensation contingent upon the award of the contract to the applicant.

I hereby attest with full knowledge of the penalties for perjury, as in accordance with Massachusetts G.L.c.7,§ 38E, that all information provided in this application for services is correct.

---

Firm

---

Signed (Typed)

Signed (Written)

---

Title

---

Date

## **Exhibit B Cost Proposal Worksheet**

The vendor is to fill out and return the separate Exhibit B – Proposal Financial Worksheet as part of the cost proposal. Exhibit B is to be provided in hard copy and MS excel format. It is expected that not all line items will be required for this project by all vendors. It is acceptable and expected to have \$0 cost line items. A \$0 cost line item does not equal a formal exception taken of a requirement of this RFP. All exceptions must still be listed in an exception section.

[Add remaining attachments as applicable]

## **4.4 Summary**

Chapter 4 provides an overview of procurement options based on approaches used both in the past and for current projects. Topics addressed in this chapter include purchasing options, interconnection and communication, warranty, and disposal issues. Additionally, CESA’s Energy Storage Procurement Matrix in Appendix H shows in detail information the initiator should provide or ask for in the RFP, and questions the bidder should answer in the proposal, and the evaluation criteria that should be addressed in a procurement process.

## **4.5 Extended Technical Discussion**

AEP studied the direct and indirect benefits, strengths, and weaknesses of DESSs and chose to transform its entire utility grid into a system that achieves optimal integration of both central and distributed energy assets. To that end, AEP installed the first NaS battery-based energy storage system in North America. After one year of operation and testing, AEP has concluded that, although the initial costs of DESS are greater than conventional power solutions, the net benefits justify the AEP decision to create a grid of DESS with intelligent monitoring, communications, and control, in order to enable the utility grid of the future. The SAND Report *Installation of the First Distributed Energy Storage System (DESS) at American Electric Power (AEP)* (SAND2007-3580), found in the link below, details the site selection, construction, and benefits of the first installation at Chemical Station in North Charleston, WV, and the lessons learned.

<http://prod.sandia.gov/techlib/access-control.cgi/2007/073580.pdf>



## CHAPTER 5 : THERMAL ENERGY STORAGE – A CASE STUDY

### 5.1 Generation Information

Affordable and effective energy storage is very beneficial to utilities, consumer, and the grid for balancing supply and demand in “real time” and to maintain power grid stability. Grid-interactive Electric Thermal Storage (GETS) is a low-cost and very effective means of providing balancing services (frequency regulation) during the off-peak evening hours and also reducing the contribution of water heaters to daily peak loads. Combining grid-interactive communication and controls with conventional water heaters makes up the GETS system plus electric thermal storage; electric thermal storage (ETS) space heaters can also be used to provide balancing services.

When considering all stakeholders, the universal mission of GETS systems is to be a precise, dependable, predictable, and verifiable “Up” and “Down” dispatchable load. GETS is the integration of intelligent and real-time control signals with water heaters and can include enhanced ETS space.

### 5.2 Approach

The approach is to use the DOE/NRECA Smart Grid Demonstration Grid demonstration project section on Energy Storage – The Benefits of “Behind-the-Meter” Storage *Adding Value with Ancillary Services* as a case study for how thermal energy storage can be used for grid optimization needs.

### 5.3 Data

#### 5.3.1 Background: The DOE NRECA Smart Grid Demonstration Project

The benefits of GETS were evaluated at 10 distributed grid interactive dynamically dispatched hot water heaters by Great River Energy (GRE), a generation and transmission (G&T) electric cooperative in Minnesota. The overall goals were to validate and verify the GETS technology and determine their value in demand reduction and for providing such ancillary services as frequency regulation and spinning reserve to the Midcontinent Independent System Operator (MISO) electricity market. These projects were undertaken through the NRECA Smart Grid Demonstration Project (SGDP) and funded by the DOE under an American Recovery and Reinvestment Act (ARRA) grant, with cost share provided from participating co-ops.

##### 5.3.1.1 Thermal Energy Storage Project

The GETS was an extension of thermal energy storage systems that have been in use for demand-side management (DSM) by GRE. GRE provides wholesale electric service to 28 distribution co-ops in Minnesota and Wisconsin that distribute electricity to more than 650,000 member-consumers—about 1.7 million people. GRE offers more than 3,500 MW of generation capability, consisting of a diverse mix of baseload and peaking power plants, including coal, refuse-derived fuel, natural gas and fuel oil, and wind generation. As part of its DSM program,

more than 70,000 hot water heaters have load management systems (LMSs) installed that will allow hot water heaters to be heated (that is, “charged”) with low-cost off-peak energy from 11 p.m. to 7 a.m.. These hot water heaters generally are not allowed to contribute to the peak load that occurs during the day and early evening—generally between 7 a.m. and 11 p.m..

The purpose of the GETS project was to evaluate using a water heater to dynamically store thermal energy during off-peak hours and offset on-peak charging of hot water heaters, while providing frequency regulation (variation on heating hot water during the off-peak hours) to the MISO wholesale power market. The GETS project successfully deployed a new control technology for the water heaters. The controller for GETS had a fast, Internet Protocol (IP)-based connection back to the head-end system and the ability to vary the charge rate on the water heater between 0 and 100% of the appliances’ maximum demand. Combining the fast connection with the ability to vary the charge rate technically provides a distributed resource capable of providing dynamic dispatch, spinning reserve, and fast frequency regulation during off-peak hours to a wholesale power market such as MISO.

The overall project goals were accomplished:

1. Ten Steffes Water Heater Control (<http://www.steffes.com/offpeak>) with remotely configurable charge rates were deployed in the service territories of the participating member distribution cooperatives.
2. Two-way communication of the water heater controls was tested, evaluated, and proven to be effective.
3. The use of power-line carrier, 700-MHz wireless, and Wi-Fi were tested as possible communication technologies.
4. An economic model was developed for evaluating use of hot water heaters for frequency regulation.

### **5.3.2 Project Implementation and Results – Thermal Energy Storage**

#### **5.3.2.1 Enabling Technology**

Thermal energy storage using hot water heaters is a potentially low-cost and effective method of providing peak shaving, spinning reserve, and balancing services for the electric grid, usually referred to as “frequency regulation service” or just “regulation service.” This service can be provided by “charging up” a water heater (that is, heating water in a domestic water heater) in response either to an ACE or AGC signal from a utility/ISO, or RTO. The utility, ISO, or RTO can request the hot water heater either to charge up (heat the water) from a mid-level charge of 1.5 kW to 3 kW (so as to last for 8 hours, from 11 p.m. to 7 a.m.), or stop the charge up by dropping the electric hot water heater to 0 kW. Thus, the hot water heater can respond to ACE or AGC signals for controlling frequency by providing frequency regulation up (“reg up”) or frequency regulation down (“reg down”), which provides the area balancing services. It can do this for hundreds of thousands of cycles.

In addition, by combining controls and communications with water heaters, the technology can interface with standard load management through the GRE DSM program to provide not only responsive regulation but also spinning reserve and nearly instant “valley filling” building load

## Chapter 4. Storage Systems Procurement Installation

during the off-peak hours. Effectively, hot water heaters can be “dynamically dispatched.” This technology is being developed by the Steffes Corporation to provide regulation service during the off-peak hours of heating water, thus valley filling load exactly to minimize the cost of charging and remove the hot water heater load from the morning or early evening peak hours. Such a configuration could qualify for a capacity credit or demand charge reduction if enough hot water heaters are aggregated (usually ISOs or RTOs need a minimum of 100 kW to 1 MW of aggregated load depending upon the ISO or RTO).

As mentioned previously, the system reliability within MISO or other ISOs/RTOs can be improved further by providing fast frequency response systems like GETS or energy storage, as required by FERC Order 755. The PJM RTO has found that the implementation of performance-based compensation for regulation resources has been successful (PJM RTO report of October 14, 2013, to FERC on analysis of performance-based regulation for frequency regulation). To support this need, the dynamic dispatch of the hot water heaters can provide response as fast as 4 seconds (often obscured by the 20- to 90-second latency time for reporting). PJM noted that fast-responding resources (like thermal energy storage in hot water heaters) can participate in the PJM regulation market when aggregated to provide more than 100 kW of regulation. This will provide the PJM RTO market and other ISOs/RTOs in the future with control over regulation that is the same or better, as measured by NERC Control Performance Standards 1 (CPS1) and Balancing Authority ACE Limit (BAAL) reliability criteria. PJM concluded that paying for performance of fast-response/fast-moving frequency regulation can provide significant benefits, reduce overall frequency regulation costs, and meet synchronous reserve requirements, thus reducing the total cost for providing frequency regulation.

The GETS technology has a dynamic dispatch control system comprising a control panel with embedded microprocessor connected to current transformers and thermocouples in the hot water heater; it also has a high-speed Internet connection that for the demonstration was hard-wired back to the Internet modem and then back to the head-end computer monitoring and control system (which is probably too expensive for full commercial implementation because of the high cost for the labor of hardwiring back to the Internet, so in the future it may be more cost-effective to use Wi-Fi communication). For this project, the water heaters were aggregated in the Microsoft Azure Cloud, and the head-end control system was located at GRE.

GRE configured the GETS units charge during the off-peak hours each night (11 p.m. to 7 a.m.) to charge at an average of 1.5 kW for 8 hours, for a total of 12 kWh. It can oscillate in response to the AGC or ACE signal by reg up from 1.5 KW to 3 kW or reg down from 1.5 kW to zero. The system is flexible enough that if the MISO regulation market clearing price (RMCP) during any hour is projected to be higher at any point during the charging time, the system could swing from 0 to 4.5 KW (maximum charging load) until the tank hits the temperature limits of 170 °F. The time to provide frequency regulation is usually limited to less than 8 hours depending on how long the tank heating element swings from 0 to 4.5 kW rather than from 0 to 3 kW.

During the charging time period, for purposes of this demonstration, GRE communicates an AGC signal to simulate an ACE signal that GRE would receive in the future from MISO (presently, MISO does not recognize pilot efforts or any aggregation of demand response less than 1 MW); this was communicated to GRE’s energy management system and the Steffes Corporation. In the future, the ACE signal would be more volatile than the AGC signal if the

## Chapter 4. Storage Systems Procurement Installation

devices were enrolled in the MISO market to provide fast frequency regulation service but, as will be shown later, that will not be a problem for the Steffes GETS system. Currently, between 7 a.m. and 11 p.m., the units are not allowed to charge or provide regulation service, but they could be configured to allow manual override if the end user needs more hot water during the peak hours than was originally planned.

The advantages of this technology include the following:

1. Balanced and stable electric grid, offering improved reliability.
2. Purchases of power for load serving entities (LSEs) when the MISO Locational Marginal Price (LMP) is low (\$20/MWh or less) during the off-peak time, and avoidance of buying power from MISO when the LMP is high (\$45/MWh) during peak periods.
3. Economic benefits from aggregating water heater controls responding to frequency regulation and obtaining payment for providing the service.
4. Reducing demand for power during the daily peaks.
5. Dynamically dispatching the hot water heaters during the off-peak variable charging periods to minimize the cost to recharge the hot water heater.

### 5.3.2.2 Installation

The project initially planned to install 10 water heater controls. GRE installed 11 devices, 10 of which currently are operational. The one failure was a home that was struck by lightning, which damaged the control unit. The devices were installed in homes in and around Pelican Rapids, MN.

The installation of the controllers was done by licensed electricians. While the installation work can be quick, complications arose with wiring the Ethernet cable to the control device. This was due to the water heaters typically being located in utility rooms, whereas modems are found in home offices or living rooms. Making a physical connection between the modem and the controller often meant drilling through floors or finding other ways to route the cables. Having a wireless connection for the Steffes Corporation GETS controller would have made the installation easier and cheaper. Participating consumers generally were happy with the installation, and later queries revealed that they did not notice any difference in the operation of their hot water heaters.

A key lesson learned from the installations was that identifying locations with reliable Internet connectivity was more challenging than originally thought. It is important to note that a high percentage of GRE customers reside in rural parts of Minnesota.


### 5.3.2.3 Operation

Operation is project-specific. In the systems installed, critical components monitored include the current temperature in the tank; upper, middle, and lower thermocouples; current hot water charge status; and historical consumption in the home. Having temperature information permits a determination of the amount of charging, or heating of water, that still can be provided. The tank temperature is never allowed to exceed 170 °F. There was one hot water heater that had an upper

limit set point of only 120 °F. With the current charging status and control signal, the charging level can be manipulated and its response verified in near-real-time, simulated 4-second ACE data.

Tracking the historical temperature reduction and the time in which the reduction is occurring allowed GRE to determine how much water/kWh is used on a typical weekday or weekend day. Weekend days and weekdays are tracked separately because of their different consumption patterns. This enables a forecast of how much energy can be expected to be put into the hot water heater the following day. GRE may want to offer these resources in the MISO market for regulation in the future. Part of that offer would be providing MISO with the MW that would be supplied in each hour of the following day. Tracking historical consumption for each water heater allows GRE to determine, with a high degree of certainty, the MW of regulation that can be provided from implementation of the GETS into their DSM program for MISO. The application then aggregates these values to provide an energy and capacity value from the GETS and bid frequency regulation, and what would be provided to MISO. In the future, should ISOs/RTOs move to 5-minute-ahead markets like the Southwest Power Pool has done to manage the intermittency of wind (which ERCOT and NERC are evaluating), the dynamic dispatch of the GETS could become even more valuable.

A typical example of a GETS system is on display at the PJM RTO headquarters, as shown in Figure 71.



**Figure 71. Typical Example of a GETS System Integrated with a 105-Gallon Marathon Hot Water Heater, on display at the PJM RTO (courtesy of Steffes Corporation)**

#### 5.3.2.4 Data Collection

Data are collected through a system developed by Steffes (Figure 72).




**Figure 72. Steffes Data on Temperature, Power, and Energy for an Individual Water Heater**

Figure 72 shows the temperature of the top of the hot water heater in green (note that the temperature reaches a peak at about 170 °F), the middle of the hot water heater in red, and the bottom of the hot water heater in blue. The yellow-gold line shows the total cumulative state of charge of the hot water heater. The x-axis time is in Universal Coordinated Time (UTC) time, which currently is 6 or 7 hours ahead of the Central time zone applicable in Minnesota (depending on standard or daylight savings time). The graph is a 2-day plot, with the blue and gold lines on the bottom corresponding to the simulated ACE signal and the response of the GETS system heating element oscillating around 4 a.m. to 12 p.m. UTC or 11 p.m. to 7 a.m. Central time.

The change in the kW output appears to be close to synchronous and coincident with the ACE signal shown in this graph. Thus, the GETS system will qualify as a fast-response frequency response provider in accordance with FERC Regulation 755 (Frequency Regulation Compensation Organized Wholesale Power Markets). The final FERC Order 755 requires RTOs and ISOs to compensate frequency regulation resources based on the actual service provided, including a capacity payment that includes the marginal unit's opportunity costs and a payment for performance that reflects the quantity of frequency regulation service provided by a resource when that resource is following the dispatch signal accurately and quickly.

Initially, the plan by GRE and Steffes Corporation was to charge the hot water heaters at a 1.5-kW average heat-up during off-peak periods and swing up to 3 kW or down to 0 kW to respond

to an ACE signal. However, as shown in Figure 72 (the blue line) and Figure 73, the Steffes Corporation strategy is to dynamically dispatch and charge using a valley-filling input strategy.



**Figure 73. Steffes Corporation Valley-Filling Input Strategy (x-axis is time of day and y-axis is kW)**


Steffes uses a valley-filling input strategy while simultaneously doing up and down fast regulation as needed for the aggregated 10 hot water heaters in the demonstration (as shown in Figure 73). Basically, the strategy is to begin slowly charging the hot water heater at 11 p.m. when the loads and the MISO LMP are still high (see Figure 76 on LMP for MISO—\$25/MWh at 11 p.m.) and then increase the average charge rate to 2 kW or more per hot water heater at 3 a.m., when the loads and the LMP are lowest (\$20/MWh) (shown as the red bars in Figure 73). This demonstrates valley filling of the off-peak loads and LMP. The average energy output profile is represented by the blue bars in Figure 73; the cumulative energy stored as thermal energy is shown in green and by the yellow line in the lower graph, Figure 74.



**Figure 74. Near Coincidence of Requested vs. Reported Load from GETS System Aggregated Group in Response to Simulated ACE Signals for Frequency Regulation**

In Figure 74, the response to the simulated ACE signal from GRE is shown over a 2.5-hour time interval for the aggregated group. The load response from the GETS system is requested by the simulated ACE signal from GRE and plotted with the reported load. The plot occurs over a 2.5-hour time interval and shows near coincidence of the reported load relative to the requested load for frequency regulation.

A more detailed evaluation of the fast response of the GETS to a simulated ACE signal in the current demonstration is shown in Figure 75. The load response in the left graph is a function of the current 90-second latency in reporting the results. However, the Steffes Corporation has developed a controller and monitoring system that will reduce the latency to less than 10 seconds, as shown in the right graph. The latency includes the communications latency back to the Steffes controller and monitoring system, computer analysis, and web site, referred to as the head-end system.



Note: Actual load response latency is ~4-6 seconds. The latencies listed above include communications transport back to the head-end system.


**Figure 75. Detailed Steffes GETS System Load Response**

### 5.3.2.5 Economic Evaluation

The total cost of the software modifications, project management fees, equipment, and other miscellaneous costs for this demonstration was \$111,280. A total of \$8,500 of this amount was for the GETS controllers and ancillary components (\$850 per site). Future cost per site is estimated to be approximately \$375 for the control and mixing valve. Three distinct value streams arise from a system of this type:

1. Fast-response frequency regulation per FERC Order 755 and 784
2. Energy shifting—from low cost (night) to high cost (day)
3. Demand reduction—a passive method of lowering morning and/or afternoon peaks by eliminating electric water heater usage

Over time, the MISO RMCP may increase to pay more for additional fast-response frequency regulation. Conversely, for performance, the PJM RTO is paying a much higher price for fast regulation by paying a regulation market capability clearing price (RMCCP) and a regulation market performance clearing price (RMPCP). In 2013, the MISO RMCP averaged about \$8.55/MWh for the year for all of the hours in a day, as noted in Figure 76. The line LMP minus RMCP is the effective cost and net cost for heating hot water and averages only \$10/MWh when the hot water heater utilizes the Steffes Corporation GETS system for providing frequency regulation.



**Figure 76. Average Hourly Prices in MISO in 2013 for LMP, RMCP, and LMP Minus RMCP or Effective Net cost**


Note: Although the annual average for the MISO RMCP is about \$8.55/MWh, the Steffes Corporation GETS system in the demonstration was set to operate only from 11 p.m. until 7 a.m. during the off-peak periods when the RMCP averaged only about \$7/MWh, but the LMP during the off-peak periods is minimized for charging the hot water heaters.

Based on the MISO off-peak average price of \$7/MWh, the equipment cost of \$700 for the controller used for this demonstration (the GETS is not currently being mass produced and is not configured to communicate wirelessly to a wireless WiFi modem in the home), \$75 for the mixing valve, \$10 for shipping, and approximately \$250 for installation (assuming no learning curve and installation of the wiring to the internet modem), the currently high initial investment is not paid back within MISO given the current prices for MISO RMCP and the cost of acquisition and installation of the GETS system. This assumes that costs will be avoided for the current DSM equipment cost of \$85 and installation cost of approximately \$200. These are avoided because the GETS system also will provide a superior DSM system by timing the charge of the hot water heaters to occur during the off-peak periods and valley filling while providing frequency regulation. Assuming in the future that the current estimated MISO compensation structure remains the same, the cost for the GETS system controller drops to \$300 per unit (assuming mass production), and the installation cost of \$200 (assuming wireless communication to the home WiFi internet modem) could move down due to a shorter learning curve and faster installation. Essentially the cost for the GETS during the demonstration would drop from \$1025 per GETS hot water heater down to \$625 per hot water heater installation. The investment in a GETS system still will not have an acceptable payback in MISO. Higher rates for pay-for-performance compensation for fast frequency response regulation in the future will improve the economics.

Steffes currently also charges \$3/month for controller and monitoring system, computer analysis, and web site, referred to as the head-end system. Thus if, in addition to the above cost decreases, there is a reduction in the monthly fee for the head-end aggregation and control services from \$3 to \$2 a month, the system will pay back the initial investment in about 26 years in MISO return on investment. If the monthly fee is dropped to \$1/month, then the payback is 13 years and a

utility might be interested in installing the GETS system due to an adequate return on investment.

However, should MISO begin to pay prices similar to the PJM RTO for fast-response frequency regulation service under the requirements for FERC Order 755 and a premium for fast-response resources such as the Steffes Corporation GETS system (which currently is also being demonstrated on the PJM RTO), the rate of return will be very favorable.




**Figure 77. PJM Regulation Market Clearing Price, October 2012 through September 2013.**

(Source: October 14, 2013, PJM RTO report to FERC on analysis of performance-based regulation for frequency regulation.)

In Figure 77, the PJM RTO RMCP from October 2012 through September 2013 was about \$31.64/MWh for all hours. This was significantly higher than the MISO RMCP of \$8.55/MWh. Even the PJM RTO RMCCP of about \$30/MWh was significantly higher than the MISO RMCP. (Note that the PJM RTO RMCP is equal to the RMCCP + RMPCP as shown in Figure 78—the pay-for-performance in accordance with FERC Order 755 for fast-response regulation.) If the MISO market prices for RMCP eventually evolve in the direction of the prices for RMCP in PJM RTO, a future MISO market price for RMCP could eventually be expected to average about \$32/MWh for all hours, and the MISO market price for RMCP to average about \$27.75/MWh for the off-peak hours.

Figure 78 provides more detail on the PJM RTO RMCP, RMCCP, and RMPCP as a function of the time-of-day average for the entire year.



**Figure 78. PJM RTO LMP, RMCCP, and RMPCP as a Function of the Time-of-Day Average for FY 2013**

The equation and data for Locational Marginal Price developed by Steffes Corporation is  $LMP = s - (0.95 \cdot RMCCP) - (2.8 \cdot 0.95 \cdot RMPCP)$ , which represents an estimate of the average cost to heat a hot water heater providing frequency regulation. The “mileage factor” of 2.8 is calculated by the Steffes Corporation, which the PJM RTO calculates as a “marginal benefits factor” (discussed in more detail below). Of course, since the Steffes Corporation GETS system was set to operate only during the off-peak hours (11 p.m. to 7 a.m.), the average cost to heat the hot water was nearly zero (the yellow line). What is interesting and counterintuitive for the PJM RTO is that, with dynamic dispatch and an algorithm that would predict day-ahead LMP, RMCCP, and RMPCP (with mileage or marginal benefits factors), the lowest-cost time for charging the hot water heaters in the PJM RTO area would be the 3 hours between 6 a.m. and 9 a.m., the 2 hours between 11 a.m. and 1 p.m., and the 3 hours from 9 p.m. until midnight (for a total of 8 hours of charging throughout the day). Of course, in the case of MISO, the current optimum time for charging the hot water heaters is the 8 hours from 11 p.m. until 7 a.m., as indicated in Figure 76. A great benefit of the GETS system is that it can be set to optimize the economics by weighing the compensation for frequency control against LMP prices and then selecting the combination that provides the best return.

### 5.3.2.6 More Detailed Discussion of Frequency Regulation Markets

In the October 14, 2013, PJM RTO report to FERC on analysis of performance-based regulation for frequency regulation, PJM reported the following:

“Consistent with the clearing of the Performance Based Regulation Market, PJM Settlements compensates regulating resources with a capability and performance credit. For the regulation capability credit, PJM identifies each resource that supplied Regulation (both pool-scheduled and self-scheduled) with an hourly performance score greater than or equal to the applicable threshold for minimum hourly performance during an hour. PJM calculates the hourly Regulation Market Capability Clearing Price Credit for each applicable regulating resource by multiplying the individual resource’s hourly Regulation megawatts by the

Regulation Market Capability Clearing Price (RMCCP), and the resource's actual performance score. PJM calculates the hourly Regulation Market Performance Clearing Price Credit for each applicable regulating resource by multiplying the individual resource's hourly Regulation megawatts by the Regulation Market Performance Clearing Price (RMPCP) for that hour, a performance multiplier, and the resource's actual performance score for that hour.”

FERC Order 755 refers to the performance multiplier as a “mileage factor” (calculated by Steffes as 2.8), which is multiplied by the RMPCP and added to the RMCCP for a total RMCP average for the year of \$31.55/MWh. PJM also evaluated the possibility of over-penetration of fast-response systems for frequency regulation. It noted that the marginal benefits factor (the PJM measure of the mileage factor) is about 2.8, for a 1% penetration of fast-response resources into the total frequency regulation market (which would be about 6 to 7 MW for PJM and ~7,000 GETS-enabled water heaters). With a 3% penetration of fast-response resources for frequency regulation (about 18 to 24 MW for the RTO and 24,000 GETS-enabled water heaters), the marginal benefits factor drops to about 2.5. At a 40% penetration of fast-response frequency regulation (about 240 to 280 MW), the marginal benefits factor would drop to 1.0. Thus, there will be a limited penetration of fast-response frequency regulation; however, this will be after approximately 280,000 GETS-enabled water heaters are installed. It should be noted that even with a marginal benefits factor of 1.0, fast-response frequency regulation technology (such as the GETS system) still might be able to provide an adequate return on investment with a reduced RMCP price under the PJM system.

When the Steffes GETS system charges during the off-peak hours, 2.8 times the RMPCP yields about \$13/MWh; the RMCCP of \$14.75/MWh yields the off-peak RMCP for the PJM RTO of \$27.75/MWh.

### 5.3.2.7 Economic Evaluation

If MISO prices for fast-response frequency regulation during the off-peak periods rise to the levels of the PJM RTO of \$27.75/MWh plus \$1.50/MWh for valley filling, or \$29.25/MWh, the payback for a full-priced GETS would be 8 years, or 11% return on investment. With a hoped for lower-cost GETS system, the payback would be 4 years. It should be noted that at the time of this project and report, natural gas costs were between \$2.25 and \$2.75 mmBtu in MISO and PJM RTO, which averaged near a 10-year low. The low cost of natural gas has driven down the cost of regulation for MISO, and hence the RMCP. Of course, in the winter of 2013 the prices rose to \$4.5/mmBtu, and during the winter “polar vortex” of 2013 in the northeast prices as high as \$28/mmBtu occurred in the PJM RTO for a few hours.

### 5.3.3 Conclusions

#### 5.3.3.1 Effectiveness and Benefits of Thermal Storage in Meeting Utility Needs

- As with battery storage, this is a new commercial technology that presents a significant learning curve for both the manufacturer and the co-op. Presumably this learning curve will result in reduced “real” installation costs upon large-scale replication.

## Chapter 4. Storage Systems Procurement Installation

- Thermal energy storage has the ability to provide firm DSM during the most attractive and economical peak hours and fast-response frequency regulation during the off-peak hours.
- Current MISO market payments for regulation and high introductory costs of the Steffes GETS system have not provided a reasonable payback to GRE for frequency response. Scaled future production of the GETS system will reduce product costs substantially. Along with increased value for regulation services, this could provide a reasonable return for GRE and co-ops in the MISO footprint.
- GRE could have a rate of return >100% if (1) MISO frequency regulation market payments for fast-frequency regulation increase to prices similar to those paid by the PJM RTO, and (2) the Steffes Corporation reduces the price for its GETS system and installation..
- With the increased cost of natural gas, the price paid for RMCP will increase, making even more attractive those fast-responding products that can provide regulation services.
- GETS systems provide a very high round-trip efficiency (>95%).
- Hundreds of thousands of cycles and 10+ years of service could be received from GETS-enabled water heaters, even with DOD of >80%.
- Thermal systems are consumer friendly and safe, and there is no added cost for insurance or other similar factors.
- Steffes GETS systems have built-in kWh metering. This can eliminate the need for co-ops to add costly secondary services and metering into homes while still achieving all the economic benefits of demand reduction, LMP optimization, and frequency control.
- Comfort assurance features, if enabled, ensures hot water for the homeowner at all times. The GETS system monitors hot water heater temperatures and, only when needed, it will enable a temporary override to provide continuous hot water to a specific homeowner. Co-ops with traditional load management controls often will enable a permanent mid-day “bump” or recharge period, which then consumes higher-cost energy for a significant amount of its annual hot water heating requirements.
- Based on economics, an option for designating a block of time during the day can be used which normally will be during hours when the loads are low and during which a regulation signal can be provided to GETS and other water heaters that need it to allow limited recharging while also providing fast regulation services.
- The Steffes GETS system, along with its head-end aggregation control, provides great visibility and granularity, thus allowing co-ops to regroup endpoint control to better manage loading of substations and feeders. This can delay or eliminate the need for costly upgrades.
- The GETS communication system provides a complete and separate control system, and serves as an alternative to the aging and existing load management control system.
- The GETS system is a very flexible power management and storage resource. While GRE chose to limit the window for regulation from 11 p.m.–7 a.m., the system has the ability to maximize benefit by selecting the best hours on a day-by-day or hour-by-hour basis.

### 5.3.4 Recommendation for Further Study

Although the lowest-cost fast-acting energy storage today is the GETS system, this cost must be reduced further through manufacturing; at the same time, a wireless connection needs to be developed for the GETS controller that will make installation easier and less costly. Research into cost reduction mechanisms will be important for obtaining the full range of value from a GETS system.

## 5.4 Summary

The overall project goals were accomplished:

1. Ten Steffes water heater controls (<http://www.steffes.com/offpeak>) with remotely configurable charge rates were deployed in the service territories of the participating member distribution cooperatives.
2. Two-way communication of the water heater controls was tested, evaluated, and proven to be effective.
3. The use of power-line carrier, 700-MHz wireless, and Wi-Fi were tested as possible communication technologies.
4. An economic model was developed for evaluating use of hot water heaters for frequency regulation.

## 5.5 Extended Technical Discussion A

### Energy Storage – The Benefits of “Behind-the-Meter” Battery Storage *Adding Value with Ancillary Services*

The benefits of behind-the-meter energy storage were evaluated through two closely related technology demonstration projects involving storage at several electric distribution cooperatives (co-ops) and GRE, a generation and transmission (G&T) electric cooperative in Minnesota. The overall goals were to validate the technologies and determine their value in demand reduction and for providing such ancillary services as frequency regulation and synchronous reserves to the MISO<sup>69</sup> electricity market.

These projects were undertaken through the NRECA SGDP and funded by the DOE under an ARRA grant, with cost share provided from participating co-ops. The lead co-op on the battery energy storage project was Minnesota Valley Electric Cooperative (MVEC), a distribution co-op in Minnesota, with participation by Wright-Hennepin Cooperative Electric Association (WHCEA), Federated Rural Electric Association (Federated), and Meeker Cooperative Light and Power Association (Meeker). The lead co-op on the thermal storage project was GRE, which installed systems at a number of distribution co-ops within its membership.

The first project involved battery energy storage systems at MVEC, WHCEA, and two nearby distribution co-ops—Federated and Meeker. The specific technology used was a Silent Power

---

<sup>69</sup> See <https://www.misoenergy.org/Pages/Home.aspx>.

## Chapter 4. Storage Systems Procurement Installation

(SP) “OnDemand™ Energy Appliance”—an integrated utility-controlled edge-of-grid battery energy storage system.<sup>70</sup> Unfortunately, Silent Power became insolvent in early 2014 due to circumstances beyond its control. It should be noted that this does not sound the death knell for residential battery storage. There are other residential battery storage companies, such as Sunverge Energy in Stockton, CA, very similar to SP. Also, Tesla Motors and Solar City are actively pursuing residential solar and battery storage solutions. Meanwhile, the work with SP has allowed electric cooperatives to gain a better understanding of the opportunities and challenges for battery storage.

The SP appliances in this test used sealed lead acid batteries. Li-ion batteries are a better fit for this type of application, albeit more these were more expensive 4 years ago, but that is no longer the case with Li-ion battery costs dropping 70% in the last 18 months.

The first project accomplished the following goals:

1. Eighteen SP battery storage appliances have been installed in the field to learn about and solve issues related to installation at members’ homes and businesses.
2. The stated features of the SP battery storage appliances were tested and evaluated in the field, using sealed lead acid batteries. Feedback was provided to the vendor on product deficiencies and suggestions for improvements.
3. When aggregated, the SP battery storage appliances provided controllable demand reduction that could reduce the need for future natural gas peaking units. The immediate benefit is cost savings on wholesale power demand charges for the participating distribution co-ops. The benefit for the G&T co-ops is achieved not only through reduced need for new capacity in the future, but also reduced congestion costs on the transmission networks. It is important to understand that the value of “dispatchable battery storage” is greater than more traditional options, such as dual fuel electric heating or cycled air conditioner control.
4. Simultaneous control of battery storage units in multiple distribution co-ops was simulated/tested for the purpose of providing aggregated ancillary services—in this case, for MISO.
5. Battery storage for small residential and commercial consumers was used for instantaneous and dispatchable load management.
6. The whole-house load management tool was tested in a natural gas market.
7. WHCEA is prepared to use battery storage as the “dual fuel” for air conditioning. Dual fuel uses electric heat as the primary source, and a backup heating source, such as liquefied petroleum (LP) gas or fuel oil, during peak load conditions. In this case, the battery storage energy would be injected into the grid to offset the A/C unit load during peak load conditions in the summertime. The A/C unit would function as normal during the peak load condition. This provides demand reduction savings over the peak while eliminating “rebound” peaks when control ends. The SP units for these locations were not installed during summer 2013.
8. MVEC and WHCEA SP units successfully provided backup power for critical circuits.

<sup>70</sup> See <http://www.silentpwr.com/HomeOwner.htm>.

9. A battery storage unit allowed continued solar energy production during a power outage at one location with a 2,000-watt solar photovoltaic array, while remaining isolated from the grid.<sup>71</sup>
10. The SP battery storage inverter (at 48 volts dc) was integrated with a 2,000-watt residential solar photovoltaic (PV) (at 48 volts dc), thus reducing cost for the solar PV/storage solution because the two units shared an inverter.
11. The ability to measure the amount and impact of battery storage load before and after load control was tested.

An anticipated implementation of localized VAR control was not tested.

### **5.5.1 Project Implementation and Results — Battery Energy Storage**

#### **5.5.1.1 Enabling Technology**

The battery storage project used equipment from SP. The OnDemand™ system used advanced lead acid battery energy storage for this study; a dedicated grid battery charger; an inverter that can serve in either grid-connected or isolated, off-grid modes; and a monitoring and control system. Li-ion batteries were available but not included in this study. It was felt that lead acid batteries might be adequate and have sufficient life, based on the anticipated few hours of control (about 150) a year. The system includes an option for connection of a PV array through either a maximum-power, point-tracking controller provided by SP or an external controller.

OnDemand™ Energy Appliance specifications are shown in Table 26.

---

<sup>71</sup> Note: Solar panels generally will not function if grid power is lost because the inverters are required by UL-1741 / IEEE-1547 to operate only if the grid voltage and frequency are stable. With battery storage, the inverters can switch modes and operate isolated from the grid. This can provide grid resiliency.

**Table 26. OnDemand™ Energy Appliance Specifications**

<b>Inverter</b>	
<b>Specification</b>	<b>Range</b>
Input Battery Voltage Range	40 to 66 VDC
Nominal AC Output Voltage	120 or 120/240 Vrms $\pm$ 3%
Output Frequency	60 Hz $\pm$ 0.3%
Total Harmonic Distortion	< 5%
Continuous Power Output at 40° C	4,600 W/9,200 W
Continuous Input Battery Current	4.6kW-115A, 9.2kW-230A
Waveform	Pure Sine Wave (320 step)
<b>Back-Up Power Features</b>	
<b>Specification</b>	<b>Range</b>
AC Pass-Through Current to Critical Circuits Panel	50A at 120 volts, 100A at 120/240 volts
Switching Time upon Grid Outage	Less than 30 milliseconds
Back-Up Switching Criteria	Per IEEE 1547
Continued Solar Production in Island Mode	Yes
<b>Communications</b>	
<b>Specification</b>	<b>Range</b>
Consumer Interface	7" Touch Screen Display, Ethernet for Web-Based PC Interface
Utility Interface	RS232 for AMI, Ethernet for Broadband Internet, XML Protocol
Other	CAN Bus Communication Port, USB
<b>Environmental</b>	
<b>Specification</b>	<b>Range</b>
OnDemand Operating Temperature*	-20° C to +55° C (-4° F to +131° F)
OnDemand Storage Temperature	-40° C to +70° C (-40° F to 158° F)
Recommended Battery Operating Temperature	-15° C to 45° C
Max Operating Altitude	15,000' (4,570m)
Operating Humidity	0 to 95% RH Non-Condensing
System Output	Operating Temperature 45°C 50°C Derating 83.3% 66.6% 50.0%
<b>Safety</b>	
<b>Specification</b>	<b>Range</b>
Listing	Complies with UL 1741 and CSA 107.1 Complies with UL 1778 and CSA 107.3
<b>Physical</b>	
<b>Specification</b>	<b>Range</b>
Dimensions and Weight Without Batteries	Standard XLT Cabinet 54.5"H x 27.0"W x 29.5"D - ~375 lbs 73.0"H x 27.0"W x 29.5"D - ~400lbs
Clearance for Ventilation	See installation manual for workspace clearance

As shown in the table, the battery inverter is rated at 4.6 kW or 9.2 kW. The batteries installed during this demonstration by SP are GS-Yuasa 246 Amp-hour (AH) batteries that can produce 11.8 kWh or 23.6 kWh over a 20-hour discharge time. In discussions with WHCEA and MVEC, when the system is discharged over a quick 2 hours (WHCEA) and a 1-hour discharge time (MVEC), the peak output from the battery rated at 4.6 kW will be limited to less than 4.6 kW

while also limiting the Depth of Discharge<sup>72</sup> (DOD) to <60% (WHCEA) or <80% (MVEC). This is because of Peukert's law, developed by the German scientist W. Peukert in 1897. He expressed the energy capacity of a lead acid battery as the rate at which it is discharged. As the rate increases, the battery's available energy capacity decreases (primarily from  $I^2R$  losses due to the series resistance in the batteries). With a limitation on the percentage of DOD, as the energy capacity of the battery decreases due to rate of discharge, its maximum kW output during the rapid discharge times also decreases.

Thus, when the MVEC unit discharges over a 1-hour time interval, the output has been less than 4.6 kW because of the following:

1. Increasing the nominal discharge time from 20 hours to 1 or 2 hours significantly increases the  $I^2R$  losses from the equivalent series resistance by a factor of 10 to 20 and the battery and the inverter by a factor of 100 to 400, which in turn significantly reduces the peak capacity of the GS-Yuasa 246 AH batteries.
2. The more cycles consumed and the more the batteries age, the more the voltage drops and the output from the batteries decreases.
3. For this research, WHCEA limited the degree of operating discharge to a conservative 60% DOD over 2 hours, which sets the limit on the peak output of the batteries but increases their life to a more conservative 700 cycles.
4. For this research, MVEC limited the degree of operating discharge to an aggressive 80% DOD, which shortens the life of the batteries to only 450 cycles.

Over time, MVEC has not been able to provide peak demand reduction of 4.6 kW or 9.2 kW; rather, the peak output was about 3.2 kW and 6.5 kW, respectively, for slightly more than 1 hour. WHCEA discharges its batteries to 60% DOD over a 2-hour time interval, which allows it to provide peak demand reduction of 2.7 kW and 5.5 kW, respectively, over the longer time interval of 2 hours. WHCEA and MVEC felt that Li-ion batteries would be a better option for storage because the battery output does not decrease significantly as the discharge time decreases.

### 5.5.1.2 Installation


The SP unit is designed to be installed “behind the meter” at the customer’s premises. Installation involves physical placement of the equipment cabinet, installation of the batteries, and connection to the main load panel at two breakers (one for the charge circuit and one for the inverter-to-grid connection). Critical loads are connected through a separate “Critical Circuits Panel,” typically by a selector switch that would allow the critical loads to be connected directly to the main panel and, in the event of outage, serve off the grid until the battery is discharged. If a PV array is to be attached, it is done either through an optional DC/DC charge controller or through a separate vendor-supplied charge controller. Communications are through customer-provided broadband Internet. The systems interact with the “On Command” software, hosted by SP.

---

<sup>72</sup> The percentage of battery capacity that has been discharged, expressed as a percentage of maximum capacity. A discharge to at least 80% DOD is referred to as a deep discharge.

Utility access to metering information also is provided through On Command. System performance data were collected by SP once per day and made available to the participating co-ops. Control over the units was provided through schedules, not by direct device control. Each cooperative managed its units separately through the On Command software service. Co-ops could set schedules specifying the time and magnitude of the discharge, and also the time and duration window for recharge.

Figure 79 shows a simplified installation wiring diagram:



**Figure 79. Simplified SP Installation Wiring Diagram**

### 5.5.1.2.1 Project-Specific Installations

Table 27 shows the installation details for the units purchased for this project.

**Table 27. Installation Details for the Units Purchased**

Co-op	kW Rating	Solar?	Location
MVEC	4.6	Yes	Residential member location
MVEC	9.2	No	Residential member location
MVEC	9.2	No	MVEC headquarters
MVEC	4.6	No	MVEC headquarters
MVEC	4.6	No	MVEC headquarters
Federated	4.6	No	Federated headquarters
Meeker	4.6	No	Meeker headquarters
WHCEA	4.6	No	WHCEA headquarters-energy park
WHCEA	4.6	No	WHCEA headquarters-commercial building
WHCEA	4.6	No	Residential member location
WHCEA	4.6	No	Residential member location
WHCEA	4.6	No	Residential member location
WHCEA	9.2	No	Commercial member location
WHCEA	4.6	No	Residential member location
WHCEA	9.2	Wind	Residential member location
WHCEA	4.6	No	Residential member location
WHCEA	4.6	No	Residential member location
WHCEA	9.2	No	Residential member location

Federated installed three additional bi-directional meters on its unit. (See details in Section 5.5.3.4.)

WHCEA installed three large (9.2 kW net) battery storage units and eight small (4.6 kW net) units. One of the large units was installed in a small commercial location, one large unit was at a residential location, and the third large unit was located at a residential site that included a small (20 kW) wind turbine. Otherwise, all units were placed in residential locations. Five units were installed with “critical circuits” panels. One of the MVEC installations includes integration with a 2,000-watt solar PV array, using the same inverter for the solar PV and the SP battery. The batteries provide voltage to the solar PV inverters, allowing operation of the solar PV if the grid has a short or extended outage. In addition, the batteries provide electricity to critical loads at night during an extended outage.

### 5.5.1.2.2 Experience

Installation of the SP units began in July 2012 and was completed by August 2013 (see Figure 80 and Figure 81). The co-ops experienced delays in installation, due primarily to control software issues and communications problems with the SP systems. These eventually were resolved.

WHCEA noted some specific issues with the installations:

## Chapter 4. Storage Systems Procurement Installation

- “Installation of the equipment is fairly straightforward, and none of our electricians had any trouble with the installations. The one difficulty is the physical size and weight of the equipment and batteries, which require a two-person crew (at least for the initial installation).”
- “When installing the units in a critical-circuits configuration, the electricians have to use a manual bypass to allow operation of the critical circuits loads during maintenance or downtime of the SP unit. The manual bypass requires additional space and wiring and, in order to meet code, is fairly large, which adds some to the project costs.”
- “The only means of communication with the device is through an Ethernet interface. Therefore, at each location, we’ve had external equipment that had to be added. Some could directly connect via Ethernet and communicate through the local broadband connection at the premises. However, the majority did not have direct Ethernet access. We used Linksys range extenders to convert Ethernet to Wi-Fi, so we could drop into the local Wi-Fi. However, this was not available at all locations. Where Wi-Fi was not available, we used cell modems with an Ethernet port. All of these items require external power.”



**Figure 80. 9.2-kW SP Unit with Cover Removed**



**Figure 81. Display on SP Appliance**

## 5.5.2 Operation

### 5.5.2.1 General Operation

In normal operation, the battery charge circuit is turned off; the majority of power flows directly “across” the SP inverter bus to the critical load panel. The only losses in this state are the self-discharge of the battery and the “tare losses” (parasitic losses)<sup>73</sup> required to run the control system. Periodically, the software is instructed to charge the battery. There are two stages to this charge—a bulk charge and an “absorption” charge. The MVEC nominally rated 4.6-kW units were recharged during off-peak hours and drew an average of about 40 watts per hour during periods for the tare load, even if the unit was not dispatched. This would put the tare loss and battery maintenance at about 29 kWh per month, or a little more than \$3 cost for tare losses for the 4.6-kW unit and \$6 cost for tare losses per month for the 9.2-kW unit at retail rates. If a power outage occurs, the unit will disconnect from the grid and supply power directly to the Critical Circuits Panel, forming an intentional “island” that operates separately from the main power grid. This continues either until the battery is fully discharged (at which point the battery is disconnected) or grid power is restored and stable for five minutes, at which point the system will reconnect to the grid. If a PV array is used, the array can recharge the battery during sunlight hours during this “islanded” period. Today, batteries will only be allowed to be discharged 50% or 70% to allow maximum lifetime for the batteries and not fully discharged unless the battery is designed to have a long life when fully discharged (like flow batteries, zinc air batteries, etc.)

If the unit is scheduled to “dispatch” to the grid, it will turn on and provide a targeted amount of power for a specific period of time. The maximum power available is limited by the size of the inverter (4.6 kW or 9.2 kW), and the discharge duration is limited by the power setting and the size of the battery. The discharge can be terminated either on a timer or a maximum DOD. The output power supplies the critical load, with any excess flowing back into the main panel. (Note that this “load sharing” occurs as a result of the laws of physics and not from any active control technology.) The “dispatch” results in a constant, verifiable, measured load reduction.

### 5.5.2.2 Project-Specific Operation

MVEC discharged its units at full nominal rated power (4.6/9.2 kW) until the battery is discharged to 80% battery DOD in the 1 hour it predicts will be the peak for the month. On average, it discharges the units about four or five times a month while attempting to hit the monthly peak demand. The battery is predicted to have a cycle life of about 450 cycles when operated at 80% DOD, as shown in Figure 82. Thus, if the units are discharged five times a month, the life of the battery will be about 90 months, or about 7.5 years. WHCEA discharges its units over a 2- to 3-hour period and usually discharges the batteries only down to 60% DOD, hoping to extend their life. The life of the battery when discharged down to 60% DOD is expected to be about 700 cycles, or about 12 years, if used five times a month. Federated discharges its unit at a 2.3-kW rate for one or two separate 1-hour periods, depending on the season. (Some winters may have two peaks each day, one in the morning and one in the afternoon or early evening; summers have afternoon peaks only.)

---

<sup>73</sup> Loss caused by a charge controller.

SP has been monitoring the operation for 16 of the units in service; nine currently are considered good and have been given a green status. Five batteries have been given a yellow status, as the batteries report a state of charge (SOC) of 80% or lower and thus are considered as candidates for replacement. One battery had a charger drawer that needed repair; it was repaired but now is reporting an SOC of 80% or lower and so is a candidate for replacement—its status is red. The last battery of the 16 is also in a red status and is a candidate for replacement.

### 5.5.2.3 Maintenance Requirements

The units use VRLA batteries that are sealed under normal operation, so the unit requires no regular maintenance. Depending on the use, number of cycles, and DOD of the batteries, they may need to be replaced one or more times over the course of the 10-year life of the system.

### 5.5.3.4 Data Collection

Data were collected for each unit through a web-hosted service provided by SP. Federated installed three additional bi-directional meters on its unit.

- One meter is between the main panel and the battery charger input.
- A second meter is between the main panel and the SP Inverter. This meter measures both power supplied from the panel to the unit (and through to the critical loads) and power supplied from the battery through the SP inverter and back onto the grid.
- A third meter is between the SP inverter and the critical loads panel.

### 5.5.3.5 Economic Evaluation

All four of the project co-ops purchase power through two G&T cooperatives. Their primary contract is through GRE and is fixed at their energy requirements from 2006. The balance of energy is purchased through Basin Electric Power Cooperative (Basin Electric). The co-ops pay a transmission charge to GRE, based on the coincident GRE system peak and a demand charge to Basin Electric, based on the peak demand at the individual co-op each month. The reduced demand cost can range from \$20 to \$25 per month per kW.

A detailed analysis that calculates payback for future commercial units based on using detailed assumptions regarding the components is shown in Table 28 for WHCEA and Table 29 for MVEC. The assumptions used include the following:

- Electricity is valued at 11.7 cents per kilowatt hour (kWh) when discharged into the grid during the peak hours; when recharging, the battery is charged 4.9 cents per kWh during the off-peak hours.
- The datasheet rating of the battery in the small system is 246 amp-hours at 48 volts, or 11.8 kWh at the 20-hour rate. As mentioned previously, however, the nominal ratings are assumed to be 4.6 kW and 9.2 kW; if discharged quickly over a 2-hour period, the ratings are assumed to be 2.7 kW and 5.5 kW, respectively. If discharged at the fast rate of 1 hour, the ratings are assumed to be 3.2 kW and 6.5 kW, respectively.

Chapter 4. Storage Systems Procurement Installation

- As mentioned previously, the actual useful storage of the battery is diminished because of reduction in capacity due to high rate of discharge, conversion of energy from dc to ac, and reserving some capacity to prevent damage to the battery during excessive discharge.
- System round-trip efficiency is 60%, based on 85% efficiency for the electronics in each direction and 83% dc round-trip efficiency quoted for the GS Yuasa 260 amp-hr battery. However, while both the inverter efficiency and dc efficiency of the battery decrease as the battery discharges faster, that effect has not been included in this analysis.
- For the nominally 4.6 kW rating of the GS Yuasa 260 amp-hr battery, there is a 40-watt continuous tare load (a parasitic load), including maintenance charges on batteries when not in use.
- It is assumed that eight cycles per month currently are required to meet the two demand peaks; each cycle lasts for  $\approx$ 1.2 hours, resulting in an 80% discharge. It is assumed that about five cycles per month are required to meet a single demand peak.
- The analysis assumes that the battery will last for 11.67 years if the battery system is discharged to 60% DOD or less or 4.69 years if discharged to 80% DOD.
- The net cost of the system each year is assumed to be a loan payment for the life of the battery at a 5% interest rate per year on the installed cost of the system over the life of the system.
- No allowance has been added for any operation and maintenance costs, replacement of batteries, or insurance on the installations. When the system becomes commercial, it is not clear who will bear the responsibility for insurance on the battery or the increased insurance the homeowner will require because of having the battery on the premises. DOE and stakeholders realize that unanswered safety questions exist and are developing best practices.
- The net benefit is the demand reduction cost benefit of about \$20–25/kW per month.
- The probability of hitting the monthly hourly peak is assumed to be 100% for WHCEA when the battery is discharged over 2 hours and 90% when MVEC discharges the units in 1 hour.
- The net value received from the battery discharge is the demand reduction value times the peak rating for 1 or 2 hours, less the cost of charging the system, less the tare cost for the system, plus the value for the electricity sold during the peak hours.

**Table 28. Battery Energy Storage Project Detailed Payback Analysis for WHCEA, Assuming 2-Hour Discharge, 5 Cycles per Month, 60% DOD**

	Base 4.6-kW System	Base 9.2-kW System	Reduced-Cost 4.6-kW System	Low-Cost 9.2-kW System	
Unit cost	\$13,000	\$18,800	\$9,000	\$13,015	
Installation cost	\$1,200	\$1,200	\$1,000	\$1,000	
Nameplate rating	4.6	9.2	4.6	9.2	kW-AC
Actual rating for 2 hours, 60% DOD	2.7	5.5	2.7	5.5	kW-AC
Discharge hours per cycle	2	2	2	2	hours
Electric rate when discharging	\$0.117	\$0.117	\$0.117	\$0.117	\$/kWh
Electric rate when charging	\$0.05	\$0.049	\$0.049	\$0.049	\$/kWh
Demand value (average)	\$23.51	\$23.51	\$23.51	\$23.51	\$/kW/mo
Probability of hitting the peak %	100%	100%	100%	100%	%
Net average demand value	\$ 23.51	\$ 23.51	\$ 23.51	\$ 23.51	\$/kW/mo
Round-trip efficiency	60%	60%	60%	60%	%
Recharge energy per cycle or event	9.00	18.34	9.00	18.34	kWh
Number of cycles per month	5	5	5	5	per month
Recharge energy per month	45	92	45	92	kWh per month
Recharge cost	\$ 2.21	\$ 4.49	\$ 2.21	\$ 4.49	\$ per month
Discharge energy per month	27	55	27	55	kWh per month
Value of discharge energy per month	\$ (3.16)	\$ (6.44)	\$ (3.16)	\$ (6.44)	\$ per month
Tare load	40	80	40	80	watts per hour
Monthly tare load	29	58	29	58	kWh-AC/mo
Tare energy cost	\$3.42	\$6.83	\$3.42	\$6.83	\$ per event
Net cost energy for the ES (value for discharge energy less tare load and charge energy)	\$ 2.46	\$ 4.89	\$ 2.46	\$ 4.89	\$ kWh-mo
Demand charge savings	\$ 63.48	\$ 129.31	\$ 63.48	\$ 129.31	\$ per month
Net monthly savings for ES	\$ 61.01	\$ 124.41	\$ 61.01	\$ 124.41	\$ per month
Financing years	10	10	10	10	years
Interest rate per year	5%	5%	5%	5%	per year
Interest rate per month	0.42%	0.42%	0.42%	0.42%	per month
Monthly P&I payment factor	0.94%	0.94%	0.94%	0.94%	per month
Monthly payment for battery	\$ 122.24	\$ 176.77	\$ 84.63	\$ 122.38	\$ per month
<b>Monthly net benefit</b>	<b>\$ (61.22)</b>	<b>\$ (52.36)</b>	<b>\$ (23.61)</b>	<b>\$ 2.03</b>	<b>\$ per month</b>
<b>Lifetime net benefit</b>	<b>\$ (8,571.36)</b>	<b>\$ (7,330.53)</b>	<b>\$ (3,305.75)</b>	<b>\$ 284.85</b>	<b>\$ over lifetime</b>
DOD	60%	60%	60%	60%	DOD
Cycle life	700	700	700	700	cycles
# of cycles per year	60	60	60	60	cycles per year
Battery life, in years	11.67	11.67	11.67	11.67	years
Battery life, in months	140.00	140.00	140.00	140.00	months

**Table 29. Battery Energy Storage Project Detailed Payback Analysis for MVEC, Assuming 1-Hour Discharge, 8 Cycles per Month, 80% DOD**

	Base 4.6-kW System	Base 9.2=kW System	Reduced-Cost 4.6-kW System	Low-Cost 9.2-kW System	
Unit cost	\$13,000	\$18,800	\$9,000	\$13,015	
Installation cost	\$1,200	\$1,200	\$1,000	\$1,000	
Nameplate rating	4.6	9.2	4.6	9.2	kW-AC
Actual rating for 1 hour, 80% DOD	3.2	6.5	3.2	6.5	kW-AC
Discharge hours per cycle	1	1	1	1	hours
Electric rate when discharging	\$0.117	\$0.117	\$0.117	\$0.117	\$/kWh
Electric rate when charging	\$0.05	\$0.049	\$0.049	\$0.049	\$/kWh
Demand value (average)	\$23.51	\$23.51	\$23.51	\$23.51	\$/kW/mo
Probability of hitting the peak %	92%	92%	92%	92%	%
Net average demand value	\$ 21.55	\$ 21.55	\$ 21.55	\$ 21.55	\$/kW/mo
Round-trip efficiency	60%	60%	60%	60%	%
Recharge energy per cycle or event	5.34	10.84	5.34	10.84	kWh
Number of cycles per month	8	8	8	8	per month
Recharge energy per month	43	87	43	87	kWh per month
Recharge cost	\$ 2.09	\$ 4.25	\$ 2.09	\$ 4.25	\$ per month
Discharge energy per month	26	52	26	52	kWh per month
Value of discharge energy per month	\$ (3.00)	\$ (6.08)	\$ (3.00)	\$ (6.08)	\$ per month
Tare load	40	80	40	80	watts per hour
Monthly tare load	29	58	29	58	kWh-AC/mo
Tare energy cost	\$3.42	\$6.83	\$3.42	\$6.83	\$ per event
Net cost energy for the ES (value for discharge energy less tare load and charge energy)	\$ 2.51	\$ 5.00	\$ 2.51	\$ 5.00	\$ kWh-month
Demand charge savings	\$ 68.96	\$ 140.08	\$ 68.96	\$ 140.08	\$ per month
Net monthly savings for ES	\$ 66.45	\$ 135.08	\$ 66.45	\$ 135.08	\$ per month
Financing years	10	10	10	10	years
Interest per year	5%	5%	5%	5%	per year
Interest per month	0.42%	0.42%	0.42%	0.42%	per month
Monthly P&I payment factor	1.99%	1.99%	1.99%	1.99%	per month
Monthly payment for battery	\$ 258.65	\$ 374.05	\$ 179.07	\$ 258.95	\$ per month
<b>Monthly net benefit</b>	<b>\$ (192.20)</b>	<b>\$ (238.97)</b>	<b>\$ (112.62)</b>	<b>\$ (123.87)</b>	<b>\$ per month</b>
<b>Lifetime net benefit</b>	<b>\$ (10,811.42)</b>	<b>\$ (13,442.00)</b>	<b>\$ (6,334.74)</b>	<b>\$ (6,967.60)</b>	<b>\$ over lifetime</b>
DOD	80%	80%	80%	80%	DOD
Cycle life	450	450	450	450	cycles
# of cycles per year	96	96	96	96	cycles per year
Battery life, in years	4.69	4.69	4.69	4.69	years
Battery life, in months	56.25	56.25	56.25	56.25	months

The complete spreadsheets for the analysis of Table 28 and Table 29 are available upon request and posted on the NRECA CRN SharePoint.

Some important observations and conclusions follow:

1. Battery storage has very limited (if any) payback when installed for peak load management or energy arbitrage (buying low-cost energy at night and redeploying it into the grid on peak). The only case that showed a small positive payback was the assumption of a lower-cost 10-kW SP battery system at \$13,015 plus \$1,000 for installation, compared to today's \$18,800 for the SP battery system plus \$1,200 for installation. All other cases had a negative net lifetime benefit, primarily because of the following factors:
  - a. The demand charge savings alone are not enough to offset the capital cost of the equipment and installation.
  - b. Lead acid batteries have a short life cycle if operated to a less than 60% DOD on a regular basis. Li-ion batteries were not tested in this study.
  - c. The cost of equipment needs to come down. We feel this will happen for battery storage, as it did for solar panels. Solar PV modules dropped from \$8/watt to under \$1/watt once mass production and a competitive market developed. Companies like Tesla Motors and Solar City are working on bringing mass marketing of Li-ion batteries and solar PV to the United States, and legislators and regulators are starting to provide incentives for solar. When lower costs and longer cycle life for batteries (probably Li-ion) are achieved, battery storage may have a return on investment for demand charge savings. Li-ion battery prices dropped by 70% over the last 18 months and thus they are now cost-effective for use in demand charge reduction.
2. The case for battery storage is better if there is not only a peak load management application, but also usage in "premium power" applications, in which the customer is looking for better reliability and is willing to pay a monthly fee for the service—for example, \$25–\$30 per month.
3. The case for battery storage is best when combined with solar. In fact, solar should be combined with battery storage if the utility system peak is late in the day—after 6:00 p.m., for example. Solar alone will cause cost-shifting to other members because it reduces kWh energy purchases but does not significantly reduce the kW demand. The effect is to reduce the utility's load factor, which could drive up the cost/kWh. Figure 82 illustrates this issue.




Figure 82. Cost-Shifting from Solar without Storage

4. Note that there is no assumption of any annual operation and maintenance costs. If the electric cooperatives have to send a technician out to each of the batteries once a year at a cost of \$100 per visit, all cases will have a negative payback—even the one case that showed a positive payback here.




Figure 83. Lead Acid Battery Cycle vs. DOD

Additional conclusions from the demonstration of the SP GS Yuasa batteries are as follows:

1. As noted in Figure 83, the capacity of a VRLA battery goes down as the discharge rate increases. Different lead acid batteries are designed to be optimum at differing discharge rates. It is important to understand the full performance characteristics of a particular battery when attempting to determine whether these batteries overall will be viable in any given application. Obviously, if the cost for technology such as Li-ion batteries can be reduced to \$500/kWh (in the day are being reduced down towards \$300/kWh) or about \$14,000 total installed cost, these batteries will be the preferred option, as they have cycle lives of 3,000 cycles or more at 80% DOD and 125,000 cycles at 10 to 20% DOD. The electric cooperative then could have the option to bid Li-ion batteries into the frequency regulation market and for demand charge reduction; this would open up a second value stream, further strengthening the financial return of battery energy storage systems.
2. Many of the other applications envisioned by the co-ops—such as PV firming, wind energy load shifting, and commercial load management—will require additional cycling, thus putting additional strain on the batteries and requiring those with a significantly longer cycle life. The firming of PV potentially could require hundreds of cycles a year, which in turn would require the use of Li-ion batteries.
3. The typical discharge time for peak shaving is late in the afternoon, and in northern climates it might occur early in the morning during the winter. For the early morning peaks, it is conceivable that a utility could store wind or low-cost grid energy produced off peak at night.
4. A key benefit of an energy storage system could be to provide the voltage and frequency signal to the residential solar PV, so the PV can continue to operate when there is a power outage. This is accomplished by using the battery storage system to provide a critical source of power, voltage, and frequency to the solar array and inverter, which quickly and automatically disconnects from the grid if the main source power is lost. In this way, customers could continue to have a source of power for some critical loads during extended power outages..
5. The “certainty” of battery dispatch as a demand response solution has a significant value to cooperatives, as opposed to more probabilistic methods, such as air conditioner load control.

## 5.5.4 Conclusions

### 5.5.4.1 Effectiveness of Battery Energy Storage in Meeting Utility Needs

- This is a new commercial technology that presents a significant learning curve for both the manufacturer and the co-op. Presumably this learning curve will result in reduced “real” installation costs upon large-scale replication.
- At the present cost of equipment, both the 4.6 kW and the 9.2 kW systems have a negative net benefit.
- With present lead acid battery technology, accurate but limited use of the cycle life of the unit would be required to ensure that the battery would meet lifetime expectations. Such use would necessitate the ability to predict, as accurately as possible, the exact hour that

## Chapter 4. Storage Systems Procurement Installation

the peak would occur for each month. This study did not evaluate Li-ion batteries, small flow batteries, or zinc air batteries. We feel that these batteries would meet necessary and minimum performance requirements, but at the time of this demonstration their costs were higher. Now, the cost for these batteries is competitive if not actually cheaper than lead acid batteries. This study attempted to see whether a utility could achieve the desired results using lower-cost sealed lead acid batteries. Our conclusion is that these batteries did not meet our standards.

- The “certainty” of battery dispatch as a demand response solution has value for the co-ops, as opposed to more probabilistic methods, such as air conditioner load control.
- Initially, MVEC and WHCEA were looking for potential battery applications for small businesses and members with medical needs, where the advantages of continuous backup power has a large benefit that can help offset the physical costs of the unit. As the cost comes down, we can look for more widespread applications. These would cover the power blinks (which cannot be managed by backup diesel generators) and short-term (0–3 hours) outages for those customers that presently have no backup power.
- Battery storage, when integrated with solar PV, can provide grid resiliency, which currently is not monetized. (“Grid resiliency” means operation of the solar PV when the grid has an outage by providing voltage and a frequency signal to the inverters that keep the solar PV on line and also ensure that the batteries will be available to store solar PV for nighttime loads during extended outages.)
- With significant increases in battery cycle life, additional applications, such as reduced loads on radial feeders, reducing peak loads on transformer banks, “soaking up excess renewable energy,” or other economic dispatch applications, may become more feasible.
- The battery storage market is evolving quickly, especially as more solar energy is being dispatched into the electric distribution grids across the U.S. utilities. . The information gathered in this analysis will help others to understand the present economics and operating challenges. In addition, it is anticipated that other revenue streams or benefits will drive the battery storage industry, just as others have been discovered by adopting automated metering infrastructure (AMI) systems and supervisory control and data acquisition (SCADA) systems. Many electric cooperatives and IOUs also wrestled with economic justification issues in the early stages of AMI and SCADA implementation, but these now have been implemented in a majority of cooperatives and IOUs.

#### 5.5.4.2 Effectiveness and Benefits of Thermal Storage in Meeting Utility Needs

- As with battery storage, this is a new commercial technology that presents a significant learning curve for both the manufacturer and the co-op. Presumably this learning curve will result in reduced “real” installation costs upon large-scale replication.
- Thermal energy storage has the ability to provide instant and usually firm DSM during the most attractive and economical peak hours and fast-response frequency regulation during the off-peak hours.
- Current MISO market payments for regulation and high introductory costs of the Steffes GETS system have not provided a reasonable payback to GRE for frequency response. Scaled future production of the GETS system will reduce product costs substantially. Along with increased value for regulation services, this could provide a reasonable return for GRE and co-ops in the MISO footprint.

## Chapter 4. Storage Systems Procurement Installation

- GRE could have a very attractive rate of return >100% and paid back within a year if (1) MISO frequency regulation market payments for fast-frequency regulation increase to prices similar to those paid by the PJM RTO, and (2) the Steffes Corporation reduces the price for its GETS system and installation as predicted.
- With the increased cost of natural gas, the price paid for RMCP will increase, making even more attractive those fast-responding products that can provide regulation services.
- GETS systems provide a very high round-trip efficiency (>95%).
- Hundreds of thousands of cycles and 10+ years of service could be received from GETS-enabled water heaters, even with DOD of >80%.
- Thermal systems are consumer friendly and safe, and there is no added cost for insurance or other similar factors.
- Steffes GETS systems have built-in kWh metering. This can eliminate the need for co-ops to add costly secondary services and metering into homes while still achieving all the economic benefits of demand reduction, LMP optimization, and frequency control.
- Comfort assurance features, if enabled, ensure hot water for the homeowner at all times. The GETS system monitors hot water heater temperatures and, only when needed, it will enable a temporary override to provide continuous hot water to a specific homeowner. Co-ops with traditional load management controls often will enable a permanent mid-day “bump” or recharge period, which then consumes higher-cost energy for a significant amount of its annual hot water heating requirements.
- Based on economics, an option for designating a block of time during the day can be used, during which a regulation signal can be provided to GETS and other water heaters that need it to allow limited recharging while also providing fast regulation services.
- The Steffes GETS system, along with its head-end aggregation control, provides great visibility and granularity, thus allowing co-ops to regroup endpoint control to better manage loading of substations and feeders. This can delay or eliminate the need for costly upgrades.
- The GETS communication system provides a complete and separate control system, and serves as an alternative to the aging and existing load management control system.
- The GETS system is a very flexible power management and storage resource. While GRE chose to limit the window for regulation from 11 p.m. to 7 a.m., the system has the ability to maximize benefit by selecting the best hours on a day-by-day or hour-by-hour basis.

#### 5.5.4.3 Overall Assessment of the Storage Demonstration

- A well-designed thermal energy storage program can be used by utilities to shift their peak load while maintaining or even increasing energy sales, and potentially provide very valuable fast-response frequency regulation service. It is a technology that can benefit both the utility and the consumer.
- Cyber security issues have not been addressed for either the SP or the Steffes Corporation GETS systems. Both of these systems leverage and require existing broadband communications through the Internet.
- During the demonstration, there was a power quality issue with the operation of the GETS controller, and a probable minor issue with the SP advanced lead acid battery. At first, when there was an interruption in electric service to the home, the Internet modems

had to be rebooted manually when service was restored. This initially was a problem, but it did not become an ongoing issue. Clearly, a robust Internet modem needs to be installed that reboots itself in the event of an interruption in electric service. An economic model to evaluate the GETS system through a simple Excel spreadsheet has been developed and is available from Dale T. Bradshaw, the consultant to NRECA that drafted this report. He can be reached at [dale.bradshaw@nreca.coop](mailto:dale.bradshaw@nreca.coop) or [dtbradshaw@electrivation.com](mailto:dtbradshaw@electrivation.com) upon request.

### 5.5.5 Recommendation for Further Study

As this project is ongoing, further data will be compiled, and additional studies of that data are recommended. Another “behind-the-meter” demonstration for residential and commercial energy storage could be developed as advanced battery energy systems are developed that (1) are 30 to 50% lower in cost than the current SP systems for 2 to 4 hours of storage, (2) have cycle lifetimes longer than 3,000 cycles for 70% DOD, and (3) do not show significant loss of capacity over time and use. A new demonstration would focus on peak shaving and demand charge reduction, firming up and managing the intermittency of distributed solar PV and providing grid resiliency, provision of spinning reserve and frequency regulation, and backup power. Although the lowest-cost fast-acting energy storage today is the GETS system, this cost must be reduced further through manufacturing; at the same time, a wireless connection needs to be developed for the GETS controller that will make installation easier and less costly. Research into cost-reduction mechanisms will be important for obtaining the full range of value from a GETS system.

## 5.6 Extended Discussion B

There is a strong motivation to explore the possibility of harnessing solar thermal energy around the world, especially in locations with temperate weather. The review, Heat transfer fluids for concentrating solar power systems discusses the current status of heat transfer fluid, which is one of the critical components for storing and transferring thermal energy in concentrating solar power systems. Molten salts are one of the very attractive heat transfer fluids. One of the major issues of the molten-salts is their relatively high corrosive nature to metal alloys. Many new molten salts are being proposed, however the corrosion issues have to be resolved completely before commercial application of heat transfer fluids in concentrating solar powers.<sup>74</sup>

Notes:

References

<http://www.nreca.coop/what-we-do/bts/smart-grid-demonstration-project/>

[https://www.smartgrid.gov/files/OE0000222\\_NRECA\\_FinalRep\\_2015\\_03.pdf](https://www.smartgrid.gov/files/OE0000222_NRECA_FinalRep_2015_03.pdf)

<sup>74</sup> K. Vignarooban, Xinhai Xu, A. Arvay, K. Hsu and A.M. Kannan, Heat Transfer Fluids for Concentrating Solar Power Systems - A Review, *Applied Energy*, Vol. 146, Issue C, pp. 383-396, 2015.

<http://www.nreca.coop/testing-the-smart-grid/>

The May 2014 Report at: <http://www.nreca.coop/what-we-do/bts/smart-grid-demonstration-project/>

Extended Reference

Behind the Meter Report

[https://www.smartgrid.gov/files/NRECA\\_DOE\\_Energy\\_Storage.pdf](https://www.smartgrid.gov/files/NRECA_DOE_Energy_Storage.pdf)

# CHAPTER 6: ENERGY STORAGE SYSTEMS COST UPDATE

## 6.1 General Information

The cost of energy storage expressed in the DOE/EPRI Electricity Storage Handbook published in 2013 used hypothetical scenarios and best guesses from vendors. The body of work took place before real-world grid-integrated storage installations and demonstrations were in place. In a 2011 report, Susan Schoenung offered the following analysis.

## 6.2 Approach

This chapter will use Susan Schoenung's work, *Energy Storage Systems Cost Update*, to illuminate the worth of energy storage's various technologies and expose real cost and value<sup>75</sup>.

## 6.3 Data

Schoenung's work presents an update of energy storage system costs assessed previously and separately by the U.S. Department of Energy (DOE) Energy Storage Systems Program.

The most important factors influencing total life-cycle cost are the capital cost of the equipment, followed by replacement costs, and, finally, the cost of energy for recharging. Service life, discount rate, and inflation rate are three factors used to calculate the "present worth" factor, which provides a simple, consistent way to represent the value of a regular stream of revenues or payments for a given number of years (10 in this case).

While capital cost is important, total ownership cost, including O&M costs, is a much more meaningful index for a complete economic analysis. In general, present worth is based on ownership of the device over 10 years for a given application and includes the following factors: Efficiency, Cycle Life, Initial Capital Costs, Operations and Maintenance, and Storage-device Replacement.

Thus, the present worth (or present value) calculation includes not only capital cost, but operating costs as well.

This discussion will include technologies and application categories, cost calculations, and results, and observations.

---

<sup>75</sup> Energy Storage Systems Cost Update: A Study for the DOE Energy Storage Systems Program, Susan Schoenung, SAND2011-2730, Sandia National Laboratories, Albuquerque, NM, 2011.

### 6.3.1 Technologies and Application Categories

#### 6.3.3.1 Frequency and Duration Characteristics

As discussed above, the frequency of operation (and thus planned discharge cycles) is an important parameter for calculating life-cycle cost or present worth of life-cycle cost. The applications for energy storage can be roughly categorized by whether frequent cycling is expected, as in daily load-leveling, or infrequent discharge is expected, as in capacity applications.

Likewise, utility energy storage applications can be roughly categorized by whether a short capacity or discharge is needed (on the order of less than minutes) or whether a long storage or discharge time is expected (on the order of hours). Therefore, for this analysis, four utilization categories have been identified so that appropriate system costs could be evaluated. The four categories are defined in Table 30.

Representative applications or value propositions are also listed in Table 1. Many more applicable value propositions are defined and discussed in Schoenung's report<sup>76</sup>. Most are covered by these general technology application categories.

**Table 30. Operation/Use Categories**

Category/Definition	Hours of Storage	Use/Duty Cycle	Representative Application
Long-duration storage, frequent discharge	4 – 8*	1 cycle/day 250 days/year	Load-levelling, source-following, arbitrage
Long-duration storage, infrequent discharge	4 – 8*	20 times/year	Capacity credit
Short-duration storage, frequent discharge	0.25 – 1**	4 15 minutes of cycling 250 days/year = 1000 cycles/year***	Frequency or area regulation
Short-duration storage, infrequent discharge	0.25 – 1**	20 times/year	Power quality, momentary carry-over

\* This analysis uses 4 hours unless otherwise noted.

\*\* This analysis uses 1 hour unless otherwise noted.

\*\*\* Some technologies are capable and will be used up to 10,000 cycles/year.

<sup>76</sup> Ibid.

### 6.3.1.2 Technologies Considered

For this analysis, only the most common technology systems were evaluated. For the most part, these types of systems correspond to those analyzed in previous assessments. Costs have simply been updated using the previous methodology. The technologies and appropriate use categories are listed in Table 31. In some cases, the listed applications may be unrealistic; the cost calculations were performed for completeness. For example, flow batteries may not *practical* for applications needing only short-duration storage, but *could be used* in this way if necessary.

**Table 31. Technologies Considered**

Technology	Appropriate Use(s)
Advanced lead-acid batteries (2000-cycle life)	1, 2, 3, 4
Sodium/sulfur batteries	1, 2
Lead-acid batteries with carbon-enhanced electrodes	1, 2, 3, 4
Zinc/bromine batteries	1, 2, 3, 4
Vanadium redox batteries	1, 2, 3, 4
Lithium-ion batteries (large)	1, 2, 3, 4
Compressed air energy storage (CAES)	1
Pumped hydro	1
Flywheels (high-speed composite)	3, 4
Supercapacitors (double-layer electrochemical)	3, 4

The technologies considered include those described and considered previously<sup>77</sup>, but several have seen some significant development in the past few years. In particular, Li-ion batteries are now available in many different chemistries; the most promising is considered here. Also, lead-acid batteries with carbon-enhanced electrodes are the latest variation on lead-carbon asymmetric batteries or capacitors.

### 6.3.2 Cost Calculations

This section of the report contains a description of the life-cycle cost analysis performed for this study. It follows the same procedure as that in Schoenung's report<sup>78</sup>, which results in the present worth of costs (capital and operating) for 10-year operation. (Note that although the term "life-cycle" sometimes refers to an analysis that includes the eventual disposal of the spent capital equipment, the disposal component is not included in this analysis.)


---

<sup>77</sup> Ibid.

<sup>78</sup> Ibid.

### 6.3.2.1 Cost Methodology

Energy storage system components are shown in Figure 84. The major cost components of the energy storage system are the storage unit (\$/kWh) and the power conversion unit (\$/kW). The balance of plant is typically costed with the storage unit.



**Figure 84. Energy Storage System Components**

#### 6.3.2.1.1 Capital Cost

The capital cost calculation, in its simplest form is

$$\text{Costtotal} (\$) = \text{Costpcs} (\$) + \text{Coststorage} (\$) \quad (1)$$

The cost of the power conversion equipment is proportional to the power rating of the system:

$$\text{Costpcs} (\$) = \text{UnitCostpcs} (\$/\text{kW}) \cdot P (\text{kW}) \quad (2)$$

For most systems, the cost of the storage unit is proportional to the amount of energy stored

$$\text{Coststorage} (\$) = \text{UnitCoststorage} (\$/\text{kWh}) \cdot E (\text{kWh}) \quad (3)$$

where E is the stored energy capacity.

In the simplest case, E is equal to P t, where P is Power and t is the discharge or storage time.

All systems have some inefficiency. To account for this, Equation 3 is modified as

$$\text{Coststorage} (\$) = \text{UnitCoststorage} (\$/\text{kWh}) \cdot (E (\text{kWh}) / \eta) \quad (4)$$

where  $\eta$  is the efficiency.

Only when the unit costs of the subsystems are known, and the storage capacity in kWh is known, it is possible to rewrite the capital cost in terms of the power rating:

$$\text{Costsystem} (\$/\text{kW}) = \text{Costtotal} (\$) / P (\text{kW}) \quad (5)$$

### 6.3.2.1.2 Life-cycle Cost

The calculation of life-cycle cost includes the cost of capital, O&M, electricity for recharging, fuel (for CAES), and replacement costs. Life-cycle cost calculations are described in detail in Schoenung's report<sup>79</sup>.

### 6.3.2.1.3 Present Worth

Present worth, or present value, is the value on a given date (for example, the beginning of the project) of a future payment or series of future payments, discounted to reflect the time value of money. In this analysis, present worth *cost* is the sum of all discounted costs over the 10-year life of the system. A detailed rationale for the concept's use and examples of how it is used to calculate benefits *and* costs are provided in Schoenung's report<sup>80</sup>. The same methodology has been used here to calculate the present worth (PW) factor of the life-cycle cost. The equation for the PW factor for a 10-year service life is as follows:

$$\text{PW factor} = \sum_{i=1}^{10} \frac{(1+e)^{i-5}}{(1+d)^{i-5}} \quad (6)$$

$$\sum_{i=1}^{10} \frac{(1+e)^{i-5}}{(1+d)^{i-5}}$$

e = annual price escalation rate (%/year)

d = discount rate (%/year)

i = year

This factor is combined with other values obtained using other information and algorithms (which are sometimes proprietary) to calculate the present value (or present worth) of a given cost (or benefit).

### 6.3.2.2 Economic Assumptions

Costs associated with storage system use are calculated in this study using the assumed financial values shown in Table 32. Most notable, in order of significance, are (1) 10-year storage system service life, (2) 10% discount rate, and (3) 2% annual price escalation (inflation) rate. When the same values are assumed in the calculation of benefits, the two can be compared.

---

<sup>79</sup> Ibid.

<sup>80</sup> Ibid.

**Table 32. Assumptions for Life-cycle Benefit and Cost Analysis**

Parameter	Value
General Inflation Rate	2%
Discount Rate	10%
Service Life	10 years
Utility Fixed Charge Rate	11%
Customer Fixed Charge Rate	15%
Fuel Cost, Natural Gas (surface CAES only)	\$5/MBTU
Electricity Cost, Charging	10¢/kWh

### **6.3.2.3 Cost and Performance Assumptions**

Cost is calculated for a system by adding the cost of the storage unit and the power conditioning system. These subsystems are treated separately because they provide different functions and are priced by different ratings. Power components are priced in \$/kW. Energy storage units are priced in \$/kWh. For this reason, the individual subsystem costs are needed, although they are often difficult to separate from vendor system prices. The values used in this update are listed in Table 33 , along with references.

The costs in Table 33 are based on certain standard assumptions for the applications and technologies considered, and on expert opinion. They are meant to be used for comparative purposes. The actual costs of any storage system depend on many factors and the assumptions and the means of calculating some of the values used are subjective and continue to be debated, even among experts in the field.

**Table 33. Cost and Performance Assumptions**

<b>Technology</b>	<b>Power Subsystem</b>	<b>Energy Storage Subsystem Cost</b>	<b>Round-trip Efficiency</b>	<b>Cycles</b>	<b>Source</b>
	<b>Cost</b> \$/kW	<b>\$/kWh</b>	<b>%</b>		
Advanced Lead-acid Batteries (2000 cycle life)	400	330	80	2000	8
Sodium/sulfur Batteries	350	350	75	3000	8, 9, 10
Lead-acid Batteries with Carbon-enhanced Electrodes	400	330	75	20000	8, 10, 13
Zinc/bromine Batteries	400	400	70	3000	10
Vanadium Redox Batteries	400	600	65	5000	11
Lithium-ion Batteries (large)	400	600	85	4000	8,10
CAES	700	5	N/A (70)	25000	8
Pumped hydro	1200	75	85	25000	10
Flywheels (high speed composite)	600	1600	95	25000	10
Supercapacitors	500	10000	95	25000	12

### 6.3.3 Results and Observations


#### 6.3.3.1 Results

The calculated values for present worth (\$/kW) are listed in Table 34 and shown graphically in Figure 85.

Table 34. Present Worth Cost of 10-year Operation in Year 1 (\$/kw)<sup>1</sup><sup>81</sup>

Technology/Use	Advanced Lead-acid Battery	Na/S (7.2 hr)	Zn/Br	V-redox	Lead-acid Battery with Carbon- enhanced Electrodes		CAES (8 hrs)	Pumped Hydro (8 hrs)	High-speed Flywheel (15 min)	Supercap (1 min)
	Li-ion									
Long-duration storage, frequent discharge	2839.26	2527.97	2518.03	3279.34	2017.87	2899.41	1470.10	2399.90		
Long-duration storage, infrequent discharge	1620.37	2438.97	1817.82	2701.41	1559.57	2442.79				
Short-duration storage, frequent discharge	1299.70		905.53	1459.85	669.85	1409.99			965.73	834.62
Short-duration storage, infrequent discharge	704.18		697.78	999.78	625.57	960.48			922.87	793.02

<sup>81</sup> Storage duration 4 hours, unless otherwise noted.



**Figure 85. Graphic Representation of 10-year Present Worth Cost**

### 6.3.3.2 Observations

As seen in Figure 85, present worth is highly variable, not only between technologies, but also between application categories. The most obvious difference is between long-duration and short-duration uses; long-duration use simply requires more storage capacity. The least expensive long-duration storage is found for CAES, but this of course requires an appropriate geologic site.

The differences between frequent and infrequent operation are also substantial for some technologies. Frequent use is more expensive because more electricity is purchased for charging, and because some technologies will outlive their cycle life during the 10-year time frame and expensive replacements will be required. Technologies with good cycle life are more attractive for applications requiring frequent charge and discharge.

## 6.4 Summary

Costs of energy storage systems depend not only on the type of technology, but also on the planned operation and especially the hours of storage needed. Calculating the present worth of life-cycle costs makes it possible to compare benefit values estimated on the same basis.

## 6.5 Extended Technical Discussion

Electric energy storage technologies have been discussed as essential grid assets that can provide services to increase the reliability and resiliency of the grid, including furthering the integration of variable renewable energy resources. Though they can provide numerous grid services, there are a number of factors that restrict their current deployment. The most significant barrier to deployment is high capital costs, though several recent deployments indicate that capital costs are decreasing and energy storage may be the preferred economic alternative in certain situations. However, a number of other market and regulatory barriers persist, limiting further deployment. These barriers can be categorized into regulatory barriers, market (economic) barriers, utility and developer business model barriers, cross-cutting barriers and technology barriers.

Through interviews with stakeholders and review of regulatory filings in four regions roughly representative of the United States, *Market and Policy Barriers to Energy Storage Deployment* identifies the key barriers restricting further energy storage development in the United States. The report also includes a discussion of possible solutions to address these barriers and a review of initiatives around the country at the federal, regional and state levels that are addressing some of these issues.

<http://www.sandia.gov/ess/publications/SAND2013-7606.pdf>

## Chapter 7. The Characteristics of and Process for Updating the Next DOE/EPRI/SNL/NRECA Electricity Storage Handbook

### 7.1 General Information

The U.S. Department of Energy (DOE) Office of Electricity Delivery and Energy Reliability (OE, <http://energy.gov/oe/>) collaborated with the Electric Power Research Institute (EPRI, <http://epri.com/>), Sandia National Laboratories (<http://sandia.gov>) and The National Rural Electric Cooperative Association (NRECA, <http://nreca.coop/>) to develop an updated version of the *DOE/EPRI 2015 Electricity Storage Handbook in Collaboration with NRECA* (the Handbook).

The overarching purpose of the Handbook was to provide stakeholders with information needed to (1) be familiar with storage technology types and their characteristics, (2) identify and characterize electricity-related challenges and opportunities which could be addressed with storage, and (3) specify electricity solutions and products that could address those challenges and opportunities.

This document describes the overall mission and purpose, scope, audience, notable challenges, and considerations affecting an update of the Handbook. The characterizations of those topics herein provide bases for discussion about the final mission and scope of the document among key stakeholders.

### 7.2 Approach

The approach taken to update the Handbook was to

- look at the previous versions of the ESHB;
- consider the audience;
- understand the reader feedback for the best way to share the information regarding energy storage; and
- help decision makers by considering installation requirements, cost, and life cycle using information and input from the previous versions to develop a better model for a most useful Handbook.

### 7.3 Data

#### 7.3.1 Mission for the Handbook

##### 7.3.1.1 *Introduction*

Broadly, there are two proposed versions of the mission for a handbook of this sort: one reflecting a narrower scope and one involving a broader scope.

## Chapter 7. The Characteristics of and Process for Updating the Next DOE/EPRI/SNL/NRECA Electricity Storage Handbook

A narrowly focused mission emphasizes information and processes that enable specification of an ESS for a given use case.

A broader mission expands ESHB coverage to include topics helpful for a more diverse audience seeking familiarity with possibilities for storage generally, and requirements for ESSs in specific use cases.

The most compelling purpose for a topic-specific handbook would be to provide prospective ESS users with information, frameworks, and tools that enable development of the ESS design mindset and development of an appropriate characterization of an ESS for a specific use case and for a specific circumstance. That is consistent with the narrower mission.

Certainly, there is a need for a document with the broader mission given the array and growing number of stakeholders seeking a richer understanding of and familiarity with storage opportunities. Arguably, that broader mission reflects two distinct audience types. One is a more technical/engineering audience focused on ESS design. The other is an audience with a somewhat technical perspective combined with a business/policy orientation.

While a broader mission may be desirable, it is also significantly more challenging and expensive to develop. It may also be a distraction from the primary need of enabling those prospective ESS users to develop an appropriate specification for a given challenge or opportunity. Those with a business/policy orientation may be better served with a separate guide/handbook tailored to their specific issues and needs.

### 7.3.1.2 Mission Statement

The mission includes:

- Provide a compendium of information necessary to specify safe and appropriate electricity storage solutions for the growing spectrum of electrical grid related needs, challenges and opportunities.
- Provide a compendium of timely information that enables technically competent stakeholders to specify safe, appropriate, and financially attractive electricity storage solutions for the growing spectrum of electrical grid related needs, challenges, and opportunities.

### 7.3.2 Audience for the Handbook

The audience for the Handbook includes appropriately qualified technical experts – especially engineers – who seek a general familiarity with ESS characteristics and design considerations or have a need to specify an ESS for a use case or circumstance.

The audience can, however, also include the growing number of nonengineer stakeholders who need a higher-level familiarity with design considerations and characteristics for grid-tied ESSs. That secondary audience includes (1) other utility planners and other decision-makers, (2) electric utility regulators, (3) energy policymakers, (4) legislators and their staff, (5) investors in ESS and electricity storage subsystems providers, (6) non-utility providers of electricity storage

Chapter 7. The Characteristics of and Process for Updating the Next DOE/EPRI/SNL/NRECA Electricity Storage Handbook

subsystems and ESS products and related services, and (7) commercial and possibly residential electricity consumers.

### **7.3.3 Handbook Development Approach**

#### **7.3.3.1 *Introduction***

Given the status of the state-of-the-art of design and specification of ESSs for utility services, core content will be updated, contributed, developed, or adapted by a team of knowledgeable experts, representing several perspectives and organizations. The development effort could be managed by SNLs' ESS Program or a similar organization.

#### **7.3.3.2 *Identify, Characterize, and Prioritize Topics***

The overarching purpose for the Handbook – to identify and describe electricity storage technology/products and uses and develop ESS specifications – can be quite involved. Once the mission, theme, and audience are established a key initial step in the planning process for the ESHB is to identify topics that the ESHB could and should include. That leads to another important step: determining the relative importance of the topics to be addressed. That prioritization – plus consideration of budget and other resource limitations – provides bases for decisions about which topics to address and the amount of detail provided for each topic.

It may be prudent to a survey of a selected group of 10 or 20 very knowledgeable persons – those who know what the ESHB should include and how to prioritize topics and tools – before finalizing the ESHB scope. As a starting point for discussion, consider a survey with 10 to 20 easy-to-answer questions plus a list of topics that allows responders to specify a qualitative score for each. Budget and goodwill from respondents allowing, there should also be a brief follow-up with key respondents to elicit thoughts and ideas that cannot be captured in a survey. This would provide helpful and auditable bases for prioritizing topics' coverage and detail.

#### **7.3.3.3 *Characterize the Specification Process***

Core content in the Handbook provides background and context for specification of an ESS solution or response for a given challenge and opportunity. Therefore, a significant portion of resources used will be focused on developing the ESS specification process steps and continuity. To the extent practical, that will include an emphasis on eliciting suggestions and perspective from the primary stakeholders and prospective Handbook users. There should be feedback between the specification process and identification, characterization, and prioritization of Handbook topics and content.

#### **7.3.3.4 *Collaboration***

Primary collaborators include scientists and researchers from at least three national laboratories: Pacific Northwest National Laboratory (PNNL, <http://pnnl.gov/>), Sandia National Laboratories (SNL, <http://www.sandia.gov/>) and National Renewable Energy Laboratory (NREL, <http://nrel.gov/>).

## Chapter 7. The Characteristics of and Process for Updating the Next DOE/EPRI/SNL/NRECA Electricity Storage Handbook

EPRI is expected to provide significant guidance about several key topics as well as some key content. EPRI's growing body of work involving the Energy Storage Integration Council (ESIC) is particularly relevant. (See Exhibit 2 for details about ESIC working groups.)

Important collaborators also include stakeholders from the three segments of the electric utility industry: investor-owned utilities, electric cooperatives, and public power entities. Several individual IOUs will be asked to collaborate on development of the Handbook. Participation by the IOU segment may also include collaboration with the Edison Electric Institute (EEI, <http://eei.org>), a trade association. NRECA (<http://nreca.coop/>) is the primary research organization for the “electric cooperative” (co-op) segment of the electric utility industry. Similarly, the American Public Power Association (APPA, <http://publicpower.org/>) represents the interests of public and municipal electric utility entities. The APPA and possibly individual public power agencies, including municipal utilities, may also be invited to collaborate.

ESS vendors have a big stake in the Handbook as it will be a key resource for utility ESS system specifiers. As such, ESS vendors should be willing to provide significant assistance.

Prospective non-utility stakeholders, including electricity end-users/consumers and third party “merchant” developers, have a growing stake in topics addressed by the Handbook. To the extent practical, input from those stakeholders should also be sought.

Electric utility regulators are another possible category of collaborators. At the federal level are the Federal Energy Regulatory Commission (FERC, <http://ferc.gov/>) and an important surrogate organization of the FERC, the North American Electric Reliability Corporation (NERC, <http://nerc.com/>). It may also be desirable to collaborate with selected state electric utility regulators or their coordination organization – the National Association of Regulatory Utility Commissioners (NARUC, <http://naruc.org/>).

It may also be desirable to include representatives from and/or knowledgeable stakeholders in the regional electricity “independent system operators” (ISOs) and “transmission system operators” (TSOs) as collaborators.

Finally, possible collaborators could include representatives from power engineering and standards related entities: leading power engineering universities, the Institute of Electrical and Electronics Engineers (IEEE, <http://ieee.org/>), the International Energy Agency (IEA, <http://iea.org/>) and the (U.S.) National Fire Protection Association (NFPA, <http://nfpa.org/>).

### **7.3.3.5 The Handbook as a Modular Living Document**

For a variety of reasons – described below – it is increasingly compelling to develop reports that form modular content for electronic living documents.

A modular living document (MLD) model enables a phased approach to development and publication. To the extent that budget and time are too limited to produce a “complete” document in a timely way, this approach allows for development and publication of the highest-priority content during an initial phase. Additional, lower-priority content can be developed and published when budget and time are available. It also enables development of preliminary

Chapter 7. The Characteristics of and Process for Updating the Next DOE/EPRI/SNL/NRECA Electricity Storage Handbook

versions of content, with less detail than a final version might include, to be updated later when resources are available.

An important consideration affecting both the content and form of the Handbook is the accelerating pace of technical and institutional change(s) with respect to storage specifically and the electricity industry generally. The content addressed by the Handbook is, to an increasing extent, a moving target. Consider the following theme categories that are changing in no particular order:

- Electro and electrical technologies – primary and subsystems (for example, DESS, grid interconnection, PCSs, technologies that “compete” with or complement storage.)
- Utility “services and products” and related “benefits and costs”
  - \* Security and cybersecurity
  - \* Grid infrastructure and power/energy resource communications and control technology, needs, standards, and practices
  - \* Electricity market structures and pricing
  - \* Grid operation best practices
  - \* Grid/power engineering design, capacity planning and operations models and modelling practices
  - \* Financial and benefit/cost models and modelling practices
  - \* Storage-related design, siting, and operation standards and best practices
  - \* The expanding array of alternatives to storage and storage-enabling technologies (especially inverters and optimization algorithms)
  - \* Regulatory provisions and rules

Given these rapid changes, it is prudent to contemplate and plan for ongoing, periodic updates to the Handbook. A document designed and produced as an MLD can be readily updated as important developments occur. Specifically, the MLD approach enables incremental updates of select content when timely rather than having to wait until a complete document update can be justified. (In the past the Handbook has been published as a static document to be updated periodically.)

In addition to enabling inclusion of current, timely, up-to-date information, a living document could enable a variety of stakeholders to provide feedback. This may include valuable suggestions about new or updated content (for example, relevant standards, practices, tools, policies, regulations).

Modular content can be used for a variety of purposes. That is, content developed for one report can be included in another one. That avoids redundancy – of content and effort – and in some cases eliminates the possibility of conflicting data or information in various documents. It may even be attractive as a means to provide stand-alone topical content for a variety of uses. Topical examples include but are not limited to:

- \*\* Storage technology descriptions
- \*\* Storage services: descriptions and financial benefits
- \*\* Value propositions/Use cases
- \*\* Alternatives and competitors

Chapter 7. The Characteristics of and Process for Updating the Next DOE/EPRI/SNL/NRECA Electricity Storage Handbook

\*\* Regulations and standards characterizations

### **7.3.3.6 Project Team**

There is a broad and growing array of storage stakeholders, many of whom are willing to participate in developing the scope, priorities, and content of the Handbook. Adept coordination is essential to ensure use of these resources is optimized within the defined scope, budget, and timeline. Given the foregoing and the unique nature of the Handbook, developing a “management structure” and well-scoped teams will be critical for successful development of a valuable and useful Handbook. One possible project management structure is as follows.

### **7.3.3.7 Executive Oversight Committee**

The Executive Oversight Committee (EOC) provides high-level guidance and oversight regarding the overall scope and approach used to develop the Handbook. It should be limited to five to six members, especially including co-sponsors. As such, it could include representatives of the DOE, SNL, PNNL, EPRI, and NRECA.

### **7.3.3.8 Executive Advisory Group**

The Executive Advisory Group (EAG) provides insight and recommendations for the Handbook’s scope and the approach to use to develop that scope. That could include, for example, a representative from organizations including leading utilities, APPA, EEI, FERC, NERC, NARUC, and/or state electric utility regulators and possibly standards groups such as the IEEE.

### **7.3.3.9 TECHNICAL ADVISORY GROUP**

The Technical Advisory Group (TAG) is a more informal team of advisors who provide more detailed, technical input regarding the content and descriptions within the Handbook. Ideally this group includes prospective users.

## **7.3.4 The Handbook Scope**

Following are brief characterizations of key scope items (that is, topics) addressed in the Handbook. (See Exhibit 1 for preliminary content outline.)

### **7.3.4.1 Introduction**

The Handbook includes information that enables technically competent stakeholders to be familiar with ESS characteristics that are needed for a growing spectrum of grid services and use cases. It also provides ESS specifiers with key information needed to develop a detailed specification that can be used to elicit proposals ranging from informal expressions of interest to actual proposed solutions.

Given the broad scope of storage for utility-related uses, and given the circumstance-specific nature of many needs and opportunities that storage can address, it is not practical to address some topics in detail. For those topics, the Handbook includes introductory information and

Chapter 7. The Characteristics of and Process for Updating the Next DOE/EPRI/SNL/NRECA Electricity Storage Handbook

characterizations and suggested approaches and listing of other resources (that could be used to address those topics in more detail).

#### **7.3.4.2 Key Scope Items**

The objectives underlying the Handbook's design (including content selection, prioritization, detail and development) are to enable targeted stakeholders to establish the mindset needed to consider, evaluate, specify, and procure appropriate ESS solutions for a specific use case/circumstance.

#### **7.3.4.3 Electricity Storage Technology**

Although the ESS specification process is technology-neutral, it is necessary to provide users with basic familiarity with the various storage technologies, as well as their cost and performance characteristics. That includes characterizations of electricity storage subsystems and fully integrated electricity storage systems. Another important facet of ESS is its safety-related characteristics, standards, and considerations. A technology-related background helps to inform specifiers about what is possible and what to expect when potential solutions/products are proposed.

#### **7.3.4.4 Electricity Storage Services, Benefits, and Use Cases**

Each circumstance (need or opportunity) for which a storage solution/product may be desirable is unique. Therefore, the Handbook covers the wide array of the individual services that ESS can provide and the financial benefit associated with those services. Grid services related to the utilities' electricity supply, transmission and distribution systems, and electricity end-use related needs are also addressed.

The concept of combining various services and “stacking” the related benefits as building blocks for ESS use cases (also known as value propositions) is described. This includes a discussion of the practical and technical limitations regarding combined services and stacked benefits. Coverage of more common and compelling use case/value proposition examples will be included. That coverage will feature the DOE Global Energy Storage Database (<http://energystorageexchange.org/>) which provides information about actual ESS assessments and deployments.

## Chapter 7. The Characteristics of and Process for Updating the Next DOE/EPRI/SNL/NRECA Electricity Storage Handbook

### 7.3.4.5 The Specification Process

Two primary elements of the ESS specification process addressed in detail are the process of defining the specific use case to be addressed and developing the appropriate specification for the ESS needed to address the specific circumstance/use case being evaluated.

That process includes various steps and continuity like that shown in the diagram to the right.

A key element of this part of the process likely involves use of the *Energy Storage Technical Specification Template* being developed under auspices of EPRI's ESIC program.

### 7.3.4.6 Procurement and Deployment

The Handbook provides at least some coverage of the procurement process and possible procurement approaches such as ESS ownership structures, ESS rentals or leases, and contracts for purchase and/or procurement of ESS services. Similarly, the Handbook addresses possible means/approaches to control, operate, and maintain ESSs.

### 7.3.4.7 Appendices: Details, Tools, and Resources

Several appendices provide details not covered in the main body of the Handbook.

Topics addressed by appendices could include, for example, (1) checklists, (2) other important information/data resources, models and tools – especially those of national laboratories, EPRI/ESIC, and state energy offices, (3) details and standards related to safe and appropriate electricity storage solutions and operation, (4) ESSs and microgrids and renewable energy resources integration, 5) various types of and uses for models, and 6) important electrical “protection” and interconnection related information, data, and practices.

```

graph TD
    A[screening-level benefit estimate] --> B[define the challenge or opportunity]
    B --> C[define the technical solution1]
    C --> D[issue RFP, RFI, RFQ]
    D --> E[possible solutions' characteristics & cost]
    E --> F[assess technical viability2]
    F --> G[detailed benefit/cost assessment]
    G --> H[assess procurement approaches]
    H --> I[go/no go decision]
    I --> A
    C --> J[reassess, revise]
    F --> K[reassess, revise]
  
```

1. Includes performance and physical characteristics. To the extent appropriate/necessary includes technical and financial evaluation and modelling such as that related to benefit/cost, integration/interconnecton and safety.
2. Includes performance, physical characteristics, maturity, new technology risk, “warranty,” safety, security, other standards, communications, etc.
3. Procurement alternatives: a) buy/own, b) rent/lease, c) pay-for-performance (“PPA” with third party or utility customer). Includes operation and maintenance.

### 7.3.5 Notable Challenges and Considerations

Following is a discussion of challenges and considerations to be addressed explicitly during the Handbook development planning process to ensure the document provides the best possible combination of coverage topics and details. Note that amidst these topics there is some degree of overlap.

#### 7.3.5.1 Notable Technical Challenges Will Affect Characterizations of Key Topics

The proposed approach of focusing on enabling development of an electricity storage specification has some notable technical challenges, especially those related to

- entity-specific biases and preferences,
- \*\*\*the circumstance-specific nature of needs and opportunities,
- \*\*\*the accelerating evolution of ESS standards, best practices, and regulatory (technical) rules, and
- \*\*\*limited availability of financial and technical evaluation methods and tools.

For the Handbook to be a useful and timely resource, it is critical to identify and prioritize the most important technical challenges and to establish specific tactics to address them in the most efficient manner possible, given resource limitations.

#### 7.3.5.2 Circumstance-specific Technical Challenges

The technical challenges related to the circumstance-specific nature of the needs and opportunities to be addressed include, but are not limited to entity-specific engineering best practices and tools, and location-specific electrical effects, protection, reliability, power quality, and interconnection.

#### 7.3.5.3 Tools and Modelling Related Technical Challenges

A key facet of any ESS solution related evaluation involves assessment of benefits and the relationship between ESS technical characteristics and benefits. Currently, there are a very limited number of tools available to undertake artful technical assessment of electrical and electricity supply integration related impacts and considerations. Furthermore, tools and methodologies needed for robust assessment of the important subject of interplay/tradeoffs between ESS benefits, costs, performance characteristics, and operation are yet to be developed.

#### 7.3.5.4 Developing Use-case-specific Discharge Duration

Perhaps the most significant challenge is providing a straightforward, generalized, and yet robust characterization of storage discharge duration for some services and use cases.

Consider the demand charge management service as an example. For that service, the discharge duration is heavily dependent on the key provisions of the applicable tariff – which can vary significantly among utilities and customer classes. Specifically, the schedule/timing and magnitude of demand charges varies significantly among tariffs. Furthermore, establishing the

## Chapter 7. The Characteristics of and Process for Updating the Next DOE/EPRI/SNL/NRECA Electricity Storage Handbook

discharge duration is often complicated by the schedule/timing and magnitude of a tariff's energy prices. Other complicating considerations may include demand profiles which can vary depending on season, weather, and changing end-use types and patterns.

Similar challenges affect estimation of the discharge duration required for the time-of-use (TOU) energy cost management service.

In some cases, it may be necessary to do at least some optimization – which might include heuristic, stochastic or statistical analysis – to establish the appropriate discharge duration for specific circumstances. That may be especially important if there is non-trivial uncertainty about power use, energy use, energy price, or capacity/demand charges.

### **7.3.5.4.1 Conclusions and Recommendations**

Given the background, it is critical to consider important technical changes affecting characterizations in the Handbook at the outset, to scope those characterizations, and to establish the degree of detail and resources to be allocated to them.

### **7.3.5.5 Storage/Subsystem Technologies and ESS Products are Moving Targets**

Electricity storage technologies, subsystems, and related products are evolving and improving at an incredible and accelerating pace. Furthermore, ESS design practices and standards are still in somewhat formative stages.

We must also consider the rapid evolution of (1) electrical grid infrastructure configuration and design best practices, especially those involving distributed and modular electro-technologies, (2) electrical grid operation philosophies and best practices, (3) communications and control requirements, (4) wholesale and retail electricity markets, including “products” and prices, (5) electric utility regulations, (6) emphasis on environment and sustainability, and (7) the spectrum and number of ESS stakeholders.

### **7.3.5.5.1 Conclusions and Recommendations**

The Handbook should be designed to provide timely and relevant content that reflects and accommodates changes over time. As such it should be designed to be updated periodically.

Given that that ESS for the grid is still developing, it is important to provide means for ESS specification practitioners to share insights and lessons learned for users of the ESHB and as input for future additions and improvements. Feedback and shared insights could be included at the end of each section of an online (living document) version of the ESHB. Enabling knowledgeable stakeholders to share lessons learned and insights could be a valuable feature of a living document, can enhance the timeliness of the content, and could provide important indications of how the ESHB can be improved or enhanced.

### 7.3.5.6 Accurate, Timely Storage Cost Data is Challenging, Evolving, and Expensive to Gather/Compile/Verify

Ideally, the Handbook would include up-to-date and accurate cost for all subsystems and products that might be part of an ESS for a specific use case. However, ensuring that such data are complete, up to date, and accurate is challenging, given:

1. the accelerating evolution of storage technology, subsystems and product;
2. evolving competition, supply, demand, and resulting market forces;
3. the propensity for vendors to provide price data that reflects unjustified optimism, blind spots or partial information, and data that reflect insufficient candor; and
4. confidentiality of cost quotes by vendors to customers.

Furthermore, the specifier may have to develop cost based on prices for individual subsystems.

#### 7.3.5.6.1 Conclusions and Recommendations

Providing “good” storage cost data is challenging at best and is likely to require a significant amount of budget and people resources that would likely be better spent on providing the best information and guidance possible for establishing the technical specifications for a given ESS solution. It may be best to emphasize reliance on vendors to provide a price estimate for a given ESS specification rather than placing significant emphasis on enabling ESS specifiers to undertake any but the most cursory cost estimates.

One approach is to include helpful guidance needed for specifiers to have a good familiarity with ESS cost elements and/or cost for individual subsystems, and total cost coupled with some representative ESS price data (and possibly for key subsystems) that can be used to demonstrate how cost calculations are made. That is meant to enable specifiers to use vendor prices to perform important or necessary in-house cost calculations and to effectively evaluate the reasonableness and completeness of vendor prices.

Although most utilities have in-house means to calculate and assess costs, it is possible that providing a few basic cost worksheets (presumably Excel) would be helpful for a subset of the audience, especially non-utility entities. Providing those would be relatively inexpensive.

### 7.3.5.7 It Is Quite Challenging to Do Robust Benefit Estimates

As described above, presently, it is challenging to evaluate the important interplay between ESS technical requirements/performance, benefits, and costs. In fact, to optimize many ESS value propositions it may be necessary to optimize ESS design and operation by evaluating more than one possible combination benefits and costs. Unfortunately methodologies and tools to accomplish such benefit/cost assessments and optimization do not exist or are just being developed.

#### 7.3.5.7.1 Conclusions and Recommendations

Important themes to address explicitly and robustly during the planning process for the Handbook are modelling-related needs; the dearth of related tools, practices, and methodologies; current and expected alternatives; and interim approaches.

### 7.3.5.8 If/How to Address How Storage Compares to Competing Alternatives?

Storage is not coming to the fore in a vacuum. In many cases there may be one or more competing solutions. For any particular location or circumstance, competing alternatives may include:

- distributed generation
- geographically targeted demand response
- geographically targeted energy efficiency
- geographically targeted innovative energy and demand pricing
- electric vehicle (EV) charging management and related synergies

Emerging alternatives include “frequency response” devices that can provide demand-side solutions for ancillary services and increasingly sophisticated members of the Flexible AC transmission system family of devices for T&D management including static VAR compensators (SVCs) and static synchronous compensators (STATCOMS).

#### 7.3.5.8.1 Conclusions and Recommendations

It seems both desirable and important to address how storage compares to the alternatives.

### 7.3.5.9 Need to Incorporate EPRI ESIC Materials

A key source of content for the Handbook will be materials, tools, and practices developed under auspices of EPRI’s ESIC program. Note, however, that ESIC is only addressing distribution-level ESS deployment and considerations, although there is some increasing emphasis on “customer side of the meter” ESSs.

#### 7.3.5.9.1 Conclusions and Recommendations

It is important to undertake an assessment of ESIC products that can/should be incorporated into or adapted for the Handbook and to identify gaps regarding ESS benefits and services involving other use categories (electric supply, grid operations/ancillary services, transmission, and customer side of the meter) and the means to address those gaps.

## 7.3.6 TERMS AND ACRONYMS

**Benefit** – a quantified financial amount or qualitative reason that electricity storage is used. Quantified financial benefits include reduced or avoided cost or increased revenue or profit. Note that significant qualitative benefits may also exist.

**Electricity Storage System** – integrated ESS subsystems that are necessary for electricity storage used for an electrical grid use case.

**ESIC** – Energy Storage Integration Council (EPRI).

**ESS** – electricity storage system.

**MLD** – modular living document.

**Service** – a specific electricity storage system use or application with a corresponding benefit.

**Use Case** – one or more services that provide a combination of benefits (that is, a value proposition) that may be generic or may be for a specific circumstance.

### 7.3.7 EXHIBIT 1. PRELIMINARY HANDBOOK OUTLINE

This preliminary outline was developed per current ESHB feedback and detailed discussions about content. It serves as a point of departure, to be refined once the mission and scope are finalized.

Section 1. Background and Introduction (5 pages) .....
Objectives and Goal Addressed.....
Primary Stakeholders .....
Establishing the Mindset.....
About this Handbook (content).....
Using this Handbook .....
Section 2. Introduction to Electricity Storage Technology (15 - 20 pages)..
Introduction.....
Electricity Storage Media.....
Electricity Storage Systems.....
Electricity Storage Characteristics .....
Electricity Storage Operation Basics .....
Electricity Storage Cost Basics.....
Electricity Storage Technologies' Status and Maturity Overview.....
Section 3. Services, Benefits and Use Cases (30 – 40 pages) .....
Introduction (what are services, benefits and use cases).....
Electricity Supply .....
Electricity Supply Operations (ancillary services) .....
Electrical Transmission and Distribution Infrastructure .....
Electrical Transmission and Distribution Operations (electrical) .....
Electricity Consumer .....
Renewables Integration.....
Incidental Benefits .....
Use Case and Service/Benefit Building Blocks .....
Section 4. Use Case Examples (10 – 15 pages).....
Describe Key/More Common Use Cases (8 – 10) .....
DOE Global Energy Storage Database .....

Chapter 7. The Characteristics of and Process for Updating the Next DOE/EPRI/SNL/NRECA Electricity Storage Handbook	
Section 5. Defining the Challenge/Opportunity and Use Case (20 – 30 pages)...	
Characterize the Challenge/Opportunity .....	
Evaluation.....	
Characterize the Use Case.....	
Section 6. Specifying The Electricity Storage System (30 – 40 pages) .....	
Electricity Storage Characteristics for the Use Case .....	
Section 7. Procurement (5 - 10 pages).....	
RFP, RFQ, RFI.....	
Procurement Mechanisms (Own, Rent/Lease, “Service”). ....	
Section 8. Deployment (5 -10 pages).....	
Commissioning.....	
Appendix 1. Checklists .....	
Appendix 2. Information Resources .....	
Appendix 3. Electricity Storage Characteristics Details (20 - 30 pages) .....	
Appendix 4. Cost Details (10 - 20 pages).....	
Cost Elements .....	
Cost Metrics (\$/kWh out & LCOE, \$/kW installed, \$/kW-year) .....	
Utility-related Cost Considerations.....	
Appendix 5. Electricity Storage Operation Details (10 - 20 pages).....	
Appendix 6. Safety and Cybersecurity Details (10 - 20 pages) .....	
Appendix 7. Evaluation Tools and Models (10 - 20 pages) .....	
Appendix 8. Electricity Storage System Interconnection Details (5 - 10 pages) ..	
Appendix 9. Introduction to Electrical Microgrids (5 - 10 pages).....	
Appendix 10. Regulatory Entities and Considerations (10 - 20 pages) .....	

### 7.3.8 EXHIBIT 2. ESIC SCOPE OVERVIEW

The following is taken from the EPRI/ESIC web site:

[http://www.epri.com/Pages/EPRI-Energy-Storage-Integration-Council-\(ESIC\).aspx](http://www.epri.com/Pages/EPRI-Energy-Storage-Integration-Council-(ESIC).aspx)

#### Background

In 2013 the Energy Storage Program at EPRI, in collaboration with utilities, vendors, National labs, and industry experts created the Energy Storage Integration Council (ESIC). ESIC is an open and active venue, executed via a combination of in-person meetings, webcasts, and teleconferences, for identifying key gaps and common approaches for the integration of energy storage across key technical topic areas. The ESIC forum is initially focused on applications of energy storage connected to the utility distribution system (< 69 kV).

#### ESIC Mission

To advance the integration of energy storage systems through open, technical collaboration: guided by the vision of universally accessible safe, secure, reliable, affordable, environmentally-responsible, electricity

#### ESIC Published Resources

EPRI regularly publishes guidelines documents as they are developed and reviewed by ESIC participants. The current publicly available resources include the following.

*Energy Storage Integration Council: 2014 Update, Interim Guidelines for Distribution-Connected Energy Storage Deployments.* 3002003675

This document provides a project managers' guide to energy storage project lifecycle through all phases, including planning, procurement, deployment and integration, operations and maintenance, and decommissioning. It references additional resources and activities to support project stages.

*Energy Storage Technical Specification Template: Guidelines Developed by the Energy Storage Integration Council for Distribution-Connected Systems.* 3002006673

This document with editable fields is designed to be a common template for energy storage project developers to specify their projects and products with consistent terminology and definitions and for electric utilities to communicate their minimum requirements to the vendor community. It also serves as a valuable checklist to help ensure components of a successful project are identified.

Many additional resources are in-progress and being actively developed in the 5 working groups of ESIC. In-process documents are accessible on the ESIC Collaboration Site in working group spaces. <https://collab.epri.com/esic> (Registration and log-in required)

## General Meetings

ESIC general meetings are held 2-3 times annually for a single day at different locations across the U.S.

## ESIC Working Group Overview

ESIC is organized in topic focused working groups (WGs) that meet on a monthly basis. Work product focused subgroups meet more frequently, typically every 1-2 weeks to make progress on more specific deliverables

The five working groups (whose scope is summarized below) are all coordinating to define common approaches to the development and use of safe, reliable, cost-effective energy storage. Cross-group coordination is facilitated by Eva Gardow, ESIC Chair, and EPRI technical staff.

**WG 1 - Applications:** The Applications working group is focused on developing the functional and technical requirements of energy storage in distribution-connected use cases.

Chair: Bruno Prestat, Électricité de France (EdF) EPRI Co-chair: Stella Chen

**WG 2 - Performance:** The Performance group focuses on development of common metrics of performance for energy storage system, test protocols, and reference duty cycles to understand fully integrated energy storage system performance on a consistent basis.

Chair: Naum Pinsky, Southern California Edison (SCE) EPRI Co-Chair: Brittany Westlake

**WG 3 - System Development:** The System Development group is focused on developing common approaches to component and system standardization, technical specification, safety, and communications and control.

Chair: Ryan Franks, National Electrical Manufacturers Association (NEMA) EPRI Co-Chair: Steve Willard

**WG 4 - Grid Integration:** This group is focusing on installation and commissioning of storage for grid purposes. The group focuses on the actual deployment and usage of storage, they also are responsible for controls, dispatch, and protection of storage once installed.

Chair: Thomas Golden, Duke Energy EPRI Co-Chair: Steve Eckroad

**WG 5 - Analysis:** This group is focusing on developing methods and defining data and model requirements for considering energy storage in planning and operations processes.

Chair: Udi Helman, Helman Analytics EPRI Co-Chair: Paul Sanford

## 7.4 Summary

This chapter characterizes electric energy storage applications and related benefits, including a description of a means to estimate benefits. It also describes criteria and a framework for estimating market potential. It addresses the challenges of presenting data in a timely manner

Chapter 7. The Characteristics of and Process for Updating the Next DOE/EPRI/SNL/NRECA Electricity Storage Handbook

aiming to enable stakeholders to effectively analyze energy storage options, challenges, and opportunities.

## **7.5 Extended Discussion**

AEP studied the direct and indirect benefits, strengths, and weaknesses of DESSs and chose to transform its entire utility grid into a system that achieves optimal integration of both central and distributed energy assets. To that end, AEP installed the first NaS battery-based energy storage system in North America. After one year of operation and testing, AEP has concluded that, although the initial costs of DESS are greater than conventional power solutions, the net benefits justify the AEP decision to create a grid of DESS with intelligent monitoring, communications, and control, in order to enable the utility grid of the future. This report details the site selection, construction, and benefits of the first installation at Chemical Station in North Charleston, WV, and the lessons learned.

<http://prod.sandia.gov/techlib/access-control.cgi/2007/073580.pdf>

## LIST OF APPENDICES

- A. [Review of Selected Tools](#)
- B. [Storage System Cost Detail](#)
- C. [Sample Procurement Documents](#)
- D. [Utility and Owner Interconnected Costs and Schematics for Various Storage Systems](#)
- E. [Regulations](#)
- F. [Test Facilities](#)
- G. [Noteworthy Projects](#)
- H. [Life-Cycle Cost Analysis Figures for Mature Energy Storage Technologies](#)

## APPENDIX A: REVIEW OF SELECTED TOOLS

### Appendix A: Table of Contents

<a href="#">A.1</a>	<a href="#">Technology Screening: ES-Select</a>	<a href="#">A-4</a>
<a href="#">A.2</a>	<a href="#">Energy Storage Valuation Tool and Energy Storage Computational Tool</a>	<a href="#">A-7</a>
	<a href="#">A.2.1 Energy Storage Valuation Tool by EPRI</a>	
	<a href="#">A.2.2 Energy Storage Computational Tool</a>	
<a href="#">A.3</a>	<a href="#">Production Cost Simulation</a>	<a href="#">A-11</a>
	<a href="#">A.3.1 Production Cost Modeling</a>	
	<a href="#">A.3.2 Limitations</a>	
	<a href="#">A.3.3 Data Requirements</a>	
	<a href="#">A.3.4 PLEXOS</a>	
	<a href="#">A.3.5 UPLAN-NPM</a>	
	<a href="#">A.3.6 Load Flow/Stability: PSS/E and PSLF</a>	

### Appendix A: List of Figures

<a href="#">Figure A-1. ES-Select Overview</a>
<a href="#">Figure A-2. ES-Select Design and Functionalities</a>
<a href="#">Figure A-3. Screen Capture of ESVT Main User Interface</a>
<a href="#">Figure A-4. Illustration of ESVT Operation</a>
<a href="#">Figure A-5. ESVT Example Output: Energy Storage Annual Revenue by Grid Service</a>
<a href="#">Figure A-6. ESVT Example Output: Simulation of Storage Charge/Discharge Dispatch</a>
<a href="#">Figure A-7. Methodology for Determining the Monetary Value of an Energy Storage Deployment</a>
<a href="#">Figure A-8. Detailed Schematic Model of UltraCapacitor and Grid-Tied Inverter</a>
<a href="#">Figure A-9. Damping of Inter-area Oscillations</a>
<a href="#">Figure A-10. Generator Speed Difference</a>
<a href="#">Figure A-11. Generator Speeds at Five Buses in the WECC With/Without Damping Control</a>

### Appendix A: List of Tables

<a href="#">Table A-1. Summary Matrix of Energy Storage Evaluation Tools by Functionality</a>
---

## REVIEW OF SELECTED TOOLS

Table A-1 shows the main categories of energy storage simulation tools. Energy storage tools often have overlaps in applications and therefore main applications of a tools are represented with a black dot and secondary applications are represented with an open dot.

## Appendix A: Review of Selected Tools

**Table A-1. Summary Matrix of Energy Storage Evaluation Tools by Functionality**


Modeling Tool	ES Models and Tools					Electricity Storage Technology Screening	Electricity Storage Cost Effectiveness	Grid Operations and Control
	Resource Portfolio Planning	Production Simulation	Load Flow/ Stability	Dynamic Simulation				
Demand Side Management Option Risk Evaluator (DSMore)	●						○	
Electric Generation Expansion Analysis System (EGEAS)	●						○	
Electricity Market Complex Adaptive System (EMCAS)	●	○					○	
Integrated Planning Model (IPM)	○						○	
North American Electricity and Environment Model (NEEM)	●						○	
National Energy Modeling System (NEMS)	●						○	
Portfolio Optimization Model (POM)	●						○	
Regional Energy Deployment System (ReEDS) Model	●						○	
Aurora XMP (Aurora)	○						●	
Day-Ahead Locational Market Clearing Prices Analyzer (DAYZER)	○				●		●	
Flexible Energy Scheduling Tool for Integration of Variable Generation (FESTIV)				●			●	
GE Multi-Area Production Simulation Software (GE MAPS)	○	●					○	
GridView	○	●					○	
HOMER	○	●	●				○	
PLEXOS		●	●				○	
Portfolio Ownership and Bid Evaluation (PROBE)		●	○				○	
PROMOD IV		●	●				○	
REFlex					○	○		
UPLAN Network Power Model (NPM)	●	●	●				○	
ETAP Grid: Transmission Software		●	●					
GE Concordia Power Systems Load Flow Software (PSLF)		●	●		○			
GE Power System Dynamic Simulation (PSDS)					●			
Integrated Dispatchable Resource Optimization Portfolio (IDROP)		●	●	○			○	
Power System Simulator for Engineering (PSS/E)		●	●					
PowerFlow & Short Circuit Assessment Tool (PSAT)		●	○	○				
PowerWorld Simulator (PWS)		●	●					
TRANZER		○	○					
Electricity Distribution Grid Evaluator (EDGE) Model	●	●					●	
ES-Grid	●	○					●	
ETAP Grid: Distribution Software			●	●				
GridLab-D		○	●					
KERMIT			●	●			○	
LoadSEER	○	●					●	
Open Distribution System Simulator (OpenDSS)		●	●	●				
SynerGEE		●						
WindMil			●					
Alstom Distribution Management System - Demand Response Distributed Generation (DMS – DRDG)								●
Decentralized Energy Management System								●
Distribution System Operations Solution								●
GE Distribution Management System								●
Oracle Distribution Management System (DMS)								●
OSI Spectra Distribution Management Systems								●
Advance 2 Control	○					○	●	
Battery XT						○	●	
BOS4						○	●	
Core Operating System						●	●	
Cost Performance for Redox Technologies						●	●	
DynaTran						●		
Energy Operating System							●	
Energy Storage Computational Tool					●	●		
Energy Storage Valuation Tool					●	●		
Energy System Model					○			
ES Simulator						●	●	
ES Select					●	●		
Frequency Regulation Performance Model				●		●		
GridStore	○					●		
Joule.System						●		●
Market Revenue Optimization Model for Behind-the-Meter Storage Projects							●	
Market Revenue Optimization Model for Grid-Connected Storage Projects							●	
Microgrid Optimizer							●	
OnCommand								●
PowerScope						●	●	
1E Storage Integrator								●
WindStore							●	
	● tool is well suited for the application							
	○ tool has some functionality for the application							

## A.1 Technology Screening: ES-Select

The ES-Select™ Tool aims to improve the understanding of different electrical energy storage technologies and assess the feasibility for intended applications in a simple, visually comparative form. This tool treats the uncertainties in technical and financial parameters as statistical distributions.

ES-Select™ was created by KEMA in collaboration with Sandia National Laboratories. It is licensed for public use.

A sample screen capture from ES-Select™ Tool is shown in Figure A-1.




**Figure A-1. ES-Select Overview**

ES-Select is designed to work with the uncertainties of storage and applications characteristics, costs, and benefits and provides answers in reasonable ranges. It applies the Monte Carlo analysis to choose randomly hundreds of possible values within the provided ranges of input parameters to calculate the range of possible answers. In this educational/screening tool, simplicity is more important than precision. This decision support tool is made for the initial screening purpose. Most facts are still unknown to the user, but some decisions must be made based on what is known at this point.

ES-Select assumes the most likely values for all project parameters that it needs, allowing the user to overwrite these values if more accurate information is available. The objective behind this design principle is to make the tool useful to both a novice user, who needs to be educated on reasonable values, as well as an experienced user, who knows exactly what the problem is and has all relevant data ready to enter.

The main outputs of ES-Select are expected ranges of cash flow, present value, and payback for all storage options for selected applications. The tool also helps users plot all financial and physical parameters of applications and storage options for comparative studies. Figure A-2 shows an overview of ES-Select design and functionality.



**Figure A-2. ES-Select Design and Functionalities**

ES-Select helps decision makers:

- To understand and compare accurately the costs and benefits of various energy storage technologies,
- To identify and compare applicable electricity storage parameters, and
- To develop a preliminary business case for specific services and/or use cases.

ES-Select performs the following key functions:

- Allows selection of a grid location to deploy energy storage;
- Allows selection of two or more grid services and/or use cases to be bundled to increase the total value of an electricity storage system;
- Recommends feasible electricity storage options for the selected grid services and/or use cases;
- Considers the uncertainty in cost and benefit numbers, as well as other factors, and does calculations based on a probabilistic distribution comparing the different energy storage options; and
- Provides distributions of economic and technical parameters for graphic comparison and sensitivity analyses.

Although ES-Select has many strong capabilities, it is only the starting point toward a comprehensive analysis of an energy storage system. In its current form, it does not allow:

- Specification of system location in the United States (or world) and the associated parameters (market environment, etc.),
- Detailed specification of location on the grid,
- Specific size of the system,
- Modification of technology parameters (although it does allow new technologies to be added),
- Specification of prices for various grid services, or
- Modification of many calculation assumptions.

Some of these limitations are because the tool is intended for high-level analysis and screening, and some are because it is a publicly available tool. Future versions of the tool will address some of these limitations. Future versions will continue to be publicly available.

To run the model, no data are required, although the user must be knowledgeable about the general grid location for the system, services that are required by the grid (an estimated breakdown of system use if multiple services will be provided), and basic financial assumptions including peak and off-peak energy prices, cost of capital, and cost of equity.

The results from running ES-Select will indicate the appropriate technologies that are the best fit to provide the required services in the selected location based on installed cost, technology performance to meet service requirements, relevance to the selected location, and commercial maturity. Also provided are distributions to estimate what the user might expect based on his or her input parameters for economic value, market potential, cost of ownership, and payback period for the best-fit technologies. Distributions for technology characteristics are also available, including cycle life, discharge duration, efficiency, and energy density.

Using this output, a decision maker would be able to determine whether energy storage is a feasible option for specific requirements, the technologies that might be applicable along with their characteristics and expected costs, and an estimation of the expected economic value from the use of a storage system. Such information could be used to inform the use of the

## Appendix A: Review of Selected Tools

other tools detailed in this section to conduct a comprehensive performance and economic analysis to estimate the technical and economic performance that can be expected in the actual use of the selected storage systems.

## A.2 Energy Storage Valuation Tool and Energy Storage Computational Tool

### A.2.1 Energy Storage Valuation Tool by EPRI

EPRI has developed the Energy Storage Valuation Tool Version 3.1 (ESVT) to enable the assessment of energy storage cost-effectiveness in different use cases. ESVT was designed with goals of (1) site-customizable, (2) user-friendly, and (3) model and input transparency.


With a step-by-step user interface, it guides the user through the necessary steps to define and enter data for energy storage use cases (Figure A-3). ESVT calculates the value of energy storage use cases taking into account the full scope of the electricity system, including system/market, transmission, distribution, and customer services. ESVT also models a wide range of pre-loaded storage technologies, including several battery technologies, CAES, and pumped hydropower, leveraging EPRI's domain expertise in understanding the cost and performance of different storage technologies. It also models combustion turbine operation for business case comparison purposes. Input parameters of all technologies can be customized to best match the knowledge and expectations of cost and performance of the user.

The screenshot shows the Energy Storage Valuation Tool 3.1 interface. It is a web-based application with a clean, modern design. The top header features the EPRI logo and the title 'Energy Storage Valuation Tool 3.1'. The interface is organized into four main sections, each with a distinct header and a series of input fields and buttons:

- Step 1: Select Grid Services for Analysis**
  - ISO/RTO/Service Area: CAISO: 2011
  - Enable Optimization: Yes
- Step 1b. : Define Grid Service Requirements**
  - System Market Inputs
  - Transmission Inputs
  - Distribution Inputs
  - Customer Premise Inputs
- Step 2: Select Financial and Economic Assumptions**
  - Ownership type: IOU
  - Discount Rate: Calc
  - Financial and Economic Inputs
- Step 3: Select Energy Storage System Performance Characteristics and Costs**
  - Technology: Li-Ion: 1 MW/4 Hour
  - Discharge Duration: (Hours): 4
  - Discharge Capacity: (kW): 1000
  - Storage System Capital Costs: (\$): \$3,600,000
  - Storage System Capital Co... (\$/kW): \$3,600
  - Define Custom Storage System (Optional)
- Step 4: Calculate Results**
  - Calc All
  - NPV Cost vs. Benefit
  - Annual Services Revenue
  - Daily Revenue
  - Daily Dispatch
  - Financial Results
  - Technical Results
  - Service Specific Results
  - Model Details


Figure A-3. Screen Capture of ESVT Main User Interface

ESVT simulates energy storage operation for different use cases with compatible grid services, based on user selections of location-specific load and price data, owner financial characteristics, and technology performance and cost information. The ESVT simulation engine uses a hierarchical dispatch that prioritizes long-term commitments over shorter ones and co-optimizes for energy storage system profitability across services where decisions are made in the day-ahead market. A diagram of the key inputs, model operation, and outputs are displayed in Figure A-4.




**Figure A-4. Illustration of ESVT Operation**

ESVT's outputs include financial results such as Net Present Value (NPV), financial pro forma statement, and technical simulation outputs such as cycle-life count. It also provides service-specific results such as annual revenue for each service and hourly dispatch results (Figure A-5 and Figure A-6). The tool calculates the potential value streams from the chosen grid service, accounting for the site-specific benefits and technical requirements to provide the service.



**Figure A-5. ESVT Example Output: Energy Storage Annual Revenue by Grid Service**



**Figure A-6. ESVT Example Output: Simulation of Storage Charge/Discharge Dispatch**

The Energy Storage Valuation Tool development continues with an updated model (Version 4) expected in mid-2014. Version 3.1 (issued April 2013) is currently available from [www.epri.com](http://www.epri.com) (Product ID: 3002000312).

### A.2.2 Energy Storage Computational Tool


The DOE Office of Electricity Delivery and Energy Reliability (OE) and the National Energy Technology Laboratory (NETL) tasked Navigant Consulting, Inc. to develop the Energy Storage Computational Tool (ESCT) to identify and quantify the benefits accrued through services provided by storage projects. The ESCT, an overview presentation, and a user guide can be downloaded from [www.smartgrid.gov](http://www.smartgrid.gov).

The ESCT identifies 18 applications and their benefits, categorized as Economic, Reliability, or Environmental. The ESCT helps the user analyze the costs and benefits to determine the storage system's overall value. With this tool, the user can determine project costs and benefits to gain a clearer understanding of the financial benefits of the storage deployment. The user can also use the ESCT to analyze costs and benefits of storage deployments under different scenarios and assumptions. The monetary value of the benefits calculated by the ESCT could be attributed to ratepayers/utilities, non-utility merchants, end-users, society, or a combination of these parties, depending on the nature of the deployment and the applications pursued. The primary and secondary benefits that the ESCT calculates are assumed to accrue to the owner unless otherwise specified in the name of the benefit.

However, in determining the total value of storage, the ESCT aggregates all benefits regardless of who the likely benefactor is. Therefore, if the user wishes to carry out a more detailed cost-benefit analysis that is more specific to user benefits, the user can designate which of the various benefits accrue to the user specifically and complete this analysis separately. *The tool was not specifically designed to yield results to be used in regulatory hearings or other similar proceedings.* Ultimately, the results of the tool are intended for educational/screening purposes only and are meant to provide insight that can be used in conjunction with other analyses to understand more clearly the impact and benefits of storage to the grid.

Figure A-7 depicts the overall methodology that the tool employs to determine the monetary value of an energy storage deployment. In summary, the ESCT:

1. Characterizes energy storage projects in terms of technologies employed, location on the grid, regulatory structure, owner, and applications;
2. Identifies the economic, reliability, and environmental benefits the storage project could yield;
3. Guides the user through the process of entering data required for calculating the monetary value of benefits and associated capital and O&M costs; and
4. Estimates the NPV of the energy storage system over its lifetime, displayed as graphs and tables.



**Figure A-7. Methodology for Determining the Monetary Value of an Energy Storage Deployment**

## A.3 Production Cost Simulation

### A.3.1 Production Cost Modeling

There are different production cost models, all aiming to deliver the same result: a security-constrained economic dispatch of a system's generation units to meet load. In the case of renewable energy technologies, energy storage technologies, and other new power system assets, production cost modeling can be especially valuable in not only ensuring that demand can be met, but also in quantifying the value of these technologies relative to a system without their service. Production cost modeling is the professional standard of evaluation that would be employed to demonstrate the ability of a storage system to contribute to operating effectiveness, thereby helping to make the case to investors or a PUC.

In the past, production cost models have operated at an hourly resolution, optimizing by hour the operation and economics of a system. That was all that was necessary when generation units were directly controlled and load was relatively stable. However, with the integration of variable renewable generation, the increase in demand, and the variability of this demand, the value of hourly optimization models is limited, especially when evaluating the benefits of energy storage services. Newer models have the ability to increase this resolution to five-minute intervals – a feature that is essential to evaluating the operation of storage in highly variable systems.

Using production cost modeling, the user can specify the optimization windows for the models to evaluate to emulate reality as closely as possible, or conversely, to evaluate the minimum possible cost or evaluate the maximum possible value of a system addition. This optimization

## Appendix A: Review of Selected Tools

window is the time frame over which the model will optimize dispatch at lowest cost. A daily window is the optimization of unit dispatch to meet demand over the day.

Specifically, using production cost modeling, the following analyses can be conducted:

- Economic analyses, including determining the overall production cost for an electricity system, the nodal electricity pricing for a system, and overall electricity pricing;
- Evaluating energy resource economics, including ancillary service, demand response, other contracts through basic markets analysis, and new asset analyses (including energy storage);
- Renewable energy analyses; and
- Service provision analyses.

Considering that the use of a production cost model requires detailed system data, including generator specifics, and at minimum, an hourly load profile (more on data requirements below), it develops a detailed characterization of a system's performance that can realize the above-listed analyses. This characterization includes:

- System-specific generation, load, assets, operations, market, ancillary service provisions;
- Overall costs: generation, start and shutdown, variable operation and maintenance, fixed costs, pump (charging) costs for storage, ancillary service costs, fuel costs, emissions;
- Pricing (system and nodal);
- Transmission line usage and congestion; and
- Nodal congestion.

This list highlights some of the value of a production cost model. There are other details that can be evaluated with the various production cost models available. More comprehensive information on their capabilities is available directly from the model vendors.

### A.3.2 Limitations

While production cost modeling is a very powerful tool and can provide valuable analysis, there are some limitations. Often, results from production cost modeling are cited without noting these limitations, potentially misleading the reader about the robustness of the results.

As generally used, these models are unable to quantify the value of added capacity and thus resource adequacy. This quantification is especially important when considering energy storage technologies. This limitation results from short-timeframe runs, usually only one year, due to process speed and data limitations. This limited time frame also presents issues in terms of risk in the form of load and renewables forecasting. For example, a value determined for a storage system that is associated with a 1-year run may not accurately represent the value of the system in future years.

When using production cost modeling, these issues should be supported by other analyses, such as multiple-year and sensitivity production cost runs. Presuming that these limitations are

## Appendix A: Review of Selected Tools

addressed, production cost models are particularly well adapted to the decision space occupied by vertically integrated, investor-owned, regulated utilities.

### A.3.3 Data Requirements

To evaluate a production cost model, the following items are required:

- Load data for the evaluation year in an hourly resolution, at minimum. For sub-hourly analysis, sub-hourly load data are required. For more comprehensive analysis, data for multiple years are necessary;
- Generation characteristics for all units on the system including max capacity, must-run requirements, seasonal ratings, ramp rates, heat rates, fuel types, start costs, variable O&M costs, maintenance details, and fixed costs;
- Transmission and distribution characteristics for nodal modeling: node specifications (load and voltage), transmission line details (max. and min. flow, resistance, and reactance);
- Fuel specifications;
- Reserve specifications: types, required provision, generators that can provide the reserve, and amounts that can be provided;
- Any contracts in place; and
- System operating constraints: for example, minimum or maximum limits.

### A.3.4 PLEXOS

PLEXOS is a newer production cost model that allows the user to implement various energy storage resources. While the model is based on a pumped hydro setup using water as the working medium, other energy storage devices can be emulated with the pumped hydro construct. Using an energy model of the pumped hydro setup, it is possible to set maximum and minimum energy levels, roundtrip efficiency, and generation and pump capacities, as well as any associated costs to model an energy storage system.

As discussed previously, a production cost model is unable to dispatch resources to model regulation reserves. Instead, it holds those regulation reserves in a “regulation raise (and lower) reserve” category, where they cannot contribute to energy or other ancillary services. Thus it is assumed they will be available to meet any regulation requirements. However, in an energy storage system, even with the assumption that is typically made of an energy net zero in serving regulation resources over a long-enough time frame – an hour in this case – there are losses due to the inefficiencies of charging and discharging. To address this energy loss, an auxiliary load is applied to the energy storage resources modeled. This means that whenever they are operating, there will be a load applied to the system. This continuous auxiliary load for each storage system type is calculated as:

$$\text{aux load} = (1 - \text{ac roundtrip efficiency}) * (25\%) * (\text{average regulation raise provision})$$

where ac round-trip efficiency is the storage system’s roundtrip ac-to-ac efficiency, 25% is an assumption of the amount of actual regulation energy demanded by the system relative to the amount provisioned, and the average provision is the averaged regulation reserve

## Appendix A: Review of Selected Tools

provision on the storage system over the year on an identical simulation run lacking an auxiliary load.

### A.3.5 UPLAN-NPM<sup>1</sup>

UPLAN Network Power Model (UPLAN-NPM) is another commercially available production simulation and network model that can be used by system planners to evaluate energy storage systems. UPLAN models the detailed physical and financial operations of electricity markets under conditions ranging from traditional regulation to today's post-restructuring competitive market structures. UPLAN-NPM integrates electricity market simulation with a full (ac/dc) transmission network model; it projects hourly Locational Marginal Prices (LMP), and is fully compliant with the market design specifications of FERC Order 2000 and Standard Market Design (SMD). UPLAN-NPM has been used to simulate and analyze such regional markets as PJM, New York, New England, MISO, ERCOT, and California. The day-ahead market is simulated in UPLAN by optimizing the commitment of resources for energy and all ancillary services taking into account transmission and inter-regional constraints. The commitment and dispatch algorithms incorporate both optimal power flow and resource scheduling to simulate the security constraints of a complete transmission network.

- UPLAN-NPM is a full network model designed to replicate the engineering protocols and market procedures of an operator. It captures the commercial activities, such as bidding, trading, hedging, and contracting, of all players in a restructured power market.
- UPLAN-NPM performs coordinated marginal cost-based energy and ancillary service procurement, incorporating operating costs, congestion management, and full-fledged contingency analysis. It incorporates Security Constrained Unit Commitment (SCUC) and Security Constrained Economic Dispatch (SCED) similar to those used by market operators.
- UPLAN-NPM co-optimizes energy and ancillary services market products (e.g., regulation, spin, non-spin, 30-minute spinning, and reliability must-run).
- UPLAN-NPM produces information on the projected hourly operation of generators, hourly balancing prices, and resulting generator energy delivered, as well as ancillary service revenue, costs, and net income. The model provides a projection of what is going to happen physically and financially throughout a region under specified circumstances (e.g., fuel prices, loads, outages). This enables the assessment of the engineering, economic, and financial implications of spatial and temporal changes in operations, reliability, production costs, and resources (e.g., generation capacity, retirements, remote and local renewable capacity, transmission expansions).

EPRI has conducted several regional case studies of energy storage using the UPLAN tool to illustrate approaches for modeling bulk and distributed energy storage systems. Some of these are listed below:

- Quantifying the Value of Hydro Power on the Electric Grid: Plant Cost Elements, EPRI, Palo Alto, CA, November 2011. EPRI Report 1023140.
- Grid Services from Hydropower and Pumped Storage, EPRI, Palo Alto, CA, December 2010, EPRI Report 1020081

<sup>1</sup> <http://www.energionline.com/products/uplane.aspx>, last accessed April 28, 2013.

## Appendix A: Review of Selected Tools

- Economic and Greenhouse Gas Emission Assessment of Utilizing Energy Storage Systems in ERCOT, EPRI, Palo Alto, CA, November 2009, EPRI Product ID: 1017824
- Impacts of Energy Storage Systems in Addressing Regional Wind Penetration: Case Studies in NYISO and ERCOT, EPRI, Palo Alto, CA, December 2010, EPRI Product ID: 1020082.

### **A.3.6 Load Flow/Stability: PSS/E and PSLF**

#### A.3.6.1 PSS/E

PSS/E is a software modeling tool developed by Siemens for use by electrical transmission planners and engineers. This software aids in designing and operating the transmission system. PSS/E can perform analyses such as power flow, fault analysis, dynamic simulations, and open access and pricing.

The PSS/E tool allows the user to see how the system can operate on a transmission system during dynamic and static loads. This knowledge helps the user determine the size of the energy storage required for stabilizing the electrical system. Most of the inputs are about the size, energy, and inverter parameters for filtering and response time.

Results include voltage and frequency stabilization and what contribution the energy storage system will have in providing short-circuit current on the system. PSS/E contains user cases that are pre-modeled for the Western Electric Coordinating Council (WECC), so adding energy storage in the WECC would be relatively simple because the model is already developed and basically validated.

Other models such as Positive Sequence Load Flow (PSLF) perform similar tasks. For small-signal analysis, software such as MATLAB/PowerSim may be more suitable. This is not as important at the transmission level compared to the distribution level.

Although other models exist, this version of the Handbook considers the widely industry-accepted models listed above.

#### A.3.6.2 Positive Sequence Load Flow (PSLF)

PSLF is a power system analysis software package offered by General Electric (GE). PSLF is capable of solving static load flow problems and performing dynamic simulations; it is intended for the evaluation of large-scale power systems with as many as 60,000 buses.<sup>2</sup> PSLF contains an extensive library of component dynamic models for transmission lines, generators, and loads, as well as control components, such as excitors, power system stabilizers, relays, transformers, tap-changers, and more, that a user can include as building blocks when modeling a large-scale power system.

---

<sup>2</sup> Power System Analysis Software,” [http://www.ge-energy.com/content/multimedia/\\_files/downloads/EC\\_Download\\_WilliamsS\\_Concorda%20PSLF%20Engine%20Fact%20Sheet%20GEA19666.pdf](http://www.ge-energy.com/content/multimedia/_files/downloads/EC_Download_WilliamsS_Concorda%20PSLF%20Engine%20Fact%20Sheet%20GEA19666.pdf), last accessed March 25, 2013.

## Appendix A: Review of Selected Tools

New dynamic models are often developed for PSLF through substantial project efforts. The focus is on realistic behavior and computational tractability rather than on representation of the system physics. Sophisticated physical processes, such as those in a hydro-turbine or steam-turbine, are often simplified to transfer functions with empirically derived coefficients. This approach is in contrast to a physics-based model that might include the density of water or the temperature of steam in its model definition. In addition, all electrical quantities in PSLF are in terms of real power, reactive power, and reference frame variables: that is, q-axis and d-axis voltages and currents. Thus for an energy storage system, PSLF would be suitable for tracking high-level characteristics such as battery state-of-charge, q-axis line current, and so forth, but it would not be suitable for modeling fine-scale physical or chemical phenomena in an energy storage device.

To evaluate a new component in PSLF, the first step is to develop a dynamic model of the component using the *epcl* programming language embedded within the software package. *Epcl* allows the definition of the system model as a set of ordinary differential equations. In the following example, the differential equations of a third-order wind turbine exciter are presented where  $@mx$  is the model index, remaining quantities beginning with  $@$  are local variables,  $epcexc[@mx].s0$  is the exciter state  $s_0$ , and  $epcexc[@mx].ds0$  is the derivative  $ds_0/dt$ , with the other states following the same syntax.

```
/* EPCL Example Begin*/
@piin = epcexc[@mx].s0 - epcexc[@mx].s2 - @pref
epcexc[@mx].ds0 = (@pelec -
epcexc[@mx].s0)/@tpw epcexc[@mx].ds1 = @piin
epcexc[@mx].ds2 = (@kf*@kip*@piin + @kf*@kpp*(@pelec-epcexc[@mx].s0)/@tpw -
/ epcexc[@mx].s2)/(@tf+@kf*@kpp)
/* EPCL Example End*/
```


The evolution of the system state is determined through numerical solution with a fixed time step, usually 4.2 msec, although this can be adjusted. The PSLF dynamic simulations typically consider tens or hundreds of seconds of time after some event or disturbance, such as a generator going offline or a transmission line being disconnected. PSLF is thus a valuable tool for evaluating the effect of energy storage components on system stability and robustness. However, PSLF would be impractical for evaluating the economic benefits of an energy storage system performing shifting, for example.

A simulation example based on an effort at Sandia National Laboratories to investigate the use of energy storage elements to mitigate inter-area oscillations on the WECC illustrates PSLF capabilities. In this study, a candidate UltraCapacitor-based oscillation damping system was developed and tested in PSLF.<sup>3</sup> First, the UltraCapacitor-based energy storage system with grid-tied inverter was developed (Figure A-8) and modeled using *epcl*. The new *epcl* model was inserted in two locations within an existing PSLF WECC base case with predicted characteristics for 2017 heavy summer. One damping control was connected to a bus in Palo Verde, and the other was connected near Grand Coulee Dam. Damping of inter-area oscillations


<sup>3</sup> *Energy Storage Controls for Grid Stability*, Byrne, Ray, Jason Neely, Cesar Silva Monroy, David Schoenwald, and Ryan Elliot, November 2012, SAND-REPORT, Sandia National Laboratories, Albuquerque, NM.

## Appendix A: Review of Selected Tools

was accomplished in simulation through power modulation control of the two systems that used the difference in bus frequencies in the two areas (Figure A-9).




**Figure A-8. Detailed Schematic Model of UltraCapacitor and Grid-Tied Inverter**




**Figure A-9. Damping of Inter-area Oscillations**

For the simulation study, a transient inter-area oscillation was excited by simulating the loss of a 500kV power line in British Columbia. For a gain value of  $K_d = 0$ , the damping controllers had no effect, and the generator speeds in the two areas oscillated against one another for over 20 seconds (Figure A-10). For  $K_d = 10$  MW/mHz, the oscillations were considerably damped, resulting in an oscillation that lasted approximately 7 seconds. Because PSLF provides results for the system-wide response, the effect of the damping controllers may be seen on generators across the WECC (Figure A-11).



**Figure A-10. Generator Speed Difference**  
(Simulation performed in PSLF; plot generated in Matlab.)



**Figure A-11. Generator Speeds at Five Buses in the WECC With/Without Damping Control**  
(Simulation performed in PSLF; plot generated in Matlab.)

While this example employed GE's PSLF software, other software packages with similar capabilities for power system dynamic simulations include PSS/E offered by Siemens, Dynamic Security Assessment (DSA) Tools offered by Powertech Labs, and the PowerWorld Simulator offered by PowerWorld. Detailed information about the capabilities of each simulation environment is found on the company websites.<sup>4, 5, 6</sup>

---

<sup>4</sup> Power World Corporation, <http://www.powerworld.com/>, last accessed March 25, 2013.

<sup>5</sup> Siemens PSS® Product Suite, <http://www.energy.siemens.com/hq/en/services/power-transmission-distribution/power-technologies-international/software-solutions/pss-e.htm>, last accessed March 25, 2013.

<sup>6</sup> DSA Tools, <http://dsatools.com/index.php>, last accessed March 25, 2013.



## APPENDIX B: STORAGE SYSTEM COST DETAILS

### Appendix B: Table of Contents

<a href="#"><u>B.1</u></a>	<a href="#"><u>Technical Approach and Assumptions</u></a>	.....	B-3
<a href="#"><u>B.2</u></a>	<a href="#"><u>Cost Metrics</u></a>	.....	B-10
	<a href="#"><u>B.2.1</u></a>	<a href="#"><u>Life-cycle Cost Analysis</u></a>	
	<a href="#"><u>B.2.2</u></a>	<a href="#"><u>Financial Assumptions</u></a>	
	<a href="#"><u>B.2.3</u></a>	<a href="#"><u>Methodology</u></a>	
	<a href="#"><u>B.2.4</u></a>	<a href="#"><u>Annual Storage Technology Costs</u></a>	
<a href="#"><u>B.3</u></a>	<a href="#"><u>Comparison with a Combustion Turbine</u></a>	.....	B-20
<a href="#"><u>B.4</u></a>	<a href="#"><u>Technology Cost Tables</u></a>	.....	B-24
	<a href="#"><u>B.4.1</u></a>	<a href="#"><u>Pumped Hydro</u></a>	
	<a href="#"><u>B.4.2</u></a>	<a href="#"><u>CAES</u></a>	
	<a href="#"><u>B.4.3</u></a>	<a href="#"><u>Sodium Sulphur Battery</u></a>	
	<a href="#"><u>B.4.4</u></a>	<a href="#"><u>Sodium-nickel-chloride Battery</u></a>	
	<a href="#"><u>B.4.5</u></a>	<a href="#"><u>Vanadium Redox Battery</u></a>	
	<a href="#"><u>B.4.6</u></a>	<a href="#"><u>Iron-chromium Battery</u></a>	
	<a href="#"><u>B.4.7</u></a>	<a href="#"><u>Zinc-bromine Systems</u></a>	
	<a href="#"><u>B.4.8</u></a>	<a href="#"><u>Zinc-air Battery</u></a>	
	<a href="#"><u>B.4.9</u></a>	<a href="#"><u>Lead-acid Battery</u></a>	
	<a href="#"><u>B.4.10</u></a>	<a href="#"><u>Flywheel</u></a>	
	<a href="#"><u>B.4.11</u></a>	<a href="#"><u>Lithium Ion Family of Batteries</u></a>	

*See next page for bookmarked list of Figures and Tables.*

## Appendix B: List of Figures

[Figure B-1. Impact of Ownership Assumptions](#)

[Figure B-2. Annual Costs and Levelized Revenue for 50MW/6-hour NaS Battery](#)

[Figure B-3. Illustrative Comparison of CT and Energy Storage Residual Capacity Value Calculation](#)

## Appendix B: List of Tables

[Table B-1. Cost and Performance Data Sheets Provided to Survey Participants](#)

[Table B-2. Vendors Contacted in the Cost and Performance Survey](#)

[Table B-3. Process and Project Contingency Assumptions](#)

[Table B-4. Key Financial Assumptions and Levelized Costs](#)

[Table B-5. Example Life-Cycle Calculator](#)

[Table B-6. Example Key System Inputs for the Life-cycle Cost Analysis for a NaS Energy Storage Option](#)

[Table B-7. Input Assumptions for 50-MW/6-hour NaS Battery](#)

[Table B-8. IOU Revenue Requirement Model for 50-MW/6-hour NaS Battery](#)

[Table B-9. Levelized and Present Value Cost Metrics for 50-MW/6-hour NaS Battery](#)

[Table B-10. Comparable Costs for a Combustion Turbine and Combined-Cycle Gas Turbine](#)

[Table B-11. Inputs for the Combustion Turbine and Combined-Cycle Gas Turbine](#)

[Table B-12. Cost Estimates for New Greenfield Pumped Hydro Projects](#) [Table B-13. Cost Estimates for CAES Systems](#)

[Table B-14. Performance, Design, and Cost of NaS Systems](#)

[Table B-15. Cost and Performance of Sodium-nickel-chloride Battery Systems](#)

[Table B-16. Cost and Performance of Vanadium Redox Battery Systems](#)

[Table B-17. Cost and Performance of Iron-chromium Systems](#)

[Table B-18. Zinc-bromine System Cost and Performance Data for Bulk, Frequency Regulation, and Utility T&D Grid Support Services](#)

[Table B-19. Zinc-bromine System Cost and Performance Data for Distributed Energy Storage and Commercial and Industrial Energy Management Services](#)

[Table B-20. Zinc-bromine Systems for Small Residential Applications](#)

[Table B-21. Cost and Performance Data for Zinc-air Batteries](#)

[Table B-22. Cost and Performance of Advanced Lead-acid Batteries in Bulk Storage Service](#)

[Table B-23. Cost and Performance of Advanced Lead-acid Batteries for Frequency Regulation](#)

[Table B-24. Cost and Performance of Advanced Lead-acid Batteries in Utility T&D](#)

[Table B-25. Cost and Performance Data of Advanced Lead-acid Batteries](#)

[Table B-26. Cost and Performance of Advanced Lead-acid Batteries for Commercial and Industrial Applications](#)

[Table B-27. Cost and Performance of Flywheel Systems](#)

[Table B-28. Cost and Performance of Li-Ion Family of Battery Systems for Frequency Regulation and Renewables](#)

[Table B-29. Li-ion Battery Systems for Utility T&D Grid Support](#)

[Table B-30. Li-ion Battery Systems for Distributed Energy Storage](#)

[Table B-31. Li-ion Battery Systems for Commercial and Residential Applications](#)

## STORAGE SYSTEM COST DETAIL

The cost and performance data provided in the Handbook and in this appendix are based on EPRI report *“Electricity Energy Storage Technology Options 2012 System Cost Benchmarking”*; EPRI ID 1026462, December 2012.

Storage system costs have a “power” and an “energy” component. The power cost component is the cost of the power conditioning system and its auxiliaries that determines the kW or MW capability of that particular system and contributes to the \$/kW component of the system cost. The energy component is the cost of the storage components – battery, flywheel, or the upper reservoir capacity in pumped hydro and related aux – that determines the kWh or MWh capability of the same system and contributes to the \$/kWh of the system cost.

For a given system, the total cost is the sum of these components. This total cost is fairly specific to that system size, and is not linearly scalable in most cases. Using Table B-24 and the first system from Supplier S15 as an example, the sum of the \$/kW and \$/kWh is only applicable to discrete multiples of the system size of 1,000 kW/1,000 kWh. In most cases, these costs cannot be reliably extrapolated to a system size that is a fractional increment of this discrete size, such as 1,700 kW/1,200 kWh.

Continuing with the same system: Supplier S15 quoted the cost of the 1 MW/1MWh system to be \$1,481,040, shown in the lower half of Table B-24, under “ES Equipment.” This cost is vendor supplied and has not been altered. To this, we added other costs that are not included in the vendor quote, such as site installation, enclosure, interconnection, and other site specific costs, broken out in Equipment and Installation categories. This gives the “Total Cost Equipment” (\$2,083,800); and “Total Cost Installation” (\$254,972). To this, we further added project and process contingencies and engineering fees to derive a Total Plant Cost (TPC) = \$2,476,567. (Note that the project and process contingencies are chosen based on our assessment of the maturity of the technology and vendor experience as discussed in Section B.1 and shown in Table B-3.)

The TPC divided by the power rating gives the TPC in \$/kW; and when divided by the energy rating it gives the TPC in \$/kWh for that specific system. In this case they are both = \$2,477. The \$/kWh of \$2,477 is only for the rated depth of discharge. At 100% depth of discharge, the TPC would be divided by 3,030 kWh, yielding the lower \$817/kWh value.

The Plant Capital Cost is a unit cost for the power (\$847) and energy (\$1,629) components, each multiplied by their respective rating and added gives the TPC. In this case, they are = \$847,000 and \$1,629,000. Added together, they give the TPC of \$2,476,00 (rounded).

The interconnection and other site costs are our estimates as shown in Appendix D. These costs and all other adders shown in red in Table B-24 are our estimates which can be adjusted to your specific project needs.

### B.1 Technical Approach and Assumptions

The 2011 cost benchmarking study was undertaken using the following approach:

## Appendix B: Storage System Cost Details

1. Detailed cost and performance data sheets, shown in *Table B-1. Cost and Performance Data Sheets Provided to Survey Participants*, were prepared and sent to invited battery OEM suppliers, power conditioning system (PCS) providers and system integrators. The list of companies contacted and their technology area is shown in *Table B-2. Vendors Contacted in the Cost and Performance Survey*.
2. Earlier 2010 data sheets were reviewed and updated based on new supplier input. An iterative approach was used with supplies to ensure scope of supply and cost information was presented on a consistent basis.
3. One-line electrical drawings and costs estimates for interconnection and step-up transformation were developed for each application to arrive at estimates for installed costs per electric utility requirements. These are shown in Appendix D, *Utility and Owner Interconnection Costs and Schematics for Various Storage Systems* (attached).
4. Process and project contingencies were applied based on technology maturity and level of development and commercialization as shown in *Table B-3. Process and Project Contingency Assumptions*.
5. Cost metrics were defined to consistently compare installed and life-cycle costs across systems and applications. See the discussion below for definitions.
6. Financial and leveled cost of ownership methods and analysis were developed for several industry ownership scenarios including IOU, municipal utility, and IPP. The methodology and analysis are described in this appendix.
7. Given uncertainty and lack of credible O&M data, proxy estimates were developed for fixed, variable, and replacement costs.

The cost basis of these estimates must be understood to compare energy storage options presented appropriately. Site-specific conditions with more detailed energy storage use cases defined can result in quite different and varying estimates for installed costs and system life-cycle estimates than those presented. The assumptions made in the study include:

1. The cost estimates presented in the study are representative base costs for the energy storage system and do not include all the owner's financial costs or site-specific project costs except for pumped hydro.
2. The following owner's financial costs are excluded from the estimates:
  - Interest During Construction (IDC)
  - Project Insurance and Project Escalation
  - Financing Fees
  - Allowance for Funds Used During Construction (AFUDC)
  - Sales Tax
  - Bonds
  - Legal Fees
  - Construction Power
  - Other Owner's Costs and Escalations.

Appendix B: Storage System Cost Details

3. The following site-specific project costs are excluded from the estimates for all technologies except pumped hydro and CAES:
  - Environmental Studies
  - Preliminary Engineering and Geology Work
  - Water Rights
  - Right of Way
  - Start Up
  - Permitting
  - Off-Site Infrastructure
  - Supporting Utilities (water, shore power, sewer, and communications)
  - Substation and New Transmission (unless otherwise shown in base estimate as utility interconnection)
  - Access (ingress and egress)
  - Security (lighting, fencing and communications)
  - Civil Site Preparation
  - Land Acquisition.
4. Battery and flywheel systems are assumed to be located at brownfield sites where site-specific project costs are not included, because these associated assets are assumed to be adjacent to the site or in place. Therefore, these estimates represent an installed TPC less the owner's costs. These sites would be typical of a prepared site such as a utility substation or a private owner's property that is fully prepared for the project. The applicable utility and owner interconnection costs for battery and flywheel systems are included in the cost estimates.
5. CAES systems are assumed to be located at greenfield sites where site-specific project costs are not included. This site would be typical of an unprepared or new site for a utility or a private developer and requires the inclusion of all the listed site-specific project costs. To complete the installed TPC for CAES systems, owner's costs, site-specific costs, step-up transformers, and utility/owner interconnection costs must be added.
6. Pumped hydro systems are assumed to be located at greenfield sites where site-specific project costs are included in the cost estimates. This site would be typical of an unprepared or new site for a utility or a private developer that includes all the listed site-specific project costs. Therefore, these estimates represent an installed TPC less the owner's financial costs. The utility and owner interconnection transmission line costs for pumped hydro systems are also not included in the cost estimates; however, site-specific generator step-up transformers and the site substation are included in the site-specific costs.
7. IOU financial ownership scenarios were used.

Appendix B: Storage System Cost Details

Other key financial assumptions are shown in *Table B-4. Key Financial Assumptions and Levelized Costs* and technology-specific assumptions are listed in the associated technology sections in this appendix.

**Table B-1. Cost and Performance Data Sheets Provided to Survey Participants***(Highlighted parameters are vendor inputs)*

LINE NUMBER	AECOM ENGINEERING		
	Advanced Lead Acid		
	Application		
	Technology Type		
	tech		
	System Size & Status		
	Storage Capacity (Hours)		
1	<b>DESIGN BASIS - General</b>		
2	System Capacity - Net kW		
3	Hours of Energy storage at rated Capacity - hrs		
4	Depth of Discharge (DOD) per cycle - %		
5	Energy Capacity - kWh @ rated DOD		
6	Energy Capacity - kWh @ 100% DOD		
7	Auxiliaries - kW		
8	Unit Size - Net kW		
9	Number of Units - #		
10	Physical Size - SF/Unit		
11	System Foot Print - SF		
12	System Weight - lbs		
13	Round Trip AC / AC Efficiency - %		
14	Number of cycles / year		
18	<b>DESIGN BASIS - Temperature</b>		
19	Design Summer Ambient T - °F		
20	Design Winter Ambient T - °F		
21	<b>GENERAL - Timing</b>		
22	Year \$ for Input Data		
23	Month \$ for Input Data		
24	Commercial Order Date		
25	Commercial Service Date		
26	Book Life, yrs		
27	Plant Life, yrs		
28	Pre-construction Time, yrs		
29	<b>TOTAL PLANT COST</b>		
30	\$/kW		
31	\$/kWh @ rated DOD		
32	\$/kWh @ 100% DOD		
38	<b>PLANT CAPITAL COST</b>		
39	Power - \$/kW		
40	Storage - \$/kWh @ rated DOD		
41			
		43	<b>SYSTEM COSTS - Equipment &amp; Install</b>
		44	
		45	<b>ES System</b>
		46	<b>ES Equipment</b>
		47	ES Installation
		48	Enclosures
		49	<b>Owner Interconnection</b>
		50	Equipment
		51	Installation
		52	Enclosures
		53	<b>System Packing</b>
		54	
		55	<b>System Shipping to US Port</b>
		56	
		57	<b>Utility Interconnection</b>
		58	Equipment
		59	Installation
		60	
		61	<b>Site BOP Installation (Civil Only)</b>
		62	
		63	<b>Total Cost Equipment</b>
		64	<b>Total Cost Installation</b>
		65	
		66	General Contractor Facilities at 15% install
		67	Engineering Fees @ 5% Install
		68	Project Contingency Application @ 0-15% install
		69	Process Contingency Application @ 0-15% of battery
		70	<b>Total Plant Cost (TPC)</b>
		71	<b>Plant Cost - \$/kW</b>
		72	<b>Plant Cost - \$/kWh @ rated DOD</b>
		73	<b>OPERATING EXPENSES</b>
		74	<b>FIXED O&amp;M - \$/kW-yr</b>
		75	Replacement Battery Costs - \$/kW
		76	Battery replacement - yrs
		77	<b>Variable O&amp;M - \$/kWh (Charging or Discharging)</b>
		82	<b>PERFORMANCE - General</b>
		83	<b>Energy Storage (ES) Capacity:</b>
		84	Useable ES Capacity at Nominal output - kWh
		85	Nominal Power Output per Line 84 - kW
		86	Nominal Power Input per Line 84 - kW
		87	<b>Charging Performance:</b>
		88	Maximum Power Input for 15 min - kW
		89	Maximum Power Input for 1 hr - kW
		90	Maximum Power Input for 5 hr - kW
		91	Sustainable Minimum Power Input - kW
		92	Nominal Ramp Rate - kW/sec
		93	<b>Discharge Performance:</b>
		94	Maximum Power Output for 15 min - kW
		95	Maximum Power Output for 1 hr - kW
		96	Maximum Power Output for 5 hr - kW
		97	Sustainable Minimum Power Output - kW
		98	Nominal Ramp Rate - kW/sec
		99	<b>Spinning Reserve Response - immediate or time delay</b>
		100	<b>Operating Reserve:</b>
		101	Cold Start-up - kW/Sec
		102	Cold Start-up - kW output in 5 minutes
		103	<b>Duty Cycle:</b>
		104	Cycles/Year
		105	Time to Fully Charge (at Nominal Power Input)-hrs
		106	Time to Functionally Discharge (at Nominal Power Output)-hrs
		107	Minimum Load - %

**Table B-2. Vendors Contacted in the Cost and Performance Survey**

A123 Systems/Li-ion	International Battery/Li-ion
ABB Inc./Inverter	IONEX Energy Storage Systems/Li-ion
Altairnano/Li-ion	Isentropic/Pumped Heat Energy Storage
Aquion Energy/Aqueous Hybrid Ion	LG Chem/Li-ion
Beacon Power/Flywheel	NEC/Li-ion
Beckett Energy Systems/Li-ion	Parker Hannifin/Inverter
Boston Power/Li-ion	Powergetics
BYD/Li-ion	Premium Power/Zn-br
Chevron Energy Solutions	Primus Power/Zn-Halogen
Dow Kokam/Li-ion	Princeton Power/Inverter
Dresser-Rand/CAES	Prudent Energy/Vanadium Redox
DynaPower/Inverter	RedFlow/Zn-Br
Ecovoltz/Flow Battery	Ricardo Inc./Integrator
Ecoults-EastPenn/Adv. Lead-acid	ReVolt/Zn-air
EnerSys/Adv. Lead-acid	Saft/Li-ion
EnerVault/Fe-Cr	S&C Electric/Li-ion
EOS/Zn-air	Siemens/Inverter
Exide/Adv. Lead-acid	Samsung SDI
FIAMM/NaNiCl <sub>2</sub>	Satcon/inverter
Fluidic Energy/Zn-air	Silent Power/Adv. Lead-acid
GE/NaNiCl <sub>2</sub>	Sunverge Energy/Li-ion
Green Charge Networks/Li-ion	SustainX/Isothermal
Greensmith/Li-ion	Toshiba Corp.
GS Yuasa/Adv. Lead-acid	Xtreme Power/Adv. Lead-acid
Highview Energy/Liquid-air	ZBB Energy/Zn-br
	Zinc Air Inc./Zn-air

**Table B-3. Process and Project Contingency Assumptions**

Technology	5kW - 50kW		100kW - 1MW		2MW - 10MW		25MW - 100MW		101MW - 500MW	
	Process	Project	Process	Project	Process	Project	Process	Project	Process	Project
CAES	na	na	na	na	10%	10%	10%	10%	10%	10%
Pumped Hydro	na	na	na	na	na	Na	na	na	Included	Included
NaS	0%	0%	0%	5%	0%	5%	0%	10%	na	na
Advanced Lead-Acid	5%	0%	5%	5%	5%	5%	5%	10%	na	na
Li-ion	10%	0%	10%	5%	10%	5%	10%	10%	na	na
Vanadium Redox	5%	0%	5%	5%	5%	5%	5%	10%	na	na
Zn/Br	10%	0%	15%	10%	15%	10%	15%	15%	na	na
Fe/Cr	15%	0%	15%	10%	15%	10%	15%	15%	na	na
Zn/Air	15%	0%	15%	10%	15%	10%	15%	15%	na	na
Flywheel	na	0%	na	na	na	Na	0%	na	na	na
Sodium Metal Halide	na	na	10%	5%	10%	10%	10%	10%	na	na
Aqueous Hybrid Ion	na	na	na	na	na	Na	15%	15%	na	na

**Notes:** Read “na” as not assessed in this study.

## Appendix B: Storage System Cost Details

**Table B-4. Key Financial Assumptions and Levelized Costs**

Ownership Default Financials	IOU	Muni	IPP w/Contract	IPP - No Contract	
Equity Share in Capital Structure	50%	0%	30%	60%	
Cost of Debt	6.00%	5.00%	6.60%	7.40%	
After Tax WACC	7.30%	5.00%	8.00%	10.50%	
<b>FINANCIAL ASSUMPTIONS</b>		<b>DETAILED FINANCIAL INPUTS</b>			
<b>Inflation Assumptions</b>		<b>Detailed Tax Assumptions</b>			
Fixed O&M Cost - Escalator (%/yr)	2.0%	Federal Production Tax Credit (PTC) ?	<input type="checkbox"/>	\$0.00	
Variable O&M Cost - Escalator (%/yr)	2.0%	Tax Credit - Federal PTC (\$/MWh)			2012
Electricity/Fuel Inflation	5.0%	Tax Credit - Federal PTC Expiration			10
<b>Fuel Cost Assumptions</b>		Tax Credit - Federal PTC (Years)			0
Charging Cost (\$/MWh)	\$30.00	Tax Credit - Federal PTC Escalator			2%
Fuel Cost (\$/MMBtu)	\$3.00	Tax Credit - State expiry (end year)			0
<b>GHG Assumptions</b>		Tax Credit - State ITC (%)			0.00%
CO2 Emissions (Lb/MMBtu)	117	Tax Credit - State Tax Credit (\$/MWh)			\$0.00
CO2 Price (\$/Ton)	\$30.00	Tax Credit - State Tax Credit (\$ millions)			\$0.0
<b>Fixed Cost Assumptions</b>		Tax Credit - State Tax Credit Annual Max (% capex)			0.00%
Insurance	0.50%	Tax Credit - State Tax Credit Annual Max (\$mill)			\$0.00
Property Tax	1.00%	Tax Credit - State Tax Credit Duration (Years)			0
Insurance Expense (\$/kW)	\$0.00	Sales Tax - State Rate			4.00%
<b>Financing Assumptions</b>		Sales Tax - State & Local Combined			5.38%
Ownership	IOU	Sales Tax - Maximum per MW			\$0
Percent Financed with Equity	50.00%	Sales Tax Exemption Expiration			2011
Debt Interest Rate	6.00%	Gross Receipts Tax - State Rate			0.00%
After-Tax WACC	7.30%	Gross Receipts Tax - Average Local Rate			0.00%
Pre-Tax WACC	8.52%	Gross Receipts Tax - State & Local Combined			0.00%
Cost of Equity	11.04%	Property Tax - During Exemption Period			0.50%
Target average DSCR	1.40	Property Tax - Exemption Expiration (end year)			2015
Debt Term	15	Property Tax - Straight-line Depreciation (0=None)			20
<b>Tax Assumptions</b>		Excise Tax - State Tax Rate (\$/MWh)			\$0
COD Year	2012	Excise Tax - tax holiday period			0
Income Tax - Federal	35%	Payments-In-Lieu-Of-Taxes (PILOT) - (\$/kW)			\$0.00
Income Tax - State	8.84%	Payments-In-Lieu-Of-Taxes (PILOT) - (\$/MWh)			\$0.00
Total Tax	40.75%				
Tax Depreciation (MACRS) schedule (yrs)	10				
Royalty Payment to Landowner	0.25%				
Tax Credit - Federal ITC (%)	0.00%				
Tax Credit - Federal ITC Expiration	2012				
Federal Investment Tax Credit (ITC) ?	<input type="checkbox"/>				
Sales Tax - State Rate (no exemption)	4.00%				
Sales Tax - Average Local Rate	1.38%				
Sales Tax - % of Capital Cost Subject to Sales Ta	80%				

\*Muni financing is similar to Cooperative financing with 100% debt, 5% cost of debt, etc. Note that even with 100% debt, there will always be a coverage ratio of 1.25 or more.

Note: DSCR stands for Debt Service Coverage Ratio.

Project contingency reflects uncertainties in major equipment costs and installation and integration costs. Systems that have been field-demonstrated have low project contingencies. Systems still in R&D, with limited or no integration or field deployment history are assigned a higher project contingency. Project contingency is applied by multiplying the total estimated cost of a storage system installation by the project contingency percentage then adding this to the estimated TPCs.

## B.2 Cost Metrics

The cost for each storage technology is calculated using a detailed utility revenue requirement model. The leveled price for delivered energy is calculated to achieve the target return on equity for the project. All results presented are based on an investor-owned utility with an after-tax weighted cost of capital of 7.3%. The present values of the fixed and variable costs over the life of the project are calculated and then used to calculate the leveled and present value cost metrics described below. In addition to debt and equity payments, the primary annual costs for the storage technologies are charging costs (electricity, fuel, and CO<sub>2</sub>) fixed O&M (\$/kW installed), and variable O&M (\$/kWh discharged). Periodic maintenance, such as module replacement, is also included for some technologies. Additional costs such as insurance and property tax are based on a percentage of total installed costs.

There are no costs per cycle included. However, the annual charging costs are based on the number of cycles assumed per year for each application, the kWh of energy storage (duration), and the round-trip efficiency.

The five summary cost metrics are:

### 1. Installed Cost (\$/kW)

The installed cost includes all equipment, delivery, installation, interconnection, and step-up transformation costs. For this benchmarking work it was assumed a site was available; however no land costs, permitting, and project planning costs were included. These costs are comparable to the installed costs of a combustion turbine (CT) or combined-cycle gas turbine (CCGT) for up-front capital and financing requirements.

### 2. Levelized Cost of Capacity (\$/kW-yr.)

The leveled cost of capacity is the \$/kW-yr. revenue per kW of discharge capacity needed to cover all life-cycle fixed and variable costs and provide the target rate of return based on financing assumptions and ownership types. This metric is primarily of interest for comparing to capacity resources, such as a CT.

### 3. Levelized Cost of Energy (LCOE) (\$/MWh)

The LCOE is the \$/MWh revenue for delivered energy needed to cover all Life-cycle fixed and variable costs, and provide the target rate of return based on financing assumptions and ownership types. This metric is primarily of interest for energy resources such as renewables or baseload fossil generation.

### 4. Present Value of Life-cycle Costs (\$/kW Installed)

The Present Value of Life-cycle Costs includes the installed costs (above) and all ongoing fixed and variable operating costs over useful life. The present value of the annual costs is divided by the kW of energy storage system discharge capacity installed.

## 5. Present Value of Life-cycle Costs (\$/kWh Installed)

The Present Value of Life-cycle Costs described above divided by usable kWh of energy storage capacity installed. Both of the Present Value of Life-cycle Costs metrics can be compared against estimates of present value benefits or revenues to estimate cost-effectiveness.

These cost metrics are provided for broad comparisons of different energy storage technologies with each other and to a CT. For purposes of consistent comparison across a broad range of technologies\ simple assumptions are required regarding the dispatch of energy storage in the representative applications presented. Actual costs across storage technologies for specific sites and applications will vary considerably from those presented here. Nevertheless, these metrics give useful indications: for example, how a low-cost, less-efficient storage technology compares to a higher-cost, more-efficient storage technology.

The applicability of each cost metric depends on the application under consideration. A utility interested in adding a capacity resource that will run a limited number of hours each year is most concerned with the Installed Cost (\$/kW) and Levelized Cost of Capacity (\$/kW-yr) metrics. These are the metrics used by utilities to estimate the full costs of a new CT, which is often used as a benchmark for alternative capacity resources such as demand response. Because the resource is expected to operate at a low capacity factor, the cost of delivered energy is not of particular concern and may be relatively high.

On the other hand, a utility interested in adding an intermediate generating resource, with a high capacity factor, may be more interested in the cost of the energy produced, and thus looks at the \$/MWh LCOE metric. This metric is often used to compare to the delivered cost of energy from different renewable energy technologies in different regions.

The Present Value of Life-cycle Costs (\$/kW or \$/kWh Installed) are presented specifically for energy storage and are not commonly used for fossil resources. The primary value or revenue from fossil resources is readily compared to market prices or proxy resources. Determining the value of storage performing multiple services is more difficult. The Present Value of Life-cycle Costs is designed to be compared against corresponding estimates of present value benefits or revenues. The present value of revenues can be compared against the present value of costs to estimate cost-effectiveness of an individual technology for a specific application.

### B.2.1 Life-cycle Cost Analysis

Levelized cost and life-cycle analysis metrics are valuable metrics for assessing and benchmarking energy storage options within a specific application and use case requirement. The analysis methods used to estimate the leveled cost of energy (\$/MWh) and the leveled cost of capacity (\$/kW-yr.) are presented in this section.

EPRI research supported the development of a Life-cycle Analysis Calculator (Calculator) to conduct easy estimation of these metrics based on system/technology features, ownership scenarios, and financial assumptions. Vendor data obtained from the survey was

**Appendix B: Storage System Cost Details**

used as input to the Calculator to estimate the results presented in this appendix. Table B-3 lists the key system feature inputs necessary, while Table B-4 (above) details the key financial input assumptions. The Calculator has the capability to estimate these metrics from several ownership perspectives, including investor-owned utility, municipal utility (Muni), and IPP. The IPP option includes inputs for both a contracted and a merchant (non-contracted) storage project. The debt-to-equity ratio, cost of debt, return on equity, and resulting weighted average cost of capital (WACC) appropriate for each option are included in the model.

**Table B-5. Example Life-Cycle Calculator**

<b>COST AND PERFORMANCE DATA</b>		
<b>System Size</b>		
Charge/Discharge Capacity (kW)	kW	1000
Hours of storage at rated capacity	hours	4
Depth of Discharge per cycle	%	0.8
Useable Energy Storage Capacity (kWh)	kWh	4,000
Installed Energy Storage Capacity	kWh	5,000
<b>Useful Life</b>		
End-of-Life Residual Energy Storage	%	100.00%
Degradation Factor (%/yr)	%	0.00%
System Life	Years	15
<b>Efficiency</b>		
AC/AC Efficiency OR	%	80%
Energy Charge Ratio	kW in/kW out	-
<b>Output</b>		
Cycles per Year	#	365
<b>Installed Cost</b>		
DC Battery Cost per kWh of <u>usable</u> storage	\$/kWh	\$390
Total DC Battery Cost	\$	\$1,560,000
\$/kW installed (incl PCS)	\$/kW	\$527
Total \$/kW Cost	\$	\$527,000
<b>Total</b>	\$	\$2,087,000
Cost per kW	\$/kW	\$2,087
System Cost - Regional Multiplier	Ratio	1.000
System Cost - Regional Cost	\$/kW	\$2,087
	\$/Useable kWh	\$522
<b>Fixed O&amp;M</b>		
Fixed O&M Cost	\$/kW-Yr.	\$4.5
Periodic Major Maintenance	\$/kW	\$0
period between maintenance	years	8
Property Tax	% of \$/kW capex	1.0%

## Appendix B: Storage System Cost Details


COST AND PERFORMANCE DATA		
Insurance Cost	% of \$/kW capex	0.5%
<b>Variable O&amp;M</b>		
Variable Costs	\$/kWh produced	\$0.00140
<b>Charging Costs</b>		
Avg. Charging Cost	\$/MWh	\$30.00
Fuel Cost	\$/MMBtu	\$3.00
Fuel Cost Escalation	%	5%
CO <sub>2</sub> Emission Rate by Fuel	lb/MMBtu	117
CO <sub>2</sub> Allowance Price	\$/ton	\$30
Heat rate	Btu/kWh	-
Annual Heat Rate Degradation	%	
Fixed O&M Cost - Escalator (%/yr)		2.0%
Variable O&M Cost - Escalator (%/yr)		2.0%
<b>Finance</b>		
Ownership		IOU
Percent Financed with Equity	%	30%
Debt Interest Rate	%	6.60%
After-Tax WACC	%	8.00%
Cost of Equity	%	17.54%
Target average Debt Service Coverage Ratio	ratio	1.40
Debt Term	Years	15

## B.2.2 Financial Assumptions

Table B-4 (above) lists the key financial assumptions used to calculate the present value of installed cost, leveled cost of energy, and leveled cost of capacity. For this appendix, the IOU ownership scenario was used in all calculations and estimates. For the IOU financing scenario, the financing is 50% debt and 50% equity with a WACC of 7.3%.

Other assumptions used throughout the analysis are also shown in Table B-5. Gas prices start at \$3.00/MMBtu in 2012 and escalate at 5% per year. Electricity charging costs for energy storage are based on an off-peak energy cost of \$30/MWh, also escalated at 5% per year. A flat carbon price of \$30 per short-ton is included for gas-fired technologies. The model includes inputs for various tax credits, but none are used in this report (beyond deductions for interest expense and depreciation).

The ownership assumptions affect the present value of installed costs and life cycle analysis due to differences in WACC, income tax rates, etc. Figure B-1 (below) illustrates the sensitivity to ownership approach for an example 50-MW/6-hour NaS battery. Tax-free, debt-only financing for municipal utilities provides the lowest leveled cost. The next highest is the IPP with a power purchase agreement. The return on equity is higher than for an IOU, but the presumed debt ratio also higher. This results in a slightly lower WACC than for an IOU with 50% debt and equity. An un-contracted IPP asset has the highest return on equity and WACC and therefore the highest leveled cost.



**Figure B-1. Impact of Ownership Assumptions**

(Example estimated for 50-MW/6-hour NaS Battery @ \$3071/kW installed, 365 cycles/yr.; 15 years; 75% efficiency; \$30/MWh cost of off-peak energy.)

### B.2.3 Methodology

Life-cycle costs are modeled with a detailed annual cash-flow analysis. The inputs to the cash-flow analysis for a 50-MW/6-hour NaS battery are shown in Table B-6 and Table B-7. These include the storage cost and efficiency inputs as well as the financial inputs described above.

The model employs a revenue requirement model for IOU or Muni financing and an after-tax cash flow model for IPP financing. The first years of the IOU revenue requirement model are shown in Table B-8 (again for the 50-MW/6-hour NaS battery). The upfront capital investment is split 50% debt and 50% equity in year zero (2011). For each operational year, an annual utility revenue requirement is calculated including interest payments on debt, return on ratebase, and taxes. The leveled price for delivered energy is calculated to achieve the target return on equity for the project. The present values (PVs) of the fixed and variable costs over the life of the project are calculated and then used to calculate the leveled and present value cost metrics (Table B-9).

**Table B-6. Example Key System Inputs for the Life-cycle Cost Analysis for a NaS Energy Storage Option**

Energy Storage System Maturity	
Technology Type	NaS
System Size	50 MW
Storage Capacity (Hours)	6
Unit Capacity, Net kW	50,000
Hours of Energy storage at rated Capacity	6
Depth of Discharge (DOD)	80%
Plant Life	15 Years
Round Trip AC/AC Efficiency	75%
Number of cycles/year	365
Total Plant Cost - \$/kW	\$3,071
Total Plant Cost - \$/kWh @ rated DOD	\$512
Total Plant Cost - \$/kWh @ 100% DOD	\$409
Power Cost - \$/kW	\$516
Storage Cost @ rated DOD \$/kWh	\$426
Periodic Major Maintenance - \$/kW	-
Period between Maintenance, yrs	-
Fixed O&M - \$/kW-yr	\$4.5
Variable O&M - \$/kWh	\$0.0005

## Appendix B: Storage System Cost Details

**Table B-7. Input Assumptions for 50-MW/6-hour NaS Battery**

COST AND PERFORMANCE DATA		Bulk NaS 50 MW 6 Hrs S36
<b>System Size</b>		
Charge/Discharge Capacity (kW)	kW	50,000
Hours of storage at rated capacity	hours	6.00
Depth of Discharge per cycle	%	80%
Useable Energy Storage Capacity (kWh)	kWh	300,000
Installed Energy Storage Capacity	kWh	375,000
<b>Useful Life</b>		
End-of-Life Residual Energy Storage	%	100.00%
Degradation Factor (%/yr)	%	0.00%
System Life	Years	15
<b>Efficiency</b>		
AC/AC Efficiency OR	%	75%
Energy Charge Ratio	kWin/kWout	-
<b>Output</b>		
Cycles per Year	#	365
<b>Installed Cost</b>		
DC Battery Cost per kWh of <u>usable</u> storage	\$/kWh	\$426
Total DC Battery Cost	\$	\$127,735,000
\$/kW installed (incl PCS)	\$/kW	\$516
Total \$/kW Cost	\$	\$25,795,750
<b>Total</b>	\$	\$153,530,750
Cost per kW	\$/kW	\$3,071
System Cost - Regional Multiplier	Ratio	1.000
System Cost - Regional Cost	\$/kW	\$3,071
	\$/Useable kWh	\$512
<b>Fixed O&amp;M</b>		
Fixed O&M Cost	\$/kW-Yr.	\$4.5
Periodic Major Maintenance	\$/kW	\$0
period between maintenance	years	15
Property Tax	% of \$/kW capex	1.0%
Insurance Cost	% of \$/kW capex	0.5%
<b>Variable O&amp;M</b>		
Variable Costs	\$/kWh produced	\$0.0005
<b>Charging Costs</b>		
Avg. Charging Cost	\$/MWh	\$30.00
Fuel Cost	\$/MMBtu	\$3.00
Fuel Cost Escalation	%	5%
CO2 Emission Rate by Fuel	lb/MMBtu	117
CO2 Allowance Price	\$/ton	\$30
Heat rate	Btu/kWh	-
Annual Heat Rate Degradation	%	
Fixed O&M Cost - Escalator (%/yr)		2.0%
Variable O&M Cost - Escalator (%/yr)		2.0%
<b>Finance</b>		
Ownership		IOU
Percent Financed with Equity	%	50%
Debt Interest Rate	%	6.00%
After-Tax WACC	%	7.30%
Cost of Equity	%	11.04%
Target average DSCR	ratio	1.40
Debt Term	Years	15

## Appendix B: Storage System Cost Details

**Table B-8. IOU Revenue Requirement Model for 50-MW/6-hour NaS Battery**

IOU/POU REVENUE REQUIREMENT MODEL	2011	2012	2013
<b>Usable Storage</b>		300,000	300,000
Cycles		365	365
<b>Energy Production (kWh)</b>		<b>109,500,000</b>	<b>109,500,000</b>
<b>Total Revenue</b>		<b>\$36,699,178</b>	<b>\$35,786,439</b>
<b>Operating Costs</b>			
Charging Costs		(\$4,380,000)	(\$4,599,000)
Fuel Costs		\$0	\$0
CO2 Costs		\$0	\$0
Periodic Maintenance		\$0	\$0
Fixed O&M Costs		(\$224,580)	(\$229,072)
Variable O&M Cost		(\$50,000)	(\$51,000)
Insurance Costs		(\$767,654)	(\$783,007)
Property tax		(\$800,694)	(\$760,659)
Excise tax		\$0	\$0
Payment-In-Lieu-Of-Taxes (PILOT) - (\$/kW)		\$0	\$0
Payment-In-Lieu-Of-Taxes (PILOT) - (\$/MWh)		\$0	\$0
Royalty payment to landowner		(\$71,498)	(\$71,498)
Gross-receipts tax		\$0	\$0
<b>Total Costs</b>		<b>(\$6,294,425)</b>	<b>(\$6,494,235)</b>
<b>Operating Profit</b>		<b>\$30,404,753</b>	<b>\$29,292,204</b>
<b>Revenue Requirement</b>			
Operating Costs		\$6,294,425	\$6,494,235
Net Debt Financing Costs		\$4,804,161	\$4,483,884
Equity Return		\$8,843,468	\$8,374,016
Depreciation		\$10,675,914	\$10,675,914
Tax on Equity Return - before grossup		\$3,603,360	\$3,412,076
ITC		\$0	\$0
PTC		\$0	\$0
Tax Grossup		\$2,477,849	\$2,346,314
<b>Total Revenue Requirement</b>		<b>\$36,699,178</b>	<b>\$35,786,439</b>
Capital Cost		160,138,713	160,138,713
Starting Rate Base		160,138,713	151,637,803
Accumulated Deferred Income Tax		2,175,004	9,570,018
Accumulated Depreciation		(10,675,914)	(21,351,828)
Ending Balance Rate Base		\$160,138,713	148,356,903
<b>Debt Schedule</b>			
Debt Term Flag		1	1
Beginning Balance		\$80,069,357	\$74,731,400
Debt Service		(\$80,069,357)	(\$10,142,119)
Interest			(\$4,804,161)
Principal		(\$80,069,357)	(\$5,337,957)
Ending Balance		\$80,069,357	\$74,731,400
Interest earned on Debt Service Fund			\$0
<b>Equity Return</b>			
Beginning Balance		\$80,069,357	\$75,818,902
Equity Return			(\$8,843,468)
Return of Invested Equity		(\$80,069,357)	(\$5,337,957)
Book Equity Return			(\$14,181,425)
			(\$13,711,973)


## Appendix B: Storage System Cost Details

**Table B-9. Levelized and Present Value Cost Metrics for 50-MW/6-hour NaS Battery**

	Total		Levelized		Present Value	
	Sum (\$)	NPV	\$/MWh	\$/KW-yr	PV\$/kW	PV\$/kWh
Fixed Costs	\$368,720,593	\$234,298,958	\$239.40	\$524.29	\$4,686	\$781
Variable Costs	\$95,378,779	\$53,345,943	\$54.51	\$119.37	\$1,067	\$178
Total Costs	<b>\$464,099,373</b>	<b>\$287,644,901</b>	<b>\$293.91</b>	<b>\$643.66</b>	<b>\$5,753</b>	<b>\$959</b>

The annual costs and levelized revenue are summarized in Figure B-2. The installation costs are shown in year zero (2011), with the proportion financed by debt and by equity. The annual equity financing costs include the return of equity and return on equity to shareholders. Similarly, the debt financing includes principal and interest payments on debt. Taxes include all property and income taxes, including deductions for interest payments and depreciation. The operating costs include charging costs, fixed O&M, variable O&M and periodic replacement costs.

The LCOE (\$/MWh) is set to provide the target return on equity and results in the positive revenue line at the top of the chart.

**Figure B-2. Annual Costs and Levelized Revenue for 50-MW/6-hour NaS Battery**

#### B.2.4 Annual Storage Technology Costs

The primary annual costs for the storage technologies are charging costs (electricity, fuel and CO<sub>2</sub>) fixed O&M (\$/kW installed), and variable O&M (\$/kWh discharged). Periodic maintenance, such as module replacement, is also included for some technologies.

Additional costs such as insurance and property tax are based on a percentage of total installed costs.

Vendors provide price quotes for their systems with a presumed number of cycles per year. However, the definition of a cycle is not consistent across all vendors. Systems offering 5,000 to 17,000 cycles per year for frequency regulation will provide more frequent shallow cycles than systems offering peaking capacity with 365 full cycles per year. The vendors did not provide O&M costs per cycle, whether deep or shallow, so such distinctions could not be incorporated in this cost analysis. The variable costs for each application are therefore driven solely by the annual quantity of energy discharge required. The annual charging costs are based on the MWh of energy discharged per year and the round-trip efficiency of the storage technology.

For all applications except frequency regulation, annual energy discharged is based on an assumption of a single full cycle per day (365 cycles per year). A 1-MW system with 4 hours of duration would require 1,460 MWh per year of energy discharge (1 MW \* 4 hours \* 365 days), which equates to a capacity factor of approximately 16% (1,460 MWh/1 MW \* 8760 hours per year). With this assumption, longer duration systems will discharge more energy, and therefore require a higher proportion of energy charging per MW of installed capacity (e.g., a higher capacity factor). This results in similar charging costs on a present value \$/kWh installed basis, but higher costs on a present value \$/kW installed basis for longer duration systems. On the other hand, longer duration systems will presumably also have a greater ability to stack multiple benefit streams and therefore accrue more benefits in a cost-benefit analysis.

Unlike the other applications modeled, frequency regulation is defined more by the capacity (MW) offered than the energy (MWh) discharge required (i.e., mileage). Therefore, rather than assuming the same number of cycles, the frequency regulation analysis assume the same mileage—that is, the quantity of energy discharge per MW of capacity—for each system, independent of duration. A reference case of 5,000 cycles for a 0.25-hour duration battery is used, which equates to a capacity factor of just under 15%. In other words, each MW of installed capacity will discharge 1,250 MWh of energy per year in providing frequency regulation. This approach allows more consistent comparison with equivalent charging and variable O&M costs as a proportion of the MW of discharge capacity. The comparison of technologies providing frequency regulation is limited to shorter duration systems (less than 1.3 hours).

### B.3 Comparison with a Combustion Turbine

To validate the model and provide a reference point, both a CT and a CCGT were run through the same spreadsheet model with the same financial assumptions used to calculate the energy storage technology costs. The natural gas price starts at \$3.00/MMBtu and escalates at 5% per year. The results are presented in Table B-10 and Table B-11.

**Table B-10. Comparable Costs for a Combustion Turbine and Combined-Cycle Gas Turbine**

Technology Option	Capacity (MW)	Heat Rate	Capacity Factor	Installed Cost (\$/kW)	Present Value Life-cycle Cost (\$/kW)	Levelized Cost of Capacity	LCOE (\$/MWh)
Combustion Turbine	100	11,000	5%	720	2225	156 (Total) 124 (Fixed Only)	357
Combined-Cycle Gas Turbine	500	6900	80%	1100	5152	498 (Total) 173 (Fixed Only)	71

**Table B-11. Inputs for the Combustion Turbine and Combined-Cycle Gas Turbine**

COST AND PERFORMANCE DATA		CT	CCGT
<b>System Size</b>			
Charge/Discharge Capacity (kW)	kW	100,000	500,000
Hours of storage at rated capacity	hours	24.00	24.00
Depth of Discharge per cycle	%	100%	100%
Useable Energy Storage Capacity (kWh)	kWh	2,400,000	12,000,000
Installed Energy Storage Capacity	kWh	2,400,000	12,000,000
<b>Useful Life</b>			
End-of-Life Residual Energy Storage	%	100.00%	100.00%
Degradation Factor (%/yr)	%	0.00%	0.00%
System Life	Years	20	20
<b>Efficiency</b>			
AC/AC Efficiency OR	%	0%	0%
Energy Charge Ratio	kWin/kWout	0.97	0.97
<b>Output</b>			
Cycles per Year	#	18	292
<b>Installed Cost</b>			
DC Battery Cost per kWh of <u>usable</u> storage	\$/kWh	\$0	\$0
Total DC Battery Cost	\$	\$0	\$0
\$/kW installed (incl PCS)	\$/kW	\$720	\$1,100
Total \$/kW Cost	\$	\$72,000,000	\$550,000,000
<b>Total</b>	\$	<b>\$72,000,000</b>	<b>\$550,000,000</b>
Cost per kW	\$/kW	\$720	\$1,100
System Cost - Regional Multiplier	Ratio	1.000	1.000
System Cost - Regional Cost	\$/kW	\$720	\$1,100
	\$/Useable kWh	\$30	\$46
<b>Fixed O&amp;M</b>			
Fixed O&M Cost	\$/kW-Yr.	\$15.8	\$8.8
Periodic Major Maintenance	\$/kW	\$0	\$0
period between maintenance	years	4	4
Property Tax	% of \$/kW capex	1.0%	0.0%
Insurance Cost	% of \$/kW capex	0.5%	0.0%
<b>Variable O&amp;M</b>			
Variable Costs	\$/kWh produced	\$0.00400	\$0.00300

**NOTE:** CT estimates typical of a frame type turbine with heat rate of 11,000 Btu/kWh for CT and 6.900 Btu/kWh for the CCGT. Simple cycle aero derivative CTs would have higher capital costs and lower heat rates.

The CT is generally viewed as a capacity resource to be used during a limited number of peak hours. The CCGT, on the other hand, is a baseload energy resource. The leveled cost of capacity for the CT, for fixed costs only and for both fixed and variable costs, is \$124/kW-yr. and \$156/kW-yr., respectively. With a capacity factor of only 5%, the LCOE including both fixed and variable cost is relatively high at \$357/MWh. The CCGT has a low LCOE at \$71/MWh. The leveled cost of capacity considering fixed costs only is \$173/kW-yr. With variable costs also included, the leveled cost of capacity is \$498/kW-yr.

One of the first questions often asked about energy storage is how it compares to a CT as a peaking or flexible resource. The CT serves as the proxy or benchmark of choice for a flexible capacity resource. CTs can be started on short notice (approximately 10 minutes) and ramp quickly (approximately 3 MW/minute). This report focuses solely on technology costs. On the cost side, energy storage technology costs range from near to much higher than the cost of a CT on a \$/kW installed basis. As discussed above, the relevant leveled cost metric for a CT is capacity (\$/kW-yr), not LCOE (\$/MWh). With the assumptions used in this appendix, the leveled cost of capacity for all the energy storage technologies are well above the \$156/kW-yr. for a CT.

## Appendix B: Storage System Cost Details


The cost side, however, is only part of the story when comparing storage to a CT. Another important consideration is the operational value of the capacity to the system operator. Many storage technologies offer greater operational flexibility, faster response times, and faster ramp rates than a CT, all of which are of increasing value with increasing penetrations of intermittent renewable resource. How to value storage and fossil capacity on a comparable basis is an area of active study and debate and beyond the scope of this appendix.

Another consideration is the net revenues earned by storage or a CT in energy, ancillary service (AS), and other markets. When calculating the cost or value of capacity, the net revenues (or net margins) earned from other markets are first subtracted from the full cost of the plant. This results in a residual capacity value or Cost of New Entry (CONE). The CONE represents the additional payments needed over and above energy and AS market revenues to provide sufficient incentive for a developer to construct and operate a new plant in the region. These values are used by ISOs such as PJM, NYISO, and CAISO to establish benchmarks for the value of new capacity.

CTs bid into energy and AS markets when it is economical to do so based on their cost of generation, driven primarily by the cost of natural gas. CTs also incur start-up and minimum operating costs to stand ready to provide energy or AS. Because of these costs and because CTs are less efficient (have a high heat rate) compared to CCGTs, CTs generally have a relatively low capacity factor on the order of 5% to 15%.

Many storage technologies do not have such constraints and can reasonably be expected to earn more net revenues than a CT. Storage technologies without minimum operating or standby costs will find it more frequently economical to bid into energy and AS markets. Furthermore, a 50-MW CT with a minimum operating level of 10 MW could only offer 20 MW of regulation up and down with a set point of 30 MW (and associated operating costs). In comparison, a similarly sized battery could offer a full 50 MW of regulation up and down at a set point of 0 MW (with minimal operating costs).

The relevant comparison from a cost standpoint is residual capacity value after net revenues for a CT and storage technology have been subtracted. A full analysis of net revenues requires a co-optimized dispatch such as that performed by EPRI's ESVT, which is beyond the scope of this analysis. However, an illustrative comparison is shown in Figure B-3. An example CT with a leveledized capacity cost of \$188/kW-yr. operating in California earns \$49/kW-yr. in net revenue in the energy and AS markets (at capacity factor of 9%).<sup>7</sup> This leaves a residual capacity value of \$139/kW-yr. An energy storage system has a higher leveledized cost, but also higher net revenues. The key question will be: Do the higher net revenues for energy storage offset the higher costs to such a degree as to make the residual capacity values comparable?



**Figure B-3. Illustrative Comparison of CT and Energy Storage Residual Capacity Value Calculation**


This analysis leaves us with two primary considerations when comparing energy storage to a CT. With respect to cost: how do the residual capacity values (or CONEs) for the two technologies compare? With respect to value: how much additional value does a megawatt of storage have compared to a megawatt of flexible fossil generation?

<sup>7</sup> CAISO, 2012.

## B.4 Technology Cost Tables

The following mini-charts are organized by service and summarize the detailed information in the tables for each technology which are shown in the sections that follow.

### BULK STORAGE




## Appendix B: Storage System Cost Details


T &amp; D

DESS \C&amp;I

RESIDENTIAL



## Appendix B: Storage System Cost Details



The cost tables on the following pages are organized by technology and show detailed information summarized in the mini-charts above.

## Appendix B: Storage System Cost Details

**B.4.1 Pumped Hydro**

**Table B-12. Cost Estimates for New Greenfield Pumped Hydro Projects**  
*(Parameters noted in black are vendor inputs.)*

Technology Type For Bulk Storage Application Survey Year	Pumped Hydro 2010	Pumped Hydro 2010	Pumped Hydro 2010	Pumped Hydro 2010
<b>DESIGN BASIS - General</b>				
Unit Capacity - Net kW	280,000	1,300,000	900,000	1,200,000
Hours of Energy storage at rated Capacity - hrs	8	9	16	8
Depth of Discharge (DOD) per cycle	1	1	1	1
Energy Capacity - kWh @ rated DOD	2,240,000	11,700,000	14,400,000	9,600,000
Energy Capacity - kWh @ 100% DOD	2,240,000	11,700,000	14,400,000	9,600,000
Auxiliaries - kW	na			
Unit Size - Net kW	variable	variable	variable	variable
Number of Units - #	1 - 4	1 - 4	1 - 4	1 - 4
Physical Size - Unit / SF	< 10 Acres	250 Acres	40 Acres	250 Acres
Foot Print - SF	40 Acres	250 Acres	40 Acres	250 Acres
Unit Weight - lbs	NA	NA	NA	NA
Round Trip AC / AC Efficiency - %	81%	81%	81%	81%
Number of cycles / year	365	365	365	365
<b>DESIGN BASIS - Site</b>				
Design Summer Ambient T - °F	NA	NA	NA	NA
Design Winter Ambient T - °F	NA	NA	NA	NA
<b>GENERAL - Timing</b>				
Plant Life, yrs	60	60	60	60
<b>TOTAL PLANT COST</b>				
\$/kW	\$2,500	\$1,850	\$2,200	\$2,700
\$/kWh @ rated DOD	\$312.50	\$206	\$138	\$338
\$/kWh @ 100% DOD	NA	NA	NA	NA
\$/kWh Delivered @ rated DOD				
<b>PLANT COST</b>				
Power - \$/kW (all elect/mech equipment including prime mover and balance of plant systems to support unit ops)	fixed speed	variable speed	fixed speed	variable speed
	\$550	\$750	\$550	\$750
Storage - \$/kWh @ 6 hours	\$156		\$103	
Storage - \$/kWh (construct the physical facility to hold the storage and this cost includes all civil works and water conveyance)	900 - 2000		900 - 2000	
<b>SYSTEM COSTS - Equipment &amp; Install</b>				
	\$/kW	Actual Cost	\$/kW	Actual Cost
<b>Pumped Hydro System</b>				
Pumped Hydro Equipment - included in row 56 above				
Pumped Hydro Installation - included in row 56 above				
Enclosures				
<b>Utility Interconnection</b>				
Equipment				
Installation				
<b>Site BOP Installation (Civil Only) - all site civil and water conveyance costs incl in row 57 above.</b>				
<b>Total Cost Equipment</b>				
<b>Total Cost Installation</b>				
General Contractor Facilities at 15% install				
Engineering Fees @ 5% Install				
Project Contingency Application @ 5% install				
Process Contingency Application @ 5% of battery				
<b>Total Plant Cost (TPC)</b>	\$2,500	\$700,000,000	\$1,850	\$2,405,000,000
<b>OPERATING EXPENSES</b>				
<b>Fixed O&amp;M - \$/kW-yr</b>		\$8.21	\$5.60	\$6.13
Periodic Major Maintenance - \$/kW		\$112	\$112	\$112
Period between Major Maintenance - yrs		20	20	20
<b>Variable O&amp;M - \$/kWh (Charging or Discharging)</b>		\$0.00029	\$0.0003	\$0.0003

**Notes:**

Transmission costs not included and could be substantial as the typical voltage is 500kV.  
 New stations which use variable speed drives are incrementally higher than fixed speed units.

Projects that have at least one existing reservoir will be on the low end of this civil cost range.

No interconnect costs are included.

Periodic maintenance costs are estimated at \$112/kW and include the following major maintenance activities: complete turbine overhaul and disassembly every 10 years; complete generator rewind every 20 years; estimates are based on actual pumped storage operating plants.

**B.4.2 CAES*****Cost Estimates for CAES Systems***

CAES systems sized up to 400 MW to 2000 MW or more are possible, as are underground storage durations of 20 to 30 hours or longer. CAES plants may have heat rates near 3850 Btu/kWh; energy ratios (kWh in/kWh out) can range from 0.68–0.75. Estimates include process and project contingency and costs for nitrogen oxides (NO<sub>x</sub>) emission-control technology [Selective Catalytic Reduction (SCR)]. A storage cavern with salt geology is assumed; costs for other geologies can vary significantly and are site-specific. Costs for siting, permitting, environmental impact studies, geological assessments, and owner's costs are not included. These cost elements can be very significant. Future system costs may be lower once standard, pre-designed systems are available.

Table B-13 provides reference cost estimates for several CAES plant systems. Data are based on several reference designs from vendors.

## Appendix B: Storage System Cost Details

**Table B-13. Cost Estimates for CAES Systems**

Technology Type For Bulk Storage Application	CT-CAES (Below Ground)	CT-CAES (Above Ground)	CT-CAES (Above Ground)	CT-CAES (Above Ground)	BRAYTON-CAES (Below Ground)	BRAYTON-CAES (Below Ground)
<b>Survey Year</b>	2011	2011	2010	2011	2011	2011
<b>System Size</b>	50 MW	50 MW	50 MW	50 MW	103 MW	103 MW
<b>Storage Capacity (Hours)</b>	8-26	5	5	5	8-20	8-20
<b>Supplier</b>	<b>S12</b>	<b>S12 - 2</b>	<b>S0</b>	<b>S12 - 1</b>	<b>S9 - 1</b>	<b>S9 - 2</b>
<b>DESIGN BASIS - General</b>						
Minimum storage pressure for full generation capability - psia @ surface	~ 400-800	~ 400-800		~ 400-800	315	315
Maximum compression discharge pressure - psia @ surface	~ 1500-2000	~ 1500-2000		~ 1500-2000	515	515
Storage type - above or below ground	Salt Dome, Aquifer or Hard Rock	Above Ground		Above Ground	Shallow aquifer	Shallow aquifer
Unit Net Capacity - MW @ 95F ambient	50.0	50.0	50	50.0	103	103
Combustion Turbine Capacity - MW, if applicable	19.2	19.2	24	19.5	103	103
Air Expander(s) Total Net Capacity - MW	30.8	30.8	26	30.5		
CAES Energy Stored/Released/Generated based on 8 hrs generation (or 2 hours for above ground air storage) - MWH	304 / 400	124 / 250 (5 hours)	250, for a 5 hour storage plant	190 / 250 (5 hours)	823.8 MWh	826.5 MWh
More Storage -- CAES Energy Stored/ Released/ Generated based on 20 hrs generation (or 4 hours for above ground air storage) - MWH	988 / 1300	N/A		N/A	2,059 MWh	2,066.2 MWh
Round Trip AC / AC Efficiency - %						
Energy Charge Ratio - kWh in/kWh out @ Full Load	0.70	0.45	0.8	0.70	0.74	0.74
Number of cycles / year	365	365	365	365	365	365
CAES Plant unit Net Heat Rate @ Full Load - Btu/kwh (LHV)	3,900	5,880	4,091	3,900	3,916	3,901
Total Compressors Power - MW. Compressors number are optimized to meet "smart" grid requirements.	19.0	Jan-00	23	Jan-00	76470 kW (based on 415 psia mean)	76150 kW (based on 415 psia mean)
Hours of Energy storage at Rated Capacity shown - hrs	8.0	5.0	5	5.0	8.0	8
More Storage -- CAES Energy Stored/Released - kWh based on 20 hrs storage for underground	1,300,000	N/A		N/A	2,059,400	2,066,500
Storage Efficiency (Energy Generated/Energy Stored); Inverse of Energy Ratio - %	>90%	>90%	See Heat Rate and Energy Ratio	>90%	1.346	1.357
<b>DESIGN BASIS - Site</b>						
Design Summer Ambient T - °F	95F	95F		95F	60	60
Design Winter Ambient T - °F	Not Limited	Not Limited		Not Limited		
<b>GENERAL - Timing</b>						
Month \$ for Input Data	9	9	9	9		
Plant Life - yrs	40	40	35	40	40	40
Pre-construction Time - yrs						
<b>TOTAL PLANT COST</b>						
\$/kW	\$1,210	\$1,762	\$1,950	\$1,958	\$1,040	\$1,053
\$/kWh @ rated DOD	\$151	\$352	\$390	\$392	\$130	\$132
\$/kWh @ 100% DOD	\$151	\$352	\$390	\$392	\$130	\$132
<b>TOTAL PLANT COST (More Storage)</b>						
\$/Kw (20 or 26 hours underground storage)	\$1,359				\$1,129	\$1,142
\$/kWh @ rated DOD	N/A				N/A	N/A
\$/kWh @ 100% DOD	\$52				\$56	\$57
<b>PLANT COST</b>						
Power - \$/kW	\$1,078	\$1,188	\$1,131	\$1,078	\$921	\$934
Storage - \$/kWh @ 8 hours underground, varies above ground	\$17	\$115	\$164	\$176	\$15	\$15
Storage - \$/kWh @ 20 or 26 hours	\$11	N/A	N/A	N/A	\$10	\$10
Incremental Cost for each hour of storage - \$/kW-hour						
<b>SYSTEM COSTS - Equipment &amp; Install</b>						
<b>CAES Capital Costs</b>						
Power Plant Cost Excluding Storage	\$49,000,000	\$54,000,000	\$56,550,000	\$49,000,000	\$56,118,650	\$57,655,350
BOP equipment and installation	included	included	included	included	\$35,215,740	\$35,337,150
Compressed Air Storage Cost	\$6,000,000	\$26,105,300	\$40,950,000	\$40,000,000	\$11,120,760	\$11,159,100
Total CAES Plant Cost	55,000,000	80,105,300	88,636,364	89,000,000	102,455,150	104,151,600
Total CAES Plant Cost w/ 10% Contingency of BOP and Storage	\$60,500,000	\$88,115,830	\$97,500,000	\$97,900,000	\$107,088,800	\$108,801,225
CAES TPC (\$/kW) (8 hours underground storage)	\$1,210	\$1,762	\$1,950	\$1,958	\$1,040	\$1,053
<b>Capital Costs (More Storage)</b>						
Power Plant Cost Excluding Storage	\$49,000,000				\$91,334,390	\$92,992,500
Compressed Air Storage Cost	\$12,750,000				\$19,461,330	\$19,528,425
Total CAES Plant Cost w/ 10% Contingency	\$67,925,000				\$116,263,427	\$118,007,483
CAES TPC (\$/kW) (20 or 26 hours underground storage)	\$1,359				\$1,129	\$1,142
<b>Total Plant Cost (TPC)</b>	\$60,500,000	\$88,115,830	\$97,500,000	\$97,900,000	\$107,088,800	\$108,801,225
<b>OPERATING EXPENSES</b>						
Fixed O&M - \$/kW-yr	\$3	\$3	\$4	\$3	\$5	\$5
Periodic Major Maintenance - \$/kW	\$90	\$90	\$90	\$90	\$90	\$90
Period between Major Maintenance - yrs	4	7	7	7	4	4
Variable O&M - \$/kWh (Charging or Discharging)	\$0.0030	\$0.0030	\$0.0040	\$0.0030	\$0.0035	\$0.0035

## Appendix B: Storage System Cost Details

Table B-13. Cost Estimates for CAES Systems (continued)

Technology Type For Bulk Storage Application	BRAYTON-CAES (Below Ground)	BRAYTON-CAES (Below Ground)	CT-CAES (Below Ground)	CT-CAES (Below Ground)	CT-CAES (Below Ground)	BRAYTON-CAES (Below Ground)	CT-CAES (Below Ground)
<b>Survey Year</b>	2011	2011	2011	2011	2011	2011	2011
<b>System Size</b>	136 MW	136 MW	183 MW	236 MW	322 MW	408 MW	441 MW
<b>Storage Capacity (Hours)</b>	8-20	8-20	8-26	8-26	8-26	8-20	8-26
<b>Supplier</b>	S9 - 1	S9 - 2	S12	S12	S12	S9	S12
<b>DESIGN BASIS - General</b>							
Minimum storage pressure for full generation capability - psia @ surface	900	900	~ 400-800	~ 400-800	~ 400-800	900	~ 400-800
Maximum compression discharge pressure - psia @ surface	1200	1200	~ 1500-2000	~ 1500-2000	~ 1500-2000	1200	~ 1500-2000
Storage type - above or below ground	Salt, hard rock, deep aquifer	Salt, hard rock, deep aquifer	Salt Dome, Aquifer or Hard Rock	Salt Dome, Aquifer or Hard Rock	Salt Dome, Aquifer or Hard Rock	salt, hard rock, deep aquifer	Salt Dome, Aquifer or Hard Rock
Unit Net Capacity - MW @ 95F ambient	136	136	182.7	236.0	321.8	408	441.0
Combustion Turbine Capacity - MW, if applicable	136	136	65.3	86.0	122.2	408	174.0
Air Expander(s) Total Net Capacity - MW			117.4	150.0	199.5		267.0
CAES Energy Stored/Released/Generated based on 8 hrs generation (or 2 hours for above ground air storage) - MWh	1,085 MWh	1,088 MWh	1168 / 1462	1422 / 1888	1838 / 2574	3,264 MWh	2528 / 3528
<b>More Storage</b> -- CAES Energy Stored/ Released/ Generated based on 20 hrs generation (or 4 hours for above ground air storage) - MWh	2,712 MWh	2,720 MWh	3796 / 4750	4623 / 6136	5975 / 8367	8,160 MWh	8216 / 11466
Round Trip AC / AC Efficiency - %							
Energy Charge Ratio - kWh in/kWh out @ Full Load	0.75	0.74	0.70	0.70	0.70	0.74	0.70
Number of cycles / year	365	365	365	365	365	365	365
CAES Plant unit Net Heat Rate @ Full Load - Btu/kwh (LHV)	3,857	3,847	3,847	3,770	3,784	3,847	3,760
Total Compressors Power - MW. Compressors number are optimized to meet "smart" grid requirements.	101592 kW (based on 1050)	101272 kW (based on 1050)	73.0	88.9	114.9	303816 kW (based on 1050)	158.0
Hours of Energy storage at Rated Capacity shown - hrs	8.0	8.0	8	8.0	8.0	8	8.0
<b>More Storage</b> -- CAES Energy Stored/Released - kWh based on 20 hrs storage for underground	2,712,400	2,720,000	4,750,200	6,136,000	8,366,280	8,160,000	11,466,000
Storage Efficiency (Energy Generated/Energy Stored); Inverse of Energy Ratio - %	1.335	1.344	>90%	>90%	>90%	1.344	>90%
<b>DESIGN BASIS - Site</b>							
Design Summer Ambient T - °F	60	60	95F	95F	95F	60	95F
Design Winter Ambient T - °F			Not Limited	Not Limited	Not Limited		Not Limited
<b>GENERAL - Timing</b>							
Month \$ for Input Data							
Plant Life - yrs	40	40	40	40	40	40	40
Pre-construction Time - yrs							
<b>TOTAL PLANT COST</b>							
\$/kW	\$1,050	\$1,065	\$957	\$997	\$769	\$787	\$656
\$/kWh @ rated DOD	\$131	\$133	\$120	\$125	\$96	\$98	\$82
\$/kWh @ 100% DOD	\$131	\$133	\$120	\$125	\$96	\$98	\$82
<b>TOTAL PLANT COST (More Storage)</b>							
\$/kW (20 or 26 hours underground storage)	\$1,149	\$1,164	\$1,106	\$1,144	\$919	\$886	\$805
\$/kWh @ rated DOD	N/A	N/A	N/A	N/A	N/A	N/A	N/A
\$/kWh @ 100% DOD	\$57	\$58	\$43	\$44	\$35	\$44	\$31
<b>PLANT COST</b>							
Power - \$/kW	\$918	\$933	\$825	\$867	\$636	\$655	\$524
Storage - \$/kWh @ 8 hours underground, varies above ground	\$17	\$17	\$17	\$16	\$17	\$17	\$17
Storage - \$/kWh @ 20 or 26 hours	\$12	\$12	\$11	\$11	\$11	\$12	\$11
Incremental Cost for each hour of storage - \$/kW-hour							
<b>SYSTEM COSTS - Equipment &amp; Install</b>							
<b>CAES Capital Costs</b>							
Power Plant Cost Excluding Storage	\$67,810,000	\$70,040,000	\$137,000,000	\$186,000,000	\$186,000,000	\$186,300,000	\$210,000,000
BOP equipment and installation	\$51,535,600	\$51,680,000	included	included	included	\$73,440,000	included
Compressed Air Storage Cost	\$16,274,400	\$16,320,000	\$22,000,000	\$28,000,000	\$39,000,000	\$48,960,000	\$53,000,000
Total CAES Plant Cost	135,620,000	138,040,000	159,000,000	214,000,000	225,000,000	308,700,000	263,000,000
Total CAES Plant Cost w/ 10% Contingency of BOP and Storage	\$142,401,000	\$144,840,000	\$174,900,000	\$235,400,000	\$247,500,000	\$320,940,000	\$289,300,000
CAES TPC (\$/kW) (8 hours underground storage)	\$1,050	\$1,065	\$957	\$997	\$769	\$787	\$656
<b>Capital Costs (More Storage)</b>							
Power Plant Cost Excluding Storage	\$119,345,600	\$121,720,000	\$137,000,000	\$186,000,000	\$186,000,000	\$259,740,000	\$210,000,000
Compressed Air Storage Cost	\$28,480,200	\$28,560,000	\$46,750,000	\$59,500,000	\$82,875,000	\$85,680,000	\$112,625,000
Total CAES Plant Cost w/ 10% Contingency	\$155,827,380	\$158,304,000	\$202,125,000	\$270,050,000	\$295,762,500	\$361,332,000	\$354,887,500
CAES TPC (\$/kW) (20 or 26 hours underground storage)	\$1,149	\$1,164	\$1,106	\$1,144	\$919	\$886	\$805
<b>Total Plant Cost (TPC)</b>	\$142,401,000	\$144,840,000	\$174,900,000	\$235,400,000	\$247,500,000	\$320,940,000	\$289,300,000
<b>OPERATING EXPENSES</b>							
Fixed O&M - \$/kW-yr	\$5	\$5	\$3	\$3	\$3	\$5	\$3
Periodic Major Maintenance - \$/kW	\$90	\$90	\$90	\$90	\$90	\$90	\$90
Period between Major Maintenance - yrs	4	4	4	4	4	4	4
Variable O&M - \$/kWh (Charging or Discharging)	\$0.0035	\$0.0035	\$0.0030	\$0.0030	\$0.0030	\$0.0035	\$0.0030

**Notes:** Total plant cost (TPC) assumes a conditioned site with all utilities available to the plant and no site-specific costs such as roads, fencing, and site prep. Cost allowances for substation and utility interface are assumed to be included, as well as engineering and project and process contingencies in the TPC. Cost allowances for substation and utility interface are included, as well as engineering and project and process contingencies in the TPC. Cost adjustments, to account for greater hours of storage capacity and increased underground storage volume beyond the minimum ranges listed, are a small portion of the TPC and are dependent on geology of the site.

### B.4.3 Sodium Sulphur Battery

**Table B-14. Performance, Design, and Cost of NaS Systems**  
*(Parameters noted in black are vendor inputs.)*

Application	Bulk Storage	Bulk Storage	Utility T&D	Utility T&D
Technology Type	NaS	NaS	NaS	NaS
Supplier	S36	S36	S36	S36
Survey Year	2010	2010	2010	2010
<b>DESIGN BASIS - General</b>				
System Capacity - Net kW	50,000	100,000	1,000	12,000
Hours of Energy storage at rated Capacity - hrs	6	7.2	7.2	7.2
Depth of Discharge (DOD) per cycle - %	80%	80%	80%	80%
Energy Capacity - kWh @ rated DOD	300,000	720,000	7,200	86,400
Energy Capacity - kWh @ 100% DOD	375,000	900,000	9,000	108,000
Auxiliaries - kW	0	0	0	0
Unit Size - Net kW	50	100	1	12
Number of Units - #	50	100	1	12
Physical Size - SF/Unit			168	
System Foot Print - SF	100,000	200,000	2,090	25,080
System Weight - lbs	3,500,000	7,000,000	70,000	840,000
Round Trip AC / AC Efficiency - %	75%	75%	75%	75%
Number of cycles / year	365	365	365	365
<b>GENERAL - Timing</b>				
Commercial Order Date				
Plant Life, yrs	15	15	15	15
<b>TOTAL PLANT COST</b>				
\$/kW	\$3,071	\$3,168	\$3,434	\$3,152
\$/kWh @ rated DOD	\$512	\$440	\$477	\$438
\$/kWh @ 100% DOD	\$409	\$352	\$382	\$350
<b>PLANT CAPITAL COST</b>				
Power - \$/kW	\$516	\$490	\$757	\$474
Storage - \$/kWh @ rated DOD	\$426	\$372	\$372	\$372
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Projected Cost	Projected Cost	Projected Cost	Projected Cost
<b>ES System</b>				
ES Equipment	\$110,000,000	\$230,000,000	\$2,300,000	\$27,600,000
ES Installation	\$17,600,000	\$37,500,000	\$375,000	\$4,500,000
Enclosures	included	included	included	included
<b>Owner Interconnection</b>				
Equipment	\$9,981,500	\$18,893,500	\$367,000	\$2,288,500
Installation	\$1,247,500	\$2,361,500	\$92,000	\$572,000
Enclosures	Included	Included	Included	Included
<b>System Packing</b>	included	included	included	included
<b>System Shipping to US Port</b>	\$135,000	\$270,600	\$2,706	\$32,472
<b>Utility Interconnection</b>				
Equipment	\$3,875,000	\$6,875,000	\$80,400	\$695,000
Installation	\$3,875,000	\$6,875,000	\$80,400	\$695,000
<b>Site BOP Installation (Civil Only)</b>	included	included	included	included
<b>Total Cost Equipment</b>	\$123,991,500	\$256,039,100	\$2,750,106	\$30,615,972
<b>Total Cost Installation</b>	\$22,722,500	\$46,736,500	\$547,400	\$5,767,000
General Contractor Facilities at 15% install	\$3,408,375	\$7,010,475	\$82,110	\$865,050
Engineering Fees @ 5% Install	\$1,136,125	\$2,336,825	\$27,370	\$288,350
Project Contingency Application @ 0-15% install	\$2,272,250	\$4,673,650	\$27,370	\$288,350
Process Contingency Application @ 0-15% of battery	\$0	\$0	\$0	\$0
<b>Total Plant Cost (TPC)</b>	\$153,530,750	\$316,796,550	\$3,434,356	\$37,824,722
<b>OPERATING EXPENSES</b>				
FIXED O&M - \$/kW-yr	\$4.5	\$4.3	\$9.2	\$4.8
Replacement Battery Costs - \$/kW	\$0	\$0	\$0	\$0
Battery replacement - yrs	15	15	15	15
Variable O&M - \$/kWh (Charging or Discharging)	0.0005	0.0004	0.0008	0.0004

## Appendix B: Storage System Cost Details

**B.4.4 Sodium-nickel-chloride Battery**

Data sheets for several references systems are provided in Table B-15.

**Table B-15. Cost and Performance of Sodium-nickel-chloride Battery Systems**  
(Parameters noted in black are vendor inputs.)

Application	Bulk Storage	Bulk Storage	Bulk Storage	FR & RI	Utility T&D	Utility T&D	DESS	Commercial & Industrial
<b>Technology Type</b>	Sodium Metal Halide	Sodium Metal Halide	Sodium Metal Halide	Sodium Metal Halide	Sodium Metal Halide	Sodium Metal Halide	Sodium - Metal Halide	Sodium Metal Halide
<b>Supplier</b>	<b>S16</b>	<b>S16</b>	<b>S17</b>	<b>S17</b>	<b>S16</b>	<b>S17</b>	<b>S16</b>	<b>S17</b>
<b>Survey Year</b>	2011	2011	2011	2011	2011	2011	2011	2011
<b>DESIGN BASIS - General</b>								
System Capacity - Net kW	10,600.0	53,000.0	50,000	1,000	1,060.0	1,000	26.7	500
Hours of Energy storage at rated Capacity - hrs	5	5	5	2	5	4	3	2
Depth of Discharge (DOD) per cycle - %	85%	85%	80%	80%	85%	80%	85%	80%
Energy Capacity - kWh @ rated DOD	53,000	265,000	250,000	2,000	5,300	4,000	80	1,000
Energy Capacity - kWh @ 100% DOD	62,275.0	311,375.0	312,500	2,600	6,227.5	5,200	94.0	1,250
Auxiliaries - kW	2120	10600	0	0	212	0	3.2	0
Unit Size - Net kW	10600	53000	1000	1000	901	1000	26.7	500
Number of Units - #	2650	13250	50	1	265	1	4	1
Physical Size - SF/Unit	5	5	1,200	413	5.18	350	5	350
System Foot Print - SF	5152	25762	60,000	588	1030	588	8	588
System Weight - lbs	1,291,345	6,456,725	7,500,000	80,000	129,135	150,000	1,949	
Round Trip AC / AC Efficiency - %	88%	88%	86%	86%	88%	86%	84%	84%
Number of cycles / year	365	365	365	365	365	365	365	365
<b>GENERAL - Timing</b>								
Commercial Order Date	3 <sup>rd</sup> quarter 2012	3 <sup>rd</sup> quarter 2012	Q1 2012	Q1 2012	1 <sup>st</sup> quarter 2012	Q1 2012	1 <sup>st</sup> quarter 2012	Q1 2012
Plant Life, yrs	<b>15</b>	<b>15</b>	15	<b>15</b>	15	<b>15</b>	<b>15</b>	15
<b>TOTAL PLANT COST</b>								
\$/kW	<b>\$5,334</b>	<b>\$4,306</b>	<b>\$2,823</b>	<b>\$1,846</b>	<b>\$5,676</b>	<b>\$2,907</b>	<b>\$4,941</b>	<b>\$2,360</b>
\$/kWh @ rated DOD	<b>\$1,067</b>	<b>\$861</b>	<b>\$565</b>	<b>\$923</b>	<b>\$1,135</b>	<b>\$727</b>	<b>\$1,647</b>	<b>\$1,180</b>
\$/kWh @ 100% DOD	<b>\$908</b>	<b>\$733</b>	<b>\$452</b>	<b>\$710</b>	<b>\$966</b>	<b>\$559</b>	<b>\$1,402</b>	<b>\$944</b>
<b>PLANT CAPITAL COST</b>								
Power - \$/kW	<b>\$482</b>	<b>\$427</b>	<b>\$487</b>	<b>\$800</b>	<b>\$718</b>	<b>\$814</b>	<b>\$1,869</b>	<b>\$1,354</b>
Storage - \$/kWh @ rated DOD	<b>\$970</b>	<b>\$776</b>	<b>\$467</b>	<b>\$523</b>	<b>\$992</b>	<b>\$523</b>	<b>\$1,024</b>	<b>\$503</b>
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Actual Cost	Actual Cost	Actual Cost	Actual Cost	Actual Cost	Actual Cost	Actual Cost	Actual Cost
<b>ES System</b>								
ES Equipment	<b>\$45,460,750</b>	<b>\$181,843,000</b>	<b>\$101,562,500</b>	<b>\$910,000</b>	<b>\$4,546,075</b>	<b>\$1,820,000</b>	<b>\$68,620</b>	<b>\$437,500</b>
ES Installation	<b>\$1,363,823</b>	<b>\$5,455,290</b>	<b>\$5,078,125</b>	<b>\$45,500</b>	<b>\$227,304</b>	<b>\$91,000</b>	<b>\$3,431</b>	<b>\$21,875</b>
Enclosures	<b>\$187,484</b>	<b>\$929,418</b>	<b>\$2,162,000</b>	<b>\$40,064</b>	<b>\$39,097</b>	<b>\$40,064</b>	<b>\$2,350</b>	<b>\$40,064</b>
<b>Owner Interconnection</b>								
Equipment	<b>\$2,288,500</b>	<b>\$9,981,500</b>	<b>\$9,981,500</b>	<b>\$367,000</b>	<b>\$367,000</b>	<b>\$367,000</b>	<b>\$31,000</b>	<b>\$233,500</b>
Installation	<b>\$572,000</b>	<b>\$1,247,500</b>	<b>\$1,247,500</b>	<b>\$92,000</b>	<b>\$92,000</b>	<b>\$92,000</b>	<b>\$15,500</b>	<b>\$58,500</b>
Enclosures	Included	Included	Included	Included	Included	Included	Included	Included
<b>System Packing</b>	Included	Included	\$0	\$0	Included	\$0	Included	\$0
<b>System Shipping to US Port</b>	\$61,146	\$135,880	\$0	\$0	\$27,176	\$0	\$3,000	\$0
<b>Utility Interconnection</b>								
Equipment	<b>\$695,000</b>	<b>\$3,875,000</b>	<b>\$3,875,000</b>	<b>\$80,000</b>	<b>\$80,400</b>	<b>\$80,400</b>	<b>\$250</b>	<b>\$70,400</b>
Installation	<b>\$695,000</b>	<b>\$3,875,000</b>	<b>\$3,875,000</b>	<b>\$80,000</b>	<b>\$80,400</b>	<b>\$80,400</b>	<b>\$250</b>	<b>\$70,400</b>
<b>Site BOP Installation (Civil Only)</b>								
Total Cost Equipment	<b>\$10,305</b>	<b>\$51,523</b>	<b>\$120,000</b>	<b>\$58,000</b>	<b>\$2,061</b>	<b>\$58,000</b>	<b>\$500</b>	<b>\$58,000</b>
Total Cost Installation	<b>\$48,692,880</b>	<b>\$196,764,798</b>	<b>\$117,581,000</b>	<b>\$1,397,064</b>	<b>\$5,059,747</b>	<b>\$2,307,464</b>	<b>\$105,220</b>	<b>\$781,464</b>
General Contractor Facilities at 15% install	<b>\$396,169</b>	<b>\$1,594,397</b>	<b>\$1,548,094</b>	<b>\$41,325</b>	<b>\$60,265</b>	<b>\$48,210</b>	<b>\$0</b>	<b>\$31,316</b>
Engineering Fees @ 5% Install	<b>\$132,056</b>	<b>\$531,466</b>	<b>\$516,031</b>	<b>\$13,775</b>	<b>\$20,088</b>	<b>\$16,070</b>	<b>\$0</b>	<b>\$10,439</b>
Project Contingency Application @ 0-15% install	<b>\$132,056</b>	<b>\$531,466</b>	<b>\$1,032,063</b>	<b>\$27,550</b>	<b>\$20,088</b>	<b>\$32,140</b>	<b>\$0</b>	<b>\$104,388</b>
Process Contingency Application @ 0-15% of battery	<b>\$4,546,075</b>	<b>\$18,184,300</b>	<b>\$10,156,250</b>	<b>\$91,000</b>	<b>\$454,608</b>	<b>\$182,000</b>	<b>\$6,862</b>	<b>\$43,750</b>
<b>Total Plant Cost (TPC)</b>	<b>\$56,540,364</b>	<b>\$228,235,740</b>	<b>\$141,154,063</b>	<b>\$1,846,214</b>	<b>\$6,016,561</b>	<b>\$2,907,284</b>	<b>\$131,763</b>	<b>\$1,180,132</b>
<b>OPERATING EXPENSES</b>								
FIXED O&M - \$/kW-yr	<b>\$5.4</b>	<b>\$4.2</b>	<b>\$4.5</b>	<b>\$9.2</b>	<b>\$8.7</b>	<b>\$9.2</b>	<b>\$34.9</b>	<b>\$11.7</b>
Replacement Battery Costs - \$/kW	<b>\$1,287</b>	<b>\$1,029</b>	<b>\$0</b>	<b>\$273</b>	<b>\$1,287</b>	<b>\$0</b>	<b>\$772</b>	<b>\$0</b>
Battery replacement - yrs	<b>8</b>	<b>8</b>	<b>15</b>	<b>15</b>	<b>8</b>	<b>15</b>	<b>8</b>	<b>15</b>
Variable O&M - \$/kWh (Charging or Discharging)	<b>0.0005</b>	<b>0.0005</b>	<b>0.0005</b>	<b>0.0027</b>	<b>0.0011</b>	<b>0.0014</b>	<b>0.0018</b>	<b>0.0027</b>

### B.4.5 Vanadium Redox Battery

#### Performance and Cost Characteristics

Data sheets for several vanadium system reference designs are provided in Table B-16.

**Table B-16. Cost and Performance of Vanadium Redox Battery Systems**  
(Parameters noted in black are vendor inputs.)

Application	Bulk Storage	Utility T&D	Utility T&D	Commercial & Industrial	Commercial & Industrial
<b>Technology Type</b>	<b>Vanadium Redox</b>	<b>Vanadium Redox</b>	<b>Vanadium Redox</b>	<b>Vanadium Redox</b>	<b>Vanadium Redox</b>
<b>Supplier</b>	<b>S32</b>	<b>S32</b>	<b>S32</b>	<b>S32</b>	<b>S32</b>
<b>Survey Year</b>	2011	2011	2011	2011	2011
<b>DESIGN BASIS - General</b>					
System Capacity - Net kW	50000	10000	10000	200	1200
Hours of Energy storage at rated Capacity - hrs	5	4	5	3.5	3.33
Depth of Discharge (DOD) per cycle - %	100%	100%	100%	100%	100%
Energy Capacity - kWh @ rated DOD	250,000	40000	50000	700	3996
Energy Capacity - kWh @ 100% DOD	250,000	40000	50000	700	3996
Auxiliaries - kW	3375	675kW	675kW	17.5kW	
Unit Size - Net kW	250	250	250	200	200
Number of Units - #	200	40	40	1	5
Physical Size - SF/Unit	integrated	200	200	220	220
System Foot Print - SF	101,850	20,000	20,370	356	2037
System Weight - lbs	24,750,000	9,800,000	10,980,000	32000	32000
Round Trip AC / AC Efficiency - %	75%	72%	72%	68%	68%
Number of cycles / year	365	365	365	365	365
<b>GENERAL - Timing</b>					
Commercial Order Date	Late 2011				
Plant Life, yrs	15	15	15	15	15
<b>TOTAL PLANT COST</b>					
\$/kW	\$3,734	\$3,335	\$3,756	\$5,213	\$3,203
\$/kWh @ rated DOD	\$747	\$834	\$751	\$1,490	\$962
\$/kWh @ 100% DOD	\$747	\$834	\$751	\$1,490	\$962
<b>PLANT CAPITAL COST</b>					
Power - \$/kW	\$635	\$656	\$657	\$2,133	\$706
Storage - \$/kWh @ rated DOD	\$620	\$670	\$620	\$880	\$750
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Projected Cost	Projected Cost	Projected Cost	Projected Cost	Projected Cost
<b>ES System</b>					
ES Equipment	\$124,380,000	\$20,876,000	\$24,876,000	\$480,000	\$2,458,571
ES Installation	\$24,350,000	\$4,870,000	\$4,870,000	\$112,000	\$415,000
Enclosures	\$3,668,600	\$722,000	\$735,320	\$30,048	\$75,332
<b>Owner Interconnection</b>					
Equipment	\$9,981,500	\$2,288,500	\$2,288,500	\$131,500	\$367,000
Installation	\$1,247,500	\$572,000	\$572,000	\$33,000	\$92,000
Enclosures	Included	Included	Included	Included	Included
<b>System Packing</b>	\$0	\$0	\$0	\$0	\$0
<b>System Shipping to US Port</b>	\$0	\$0	\$0	\$0	\$0
<b>Utility Interconnection</b>					
Equipment	\$3,875,000	\$695,000	\$695,000	\$62,900	\$80,400
Installation	\$3,875,000	\$695,000	\$695,000	\$62,900	\$80,400
<b>Site BOP Installation (Civil Only)</b>	\$203,700	\$40,000	\$40,740	\$43,500	\$4,074
<b>Total Cost Equipment</b>	\$141,905,100	\$24,581,500	\$28,594,820	\$704,448	\$2,981,303
<b>Total Cost Installation</b>	\$29,676,200	\$6,177,000	\$6,177,740	\$251,400	\$591,474
General Contractor Facilities at 15% install	\$4,451,430	\$926,550	\$926,661	\$37,710	\$88,721
Engineering Fees @ 5% Install	\$1,483,810	\$308,850	\$308,887	\$12,570	\$29,574
Project Contingency Application @ 0-15% install	\$2,967,620	\$308,850	\$308,887	\$12,570	\$29,574
Process Contingency Application @ 0-15% of battery	\$6,219,000	\$1,043,800	\$1,243,800	\$24,000	\$122,929
<b>Total Plant Cost (TPC)</b>	\$186,703,160	\$33,346,550	\$37,560,795	\$1,042,698	\$3,843,574
<b>OPERATING EXPENSES</b>					
FIXED O&M - \$/kW-yr	\$4.5	\$5.7	\$5.7	\$16.5	\$7.7
Replacement Battery Costs - \$/kW	\$746	\$626	\$746	\$720	\$615
Battery replacement - yrs	8.0	8.0	8.0	8.0	8
Variable O&M - \$/kWh (Charging or Discharging)	0.0005	0.0014	0.0011	0.0016	0.0016

## Appendix B: Storage System Cost Details

**B.4.6 Iron-chromium Battery****Performance and Design Characteristics**

Table B-17 provides sample data sheets for conceptual systems by application shown.

**Table B-17. Cost and Performance of Iron-chromium Systems**  
(Parameters noted in black are vendor inputs.)

Application	Bulk Storage	Bulk Storage	PV Integration	Wind Integration	Utility T&D	Utility T&D	Utility T&D	Commercial & Industrial /
Technology Type	Fe / Cr	Fe / Cr	Fe / Cr	Fe / Cr	Fe / Cr	Fe / Cr	Fe / Cr	Fe / Cr
Supplier	<b>S14</b>	<b>S14</b>	<b>S14</b>	<b>S14</b>	<b>S14</b>	<b>S14</b>	<b>S14</b>	<b>S14</b>
Survey Year	2011	2011	2011	2011	2011	2011	2011	2010
<b>DESIGN BASIS - General</b>								
System Capacity - Net kW	50,000	50,000	2,000	100,000	1,000	10,000	50,000	500
Hours of Energy storage at rated Capacity - hrs	5	10	4	8	4	5	5	10
Depth of Discharge (DOD) per cycle - %	100%	100%	100%	100%	100%	100%	100%	100%
Energy Capacity - kWh @ rated DOD	250,000	500,000	8,000	800,000	4,000	50,000	250,000	5,000
Energy Capacity - kWh @ 100% DOD	250,000	500,000	8,000	800,000	4,000	50,000	250,000	5,000
Auxiliaries - kW	250	250	10	500	5	50	250	3
Unit Size - Net kW	10,000	10,000	250	10,000	250	10,000	10,000	250
Number of Units - #	5	5	8	10	4	1	5	2
Physical Size - SF/Unit	42,625	54,250	360	47,000	360	42,625	42,625	700
System Foot Print - SF	222,000	283,000	2,880	245,000	1,440	42,625	222,000	1,400
System Weight - lbs	6,800 metric tons	13,610 metric tons	138 metric tons	10,900 metric	138 metric tons	6,800 metric tons	6,800 metric tons	344 metric tons
Round Trip AC / Ad Efficiency - %	75%	75%	75%	75%	75%	75%	75%	75%
Number of cycles / year	365	365	4000	365	365	365	365	365
<b>GENERAL - Timing</b>								
Commercial Order Date								
Plant Life, yrs	<b>15</b>	<b>15</b>	<b>15</b>	<b>15</b>	<b>15</b>	<b>15</b>	<b>15</b>	<b>15</b>
<b>TOTAL PLANT COST</b>								
\$/kW	<b>\$1,427</b>	<b>\$2,045</b>	<b>\$840</b>	<b>\$1,820</b>	<b>\$1,517</b>	<b>\$1,596</b>	<b>\$1,473</b>	<b>\$2,984</b>
\$/kWh @ rated DOD	<b>\$285</b>	<b>\$205</b>	<b>\$210</b>	<b>\$228</b>	<b>\$379</b>	<b>\$319</b>	<b>\$295</b>	<b>\$298</b>
\$/kWh @ 100% DOD	<b>\$285</b>	<b>\$205</b>	<b>\$210</b>	<b>\$228</b>	<b>\$379</b>	<b>\$319</b>	<b>\$295</b>	<b>\$298</b>
<b>PLANT CAPITAL COST</b>								
Power - \$/kW	<b>\$455</b>	<b>\$485</b>	<b>\$25</b>	<b>\$437</b>	<b>\$701</b>	<b>\$552</b>	<b>\$501</b>	<b>\$1,178</b>
Storage - \$/kWh @ rated DOD	<b>\$194</b>	<b>\$156</b>	<b>\$204</b>	<b>\$173</b>	<b>\$204</b>	<b>\$209</b>	<b>\$194</b>	<b>\$181</b>
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Projected Cost	Projected Cost	Projected Cost	Projected Cost	Actual Cost	Projected Cost	Projected Cost	Actual Cost
<b>ES System</b>								
ES Equipment	\$40,500,750	\$65,000,000	\$1,359,000	\$115,250,000	\$679,500	\$8,700,150	\$40,500,750	\$752,665
ES Installation	<b>\$2,025,038</b>	<b>\$3,250,000</b>	<b>\$67,950</b>	<b>\$5,762,500</b>	<b>\$33,975</b>	<b>\$435,008</b>	<b>\$2,025,038</b>	<b>\$37,633</b>
Enclosures	<b>\$2,139,360</b>	<b>\$2,864,040</b>	<b>\$36,214</b>	<b>\$1,912,600</b>	Included	<b>\$408,385</b>	<b>\$2,139,360</b>	Included
<b>Owner Interconnection</b>								
Equipment	<b>\$7,685,755</b>	<b>\$7,685,755</b>	Included	<b>\$18,893,500</b>	<b>\$367,000</b>	<b>\$2,288,500</b>	<b>\$9,981,500</b>	<b>\$233,500</b>
Installation	<b>\$1,247,500</b>	<b>\$1,247,500</b>	Included	<b>\$2,361,500</b>	<b>\$92,000</b>	<b>\$572,000</b>	<b>\$1,247,500</b>	<b>\$58,500</b>
Enclosures	Included	Included	Included	Included	Included	Included	Included	Included
<b>System Packing</b>	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
<b>System Shipping to US Port</b>	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
<b>Utility Interconnection</b>								
Equipment	<b>\$3,875,000</b>	<b>\$3,875,000</b>	Included	<b>\$6,875,000</b>	<b>\$80,400</b>	<b>\$695,000</b>	<b>\$3,875,000</b>	<b>\$70,400</b>
Installation	<b>\$3,875,000</b>	<b>\$3,875,000</b>	Included	<b>\$6,875,000</b>	<b>\$80,400</b>	<b>\$695,000</b>	<b>\$3,875,000</b>	<b>\$70,400</b>
<b>Site BOP Installation (Civil Only)</b>								
Total Cost Equipment	<b>\$1,041,180</b>	<b>\$1,327,270</b>	<b>\$13,507</b>	<b>\$1,149,050</b>	<b>\$6,754</b>	<b>\$199,911</b>	<b>\$1,041,180</b>	<b>\$72,500</b>
Total Cost Installation	<b>\$54,200,865</b>	<b>\$79,424,795</b>	<b>\$1,395,214</b>	<b>\$142,931,100</b>	<b>\$1,126,900</b>	<b>\$12,092,035</b>	<b>\$56,496,610</b>	<b>\$1,056,565</b>
General Contractor Facilities at 15% install	<b>\$8,188,718</b>	<b>\$9,699,770</b>	<b>\$81,457</b>	<b>\$16,148,050</b>	<b>\$213,129</b>	<b>\$1,901,919</b>	<b>\$8,188,718</b>	<b>\$239,033</b>
Engineering Fees @ 5% Install	<b>\$1,228,308</b>	<b>\$1,454,966</b>	\$0	<b>\$2,422,208</b>	<b>\$31,969</b>	<b>\$285,288</b>	<b>\$1,228,308</b>	<b>\$35,855</b>
Project Contingency Application @ 0-15% install	<b>\$409,436</b>	<b>\$484,989</b>	\$0	<b>\$807,403</b>	<b>\$10,656</b>	<b>\$95,096</b>	<b>\$409,436</b>	<b>\$11,952</b>
Process Contingency Application @ 0-15% of battery	<b>\$1,228,308</b>	<b>\$1,454,966</b>	\$0	<b>\$2,422,208</b>	<b>\$31,969</b>	<b>\$285,288</b>	<b>\$1,228,308</b>	<b>\$35,855</b>
Total Plant Cost (TPC)	<b>\$71,330,746</b>	<b>\$102,269,485</b>	<b>\$1,680,522</b>	<b>\$182,018,468</b>	<b>\$1,516,549</b>	<b>\$15,964,648</b>	<b>\$73,626,491</b>	<b>\$1,492,160</b>
<b>OPERATING EXPENSES</b>								
FIXED O&M - \$/kW-yr	\$3.6	\$3.6	\$0.0	\$4.3	\$9.2	\$5.7	\$4.5	\$11.7
Replacement Battery Costs - \$/kW	\$194	\$194	\$204	\$194	\$194	\$194	\$194	\$194
Battery replacement - yrs	8.0	8.0	5	8.0	8.0	8.0	8.0	8.0
Variable O&M - \$/kWh (Charging or Discharging)	0.0005	0.0003	0.0001	0.0003	0.0014	0.0011	0.0005	0.0005

## Appendix B: Storage System Cost Details

**B.4.7 Zinc-bromine Systems**

Data sheets for zinc- bromine system reference designs in several services and use cases are provided in Table B-18, Table B-19, and Table B-20.

**Table B-18. Zinc-bromine System Cost and Performance Data for Bulk, Frequency Regulation, and Utility T&D Grid Support Services**  
(Parameters noted in black are vendor inputs.)

Application	Bulk Storage	Bulk Storage	FR & RI	Utility T&D				
Technology Type	Zinc Bromine	Zinc Bromine	Zinc Bromide	Zinc Bromine	Zinc Bromine	Zinc Bromide	Zinc Bromide	Zinc Bromide
Supplier	S29	S29	S29	S45	S45	S29 - 1	S29 - 1	S29 - 2
Survey Year	2011	2011	2011	2011	2011	2011	2011	2011
<b>DESIGN BASIS - General</b>								
System Capacity - Net kW	50,000	100,000	1,000	1000	2000	1,000	10,000	10,000
Hours of Energy storage at rated Capacity - hrs	5.0	5.0	1.0	2	2	5.0	5.0	5.0
Depth of Discharge (DOD) per cycle - %	100%	100%	100%	100%	100%	100%	100%	100%
Energy Capacity - kWh @ rated DOD	250,000	500,000	1,000	2000	4000	5,000	50,000	50,000
Energy Capacity - kWh @ 100% DOD	250,000	500,000	1,000	2000	4000	5,000	50,000	50,000
Auxiliaries - kW	80	80	20	0.04	0.04	20	80	20
Unit Size - Net kW	2,000	2,000	1000	0.25	0.5	500	2,000	500
Number of Units - #	25	50	1	4	4	2	5	20
Physical Size - SF/Unit	2,800	2,800	477	50'L x 48'W	20'W x 30'L	477	2,800	477
System Foot Print - SF	70,000	140,000	1,917	2500	800	3,195	14,000	9,540
System Weight - lbs	448,000	448,000	112,000	140,000 lbs	N/A	112,000	448,000	112,000
Round Trip AC / AC Efficiency - %	60%	60%	60%	62%	65%	60%	60%	60%
Number of cycles / year	365	365	5,000	365	365	500	500	500
<b>GENERAL - Timing</b>								
Commercial Order Date	--	--	--			--	--	--
Plant Life, yrs	15	15	15	15	15	15	15	15
<b>TOTAL PLANT COST</b>								
\$/kW	\$1,674	\$1,641	\$1,464	\$2,957	\$1,699	\$2,053	\$1,823	\$1,805
\$/kWh @ rated DOD	\$335	\$328	\$1,464	\$1,479	\$849	\$411	\$365	\$361
\$/kWh @ 100% DOD	\$335	\$328	\$1,464	\$1,479	\$849	\$411	\$365	\$361
<b>PLANT CAPITAL COST</b>								
Power - \$/kW	\$484	\$451	\$754	\$797	\$619	\$575	\$633	\$615
Storage - \$/kWh @ rated DOD	\$238	\$238	\$710	\$1,080	\$540	\$296	\$238	\$238
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Actual Cost	Actual Cost	Actual Cost	\$	\$	Actual Cost	Actual Cost	Actual Cost
<b>ES System</b>								
ES Equipment	\$50,000,000	\$100,000,000	\$600,000	\$1,800,000	\$1,800,000	\$1,250,000	\$10,000,000	\$10,000,000
ES Installation	\$2,000,000	\$4,000,000	\$20,000	\$90,000	\$90,000	\$40,000	\$400,000	\$400,000
Enclosures	\$2,520,000	\$5,040,000	\$71,012	\$92,000	\$30,800	\$117,020	\$506,000	\$345,440
<b>Owner Interconnection</b>								
Equipment	\$9,981,500	\$18,893,500	\$367,000	\$367,000	\$523,000	\$240,000	\$2,288,500	\$2,288,500
Installation	\$1,247,500	\$2,361,500	\$92,000	\$92,000	\$131,000	\$10,000	\$572,000	\$572,000
Enclosures	Included	Included	Included	Included	Included	Included	Included	Included
<b>System Packing</b>								
System Shipping to US Port	\$0	\$0	\$0	0	0	\$0	\$0	\$0
<b>Utility Interconnection</b>								
Equipment	\$3,875,000	\$6,875,000	\$80,400	\$80,400	\$210,400	\$80,400	\$1,144,250	\$1,144,250
Installation	\$3,875,000	\$6,875,000	\$80,400	\$80,400	\$210,400	\$80,400	\$1,144,250	\$1,144,250
<b>Site BOP Installation (Civil Only)</b>								
Total Cost Equipment	\$140,000	\$280,000	\$3,834	\$5,000	\$1,600	\$6,390	\$28,000	\$19,080
Total Cost Installation	\$66,376,500	\$130,808,500	\$1,118,412	\$2,339,400	\$2,564,200	\$1,687,420	\$13,938,750	\$13,778,190
General Contractor Facilities at 15% install	\$1,089,375	\$2,027,475	\$29,435	\$40,110	\$64,950	\$20,519	\$321,638	\$320,300
Engineering Fees @ 5% Install	\$363,125	\$675,825	\$9,812	\$13,370	\$21,650	\$6,840	\$107,213	\$106,767
Project Contingency Application @ 0-15% install	\$1,089,375	\$2,027,475	\$19,623	\$26,740	\$43,300	\$13,679	\$214,425	\$213,533
Process Contingency Application @ 0-15% of battery	\$7,500,000	\$15,000,000	\$90,000	\$270,000	\$270,000	\$187,500	\$1,500,000	\$1,500,000
<b>Total Plant Cost (TPC)</b>	\$83,680,875	\$164,055,775	\$1,463,516	\$2,957,020	\$3,397,100	\$2,052,747	\$18,226,275	\$18,054,119
<b>OPERATING EXPENSES</b>								
FIXED O&M - \$/kW-yr	\$4.5	\$4.3	\$9.2	\$9.2	\$6.5	\$5.0	\$5.7	\$5.7
Replacement Battery Costs - \$/kW	\$0	\$0	\$0	\$540	\$270	\$0	\$0	\$0
Battery replacement - yrs	15	15	15	5	5	15	15	15
Variable O&M - \$/kWh (Charging or Discharging)	0.0005	0.0005	0.0004	0.0027	0.0027	0.0008	0.0008	0.0008

## Appendix B: Storage System Cost Details

**Table B-19. Zinc-bromine System Cost and Performance Data for Distributed Energy Storage and Commercial and Industrial Energy Management Services**  
*(Parameters noted in black are vendor inputs.)*

Application	Commercial & Industrial						
<b>Technology Type</b>	Zinc Bromine	Zinc Bromide	Zinc Bromine				
<b>Supplier</b>	S33	S33	S29	S29	S29	S29	S29
<b>Survey Year</b>	2011	2011	2011	2011	2011	2011	2011
<b>DESIGN BASIS - General</b>							
System Capacity - Net kW	120	333	37.5	50	125	500	1,000
Hours of Energy storage at rated Capacity - hrs	2	2	4	2	5	5.0	5.0
Depth of Discharge (DOD) per cycle - %	100%	100%	100%	100%	100%	100%	100%
Energy Capacity - kWh @ rated DOD	240	666	150	100	625	2,500	5,000
Energy Capacity - kWh @ 100% DOD	240	666	150	100	625	2,500	5,000
Auxiliaries - kW	no chiller req'd	no chiller req'd	4	2	5	20	20
Unit Size - Net kW	120	333	37.5	50	125	500	500
Number of Units - #	1	1	1	1	1	1	2
Physical Size - SF/Unit	160	160	95	97	160	477	477
System Foot Print - SF	160	160	275	255	988	1,917	3,195
System Weight - lbs	up to 33000	up to 33000	17,500	14,962	28000	112,000	112,000
Round Trip AC / AC Efficiency - %	63%	67%	60%	60%	60%	60%	60%
Number of cycles / year	365	365	365	365	365	365	365
<b>GENERAL - Timing</b>							
Commercial Order Date	Q4-2011	Q3-2012	--	--	--	--	--
Plant Life, yrs	15	15	15	15	15	15	15
<b>TOTAL PLANT COST</b>							
\$/kW	\$4,773	\$4,499	\$4,488	\$3,021	\$2,808	\$2,584	\$2,286
\$/kWh @ rated DOD	\$2,386	\$2,250	\$1,122	\$1,510	\$562	\$517	\$457
\$/kWh @ 100% DOD	\$2,386	\$2,250	\$1,122	\$1,510	\$562	\$517	\$457
<b>PLANT CAPITAL COST</b>							
Power - \$/kW	\$1,153	\$982	\$3,108	\$2,331	\$1,308	\$1,107	\$809
Storage - \$/kWh @ rated DOD	\$1,810	\$1,759	\$345	\$345	\$300	\$296	\$296
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Projected Cost	Projected Cost		Actual Cost	Actual Cost	Actual Cost	Actual Cost
<b>ES System</b>							
ES Equipment	\$360,000	\$999,000	\$45,000	\$30,000	\$156,250	\$625,000	\$1,250,000
ES Installation	\$18,000	\$19,980	\$2,250	\$1,500	\$7,813	\$20,000	\$40,000
Enclosures	Included	Included	\$20,032	\$20,032	\$37,568	\$71,012	\$117,020
<b>Owner Interconnection</b>							
Equipment	\$79,000	\$131,500	\$44,500	\$44,500	\$79,000	\$233,500	\$367,000
Installation	\$39,500	\$33,000	\$22,500	\$22,500	\$39,500	\$58,500	\$92,000
Enclosures	Included						
<b>System Packing</b>							
System Shipping to US Port	\$2,400	\$2,400	\$0	\$0	\$0	\$0	\$0
<b>Utility Interconnection</b>							
Equipment	\$250	\$62,900	\$250	\$250	\$250	\$70,400	\$80,400
Installation	\$250	\$62,900	\$250	\$250	\$250	\$70,400	\$80,400
<b>Site BOP Installation (Civil Only)</b>	included	included	\$29,000	\$29,000	\$1,976	\$3,834	\$6,390
<b>Total Cost Equipment</b>	\$443,650	\$1,197,800	\$109,782	\$94,782	\$273,068	\$999,912	\$1,814,420
<b>Total Cost Installation</b>	\$57,750	\$115,880	\$54,000	\$53,250	\$49,539	\$152,734	\$218,790
General Contractor Facilities at 15% install	\$8,663	\$17,382	\$0	\$0	\$0	\$22,910	\$32,819
Engineering Fees @ 5% Install	\$2,888	\$5,794	\$0	\$0	\$0	\$7,637	\$10,940
Project Contingency Application @ 0-15% install	\$5,775	\$11,588	\$0	\$0	\$4,954	\$15,273	\$21,879
Process Contingency Application @ 0-15% of battery	\$54,000	\$149,850	\$4,500	\$3,000	\$23,438	\$93,750	\$187,500
<b>Total Plant Cost (TPC)</b>	<b>\$572,725</b>	<b>\$1,498,294</b>	<b>\$168,282</b>	<b>\$151,032</b>	<b>\$350,998</b>	<b>\$1,292,216</b>	<b>\$2,286,347</b>
<b>OPERATING EXPENSES</b>							
FIXED O&M - \$/kW-yr	\$19.8	\$9.9	\$35.7	\$26.8	\$19.0	\$11.7	\$9.2
Replacement Battery Costs - \$/kW	\$900	\$900	\$0	\$0	\$0	\$0	\$0
Battery replacement - yrs	5	5	15	15	15	15	15
Variable O&M - \$/kWh (Charging or Discharging)	0.0027	0.0027	0.0014	0.0027	0.0011	0.0011	0.0011

## Appendix B: Storage System Cost Details

**Table B-20. Zinc-bromine Systems for Small Residential Applications**  
(Parameters noted in black are vendor inputs.)

Application	Residential	Residential	Residential	Residential	Residential
<b>Technology Type</b>	Zinc-Bromine	Zinc-Bromine	Zinc-Bromine	Zinc Bromine	Zinc Bromine
<b>Supplier</b>	<b>S33 - 1</b>	<b>S33 - 2</b>	<b>S33</b>	<b>S29</b>	<b>S29</b>
<b>Survey Year</b>	2011	2011	2011	2011	2011
<b>DESIGN BASIS - General</b>					
System Capacity - Net kW	5	5	5	5	15
Hours of Energy storage at rated Capacity - hrs	2	2	4	4	2
Depth of Discharge (DOD) per cycle - %	100%	100%	100%	100%	100%
Energy Capacity - kWh @ rated DOD	10	10	20	20	30
Energy Capacity - kWh @ 100% DOD	10	10	20	20	30
Auxiliaries - kW	no chiller req'd	no chiller req'd	no chiller req'd	0.2	0.6
Unit Size - Net kW	5	5	5	5	15
Number of Units - #	1	1	1	1	1
Physical Size - SF/Unit	2.5	3	14	12	12
System Foot Print - SF	2.5	3	14	90	90
System Weight - lbs	484 (220 kg)	730 (330 kg)	2090 (950 kg)	N/A	5,325
Round Trip AC / AC Efficiency - %	70%	68%	63%	60%	60%
Number of cycles / year	365	365	365	365	365
<b>GENERAL - Timing</b>					
Commercial Order Date	Today	Today	Today	--	--
Plant Life, yrs	15	15	15	15	15
<b>TOTAL PLANT COST</b>					
\$/kW	\$7,040	\$6,510	\$10,020	\$4,950	\$3,380
\$/kWh @ rated DOD	\$3,520	\$3,255	\$2,505	\$1,238	\$1,690
\$/kWh @ 100% DOD	\$3,520	\$3,255	\$2,505	\$1,238	\$1,690
<b>PLANT CAPITAL COST</b>					
Power - \$/kW	\$3,570	\$3,000	\$3,000	\$3,570	\$2,690
Storage - \$/kWh @ rated DOD	\$1,735	\$1,755	\$1,755	\$345	\$345
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Projected Cost	Actual Cost	Actual Cost	Actual Cost	Actual Cost
<b>ES System</b>					
ES Equipment	\$15,000	\$15,000	\$30,000	\$6,000	\$9,000
ES Installation	\$750	\$750	\$1,500	\$300	\$450
Enclosures	\$2,350	included	included	\$2,350	\$2,350
<b>Owner Interconnection</b>					
Equipment	\$9,500	\$9,500	\$9,500	\$9,500	\$24,500
Installation	\$5,000	\$5,000	\$5,000	\$5,000	\$12,500
Enclosures	included	included	included	Included	Included
<b>System Packing</b>	included	included	included	Included	Included
<b>System Shipping to US Port</b>	\$100	\$300	\$600	\$0	\$0
<b>Utility Interconnection</b>					
Equipment	\$250	\$250	\$250	\$250	\$250
Installation	\$250	\$250	\$250	\$250	\$250
<b>Site BOP Installation (Civil Only)</b>	\$500	included	included	\$500	\$500
<b>Total Cost Equipment</b>	\$27,200	\$25,050	\$40,350	\$18,100	\$36,100
<b>Total Cost Installation</b>	\$6,500	\$6,000	\$6,750	\$6,050	\$13,700
General Contractor Facilities at 15% install	\$0	\$0	\$0	\$0	\$0
Engineering Fees @ 5% Install	\$0	\$0	\$0	\$0	\$0
Project Contingency Application @ 0-15% install	\$0	\$0	\$0	\$0	\$0
Process Contingency Application @ 0-15% of battery	\$1,500	\$1,500	\$3,000	\$600	\$900
<b>Total Plant Cost (TPC)</b>	<b>\$35,200</b>	<b>\$32,550</b>	<b>\$50,100</b>	<b>\$24,750</b>	<b>\$50,700</b>
<b>OPERATING EXPENSES</b>					
FIXED O&M - \$/kW-yr	\$58.0	\$58.0	\$58.0	\$58.0	\$49.3
Replacement Battery Costs - \$/kW	\$900	\$900	\$1,800	\$0	\$0
Battery replacement - yrs	5	5	5	15	15
Variable O&M - \$/kWh (Charging or Discharging)	0.0027	0.0027	0.0014	0.0014	0.0027

## Appendix B: Storage System Cost Details

**B.4.8 Zinc-air Battery****Performance and Design Characteristics**

Projected performance, capital costs, and design characteristics are illustrated in the Table B-21.

*Note: These are features for systems that vendors may offer at some future time. As this technology is still in the very early stages of development, many of these features would require updating based on the RFI and RFP process detailed in this Handbook.*

**Table B-21. Cost and Performance Data for Zinc-air Batteries**  
(Parameters noted in black are vendor inputs.)

Application	Bulk Storage	Utility T&D	Commercial & Industrial
<b>Technology Type</b>	<b>Zn / Air</b>	<b>Zn/ Air</b>	<b>Zn/ Air</b>
<b>Supplier</b>	<b>S20</b>	<b>S20</b>	<b>S20</b>
<b>Survey Year</b>	<b>2011</b>	<b>2011</b>	<b>2011</b>
<b>DESIGN BASIS - General</b>			
System Capacity - Net kW	50,000	1,000	1,000
Hours of Energy storage at rated Capacity - hrs	6	6	6
Depth of Discharge (DOD) per cycle - %	100%	100%	100%
Energy Capacity - kWh @ rated DOD	300,000	6,000	6,000
Energy Capacity - kWh @ 100% DOD	300,000	6,000	6,000
Auxiliaries - kW			
Unit Size - Net kW	1 MW per unit	1 MW per unit	1 MW per unit
Number of Units - #	50	1	1
Physical Size - SF/Unit			
System Foot Print - SF	31,680	634	634
System Weight - lbs	80,000	80,000	80,000
Round Trip AC / AC Efficiency - %	80%	80%	80%
Number of cycles / year	365	365	365
<b>GENERAL - Timing</b>			
Commercial Order Date	Now	Now	Now
Plant Life, yrs	15	15	15
<b>TOTAL PLANT COST</b>			
\$/kW	<b>\$1,428</b>	<b>\$1,858</b>	<b>\$1,858</b>
\$/kWh @ rated DOD	<b>\$238</b>	<b>\$310</b>	<b>\$310</b>
\$/kWh @ 100% DOD	<b>\$238</b>	<b>\$310</b>	<b>\$310</b>
<b>PLANT CAPITAL COST</b>			
Power - \$/kW	<b>\$443</b>	<b>\$700</b>	<b>\$700</b>
Storage - \$/kWh @ rated DOD	<b>\$164</b>	<b>\$193</b>	<b>\$193</b>
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Projected Cost	Actual Cost	Actual Cost
<b>ES System</b>			
ES Equipment	\$42,500,000	\$1,000,000	\$1,000,000
ES Installation	\$375,000	\$7,500	\$7,500
Enclosures	<b>\$1,142,480</b>	<b>\$24,810</b>	<b>\$24,810</b>
<b>Owner Interconnection</b>			
Equipment	<b>\$9,981,500</b>	<b>\$367,000</b>	<b>\$367,000</b>
Installation	<b>\$1,247,500</b>	<b>\$92,000</b>	<b>\$92,000</b>
Enclosures	Included	Included	Included
<b>System Packing</b>	\$0	\$0	\$0
<b>System Shipping to US Port</b>	\$0	\$0	\$0
<b>Utility Interconnection</b>			
Equipment	<b>\$3,875,000</b>	<b>\$80,400</b>	<b>\$80,400</b>
Installation	<b>\$3,875,000</b>	<b>\$80,400</b>	<b>\$80,400</b>
<b>Site BOP Installation (Civil Only)</b>	<b>\$63,360</b>	<b>\$1,267</b>	<b>\$1,267</b>
<b>Total Cost Equipment</b>	<b>\$57,498,980</b>	<b>\$1,472,210</b>	<b>\$1,472,210</b>
<b>Total Cost Installation</b>	<b>\$5,560,860</b>	<b>\$181,167</b>	<b>\$181,167</b>
General Contractor Facilities at 15% install	<b>\$834,129</b>	<b>\$27,175</b>	<b>\$27,175</b>
Engineering Fees @ 5% Install	<b>\$278,043</b>	<b>\$9,058</b>	<b>\$9,058</b>
Project Contingency Application @ 0-15% install	<b>\$834,129</b>	<b>\$18,117</b>	<b>\$18,117</b>
Process Contingency Application @ 0-15% of battery	<b>\$6,375,000</b>	<b>\$150,000</b>	<b>\$150,000</b>
<b>Total Plant Cost (TPC)</b>	<b>\$71,381,141</b>	<b>\$1,857,727</b>	<b>\$1,857,727</b>
<b>OPERATING EXPENSES</b>			
FIXED O&M - \$/kW-yr	<b>\$4.5</b>	<b>\$9.2</b>	<b>\$9.2</b>
Replacement Battery Costs - \$/kW	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>
Battery replacement - yrs	<b>15</b>	<b>15</b>	<b>15</b>
Variable O&M - \$/kWh (Charging or Discharging)	<b>0.0005</b>	<b>0.0009</b>	<b>0.0009</b>

## Appendix B: Storage System Cost Details

**B.4.9 Lead-acid Battery**

Cost, performance, and technical design features of advanced lead acid energy storage systems are detailed in Table B-22 through Table B-26 by general service and use cases: Bulk Energy, Frequency Regulation/Renewable Integration, Utility T&D Grid Support, and smaller systems for Distributed Energy Storage, C&I Energy management, and Residential Energy management.

**Table B-22. Cost and Performance of Advanced Lead-acid Batteries in Bulk Storage Service**  
(Parameters noted in black are vendor inputs.)

Application	Bulk Storage	Bulk Storage	Bulk Storage	Bulk Storage	Bulk Storage	Bulk Storage	Bulk Storage
Technology Type	Adv. Lead Acid	Adv. Lead Acid	Adv. Lead Acid	Adv. Lead Acid	Adv. Lead Acid	Adv. Lead Acid	Adv. Lead Acid
<b>Supplier</b>	<b>S15</b>	<b>S15</b>	<b>S11</b>	<b>S11</b>	<b>S13</b>	<b>S44</b>	<b>S44</b>
<b>Survey Year</b>	2010	2010	2011	2011	2011	2010	2010
<b>DESIGN BASIS - General</b>							
System Capacity - Net kW	20,000	50,000	50,000	100,000	50,000	50,000	100,000
Hours of Energy storage at rated Capacity - hrs	6	5	5	4	5	4.8	4.8
Depth of Discharge (DOD) per cycle - %	33%	33%	60%	60%	80%	75%	75%
Energy Capacity - kWh @ rated DOD	120,000	250,000	250,000	400,000	250,000	240,000	480,000
Energy Capacity - kWh @ 100% DOD	363,636	757,576	416,667	666,667	312,500	320,000	640,000
Auxiliaries - kW			n/a	n/a			
Unit Size - Net kW	20,000	50,000	n/a	n/a		100	100
Number of Units - #	685	<b>1713</b>	Building Concept	Building Concept	Chino x 5		
Physical Size - SF/Unit			Not used	Not used			
System Foot Print - SF	<b>101169</b>	<b>252923</b>	95,000	110,000	<b>103200</b>	<b>120,000</b>	<b>240,000</b>
System Weight - lbs			n/a	n/a	5 x 627,800 lbs		
Round Trip AC / AC Efficiency - %	90%	90%	90%	90%	85%	85%	85%
Number of cycles / year	<b>365</b>	<b>365</b>	<b>365</b>	<b>365</b>	<b>365</b>	<b>365</b>	<b>365</b>
<b>GENERAL - Timing</b>							
Commercial Order Date			2012	2012		6 to 9 Months	
Plant Life, yrs	15	15	<b>15</b>	<b>15</b>	15	<b>15</b>	15
<b>TOTAL PLANT COST</b>							
\$/kW	<b>\$5,876</b>	<b>\$4,897</b>	<b>\$4,809</b>	<b>\$4,326</b>	<b>\$1,743</b>	<b>\$2,287</b>	<b>\$2,254</b>
\$/kWh @ rated DOD	<b>\$979</b>	<b>\$979</b>	<b>\$962</b>	<b>\$1,082</b>	<b>\$349</b>	<b>\$476</b>	<b>\$470</b>
\$/kWh @ 100% DOD	<b>\$323</b>	<b>\$323</b>	<b>\$577</b>	<b>\$649</b>	<b>\$279</b>	<b>\$357</b>	<b>\$352</b>
<b>PLANT CAPITAL COST</b>							
Power - \$/kW	<b>\$796</b>	<b>\$663</b>	<b>\$634</b>	<b>\$546</b>	<b>\$507</b>	<b>\$527</b>	<b>\$494</b>
Storage - \$/kWh @ rated DOD	<b>\$847</b>	<b>\$847</b>	<b>\$835</b>	<b>\$945</b>	<b>\$247</b>	<b>\$367</b>	<b>\$367</b>
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Actual Cost	Actual Cost	Projected Cost	Projected Cost	Projected Cost	Projected Cost	Projected Cost
<b>ES System</b>							
ES Equipment	<b>\$92,363,636</b>	<b>\$192,424,242</b>	<b>\$175,000,000</b>	<b>\$320,000,000</b>	<b>\$56,200,000</b>	<b>\$80,000,000</b>	<b>\$160,000,000</b>
ES Installation	<b>\$4,618,182</b>	<b>\$9,621,212</b>	<b>\$25,000,000</b>	<b>\$42,000,000</b>	<b>\$2,810,000</b>	<b>\$4,000,000</b>	<b>\$8,000,000</b>
Enclosures	<b>\$3,644,084</b>	<b>\$9,107,228</b>	<b>\$3,422,000</b>	<b>\$3,962,000</b>	<b>\$3,717,200</b>	<b>\$4,322,000</b>	<b>\$8,642,000</b>
<b>Owner Interconnection</b>							
Equipment	<b>\$5,154,500</b>	<b>\$9,981,500</b>	<b>\$9,981,500</b>	<b>\$18,893,500</b>	<b>\$9,981,500</b>	<b>\$9,981,500</b>	<b>\$18,893,500</b>
Installation	<b>\$644,500</b>	<b>\$1,247,500</b>	<b>\$1,247,500</b>	<b>\$2,361,500</b>	<b>\$1,247,500</b>	<b>\$1,247,500</b>	<b>\$2,361,500</b>
Enclosures	included	included	Included	Included	Included	Included	included
<b>System Packing</b>	\$0	\$0	\$0	\$0	\$0	included	included
<b>System Shipping to US Port</b>	\$0	\$0	\$0	\$0	\$0	\$0	\$0
<b>Utility Interconnection</b>							
Equipment	<b>\$2,012,500</b>	<b>\$3,875,000</b>	<b>\$3,875,000</b>	<b>\$6,875,000</b>	<b>\$3,875,000</b>	<b>\$3,875,000</b>	<b>\$6,875,000</b>
Installation	<b>\$2,012,500</b>	<b>\$3,875,000</b>	<b>\$3,875,000</b>	<b>\$6,875,000</b>	<b>\$3,875,000</b>	<b>\$3,875,000</b>	<b>\$6,875,000</b>
<b>Site BOP Installation (Civil Only)</b>	<b>\$202,338</b>	<b>\$505,846</b>	<b>\$190,000</b>	<b>\$220,000</b>	<b>\$206,400</b>	<b>\$240,000</b>	<b>\$480,000</b>
<b>Total Cost Equipment</b>	<b>\$103,174,720</b>	<b>\$215,387,970</b>	<b>\$192,278,500</b>	<b>\$349,730,500</b>	<b>\$73,773,700</b>	<b>\$98,178,500</b>	<b>\$194,410,500</b>
<b>Total Cost Installation</b>	<b>\$7,477,520</b>	<b>\$15,249,558</b>	<b>\$30,312,500</b>	<b>\$51,456,500</b>	<b>\$8,138,900</b>	<b>\$9,362,500</b>	<b>\$17,716,500</b>
General Contractor Facilities at 15% install	<b>\$1,121,628</b>	<b>\$2,287,434</b>	<b>\$4,546,875</b>	<b>\$7,718,475</b>	<b>\$1,220,835</b>	<b>\$1,404,375</b>	<b>\$2,657,475</b>
Engineering Fees @ 5% Install	<b>\$373,876</b>	<b>\$762,478</b>	<b>\$1,515,625</b>	<b>\$2,572,825</b>	<b>\$406,945</b>	<b>\$468,125</b>	<b>\$885,825</b>
Project Contingency Application @ 0-15% install	<b>\$747,752</b>	<b>\$1,524,956</b>	<b>\$3,031,250</b>	<b>\$5,145,650</b>	<b>\$813,890</b>	<b>\$936,250</b>	<b>\$1,771,650</b>
Process Contingency Application @ 0-15% of battery	<b>\$4,618,182</b>	<b>\$9,621,212</b>	<b>\$8,750,000</b>	<b>\$16,000,000</b>	<b>\$2,810,000</b>	<b>\$4,000,000</b>	<b>\$8,000,000</b>
<b>Total Plant Cost (TPC)</b>	<b>\$117,513,678</b>	<b>\$244,833,608</b>	<b>\$240,434,750</b>	<b>\$432,623,950</b>	<b>\$87,164,270</b>	<b>\$114,349,750</b>	<b>\$225,441,950</b>
<b>OPERATING EXPENSES</b>							
FIXED O&M - \$/kW-yr	<b>\$5.8</b>	<b>\$4.5</b>	<b>\$4.5</b>	<b>\$4.3</b>	<b>\$4.5</b>	<b>\$4.5</b>	<b>\$4.3</b>
Replacement Battery Costs - \$/kW	<b>\$1,385</b>	<b>\$1,155</b>	<b>\$1,050</b>	<b>\$960</b>	<b>\$337</b>	<b>\$480</b>	<b>\$480</b>
Battery replacement - yrs	8	8	8	8	8	8	8
Variable O&M - \$/kWh (Charging or Discharging)	0.0005	0.0005	0.0005	0.0007	0.0005	0.0006	0.0006

## Appendix B: Storage System Cost Details

**Table B-23. Cost and Performance of Advanced Lead-acid Batteries for Frequency Regulation**  
*(Parameters noted in black are vendor inputs.)*

Application	FR & RI	FR & RI	FR & RI	FR & RI	FR & RI
Technology Type	Adv. Lead Acid	Adv. Lead Acid	Adv. Lead Acid	Adv. Lead Acid	Adv. Lead Acid
<b>Supplier</b>	<b>S15</b>	<b>S15</b>	<b>S11</b>	<b>S11</b>	<b>S11</b>
<b>Survey Year</b>	2010	2010	2011	2011	2011
<b>DESIGN BASIS - General</b>					
System Capacity - Net kW	1,000	1,000	1,000	12,000	100,000
Hours of Energy storage at rated Capacity - hrs	0.25	1	0.5	0.4	0.4
Depth of Discharge (DOD) per cycle - %	33%	33%	85%	25%	25%
Energy Capacity - kWh @ rated DOD	250	1,000	500	4,800	40,000
Energy Capacity - kWh @ 100% DOD	758	3,030	588	19,200	160,000
Auxiliaries - kW			n/a	n/a	n/a
Unit Size - Net kW			n/a	n/a	n/a
Number of Units - #	1	11	Container	Container or	Building Concept
Physical Size - SF/Unit		60X71	160 sf each x 3 =	Not used	Not used
System Foot Print - SF	387	4260	3 x 20ft	3,500	30,000
System Weight - lbs			1 container at	If Containers, 4	n/a
Round Trip AC / AC Efficiency - %	90%	90%	90%	90%	90%
Number of cycles / year	5000	5000	5000	5000	15000
<b>GENERAL - Timing</b>					
Commercial Order Date			Q4/2010	Q4/2010	Q4/2010
Plant Life, yrs	15	15	15	15	15
<b>TOTAL PLANT COST</b>					
\$/kW	\$1,176	\$2,477	\$1,695	\$1,692	\$1,663
\$/kWh @ rated DOD	\$4,705	\$2,477	\$3,391	\$4,230	\$4,157
\$/kWh @ 100% DOD	\$1,553	\$817	\$2,882	\$1,058	\$1,039
<b>PLANT CAPITAL COST</b>					
Power - \$/kW	\$685	\$847	\$751	\$442	\$449
Storage - \$/kWh @ rated DOD	\$1,963	\$1,629	\$1,888	\$3,125	\$3,033
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Actual Cost	Actual Cost	Actual Cost	Actual Cost	Actual Cost
<b>ES System</b>					
ES Equipment	\$446,212	\$1,481,040	\$880,000	\$12,000,000	\$96,500,000
ES Installation	\$22,311	\$74,052	\$20,000	\$2,400,000	\$20,000,000
Enclosures	\$15,932	\$155,360	\$79,680	\$128,000	\$1,082,000
<b>Owner Interconnection</b>					
Equipment	\$367,000	\$367,000	\$367,000	\$2,288,500	\$18,893,500
Installation	\$92,000	\$92,000	\$92,000	\$572,000	\$2,361,500
Enclosures	included	included	included	included	Included
<b>System Packing</b>	\$0	\$0	\$0	\$0	\$0
<b>System Shipping to US Port</b>	\$0	\$0	\$0	\$0	\$0
<b>Utility Interconnection</b>					
Equipment	\$80,400	\$80,400	\$57,900	\$695,000	\$6,875,000
Installation	\$80,400	\$80,400	\$57,900	\$695,000	\$6,875,000
<b>Site BOP Installation (Civil Only)</b>	\$774	\$8,520	\$43,500	\$7,000	\$60,000
<b>Total Cost Equipment</b>	\$909,544	\$2,083,800	\$1,384,580	\$15,111,500	\$123,350,500
<b>Total Cost Installation</b>	\$195,485	\$254,972	\$213,400	\$3,674,000	\$29,296,500
General Contractor Facilities at 15% install	\$29,323	\$38,246	\$32,010	\$551,100	\$4,394,475
Engineering Fees @ 5% Install	\$9,774	\$12,749	\$10,670	\$183,700	\$1,464,825
Project Contingency Application @ 0-15% install	\$9,774	\$12,749	\$10,670	\$183,700	\$2,929,650
Process Contingency Application @ 0-15% of battery	\$22,311	\$74,052	\$44,000	\$600,000	\$4,825,000
<b>Total Plant Cost (TPC)</b>	\$1,176,210	\$2,476,567	\$1,695,330	\$20,304,000	\$166,260,950
<b>OPERATING EXPENSES</b>					
FIXED O&M - \$/kW-yr	\$9.2	\$9.2	\$9.2	\$4.8	\$4.3
Replacement Battery Costs - \$/kW	\$134	\$444	\$264	\$300	\$290
Battery replacement - yrs	8	8	8	8	8
Variable O&M - \$/kWh (Charging or Discharging)	0.0016	0.0004	0.0008	0.0005	0.0002

## Appendix B: Storage System Cost Details

**Table B-24. Cost and Performance of Advanced Lead-acid Batteries in Utility T&D**  
(Parameters noted in black are vendor inputs.)

Application	Utility T&D	Utility T&D	Utility T&D						
<b>Technology Type</b>	Adv. Lead Acid	Adv. Lead Acid	Adv. Lead Acid						
<b>Supplier</b>	S15	S15	S15	S15	S44	S11	S11	S11	S11
<b>Survey Year</b>	2010	2010	2010	2010	2010	2011	2011	2011	2011
<b>DESIGN BASIS - General</b>									
System Capacity - Net kW	1,000	1,000	1000	1000	20,000	1,000	1,000	12,000	100,000
Hours of Energy storage at rated Capacity - hrs	1	4	8	10	6	3.2	4	4	4
Depth of Discharge (DOD) per cycle - %	33%	33%	50%	80%	33%	75%	60%	60%	60%
Energy Capacity - kWh @ rated DOD	1,000	4,000	8,000	10,000	120,000	3,200	4,000	48,000	400,000
Energy Capacity - kWh @ 100% DOD	3,030	12,121	16,000	12,500	363,636	4,267	6,667	80,000	666,667
Auxiliaries - kW								n/a	n/a
Unit Size - Net kW		1,000			20,000	1	n/a	n/a	n/a
Number of Units - #	11	26	29	29	685	3	Container	Building Concept	Building Concept
Physical Size - SF/Unit	60X71	60X128	60X141	60X141		1600	160 sf each x 15	Not used	Not used
System Foot Print - SF	4260	7680	8460	8460	101169	1,600	15 x 20ft	13,000	110,000
System Weight - lbs		2220				60000	1 container at	n/a	n/a
Round Trip AC / AC Efficiency - %	90%	90%	90%	90%	90%	87%	90%	90%	90%
Number of cycles / year	365	365	365	365	365	365	365	365	365
<b>GENERAL - Timing</b>									
Commercial Order Date						6 to 9 Months	Q4/2010	Q4/2010	Q4/2010
Plant Life, yrs	15	15	15	15	15	15	15	15	15
<b>TOTAL PLANT COST</b>									
\$/kW	\$2,477	\$4,855	\$5,334	\$5,023	\$5,876	\$2,730	\$5,166	\$4,360	\$3,990
\$/kWh @ rated DOD	\$2,477	\$1,214	\$667	\$502	\$979	\$853	\$1,291	\$1,090	\$998
\$/kWh @ 100% DOD	\$817	\$401	\$333	\$402	\$323	\$640	\$775	\$654	\$599
<b>PLANT CAPITAL COST</b>									
Power - \$/kW	\$847	\$1,004	\$1,039	\$1,036	\$796	\$749	\$1,344	\$527	\$546
Storage - \$/kWh @ rated DOD	\$1,629	\$963	\$537	\$399	\$847	\$619	\$956	\$958	\$861
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Actual Cost	Projected Cost	Projected Cost	Projected Cost	Projected Cost				
<b>ES System</b>									
ES Equipment	\$1,481,040	\$3,500,640	\$3,904,560	\$3,625,000	\$92,363,636	\$1,792,000	\$3,600,000	\$39,000,000	\$288,000,000
ES Installation	\$74,052	\$175,032	\$195,228	\$181,250	\$4,618,182	\$89,600	\$42,000	\$5,040,000	\$42,000,000
Enclosures	\$155,360	\$278,480	\$306,560	\$306,560	\$3,644,084	\$59,600	\$398,400	\$470,000	\$3,962,000
<b>Owner Interconnection</b>									
Equipment	\$367,000	\$367,000	\$367,000	\$367,000	\$5,154,500	\$367,000	\$367,000	\$2,288,500	\$18,893,500
Installation	\$92,000	\$92,000	\$92,000	\$92,000	\$644,500	\$92,000	\$92,000	\$572,000	\$2,361,500
Enclosures	included	included	included						
<b>System Packing</b>	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
<b>System Shipping to US Port</b>	\$0	\$0	\$0	\$0	\$0	\$10,000	\$0	\$0	\$0
<b>Utility Interconnection</b>									
Equipment	\$80,400	\$80,400	\$80,400	\$80,400	\$2,012,500	\$80,400	\$80,400	\$695,000	\$6,875,000
Installation	\$80,400	\$80,400	\$80,400	\$80,400	\$2,012,500	\$80,400	\$80,400	\$695,000	\$6,875,000
<b>Site BOP Installation (Civil Only)</b>	\$8,520	\$15,360	\$16,920	\$16,920	\$202,338	\$3,200	\$217,500	\$26,000	\$220,000
<b>Total Cost Equipment</b>	\$2,083,800	\$4,226,520	\$4,658,520	\$4,378,960	\$103,174,720	\$2,309,000	\$4,445,800	\$42,453,500	\$317,730,500
<b>Total Cost Installation</b>	\$254,972	\$362,792	\$384,548	\$370,570	\$7,477,520	\$265,200	\$431,900	\$6,333,000	\$51,456,500
General Contractor Facilities at 15% install	\$38,246	\$54,419	\$57,682	\$55,586	\$1,121,628	\$39,780	\$64,785	\$949,950	\$7,718,475
Engineering Fees @ 5% Install	\$12,749	\$18,140	\$19,227	\$18,529	\$373,876	\$13,260	\$21,595	\$316,650	\$2,572,825
Project Contingency Application @ 0-15% install	\$12,749	\$18,140	\$19,227	\$18,529	\$747,752	\$13,260	\$21,595	\$316,650	\$5,145,650
Process Contingency Application @ 0-15% of battery	\$74,052	\$175,032	\$195,228	\$181,250	\$4,618,182	\$89,600	\$180,000	\$1,950,000	\$14,400,000
<b>Total Plant Cost (TPC)</b>	\$2,476,567	\$4,855,042	\$5,334,433	\$5,023,423	\$117,513,678	\$2,730,100	\$5,165,675	\$52,319,750	\$399,023,950
<b>OPERATING EXPENSES</b>									
FIXED O&M - \$/kW-yr	\$9.2	\$9.2	\$9.2	\$9.2	\$5.8	\$9.2	\$9.2	\$4.8	\$4.3
Replacement Battery Costs - \$/kW	\$444	\$1,050	\$1,171	\$1,088	\$1,385	\$538	\$1,080	\$975	\$864
Battery replacement - yrs	8	8	8	8	8	8	8	8	8
Variable O&M - \$/kWh (Charging or Discharging)	0.0055	0.0014	0.0007	0.0005	0.0005	0.0017	0.0014	0.0007	0.0007

## Appendix B: Storage System Cost Details

**Table B-25. Cost and Performance Data of Advanced Lead-acid Batteries**  
*(Parameters noted in black are vendor inputs.)*

Application	DESS	DESS	DESS	DESS	DESS	DESS
<b>Technology Type</b>	<b>Advanced Lead Acid</b>	<b>Advanced Lead Acid</b>	<b>Advanced Lead Acid</b>	<b>Advanced VRLA</b>	<b>Advanced VRLA</b>	<b>VRLA</b>
<b>Supplier</b>	<b>S15</b>	<b>S15</b>	<b>S15</b>	<b>S21 - 1</b>	<b>S21 - 2</b>	<b>S21 - 3</b>
<b>Survey Year</b>	2010	2010	2010	2011	2011	2011
<b>DESIGN BASIS - General</b>						
System Capacity - Net kW	50	50	50	25	25	25
Hours of Energy storage at rated Capacity - hrs	2	4	5	2	2	2
Depth of Discharge (DOD) per cycle - %	80%	50%	80%	70%	70%	70%
Energy Capacity - kWh @ rated DOD	100	200	250	50	50	50
Energy Capacity - kWh @ 100% DOD	125	400	313	65	71	65
Auxiliaries - kW						
Unit Size - Net kW						
Number of Units - #				234 Units of	48 Units of battery	34 Units of battery
Physical Size - SF/Unit				84(H) x 25(W) x	56(H) x 46(W) x	84(H) x 25(W) x
System Foot Print - SF	20' container	20' container	20' container	2.45	7.6	3.65
System Weight - lbs				1,470lbs/stand	4,100 lbs/stand	2,147 lbs/ stand
Round Trip AC / AC Efficiency - %	90%	90%	90%	85%	85%	85%
Number of cycles / year	365	365	365	365	365	365
<b>GENERAL - Timing</b>						
Commercial Order Date						
Plant Life, yrs	15	15	15	15	15	15
<b>TOTAL PLANT COST</b>						
\$/kW	\$2,499	\$4,505	\$2,782	\$5,526	\$3,789	\$2,609
\$/kWh @ rated DOD	\$1,249	\$1,126	\$556	\$2,763	\$1,894	\$1,304
\$/kWh @ 100% DOD	\$1,000	\$563	\$445	\$2,125	\$1,326	\$1,003
<b>PLANT CAPITAL COST</b>						
Power - \$/kW	\$1,407	\$1,407	\$1,407	\$1,994	\$1,994	\$1,994
Storage - \$/kWh @ rated DOD	\$546	\$774	\$275	\$1,766	\$897	\$307
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Actual Cost	Actual Cost	Actual Cost	Actual Cost	Actual Cost	Actual Cost
<b>ES System</b>						
ES Equipment	\$49,625	\$140,800	\$62,500	\$80,275	\$40,786	\$13,975
ES Installation	\$2,481	\$7,040	\$3,125	\$4,014	\$2,039	\$699
Enclosures	\$2,350	\$2,350	\$2,350	\$2,350	\$2,350	\$2,350
<b>Owner Interconnection</b>						
Equipment	\$44,500	\$44,500	\$44,500	\$31,000	\$31,000	\$31,000
Installation	\$22,500	\$22,500	\$22,500	\$15,500	\$15,500	\$15,500
Enclosures	included	included	included	Included	Included	Included
<b>System Packing</b>	\$0	\$0	\$0	\$0	\$0	\$0
<b>System Shipping to US Port</b>	\$0	\$0	\$0	\$0	\$0	\$0
<b>Utility Interconnection</b>						
Equipment	\$250	\$250	\$250	\$250	\$250	\$250
Installation	\$250	\$250	\$250	\$250	\$250	\$250
<b>Site BOP Installation (Civil Only)</b>						
Total Cost Equipment	\$500	\$500	\$500	\$500	\$500	\$500
Total Cost Installation	\$96,725	\$187,900	\$109,600	\$113,875	\$74,386	\$47,575
General Contractor Facilities at 15% install	\$0	\$0	\$0	\$0	\$0	\$0
Engineering Fees @ 5% Install	\$0	\$0	\$0	\$0	\$0	\$0
Project Contingency Application @ 0-15% install	\$0	\$0	\$0	\$0	\$0	\$0
Process Contingency Application @ 0-15% of battery	\$2,481	\$7,040	\$3,125	\$4,014	\$2,039	\$699
<b>Total Plant Cost (TPC)</b>	\$124,938	\$225,230	\$139,100	\$138,153	\$94,714	\$65,223
<b>OPERATING EXPENSES</b>						
FIXED O&M - \$/kW-yr	\$26.8	\$26.8	\$26.8	\$37.2	\$37.2	\$37.2
Replacement Battery Costs - \$/kW	\$298	\$845	\$375	\$2,902	\$1,468	\$480
Battery replacement - yrs	8	8	8	8	8	3
Variable O&M - \$/kWh (Charging or Discharging)	0.0027	0.0014	0.0011	0.0027	0.0027	0.0027

## Appendix B: Storage System Cost Details

**Table B-26. Cost and Performance of Advanced Lead-acid Batteries for Commercial and Industrial Applications**  
*(Parameters noted in black are vendor inputs.)*

Application	Commercial & Industrial Advanced Lead Acid	Residential Advanced Lead Acid	Residential Advanced Lead Acid					
Technology Type	\$15	\$15	\$15	\$15	\$15	\$11	\$15	\$15
Supplier								
Survey Year	2010	2010	2010	2010	2010	2011	2010	2010
<b>DESIGN BASIS - General</b>								
System Capacity - Net kW	50	50	50	1000	1000	200	5	5
Hours of Energy storage at rated Capacity - hrs	2	4	5	8	10	4	2	4
Depth of Discharge (DOD) per cycle - %	80%	50%	80%	33%	80%	60%	33%	50%
Energy Capacity - kWh @ rated DOD	100	200	250	8,000	10,000	800	10	20
Energy Capacity - kWh @ 100% DOD	125	400	313	24,242	12,500	1,333	30	40
Auxiliaries - kW								
Unit Size - Net kW						200		
Number of Units - #				44	29		1	1
Physical Size - SF/Unit				110X197	60X141			
System Foot Print - SF	pad mtd cabinet	20' container	20' container	21670	8460	154		
System Weight - lbs						152,000		
Round Trip AC / AC Efficiency - %	90%	90%	90%	90%	90%	75%	90%	90%
Number of cycles / year	365	365	365	365	365	365	365	365
<b>GENERAL - Timing</b>								
Commercial Order Date						Q4/2010		
Plant Life, yrs	15	15	15	15	15	15	15	15
<b>TOTAL PLANT COST</b>								
\$/kW	\$2,499	\$4,505	\$2,782	\$8,090	\$5,023	\$5,995	\$6,323	\$6,509
\$/kWh @ rated DOD	\$1,249	\$1,126	\$556	\$1,011	\$502	\$1,499	\$3,162	\$1,627
\$/kWh @ 100% DOD	\$1,000	\$563	\$445	\$334	\$402	\$899	\$1,043	\$814
<b>PLANT CAPITAL COST</b>								
Power - \$/kW	\$1,407	\$1,407	\$1,407	\$1,573	\$1,036	\$1,795	\$3,570	\$3,570
Storage - \$/kWh @ rated DOD	\$546	\$774	\$275	\$815	\$399	\$1,050	\$1,377	\$735
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Actual Cost	Actual Cost	Actual Cost					
<b>ES System</b>								
ES Equipment	\$49,625	\$140,800	\$62,500	\$5,924,160	\$3,625,000	\$800,000	\$12,515	\$13,360
ES Installation	\$2,481	\$7,040	\$3,125	\$296,208	\$181,250	included	\$626	\$668
Enclosures	\$2,350	\$2,350	\$2,350	\$782,120	\$306,560	\$26,560	\$2,350	\$2,350
<b>Owner Interconnection</b>								
Equipment	\$44,500	\$44,500	\$44,500	\$367,000	\$367,000	\$131,500	\$9,500	\$9,500
Installation	\$22,500	\$22,500	\$22,500	\$92,000	\$92,000	\$33,000	\$5,000	\$5,000
Enclosures	included	included	included	included	included	included	Included	Included
<b>System Packing</b>	\$0	\$0	\$0	\$0	\$0	included	Included	Included
System Shipping to US Port	\$0	\$0	\$0	\$0	\$0	included	\$0	\$0
<b>Utility Interconnection</b>								
Equipment	\$250	\$250	\$250	\$80,400	\$80,400	\$62,900	\$250	\$250
Installation	\$250	\$250	\$250	\$80,400	\$80,400	\$62,900	\$250	\$250
<b>Site BOP Installation (Civil Only)</b>								
Total Cost Equipment	\$500	\$500	\$500	\$43,340	\$16,920	\$14,500	\$500	\$500
Total Cost Installation	\$96,725	\$187,900	\$109,600	\$7,153,680	\$4,378,960	\$1,020,960	\$24,615	\$25,460
General Contractor Facilities at 15% install	\$0	\$0	\$0	\$76,792	\$55,586	\$16,560	\$0	\$0
Engineering Fees @ 5% Instal	\$0	\$0	\$0	\$25,597	\$18,529	\$5,520	\$0	\$0
Project Contingency Application @ 0-15% install	\$0	\$0	\$0	\$25,597	\$18,529	\$5,520	\$0	\$0
Process Contingency Application @ 0-15% of battery	\$2,481	\$7,040	\$3,125	\$296,208	\$181,250	\$40,000	\$626	\$668
<b>Total Plant Cost (TPC)</b>	\$124,938	\$225,230	\$139,100	\$8,089,823	\$5,023,423	\$1,198,960	\$31,617	\$32,546
<b>OPERATING EXPENSES</b>								
FIXED O&M - \$/kW-yr	\$26.8	\$26.8	\$26.8	\$9.2	\$9.2	\$16.5	\$58.0	\$58.0
Replacement Battery Costs - \$/kW	\$298	\$845	\$375	\$1,777	\$1,088	\$1,200	\$751	\$802
Battery replacement - yrs	8	8	8	8	8	8	8	8
Variable O&M - \$/kWh (Charging or Discharging)	0.0027	0.0014	0.0011	0.0007	0.0005	0.0014	0.0027	0.0014

**B.4.10 Flywheel**

Table B-27 provides performance and design characteristics for a 20-MW flywheel system designed for providing grid frequency regulation services.

**Table B-27. Cost and Performance of Flywheel Systems**  
(Parameters noted in black are vendor inputs.)

Application	FR & RI
<b>Technology Type</b>	<b>Flywheel</b>
<b>Supplier</b>	<b>S5</b>
<b>Survey Year</b>	<b>2010</b>
<b>DESIGN BASIS - General</b>	
System Capacity - Net kW	20000
Hours of Energy storage at rated Capacity - hrs	0.25
Depth of Discharge (DOD) per cycle - %	100%
Energy Capacity - kWh @ rated DOD	5,000
Energy Capacity - kWh @ 100% DOD	5,000
Auxiliaries - kW	capacity net of auxiliaries
Unit Size - Net kW	1
Number of Units - #	20
Physical Size - SF/Unit	20X 1 MW (= 200 flywheels)
System Foot Print - SF	20X 1 MW (= 200 flywheels)
System Weight - lbs	
Round Trip AC / AC Efficiency - %	85%
Number of cycles / year	15,000
<b>GENERAL - Timing</b>	
Commercial Order Date	Now
Plant Life, yrs	15
<b>TOTAL PLANT COST</b>	
\$/kW	\$2,159
\$/kWh @ rated DOD	\$8,638
\$/kWh @ 100% DOD	\$8,638
<b>PLANT CAPITAL COST</b>	
Power - \$/kW	\$867
Storage - \$/kWh @ rated DOD	\$5,168
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Actual Cost
<b>ES System</b>	
ES Equipment	\$19,360,000
ES Installation	\$6,480,000
Enclosures	included
<b>Owner Interconnection</b>	
Equipment	\$5,154,500
Installation	\$644,500
Enclosures	included
<b>System Packing</b>	\$0
<b>System Shipping to US Port</b>	\$0
<b>Utility Interconnection</b>	
Equipment	\$2,012,500
Installation	\$2,012,500
<b>Site BOP Installation (Civil Only)</b>	\$3,680,000
<b>Total Cost Equipment</b>	\$26,527,000
<b>Total Cost Installation</b>	\$12,817,000
General Contractor Facilities at 15% install	\$1,922,550
Engineering Fees @ 5% Install	\$640,850
Project Contingency Application @ 0-15% install	\$1,281,700
Process Contingency Application @ 0-15% of battery	\$0
<b>Total Plant Cost (TPC)</b>	\$43,189,100
<b>OPERATING EXPENSES</b>	
FIXED O&M - \$/kW-yr	\$5.8
Replacement Battery Costs - \$/kW	\$290
Battery replacement - yrs	5
Variable O&M - \$/kWh (Charging or Discharging)	0.0003

## Appendix B: Storage System Cost Details

**B.4.11    Lithium Ion Family of Batteries**

Performance, design, and cost data sheets for several Li-ion systems are presented in the tables below, by noted service or use case area. Table B-28 is for Lithium Ion (Li-ion) systems for frequency regulation and renewable integration applications from various suppliers noted by S.

**Table B-28. Cost and Performance of Li-on Family of Battery Systems for Frequency Regulation and Renewables**  
(Parameters noted in black are vendor inputs.)

Application	FR & RI	FR & RI	FR & RI	FR & RI	FR & RI	FR & RI	FR & RI	Wind Integration
<b>Technology Type</b>	Li-ion	Li-ion	Large format Li-ion	Large format Li-ion	Large format Li-ion	Li-ion	Li-ion	Li-ion
<b>Supplier</b>	S25	S19 - 1	S22	S22	S37	S1	S1	S7
<b>Survey Year</b>	2010	2010	2010	2010	2010	2011	2011	2011
<b>DESIGN BASIS - General</b>								
System Capacity - Net kW	2,000	1000	1,000	1,000	1,100	3,000	2000	1000
Hours of Energy storage at rated Capacity - hrs	0.25	0.25	1.2	1.35	0.5	1	0.25	1
Depth of Discharge (DOD) per cycle - %	60%	80%	85%	85%	80%	100%	100%	100%
Energy Capacity - kWh @ rated DOD	500	250	1,200	1,350	550	3,000	500	1000
Energy Capacity - kWh @ 100% DOD	833	313	1,412	1,588	688	3,000	500	1000
Auxiliaries - kW					6	12	25	
Unit Size - Net kW		1000				3,000	2000	200
Number of Units - #	1- 53' trailer/	1			1 or more	1	1	5
Physical Size - SF/Unit		1	20' x 9'6" x 7'8"	20' x 9'6" x 7'8"	160	53' X 9' X 9'	53' X 9' X 9'	
System Foot Print - SF			8X20 ft container		N/A	477	477	1,386
System Weight - lbs		50000	8775	8775	24000	160,000	60,000	
Round Trip AC / AC Efficiency - %	90%	80%	90%	90%	92%	90%	89%	90%
Number of cycles / year	5000	5000	365	365	365	4000	15000	365
<b>GENERAL - Timing</b>								
Commercial Order Date					Oct-10			2011. Jan
Plant Life, yrs	15	15	15	15	15	15	15	15
<b>TOTAL PLANT COST</b>								
\$/kW	\$1,010	\$1,017	\$2,551	\$2,144	\$1,475	\$1,388	\$1,098	\$1,634
\$/kWh @ rated DOD	\$4,040	\$4,068	\$2,126	\$1,588	\$2,949	\$1,388	\$4,394	\$1,634
\$/kWh @ 100% DOD	\$2,424	\$3,254	\$1,807	\$1,350	\$2,359	\$1,388	\$4,394	\$1,634
<b>PLANT CAPITAL COST</b>								
Power - \$/kW	\$603	\$779	\$711	\$707	\$637	\$514	\$589	\$728
Storage - \$/kWh @ rated DOD	\$1,629	\$950	\$1,533	\$1,065	\$1,674	\$874	\$2,037	\$906
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Actual Cost	Actual Cost	Projected Cost	Projected Cost	Projected Cost	Projected Cost	Actual Cost	Projected Cost
<b>ES System</b>								
ES Equipment	\$708,333	\$175,000	\$1,600,000	\$1,250,000	\$800,800	2,383,000	926,000	\$780,000
ES Installation	\$35,417	Included	\$80,000	\$62,500	\$40,040	included	included	\$39,000
Enclosures	Included	Included	\$10,016	\$10,016	\$10,016	included	included	\$51,910
<b>Owner Interconnection</b>								
Equipment	\$523,000	\$367,000	\$367,000	\$367,000	\$367,000	\$749,500	\$523,000	\$367,000
Installation	\$131,000	\$92,000	\$92,000	\$92,000	\$92,000	\$187,500	\$131,000	\$92,000
Enclosures	Included	Included	included	included	included	included	included	included
<b>System Packing</b>	\$0	\$28,125	\$0	\$0	\$0	\$0	\$0	\$0
<b>System Shipping to US Port</b>	\$0	\$45,000	\$0	\$0	\$0	\$0	\$0	\$8,644
<b>Utility Interconnection</b>								
Equipment	\$210,400	\$80,400	\$80,400	\$80,400	\$80,400	\$240,400	\$210,400	\$80,400
Installation	\$210,400	\$80,400	\$80,400	\$80,400	\$80,400	\$240,400	\$210,400	\$80,400
<b>Site BOP Installation (Civil Only)</b>	\$29,000	\$70,750	\$14,500	\$14,500	\$14,500	\$14,500	\$14,500	\$2,773
<b>Total Cost Equipment</b>	\$1,441,733	\$695,525	\$2,057,416	\$1,707,416	\$1,258,216	\$3,372,900	\$1,659,400	\$1,287,954
<b>Total Cost Installation</b>	\$405,817	\$243,150	\$266,900	\$249,400	\$226,940	\$442,400	\$355,900	\$214,173
General Contractor Facilities at 15% install	\$60,873	\$36,473	\$40,035	\$37,410	\$34,041	\$66,360	\$53,385	\$32,126
Engineering Fees @ 5% Instal	\$20,291	\$12,158	\$13,345	\$12,470	\$11,347	\$22,120	\$17,795	\$10,709
Project Contingency Application @ 0-15% install	\$20,291	\$12,158	\$13,345	\$12,470	\$11,347	\$22,120	\$17,795	\$10,709
Process Contingency Application @ 0-15% of battery	\$70,833	\$17,500	\$160,000	\$125,000	\$80,080	\$238,300	\$92,600	\$78,000
<b>Total Plant Cost (TPC)</b>	\$2,019,838	\$1,016,963	\$2,551,041	\$2,144,166	\$1,621,971	\$4,164,200	\$2,196,875	\$1,633,670
<b>OPERATING EXPENSES</b>								
FIXED O&M - \$/kW-yr	\$6.5	\$9.2	\$9.2	\$9.2	\$8.3	\$6.2	\$6.5	\$9.2
Replacement Battery Costs - \$/kW	\$177	\$88	\$800	\$625	\$364	\$0	\$0	\$390
Battery replacement - yrs	5	5	5	5	5	15	15	5
Variable O&M - \$/kWh (Charging or Discharging)	0.0016	0.0016	0.0046	0.0041	0.0110	0.0005	0.0005	0.0055

## Appendix B: Storage System Cost Details

**Table B-29. Li-ion Battery Systems for Utility T&D Grid Support**  
*(Parameters noted in black are vendor inputs.)*

Application	Utility T&D	Utility T&D	Utility T&D	Utility T&D	Utility T&D	Utility T&D	Utility T&D	Utility T&D
Technology Type	Adv. Li-ion	Adv. Li-ion	Li-ion	Large format Li-ion	Large format Li-ion	Li-ion	Li-ion	Li-ion
Supplier	\$6	\$6	\$25	\$22	\$22	\$1	\$7	\$7
Survey Year	2010	2010	2010	2010	2010	2011	2011	2011
<b>DESIGN BASIS - General</b>								
System Capacity - Net kW	1,000	10,000	10,000	1,000	1,000	3,000	1000	3000
Hours of Energy storage at rated Capacity - hrs	5	2	3	1.2	1.35	1	4	4
Depth of Discharge (DOD) per cycle - %	85%	85%	80%	85%	85%	100%	100%	100%
Energy Capacity - kWh @ rated DOD	5,000	20,000	30,000	1,200	1,350	3,000	4000	12000
Energy Capacity - kWh @ 100% DOD	5,682	23,529	37,500	1,412	1,588	3,000	4000	12000
Auxiliaries - kW						12		
Unit Size - Net kW	1,000	10,000				3,000	100	500
Number of Units - #	125	500	Battery 5X53'			1	10	6
Physical Size - SF/Unit	500	288000		20' x 9'6" x 7'8"	20' x 9'6" x 7'8"	53' X 9' X 9'		
System Foot Print - SF	1100	4400				477	2,773	10,398
System Weight - lbs	654,368	654,368		8775	8775	160,000		
Round Trip AC / AC Efficiency - %	90%	90%	94%	90%	90%	90%	90%	90%
Number of cycles / year	365	365	365	365	365	365	365	365
<b>GENERAL - Timing</b>								
Commercial Order Date							Demo In BYD	2010.12
Plant Life, yrs	15	15	15	15	15	15	15	15
<b>TOTAL PLANT COST</b>								
\$/kW	\$4,981	\$2,183	\$5,265	\$2,551	\$2,144	\$1,388	\$4,420	\$4,291
\$/kWh @ rated DOD	\$996	\$1,092	\$1,755	\$2,126	\$1,588	\$1,388	\$1,105	\$1,073
\$/kWh @ 100% DOD	\$847	\$928	\$1,404	\$1,807	\$1,350	\$1,388	\$1,105	\$1,073
<b>PLANT CAPITAL COST</b>								
Power - \$/kW	\$753	\$492	\$521	\$711	\$707	\$514	\$811	\$681
Storage - \$/kWh @ rated DOD	\$846	\$846	\$1,581	\$1,533	\$1,065	\$874	\$902	\$902
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Projected Cost	Projected Cost	Projected Cost	Projected Cost	Projected Cost	Projected Cost	Projected Cost	Projected Cost
<b>ES System</b>								
ES Equipment	\$3,676,471	\$14,705,882	\$41,250,000	\$1,600,000	\$1,250,000	2,383,000	\$3,120,000	\$9,360,000
ES Installation	\$183,824	\$735,294	\$2,062,500	\$80,000	\$62,500	included	\$156,000	\$468,000
Enclosures	\$41,600	\$160,400	Included	\$10,016	\$10,016	included	\$101,820	\$376,326
<b>Owner Interconnection</b>								
Equipment	\$367,000	\$2,288,500	\$2,288,500	\$367,000	\$367,000	\$749,500	\$367,000	\$749,500
Installation	\$92,000	\$572,000	\$572,000	\$92,000	\$92,000	\$187,500	\$92,000	\$187,500
Enclosures	Included	Included	Included	included	included	included	included	included
<b>System Packing</b>								
System Shipping to US Port	\$0	\$0	\$0	\$0	\$0	\$0	\$21,610	\$64,830
<b>Utility Interconnection</b>								
Equipment	\$80,400	\$695,000	\$695,000	\$80,400	\$80,400	\$240,400	\$80,400	\$240,400
Installation	\$80,400	\$695,000	\$695,000	\$80,400	\$80,400	\$240,400	\$80,400	\$240,400
<b>Site BOP Installation (Civil Only)</b>								
Site BOP Installation (Civil Only)	\$2,200	\$8,800	\$100,000	\$14,500	\$14,500	\$14,500	\$5,546	\$20,796
<b>Total Cost Equipment</b>	\$4,165,471	\$17,849,782	\$44,233,500	\$2,057,416	\$1,707,416	\$3,372,900	\$3,690,830	\$10,791,056
<b>Total Cost Installation</b>	\$358,424	\$2,011,094	\$3,429,500	\$266,900	\$249,400	\$442,400	\$333,946	\$916,696
General Contractor Facilities at 15% install	\$53,764	\$301,664	\$514,425	\$40,035	\$37,410	\$66,360	\$50,092	\$137,504
Engineering Fees @ 5% Install	\$17,921	\$100,555	\$171,475	\$13,345	\$12,470	\$22,120	\$16,697	\$45,835
Project Contingency Application @ 0-15% install	\$17,921	\$100,555	\$171,475	\$13,345	\$12,470	\$22,120	\$16,697	\$45,835
Process Contingency Application @ 0-15% of battery	\$367,647	\$1,470,588	\$4,125,000	\$160,000	\$125,000	\$238,300	\$312,000	\$936,000
<b>Total Plant Cost (TPC)</b>	\$4,981,147	\$21,834,238	\$52,645,375	\$2,551,041	\$2,144,166	\$4,164,200	\$4,420,262	\$12,872,926
<b>OPERATING EXPENSES</b>								
FIXED O&M - \$/kW-yr	\$9.2	\$5.7	\$5.7	\$9.2	\$9.2	\$6.2	\$9.2	\$6.2
Replacement Battery Costs - \$/kW	\$1,838	\$735	\$2,063	\$800	\$625	\$0	\$1,560	\$1,560
Battery replacement - yrs	5	5	5	5	5	15	5	5
Variable O&M - \$/kWh (Charging or Discharging)	0.0011	0.0027	0.0018	0.0046	0.0041	0.0055	0.0014	0.0014

## Appendix B: Storage System Cost Details

**Table B-30. Li-ion Battery Systems for Distributed Energy Storage**  
*(Parameters noted in black are vendor inputs.)*

Application	DESS	DESS	DESS	DESS	DESS	DESS	DESS	DESS
<b>Technology Type</b>	Adv. Li-ion	Adv. Li-ion	Li-ion	Li-ion	Large format Li-ion	Large format Li-ion	Large format Li-ion	Large format Li-ion
<b>Supplier</b>	<b>S6</b>	<b>S6</b>	<b>S25</b>	<b>S19 - 1</b>	<b>S22</b>	<b>S22</b>	<b>S22</b>	<b>S22</b>
<b>Survey Year</b>	2010	2010	2010	2010	2010	2010	2010	2010
<b>DESIGN BASIS - General</b>								
System Capacity - Net kW	25	50	50	50	25	25	25	25
Hours of Energy storage at rated Capacity - hrs	2	4	2	3	1.1	3	1.2	3.2
Depth of Discharge (DOD) per cycle - %	85%	85%	80%	80%	85%	85%	85%	85%
Energy Capacity - kWh @ rated DOD	50	200	100	150	28	75	30	80
Energy Capacity - kWh @ 100% DOD	59	235	125	188	32	88	35	94
Auxiliaries - kW								
Unit Size - Net kW	25	50		50				
Number of Units - #	1	6	Pad mounted	1				
Physical Size - SF/Unit	15	24		1	43" x 25" x 23"	27" x 61" x "26	43" x 25" x 23"	27" x 61" x "26
System Foot Print - SF	15	26.4		4X4				
System Weight - lbs	880.88	654.368		5,000				
Round Trip AC / AC Efficiency - %	89%	89%	93%	80%	85%	85%	90%	90%
Number of cycles / year	365	365	365	365	365	365	365	365
<b>GENERAL - Timing</b>								
Commercial Order Date								
Plant Life, yrs	15	15	15	15	15	15	15	15
<b>TOTAL PLANT COST</b>								
\$/kW	\$3,685	\$4,789	\$4,570	\$3,523	\$4,064	\$6,594	\$4,064	\$5,904
\$/kWh @ rated DOD	\$1,843	\$1,197	\$2,285	\$1,174	\$3,695	\$2,198	\$3,387	\$1,845
\$/kWh @ 100% DOD	\$1,566	\$1,018	\$1,828	\$939	\$3,140	\$1,868	\$2,879	\$1,568
<b>PLANT CAPITAL COST</b>								
Power - \$/kW	\$1,994	\$1,407	\$1,407	\$1,896	\$1,994	\$1,994	\$1,994	\$1,994
Storage - \$/kWh @ rated DOD	\$846	\$846	\$1,581	\$542	\$1,882	\$1,533	\$1,725	\$1,222
<b>SYSTEM COSTS - Equipment &amp; Install</b>	Actual Cost	Actual Cost	Actual Cost	Actual Cost	Actual Cost	Actual Cost	Actual Cost	Actual Cost
<b>ES System</b>								
ES Equipment	\$36,765	\$147,059	\$137,500	\$57,750	\$45,000	\$100,000	\$45,000	\$85,000
ES Installation	\$1,838	\$7,353	\$6,875	Included	\$2,250	\$5,000	\$2,250	\$4,250
Enclosures	\$2,350	\$2,350	\$2,350	Included	\$2,350	\$2,350	\$2,350	\$2,350
<b>Owner Interconnection</b>								
Equipment	\$31,000	\$44,500	\$44,500	\$44,500	\$31,000	\$31,000	\$31,000	\$31,000
Installation	\$15,500	\$22,500	\$22,500	\$22,500	\$15,500	\$15,500	\$15,500	\$15,500
Enclosures	Included	Included	Included	Included	Included	Included	Included	Included
<b>System Packing</b>	\$0	\$0	\$0	\$0	\$9,000	\$0	\$0	\$0
<b>System Shipping to US Port</b>	\$0	\$0	\$0	\$17,813	\$0	\$0	\$0	\$0
<b>Utility Interconnection</b>								
Equipment	\$250	\$250	\$250	\$250	\$250	\$250	\$250	\$250
Installation	\$250	\$250	\$250	\$250	\$250	\$250	\$250	\$250
<b>Site BOP Installation (Civil Only)</b>	\$500	\$500	\$500	\$18,313	\$500	\$500	\$500	\$500
<b>Total Cost Equipment</b>	\$70,365	\$194,159	\$184,600	\$129,313	\$78,600	\$133,600	\$78,600	\$118,600
<b>Total Cost Installation</b>	\$18,088	\$30,603	\$30,125	\$41,063	\$18,500	\$21,250	\$18,500	\$20,500
General Contractor Facilities at 15% install	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Engineering Fees @ 5% Install	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Project Contingency Application @ 0-15% install	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Process Contingency Application @ 0-15% of battery	\$3,676	\$14,706	\$13,750	\$5,775	\$4,500	\$10,000	\$4,500	\$8,500
<b>Total Plant Cost (TPC)</b>	\$92,129	\$239,468	\$228,475	\$176,150	\$101,600	\$164,850	\$101,600	\$147,600
<b>OPERATING EXPENSES</b>								
FIXED O&M - \$/kW-yr	\$37.2	\$26.8	\$26.8	\$26.8	\$37.2	\$37.2	\$37.2	\$37.2
Replacement Battery Costs - \$/kW	\$735	\$1,471	\$1,375	\$578	\$900	\$2,000	\$900	\$1,700
Battery replacement - yrs	8	8	8	8	8	8	8	8
Variable O&M - \$/kWh (Charging or Discharging)	0.0027	0.0014	0.0027	0.0018	0.0050	0.0018	0.0046	0.0017

**Table B-31. Li-ion Battery Systems for Commercial and Residential Applications**  
*(Parameters noted in black are vendor inputs.)*

Application	Commercial & Industrial						
Technology Type	Adv. Li-ion	Li-ion	Li-ion	Li-ion	Li-ion	Li-ion	Li-ion
Supplier	\$6	\$25	\$19 - 1	\$7	\$7	\$7	\$7
Survey Year	2010	2010	2010	2011	2011	2011	2011
<b>DESIGN BASIS - General</b>							
System Capacity - Net kW	50	50	50	100	200	250	500
Hours of Energy storage at rated Capacity - hrs	4	2	3	4	4	4	2
Depth of Discharge (DOD) per cycle - %	85%	80%	80%	100%	100%	100%	100%
Energy Capacity - kWh @ rated DOD	200	100	150	400	800	1,000	1,000
Energy Capacity - kWh @ 100% DOD	235	125	188	400	800	1,000	1,000
Auxiliaries - kW							
Unit Size - Net kW	50		50	100	200 kW	250	500
Number of Units - #	6	Pad mounted	1	1	1	1	1
Physical Size - SF/Unit	24		1				
System Foot Print - SF	26.4		4X4	336	693	693	693
System Weight - lbs	654,368		5,000		44,000		
Round Trip AC / AC Efficiency - %	89%	93%	80%	90%	90%	90%	90%
Number of cycles / year	365	365	365	365	365	365	365
<b>GENERAL - Timing</b>							
Commercial Order Date				2010.12			
Plant Life, yrs	15	15	15	15	15	15	15
<b>TOTAL PLANT COST</b>							
\$/kW	\$4,789	\$4,570	\$3,523	\$5,804	\$5,924	\$5,464	\$3,034
\$/kWh @ rated DOD	\$1,197	\$2,285	\$1,174	\$1,451	\$1,481	\$1,366	\$1,517
\$/kWh @ 100% DOD	\$1,018	\$1,828	\$939	\$1,451	\$1,481	\$1,366	\$1,517
<b>PLANT CAPITAL COST</b>							
Power - \$/kW	\$1,407	\$1,407	\$1,896	\$2,173	\$2,314	\$1,859	\$1,231
Storage - \$/kWh @ rated DOD	\$846	\$1,581	\$542	\$908	\$902	\$901	\$901
<b>SYSTEM COSTS - Equipment &amp; Install</b>							
	Actual Cost	Actual Cost	Actual Cost	Projected Cost	Actual Cost	\$/kWh	\$/kWh
<b>ES System</b>							
ES Equipment	\$147,059	\$137,500	\$57,750	\$312,000	\$624,000	\$780,000	\$780,000
ES Installation	\$7,353	\$6,875	Included	\$15,600	\$31,200	\$39,000	\$39,000
Enclosures	\$2,350	\$2,350	Included	\$30,048	\$50,080	\$50,080	\$50,080
<b>Owner Interconnection</b>							
Equipment	\$44,500	\$44,500	\$44,500	\$79,000	\$131,500	\$131,500	\$233,500
Installation	\$22,500	\$22,500	\$22,500	\$39,500	\$33,000	\$33,000	\$58,500
Enclosures	Included						
<b>System Packing</b>							
<b>System Shipping to US Port</b>	\$0	\$0	\$9,000	\$0	\$0	\$0	\$0
<b>Utility Interconnection</b>							
Equipment	\$250	\$250	\$250	\$250	\$62,900	\$62,900	\$70,400
Installation	\$250	\$250	\$250	\$250	\$62,900	\$62,900	\$70,400
<b>Site BOP Installation (Civil Only)</b>							
Equipment	\$500	\$500	\$18,313	\$43,500	\$72,500	\$72,500	\$72,500
Total Cost Equipment	\$194,159	\$184,600	\$129,313	\$425,620	\$872,802	\$1,028,802	\$1,138,302
Total Cost Installation	\$30,603	\$30,125	\$41,063	\$98,850	\$199,600	\$207,400	\$240,400
General Contractor Facilities at 15% install	\$0	\$0	\$0	\$14,828	\$29,940	\$31,110	\$36,060
Engineering Fees @ 5% Install	\$0	\$0	\$0	\$4,943	\$9,980	\$10,370	\$12,020
Project Contingency Application @ 0-15% install	\$0	\$0	\$0	\$4,943	\$9,980	\$10,370	\$12,020
Process Contingency Application @ 0-15% of battery	\$14,706	\$13,750	\$5,775	\$31,200	\$62,400	\$78,000	\$78,000
<b>Total Plant Cost (TPC)</b>	\$239,468	\$228,475	\$176,150	\$580,383	\$1,184,702	\$1,366,052	\$1,516,802
<b>OPERATING EXPENSES</b>							
FIXED O&M - \$/kW-yr	\$26.8	\$26.8	\$26.8	\$23.7	\$16.5	\$13.2	\$11.7
Replacement Battery Costs - \$/kW	\$1,471	\$1,375	\$578	\$1,560	\$1,560	\$1,560	\$780
Battery replacement - yrs	8	8	8	5	5	5	5
Variable O&M - \$/kWh (Charging or Discharging)	0.0014	0.0027	0.0018	0.0014	0.0014	0.0014	0.0027

## APPENDIX C: SAMPLE PROCUREMENT DOCUMENTS

### Appendix C: Table of Contents

<a href="#"><u>C.1 Sample RFI</u></a> .....	C-3
<a href="#"><u>C.2 Sample RFP</u></a> .....	C-10
<a href="#"><u>C.3 Technical Specification Example</u></a> .....	C-22
<a href="#"><u>C.4 Sample Data Requirements Document Outline</u></a> .....	C-23
<a href="#"><u>C.5 Sample Data Acquisition System Specification</u></a> .....	C-25

### Appendix C: List of Figures and List of Tables

(none)

## **SAMPLE PROCUREMENT DOCUMENTS**

The following RFI was used in the recent procurement of a storage system at a KIUC substation to provide three services to the grid: mitigate the intermittency of a nearby 3-MW PV plant, regulate distribution bus voltage, and provide frequency support during an outage. KIUC chose to illustrate the expected duty cycle of the battery in response to the grid requirements. The KIUC RFI also provided a one-line diagram of the substation, its schematic layout, and an aerial photograph of the intended location. All these pieces of information collectively facilitate the understanding of the intended use of the storage system by prospective vendors. The subsequent RFP for this storage system acquisition by KIUC is also shown to illustrate the kind of information included in an RFP.

The sample RFI and RFP are used with written permission from KIUC.

## C.1 Sample RFI

### KIUC RFI for Demonstration of an Energy Storage System on an Islanded System Version 2.01 – August 26, 2010

#### **Overview**

The Island of Kauai is the fourth largest inhabited Hawaiian Island. It is roughly circular, and approximately 555 square miles in size and 26 miles across at its widest points. Kauai's de-facto population is 65,000 with the majority of its economy based on tourism and agriculture-related businesses. Currently, Kauai Island Utility Cooperative (KIUC) is the only franchised provider of electric service to its consumers on the Island of Kauai. KIUC is a standalone vertically integrated electric utility and as such, provides all of the facilities, equipment and personnel required to meet the power generation, transmission, and retail distribution needs of its consumers. KIUC's all time peak load is 78 MW's, serving approximately 35,000 meters over 13 substations by means of three active generating sites.

KIUC has determined that it could achieve substantial benefits by deploying a battery energy storage system (BESS) on its system. Such benefits would include the potential to firm up intermittent renewable resources and mitigate other undesirable effects of integrating such resources into KIUC's relatively small system. In order to test the BESS concept, a demonstration project is being pursued on a small-scale basis.


#### **Project Conceptual Description**

KIUC has selected Koloa Substation to demonstrate a BESS, which will be used to mitigate intermittent fluctuations of a 3 MW PV array, regulate the distribution bus voltage, serve as spinning reserve, and provide frequency support during the loss of generation. The 3 MW PV system is located approximately 1 mile from Koloa Substation and will tie in over a dedicated 12.47 kV distribution circuit. The proposed BESS and PV system will interconnect at a dedicated 12.47kV breaker in the substation yard. Koloa Substation has an approximate annual peak demand of 9.4 MW and feeds the South Shore loads over 4 independent 12.47 kV distribution feeders.

#### **Requirements**


1. Defined purpose of the storage system
  - a. Regulate output of PV system **(Below is a visual representation only – MW and Duration values are not valid)**

## Appendix C: Sample Procurement Documents



- b. Provide voltage support for 12.47 kV distribution bus
- c. Contingency reserve for use during generation shortage. 1/week
- d. Charging Sources
  - i. PV charging
  - ii. KIUC generation
- e. Charging Schedule
  - i. Minimum state of charge specified by vendor
  - ii. Manually triggered state of charge by KIUC system operator within vendor specified limits
- f. Provide frequency support during loss of generation or system disturbance. 1/week

**(Below is a visual representation only – MW and Duration values are not valid)**




Appendix C: Sample Procurement Documents


- g. Size estimate of system: Minimum 1000 kW, 700-1000 kWh
- h. Discharge durations required: Full power, 15-30 minutes, 1/week
- i. Estimated number of shallow discharges: 70% power, up to 2 minutes, 50/day

2. Usable Space and Location
  - a. Koloa One-line conceptual (see attached drawing)
  - b. Aerial view (see attached photo)
  - c. Approximate dimensions (see attached drawing)
3. BESS Physical Requirements
  - a. 55-100 degrees F
  - b. Earthquake zone Class 1
4. Control System Requirements
  - a. Integrate with existing Areva SCADA/AGC and Harris D-20 substation RTU
  - b. HMI in substation control house to show status and alarms of BESS
  - c. Dispatched by KIUC
5. Environmental and Hazardous Materials
  - a. RFI response will identify any special environmental handling or containment needs, including hazardous material and fire protection requirements for operation and maintenance of the BESS. KIUC will obtain all necessary permits and approvals for the BESS.
6. End-of-Life Decommissioning and Disposal
  - a. RFI responses must include a discussion of how the storage system will be decommissioned at its end-of-life and its eventual recycling and/or disposal.
7. Duration of desired warranty
  - a. 8 years
8. Vendor to discuss maintenance and support options
9. Vendor to discuss alternative finance and ownership structures if available
10. Vendor to estimate electrical and physical size of the BESS and provide non-binding cost estimate
11. Vendor to discuss Manufacturing/Production capabilities and estimated lead times for delivery

## Schedule

- Intent to Respond: By September 1, 2010 vendor must indicate their interest and establish themselves by emailing [jpcox@kiuc.coop](mailto:jpcox@kiuc.coop). The e-mail subject line should read, “(company name) intends to respond for BESS RFI”.
- KIUC will hold conference call 2 weeks after RFI issued to respond to questions.
- Formal Responses due 3 weeks after conference call.
- Proprietary Information: Careful consideration should be given before confidential information is submitted to KIUC. The bidder should determine whether the information is critical for evaluating a proposal, or whether general, non-confidential information, may be adequate for review purposes. KIUC will honor, to the extent permissible by the State of Hawaii, County of Kauai, and Federal law, any information that the bidder submits that is identified and labeled as “Confidential” or “Proprietary”. This information should include a written request to exempt it from disclosure including a written statement of the reasons why the information should be exempted
- This RFI does not commit KIUC to award a contract, pay any costs incurred in preparing a proposal, to procure or contract for services. KIUC reserves the right to accept or reject any or all proposals, to negotiate with all qualified sources, or to cancel in part or in its entirety this RFI. KIUC also reserves the right to waive or modify minor irregularities in proposals received and to eliminate mandatory requirements.







## C.2 Sample RFP

### REQUEST FOR PROPOSAL (RFP)

<b>Project</b>				<b>Date RFP Issued</b>
KIUC Energy Storage			10/18/2010	
<b>Email Address Supplier to Submit Proposal</b> jpcox@kiuc.coop			<b>Date Proposal Due</b> 11/8/2010	
<b>Sole Point-of-Contact at KIUC</b> John Cox	<b>Phone Number</b> 808-246-8205	<b>Fax Number</b>	<b>Email</b>	

#### 1. Introduction

KIUC is requesting that certain contractors (“Contractors”) submit a Proposal (“Proposal”) to perform the Services as set forth and described herein pursuant to the terms and conditions of this Request for Proposal. This Request for Proposal (“RFP”) is neither a contract nor an offer. Contractors shall not receive any rights whatsoever from submitting a Proposal.

If a Contractor *does not have an existing agreement* with KIUC which covers performance of the Services, the Contractor should review KIUC’s standard agreement. Any Proposal submitted by such Contractor shall represent a firm offer to contract for performance of the Services on the terms and conditions described in said standard agreement unless Contractor includes its explicit objections to such terms and conditions within the Proposal. However, if a Contractor *has an existing agreement* with KIUC which covers performance of the Services, the terms and conditions of such existing agreement shall govern the Services. If required by such existing agreement, the Contractor shall execute an Individual Task Authorization (“ITA”) for the Services.

By submitting a Proposal, Contractor is (i) making a firm offer to perform the Services as set forth and described herein pursuant to the terms and conditions of this Request for Proposal, (ii) agreeing that the Proposal shall be valid for 90 calendar days unless Contractor explicitly states otherwise in the Proposal, (iii) agreeing that KIUC may, in its sole discretion, accept or reject, in whole or in part, any Proposal, (iv) agreeing that KIUC has sole discretion in selecting a Contractor for the Services and (v) agreeing that KIUC may, in its sole discretion, discontinue negotiations at any time prior to execution of an agreement or ITA which covers the Services.

Specifically in regards to this RFP, Contractor shall (i) bear all costs and expenses that it incurs, (ii) limit all communication to the “Sole Point-of-Contact” identified above and (iii) submit all questions to the Sole Point-of-Contact’s email address identified above. Additionally, Contractor shall not (i) rely on any oral representation or oral modification made by the Sole Point-of-Contact or (ii) rely on any representation made by someone other than the Sole Point-of-Contact.

KIUC may reject any Proposal not received by the “Date Proposal Due” identified above. KIUC will make a reasonable effort to respond to all questions within two business days of receipt. KIUC will share with other Contractors any question and subsequent response which KIUC determines, in its sole discretion, to be important to a Contractor’s ability appropriately respond to this RFP.

#### 2. General

The Island of Kauai is the fourth largest inhabited Hawaiian Island. It is roughly circular, and approximately 555 square miles in size and 26 miles across at its widest points. Kauai’s de-facto population is 65,000 with the majority

## Appendix C: Sample Procurement Documents

of its economy based on tourism and agriculture-related businesses. Currently, Kauai Island Utility Cooperative (KIUC) is the only franchised provider of electric service to its consumers on the Island of Kauai. KIUC is a standalone vertically integrated electric utility and as such, provides all of the facilities, equipment and personnel required to meet the power generation, transmission, and retail distribution needs of its consumers. KIUC's all time peak load is 78 MW's, serving approximately 35,000 meters over 13 substations by means of three active generating sites.

KIUC has determined that it could achieve substantial benefits by deploying a battery energy storage system (BESS) on its system. Such benefits would include the potential to firm up intermittent renewable resources and mitigate other undesirable effects of integrating such resources into KIUC's relatively small system. In order to test the BESS concept, a demonstration project is being pursued on a small-scale basis.

### 3. Project Description

KIUC has selected Koloa Substation to demonstrate a BESS, which will be used to mitigate intermittent fluctuations of a 3 MW PV array, regulate the distribution bus voltage, serve as spinning reserve, and provide frequency support during the loss of generation. The 3 MW PV system is located approximately 1 mile from Koloa Substation and will tie in over a dedicated 12.47 kV distribution circuit. The proposed BESS and PV system will interconnect at a dedicated position in the substation yard. Koloa Substation has an approximate annual peak demand of 9.4 MW and feeds the South Shore loads over 4 independent 12.47 kV distribution feeders.

### 4. Proposal Process and Schedule

KIUC intends to select a Contractor for the turnkey BESS project and negotiate a final scope of work with the selected Contractor. Proposals will be solicited from potential BESS Contractors based on these technical specifications and documents.

KIUC will select a short list of no more than two Contractors from these proposals. Meetings will be scheduled between KIUC and the Contractor's proposed technical project personnel to discuss the details of the Contractor's proposal and to clarify the intent of the specifications. Clarifications to the specification may be required based on these meetings. Following these meetings, the short listed Contractors will submit a revised proposal. From these revised proposals, KIUC will select a preferred Contractor and enter into negotiations for a final scope of work.

The anticipated schedule for the BESS project is as follows:

Specifications Issued for Bids	October 18, 2010
Bids Due	November 8, 2010
Shortlist Selection and Onsite Meetings	November 15 – December 15, 2010
Selection of Contractor and Negotiation of Final Scope	January 10, 2011
BESS on-line	June 15, 2011
Final Acceptance	July 1, 2011

### 5. Scope of Work

The scope of supply for the BESS shall include the following principal elements. The Contractor shall be responsible for identifying and providing any and all other additional equipment, components, and services necessary to install a fully functional BESS.

- Design, fabricate, ship, assemble, test, startup, commission, warrant and make ready for service a fully functional turnkey BESS that meets or exceeds all requirements delineated herein up to the BESS step-up transformer, and auxiliary AC station service
- Design, install and make ready for the electrical connection from the BESS to the step-up transformer. **KIUC will provide the 480V/12.47kV step up transformer. Contractor is responsible for 480V connections, conduit, cable, and protection, back to BESS.**
- Design, install and make ready for the communication connection from the BESS to the Harris D-20 located in Koloa substation control house

## Appendix C: Sample Procurement Documents

- Provide all documentation including calculations, software, design drawings, equipment drawings, and modifications to the existing drawings
- Provide on-site training classes for KIUC operators, engineers, technicians and maintenance personnel
- Supply any special equipment and tools required for the operation and maintenance of the project
- Supply an initial complement of spare parts
- Provide a warranty for all BESS components
- Submit for KIUC review and comment all design drawings, O&M manuals, and miscellaneous documentation required to provide a complete installation
- Provide and maintain a Schedule for all design, fabrication, installation and testing activities for the project, including KIUC review periods

### 6. Documentation

The Contractor shall furnish complete documentation that will be used for determination of contract compliance, as well as, operation and maintenance of the BESS. The documentation shall be in English, well detailed and instructive.

At a minimum, Contractor's documentation shall consist of the following:

- Construction Materials Submittal
- Equipment Drawings and Specifications
- Bill of Material
- Protective relay and BESS Control Settings
- Operation and Maintenance Manual
- Maintenance Schedule
- Project Schedule
- Software Documentation
- Test Reports

The Contractor shall submit all final design and record drawings in digital form. In addition to the specified drawing requirements, all construction and installation drawings pertaining to architectural, civil, mechanical and electrical activities, bills of materials, interconnection, wiring, and cable diagrams shall be included. All equipment drawings that may be subjected to revisions or modification shall also be included. The format shall be AutoCAD Version 14.

### 7. Design Conditions

- Design Temperature Range: min 55 F, max 100 F
- Peak Wind Gust: 110 mph
- Seismic Zone: 1

### 8. Electrical Design Parameters

- Nominal voltage at Koloa Distribution Bus = 12.47 kV (1.0pu)
- Normal sustained voltage at Koloa Distribution Bus = 0.95 pu (min) and 1.05 pu (max)
- Normal frequency = 60 Hz with normal deviation of +/- 0.2 Hz
- Emergency frequency swings = 55.0 Hz (min) and 65 Hz (max)

### 9. Audible Noise

The maximum sound level generated from the BESS system and any associated equipment supplied by the Contractor under any output level within the BESS operating range, shall be limited to 65 dBA at 50 feet in any direction from the substation fence.

### 10. BESS Power and Energy Ratings

- 1000 kW / 1000 kWh minimum - 1500 kW / 1000 kWh maximum
- Full power discharge, 30 minutes, 1/week

## Appendix C: Sample Procurement Documents

- Shallow discharge, 70% power for 2 minutes, 50 times/day

### 11. Modes of Operation

#### 3MW PV Smoothing

The BESS shall manage (smooth) output of the 3MW PV array. The overall net power import or export of the mutually coupled BESS and 3 MW PV array shall not adversely affect KIUC system stability, reliability, or operational activities. Operation in this mode will be automatically initiated by detection of active power flow from 3 MW PV array. **KIUC will provide A, B, and C phase Currents and Voltages to the BESS Control.**

- CT inputs (ratio 300:5) from the PV array to the BESS Control
- PT inputs (ratio 60:1) from the from the Koloa 12.47kV Distribution bus to the BESS Control

#### Spinning Reserve

The BESS shall be capable of discharging up to full rated output at any time in accordance with performance criteria specified herein. Operation in this mode will be initiated by detection of low frequency or frequency rate of change while the BESS is in any other mode, including charging. Spinning reserve will be initiated when system frequency drops to a KIUC selectable setpoint and shall load to full output, or as required to arrest frequency decay. Once a spinning reserve event is initiated, the frequency control shall control the BESS output as the system recovers to 60 Hz. After a spinning reserve discharge, the BESS shall return to the mode in which it was operating at the start of the spinning reserve discharge, as allowed by the battery's state of charge at that time. If the discharge limit will not allow resumption of previous operation mode, the BESS shall go to the charge mode. Spinning reserve shall have the highest priority of all modes contained in this specification. All other modes may be interrupted for a spinning reserve event.

#### Automatic Scheduling

In order to take advantage of the fast response time possible with the BESS, KIUC desires the BESS to be capable of ramping to a predetermined output level as set by a remote signal from KIUC's SCADA system. The ramp rate and output level shall be selectable and the output level shall be programmable, on a continuous real time basis, by the remote signal from KIUC's SCADA system. Once initiated in this operating mode, the BESS shall remain at the designated output until terminated by a remote signal or the Contractor specified discharge limit is reached. Operation in this mode may be interrupted for a spinning reserve event as allowed by the battery's state of charge at that time.

#### Automatic Generation Control

The BESS shall be capable of Automatic Generation Control (AGC) similar to that of rotating machinery. The BESS output will be controlled by a remote signal from the AGC. The BESS voltage and frequency controls shall regulate the output based on appropriate KIUC selectable droop settings. The operation in the AGC mode shall be limited by the Contractor specified discharge limit for the batteries. Operation in the AGC mode may be interrupted by system disturbances requiring automatic emergency support from the BESS, as allowed by the battery's state of charge at that time.

#### Power System Stabilizer

The BESS shall provide effective damping of power system oscillations. Such oscillations may be caused by system disturbances, primarily line faults and the sudden loss of generation. The BESS shall be capable of detecting such oscillations by monitoring frequency and voltage deviations and controlling the BESS output to provide effective damping. The power system stabilizer shall be capable of being enabled or disabled by a remote signal.

#### VAR Support

The BESS will be required to provide VAR support for voltage regulation at the Koloa substation 12.47kV bus under steady state operating conditions. The BESS voltage regulator controls shall include a selectable setpoint, via SCADA, on the Koloa 12.47 kV distribution bus. BESS capacity for VAR support shall be a lower priority than all other described operating modes. The VAR output of the BESS may be limited based on remaining capacity used for real power output.

## 12. Monitoring/Alarms

The monitoring/alarm system or procedures shall alert KIUC, via SCADA, when the number of failed or inadequately performing cells or other Contractor determined conditions indicate that;

- Preventative maintenance should be performed to keep the BESS at the specified performance levels.
- The BESS is in imminent danger of failing to meet specified performance levels or potential safety hazards exist.
- The BESS can no longer meet the specified performance criteria or safety hazards exist.

The Contractor shall include, in the Operation and Maintenance Manual, the recommended corrective action and maintenance procedures for each alarm level or observed condition provided.

## 13. Harmonics

The BESS must meet the harmonic specifications of IEEE 519.

## 14. Protection Requirements

A complete protective relaying system based on prudent industry practices shall be a part of the AC system. The protective relaying and metering shall be integrated with the BESS control system and communications channel to KIUC's SCADA system. All protective equipment and schemes shall be properly coordinated with the protection of the Koloa Substation. Information on the protective relaying system for the Koloa Substation will be provided to the successful Contractor.

## 15. Controls

The BESS control system shall be designed to provide for automatic, unattended operation of the BESS. However, the control system design also shall provide for local manual operation, remote operation, or dispatch of the BESS from KIUC's SCADA system. All modes of operation and its operational set-point functionality shall be remotely adjustable from SCADA to allow change in settings and to turn on/off all controls or modes when appropriate.

## 16. SCADA Integration

The Contractor's design and BESS control system interface shall be integrated with KIUC's existing SCADA system and associated RTU/substation communication network. The interface point will be to a GE D20 Remote Terminal Unit (RTU) located in the Koloa substation control house. Existing RTU hardware is available and useful, depending on final design, for interfacing to the new BESS control system into KIUC's SCADA system.

The engineering tasks shall include, but not be limited to, the following:

- (KIUC to provide conduit and communication cabling from RTU to BESS Control. Alphawire 3232 (3/C 20AWG Shielded) or Belden 3107A (2PR/22AWG Shielded) will be utilized.)
- Communication between BESS and RTU equipment will be RS-485/Serial. Depending on final design (e.g., amount of monitored devices, equipment layout, distance, etc.), other communication methods may be recommended for approval that will provide the most efficient, reliable, and secure communication network. All signal/communication cable to be shielded to ensure signal integrity.
- DNP3 protocol to be utilized for all communications between BESS control system interface and RTU.
- DNP3 map of all I/O points and controls on local BESS control system HMI interface must be available and inclusive to SCADA system for monitoring and control.
- Additional and identifiable points or controls, if not provided initially through BESS control system interface base offering, must be programmed into interface for serial link communications (e.g., but not limited to, fire system activation & integrity, BESS building entry, breaker status).
- A provided SCADA points list shall be prepared by the Contractor and submitted to KIUC for review and approval.
- BESS control system interface will have the ability to accept AGC control setpoint signals from SCADA master station via RTU.
- Contractor will help facilitate and ensure all BESS sensor calibrations and system testing to KIUC SCADA.

## Appendix C: Sample Procurement Documents

- Provide monitoring access and control access to all proposed BESS modes of operation, state of charge, available duration at various output levels, kW/kVar setpoints, kW/kVar flow, local/remote control, misc BESS alarms/status.
- Work items shall include all labor, materials, test equipment, & engineering required to complete SCADA communication integration.
- The Contractor shall prepare plan and section drawings for the SCADA/RTU integration showing the location of all equipment and conduit runs. The Contractor showing all external cable connections to the applicable BESS switchboards and other equipment shall prepare interconnection wiring diagrams for the RTU.
- The Contractor shall provide complete testing procedures for the BESS equipment and control system and assist KIUC in the commissioning of the RTU/SCADA integration. The prepared testing procedures shall be submitted to KIUC for review and approval before any testing work is done. A final report detailing the work completed, all test forms, and any marked-up drawings shall be submitted to KIUC..

**17. Grounding**

A suitable equipment grounding system shall be designed and installed for the BESS system. This system shall be tied to the Koloa Substation grounding system. The grounding system shall provide personnel protection for step and touch potential in accordance with IEEE 80. The system also shall be adequate for the detection and clearing of ground faults. The Contractor shall determine, design and install the required interconnections between the BESS and Koloa substation grounding systems.

**18. Civil/Structural**

The Contractor shall furnish all labor, equipment, materials and services to layout, design and construct all foundation and concrete work required for a complete and operable facility. All BESS required foundations and structures shall be designed by a qualified registered professional engineer or registered architect as applicable. All final (Issued for Construction) drawings, specifications and calculations shall be wet-stamped by a Registered Civil/Structural Engineer or Architect as applicable. **The Contractor is responsible for Geotechnical surveying.**

**19. Spill Containment**

The BESS design shall mitigate against electrolyte spills that are credible for the types of cells used. The design shall include features that contain electrolyte spills (to be emptied by contracted chemical disposal company in the event of a spill) and prevent discharge to surrounding site soils.

**20. Personnel Safety**

The BESS shall include eyewash stations in the battery area as applicable.

**21. Fire Protection**

The Contractor shall design and install a fire protection system that conforms to national and local codes. The fire protection system design and associated alarms shall take into account that the BESS will be unattended at most times.

**22. Spare Parts and Equipment**

The Contractor shall evaluate its design with regard to failure rates, effects and BESS reliability. The Contractor shall provide a recommended spare parts list, including prices and availability, as part of his proposal.

**23. Factory Testing - Battery**

The Contractor shall test and submit test data for the cells designated for use on this project. At a minimum, the following tests shall be performed.

- Capacities, Ampour and Watthour
- Heat Generated
- Efficiencies

## Appendix C: Sample Procurement Documents

- As applicable, maximum noxious and toxic material release rates

The Contractor shall capacity test 100% of the production cells to ensure compliance with design requirements. The Contractor may propose optional alternate testing programs that result in a benefit to KIUC. However, the base proposal shall include capacity testing of 100% of the cells. All proposals for alternate testing shall include details of the proposed plan and the cost benefit to KIUC.

### **24. Acceptance and Performance Testing**

The Contractor shall develop and perform field testing procedures to assure that the BESS will perform as designed and that the system meets the performance criteria specified elsewhere in these specifications. All modes of operation as described in these specifications shall be tested. The Contractor shall determine that the BESS is fully operational and suitable for acceptance testing witnessed by KIUC. The Contractor shall document all acceptance and performance tests performed. The Contractor shall submit documentation, analyses, and a summary in a test report for KIUC's records. The acceptance test procedure will be developed by the Contractor and shall demonstrate to KIUC that the BESS is operational and performs as specified. These tests shall include, as a minimum:

- Verification of sensors, metering and alarms
- Verification of all control functions, including automatic, local and remote control
- Verification of performance criteria

### **25. Warranty**

Contractor warrants KIUC that the equipment and materials furnished hereunder and the completed BESS Project are fit for the purpose of producing electricity in accordance with the Contract and are free from defects in workmanship and materials. Contractor makes all such warranties for a period of eight (8) years after the date of acceptance of the Project by KIUC.

### **26. Exceptions**

All exceptions and/or deviations shall be clearly and separately itemized. It shall not be necessary for KIUC to examine the standard literature and documents of suppliers to determine the existence and extent of any exceptions and/or deviations from this specification.


**Kauai Island Utility Cooperative  
Battery Energy Storage System****Proposal Data Checklist**

- Provide firm-fixed pricing being offered in accordance with Bidder's form.
- Provide drawings showing proposed layout of all outdoor equipment in relation to the BESS and the Koloa Substation.
- Provide a detailed project schedule.
- Provide Warranty terms and conditions and information for 8 year warranty.
- Provide list of recommended spare parts and prices.
- Provide list of exceptions and clarifications to the technical proposal and commercial terms and conditions, or written verification that no exceptions or clarifications are taken.
- Provide a description of all required maintenance activities, including estimated man-hours and frequency of occurrence for each activity.
- Provide information on AC/AC round trip efficiencies (excluding step-up transformer).
- Provide proposed battery replacement schedule.
- Provide battery replacement costs and a description of escalation factors used to determine actual battery costs at the time of replacement.
- Provide information on battery replacement procedure, including estimated time to complete replacement.
- Provide information showing the length of time the battery can maintain constant output at demand levels less than rated output.
- Provide information showing the length of time the battery can maintain rated output at a reduced state of charge.
- Provide information on guaranteed life expectancy to maintain rated capacity as number of discharges or total energy delivered varies.
- Provide information on the controlling parameters that determine life expectancy for the proposed system.
- Provide information on required environmental conditions or maintenance procedures (if any) that performance guarantees are based on.
- Provide overload capability of the proposed BESS.
- Provide PCS manufacturer specifications.
- Provide information on how the charging cycle changes as maximum demand is reduced.
- Provide information on the state of charge of the battery as a function of time during the charge cycle.
- Provide proposed factory and acceptance test plans to include performance and "Modes of Operation" testing.**
- Provide a performance curve indicating # of cycles vs. depth of discharge.**


**Kauai Island Utility Cooperative**  
**Battery Energy Storage System**  
**Bidder's Proposal**

1. Project Management	\$ _____
2. Battery	\$ _____
3. Power Conversion System	\$ _____
4. Balance of Outdoor Equipment	\$ _____
5. Construction and Installation	\$ _____
6. Protective Equipment	\$ _____
7. BESS Control and Metering System	\$ _____
8. Fire Protection System	\$ _____
9. Start-up, Testing, Commissioning	\$ _____
10. SCADA Integration	\$ _____
11. Warranty	\$ _____
12. Shipping: FOB Koloa Substation	\$ _____
13. Miscellaneous (list details)	\$ _____
<b>TOTAL BESS PRICE</b>	\$ _____
14. End of Life Decommissioning	\$ _____
15. Spare Parts and Equipment	\$ _____
16. Extended Warranty	\$ _____
<b>TOTAL ADDITIONAL COSTS</b>	\$ _____


## Exhibit 1



**Exhibit 2**



**Exhibit 3**



### C.3 Technical Specification Example

An example of a technical specification for procurement of an electricity storage system is EPRI's "Technical Specification for a Transportable Lithium-Ion Energy Storage System for Grid Support Using Commercially Available Lithium-Ion Technology." This specification can be found at:

<http://www.epri.com/abstracts/Pages/ProductAbstract.aspx?ProductId=00000000001025573>

## C.4 Sample Data Requirements Document Outline (Provided by PNM)

The following is a possible outline for a Requirements Document:

1. Project Introduction
  - a. Opportunity Description
  - b. Business Need
  - c. Justification
  - d. Project Objectives
  - e. In Scope
  - f. Out of Scope
  - g. System Context
  - h. Stakeholders and Users
  - i. Risks
  - j. Assumptions
  - k. Constraints
2. Functional Requirements
  - a. System Functionality
3. Non-Functional Requirements
  - a. Look & Feel Requirements
  - b. Usability Requirements
  - c. Performance Requirements
  - d. Operational Requirements
  - e. Maintainability and Support Requirements
  - f. Security Requirements
  - g. Business Continuity
  - h. Disaster Recovery
  - i. Regulatory Requirements
  - j. Legal Requirements
4. Interface Requirements
  - a. Software Interfaces
  - b. Hardware Interfaces
  - c. Communication Interfaces
5. Data Model Requirements
6. Middleware Requirements
7. Appendix A: Preliminary Data Points List
8. Appendix B: Preliminary Data Model
9. Acronyms
10. Glossary
11. EPRI's IntelliGrid Framework which calls for the development of use cases. Developing use cases includes the description the functions to be performed, a description of what occurs when, why, how, and under what conditions. It also describes the actors (systems, organizations, devices and users) performing the roles. Further function analysis and

steps in this analysis are described in detail to understand the system needs in all conditions. A use case template along with a large sampling of developed use case analyses, many tailored to electricity storage, are available at:

<http://www.smartgrid.epri.com/Repository/Repository.aspx>

Energy storage vendors should provide the use case communication as part of the procurement package.

## C.5 Sample Data Acquisition System Specification (Provided by PNM)

Requirements

**Storage System  
Data Acquisition & Management Project**

<b>1</b>	<b>PROJECT INTRODUCTION .....</b>	<b>27</b>
1.1	Opportunity Description .....	27
1.2	Business Need .....	27
1.3	Justification .....	27
1.4	Project Objectives .....	27
1.5	In Scope .....	27
1.6	Out of Scope .....	27
1.7	System Context .....	28
1.8	Stakeholders and Users .....	28
1.9	Risks .....	28
1.10	Assumptions .....	28
1.11	Constraints .....	28
<b>2</b>	<b>FUNCTIONAL REQUIREMENTS .....</b>	<b>29</b>
2.1	System Functionality .....	29
<b>3</b>	<b>NON-FUNCTIONAL REQUIREMENTS .....</b>	<b>32</b>
3.1	Look & Feel Requirements .....	32
3.2	Usability Requirements .....	32
3.3	Performance Requirements .....	32
3.4	Operational Requirements .....	33
3.5	Maintainability and Support Requirements .....	34
3.6	Security Requirements .....	34
3.7	Business Continuity .....	34
3.8	Disaster Recovery .....	35
3.9	Regulatory Requirements .....	35
3.10	Legal Requirements .....	35
<b>4</b>	<b>INTERFACE REQUIREMENTS .....</b>	<b>35</b>
4.1	Software Interfaces .....	35
4.2	Hardware Interfaces .....	36
4.3	Communication Interfaces .....	36
<b>5</b>	<b>DATA MODEL REQUIREMENTS .....</b>	<b>37</b>
<b>6</b>	<b>MIDDLEWARE REQUIREMENTS .....</b>	<b>37</b>
<b>7</b>	<b>APPENDIX A: PRELIMINARY DATA POINTS LIST .....</b>	<b>37</b>
<b>8</b>	<b>APPENDIX B: PRELIMINARY DATA MODEL .....</b>	<b>37</b>
<b>9</b>	<b>ACRONYMS .....</b>	<b>37</b>
<b>10</b>	<b>GLOSSARY .....</b>	<b>37</b>

## 1 Project Introduction

### 1.1 Opportunity Description

Describe project background, partners and overall data needs and data systems involved.

### 1.2 Business Need

Example: primary project has several requirements related to data which include: providing information to the storage system and other vendors for warranty purposes and providing information to other internal and external business partners for analysis.

The project will also provide access to hardware controls to specific partners subject to utility security requirements.

### 1.3 Justification

Describe the market driver for the storage system – what problem is being solved? e.g. The nature of large scale renewable resources creates a system risk from the intermittency of those renewable resources, as well as the fact that the output of resources such as PV do not align with the times of greatest energy demand and utilization. This project will demonstrate a potential solution that can help mitigate future risk on the utility's system, stemming from increased use of PV technology.

This project allows us to understand the impacts of large scale PV on the distribution system and investigate mitigation and economic enhancement strategies.

### 1.4 Project Objectives

- Meet the requirements of the primary project for data storage, data distribution and system access to internal and external stakeholders.

### 1.5 In Scope

- Retrieve and store data from \_\_\_\_\_ data collection points at the battery / PV site. The data will be gathered at the required time intervals that will vary from one second to one minute.
- Develop and implement a data model to capture data being generated by the battery / PV site.
- Distribute selected data to \_\_\_\_\_ and other internal and external business partners for analysis.
- Provide required security to protect confidential/proprietary data including point to point basis.
- Address any security requirements necessary to protect the utility's computer network, electric distribution, and telecommunications systems.
- Security interoperability with UTILITY's Security standards & Cyber Security.
- Provide specifications and requirements to Communications Group so that they can provide sufficient bandwidth and physical infrastructure to support the data traffic.

### 1.6 Out of Scope

- Data requirements for other utility initiatives will not be met by this project.
- Physical security at the site will be provided by the primary project

## 1.7 System Context

### C.1.1.1 As-Is

No current state exists.

### C.1.1.2 To-Be

Include conceptual architectural diagram that details which actors (people, groups, devices) are to communicate and how they communicate (protocols and physical layers) with other actors

## 1.8 Stakeholders and Users

[Removed from vendor version]

## 1.9 Risks

[Removed from vendor version]

## 1.10 Assumptions

[Removed from vendor version]

## 1.11 Constraints

- Data transmission and storage needs to begin by\_\_\_\_.

## 2 Functional Requirements

### 2.1 System Functionality

	Requirement	Owner	Critical
2.1.1	<p>The solution shall provide a method for <b>retrieving specific data</b> from solar and battery technology source systems that will be located at the storage site, which are itemized in the <a href="#">Interface Requirements</a> section of this document.</p> <p><i>Note: Refer to Points List in Appendix.</i></p>	UTILITY	x
2.1.2	The solution shall provide a method for <b>receiving specific data</b> from over collection points from various devices located at the site.	UTILITY	x
2.1.3	The solution shall extract data from sources in regular <b>intervals</b> ranging from 1 second to every 60 seconds, depending upon stakeholder requirements.	UTILITY	x
2.1.4	The solution shall provide a method for <b>storing</b> acquired data from source systems at the site, for a period of time to be defined by the user.	UTILITY	x
2.1.5	The solution shall provide a method for <b>transmitting</b> data in 15 minute intervals (or less depending on stakeholder requirements) from a site database to an offsite storage and reporting database.	UTILITY	x
2.1.6	The solution shall provide a method for <b>storing</b> extracted data offsite for a minimum of    years from the date of solution implementation.	UTILITY	x
2.1.7	The solution shall provide a method for <b>archiving</b> all stored data into a secondary storage location, at a user-selected time cycle such as every 30 days, quarterly, annually, etc.	UTILITY	x
2.1.8	The solution shall provide a method for <b>retrieving archived</b> data within 24 hours of the request for retrieval.	UTILITY	
2.1.9	The solution shall provide a method for setting varying <b>retention</b> schedules on specified datasets in both the production storage database and the archived storage database.	UTILITY	
2.1.10	The solution shall provide a method for users to retrieve, display, and otherwise <b>make available</b> all data stored in the production database, subject to authorized user permissions and UTILITY's <a href="#">Security Requirements</a> .	UTILITY	x
2.1.11	The solution shall provide a method for transmitting or otherwise making data available to user-selected <b>internal</b> entities.	UTILITY	x

## Appendix C: Sample Procurement Documents

2.1.12	The solution shall provide a method for transmitting or otherwise making data available to user-selected <b>external</b> entities, in a manner that that is compliant with UTILITY's <a href="#">Security Requirements</a> .	UTILITY	x
2.1.13	The solution shall provide a method for <b>authorized vendors</b> and other external parties to <b>access</b> appropriate systems and resulting datasets, from a point outside the company's network (through a server in the DMZ), subject to UTILITY's <a href="#">Security Requirements</a> .	UTILITY	x
2.1.14	The solution shall provide a method for authorized internal users to create, generate, and produce user-designed <b>reports</b> on demand (monthly, quarterly, annual, etc.) subject to UTILITY's <a href="#">Security Requirements</a> .	UTILITY	x
2.1.15	The solution shall perform <b>time synchronization</b> functions on all data reads from the devices at the server level and time stamps at the device or gateway level.	UTILITY	
2.1.16	<p>The solution shall be capable of <b>grouping and segregating</b> stored records by specific data fields and record characteristics including, but not limited to, the following categories as applicable to the source device:</p> <ul style="list-style-type: none"> <li>• Operational vs. analytical</li> <li>• Operational vs. financial</li> <li>• Public vs. private</li> <li>• Vendor proprietary and confidential</li> <li>• Identify which data columns are available to user-selected internal and external entities.</li> <li>• Baseline vs. actual achieved operation (for purposes of economics and costing).</li> </ul>	UTILITY	x
2.1.17	<p>The solution shall be capable of allowing users to <b>select and query</b> data by specific fields and record characteristics including, <u>but not limited to</u>, the following categories as applicable to the specific data type:</p> <ul style="list-style-type: none"> <li>• Date/time ranges of all data reads.</li> <li>• Test modes in operation at time of read.</li> <li>• PV and Battery configuration settings at time of read.</li> <li>• Weather conditions at time of read.</li> </ul>	UTILITY	x
2.1.18	The solution shall provide a method for <b>transforming</b> all collected data from the various source devices into a <b>uniform</b> format, which will be transferred to a common database.	UTILITY IT	x
2.1.19	The solution shall perform <b>evaluation</b> on data for "changed-data-only" transaction comparison, prior to committing to the database	UTILITY	

## Appendix C: Sample Procurement Documents

2.1.20	The solution's data acquisition system shall identify and appropriately <b>label null values</b> of data which are non-existent points of data (e.g., system outage or no reading taken), as opposed to extrapolated data within each record based on no change from previous data read.	UTILITY	x
2.1.21	The solution shall identify and appropriately label each data field within the record as being evaluated and deemed and " <b>accurate read</b> ," as defined by each device.	UTILITY	x
2.1.22	The solution shall include a <b>date and time stamp at the gateway or device level</b> on every record reading, regardless of record type.	UTILITY	x
2.1.23	The solution shall capture, store and forward <b>numerical data types</b> without any display formatting, such as commas.	UTILITY	
2.1.24	The solution's data acquisition system shall capture, store, and forward the <b>status</b> of all devices at the time of read.	UTILITY	x
2.1.25	The solution's data acquisition system shall provide the ability to <b>translate status</b> of all devices, in order to create a uniform definition of status across devices.	UTILITY	x
2.1.26	The solution's data acquisition system shall capture, store, and forward any <b>alarm</b> details that may have been recorded on the device at the time of read.	UTILITY	x
2.1.27	The solution's data acquisition system shall capture, store, and forward the <b>configuration settings</b> in place on all devices at the time of read.	UTILITY	x
2.1.28	The solution's data acquisition system shall provide the ability to <b>map</b> data accurately from each device into a common database onsite for initial storage and eventual forwarding.	UTILITY	x
2.1.29	The solution's data acquisition system shall capture, store, and forward the <b>settings of the feeder</b> at the time of read.	UTILITY	x
2.1.30	The solution data acquisition system shall collect, store, and forward all records at the individual <b>record level</b> .	UTILITY	x
2.1.31	The solution's data acquisition system shall be capable of storing and forwarding <b>physical</b> changes at the site, which may have affected performance readings and were not otherwise captured electronically through the devices, such as climate control changes and cleaning of dust off PV panels.	UTILITY	x
2.1.32	The solution must be capable of linking or providing datasets to the _____ information Clearinghouse.	DOE	x

### 3 Non-Functional Requirements

#### 3.1 Look & Feel Requirements

	Requirement	Owner	Critical
3.1.1	The solution must be capable of displaying the company's approved <b>logo</b> on selected reports.	UTILITY	
3.1.2	The solution must be capable of displaying a <b>confidentiality</b> statement on selected reports, queries, and any other output formats.	UTILITY	

#### 3.2 Usability Requirements

	Requirement	Owner	Critical
3.2.1	The solution shall include a <b>data dictionary</b> , listing all data fields and their associated definitions, to be made available to the business in a readable format such as Acrobat pdf.	UTILITY	
3.2.2	The solution for data acquisition and transmitting shall be <b>accessible</b> at the <b>physical</b> site, subject to UTILITY's <a href="#">Security Requirements</a> .	UTILITY	x

#### 3.3 Performance Requirements

	Requirement	Owner	Critical
3.3.1	<p>The solution shall be capable of extracting, transmitting, and storing an estimated <b>million records per day</b> from pre-identified collection points.</p> <p><i>Estimated calculations:</i></p> <p>60 seconds * 60 minutes = 3600 seconds in one hour</p> <p>3,600 seconds * 24 hours = 86,400 seconds in 24 hours</p> <p>85,400 seconds * _____ sites = _____ records per day.</p>	UTILITY	x
3.3.2	<p>The solution shall be capable of retrieving, storing and forwarding an estimated 100 byte record length, including all measurements and settings.</p> <p><b>Assumptions</b></p> <p>Record Length = _____ bytes</p> <p>Number of data collection points = _____</p> <p>Reads per minute = _____</p>	UTILITY	x

## Appendix C: Sample Procurement Documents

	<p>The solution shall be capable of handling the following site data volumes and velocities, based on the assumptions listed in <a href="#">Requirement 3.3.2</a>.</p> <p><b>Volumes &amp; Velocities</b></p> <p>Records per second = _____</p> <p>Bytes per second = _____</p> <p>Records per 15 minutes = _____</p> <p>Records per hour = _____</p> <p>MBytes per 15 minutes = _____</p> <p>MBytes per hour = _____</p> <p>Hours per day operation = _____</p> <p>MBytes per day = _____</p>	UTILITY	x
3.3.3	<p>The solution shall be capable of storing and managing data at the following estimated volumes, based on the assumptions listed in <a href="#">Requirement 3.3.2</a>.</p> <p><b>Anticipated Storage Volumes</b></p> <p>Gbytes Per month(raw data) = _____</p> <p>Gbytes per year (raw data) = _____</p> <p>Est DB storage per month (GB) = _____</p> <p>Est DB Storage per year (GB) = _____</p>	UTILITY	x

## 3.4 Operational Requirements

	Requirement	Owner	Critical
3.4.1	If the solution selected requires an _____ <b>platform</b> , the solution shall be compatible with _____ (appropriate current version)	IT	x
3.4.2	If the solution selected requires a _____ <b>Server</b> , the solution shall be compatible _____ (appropriate current version)	IT	x
3.4.3	If the solution selected requires a _____ <b>Operating System</b> , the solution shall be compatible _____ (appropriate current version)	IT	x
3.4.4	If the solution selected can operate within a virtualized server environment, the solution shall be compatible with _____ (appropriate current version).	IT	
3.4.5	If the solution selected requires an internet platform, the solution shall be compatible with _____ (appropriate current version)	IT	
3.4.6	The solution shall be compatible with _____ reporting and analytics tool.	UTILITY	

### 3.5 Maintainability and Support Requirements

	Requirement	Owner	Critical
3.5.1	The solution's <b>storage/reporting and archival databases</b> shall be located at UTILITY's _____ Center in _____(location).	IT	
3.5.2	The solution's <b>application server</b> shall be located at UTILITY's _____ Center in _____ (location)..	IT	
3.5.3	The solution's <b>database</b> located at the <b>site</b> shall be supported by _____.	UTILITY	
3.5.4	The solution shall provide a method for <b>error handling</b> and/or logging for the data handling process from start to finish (from data reads at the site to transmission to external entities)	UTILITY & IT	x
3.5.5	The solution shall be subject to, and comply with, the _____process for all system and object changes before being migrated to a production server.	IT	x

### 3.6 Security Requirements

	Requirement	Owner	Critical
3.6.1	Specific and detailed security requirements are listed here based on Utility communication systems & networks security policies and standards. A robust version lists all company IT security requirements	IT Security	x

### 3.7 Business Continuity

	Requirement	Owner	Critical
3.7.1	The solution shall be <b>available</b> to authorized users 24 hours a day, 7 days a week, with unscheduled down time no greater than two consecutive calendar weeks at one time.	UTILITY	
3.7.2	The solution's data acquisition <b>routines</b> are expected to complete successfully at the stated intervals in the Preliminary Data Points list provided in <a href="#">Appendix A</a> .	UTILITY	

### 3.8 Disaster Recovery

	Requirement	Owner	Critical
3.8.1	The solution's online storage database shall be <b>backed up</b> to secondary media on a routine schedule, at a minimum of every 24 hours, every day of the calendar week.	UTILITY	

### 3.9 Regulatory Requirements

More information about NERC CIP requirements can be found on their website:  
<http://www.nerc.com/page.php?cid=2|20>

	Requirement	Owner	Critical
3.9.1	All cyber assets for the solution and systems contained within must be <b>evaluated</b> for NERC CIP applicability during the design phase.	IT Security	x
3.9.2	<b>Assets identified</b> as in-scope for NERC CIP compliance must meet the NERC CIP-002 through CIP-009 requirements applicable to the asset, prior to implementation.	IT Security	x
3.9.3	The system shall <u>not</u> have the capability to impede, interfere with, or degrade, any existing UTILITY solution(s) in place.	IT Security	x

### 3.10 Legal Requirements

None defined.

	Requirement	Owner	Critical

## 4 Interface Requirements

### 4.1 Software Interfaces

	Requirement	Owner	Critical
4.1.1	The solution shall be capable of extracting data from Storage System, which will be used for monitoring the performance, and reading/producing all pertinent data to the storage system, as well as allowing settings control.	UTILITY	x

## 4.2 Hardware Interfaces

	Requirement	Owner	Critical
4.2.1	<p>The solution must interface with <b>source devices</b> that will produce readings that will be interrogated for data acquisition. Source devices include, but may not be limited to:</p> <ul style="list-style-type: none"> <li>• UTILITY Metering</li> <li>• PCS Controller</li> <li>• Other Sensors</li> <li>• Meteorological stations (wind, temp, etc.)</li> </ul>	UTILITY	X

## 4.3 Communication Interfaces

	Requirement	Owner	Critical
4.3.1	The solution shall include a_____ protocol interface in the solution, which will interface with various source devices at the site.	UTILITY	X
4.3.2	The solution shall <b>interrogate</b> source devices at specified intervals listed in the Preliminary Data Points document in Appendix, capturing and storing data in one database at the physical site.	UTILITY	X
4.3.3	The solution shall transfer data from the physical site database to _____(location), using_____ <b>(network description)</b>	UTILITY	X
4.3.4	The solution's communication lines shall be capable of handling a minimum of _____ of transmission per hour.	STORAGE MFTR	X
4.3.5	The storage system utilizes_____ for maintenance and must be supported.	STORAGE MFTR	X
4.3.6	The storage system utilizes_____ for data logging, and must be supported.	STORAGE MFTR	X

## 5 Data Model Requirements

	Requirement	Owner	Critical
5.1.1	The solution's data model shall include calculated fields that contain common data <b>aggregation</b> summations, as they apply to specific data types.	UTILITY	
5.1.2	The solution's data model shall allow for <b>null values</b> in any record field except for date and time of data reading.	UTILITY	X
5.1.3	The solution's data model shall be <b>minimally normalized</b> .	UTILITY	x
5.1.4	The solution's data model shall provide a method for storing <b>information</b> about each data field, their descriptions, and typical purpose.	UTILITY	

## 6 Middleware Requirements

None defined.

	Requirement	Owner	Critical
6.1.1			

## 7 Appendix A: Preliminary Data Points List

## 8 Appendix B: Preliminary Data Model

## 9 Acronyms

## 10 Glossary



## **APPENDIX D: UTILITY AND OWNER INTERCONNECTION COSTS AND SCHEMATICS FOR VARIOUS STORAGE SYSTEMS**

### **Appendix D: Table of Contents**

<u>D.1</u>	<u>5-kW to 100-kW Storage System Utility and Owner Interconnection and Equipment Costs</u>	..... D-2
<u>D.2</u>	<u>250-kW, 500-kW, and 1-MW Storage System Utility and Owner Interconnection and Equipment Costs</u>	..... D-3
<u>D.3</u>	<u>2-MW, 2.5-MW, and 3 -MW Storage System Utility and Owner Interconnection and Equipment Costs</u>	..... D-4
<u>D.4</u>	<u>5-MW Storage System Utility and Owner Interconnection and Equipment Costs</u>	..... D-5
<u>D.5</u>	<u>10-MW Storage System Utility and Owner Interconnection and Equipment Costs</u>	..... D-6
<u>D.6</u>	<u>25-MW Storage System Utility and Owner Interconnection and Equipment Costs</u>	..... D-7
<u>D.7</u>	<u>50-MW Storage System Utility and Owner Interconnection and Equipment Costs</u>	..... D-8
<u>D.8</u>	<u>100-MW Storage System Utility and Owner Interconnection and Equipment Costs</u>	..... D-9

### **Appendix D: List of Figures**

<u>Figure D-1.</u>	<u>Schematic of 5 to 10 kW Storage System showing Utility and Owner Interconnection and Equipment Costs</u>	.....
<u>Figure D-2.</u>	<u>Schematic of 250-kW, 500-W, and 1-MW Storage System showing Utility and Owner Interconnection and Equipment Costs</u>	.....
<u>Figure D-3.</u>	<u>Schematic of 2-MW, 2.5 MW, and 3-MW Storage Systems showing Utility and Owner Interconnection and Equipment Costs</u>	.....
<u>Figure D-4.</u>	<u>Schematic of 5-MW Storage System showing Utility and Owner Interconnection and Equipment Costs</u>	.....
<u>Figure D-5.</u>	<u>Schematic of 10-MW Storage System showing Utility and Owner Interconnection and Equipment Costs</u>	.....
<u>Figure D-6.</u>	<u>Schematic of 25-MW Storage System showing Utility and Owner Interconnection and Equipment Costs</u>	.....
<u>Figure D-7.</u>	<u>Schematic of 50-MW Storage System showing Utility and Owner Interconnection and Equipment Costs</u>	.....
<u>Figure D-8.</u>	<u>Schematic of 100 MW Storage System showing Utility and Owner Interconnection and Equipment Costs</u>	.....

### **Appendix D: List of Tables**

(none)

## UTILITY AND OWNER INTERCONNECTION COSTS AND SCHEMATICS FOR VARIOUS STORAGE SYSTEMS

### D.1 5-kW TO 100-kW Storage System Utility and Owner Interconnection and Equipment Costs

The following schematics represent interconnection configurations for various sizes of electricity storage systems illustrating the utility and owner interconnection equipment, such as transformers and switchgear that is required for that particular type and size of storage system.

The costs for the equipment are representative costs only and these can be changed if more specific costs are available for that site or if additional equipment is necessary. The costs estimated in these schematics have been used to derive the total system costs shown in the plots in *Chapter 2: Electricity Storage Technologies: Cost, Performance, and Maturity* and in the detailed cost breakdowns.

	Subtotal \$/kW	\$500 \$100	\$500 \$33	\$500 \$20	\$500 \$10	\$500 \$5
<b>Owner Interconnection (OI) Costs</b>						
3	PCS Equipment:	\$9,500	\$24,500	\$31,000	\$44,500	\$79,000
	PCS Installation:	\$5,000	\$12,500	\$15,500	\$22,500	\$39,500
	Subtotal	\$14,500	\$37,000	\$46,500	\$67,000	\$118,500
	\$/kW	\$2,900	\$2,467	\$1,860	\$1,340	\$1,185
	Total (UI and OI)	\$15,000	\$37,500	\$47,000	\$67,500	\$119,000
	\$/kW	\$3,000	\$2,500	\$1,880	\$1,350	\$1,190

**Figure D-1. Schematic of 5 to 10 kW Storage System showing Utility and Owner Interconnection and Equipment Costs**

## D.2 250-kW, 500-kW, and 1-MW Storage System Utility and Owner Interconnection and Equipment Costs

<u>Utility Interconnection (UI) Costs</u>			
	250kW	500kW	1MW
1      *** Remote Switch:	\$100,000	\$100,000	\$100,000
2      Communication (Radio):	Incl.	Incl.	Ind.
3      Smart Metering:	\$800	\$800	\$800
4      Transformer Equipment:	\$12,500	\$20,000	\$30,000
Transformer Installation:	\$12,500	\$20,000	\$30,000
<b>Subtotal</b>	<b>\$125,800</b>	<b>\$140,800</b>	<b>\$160,800</b>
	\$/kW	\$503	\$282
		\$161	

<u>Owner Interconnection (OI) Costs</u>			
	250kW	500kW	1MW
5      PCS Equipment:	\$131,500	\$233,500	\$367,000
PCS Installation:	\$33,000	\$58,500	\$92,000
<b>Subtotal</b>	<b>\$164,500</b>	<b>\$292,000</b>	<b>\$459,000</b>
	\$/kW	\$658	\$584
		\$459	
<b>Total (UI and OI) Cost</b>	<b>\$290,300</b>	<b>\$432,800</b>	<b>\$619,800</b>
	\$/kW	\$1,161	\$866
		\$620	

NOTES:

\* Supplier to provide metering connections at 480V

\*\* Should a new ESS be installed to support an existing Renewable Generation System (RGS) then no additional Utility and Owner Interconnection equipment or cost is required. This assumes that the DC voltage output for the ESS is similar to the RGS.


\*\*\* U.G. Distribution System with Pad Mounted Equipment

PCS Power Conditioning System

U.G. UnderGround


**Figure D-2. Schematic of 250-kW, 500-W, and 1-MW Storage System showing Utility and Owner Interconnection and Equipment Costs**

### D.3 2-MW, 2.5-MW, and 3-MW Storage System Utility and Owner Interconnection and Equipment Costs




**Figure D-3. Schematic of 2-MW, 2.5 MW, and 3-MW Storage Systems showing Utility and Owner Interconnection and Equipment Costs**

## D.4 5-MW Storage System Utility and Owner Interconnection and Equipment Costs




**Figure D-4. Schematic of 5-MW Storage System showing Utility and Owner Interconnection and Equipment Costs**

## **D.5 10-MW Storage System Utility and Owner Interconnection and Equipment Costs**




**Figure D-5. Schematic of 10-MW Storage System showing Utility and Owner Interconnection and Equipment Costs**

## D.6 25-MW Storage System Utility and Owner Interconnection and Equipment Costs




**Figure D-6. Schematic of 25-MW Storage System showing Utility and Owner Interconnection and Equipment Costs**

## D.7 50-MW Storage System Utility and Owner Interconnection and Equipment Costs



**Figure D-7. Schematic of 50-MW Storage System showing Utility and Owner Interconnection and Equipment Costs**

## D.8 100-MW Storage System Utility and Owner Interconnection and Equipment Costs



**Figure D-8. Schematic of 100 MW Storage System showing Utility and Owner Interconnection and Equipment Costs**



## APPENDIX E: REGULATIONS

### Appendix E: Table of Contents

<a href="#"><u>E.1</u></a>	<a href="#"><u>Non-Storage Regulatory Proceedings affecting Electricity Storage Opportunities</u></a>	.....E-2
<a href="#"><u>E.2</u></a>	<a href="#"><u>References for Details and Updates on Regulatory Proceedings</u></a>	.....E-2
<a href="#"><u>E.3</u></a>	<a href="#"><u>E.3 Synopsis of Investment Recovery Requests</u></a>	.....E-2
	E.3.1    Synopsis Requests for Investment Recovery through Rate-Base Addition	
	E.3.2    Synopsis of Hearing Record Discussion on the Definition of Electricity Storage	
<a href="#"><u>E.4</u></a>	<a href="#"><u>The Regulatory Environment for Energy Storage</u></a>	.....E-6
<a href="#"><u>E.5</u></a>	<a href="#"><u>Regulatory Database</u></a>	.....E-7

### Appendix E: List of Figures

[Figure E-1. The DOE International Energy Storage Database](#)

### Appendix E: List of Tables

(none)

## REGULATIONS

### **E.1 Non-Storage Regulatory Proceedings Affecting Electricity Storage Opportunities**

Although many state energy offices and PUCs are aware of the general benefits of energy storage, many do not currently have any rulemaking proceedings specifically to encourage the use of electricity storage. Absence of such a proceeding does not mean that opportunities may not exist elsewhere and there could be other proceedings that may be appropriate and possibly important venues for promoting energy storage services. California's regulatory scene is a good example: both storage and non-storage proceedings create opportunities for electricity storage deployment.

In the recent past advocates of the storage industry have used the non-storage proceedings to achieve two goals: first, to develop detailed and nuanced understanding of electrical system operations (e.g., load following) that has traditionally sought only conventional generation options and second, to educate regulators about capabilities, uses, and limitations of storage technologies and identify rules that may inadvertently inhibit energy storage participation.

### **E.2 References for Details and Updates on Regulatory Proceedings**

The regulatory regime at the national and state levels affecting opportunities and pricing for electricity storage systems and services is evolving continuously. Those who want to design their products and services to serve the electrical grid must remain informed of industry developments, a labor-intensive and daunting task. However, there are tools that can help. One option to remain informed is through websites that continuously update regulations and interpret their impact on the industry. Industry associations' websites are good locations for such an update. Another option is a database funded by the DOE for policy updates.<sup>8</sup> Lastly, a separate handbook<sup>9</sup> funded by the DOE and published by SNL has a chapter that reviews the current and recent PUC dockets on electricity storage.

To aid the reader in keeping up with the evolving developments in the regulatory sphere, citations to and brief discussions of the current status of the formal regulatory investigations presently under review in various jurisdictions around the United States are discussed below.

### **E.3 Synopsis of Investment Recovery Requests**

This section provides a review of investment recovery cases, or project approval cases, in which regulated utilities have filed requests related to electricity storage technology investments with public hearings held before state PUCs around the United States. This is not a comprehensive review, in that the cases selected are only those that have had procedural

<sup>8</sup> <https://www.energystorageexchange.org>, last accessed April 29, 2013.

<sup>9</sup> *Evaluating Utility Procured Electric Energy Storage Resources: A Perspective for State Electric Utility Regulators*, Bhatnagar, Dhruv and Loose, Verne, SAND2012-9422, Sandia National laboratories, Albuquerque, NM; November 2012.

debate on electricity storage proposals. Other cases with storage system proposals exist but without any procedural debate addressing electricity storage. This review presents and discusses the issues raised by PUCs, regulated utilities, storage owners, and other interested parties (or interveners) on the electricity storage system proposals and the challenges these issues present to storage system deployment.

### **E.3.1 Synopsis Requests for Investment Recovery Through Rate-Base Addition**

The investment recovery cases summarized below are presented by state. Many of these cases were brought forward as a pilot or demonstration project. Exceptions include the sodium-sulfur battery in Texas, the pumped hydroelectric proposal by PG&E, the Overall Rate Case for 2012 by San Diego Gas and Electric (SDG&E), and the California rulemaking hearing on *AB2514*. Thus, when evaluating these cases, keep in mind the potential differences in approval criteria between full-scale (actual) projects and demonstration projects. While many concerns mentioned in these cases would be relevant to a full-scale deployment request, final decisions often cited the demonstration aspect as an issue to overcome or justify deficiencies in the proposals. Nonetheless, the issues discussed in these cases have been grouped in categories by topic. Commentary and suggestions are provided as to how these issues were dealt with and can be approached in future rate recovery hearings.

#### Texas

**Case:** Presidio, TX, Sodium-sulfur Battery Installation (ETT, 2008)

**Applicant:** *Electric Transmission Texas (ETT)*

**Summary:** A case filed for regulatory approval and transmission cost of service (TCOS) recovery for the installation of a sodium-sulfur (NaS) Battery System (4.8 MW) in Presidio, TX. The purpose of the system is to ensure the reliability of electricity in a remote town that has a long history of outages and to defer new transmission investment.

**Case Status:** *Approved April 2009*

**Project Status:** *In Operation as of April 2010*

#### California

**Case:** San Diego Gas & Electric Overall Rate Case (Smart Grid Section) (CAPUC, 2010b)

**Applicant:** *San Diego Gas and Electric*

**Summary:** A case requesting the establishment of rate recovery for SDG&E starting January 1, 2012. The smart grid section implements new smart grid infrastructure including energy storage to help SDG&E meet the California Renewable Portfolio Standard.

**Case Status:** *In Progress*

**Case:** Pumped Storage Project Study (CAPUC, 2010a)

**Applicant:** *Pacific Gas and Electric*

**Summary:** A request to obtain rate recovery for a feasibility study for a new pumped storage project. The purpose of the project is to allow PG&E to fulfill its perceived need for pumped energy storage by 2020. The expectation of necessity is based on

California's renewable performance standards through 2030 that result in a large amount of variable renewable energy capacity additions to the grid.

**Case Status:** *Denied*: September 2011

**Case:** Compressed Air Energy Storage Proposal (CAPUC, 2009)

**Applicant:** *Pacific Gas and Electric*

**Summary:** A request for Commission approval to provide the balance of matching funds to support a federal grant of \$24.9 million from the DOE for a Smart Grid CAES demonstration project, authorized by the America Recovery and Reinvestment Act of 2009 (ARRA).

**Case Status:** *Approved*: January 2010

**Project Status:** *In the planning and design phase.*

**Case:** Southern California Edison Tehachapi Wind Energy Storage Project (TSP) *as part of California's Smart Grid Rule Making Process* (CAPUC, 2008)

**Applicant:** *Southern California Edison*

**Summary:** Southern California Edison Company (SCE) requested approval to recover up to \$25,978,264 for SCE's cost share in the TSP. This cost share will be matched by \$24,978,264 in Federal stimulus funding awarded by the DOE under ARRA. The project is a lithium-ion battery (8 MW/32MWh).

**Case Status:** *Approved*: July 2010

**Project Status:** *Projected to be in operation in late 2013.*

**Case:** California Rule Making for Energy Storage *AB2514 (CAPUC, 2010c)*

**Summary:** A rulemaking in response to the enactment of legislation *AB2514* (Skinner, 2009). The legislation directs the CA PUC to open a proceeding to determine appropriate targets to procure viable and cost-effective energy storage systems and, by October 1, 2013, to adopt an energy storage system procurement target, if determined to be appropriate. The CA PUC has also opened this proceeding to initiate policy for California utilities to consider the procurement of energy storage systems.

**Case Status:** *In Progress*

## New Jersey

**Case:** Proposal for Four Small Scale/Pilot Demand Response Programs: Energy Storage Program (NJBPU, 2008)

**Applicant:** *Jersey Central Power and Light Company*

**Summary:** Jersey Central Power and Light Company (JCP&L) seeks Commission approval to obtain 3 MW of demand response through an electricity storage program consisting of the deployment of three large battery systems at substations as well as customer-located electricity storage systems.

**Case Status:** Withdrawn

### **E.3.2 Synopsis of Hearing Record Discussion on the Definition of Electricity Storage**

For investment recovery cases to be analyzed properly, the operational definition and goals for electricity storage technologies must be defined. While the technical definition was stated earlier, an operational definition (identifying what specific functional uses it will serve) is lacking. Furthermore, goals for electricity storage have not been articulated.

In the AB2514 Rulemaking hearing, the need to define electricity storage and state its goals (or purpose on the grid) has been identified as a means to expedite future analysis of storage projects. The question is “What the goals are for energy storage in the current grid, in the future, and is there a priority for energy storage towards a specific goal?” (CAPUC, 2010c Doc. 129824). In many of the rate cases studies, questions about the operational definition and goals for electricity storage were a recurring theme.

For example, in the Texas PUC case for the Presidio NaS battery, this issue was of significance. Intervenors, specifically the Texas Industrial Energy Consumers (TIEC) and PUC staff, highlighted the lack of an operational definition of electricity storage, with differing operational classifications for the resource based on their differing perspectives. Arguments were made by the TIEC that electricity storage acts as generation because it delivers electricity to the grid. Thus, it would not be eligible for recovery under the utility’s TCOS tariff. The PUC staff made the argument that the battery would act partially as transmission (when providing reactive power) and partially as distribution, and thus partial recovery was warranted. Lastly, the applicant distribution utility, ETT, made the argument that the battery would act as transmission only and thus deserved cost recovery (ETT, 2008).

This case raised the issue of asset categorization. The argument is that to classify a device as a particular type of asset (generation, transmission, or distribution), its operational definition must be delineated. In this case, the Texas PUC had not determined the operational definition and goals for electricity storage in the Texas electric grid. This issue arose as a major discussion point in the case and may reflect the fact that electricity storage, outside of pumped hydro, is a relatively new concept and there was a lack of an operational definition or clear goals. Note that the Texas electricity system is operated differently from the rest of the United States, as most of the state is not under FERC jurisdiction. Transmission is operated by ERCOT and the rates for transmission and wholesale power are under the jurisdiction of the PUC.<sup>10</sup>

Due to a lack of determination about the use of electricity storage systems going forward, the Texas PUC made a decision based on the specific intended use of the battery system and was careful to state that the decision would not set a precedent for future cases. Because ETT proposed to use the system as transmission, for transmission deferral (and improvement), and provided evidence for its use, “The Commission [found] that ETT’s proposed use of the NaS battery [was] appropriate for a transmission utility because the battery system provides benefits associated with transmission service operations, including voltage control, reactive power, and enhanced reliability” (ETT, 2008 Item #114).

---

<sup>10</sup> ERCOT, the Texas electric grid, is connected to the rest of the United States only at a few points at the borders and the Texas grid is thus an intrastate network. Because it operates as an independent grid, its transmission service and wholesale power rates are free from FERC regulation and fall only under PUC regulation. For more information see: J. Totten, *“Development of Competition in Electricity in Texas”*; Environmental & Energy Law & Policy, vol. 1, p. 10, 2006.

## E.4 The Regulatory Environment for Energy Storage

The present state of the regulated utility environment for electricity storage system deployment was discussed to provide state utility regulators an understanding of how electricity storage systems can be considered an electric grid asset.

Much of the literature about electricity storage systems has sought to portray them as unique, endowed with a wide array of potential benefits; however, it is claimed to be difficult to determine how they can be evaluated and where they are most useful. The one feature that makes these systems unique—their ability to store electricity — also puts them in direct economic competition with load, or more properly, demand response. Not only do storage technologies face competition from every technology on the supply side but also competition from those on the demand side. Thus, the main present challenges to increase deployment have to do with economic comparisons—can electricity storage systems deliver their services at lower cost than competing technologies? Regulators faced with decisions regarding such technology deployments will ultimately make their decisions based on protecting the interests of their constituents: do these technologies help to protect electricity consumers from unnecessary increases in electric rates?

Trends in the industry may help to further the deployment of electricity storage systems. Clearly increased penetration of renewables is one such trend. The increased peakiness of load and declining inertia on the system may also provide opportunities. Furthermore, the relatively small scale of most electricity storage technologies (pumped hydro and CAES excepted) should provide many opportunities for deployment. Thus, a deployment strategy emphasizing the appropriate technology and scale to provide distribution system and near-to-consumer deployment can be cost-effective, and provide grid support indirectly, while at the same time, buy time for further (cost-reducing) technology development of larger electricity storage technologies. The following are among the most important takeaways from this analysis:

- Electric Energy Storage (EES) systems have the potential to play a major role in the current and future electricity grid;
- The value contributed by EES systems is judged by the cost of the next-best alternative means of providing the service;
- EES systems have a unique feature in their ability to store electricity;
- Vertically integrated utilities may have an advantage in their ability to internalize all of the benefits available from electricity storage technologies, although this probably cannot be conclusively demonstrated and may depend on organizational structure and possibly other characteristics. Unfortunately, these benefits are valued at cost (of the next-best alternative) as opposed to values based on revenues derived from market transactions, as they would be in a market environment;
- Asset classification issues can be clarified by viewing the systems from the point of view of the services they perform rather than their inherent engineering characteristics;
- The regulatory environment may make it difficult for utilities to propose such systems; regulatory commissions may need to work with utilities to facilitate deployment;

- Establishing a framework for evaluating EES and their alternatives may help increase deployment by aiding utilities in proposing, and regulatory commissions in evaluating, energy storage systems; and
- Phase-in tariffs or other incentives might provide the necessary financial incentives to induce utilities to invest in ESS in the absence of carbon pricing.

## E.5 Regulatory Database<sup>11</sup>

The DOE has initiated an Internet-based, interactive compendium of electricity storage projects and policies. The effort is relatively recent, but it has already become a credible repository of structured information on projects that can be sorted by location, technology type, size, ownership, and current status. The process of obtaining and maintaining the database is ongoing, and new information is being added to the database regularly. Figure E-1 shows a sample screen from the website.




Figure E-1. The DOE International Energy Storage Database

<sup>11</sup> The DOE International Energy Storage Database, <http://www.energystorageexchange.org/policies>, last accessed April 28, 2013.



## APPENDIX F: TEST FACILITIES

### Appendix F: Table of Contents

<a href="#">F.1</a>	<a href="#">DOE/SNL Energy Storage Test Pad and Energy Storage Analysis Laboratory</a>	.....	F-2
<a href="#">F.2</a>	<a href="#">Energy Storage Performance Test Laboratory, DNV-KEMA</a>	.....	F-5
<a href="#">F.3</a>	<a href="#">EPRI Knoxville Test Facility</a>	.....	F-5
	<a href="#">F.3.1</a>	<a href="#">Used to test storage system prototypes as well as units for field deployment and demonstration</a>	
	<a href="#">F.3.2</a>	<a href="#">Energy Storage Grid Integration – Testing and Modeling</a>	
	<a href="#">F.3.3</a>	<a href="#">Test and Research Services</a>	
<a href="#">F.4</a>	<a href="#">Bonneville Power Authority Energy Storage Test Facility</a>	.....	F-7
<a href="#">F.5</a>	<a href="#">NREL Energy Systems Integration Facility</a>	.....	F-7

### Appendix F: List of Figures

<a href="#">Figure F-1. Energy Storage Test Pad Overview</a>
<a href="#">Figure F-2. Energy Storage System Analysis Laboratory Overview</a>
<a href="#">Figure F-3. Energy Storage Test Pad</a>

### Appendix F: List of Tables

(none)

## TEST FACILITIES

This appendix describes four test facilities in the United States that were operational in 2013 where storage systems can be tested for a variety of grid services. These four facilities were operational in 2013. There are other test facilities that are operated by storage system developers and vendors for their own needs and these are generally not available for use by others. Such test facilities are not included in this appendix.

### **F.1 DOE/SNL Energy Storage Test Pad and Energy Storage Analysis Laboratory**

Commissioned in April 2011, the Energy Storage Test Pad (ESTP) provides trusted third-party testing and validation from the cell level to 1-MW ac electrical energy storage systems. The ESTP can test for both power and energy applications and offers a variety of services including energy time-shift, capacity, load-following, area regulation, voltage support, T&D deferral, demand charge management, and power quality and reliability. The test durations can range from one day to multiple months.

The ESTP can test a maximum capacity of 1-MW, 480 Vac 3-phase systems in grid-connected or stand-alone configuration using resistive and asynchronous loads with extensive data-logging capability. Along with SNL's Energy Storage Analysis Laboratory (ESAL), which tests from cell to module systems, these facilities provide users a venue for testing and validation of energy storage systems. Using a direct grid connection or simulated charge protocol along with detailed diagnostics and analysis, SNL can provide verification of a devices' reliability. In addition to providing testing and validation, system performance analysis, and development of new testing procedures, the ESTP and ESAL provide pre-certification, pre-installation, and verification of electrical energy storage systems.

The ESTP and ESAL are capable of testing energy storage devices to manufacturer's specification using characterization and application-specific cycle testing. These capabilities, supported by SNL's electrochemistry and material sciences experience provide a great depth in fundamental testing at the cell and module level.

The full range of ESTP and ESAL features are summarized in Figure F-1 and Figure F-2. The enclosure in the middle houses the programmable load banks and miscellaneous switchgear, and data-acquisition hardware in housed in the enclosures in the background.

The PV array partially visible in the background of Figure F-3 is part of SNL's Distributed Energy Technologies Laboratory (DETL). The DETL has a large portfolio of distributed and renewable generation technologies, including the 160-kW PV array, micro-turbine, diesel engine, an additional 750 kWh of battery storage, and several types of loads. These resources are interconnected on a 480-V bus to test various microgrid configurations. The ESTP, which can interconnect to the DETL to use the full capabilities of the DETL microgrid, provides the ability to test the storage systems under an even wider range of operating conditions.

For additional information regarding ESTP testing of a storage system: [http://www.sandia.gov/ess/bus\\_test.html](http://www.sandia.gov/ess/bus_test.html).

## Energy Storage Test Pad (ESTP) Overview

### System Capacity/Capability

- 1.5 MVA, 12470 V to 480 VAC 3-phase transformer capable of testing up to 1 MW energy storage systems.
- 2500 amp switchboard with motor operated main breaker.
- Five feeder breakers capable of a 1600 amp single point of EES connection or multiple feed connections through a 1200 amp branch panel.
- 1 MW/1 MVAR loadbank.
- Subcycle metering feeder breakers for transient analysis.

### Testing Capability

- Can test for both power and energy applications including energy time shift, capacity, load following, area regulation, voltage support, T&D deferral, demand charge management, and power quality and reliability.
- Test duration can range from one day to multiple months.
- Scalable from 5 KW to 1 MW, 480 VAC, 3 phase.

### Data Monitoring


- All breakers are equipped with subcycle wave capture meters.
- Can capture voltage, current, KVA, KW, KVAR, PF, frequency, harmonics and transients.
- Provides fiber optic or Ethernet connectivity to monitor parameters (will soon implement National Instruments' LabView software).

### Data Analysis & Reporting

- Evaluate system parameters including but not limited to
  - system efficiency including balance of plant,
  - ramp rate,
  - system operating temperature,
  - performance to specifications,
  - system reliability, and
  - power electronic and balance of plant operation.
- Analyze system performance relative to standards & applications.
- Develop new testing procedures.
- Support developing new energy storage standards.
- Issue reports of findings.

**Figure F-1. Energy Storage Test Pad Overview**

(Sandia National Laboratories)



**Figure F-2. Energy Storage System Analysis Laboratory Overview**  
(Sandia National Laboratories)



**Figure F-3. Energy Storage Test Pad at Sandia National Laboratories, Albuquerque, NM**

## F.2 Energy Storage Performance Test Laboratory, DNV-KEMA

The Energy Storage Performance Test Laboratory (ESPTL) is owned by DNV-KEMA and was commissioned in 2010. It can test energy storage systems at various loading conditions, according to industry standards or to specific customer requirements. Its capabilities include:

- Maximum Power: 2 MW.
- Output Voltage: 100 V, 240 V, 480 V, 600 V, 830 V; three or single phase.
- Maximum Output Current: 3,000 A at any voltage tap.
- Charge/Discharge Source: Synchronized with local utility network.
- Test Area: Outdoor 100 ft. × 60 ft.; indoor 30 ft. × 20 ft.
- Through this test circuit, ESPTL can connect a storage system to the utility electric grid, which can be used as both a power source in the charge mode and a load in the discharge mode. Providing real-life test conditions assures the end user that the storage system has been evaluated in the most realistic methods possible.

The ESPTL's control and instrumentation system can be programmed to execute various charge and discharge cycles and levels, measure and record several ac/dc voltages and currents simultaneously, and contact functions and temperatures. This system has a load-modeling tool to validate a storage system's response to simulated utility services and use cases, including market-based regulation through power dispatch, ramp rate regulation for distributed wind and solar resources, and critical peak price response. The facility can also test interconnection compatibility according to IEEE 1547.

The control and instrumentation system can also be interconnected to the actual grid through live signal feeds from PJM Interconnect, available at DNV-KEMA-Powertest. This enables real-life test conditions to be replicated in the test environment to evaluate functions like frequency and ramp rate.

For additional information on ESPTL, or to reserve it for testing a storage system go to: <http://www.dnvkema.com/>.

## F.3 EPRI Knoxville Test Facility

- EPRI'S Knoxville, TN, test facility was prepared for expanded Distributed Energy Storage System (DESS) testing
- Has outdoor bay and anti-islanding test features
- High-resolution data-acquisition capability
- Environmental chambers if needed
- 1-MW total single-size capability

**F.3.1 Used to Test Storage System Prototypes as Well as Units for Field Deployment and Demonstration****F.3.2 Energy Storage Grid Integration – Testing and Modeling**

- Obtain real charge/discharge data from DESS evaluation in laboratory
- Several DESS evaluations planned
- Develop open DESS models based on gathered experimental data

**F.3.3 Test and Research Services**

- Energy Efficiency and Demand Response: Develop test protocols, test energy-saving devices, and test lighting technologies or conduct field demonstrations of emerging technologies.
- Distributed Resources: Test inter-connection hardware as well as test and evaluate energy-storage technologies, from batteries to superconductors.
- System Compatibility: Evaluate the capabilities of devices in electrical environments, provide design expertise, and conduct voltage-sag testing with the industry-leading Porto SagSM portable voltage-sag test equipment.
- Intelligent Electronic Device Testing: Test revenue meters, protective relays and controls for distribution, and transmission equipment. Also perform data integration, system compatibility, accuracy, and communication testing.
- Electromagnetic Compatibility (EMC) Testing: Perform emissions tests, evaluate compatibility, provide field audits, and provide design assistance.
- Custom Metering and Monitoring: Design and test custom metering systems measuring energy usage, power quality, electromagnetic emissions and environmental conditions. Provide data integration and analysis, using tools such as EPRI's PQView software.
- Line Design and Performance: Conduct simulation of line voltage, geometry and phase spacing, as well as hybrid transmission studies.
- Insulator Performance: Conduct simulations of insulator contamination and contamination flashover testing.
- Insulator Aging: Perform accelerated aging of insulators and line components, including analysis in a variety of service environments.
- Lightning Performance: Simulate lightning and switching over-voltages and impulse surges for low-voltage, medium-voltage and high-voltage equipment.
- Corona: Investigate corona phenomena, including measurement of corona loss, audible noise, and radio and television interference. Line compaction also studied.
- Manhole Design and Performance: Simulate manhole events and test mitigation methods.
- High-voltage and Medium-voltage Inspections and Failure Analysis: Inspect transmission and distribution lines and substation components, including infrared, corona, splice resistance, and electric and magnetic fields.

Additional information can be found at: <http://www.epri.com/Pages/Default.aspx>.

## **F.4 Bonneville Power Authority Energy Storage Test Facility**

The Bonneville Power Authority (BPA) Energy Storage Test Facility (ESTF), located in Vancouver, WA, provides a suitable energy storage testing facility for various energy storage technologies. Major features that establish the BPA Laboratory ESTF as a unique resource suited for testing energy storage technologies include:

- Single-phase power frequency testing (60 Hz), up to 1,100,000 V
- Lightning and switching impulse up to 5,600,000 V
- Existing (upgradable) dedicated 5-MVA interconnection to the Ross Switch Yard
- Supply voltage, 13.8 kV, adjustable +/- 15% under load
- Three-phase voltage and current instrumentation in place
- Existing adjacent railroad service
- Exceptional road access for large loads
- Lots of expansion space on paved, fenced area
- Accessible interconnection to the BPA Dittmer Control Center
- For more information on this facility: <http://www.bpa.gov/Pages/home.aspx>

## **F.5 NREL Energy Systems Integration Facility**

National Renewable Energy Laboratory's (NREL) Energy Systems Integration Facility (ESIF) focuses on the integration of energy storage systems (both stationary and vehicle-mounted) and the interconnection with the utility grid. Although the focus of the facility is on battery technologies, it will also host ultra-capacitors and other electrical energy storage technologies. Facility capabilities include hardware-in-the-loop at megawatt-scale power, a high-performance data computing center, SCADA, and data analysis and visualization with electricity laboratories, thermal laboratories, and fuel laboratories<sup>12</sup>.

For more information: <http://www.nrel.gov/esi/esif.html>.

---

<sup>12</sup> <http://www.nrel.gov/esi/esif.html>, last accessed March 11, 2013.



## APPENDIX G: NOTEWORTHY PROJECTS

### Appendix G: Table of Contents

<a href="#"><u>G.1 Noteworthy Historical Electricity Storage Projects</u></a> .....	G-2
<a href="#"><u>G.1.1 Crescent Electric Membership Cooperative (now EnergyUnited)</u></a> .....	G-2
<a href="#"><u>G.1.2 Berliner Kraft- und Licht (BEWAG) Battery System</u></a> .....	G-2
<a href="#"><u>G.1.3 Southern California Edison</u></a> .....	G-2
<a href="#"><u>G.1.4 Puerto Rico Electric Power Authority (PREPA)</u></a> .....	G-3
<a href="#"><u>G.1.5 Oglethorpe Power Company – PQ2000 installation</u></a> .....	G-3
<a href="#"><u>G.1.6 Metlakatla Power and Light (MP&amp;L)</u></a> .....	G-4
<a href="#"><u>G.1.7 Golden Valley Electric Association (GVEA)</u></a> .....	G-4
<a href="#"><u>G.1.8 ARRA-Funded Electricity Storage Projects</u></a> .....	G-5
<a href="#"><u>G.1.9 The DOE International Energy Storage Database</u></a> .....	G-10

### Appendix G: List of Figures

[Figure G-1. Screenshot of DOE Energy Storage Database](#)

### Appendix G: List of Tables

[Table G-1. ARRA Energy Storage Demonstrations \(T53\)](#)

## G.1 Noteworthy Historical Electricity Storage Projects

Electricity storage projects from the 1980s provided valuable operating experience in utility service and influenced the design and operation of later projects. The list below is a chronological sequence of significant projects, mostly in the United States, with a brief notation of the role they played in the understanding of electricity storage in utility applications.

### G.1.1 Crescent Electric Membership Cooperative (now EnergyUnited)

- Grid Service: Peak shaving
- Project Location: Statesville, NC
- Commissioned: 1987
- Power/Energy: 500 kW/500 kWh
- Battery Type: Lead-acid, flooded cell, by GNB Industrial Battery (now Exide)

**NOTE:** This was the first application of electricity storage in the United States for peak shaving in the grid. The battery operated from 1987 to 2002, well past its warranty of 8 years and 2,000 cycle projected life. The long life of the battery could be attributed to its robust construction, regular maintenance, and operation within its design envelope.

### G.1.2 Berliner Kraft- und Licht (BEWAG) Battery System

- Grid Service: Frequency Regulation and Spinning Reserve
- Project Location: (Then West) Berlin, Germany
- Commissioned: 1987
- Power/Energy: 8.5 MW in 60 minutes of frequency regulation; 17 MW for 20 minutes of spinning reserve/14 MWh
- Battery Type: Lead-acid, flooded cell, by Hagen

NOTE: This was the largest battery project in the world at that time and provided essential support to the West Berlin electric grid when East and West Berlin were still divided and the West Berlin grid was an electric island. This project also represented a departure from the traditional peak-shaving application concept and successfully demonstrated the feasibility of stacked services – frequency regulation and spinning reserve – that was a critical reliability requirement for the grid due to West Berlin’s geographic and electrical isolation. The stacked services were replicated later in the Puerto Rico Electric Power Authority (PREPA) battery storage project that was commissioned in 1994. The BEWAG battery was decommissioned in 1995 after it reached the end of its design life.

### G.1.3 Southern California Edison

- Grid Services: Demonstrate load-leveling, transmission line stability, T&D deferral, local VAR control, and local area black start
- Project Location: Chino, CA
- Commissioned: 1988
- Power/Energy: 10 MW/40 MWh
- Battery Type: Lead-acid, flooded cell, by Exide

NOTE: The Chino project was an early demonstration of a large battery for multiple applications in the U.S. grid. The project was jointly sponsored by EPRI, DOE, and the International Lead Zinc Research Organization (ILZRO), supported by SCE as the host utility. This landmark project provided valuable experience with maintaining large banks of flooded lead-acid batteries and high-voltage battery strings. The lessons learned in this project influenced later battery projects and also spurred the development of smaller modular storage systems versus large field-assembled battery systems. The Chino project was also the largest utility battery system in the world until the PREPA BESS and later the Fairbanks battery projects were commissioned in 1994 and 2003, respectively. The Chino battery was decommissioned in 1997.

#### **G.1.4 Puerto Rico Electric Power Authority (PREPA)**

- Grid Services: Frequency control and spinning reserve
- Project Location: Sabana Llana substation, San Juan, Puerto Rico
- Commissioned: 1994
- Power/Energy: 20 MW/14 MWh
- Battery Type: Lead-acid, flooded cell, by C&D Battery

NOTE: Like the BEWAG battery described earlier, the PREPA BESS also provided frequency regulation and spinning reserve service to the island grid of Puerto Rico. This battery system demonstrated that the faster response of a battery system is a valuable feature for the grid, especially an island grid and is superior to CTs for frequency regulation and spinning reserve duty. Operational issues that surfaced soon after the battery was commissioned showed that frequency regulation duty requires far more cycling of the battery than originally estimated in the design and engineering phase of the project. The battery was decommissioned in 1999.

#### **G.1.5 Oglethorpe Power Company – PQ2000 installation**

- Grid Services: Power quality, UPS on customer-side-of-meter
- Project Location: Brockway Standard Lithography Plant, Homerville, GA
- Commissioned: 1996
- Power/Energy: 2 MW/55 kWh (10-second discharge)
- Battery Type: Lead-Acid, Low-Maintenance, truck-starting batteries by Delco

NOTE: The Oglethorpe demonstration of the PQ2000 represented the first use of a factory-assembled, transportable battery system – compared to the site-assembled battery projects that preceded it. Its successor versions are currently manufactured and marketed by S&C Electric under the Pure Wave trade name. The design was originated by the AC Battery<sup>13</sup> and first introduced as the PM250 by Omnion Power Engineering and was subsequently acquired by S&C Electric in 1999.

---

<sup>13</sup> Patent Number 4,894,764, “Modular AC Output Battery Load Levelling System,” issued to John F. Meyer and David G. Porter, January 16, 1990.

**G.1.6 Metlakatla Power and Light (MP&L)**

- Application: Voltage regulation to displace diesel generation
- Project Location: Metlakatla, AK
- Commissioned: 1997
- Power/Energy: 1 MW/1.4 MWh
- Battery Type: Valve-regulated lead-acid (VRLA) Absolyte IIP, by GNB Industrial Battery (Now Exide)

NOTE: The MP&L battery was installed to counter the effects of large voltage swings in the Annette Island grid caused by the intermittent operation of large 400 and 600 hp motors in a lumber mill on the island. The battery displaced a 3.3-MW diesel that was operated at partial load to mitigate the voltage swings. The diesel supplemented two hydro units that are the main generation source for the island. The battery was very well managed and outlived its warranty of 8 years. It was replaced in 2008 after 12 years of service.

**G.1.7 Golden Valley Electric Association (GVEA)**

- Application: VAR Support, spinning reserve, power system stabilization
- Project Location: Fairbanks, AK
- Commissioned: 2003
- Power/Energy: 27 MW/14.6 MWh
- Battery Type: Nickel/cadmium, by Saft

NOTE: The Fairbanks battery is currently the largest in the United States and the only one using NiCd batteries. This battery storage system is not only the largest, but also provides a real-world example of the successful stacking of several grid services, including voltage support, spinning reserve, and reserve power for Fairbanks in the event of an outage on the transmission line connecting Fairbanks to Anchorage.

### G.1.8 ARRA-Funded Electricity Storage Projects

In 2009, the DOE launched a significant electricity storage program with funding from ARRA. ARRA provided \$185 million in federal matching funds to support storage projects with a total value of \$772 million. These projects generated 537 MW of new storage to be added to the grid. These storage projects and their description are listed in Table G-1.

**Table G-1. ARRA Energy Storage Demonstrations (T53)**

ARRA ENERGY STORAGE PROJECTS				
RECIPIENT	PROJECT TITLE	PROJECT DESCRIPTION	COMMISSIONED DATE (Plan or Actual)	STATUS NARRATIVE (As of February 2013)
SustainX	Demonstration of Isothermal Compressed Air Energy Storage to Support Renewable Energy Production	1.5MW/1MWh non-grid-tied aboveground isothermal compressed air energy storage (CAES) pilot system	Nov 2013	Fabricating/assembling full-scale pilot ICAES system for 9 month pilot test (non-grid-tied).
City of Painesville	Painesville Municipal Power Vanadium Redox Battery Demonstration Program	1 MW/8MWh vanadium redox flow battery for load following for Painesville Municipal Power station	Late 2013	Essentially all R&D has been completed. Battery building construction complete. Ready to gear up for production of flow battery stacks.
Aquion Energy	Demonstration of Sodium-ion Battery for Grid-level Applications	Demonstrated Aquion Energy's 10-15 kWh prototype sodium ion battery at Aquion's facility (non-grid tied)	NA	Project Completed
New York State Electric & Gas Corp.	Advanced CAES Demonstration 150 MW Plant Using an Existing Salt Cavern	150MW compressed air energy storage system for bulk energy storage. Project has been terminated.	NA	Recipient requested termination after phase 1 feasibility study. Termination was effective Nov 2012. <a href="https://www.smartgrid.gov/document/seneca_compressed_air_energy_storage_caes_project">https://www.smartgrid.gov/document/seneca_compressed_air_energy_storage_caes_project</a>
Amber Kinetics	Demonstration of a Flywheel System for Low Cost, Bulk Energy Storage	20kW (2 x 10kW) flywheels storing 80kWh energy in a pilot demo for demand management in SDG&E territory	January 2014	Beginning phase 2 scale-up for grid-tied demo with commercial partner/customer. <a href="http://www.smartgrid.gov/sites/default/files/pdfs/tpr_final_phase1_amber_kinetics.pdf">http://www.smartgrid.gov/sites/default/files/pdfs/tpr_final_phase1_amber_kinetics.pdf</a>

ARRA ENERGY STORAGE PROJECTS				
RECIPIENT	PROJECT TITLE	PROJECT DESCRIPTION	COMMISSIONED DATE (Plan or Actual)	STATUS NARRATIVE (As of February 2013)
Public Service Company of New Mexico (PNM)	PV Plus Battery for Simultaneous Voltage Smoothing and Peak Shifting	750kW/2.8MWh advanced lead acid battery for voltage smoothing and PV firming on PNM distribution feeder.	Sept 2011	1.5 years into a 2-year demo. Executing various test plans for smoothing, shaving, and firming. Also working on predictive models for cloud cover. <a href="http://www.smartgrid.gov/sites/default/files/pdfs/PNMTPR_rev2_09_24_12.pdf">http://www.smartgrid.gov/sites/default/files/pdfs/PNMTPR_rev2_09_24_12.pdf</a>
Detroit Edison Company	Detroit Edison's Advanced Implementation of Community Energy Storage Systems for Grid Support	S&C Electric, 18 CES units DowKokam Li-ion batteries, 2 CES units secondary use EV batteries Li-ion Bosch Batteries for distribution side service providing aux. power for increase service reliability and quality.	June 2013	5 CES units are currently being installed.
Hazle Spindle LLC (Beacon Power)	Beacon Power 20MW Flywheel Frequency Regulation Plant	20MW (200 x 100kW) flywheels for frequency regulation in PJM	Sept 2011	Site clearing has been completed. Rough grading well underway. Majority of equipment and material orders have been placed. GC has been selected for site construction.
Primus Power Corporation	Wind Firming EnergyFarm™	25MW/75MWh zinc bromine flow battery system for wind firming in Modesto Irrigation District	August 2014	Design has been frozen. Beginning to fabricate pilot stacks for pilot testing and 3rd party validation testing. Once complete, design may be refined using knowledge gained. Full-scale production of demo stacks will follow.
Raytheon Ktech	Flow Battery Solution for Smart Grid Renewable Energy Applications	250kW/1MWh EnerVault Iron Chromium flow battery for firming PV	October 2013	Detailed design for a 250 kW system is complete and system components procurements are under way.
Seeo Inc.	Solid State Batteries for Grid-Scale Energy Storage	~25kWhr Seeo prototype in conjunction with solar PV	June 2013	Prototype pack design is complete and the pack manufacture is in process.
Pacific Gas & Electric	Advanced Underground CAES Demonstration Project Using a Saline Porous Rock Formation as the Storage Reservoir	300MW CAES	March 2021	Candidate sites were selected from counties east of San Francisco and core well samples are being taken to select optimum site for pressure testing.

ARRA ENERGY STORAGE PROJECTS				
RECIPIENT	PROJECT TITLE	PROJECT DESCRIPTION	COMMISSIONED DATE (Plan or Actual)	STATUS NARRATIVE (As of February 2013)
East Penn Manufacturing	Grid-Scale Energy Storage Demonstration for Ancillary Services Using the UltraBattery™ Technology	3MW East Penn UltraBattery (ultra-capacitor/lead-acid) providing frequency regulation services	June 2012	The energy storage system initiated operations in June 2012 providing frequency regulation services to the grid of PJM interconnection.
Premium Power	Distributed Energy Storage System Demonstration	1 MW Premium Power zinc bromine flow battery	2014/2015	Demonstration in conjunction with National Grid in planning.
Southern California Edison	Tehachapi Wind Energy Storage Project	8MW (32 MWh) Li-ion battery at substation within Tehachapi Wind Resource Area for voltage support, wind integration, frequency regulation, arbitrage	Early 2014	The majority of the construction activities are complete. Review and selection of battery provider in process.
Duke Energy Business Services	Notrees Wind Storage	36MW/24MWh Xtreme Power advanced lead acid battery for Wind Farm storage for frequency regulation as the targeted service.	January 2013	Operational. Gathering data.
Batelle Memorial Institute	Pacific Northwest Smart Grid Demonstration Project	42kW/170kWh Demand Energy Networks advanced lead acid batteries (4 x 10kW/40kWh units + 2 x 1kW/5kWh units) for peak load management, demand response, and renewables firming	March 2012	Operational
		125kW/125kWh ZBB zinc bromine flow battery peak load, demand response, and renewables firming	March 2013	Operational
		5MW/1.25MWh EnerDel Li-ion battery for high-reliability zone/microgrid support.	March 2013	To be located in Salem, OR
Long Island Power Authority	Long Island Smart Energy Corridor	12 sealed AGM lead acid batteries planned for demonstration of storage in the residential demonstration model at Farmingdale; 60 Amp, 720W, 12V.	July 2013	AGM-absorbed glass mat
Kansas City Power & Light Co	KCP&L Green Impact Zone Smart Grid Demonstration	1MW/1MWh (13.2kV) Superior Lithium Polymer Battery Storage (SLPB) system, grid-connected	June 2012	Operational

ARRA ENERGY STORAGE PROJECTS				
RECIPIENT	PROJECT TITLE	PROJECT DESCRIPTION	COMMISSIONED DATE (Plan or Actual)	STATUS NARRATIVE (As of February 2013)
AEP Ohio	gridSMART <sup>SM</sup> Demonstration Project	100kW/100kWh (4 units @ 25kW each) S&C Electric PureWave Li-ion batteries for Community Energy Storage	TBD	15 of the 80 planned units were installed and subsequently removed from service and returned to the vendor for troubleshooting due to technical issues.
Consolidated Edison Company of NY	Secure Interoperable Open Smart Grid Demonstration	Battery storage at 7 locations, lithium phosphate, capacity range is 25-200kWh, 40-500kW maximum output	May 2013	Three units have been installed. PI indicates that remaining four installations may be dropped. <a href="http://www.smartgrid.gov/sites/default/files/OE0000197-Con-Edison-Technology-Performance-Report-July%205%202012-Revision_1.pdf">http://www.smartgrid.gov/sites/default/files/OE0000197-Con-Edison-Technology-Performance-Report-July%205%202012-Revision_1.pdf</a> .
Center for Commercialization of Electric Technologies	Technology Solutions for Wind Integration in ERCOT	1MW/1MWh Xtreme/Samsung Li-ion battery for wind integration with Texas Tech and the South Plains Electric Coop	Dec 2013	Purchase order issued for battery.
Southern California Edison	Irvine Smart Grid Demonstration	17 homes with Residential Energy Storage Units (4kW/10kWh LG Chem Li-ion battery)	July 2013	LG batteries are automotive grade.
		9 homes will share a community energy storage unit (25kW/50kWh battery)	July 2013	
		100kW/90kWh battery supporting a grid-connected PV charging station for 20 cars.	July 2013	
University of Hawaii	Managing Distribution System Resources for Improved Service Quality and Reliability, Transmission Congestion Relief, and Grid Support Functions	1MW/1MWh A123 Li-ion battery installed at Wailea substation	April 2013	Supports reactive power and peak demand management.
University of Nevada Las Vegas (UNLV)	Integrated PV, Battery, Storage, and Customer Products with Advanced Metering	9 units - Silent Power On Demand Energy Appliances (9.2 kW/8.8kWh each Saft Li-ion batteries) for peak shaving and PV integration sized for individual homes.	June 2015	One unit installed as of February 2013, the remainder to be installed by June 2015.

## Appendix G: Noteworthy Projects

ARRA ENERGY STORAGE PROJECTS				
RECIPIENT	PROJECT TITLE	PROJECT DESCRIPTION	COMMISSIONED DATE (Plan or Actual)	STATUS NARRATIVE (As of February 2013)
ATK Launch Systems	Alliant Techsystems (ATK) Launch Systems Demonstration Project	300kW/1200kWh EaglePicher Technologies AGM Lead Acid Battery	June 2015	For peak shaving and integration of 100kW wind farm and 100 kW waste heat generation unit.
Consolidated Edison Co.	Interoperability of Demand Response Resources	Ice Storage Plant (10,000 cooling tons of ice)	July 2013	Goal is to reduce peak load by approximately 1000kW.
Allegheny Power	West Virginia Super Circuit	24kW/50 kWh Li-ion batteries (3 units @ 8 kW each) with target discharge duration of 2 hrs	Oct 2013	On a microgrid that includes 40kW of solar and 160kW natural gas backup generator.
Illinois Institute of Technology	IIT Perfect Power Demonstration	250kW/500kWh ZBB zinc bromine flow battery	January 2013	Unit was installed at Illinois Institute of Technology (IIT) Galvin Institute's "Perfect Power" campus micro grid project.

### G.1.9 The DOE International Energy Storage Database <sup>14</sup>

The DOE has initiated an Internet-based, interactive compendium of energy storage projects and policies. The effort is relatively recent, but it has already become a credible repository of structured information on projects that can be sorted by location, technology type, size, ownership, and current status. The process of obtaining and maintaining the database is ongoing, and new information is being added to the database regularly. Figure G-1 shows a sample screen from the website.




Figure G-1. Screenshot of DOE Energy Storage Database

<sup>14</sup> <http://www.energystorageexchange.org/projects>, last accessed April 28, 2013.

## APPENDIX H: Life-Cycle Cost Analysis Figures for Mature Energy Storage Technologies

### Appendix H: Table of Contents

H.1	Pumped Hydro Life-Cycle Cost Analysis .....	H-4
H.2	CAES Life-Cycle Cost Analysis.....	H-6
H.3	Sodium-sulfur Batteries Life-Cycle Cost Analysis.....	H-8
H.4	Sodium-nickel-chloride Batteries Life-Cycle Cost Analysis.....	H-11
H.5	Vanadium Redox Batteries Life-Cycle Cost Analysis .....	H-13
H.6	Iron-chromium Batteries Life-Cycle Cost Analysis.....	H-15
H.7	Zinc-bromine Batteries Life-Cycle Cost Analysis .....	H-17
H.8	Zinc-air Batteries Life-Cycle Cost Analysis .....	H-21
H.9	Lead-acid Batteries Life-Cycle Cost Analysis .....	H-23
H.10	Flywheel Storage Life-Cycle Cost Metrics .....	H-31
H.11	Li-ion Batteries Life-Cycle Cost Analysis .....	H-33

### Appendix H: List of Figures

- Figure H-1. Present Value Installed Cost in \$/kW for Pumped Hydro
- Figure H-2. Levelized Cost of Energy in \$/MWh for Pumped Hydro
- Figure H-3. Levelized Cost of Capacity in \$/kW-yr for Pumped Hydro
- Figure H-4. Present Value Installed Cost for Different Sizes of CAES Systems
- Figure H-5. Levelized Costs of Energy in \$/MWh for Different Sizes of CAES Systems
- Figure H-6. Levelized Costs of Capacity in \$/kW-yr for Different Sizes of CAES Systems
- Figure H-7. Present Value Installed Cost for Different Sodium-sulfur Systems
- Figure H-8. Levelized Cost of Energy in \$/MWh for Different Sodium-sulfur Systems
- Figure H-9. Levelized Costs of Capacity \$/kW-yr for Different Sodium-sulfur Systems
- Figure H-10. Present Value Installed Cost for Different Sodium-nickel-chloride Batteries
- Figure H-11. Levelized Cost of Energy in \$/MWh for Different Sodium-nickel-chloride Batteries
- Figure H-12. Levelized Cost of Capacity in \$/kW-yr for Different Sodium-nickel-chloride Batteries
- Figure H-13. Present Value Installed Cost for Different Vanadium Redox Systems
- Figure H-14. Levelized Cost of Energy in \$/MWh for Different Vanadium Redox Systems
- Figure H-15. Levelized Cost of Capacity in \$/kW-yr for Different Vanadium Redox Systems
- Figure H-16. Present Value Installed Cost for Different Iron-chromium Systems
- Figure H-17. Levelized Cost of Energy in \$/MWh for Different Iron-chromium Systems
- Figure H-18. Levelized Cost of Capacity in \$/kW-yr for Different Iron-chromium Systems
- Figure H-19. Present Value Installed Cost for Zinc-bromine Systems in Bulk and Utility Transmission and Distribution Service
- Figure H-20. Levelized Cost of Energy in \$/MWh for Zinc-bromine Systems in Bulk and Utility Transmission and Distribution Service
- Figure H-21. Levelized Cost of Capacity in \$/kW-yr for Zinc-bromine Systems in Bulk and Utility Transmission and Distribution Service
- Figure H-22. Present Value Installed Cost for Zinc-bromine Systems in Commercial and Industrial and Residential Applications

## Appendix H: Life-Cycle Cost Analysis Figures for Mature Energy Storage Technologies

Figure H-23. Levelized Cost of Energy in \$/MWh for Zinc-bromine Systems in Commercial and Industrial and Residential Applications

Figure H-24. Levelized Cost of Capacity in \$/kW-yr for Zinc-bromine Systems in Commercial and Industrial and Residential Applications

Figure H-25. Present Value Installed Cost for Zinc-air Systems in Bulk Services

Figure H-26. Levelized Cost of Energy in \$/MWh for Zinc-air Systems in Bulk Services

Figure H-27. Levelized Cost of Capacity in \$/kW-yr for Zinc-air Systems in Bulk Services

Figure H-28. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Systems Bulk Service Applications

Figure H-29. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Systems in Bulk Service Applications

Figure H-30. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Systems in Bulk Service Applications

Figure H-31. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Systems in Frequency Regulation

Figure H-32. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Systems in Frequency Regulation

Figure H-33. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Frequency Regulation

Figure H-34. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Transmission and Distribution Applications

Figure H-35. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Transmission and Distribution Applications

Figure H-36. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Transmission and Distribution Applications

Figure H-37. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Distributed Energy Storage System Applications

Figure H-38. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Distributed Energy Storage System Applications

Figure H-39. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Distributed Energy Storage System Applications

Figure H-40. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Commercial and Industrial Applications

Figure H-41. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Commercial and Industrial Applications

Figure H-42. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Commercial and Industrial Applications

Figure H-43. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Flywheel Systems

Figure H-44. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Flywheel Systems

Figure H-45. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Flywheel Systems

Figure H-46. Present Value Installed Cost in \$/kW for Li-ion Batteries in Frequency Regulation and Renewable Integration Applications

Figure H-47. LCOE in \$/MWh for Li-ion Batteries in Frequency Regulation and Renewable Integration Applications

Figure H-48. Levelized \$/kW-yr for Li-ion Batteries in Frequency Regulation and Renewable Integration Applications

Figure H-49. Present Value Installed Cost in \$/kW for Li-ion Batteries in Transmission and Distribution

## Appendix H: Life-Cycle Cost Analysis Figures for Mature Energy Storage Technologies

### Applications

- Figure H-50. LCOE in \$/MWh for Li-ion Batteries in Transmission and Distribution Applications
- Figure H-51. Levelized \$/kW-yr for Li-ion Batteries in Transmission and Distribution Applications
- Figure H-52. Present Value Installed Cost in \$/kW for Li-ion Batteries in Distribute Energy Storage System Applications
- Figure H-53. LCOE in \$/MWh for Li-ion Batteries in Distribute Energy Storage System Applications
- Figure H-54. Levelized \$/kW-yr for Li-ion Batteries in Distribute Energy Storage System Applications
- Figure H-55. Present Value Installed Cost in \$/kW for Li-ion Batteries in Commercial and Industrial Applications
- Figure H-56. LCOE in \$/MWh for Li-ion Batteries in Commercial and Industrial Applications
- Figure H-57. Levelized \$/kW-yr for Li-ion Batteries in Commercial and Industrial Applications

## Appendix H: List of Tables

None

## Appendix H: Life-Cycle Cost Analysis Figures for Mature Energy Storage Technologies

### H.1 Pumped Hydro Life-Cycle Cost Analysis

Figure H-1, Figure H-2, and Figure H-3 summarize present value of installed cost, the LCOE in \$/MWh, and the leveled cost of capacity in \$/kW-yr for pumped hydro facilities. These are based on round-trip efficiency of 81%, 365 cycles per year, and plant life of 60 years. Project-specific parameters with a more detailed economic dispatch would have different life-cycle estimates. Other assumptions and notes are shown in the detailed cost and performance tables for pumped hydro in Appendix B.




Figure H-1. Present Value Installed Cost in \$/kW for Pumped Hydro






Figure H-2. Levelized Cost of Energy in \$/MWh for Pumped Hydro



**Figure H-3. Levelized Cost of Capacity in \$/kW-yr for Pumped Hydro**

## H.2 CAES Life-Cycle Cost Analysis

Figure H-4, Figure H-5, and Figure H-6 summarize present value of installed cost, the LCOE in \$/MWh, and the levelized cost of capacity in \$/kW-yr for CAES plants. These estimates are based on heat rate and energy ratio and O&M data from the data sheets for CAES in Appendix B. A simple dispatch was assumed: 365 cycles per year and plant life of 30 years. Investor ownership financial assumptions are detailed in Appendix B. Natural gas cost of \$3 one million Btu (MMBtu); off peak power costs of \$30 megawatt hour (MWh). Project-specific parameters with a more detailed economic dispatch would have different life-cycle estimates.



**Figure H-4. Present Value Installed Cost for Different Sizes of CAES Systems**

DOE/EPRI Electricity Storage Handbook in Collaboration with NRECA  
Appendix H: Life-Cycle Cost Analysis Figures for Mature Energy Storage Technologies




Figure H-5. Levelized Costs of Energy in \$/MWh for Different Sizes of CAES Systems





Figure H-6. Levelized Costs of Capacity in \$/kW-yr for Different Sizes of CAES Systems


## H.3 Sodium-sulfur Batteries Life-Cycle Cost Analysis

Figure H-7, Figure H-8, and H-9 summarize present value of installed cost, the LCOE in \$/MWh, and the levelized cost of capacity in \$/kW-yr for NaS plants. These estimates are based on capital and O&M data from the NaS data sheets in Appendix B. A simple dispatch was assumed: investor-owned utility (**IOU**) financials and 365 cycles per year for 15 years. Battery replacement costs for longer service lives were not assumed over and above the O&M estimates shown in Appendix B. Key financial assumptions are also shown in Appendix B.


DOE/EPRI Electricity Storage Handbook in Collaboration with NRECA  
Appendix H: Life-Cycle Cost Analysis Figures for Mature Energy Storage Technologies



**Figure H-7. Present Value Installed Cost for Different Sodium-sulfur Systems**




**Figure H-8. Levelized Cost of Energy in \$/MWh for Different Sodium-sulfur Systems**





**Figure H-9. Levelized Costs of Capacity \$/kW-yr for Different Sodium-sulfur Systems**

## H.4 Sodium-nickel-chloride Batteries Life-Cycle Cost Analysis

Life-cycle costs of several selected  $\text{NaNiCl}_2$  systems are illustrated in Figure H-10, Figure H-11, and Figure H-12. The estimates are based on capital and O&M data from the  $\text{NaNiCl}_2$  data sheets shown in Appendix B. A simple dispatch was assumed with ~~investor-owned utility~~ IOU financials and 365 cycles per year for 15 years. Generally, key assumptions are ~~investor-owned utility~~ ownership with 365 cycles peak-shaving annually for 15 years. Cost metrics for these systems vary by vendor and related assumptions on battery replacement costs of 8 or 15 years. See Appendix B for assumptions on battery replacement costs.




**Figure H-10. Present Value Installed Cost for Different Sodium-nickel-chloride Batteries**  
(The S designation under each bar is a vendor code that masks the identity of the vendor.)

**Figure H-11. Levelized Cost of Energy****in \$/MWh for Different Sodium-nickel-chloride Batteries***(The S designation under each bar is a vendor code that masks the identity of the vendor.)***Figure H-12. Levelized Cost of Capacity****in \$/kW-yr for Different Sodium-nickel-chloride Batteries***(The S designation under each bar is a vendor code that masks the identity of the vendor.)*


## H.5 Vanadium Redox Batteries Life-Cycle Cost Analysis

Life-cycle cost analysis of several selected systems is illustrated in Figure H-13, Figure H-14, and Figure H-15. These estimates are based on capital and O&M data from the Vanadium Redox data sheets in Appendix B. A simple dispatch was assumed: ~~an investor-owned utility~~ IOU financials with 365 cycles per year for 15 years. Generally, key assumptions are IOU ownership, with 365 cycles peak-shaving annually for 15 years. Periodic stack replacement costs are assumed every 8 years and range from \$615/kW to \$746/kW. See Appendix B for discussion of life-cycle cost methods.




**Figure H-13. Present Value Installed Cost for Different Vanadium Redox Systems**

*(The S designation under each bar is a vendor code that masks the identity of the vendor.)*




**Figure H-14. Levelized Cost of Energy in \$/MWh for Different Vanadium Redox Systems**  
(The S designation under each bar is a vendor code that masks the identity of the vendor.)



**Figure H-15. Levelized Cost of Capacity in \$/kW-yr for Different Vanadium Redox Systems**  
(The S designation under each bar is a vendor code that masks the identity of the vendor.)

## H.6 Iron-chromium Batteries Life-Cycle Cost Analysis


Life-cycle cost analysis of several selected systems is illustrated in Figure H-16, Figure H-17, and Figure H-18. The estimates are based on capital and O&M data from the Fe-Cr data sheets in Appendix B. A simple dispatch was assumed, with ~~investor-owned utility~~ IOU financials and 365 cycles per year for 15 years. Generally, key assumptions are IOU ownership, with 365 cycles peak-shaving annually for 15 years. Periodic stack replacement costs assumed every 8 years and start at \$194/kW. See Appendix B for discussion of life-cycle cost methods.



**Figure H-16. Present Value Installed Cost for Different Iron-chromium Systems**


(The S designation under each bar is a vendor code that masks the identity of the vendor.)

Appendix H: Life-Cycle Cost Analysis Figures for Mature Energy Storage Technologies



**Figure H-17. Levelized Cost of Energy  
in \$/MWh for Different Iron-chromium Systems**

(The *S* designation under each bar is a vendor code that masks the identity of the vendor.)




**Figure H-18. Levelized Cost of Capacity  
in \$/kW-yr for Different Iron-chromium Systems**

(The *S* designation under each bar is a vendor code that masks the identity of the vendor.)


## H.7 Zinc-bromine Batteries Life-Cycle Cost Analysis

Life-cycle cost analysis of several selected systems is illustrated in Figure H-19, Figure H-20, Figure H-21, Figure H-22, Figure H-23, and Figure H-24 for each application. The estimates are based on capital, O&M data and stack replacement costs as shown in the data sheets for ~~ZZinc~~ Zinc-bromine in Appendix B. A simple dispatch was assumed; generally, key assumptions are IOU ownership, with 365 cycles peak-shaving annually for 15 years. See Appendix B for discussion of life-cycle cost methods.




**Figure H-19. Present Value Installed Cost for Zinc-bromine Systems in Bulk and Utility Transmission and Distribution Service**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)




**Figure H-20. Levelized Cost of Energy in \$/MWh for Zinc-bromine Systems in Bulk and Utility Transmission and Distribution Service**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)




**Figure H-21. Levelized Cost of Capacity in \$/kW-yr for Zinc-bromine Systems in Bulk and Utility Transmission and Distribution Service**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)




**Figure H-22. Present Value Installed Cost for Zinc-bromine Systems in Commercial and Industrial and Residential Applications**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)



**Figure H-23. Levelized Cost of Energy in \$/MWh for Zinc-bromine Systems in Commercial and Industrial and Residential Applications**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)




**Figure H-24. Levelized Cost of Capacity in \$/kW-yr for Zinc-bromine Systems in Commercial and Industrial and Residential Applications**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)


## H.8 Zinc-air Batteries Life-Cycle Cost Analysis

Life-cycle cost analysis of several selected systems is illustrated in Figure H-25, Figure H-26, and Figure H-27 by application. The estimates are based on capital, O&M data, and stack replacement costs from the Zinc-air data sheets in Appendix B. A simple dispatch was assumed, with life-cycle estimates based on IOU financial assumptions of 365 cycles annually for 15 years. There was no periodic stack replacement costs assumed in these figures. See Appendix B for discussion of life-cycle cost methods. If a replacement cost of \$200 per kW every 5 years is assumed, the impact on present value installed cost is about a 9% increase.




**Figure H-25. Present Value Installed Cost for Zinc-air Systems in Bulk Services**  
(The S designation under each bar is a vendor code that masks the identity of the vendor.)

DOE/EPRI Electricity Storage Handbook in Collaboration with NRECA  
Appendix H: Life-Cycle Cost Analysis Figures for Mature Energy Storage Technologies




**Figure H-26. Levelized Cost of Energy in \$/MWh for Zinc-air Systems in Bulk Services**  
(The S designation under each bar is a vendor code that masks the identity of the vendor.)



**Figure H-27. Levelized Cost of Capacity in \$/kW-yr for Zinc-air Systems in Bulk Services**  
(The S designation under each bar is a vendor code that masks the identity of the vendor.)

## H.9 Lead-acid Batteries Life-Cycle Cost Analysis


Life-cycle cost analysis of several selected systems is illustrated in Figure H-28 through Figure H-42 for each application. The estimates are based on capital, O&M data, and battery replacement costs from the Lead-acid data sheets in Appendix B. Life-cycle estimates were based on IOU financial assumptions, with 365 cycles annually for 15 years. For the frequency regulation application, a simple dispatch was assumed based on each system operating 5000 cycles per year. See Appendix B for discussion of life-cycle cost methods for this application.



**Figure H-28. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Systems Bulk Service Applications**


*(The S designation under each bar is a vendor code that masks the identity of the vendor.)*

*DOE/EPRI Electricity Storage Handbook in Collaboration with NRECA*  
**Appendix H: Life-Cycle Cost Analysis Figures for Mature Energy Storage Technologies**




**Figure H-29. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Systems in Bulk Service Applications**

*(The S designation under each bar is a vendor code that masks the identity of the vendor.)*




**Figure H-30. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Systems in Bulk Service Applications**

*(The S designation under each bar is a vendor code that masks the identity of the vendor.)*



**Figure H-31. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Systems in Frequency Regulation**


(The S designation under each bar is a vendor code that masks the identity of the vendor.)



**Figure H-32. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Systems in Frequency Regulation**


(The S designation under each bar is a vendor code that masks the identity of the vendor.)

*DOE/EPRI Electricity Storage Handbook in Collaboration with NRECA*  
**Appendix H: Life-Cycle Cost Analysis Figures for Mature Energy Storage Technologies**




**Figure H-33. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Frequency Regulation**

*(The S designation under each bar is a vendor code that masks the identity of the vendor.)*




**Figure H-34. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Transmission and Distribution Applications**

*(The S designation under each bar is a vendor code that masks the identity of the vendor.)*



**Figure H-35. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Transmission and Distribution Applications**


(The S designation under each bar is a vendor code that masks the identity of the vendor.)



**Figure H-36. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Transmission and Distribution Applications**


(The S designation under each bar is a vendor code that masks the identity of the vendor.)

## Appendix H: Life-Cycle Cost Analysis Figures for Mature Energy Storage Technologies




**Figure H-37. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Distributed Energy Storage System Applications**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)




**Figure H-38. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Distributed Energy Storage System Applications**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)




**Figure H-39. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Distributed Energy Storage System Applications**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)




**Figure H-40. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Commercial and Industrial Applications**

## Appendix H: Life-Cycle Cost Analysis Figures for Mature Energy Storage Technologies



**Figure H-41. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Commercial and Industrial Applications**  
*(The S designation under each bar is a vendor code that masks the identity of the vendor.)*



**Figure H-42. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Lead-acid Batteries in Commercial and Industrial Applications**


## H.10 Flywheel Storage Life-Cycle Cost Metrics

Life-cycle cost analysis is illustrated in Figure H-43, Figure H-44, and Figure H-45. The estimates are based on capital, O&M data, and replacement costs from the data sheets in Appendix B. A simple dispatch was assumed, based on 5000 cycles per year, \$290 per kW replacement costs every 5 years, and IOU financing. See Appendix B for key input assumptions.




**Figure H-43. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Flywheel Systems**

*(The S designation under each bar is a vendor code that masks the identity of the vendor.)*



**Figure H-44. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Flywheel Systems**

*(The S designation under each bar is a vendor code that masks the identity of the vendor.)*



**Figure H-45. Present Value Installed Cost and Levelized Costs in \$/MWh and \$/kW-yr for Flywheel Systems**


*(The S designation under each bar is a vendor code that masks the identity of the vendor.)*

## H.11 Li-ion Batteries Life-Cycle Cost Analysis

Life-cycle cost analysis of selected systems is illustrated in Figure H-46 through Figure H-57 for each application. The estimates are based on capital, O&M data, and battery replacement costs from the Li-ion data sheets in Appendix B. A simple dispatch was assumed for bulk, utility T&D, C&I energy management, and residential energy management. Life-cycle estimates are based on IOU financial assumptions of 365 cycles annually for 15 years. See Appendix B for discussion of life-cycle cost methods.


For the frequency regulation applications, a simple dispatch was assumed based on each system operating 5000 cycles per year. See Appendix B for discussion of life-cycle costs methods for this application.

## Appendix H: Life-Cycle Cost Analysis Figures for Mature Energy Storage Technologies




**Figure H-46. Present Value Installed Cost in \$/kW for Li-ion Batteries in Frequency Regulation and Renewable Integration Applications**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)




**Figure H-47. LCOE in \$/MWh for Li-ion Batteries in Frequency Regulation and Renewable Integration Applications**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)




**Figure H-48. Levelized \$/kW-yr for Li-ion Batteries in Frequency Regulation and Renewable Integration Applications**  
*(The S designation under each bar is a vendor code that masks the identity of the vendor.)*




**Figure H-49. Present Value Installed Cost in \$/kW for Li-ion Batteries in Transmission and Distribution Applications**

*(The S designation under each bar is a vendor code that masks the identity of the vendor.)*




**Figure H-50. LCOE in \$/MWh for Li-ion Batteries in Transmission and Distribution Applications**

*(The S designation under each bar is a vendor code that masks the identity of the vendor.)*




**Figure H-51. Levelized \$/kW-yr for Li-ion Batteries in Transmission and Distribution Applications**

*(The S designation under each bar is a vendor code that masks the identity of the vendor.)*




**Figure H-52. Present Value Installed Cost in \$/kW for Li-ion Batteries in Distribute Energy Storage System Applications**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)




**Figure H-53. LCOE in \$/MWh for Li-ion Batteries in Distribute Energy Storage System Applications**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)




**Figure H-54. Levelized \$/kW-yr for Li-ion Batteries in Distribute Energy Storage System Applications**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)




**Figure H-55. Present Value Installed Cost in \$/kW for Li-ion Batteries in Commercial and Industrial Applications**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)



**Figure H-56. LCOE in \$/MWh for Li-ion Batteries in Commercial and Industrial Applications**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)



**Figure H-57. Levelized \$/kW-yr for Li-ion Batteries in Commercial and Industrial Applications**

(The S designation under each bar is a vendor code that masks the identity of the vendor.)

(All system costs are based on 5000 cycles per year)



## **DISTRIBUTION**

**External distribution:**

This report will be published online at [www.sandia.gov/ess](http://www.sandia.gov/ess)

**Internal distribution:**

1      MS0899      Technical Library      9536 (*electronic copy*)





**Sandia National Laboratories**