

# PV Component Reliability Distributions – Database and Insights

*2018 PV Reliability Workshop*

**Geoffrey T. Klise, Olga Lavrova, Renee Gooding**

Sandia National Laboratories

**Janine Freeman, Andy Walker**

National Renewable Energy Laboratory

March 1, 2018

SAND2018-XXXXC



Sandia National Laboratories is a multimission laboratory managed and operated by National Technology and Engineering Solutions of Sandia, LLC, a wholly owned subsidiary of Honeywell International, Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA0003525.

# Outline

- What kind of data are we collecting?
- Summary of reliability database
- Portfolio A (utility-scale)
- Portfolio B (DG)
  - Failure and Repair Distributions – insights into events and maintenance response
- Where the data can be used
  - SAM PV-RPM feature
  - O&M Cost Model

# PV System Data – DG and Utility-Scale

Maintenance Data	Performance Data	System Data
Specific Component	Energy production	Engineering and one-line diagrams
Fault or failure timestamp	Energy loss	Commissioning date
Repair timestamp	Performance model estimates	Component manufacturer and model/make detail
Equipment replaced		
Repair under warranty		
Fault Code (inverter)		
Narrative description <i>(relationship to other components or external events)</i>		
Quarterly maintenance reports		

# Reliability Database

Data compiled and analyzed up through December 2017

Portfolio	Commissioning year	Data collection range	Number of PV systems	MW <sub>DC</sub>	% of DG systems	% of utility scale systems
A	2003	2003-2008	1	3.5	0	100
B	2008-2009	2012-2014	2	1.75	100	0
C	2008-2016	2015-2016	180	578	3.4	96
D	2010-2017	2013-2017	61	25.6	100	0

**A** – 1 - Collins, E., M. Dvorack, J. Mahn, M. Mundt, and M. Quintana, 2009, *Reliability and Availability Analysis of a Fielded Photovoltaic System*, Presented at the 34th IEEE PVSC, 7-12 June 2009, Philadelphia, PA.

2 - Klise, G.T., O. Lavrova and J. Freeman, 2017, *Validation of PV-RPM Code in the System Advisor Model*, SAND2017-3676, April 2017.

**B** – Klise, G.T., R.R. Hill, C.J. Hamman, P.H. Kobos, V. Gupta, B.B. Yang, and N. Enbar, 2014, *PV Reliability Operations and Maintenance (PVROM) Database Initiative: 2014 Progress Report*, SAND2014-20612, December 2014.

**C** – Klise, G.T., O. Lavrova, R. Gooding, J. Freeman and A. Walker, *Improved Performance Modeling that Reflects Component Reliability Metrics*, 2017 NREL/SNL/BL PV Module Reliability Workshop, March 2, 2017.

**D** – Klise, G.T., O. Lavrova and R. Gooding, 2018, *PV System Component Fault and Failure Compilation and Analysis*, SAND2018-1743, February 2018.

# Reliability Database

Data compiled and analyzed up through December 2017


Portfolio	Commissioning year	Data collection range	Number of PV systems	MW <sub>DC</sub>	% of DG systems	% of utility scale systems
A	2003	2003-2008	1	3.5	0	100
B	2008-2009	2012-2014	2	1.75	100	0
C	2008-2016	2015-2016	180	578	3.4	96
D	2010-2017	2013-2017	61	25.6	100	0

C – Klise, G.T., O. Lavrova, R. Gooding, J. Freeman and A. Walker, *Improved Performance Modeling that Reflects Component Reliability Metrics*, 2017 NREL/SNL/BL PV Module Reliability Workshop, March 2, 2017.

# Portfolio C

## All Inverter Downtime - Frequency and Trend

Distribution of Downtime Events - Red colors represent peak production months



# Reliability Database


Data compiled and analyzed up through December 2017

Portfolio	Commissioning year	Data collection range	Number of PV systems	MW <sub>DC</sub>	% of DG systems	% of utility scale systems
A	2003	2003-2008	1	3.5	0	100
B	2008-2009	2012-2014	2	1.75	100	0
C	2008-2016	2015-2016	180	578	3.4	96
D	2010-2017	2013-2017	61	25.6	100	0

Portfolio	Unique module mfrs.	Unique module models	Total number of modules	Unique inverter mfrs.	Unique inverter models	Total number of inverters
D	11	25	83,891	8	29	129


D – Klise, G.T., O. Lavrova and R. Gooding, 2018, *PV System Component Fault and Failure Compilation and Analysis*, SAND2018-1743, February 2018.

# Portfolio D – Event Summary



# Portfolio D –

## Breakdown of Events that Tripped Inverters




# Portfolio D

- Fuse failure at inverter
- DC side arc fault – Trips inverter
- Recloser trip – grid event


Example	Component & Location	Failure Type	Fault/Failure Distribution				Repair Distribution			
			Type	Shape / Mean	Scale / Stdev.	Time Unit	Type	Mean	Stdev.	Time Unit
1	One Inverter at a site in the Eastern U.S.	Fuse failures	Weibull-2	13.03	714.27	day	Lognormal	0.6507	0.5431	day
2	One Inverter at a site in the Eastern U.S.	Tripping and resetting due to arc faults	Normal	256.979	148.56	day	Lognormal	-0.1181	1.3368	day
3	One Site in the Eastern U.S.	Recloser tripping on grid side	Weibull-2	1.36296	332.93	day	Lognormal	-1.7275	1.1695	day

# Fuse failure at inverter – failure and repair distribution

Fuse FAILURE Distribution Plot  
Weibull, Shape=13.03, Scale=714.27, Thresh=0




Fuse REPAIR Distribution Plot  
Lognormal, Loc=0.65067, Scale=0.54308, Thresh=0




- Highest probability of fuse failure at 700 days
- Highest probability fuse will be replaced around 1.5 days. Only 20% chance the repair will happen three days after the event

# DC side arc fault – inverter fault and repair distribution




- Highest probability of arc fault event tripping the inverter at 300 days
- Highest probability inverter will reset at 0.15 days (~4 hours). Repairs happening later suggest manual restart

# Recloser trip – grid event



- Highest probability of recloser shutting down all inverters (entire system) at 125 days
- Operator can remotely reset the recloser. The highest probability of repair is around 1 hour after the event

# Evaluating failure or ‘trip’ rate for reclosers



What does the MCF say about the failure, is it becoming more or less frequent?

1134 failures per 1M hours. MTBF  $\sim 34.56$ , *if* failure rate is constant

Shape factor less than 1 indicates failure rate decreasing. 0.8 for this event, so failures occurring less frequently. Failure rate and MTBF are more appropriate for constant failure rates.

# PV-RPM in SAM

## ■ System Design Window

*Same as any other SAM model*


Components that can be simulated with probability distributions :

<b>Modules</b>	<b>AC Disconnects</b>
<b>Strings</b>	<b>Transformers</b>
<b>DC Combiners</b>	<b>Grid Impacts</b>
<b>Inverters</b>	<b>Trackers</b>

## Output File

- *Power & Energy loss,*
- *costs,*
- *labor hours,*
- *LCOE,*
- *failures per component.*
- *Time series and annual results, per realization*

Recorded demonstration webinar



**NREL System Advisor Model (SAM)**  
NATIONAL RENEWABLE ENERGY LABORATORY

HOME DOWNLOAD SDK SUPPORT RESOURCES CONTACT ACCOUNT

### Photovoltaic Reliability Performance Model (PVRPM) in SAM

published by Paul Gilman on Fri, 2017-12-08 09:39

Geoff Klise of Sandia and Janine Freeman of NREL provide an overview of the Photovoltaic Reliability Performance Model (PVRPM) in SAM. The PVRPM is a component of the System Advisor Model (SAM) and is used to predict the reliability of photovoltaic (PV) systems over time. The model takes into account various factors such as temperature, humidity, and solar radiation to predict the failure rate of PV components. The PVRPM is particularly useful for long-term reliability analysis of PV systems, such as those used in utility-scale power generation. The PVRPM is available as a separate module within the SAM software, and can be used to predict the reliability of PV systems under different operating conditions. The PVRPM is a valuable tool for PV system designers and operators, as it provides a quantitative way to assess the reliability of PV systems and make informed decisions about system design and operation.

Probability distributions used in SAM

Component	Distribution Type	Parameters
Module	Normal	Mean: 1000 Wp, Std Dev: 50 Wp
String	Normal	Mean: 1000 Wp, Std Dev: 50 Wp
DC Combiner	Normal	Mean: 1000 Wp, Std Dev: 50 Wp
Inverter	Normal	Mean: 1000 Wp, Std Dev: 50 Wp
AC Disconnect	Normal	Mean: 1000 Wp, Std Dev: 50 Wp
Transformer	Normal	Mean: 1000 Wp, Std Dev: 50 Wp
Grid Impact	Normal	Mean: 1000 Wp, Std Dev: 50 Wp
Tracker	Normal	Mean: 1000 Wp, Std Dev: 50 Wp

For more information about PVRPM, see <https://sam.nrel.gov/pvrpm>.

For more about LK script, see <https://sam.nrel.gov/node/69358>.

Supporting materials:

- Presentation slides (PDF 1.7 MB)

<https://sam.nrel.gov/node/75555>

# O&M Cost Model – NREL / SunSpec



Evaluates whether service cost is less than expected energy loss based on probability of failure. Ties PM to potential failure event

SUNSPEC ALLIANCE PV O&M Cost Model Web Application

- Dashboard
- User Accounts
- Reports
- Plant Groups
- Plants
- Cost Models
- Services
- Labor Rates

## Reports

### Plant - South Valley, Cost Model - Residential Rooftop

Summary View   Detailed View   Failure Mode Analysis

Service Type Name	Service Name	Failure Mode	Cost of Failure	MLE (Expected) Cost of Failure				
				Year 1	Year 2	Year 3	Year 4	Year 5
Inverter Inspection	Default	Power Electronics Failure Covered by warranty	\$5788.32	\$0.00	\$11.29	\$89.74	\$297.33	\$680.15
Inverter Inspection	Default	Power Electronics Failure Not covered by warranty	\$7194.48	\$0.00	\$14.04	\$111.54	\$369.57	\$845.37
Reboot Inverter	Default	Firmware malfunction/failure	\$0.39	\$0.08	\$0.08	\$0.08	\$0.08	\$0.08
Reboot Inverter	Default	Firmware malfunction/failure	\$270.76	\$0.00	\$131.75	\$199.39	\$234.12	\$251.95

Subcomponent name:

Failure mode:

1. Failure distribution (uniform, Weibull, Lognormal, Poisson)
2. Expected outage time (detection time + service time or replacement time)
3. Product of 1 and 2 gives expected energy loss \$\$

1. Is this failure mode covered by warranty? (yes/no)
2. If covered by warranty, which costs and losses be reimbursed? (material, labor and/or energy loss?)

1. Identify O&M or PM activity associated with this failure mode
2. Calculate costs (already existing in the worksheet)

If cost of service is below the maximum likelihood estimation of the energy lost, then it may be a good business decision to perform the specific PM event



# Thank You

[gklise@sandia.gov](mailto:gklise@sandia.gov)



Sandia National Laboratories is a multimission laboratory managed and operated by National Technology and Engineering Solutions of Sandia, LLC, a wholly owned subsidiary of Honeywell International, Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA0003525.