

Culminating Project The Laboratory Building

Cal Poly Fire Protection Engineering

Joshua Herrera



*Exceptional
service
in the
national
interest*



Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000. SAND NO. 2011-XXXXP

INTRODUCTION

Contents

- Prescriptive Design
 - Occupancy
 - Suppression
 - Alarm System
 - Structural Fire Protection
- Performance-Based Design
 - Scope, Goal, Objectives, and Criteria
 - Egress
 - Tenability
 - Fire Scenarios
 - Models
- Recommendations

Applicable Codes

- NFPA 13 Automatic Sprinkler Systems Handbook (2013)
- NFPA 72 National Fire Alarm and Signaling Code (2013)
- NFPA 101 Life Safety Code (LSC) (2012)
- International Building Code (IBC) (2012)
- International Fire Code (IFC) (2012)
- NFPA Fire Protection Handbook (20th Edition)
- SFPE Handbook of Fire Protection Engineering (4th Edition)
- DOE Standard 1066-99: Fire Protection Design Criteria
- Various Sandia Specifications

Sandia National Laboratories (SNL)

- Sandia is a multi-program laboratory operated by Lockheed Martin Co. for the U.S. DOE
- Albuquerque, NM
- Kirtland AFB




The Laboratory Building

- Nanoscale science research center
- Cleanroom
- Chemical stockroom
- 20 acres of land adjacent to SNL
- Barrier free access to visiting collaborators
- 1 story
- Lab Space Dedicated to:
 - Chem/bio synthesis and characterization
 - Optical microscopy and spectroscopy
 - Physical synthesis
 - Thin film fabrication
 - Spatially resolved scanned probe characterization
 - Advanced computation

The Laboratory Building



The Laboratory Building




PRESCRIPTIVE BASED DESIGN

Occupancy Classification

Occupancy Classification

| Room | LSC (Ch. 6) | IBC (Ch. 3) |
|---------------------|-----------------------------|-------------|
| Office | Business | B |
| Laboratory | Industrial | B |
| Conference | Assembly | A-3 |
| Mechanical | Industrial - General | F-1 |
| Chemical Storage | Industrial - High Hazard | H-3 |
| Cleanroom | Industrial - High Hazard | H-5 |




Occupant Loads

Occupant Loads (IBC 1004.1.2)

| Use | Factor (ft ² per person) | Load |
|--------------|-------------------------------------|------------|
| Assembly | 15 net | 627 |
| Business | 100 | 298 |
| Group H-5 | 200 | 27 |
| Storage | 300 | 2 |
| Mechanical | 300 | 18 |
| TOTAL | | 972 |

Exits





Required Exits (IBC 1021)


| Occupant Load | Exits |
|------------------------|-------|
| IBC Table 1021.2(2) | 1 |
| 1-500 | 2 |
| 501-1000 | 3 |

- Rooms in F-1 have a single exit.
- 1/3 of the diagonal is 144 ft.
- Closest exits are located 167 ft. apart

Fire Barriers

- Fire barriers shall have a fire-resistance rating in accordance with ASTM E 119 (IBC 703.2)
- Fire barriers are permitted to separate the building into control areas to meet maximum allowable quantities for hazardous materials (IBC 414.2.1)
- Fire barriers separating occupancies within a building, with a 2-hour rating, can serve as a horizontal exit (IBC 707.3.10; 1025.2)

| | |
|---|--------|
|  | 2-hour |
|  | 1-Hour |



Interior Finishes

IBC Interior Finish Classes (803.9)

| Group | Wall and Ceiling Class | | Floor Class |
|-------|------------------------|------|-------------|
| | Corridor | Room | |
| B | C | C | II |
| A-3 | B | C | II |
| F-1 | C | C | II |
| H-3 | B | C | II |
| H-5 | B | C | II |

- DOE-STD-1066-99 Sect. 9.3.1
 - Flame Spread Index: 25
 - Smoke Developed Index: 50
- Decorative Material: 10% of wall area
- Meets code due to more stringent DOE requirements

Wall/Ceiling Finish Index (IBC 803.1.1; ASTM E 84)

| Class | Flame Spread | Smoke Developed |
|-------|--------------|-----------------|
| A | 0-25 | 0-450 |
| B | 26-75 | 0-450 |
| C | 76-200 | 0-450 |

Floor Finish (IBC 804.2; NFPA 253)

| Class | Minimum Critical Radiant Flux |
|-------|-------------------------------|
| I | 0.45 W/cm ² |
| II | 0.22 W/cm ² |

Structural Fire Protection - Area

- No surrounding buildings – max allowable area (IBC 506)
- Exception IBC 506.2.1 W/30=2

| <i>Occupancy</i> | $A_{act} (ft^2)$ | $A_t (ft^2)$ | I_f^* | I_s | $A_a (ft^2)$ | <i>Ratio</i> |
|------------------|------------------|--------------|---------|-------|--------------|--------------|
| B** | 62,512 | 23,000 | 1.5 | 3 | 126,500 | 0.49 |
| A-3*** | 2,104 | 9,500 | 1.5 | 3 | 52,250 | 0.04 |
| F-1** | 8,085 | 15,500 | 1.5 | 3 | 85,250 | 0.09 |
| H-3**** | 711 | 14,000 | 1.5 | 0† | 35,000 | 0.02 |
| H-5 | 9,088 | 23,000 | 0.75 | 3 | 109,250 | 0.08 |
| SUM | | | | | | 0.72 |

*506.2.1 – Where building meets IBC 507, width of public way is limited to maximum of 60

**507.3 – Considered an unlimited area building

***507.6 – Considered an unlimited area building

****507.8 Considered an unlimited area building

†506.3 Exception – No sprinkler increase permitted

Structural Fire Protection - Resistance

Required Separation (IBC Old)

| Use | A-3 | B | F-1 | H-3 | H-5 |
|-----|-----|---|-----|-----|-----|
| A-3 | | 1 | 2 | 3 | 4 |
| B | | | 2 | 1 | 1 |
| F-1 | | | | 1 | 1 |
| H-3 | | | | | 1 |

Corridor Rating (IBC 1018.1)


| Use | Load | Rating* |
|-----|------|---------|
| H-5 | >30 | 1 |

*With a sprinkler system



- Type IIB Construction
 - DOE Order 420.1
 - Steel decks
 - Steel bar joists
 - Steel wide flange beams
 - Steel columns
 - Exterior nonbearing walls (no fire resistance)

Suppression

| Space | Classification (NFPA 13) | Density (gpm/ft ²) | | Area (ft ²) | | Hose (gpm) | | Duration (min) |
|--------------------|--------------------------|--------------------------------|--------------|-------------------------|--------------|------------|--------------|----------------|
| | | NFPA 13 | Sandia 15310 | NFPA 13 | Sandia 15310 | NFPA 13 | Sandia 15310 | NFPA13 |
| Office | Light Hazard | 0.10 | 0.15 | 1500 | 1500 | 100 | 500 | 30 |
| Laboratory Class C | Ordinary Hazard 1 | 0.15 | 0.17 | 1500 | 3000 | 250 | 500 | 60-90 |
| Cleanroom | Special Hazard | 0.20 | 0.20 | 3000 | 3000 | - | 500 | - |
| FLS | Extra Hazard 2 | 0.40 | - | 2500 | - | 500 | - | 90-120 |



Suppression – Water Supply



| | |
|--|--|
| | Sprinkler Demand (Hand Calculations) |
| | Hose Stream Allowance (500 gpm) |
| | Sprinkler Demand (Designer's Calculations) |
| | Hose Steam Allowance |
| | Water Supply |
| | 85% Supply (Sandia Spec.15310 Sect. 4b) |


Fire Alarm System - Characteristics

- Proprietary Supervising Station
- FACP (QuickStart 4), FATC, Annunciator (QSA)
- Initiating Devices:
 - Smoke Detector – No detection throughout the building (IBC 907.2)
 - Fire Alarm Safety Functions (IBC 907.3)
 - Control door release, HVAC, and toxic gas shutdown
 - Protect FACP & FATC (IBC 907.4.1)
 - Manual Pull Stations – Exits; every 400 feet; every 150 feet along chemical transportation route (IBC 415.10.2).
 - High Sensitivity Smoke Detection (HSSD)
 - Toxic Gas Monitoring System
 - Water Flow and Tamper Switches
- Notification Devices: Horn/Strobe (Wheelock)
- Class A Circuits: Redundant path; operates past single open; path integrity results in trouble signal (NFPA 72, 12.3.1)

Fire Alarm System

Table 1: dBA and Current Ratings for Multitone Audible Portion

| | RMS Current (amps) | | | | | | | | | | dBA @ 10ft (UL Reverberant) | | | | | |
|-----------------|--------------------|---------|------------|---------|-----------|---------|------------|---------|-----------|------------|-----------------------------|------------|-----------|------------|-----------|------------|
| | 24 VDC | | | | 12 VDC | | | | 120 VAC | | 24 VDC | | 12 VDC | | 120 VAC | |
| | HI Output | | STD Output | | HI Output | | STD Output | | HI Output | STD Output | HI Output | STD Output | HI Output | STD Output | HI Output | STD Output |
| | @ 24 VDC | UL max* | @ 24 VDC | UL max* | @ 24 VDC | UL max* | @ 24 VDC | UL max* | UL max* | UL max* | Output | Output | Output | Output | Output | Output |
| Horn | 0.074 | 0.108 | 0.033 | 0.044 | 0.145 | 0.176 | 0.023 | 0.034 | 0.050 | 0.042 | 92 | 87 | 90 | 77 | 85 | 82 |
| Bell | 0.040 | 0.053 | 0.018 | 0.024 | 0.077 | 0.095 | 0.014 | 0.020 | 0.041 | 0.039 | 86 | 80 | 85 | 69 | 82 | 75 |
| March Time Horn | 0.067 | 0.104 | 0.033 | 0.038 | 0.109 | 0.142 | 0.023 | 0.034 | 0.050 | 0.040 | 89 | 84 | 89 | 74 | 85 | 79 |
| Code-3 Horn | 0.069 | 0.091 | 0.026 | 0.035 | 0.100 | 0.142 | 0.023 | 0.034 | 0.050 | 0.042 | 88 | 83 | 88 | 73 | 82 | 75 |
| Code-3 Tone | 0.061 | 0.075 | 0.026 | 0.035 | 0.088 | 0.105 | 0.015 | 0.021 | 0.042 | 0.040 | 85 | 80 | 84 | 70 | 79 | 75 |
| Slow Whoop | 0.069 | 0.098 | 0.028 | 0.037 | 0.100 | 0.142 | 0.025 | 0.035 | 0.050 | 0.042 | 90 | 89 | 89 | 75 | 85 | 82 |
| Siren | 0.080 | 0.104 | 0.027 | 0.036 | 0.122 | 0.152 | 0.021 | 0.030 | 0.045 | 0.041 | 89 | 84 | 89 | 75 | 85 | 82 |
| HI/LO | 0.044 | 0.057 | 0.020 | 0.026 | 0.089 | 0.114 | 0.018 | 0.026 | 0.042 | 0.039 | 86 | 81 | 86 | 71 | 82 | 79 |



6 dB Rule (NFPA HB 14-3)

Sound Pressure (dBA)

Distance from Source (ft.)

| | |
|----|-----|
| 92 | 10 |
| 86 | 20 |
| 80 | 40 |
| 74 | 80 |
| 68 | 160 |


Table 2: Strobe Current Ratings

RMS Current (amps)

| Model | MT-24MCW | | | |
|---------|-----------|-----------|-----------|----------|
| | MT-121575 | MT-241575 | MTWP-2475 | MT-24MCW |
| Candela | 1575cd | 1575cd | 180cd | 15cd |
| @ 24VDC | 0.152 | 0.060 | 0.094 | 0.041 |
| UL max* | 0.255 | 0.090 | 0.138 | 0.060 |


PERFORMANCE-BASED DESIGN

Project Scope



- The performance-based analysis will consist of ensuring the fire protection systems for laboratory building will perform under the three most likely fire scenarios.
- The systems must protect all occupants to safe egress and prevent the fire from spreading beyond the room of origin.
- The primary stakeholders are the building owner, the AHJ (DOE), the “Building and Fire Safety” department, the tenants, the building operations and maintenance, and the emergency responders.

Egress Analysis



■ Assumptions

- Instant queuing will occur at the 5 main exits (maximum specific flow F_{sm})
- The exits will be used at optimum balance
- No private exits are considered

Tenability Criteria

- Visibility: Many occupants may be visiting researchers and may not be familiar with the building layout.
 - **Visibility: 13 meters (SFPE HB 3rd Ed. Table 2-4.2)**
 - **Smoke Density: 0.15 m^{-1}**
- Toxicity: Carbon monoxide is considered the most important asphyxiant formed in fires, therefore, we will only consider the CO levels for toxicity. Exposure of 2000 ppm CO would give the occupants 14 minutes to escape, however, with no knowledge of the size and RVM of the occupants, a more conservative criteria will be required.
 - **CO: 1000 ppm (SFPE HB 3rd Ed. Figure 2-6.5)**
- Temperature: After analyzing hyperthermia, skin burns, and respiratory burn limits, the most conservative temperature comes from convective heat transfer at 100% saturation
 - **Temperature: 60 C (SFPE HB 3rd Ed. Table 2-6.19)**
- Smoke Layer
 - **6 feet (IBC 909.8.1)**

Performance Criteria

| Fire Protection Goal | Stakeholder Objective | Design Objective | Performance Criteria |
|--|--|--|---------------------------------|
| Minimize fire-related injuries | Allow safe egress for all occupants outside the room of origin | Maintain tenable conditions | Visibility > 13 m |
| | | | Smoke Layer Height > 1.83 m |
| | | | CO < 1000 ppm |
| | | | Room Temperature < 60 C |
| Minimize fire-related damage to the buildings and its contents | Prevent thermal damage | Prevent Flashover | Upper Layer Temperature < 500 C |
| Minimize undue loss of operations | Minimize smoke spread | Prevent fire and smoke from spreading outside the room of origin | Upper Layer Temperature < 500 C |

Design Fire Scenarios

| NFPA 101; 5.5.3 | Common Scenarios* | Characteristics |
|--|------------------------|----------------------------------|
| 1. Occupancy-specific fire | Intentionally set fire | Visitors |
| 2. Ultrafast-developing fire in primary means of egress | Electrical malfunction | Chemical Storage |
| 3. Normally unoccupied room | Smoking | Cleanroom |
| 4. Concealed space next to large occupied room | Equipment | Located off-site (response time) |
| 5. Slowly developing fire, shielded from fire protection | Carelessness | |
| 6. Most Severe Fire | Heating | |
| 7. Outside Exposure | Cooking | |
| 8. Ordinary combustibles; fire protection ineffective | | |

*NFPA 805; *Fire in the US (FEMA)*;

Fire Scenarios

1. Lobby – Electrical Fire (NFPA 101, 5.5.3 (8))
 - Ordinary Combustibles; Fire Protection Ineffective.
2. Office – Heater Fire (NFPA 101, 5.5.3 (5))
 - Slowly developing fire shielded from fire protection.
 - The heater will be located under a desk and will be shielded by sprinklers. Portable heaters have been a common problem at SNL. Occupants can potentially leave to lunch and leave their heaters running.
3. High Hazard – Chemical Spill (NFPA 101, 5.5.3 (1))
 - Occupancy Specific Fire
 - 5 gallons of acetone

Performance-Based Design

FIRE SCENARIO 1 – LOBBY PRINTER



Fire Scenario 1 – Lobby



Fire Scenario 1 – Lobby

- Ignition Source: Printer
- Secondary Ignition: Keyboard, Monitor, Desktop tower, Cushioned office chair
- Open room therefore the smoke will spread along the main corridors.
- Fire Protection features are considered ineffective

Fire Scenario 1 – Lobby



FS1 Lobby – HRR




Figure 3-1.19. HRR of metal-frame, upholstered stacking chairs.




Figure 3-1.25. HRR results of ABS monitors, rated UL 94 V0.




Figure 3-1.30. HRR of two, personal-type printers tested at SP.





Figure 3-1.24. HRR of polystyrene computer keyboards tested at NIST.⁵²

| Item | Peak HRR (kW) |
|---------------|---------------|
| Keyboard | 23 |
| Monitor | 35 |
| Desktop Tower | 35 |
| Printer | 100 |
| Chair | 100 |
| TOTAL | 293 |

*HRR taken from SFPE HB Chapter 3-1. Approximate growth time for all of the computer products is 300 seconds.


- Assume no incubation period.
- REAC will be PU (chair) due to its higher CO and Soot output over ABS (plastic cases)

FS1 Lobby – Egress Analysis (t_d)



288 s (290 kW)

FS1 Lobby – Egress Analysis (t_d)



54 s (10.2 kW)

FS1 Lobby – Egress Analysis (t_{p-e})


- Proulx studied 3 office buildings (SFPE HB 3-358)
 - Canadian government buildings
 - Evacuation drill conducted annually
 - 1000 occupants
 - No warning of fire drill
 - Finished phone calls
 - Saved computer data
 - Secured files
 - Gathered belongings
 - MEAN PRE-EVACUATION TIME: **50 s**

FS1 Lobby – Egress Analysis (t_e)

Hand Calculations

- $W_e = 4.33 \text{ ft}$
- $F_{sm} = 24 \frac{\text{person}}{\text{min}\cdot\text{ft}}$
- $F_c = 103.9 \frac{\text{persons}}{\text{min}\cdot\text{door}}$
- $P = 972 \text{ people}$
- $\text{Doors} = 5$
- $t_e = 112 \text{ s} = 1.87 \text{ min}$

Pathfinder








$$t_e = 106.3 \text{ s}$$

FS1 Lobby – Egress Analysis (RSET)


- $RSET = t_d + t_{p-e} + t_e$
 - $RSET$ (Sprinkler) = $288 + 50 + 112 = 450$ (7.5 min)
 - $RSET$ (Smoke Detector) = $54 + 50 + 112 = 216$ s (3.6 min)
 - $RSET$ (Instant Detection) = $0 + 50 + 112 = 162$ s (2.7 min)

FS1 Lobby – Model




FS1 – Results (Flashover)

- 300 kW @ 300 s




- Passed (500 C)




FS1 Lobby – Results (Temp.)

- Temp. - Passed (60 C)




- Tenable at 1.8 meters




FS1 Lobby – Results (Smoke)

- Lobby - 160 s (6 feet)
- East – 220 s (6 feet)
- NE – 235 s (6 feet)
- Visibility Fail 200 s (13 m)



FS1 Lobby – Results (CO)

- **CO Passed (1000 ppm)**




FS1 Lobby – Summary

| Criteria | Instant Detection | Smoke Detector | Sprinkler Activation | Reason |
|-----------------|-------------------|----------------|----------------------|--|
| RSET (s) | 162 | 216 | 450 | |
| Flashover | Pass | Pass | Pass | Upper layer temperature of 500 °C never exceeded |
| Temperature | Pass | Pass | 165 | A room temperature of 60 C was exceeded below a height of 1.8 m |
| Visibility | Pass | 200 | 200 | Visibility drops below 13 m from the E door to the NE door, blocking 2 exits. |
| Smoke Layer | Pass | Pass | 220 | The smoke layer descends below 6 feet at the E door in 220 s, eliminating the most common exit |
| CO | Pass | Pass | Pass | The CO concentration never exceed 1000 ppm |

Performance-Based Design

FIRE SCENARIO 2 – OFFICE HEATER


Fire Scenarios 2 – Office Heater Fire




Fire Scenarios 2 – Office Heater

- Ignition Source: Portable Heater
- Secondary Ignition: 1 office workstation
- Open layout, therefore the smoke will spread to the entire room of cubicles.
- The heater is located under the desk and shielded from the automatic detection, therefore, the sprinklers won't activate until the fire has spread to the workstation.

Fire Scenario 2 – Office Heater



FS2 Office - HRR




- HRR of 7 MW in 500 s
- FDS model assumes time begins when the workstation catches fire.

- Detection Time
 - Sprinkler activation in the FDS model occurred in **140 s**.
- Pre-Evacuation Time
 - Modeled after Station Nightclub Fire Timetable

| Action | Time (s) |
|---------------|-----------|
| Reaction time | 10 |
| Notify others | 10 |
| TOTAL | 20 |

FS1 Lobby – Egress Analysis (t_e)




$$t_e = 28 \text{ s}$$

FS1 Lobby – Egress Analysis (RSET)

- $RSET = t_d + t_{p-e} + t_e$
 - $RSET$ (Sprinkler) = $140 + 20 + 28 = \mathbf{188\ s}$ ($\mathbf{3.1\ min}$)
 - $RSET$ (Instant Detection) = $0 + 20 + 28 = \mathbf{48\ s}$ ($\mathbf{0.8\ min}$)

FS2 Office – Model


Smokeyview 6.1.4 - Oct 24 2013



Frame: 99
Time: 59.4

mesh: 1


Smokeyview 6.1.4 - Oct 24 2013



Frame: 139
Time: 83.4

mesh: 1


Smokeyview 6.1.4 - Oct 24 2013



Frame: 201
Time: 120.6

mesh: 1

Smokeyview 6.1.4 - Oct 24 2013




Frame: 282
Time: 169.2


mesh: 1

FS2 Office – Results (Flashover)

- 510 kW @ 140 s




- Pass (500 C)




FS2 Office – Results (Temp.)

- 165 s (60 C @ S. Room)




- 165 s (60 C @ 1.75 m)




FS2 Office – Results (Smoke)

- 80 s (Visibility – 13 m)




- 100 s (Height – 1.8 m)




FS2 Office – Results (CO)

- Pass (CO – 1000 ppm)



- Pass (CO – 1000 ppm)



FS2 Office – Summary

| Criteria | Instant Detection | Sprinkler Activation | Reason |
|-----------------|-------------------|----------------------|---|
| RSET (s) | 48 | 188 | |
| Flashover | Pass | Pass | Upper layer temperature of 500 °C never exceeded |
| Temperature | Pass | 165 | A room temperature of 60 C was exceeded below a height of 1.8 m |
| Visibility | Pass | 80 | Visibility drops below 13 m in the south office |
| Smoke Layer | Pass | 100 | The smoke layer descends below 6 feet in the south office. |
| CO | Pass | Pass | The CO concentration never exceed 1000 ppm |

Performance-Based Design

FIRE SCENARIO 3 – CHEMICAL SPILL

Fire Scenarios 3 – Chemical Spill

- Spill Fire
- 5 gallons of Acetone
- High Hazard Occupancy
- High Sensitivity Smoke Detection (HSSD)
 - *The amount and location of chemicals in the model do not indicate the exact quantities and locations of chemicals in the laboratory building; however, the fire scenario is a good indication of possible hazards that may occur in any high hazard occupancy resulting from a spill fire.

FS3 Spill – HRR

Calculation

$$V = 5 \text{ gal} = 0.0189 \text{ m}^3$$

$$\delta = 0.0007 \text{ m}$$

$$A_s = \frac{V}{\delta} = \frac{0.0189 \text{ m}^3}{0.0007 \text{ m}} = 27 \text{ m}^2$$

$$A = 1.55A_s = 1.55(27 \text{ m}^2)$$

$$D = \sqrt{\frac{4A}{\pi}} = \sqrt{\frac{4(41.85 \text{ m}^2)}{\pi}} = 7.3 \text{ m}$$

$$\dot{m}'' = \frac{\dot{m}_{\infty}''}{5} = \frac{0.041 \text{ kg} \cdot \text{m}^{-2} \cdot \text{s}^{-1}}{5} = 0.0082 \frac{\text{kg}}{\text{m}^2 \cdot \text{s}}$$

$$\dot{q} = \Delta h_c \dot{m}'' A = \left(25.8 \frac{\text{MJ}}{\text{kg}}\right) \left(0.0082 \frac{\text{kg}}{\text{m}^2 \cdot \text{s}}\right) (41.85 \text{ m}^2) = \mathbf{8853.8 \text{ kW}}$$

$$t_b = \frac{m_f}{\dot{m}'' A} = \frac{V\rho}{\dot{m}'' A} = \frac{(0.0189 \text{ m}^3)(791 \frac{\text{kg}}{\text{m}^3})}{(0.0082 \frac{\text{kg}}{\text{m}^2 \cdot \text{s}})(41.85 \text{ m}^2)} = \mathbf{43.6 \text{ s}}$$

$$T_{FP} = \mathbf{-14 \text{ }^\circ\text{C}}$$

Property

Spill Volume

Spill Depth

Initial Spill Area

Maximum Area

Diameter of Maximum Area

Mass Burner Rate

Steady State Burning Rate

Burn Time

Acetone Flash Point


FS3 Spill – Egress Analysis

- Detection Time
 - Instantaneous max HRR
 - HSSD
 - **3 s**

■ Pre-Evacuation Time


| P-E Action | Time (s) |
|---------------|-----------|
| Reaction Time | 3 |
| Notify Others | 10 |
| TOTAL | 13 |

- Evacuation Time: **14 s**




- **RSET = 30 s**

FS3 Spill – Model




FS3 Spill – Results (Flashover)

- 8.8 MW for 44 s




- Pass (500 C)




FS3 Spill – Results (Temp.)

- 14 s (60 C @ S. Room)




- 14 seconds (60 C)




FS3 Spill – Results (Smoke)

- 14 s (Visibility – 13 m)





- 14 s (Height – 1.8 m)



FS3 Spill – Results (CO)

- **Pass (CO – 1000 ppm)**



FS3 Cleanroom – Summary

| Criteria | Pass/Fail | Reason |
|-------------|-----------|---|
| RSET | 30 | |
| Flashover | Pass | Upper layer temperature of 500 C never exceeded |
| Temperature | 14 | A room temperature of 60 C was exceeded below a height of 1.8 m |
| Visibility | 14 | Visibility drops below 13 m |
| Smoke | 14 | The smoke layer descends below 6 feet |
| CO | Pass | The CO concentration never exceed 1000 ppm |

Risk Analysis

- Qualitative Analysis
- Event Trees
- Risk Ranking Matrix
- Used to determine the priority level of recommendations

Risk Analysis – FS1 Event Tree

| Fire Location | Manual Suppression | Automatic Suppression | Barriers Effective | Fire Scenario | Scenario Probability | Scenario Consequence | |
|---------------|--------------------|-----------------------|--------------------|---------------|----------------------|----------------------|----------------|
| Lobby | Yes 0.3 | | | S11 | 0.3 | Very Low | |
| | No 0.7 | Yes 0.3 | | S12 | 0.21 | Low | |
| | | No 0.7 | No 0.7 | Yes 0 | S13 | 0 | Very Low |
| | No 0.7 | | No 0.7 | No 1 | S14 | 0.49 | Extremely High |
| | | | | | | | |

Risk Analysis – FS2 Event Tree

| Fire Location | Manual Detection | Manual Suppression | Automatic Suppression | Barriers Effective | Fire Scenario | Scenario Probability | Scenario Consequence | |
|---------------|------------------|--------------------|-----------------------|--------------------|---------------|----------------------|----------------------|-----------|
| Office | Yes 0.7 | Yes 0.3 | | | S21 | 0.21 | Very Low | |
| | | | No 0.7 | Yes 0.95 | | | S22 | 0.4655 |
| | | No 0.05 | | Yes 0.95 | | | S23 | 0.023275 |
| | | No 0.05 | | | No 0.05 | S24 | 0.001225 | Very High |
| | No 0.3 | Yes 0.3 | | | S25 | 0.09 | Very Low | |
| | | | No 0.7 | Yes 0.95 | | | S26 | 0.1995 |
| | | No 0.05 | | Yes 0.95 | | | S27 | 0.009975 |
| | | No 0.05 | | | No 0.05 | S28 | 0.000525 | Very High |

Risk Analysis – FS3 Event Tree

| Fire Location | HSSD | Manual Suppression | Automatic Suppression | Barriers Effective | Fire Scenario | Scenario Probability | Scenario Consequence | | |
|---------------|-------------|--------------------|-----------------------|--------------------|---------------|----------------------|----------------------|-----------|-----------|
| High Hazard | Yes 0.95 | Yes 0.05 | | | S31 | 0.0475 | Very Low | | |
| | | | No 0.95 | Yes 0.3 | | | S32 | 0.27075 | Moderate |
| | | No 0.7 | | Yes 0.95 | | | S33 | 0.6001625 | Very High |
| | | | | No 0.05 | No 0.95 | | | S34 | 0.0315875 |
| | No 0.05 | Yes 0.05 | | | S35 | 0.0025 | Very Low | | |
| | | | No 0.95 | Yes 0.3 | | | S36 | 0.01425 | High |
| | | No 0.7 | | Yes 0.95 | | | S37 | 0.0315875 | Very High |
| | | | | No 0.05 | No 0.95 | | | S38 | 0.0016625 |

Risk Analysis – Risk Ranking Matrix

| Consequence | Probability of Scenario Occurrence | | | | | |
|----------------|------------------------------------|---------------------------|----------------------|---------------------------|-----------------------|----------------------------|
| | Extremely Low (0.000-0.019) | Very Low (0.020-0.039) | Low (0.040-0.099) | Moderate (0.100-0.299) | High (0.300-0.499) | Very High (0.500-1.000) |
| Extremely High | S38 | S34 | | | S14 | |
| Very High | S24, S28, S27 | S37 | | | | S33 |
| High | S36 | | | | | |
| Moderate | | | | S32 | | |
| Low | | S23 | | S12, S26 | S22 | |
| Very Low | S13, S35 | | S25, S31 | S21 | S11 | |

Key

| | | | |
|-----------|---------------|----------|-----------------|
| High Risk | Moderate Risk | Low Risk | Negligible Risk |
|-----------|---------------|----------|-----------------|

Recommendations

| Recommendation | Reason |
|---|---|
| 1 Separate the two lobby areas from the corridor. | Separating the lobby from the corridor by means of a wall will prevent the smoke from spreading to the corridors and will also provide earlier sprinkler activation. |
| 2 Reduce the probability of a chemical spill in the high hazard area. | By working with the building owner to ensure liquid chemicals are being stored, dispensed and transported appropriately, we can reduce the chance of a spill. Spill containment may be necessary in the high hazard area. |
| 3 Install manual pull stations at the exits of the two office blocks located in the center of the building. | The manual pull stations will allow the fire alarm to be activated long before an automatic sprinkler activates. |
| 4 Ensure proper ITM of all fire protection and life safety features. | Proper ITM will ensure the sprinkler water supply is always on. It will also ensure space heaters are being used appropriately and combustibles are not accumulating in the building. |
| 5 Verify the discrepancy between the designer's sprinkler calculations and the hand calculations. | By performing a more thorough sprinkler analysis with a computer program such as AutoSPRINK, we can determine if a water pump is necessary to provide enough water to meet the demand. |

Acknowledgements

- My wife and son – Christiana and Noah
- Manager – Perry D' Antonio
- Sandia Building and Fire Safety Staff
- Dr. Mowrer, Dr. Pascual, and all of the Cal Poly FPE Professors
- The SNL Master's Fellowship Program advisors
- SFPE Cal Poly Chapter

References

- T. Jin, "Visibility Through Smoke," *Journal of Fire and Flammability*, pp. 135-157, 1978.
- T. Jin, "Studies of Emotional Instability in Smoke from Fires," *Journal of Fire and Flammability*, 1981.
- T. Jin and T. Yamada, "Experimental Study of Human Behavior in Smoke Filled Corridor," *International Association of Fire Safety Science*, Boston, 1989.
- R. C. Anderson, P. A. Croce, F. G. Feeley and J. D. Sakura, "Study to Assess the Feasibility of Incorporating Combustion Toxicity Requirements into Building Materials and Furnishing Codes of New York State," *Arthur D. Little*, Cambridge, 1983.
- J. E. Perterson and R. D. Stewart, "Predicting the Carboxyhaemoglobin Levels Resulting from Carbon Monoxide Exposures," *Journal of Applied Physiology*, 1975.
- D. A. Purser, "A Bioassay Model for Testing the Incapacitating Effects of Exposure to Combustion Product Atmospheres Using Cynomolgus Monkeys," *Journal of Fire Sciences*, 1984.
- *Handbook of Respiration*, Philadelphia: Saunders, 1958.
- R. F. Coburn, R. E. Forster and P. B. Kane, "Consideration of Physiological Variables That Determine the Blood Carboxyhaemoglobin Concentrations in Man," *Journal of Clinical Investigation*, pp. 1899-1910, 1965.
- J. E. Peterson and R. D. Stewart, "Predicting the Carboxyhaemoglobin Levels Resulting from Carbon Monoxide Exposures," *Journal of Applied Physiology*, pp. 633-638, 1975.
- W. V. Blockley, "Temperature Tolerance: Man: Part 1. Heat and Cold Tolerance with and Without Protecting Clothing," in *Biology Data Book*, Bethesda, Federation of American Societies for Experimental Biology, 1973, p. 781.
- P. H. Thomas, "Testing Products and Materials for Their Contribution to Flashover in Rooms," in *Fire and Materials*, 1981, pp. 103-111.
- U.S. Fire Administration; National Fire Data Center, "Fire in the United States 2003-2007," FEMA, 2009.
- R. B. Williamson and N. A. Dembsey, "Advances in Assessment Methods for Fire Safety," *Fire Safety Journal*, pp. 15-38, 1993.
- D. Bliss and M. Simonson, "Fire Performance of IT Equipment Studied in the Furniture Calorimeter," in *Interflam 2001 - Proceedings 9th International Conference*, London, 2001.
- M. Bundy and T. Ohlemiller, "Full-Scale Flammability Measures for Electronic Equipment," *National Institute of Standards and Technology*, Gaithersburg, 2004.
- G. Proulx and J. Pineau, "Differences in the Evacuation Behaviour of Office and Apartment Building Occupants," in *Proceedings of the Human Factors and Ergonomics Society 40th Annual Meeting*, Santa Monica, 1996.
- K. Overholt, "t-squared Fire Ramp Calculator," [Online]. Available: <http://www.koverholt.com/t-squared-fire-ramp-calculator/>. [Accessed February 2015].
- D. Madrzykowski, "Office Workstation Heat Release Rate Study: Full Scale vs. Bench Scale," in *Interflam '96*, London, 1996.
- R. F. Duval, "NFPA Case Study: Nightclub Fires," *National Fire Protection Association*, Quincy, 2006.
- L. Shi, Q. Xie, X. Cheng, L. Chen, Y. Zhou and R. Zhang, "Developing a database for emergency evacuation model," *Elsevier*, vol. *Building and Environment*, no. 44, pp. 1724-1729, 2008.
- D. T. G. e. al., *Estimating Liquid Fuel Spill Areas*.