




U.S. DEPARTMENT OF
ENERGY

SAND2019-2152PE
Nuclear Energy

sCO₂ Brayton Cycle Economics Modeling and Optimization

Authors: Blake Lance, Sandia National Laboratories
 Tom Drennen, Galisteo Consulting



Sandia National Laboratories



Sandia National Laboratories is a multimission laboratory managed and operated by National Technology and Engineering Solutions of Sandia, LLC., a wholly owned subsidiary of Honeywell International, Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA-0003525.



Project Overview

Scope


- 1) Continue development of economics model by updating component models with collaboration across DOE national labs
- 2) Perform LCOE optimization of the sCO₂ Brayton cycle to inform design parameters while considering cross-cutting heat sources
- 3) Perform market analysis for sCO₂ Brayton cycles with outside contractor





Projected LCOE (¢/kWh)


Nuclear Energy



Source: Lazard, 2018.



Planned Capacity Additions, 2018-2019





EIA, *Electric Power Monthly*, February 2018



Integrated Techno-Economic Modeling Tool for sCO₂ Power Cycles

- Estimates the levelized cost of energy (LCOE) for recompression closed Brayton cycle (RCBC) systems. **LCOE is often used as an economic measure of energy costs as it allows for comparison of technologies with different capital and operating costs, construction times, and plant load factors.**



Component Costs
O&M Fuel Financing

LCOE




SCO₂ Component Costing

Component costing for

- Heat Source
- Heat Exchangers
 - Primary Heat Exchanger
 - High Temperature Recuperator (HTR)
 - Low Temperature Recuperator (LTR)
 - Cooling
- Turbomachinery
 - Turbine
 - Compressors
 - Control Valves
 - Generator
- Piping

Source information includes

- Publications
- Reports
- Vendor cost estimates/quotes



HEAT EXCHANGER SPECIFICATION SHEET					
Page 1 US Units					
1	Job No.				
2	Customer	Sandia National Labs	Reference No.		
3	Address	Albuquerque, NM	Proposal No.	QE-492340-14	
4	Plant Location		Date	06/18/2014	Rev 0
5	Service of Unit	High Temperature Recuperator	Item No.	TBD	
6	Size	60 x 720 inch	Horizontal	Connected In	1 Parallel 1 Series
7	Surf/Unit (Gross/Eff)	38229 / 35448 ft ²	Shell/Unit	1	Surf/Shell (Gross/Eff) 38229 / 35448 ft ²
8	activities needed to guide further research and development				
9	ABSTRACT				
10	Semi-critical carbon dioxide (sCO ₂) Brayton cycles have the potential to significantly improve the thermal to electric conversion efficiency using high-temperature steam Rankine systems depending on the cycle configuration. These most likely path toward achieving the U.S. Department of Energy (DOE) Office of Energy Efficiency and Renewable Energy (EERE) target for CSP power conversion efficiency above 50% with dry cooling and a power block cost of less than 900 \$/kW ^{0.5} have been conducted to optimize the performance of sCO ₂ Brayton cycle configurations in order to maximize efficiency and a few have accounted for dry equipment costs in the cycle. However, no validated models relating component performance to economic optimization has not been found. Reasonably accurate component cost is available from several sources for conventional equipment such as compressors, and heat exchangers for use in				
11	PERFORMANCE OF ONE UNIT				
12	Shell Side				
13	Fluid Allocation		Tube Side		
14	Fluid Name				
15	Fluid Quantity, Total	lb/hr	1000020	1000020	1000020
16	Vapor (In/Out)				
17	Liquid				
18	Steam				
19	Water				
20	Noncondensables				
21	Temperature (In/Out)		824.00	368.00	332.00
22	Specific Gravity				734.70
23	Viscosity	cP	0.0326	0.0234	0.0289
24	Molecular Weight, Vapor				0.0328
25	Molecular Weight, Noncondensables				
26	Specific Heat	BTU/lb-F	0.2793	0.2715	0.3625
27	Thermal Conductivity	BTU/in-h-F ²	0.0300	0.0192	0.0246
28	Latent Heat	BTU/lb			0.0302
29	Inlet Pressure	psia		1121.0	2872.0
30	Velocity	ft/sec		4.72	5.72
31	Pressure Drop, Allow/Calc	psi	11.200	7.373	28.700
32	Flow Rate, Actual/Calc	lb/sec	0.00000		5.407



Nuclear Energy

- Tool incorporates methodology outlined by the EIA (2013) for estimating total cost estimates for utility scale electricity generating plants.


- This methodology includes the following categories:
 - Component costs
 - Electrical and instrumentation and control (transformers, switch gear, etc.)
 - Civil and structural costs (site preparation, underground utilities, structural steel supply, and on-site building construction)
 - Project indirect costs (engineering, labor, construction management)
 - Fees and contingency
 - Owners costs (development costs, feasibility and engineering studies, legal fees, insurance, electrical interconnection)



Capturing Costs as Technology Develops

First-of-a-Kind vs. Nth-of-a-Kind Methodology


- Uses approach documented by NETL (2013)
- History has shown that new technology costs initial rise as details are refined until the 1st commercial unit.
- Costs decrease as lessons are learned and processes refined.
- We are using conservative scaling for Nth-of-a-Kind scaling.






Nominal LCOE Results

Nuclear Energy



- The estimated LCOE for a 100 MWe Brayton system operating with an inlet turbine temperature of 700°C with dry cooling are **8.32 ¢/kWh and 7.54 ¢/kWh for a first-of-a-kind and Nth-of-a-kind plant**, respectively.
- For the 100 MWe facility, the various heat exchangers and turbomachinery account for 15% and 17% of the total costs for the nth-of-a-kind plant, respectively.
- The Nth-of-a-kind total mechanical costs for are
 - \$1320/kWe for 100 MWe
 - \$2000/kWe for 20 MWe


Plant Size and Turbine Inlet Temperature Parameter Study



- Costs decline rapidly as size increases from 10 to 50 MWe, before slowly leveling off.
- Plants under 50 MWe, typically used for distributed or remote generation, are expected to have higher costs but higher value.
- This result demonstrates a benefit of these parameter studies, that a **relatively small decrease in cycle minimum temperature of 7°C has as much benefit as increasing the turbine inlet temperature by 100°C.**




Turbine Inlet Temperature Parameter Study



- 20 MWe system with dry cooling
- As turbine inlet temperature increases above 600°C, certain individual system components (primary heat exchanger, turbine, and high temperature recuperator) will require higher-quality alloys. The higher component costs are quickly offset by the increased overall system efficiency.




Recuperator Effectiveness Parameter Study



- Demonstrates the impact of recuperator effectiveness on system efficiency and LCOE. As recuperator effectiveness increases, system efficiency increases. The present analysis shows that the **optimal recuperator effectiveness, regardless of fuel price, is 92%**.




Dry Cooling Approach Temperature Parameter Study



- Illustrates the sensitivity of the results to the technical assumptions regarding the approach temperatures for dry cooling in a hot, dry climate (Yuma, AZ).
- The overall system efficiency drops sharply 10% as the LMTD increases from 3 to 15°C. **The increased system costs associated with lower LMTD translate into lower LCOE due to the increased system efficiencies.**
- sCO₂ properties were assumed constant for this analysis. A discretized heat exchanger model will be developed to account for property variations.

Dry Cooling Approach Temperature Parameter Study




- This same relationship holds for Bismarck, ND in the summer, although the overall LCOE is lower than was the case in Yuma, AZ as the ambient air temperatures are lower, allowing for a smaller cooling heat exchanger.
- **The location change from AZ to ND reduces LCOE by 25%.**



Projected LCOE (¢/kWh)

Nuclear Energy



Current estimates are for Nth-of-a-kind at 700°C and 100 MWe

Source: Lazard, 2018.



The current model is cumbersome for parameter studies

■ Running the current model

- Manual manipulation of a text input file



```
base
1 1
0.008 0.008 0.001
973. 973. 5.
305. 305. 0.2
7.5d6 7.5d6 0.1d6
35.d6 35.d6 1.0d6
2
.92 .92 .01
.92 .92 .01
0.90 0.90 0.01
0.855 0.855 0.01
0.855 0.855 0.01
100.

! output filename, 4 characters long
! units flag: 1 = Metric, 2 = English. te
! dpFractMin,dpFractMax,dpFractInc
! tHotMin,tHotMax,tHotInc [K]
! tColdMin,tColdMax,tColdInc [K]
! pLowMin,pLowMax,pLowInc [MPa]
! pHighMin,pHighMax,pHighInc [MPa]
! RecupFlag: recuperator approach temp or
! fLTR_Min,fLTR_Max,fLTR_Inc
! fHTR_Min,fHTR_Max,fHTR_Inc
! effTurbMin,effTurbMax,effTurbInc
! effCompA_Min,effCompA_Max,effCompA_Inc
! effCompB_Min,effCompB_Max,effCompB_Inc
! power [MW]
```

- Running RETS from command line

```
Z:\sCO2\RETPeT-2016-10-04>"split flow recup prediction.exe"
Copyright 2013 Sandia Corporation.
Under the terms of Contract DE-AC04-94AL85000,
there is a non-exclusive license for use of this
work by or on behalf of the U.S. Government. Export of
this data may require a license from the
United States Government.
CO2.FLD

Iteration      1  complete.
Iterations complete.

Z:\sCO2\RETPeT-2016-10-04>
```

- Opening output .csv file



- Opening Excel file





- Recording Results, closing .csv file

- This process has to be repeated for each set of conditions, so parameter studies take some time



- RETS is written in FORTRAN
- Cost Models will be translated from Excel into FORTRAN
- Sandia's DAKOTA will be used as an optimization wrapper that will also enable sensitivity studies



A Genetic Algorithm is the best approach for this application,
<https://www.youtube.com/watch?v=1i8muvzZkPw>



Collaboration with DOE National Labs


- The DOE national labs that have interest in sCO₂ power cycles are starting a collaboration for component cost information sharing.
- Vendor identification will be protected.
- This collaboration is expected to improve understanding and accuracy for economics modeling.
- Nathan Weiland at NETL initiated a monthly teleconference.
- Sandia is planning to facilitate information sharing, similar to the 2017 sCO₂ Summit Site.





Component Cost Estimates of 10 MWe STEP Pilot Plant

Component	10 MW _e Plant	
	(2017 \$1,000)	% of total cost
NG-fired heater	\$8,909	38.21%
PC-fired heater	-	
LTR	\$2,056	8.82%
HTR	\$3,324	14.25%
Direct dry cooler	\$1,617	6.93%
Main compressor	\$1,558	6.68%
Recompressor	\$1,798	7.71%
Motors	\$407	1.74%
Turbine	\$2,831	12.14%
Generator	\$471	2.02%
Gearbox	\$340	1.46%
Total equipment cost (2017 \$1,000)	\$23,310	
Uncertainty range of total equipment cost	-28% to +35%	



S. E. Zitney and E. A. Liese, "Dynamic Modeling and Simulation of a 10 MWe Supercritical CO₂ Recompression Closed Brayton Power Cycle for Off-Design, Part-Load, and Control Analysis," in The 6th International Supercritical CO₂ Power Cycles Symposium, Pittsburgh, 2018.

Conclusions and Future Plans

Conclusions

- A DOE National Lab sCO₂ Power Cycle Economics Consortium was organized
- The sCO₂ Brayton Economics Tool has been updated with component cost information
- Economics optimization has begun with software selection, algorithm planning

Future Plans

- Current cost models will be updated with collaborative work from Consortium
- Economics optimization will be performed



Backup



Nuclear Energy

- Initial market opportunities
 - waste heat
 - distributed generation
- Strong market opportunities in water-stressed regions as Brayton cycles achieve high efficiencies with dry cooling
- Key challenges:
 - *Customers not willing/able to invest in unproven technologies*
 - *Need demonstrable evidence that Brayton technology can operate for extended periods of time in a real-world environment*
- Main competitors (Next slide):
 - Renewable technologies, such as onshore wind (3.0 – 6.0 ¢/kWh)
 - Natural Gas Combined Cycle (NGCC) plants (4.2 – 7.8 ¢/kWh)
 - Bottom line: Must be able to compete on an economic basis with existing options or will be difficult to break into the market (subsequent slide)



Basic LCOE Methodology

- The levelized cost of energy is given by:

$$LCOE = \frac{I * FCR}{E} + \frac{O\&M}{E} + \frac{F}{E}$$

where:

<i>I</i>	= total financed capital costs
<i>FCR</i>	= fixed charge rate
<i>E</i>	= annual plant output (i.e. kWh)
<i>O&M</i>	= fixed and variable operating and maintenance costs
<i>F</i>	= feedstock costs (i.e. natural gas, biomass)

Non-sCO₂ Component Costs

- Tool incorporates methodology outlined by the EIA (2013) for estimating total cost estimates for utility scale electricity generating plants.
- This methodology includes the following categories:
 - Mechanical equipment supply (major equipment)
 - Electrical and instrumentation and control (transformers, switch gear, etc.)
 - Civil and structural costs (site preparation, underground utilities, structural steel supply, and on-site building construction)
 - Project indirect costs (engineering, labor, construction management)
 - Fees and contingency
 - Owners costs (development costs, feasibility and engineering studies, legal fees, insurance, electrical interconnection)
- Adding all of these costs obviously increases the estimated LCOE estimates, but are more realistic than studies which ignore such costs. For example, the **project indirect costs add an additional 28.8% to the mechanical and electrical costs.**

Capturing Costs as Technology Develops

First-of-a-Kind vs. Nth-of-a-Kind Methodology

- Uses approach documented by NETL (2013) where costs are:


$$\text{Cost}_{\text{NOAK}} = \text{Cost}_{\text{FOAK}} * X^{-b}$$

Where X is the cumulative number of units and b is the learning rate exponent, which is further defined as:

$$b = \frac{\log(1 - R)}{\log(2)}$$

where R is a technology-specific learning rate.


- Suggested R values as high as 0.06 for experimental technologies (e.g., fuel cells) and in the range of 0.01 for mature technologies (e.g., buildings, steam turbines, instrumentation).





Nominal LCOE Results

Levelized Cost of Energy [\$/kWh_e]



- The estimated LCOE for a 100 MWe Brayton system operating with an inlet turbine temperature of 700°C with dry cooling are **0.832 \$/kWh and 0.754 \$/kWh for a first-of-a-kind and Nth-of-a-kind plant, respectively.**
- For the 100 MWe facility, the various heat exchangers and turbomachinery account for 15% and 17% of the total costs for the nth-of-a-kind plant, respectively.
- The Nth-of-a-kind total mechanical costs for are
 - \$1320/kWe for 100 MWe
 - \$2000/kWe for 20 MWe