


# Towards High Fidelity Modeling of DER Integration to Distribution Grids

PRESENTED BY

Matthew Lave

Smart Grid Edge Analytics Workshop

June 5, 2019, Atlanta, GA






## High-fidelity – a reproduction faithful to the original

For DER integration, we mean “accurately modeled,” including:

- 1) Granular Distribution Grid Modeling
  - Phase identification
  - Topology identification and parameter estimation
- 2) Detailed Locational Impact Analysis
  - Locational hosting capacity
  - Synthetic Cloud Fields
- 3) Long-term Timeseries Analysis
  - Daily/seasonal variability in generation and impact to grid operations
  - Rapid QSTS



# Granular Distribution Grid Modeling


---

- Phase identification
- Topology identification and parameter estimation


# Phase Identification

Use Machine Learning on voltage profiles from AMI meters to cluster by phase.


## Concept



## Method




## Result



L. Blakely, M. J. Reno and W. Feng, "Spectral Clustering for Customer Phase Identification Using AMI Voltage Timeseries," 2019 IEEE Power and Energy Conference at Illinois (PECI), Champaign, IL, USA, 2019, pp. 1-7.  
doi: 10.1109/PECI.2019.8698780  
URL:<http://ieeexplore.ieee.org/stamp/stamp.jsp?tp=&arnumber=8698780&isnumber=8698776>


May confirm utility model:

## Utility Model



Phase  
Identification:  
Phase B

## Street View



| Utility Model | Phase Identification | Street View |
|---------------|----------------------|-------------|
| Phase B ✓     | Phase B ✓            | Phase B ✓   |

# Phase Identification

Or may correct model:

Utility Model



Phase  
Identification:  
Phase B

Utility Model




| Utility Model | Phase Identification | Street View |
|---------------|----------------------|-------------|
| Phase C ✗     | Phase B ✓            | Phase B ✓   |


Use AMI voltage and power measurements to derive secondary system topology and impedances.

$$V_1 - V_2 = I_{R1}R_1 + I_{X1}X_1 + I_{R2}R_2 + I_{X2}X_2 + \epsilon$$

Known      Unknown



Linear regression to find  $R_1, R_2, X_1, X_2$  values which best fit the  $V_1-V_2$  fluctuations




M. Lave, M. J. Reno and J. Peppanen, "Distribution System Parameter and Topology Estimation Applied to Resolve Low-Voltage Circuits on Three Real Distribution Feeders," in *IEEE Transactions on Sustainable Energy*.  
doi: 10.1109/TSTE.2019.2917679  
URL: <http://ieeexplore.ieee.org/stamp/stamp.jsp?tp=&arnumber=8718261&isnumber=5433168>


# Topology and Parameter Estimation

Topology and parameter estimation (DSPE) matched well with the (good) utility secondary model.


## Parameter/Topology Est.



## Utility Secondary Model




## Comparison



# Topology and Parameter Estimation

Topology and parameter estimation (DSPE) matched well with the (good) utility secondary model, even for complicated topologies.


## Parameter/Topology Est.





## Utility Secondary Model



## Comparison




For bad or nonexistent utility secondary models (common), topology and parameter estimation can be used to develop a high-fidelity secondary model.



## Result of Granular Modeling

Detailed and verified utility secondary model.





# Detailed Locational Impact Analysis


---

- Locational hosting capacity
- Synthetic Cloud Fields

## Locational Hosting Capacity

13

Concept –add more and more PV at a single node until it causes a problem – voltage, line loading, or transformer loading. The largest amount of PV that does not cause a problem is the locational hosting capacity.




Reno, Matthew J., et al. **Novel Methods to Determine Feeder Locational PV Hosting Capacity and PV Impact Signatures**. No. SAND2017-4954. Sandia National Lab.(SNL-NM), Albuquerque, NM (United States), 2017.

URL: <https://www.osti.gov/biblio/1367426>

## Locational Hosting Capacity

14

Can also apply to electric vehicles – for EVs, line loading, transformer loading, or under voltage may be more common (EVs are essentially additional loads).




## Locational Hosting Capacity

Can be applied to facilitate interconnection requests across a feeder.




Modeling many PV interconnections on a feeder is difficult: usually only 1 (or no) solar irradiance measurement available near a feeder.


## Challenge



## Impact



## Solution: synthetic cloud fields




Lave, Matthew Samuel, Matthew J. Reno, and Robert Joseph Broderick. **Creation and Value of Synthetic High-Frequency Solar Simulations for Distribution System QSTS Simulations.** No. SAND2017-5646C.

URL: <https://www.osti.gov/servlets/purl/1458093>





Synthetic PV used as input to OpenDSS to find voltage profile.





Synthetic PV used as input to OpenDSS to find voltage profile.





# Long-Term Timeseries Analysis




---

- Daily/seasonal variability in generation and impact to grid operations
- Rapid QSTS

# Variability in Generation and Impact to Distribution Grid

20


Many DERs have variable output that is not controlled by the grid operator.



# Variability in Generation and Impact to Distribution Grid

21

Timeseries analysis shows temporal impacts (e.g., voltage regulator tap change operations), and allows for full consideration of daily/seasonal trends.



Lave, Matthew, Matthew J. Reno, and Robert J. Broderick. "Characterizing local high-frequency solar variability and its impact to distribution studies." Solar Energy 118 (2015): 327-337.  
URL: <https://www.sciencedirect.com/science/article/pii/S0038092X15002881>


Speed up Quasi-Static Time Series (QSTS) analysis to enable running 1-year distribution grid simulations on a desktop computer.

### Time taken by QSTS:

$$t_{sol} = \frac{t_{PF} * N_{PF}}{CP}$$

t<sub>sol</sub> = Time taken by a single PF  
 CP = Computational Power  
 N<sub>PF</sub> = Total PFs solved

Reno, Matthew J. **Rapid QSTS Simulations for High-Resolution Comprehensive Assessment of Distributed PV**. No. SAND2018-3899C.  
 URL: <https://www.osti.gov/servlets/purl/1507939>



Speed up Quasi-Static Time Series (QSTS) analysis to enable running 1-year distribution grid simulations on a desktop computer.

- Historic methods (snapshot, no secondary, limited measurements) are insufficient.
- AMI data and other grid edge sensing provide opportunities for deriving and validating system models.
- Developments in modeling methods are simultaneously enabling more accurate distribution grid modeling and faster simulations.
- Upcoming: “QSTS hosting capacity” will simultaneously consider locational and temporal impacts of DER integration.