


Pipe Overpack Fire Testing Program

Victor Figueroa, Hector Mendoza, Scott Sanborn,
Doug Ammerman, Walt Gill, Carlos Lopez




Sandia National Laboratories is a multi-mission laboratory managed and operated by National Technology and Engineering Solutions of Sandia, LLC., a wholly owned subsidiary of Honeywell International, Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA-0003525. SAND2017-XXXXP

Pipe Overpack Container (POC)



NuCFIL® 19DS
Carbon Media Filter
(hydrogen diffusivity)



Pipe Component (PC) Contents

- Cellulose
- Rubber
- Plastic
- Metal

Motivation for New POC Fire Tests

- SNL conducted test on POC type drums in 1996-7
 - Drums torqued to 40 ft-lbs
 - To certify PC with oxides and residues, not combustibles
 - One drum lid ejected late in one of the tests
 - Aerosol Release Fraction (ARF) $\sim 10^6$
- Concern that the 1996 test data is being used, but placing combustibles inside the PC
 - Jim O'Neil (NNSA Los Alamos)/Dr. Robert Nelson (DOE-EM)
 - With combustibles, the ARF could be higher than 10^{-6}
- In 2015, SNL was contracted by DOE-EM and NNSA to conduct additional fire testing of POCs
 - Repeat the 1996: Assume drum lid either remains or gets ejected early

Test Program History

- Presented at PATRAM 2016
 - Phase I fire tests were conducted to
 - Provide temperature histories of POC components with and without drum lid
 - Phase II fire tests were focused on repeating previous tests
 - With drums torqued to ~57 ft-lbs, will the drum lid stay on?
 - Phase III fire test series conducted at the Outdoor Burn Site
 - See if any aerosol released from a POC
- New Results
 - **Phase IV-A fire test series focused on new drum lid filter**
 - NuCFIL® 19DS commonly used on POC drums was replaced with a UT9424S
 - **Phase IV-B fire test series focused on drum stacking arrangement**
 - Three stacked drums with typical pallets

SNL THERMAL TESTING FACILITIES




INDOOR FLAME FACILITY




OUTDOOR BURN SITE

Phase I – 2015

- Two tests, POC with and without a drum lid (indoor tests)
 - Drum lid torqued below specification in one of the test
 - Measured center drum temperature



Temperatures of Drum A w/o a Lid



Plastics/Rubber/Cellulose start to decompose less 400°C

Phase II – 2016

- Insulation inside the PC to simulate its thermal response
- Repeat Phase 1 with lid torqued to specification in all drums (indoor)
 - No instrumentation
- Drum lid, plastic lid liner, and Celotex/plywood dunnage get ejected






Image of fire extracted from IR Video



Remains inside the POC drum


Drum inside the Fire



Drum inside the Fire



Phase III – 2016



4.8 μ g/g
(0.1g sample
out of 400g
digested)

15 μ g/g (0.0268g
sample collected
in coupon #2)


1.2 μ g/g
(0.1g sample out
of 8.6g collected)

60 μ g/g
(0.1g sample out of
10.4g collected)



Phase IIA – Fall of FY '17

- Four 30-minute fire tests with at least one POC drum at the center of the fire
 - PCs loaded with combustibles
- Use a different filter (UT9474S):
 - Believed the plastic sleeve would melt before ejection of the lid



Typical setup for
Tests #1 and #3



Typical setup for
Tests #2 and #4


Phase IIA Fire





UT9474S Filter: Before and After




PC Pressure History



Phase III Tests: Drums Stack Arrangement



Phase III Test Setup





Phase III Results



Drum lid filters ejected, but drum lids were kept in place in all tests

PC damage ratio of zero



Summary

- With the NuCFIL® 19DS filter:
 - No issues with POC drums outside of the fire
 - Issues with POC drum is inside the fire
 - The drum lid, plastic lid, and top Celotex dunnage will be ejected
 - Very little remains of the material surrounding the PC
 - PC filter was damaged
 - Temperature inside the PC high enough to decompose materials inside PC
- With the UT9474S filter:
 - No issues with POC drums inside/outside of the fire
 - Damage Ration (DR) = 1 when the drum lid is not ejected
- Ongoing Work
 - Currently testing 7A drums with combustibles using UT9474S filter