

Core Damage Progression Uncertainty Analysis: Fukushima Daiichi Unit 1

Lucas Albright, Nathan Andrews, Larry Humphries, Randall
Gauntt, Tatjana Jevremovic

August XX, 2019

Contents



- Overview
 - Severe Accident Analysis
 - MELCOR V2.2
- Model and Simulation Overview
 - MELCOR 1F1 model
 - Plant and Boundary conditions
- Uncertainty Analysis
 - Overview
 - Uncertain parameters
- Analysis
 - Event timings
 - Core damage progression
- Summary Future Work
 - Other Units
 - Expanded study

Contents



- Overview
 - Severe Accident Analysis
 - MELCOR V2.2
- Model and Simulation Overview
 - MELCOR 1F1 model
 - Plant and Boundary conditions
- Uncertainty Analysis
 - Overview
 - Uncertain parameters
- Analysis
 - Event timings
 - Core damage progression
- Summary Future Work
 - Other Units
 - Expanded study

Severe Accident Analysis – Where are we?




- Current integral severe accident modeling capabilities allow users to model the full scope of severe accident progression, from the initiating event to the release of radioactive materials to the environment
- The general progression of accidents in water cooled reactors are well understood
- A degree of uncertainty persists due to the complex, non-linear behavior of severe accident phenomena and their models
- Calibrated, single case analyses have been a prominent tool used successfully in many studies
- Multi-case uncertainty studies, often 100's or even 1000's of cases can be evaluated, providing analysts and decision-makers with a more complete range of potential progression-end-state combinations

Severe Accident Analysis – Why?



- The goal: severe accident analysis is to develop a robust, risk-informed decision making framework in light of irreducible uncertainties
- The challenge: capturing and quantifying the uncertainty in the “unknown” unknowns.
- This study is a proof-of-concept that basic uncertainty analysis techniques can be used to develop insights into the core damage progression, key event timings, and plant end-state configurations for the accidents at Fukushima Daiichi Nuclear Power Station

MELCOR V2.2



- MELCOR has a flexible, modular design that uses the control volume approach to model severe accidents
 - Thermal hydraulic response
 - Core heat-up, degradation, and relocation
 - Molten corium-concrete interactions
 - Hydrogen production, transport and combustion
 - Fission product release and transport



Contents



- Overview
 - Severe Accident Analysis
 - MELCOR V2.2
- Model and Simulation Overview
 - MELCOR 1F1 model
 - Plant and Boundary conditions
- Uncertainty Analysis
 - Overview
 - Uncertain parameters
- Analysis
 - Event timings
 - Core damage progression
- Summary Future Work
 - Other Units
 - Expanded study



Degraded Core Components

- Location
 - Channel/Bypass
 - Lower Plenum
- Conglomerate debris
 - Refrozen candled materials
 - Previously molten materials
- Particulate debris
 - Failure of a support structure
 - Molten pool
 - Liquefaction and blockage
 - Oxidic
 - Metallic



1F1 Model and Simulation Overview

- Input deck based on BSAF Phase II Analysis
- Simulation length – 25 hours



1F1 Model Boundary Conditions



Event	Time [hours]
Safety Relief Valve (SRV) Stuck Open	Never
Main Steam Line Isolation Valve (MSIV) Closure	0.0
Feedwater System Ceases Operation	0.0
IC Train A Operation	0.1-0.28 0.52-0.55 0.63-0.67 0.77-0.8
IC Train B Operation	0.1-0.28
Wetwell Venting	23.7
Reactor Building Explosion	24.8

Contents



- Overview
 - Severe Accident Analysis
 - MELCOR V2.2
- Model and Simulation Overview
 - MELCOR 1F1 model
 - Plant and Boundary conditions
- Uncertainty Analysis
 - Overview
 - Uncertain parameters
- Analysis
 - Event timings
 - Core damage progression
- Summary Future Work
 - Other Units
 - Expanded study





- Focus only on core degradation until the point of lower head failure
 - COR and MP packages
- Number of realizations
 - $N = 400$
- Total factors varied
 - Factors = 11
- Parameters of interest
 - Material relocation conditions
 - Eutectic treatment
 - Material transport behavior
 - Heat transport in debris
- Metrics of interest
 - Changes in debris morphology
 - Debris endstate and location

Uncertain Parameters



Package	ID	Description	Distribution	Min	Max	Other
COR	SC1131(2)	Molten Material Holdup Parameters	Scaled Beta	2100	2540	alpha: 3.83 beta: 3
COR	SC 1132(1)	Core Component Failure Parameters	UO2	INT/ZRO2	INT MP	PRC
COR	SC 1141(2)	Core Melt Breakthrough Candling Parameters	Log Triangle	0.1	2.0	Mode: 0.2
COR	SC 1244 (3)	Debris Dryout Heat Flux Correlation: Minimum Debris Porosity	Log Triangle	0.015	1.5	Mode: 0.15
COR	SC 1250 (1)	Conduction Enhancement for Molten Components: Temperature above which enhancement is employed		UO2	INT/ZRO2	INT MP PRC
COR	SC 1250 (2)	Conduction Enhancement for Molten Components: Coefficient in enhancement	Log Triangle	0.001	0.1	Mode: 0.01
COR	COR_CCT	Component Critical Minimum Thicknesses	Log Triangle	1E-06	1E-04	Mode: 1E-05
COR	COR_CMT	Candling Secondary Material Transport Parameters	Uniform	0.1	1	-
COR	COR_ROD	Rod Collapse Model	-	-	-	Disabled
COR	COR_LP	Velocity of falling debris	Log Triangle	0.1	5	Mode: 1.6
MP	UO2_INT: MP_PRC	Interactive Material Melting Point	Normal	-	-	Mean: 2479 σ: 83
MP	ZRO2_INT: MP_PRC	Interactive Material Melting Point	Normal	-	-	Mean: 2479 σ: 83

Uncertainty Analysis Overview




Contents




- Overview
 - Severe Accident Analysis
 - MELCOR V2.2
- Model and Simulation Overview
 - MELCOR 1F1 model
 - Plant and Boundary conditions
- Uncertainty Analysis
 - Overview
 - Uncertain parameters
- Analysis
 - Event timings
 - Core damage progression
- Summary Future Work
 - Other Units
 - Expanded study


Primary Pressure



Containment Pressure




Hydrogen Production




Event Timings


(a) >5% Fuel Damage Failure




(b) Core Plate Failure




(c) Steam Line Failure




(d) Core Slump




(e) >90% Fuel Damage




(f) Lower Head Failure




Lower Plenum Debris



Lower Plenum Molten Debris



Ejected Debris




Summary of Key Events and 1F1 End-State: 25 Hours After Accident Initiation




Figure of Merit	Median	5 th Percentile	95 th Percentile
Steamdome Pressure [MPa]	0.542	0.537	0.544
Drywell Pressure [MPa]	0.542	0.538	0.544
Wetwell Pressure [MPa]	0.528	0.527	0.529
Integral Hydrogen Production [kg]	738.6	639.1	840.1
Mass of Particulate Debris in the Lower Plenum [MT]	2.7	0.02	5.5
Mass of Particulate Debris and Associated Conglomerate in the Lower Plenum [MT]	7.1	0.3	13.1
Mass of Oxidic Molten Pool in the Lower Plenum [MT]	0.0	0.0	0.0
Mass of Metallic Molten Pool in the Lower Plenum [MT]	0.0	0.0	0.0
Mass Ejected [MT]	81.7	60.7	145.3
Time of >5% Fuel Damage [hr]	4.7	4.0	7.3
Time of core plate Failure [hr]	6.0	4.8	10.7
Time of Main Steamline Rupture [hr]	6.1	6.1	6.1
Time of Core Slump [hr]	8.7	4.9	11.2
Time of >90% Fuel Damage [hr]	14.7	11.4	16.8
Time of Lower Head Failure [hr]	14.6	11.3	18.2


Realization 1: Lower Plenum Materials



Realization 2: Lower Plenum Materials



Realization 3: Lower Plenum Materials



Contents



- Overview
 - Severe Accident Analysis
 - MELCOR V2.2
- Model and Simulation Overview
 - MELCOR 1F1 model
 - Plant and Boundary conditions
- Uncertainty Analysis
 - Overview
 - Uncertain parameters
- Analysis
 - Event timings
 - Core damage progression
- Summary Future Work
 - Other Units
 - Expanded study

Summary



- Little variability in observed cases up to the onset of core degradation
- Increased variability in time after core degradation begins while still retaining the same accident signatures and general progression
- Results agree with past best estimate predictions of key event timings for the severe accident at 1F1
- Results indicate that most of the material relocated to the lower plenum is solid particulate debris and refrozen conglomerate
- Short molten pool lifetimes and smaller molten pool masses relative to solid debris, especially for oxidic molten pools
- The molar composition of debris in the lower plenum at the time of lower head failure through analyzing several individual realizations is found to be: SS 0.22 – 0.31; Zr 0.20 – 0.24; ZrO_2 0.14 – 0.17; UO_2 0.27 – 0.33; INC, B_4C , and SSOX account for ~0.05 of the debris combined



Future Work



- Refinement and expansion of uncertain parameters
 - Include system response
 - Water injection
 - Leakages
 - Event Timings
 - Potential inclusion of other uncertain parameters
 - Focus on heat transfer models
- Comparison with similar study performed using the eutectics model
- In-depth characterization of the lower plenum debris composition
- Increased population size and simulation length
 - 1000s, not 100s of runs
 - 150 - 500 hours after accident initiation
- Similar analyses will be performed for 1F2 and 1F3



References



1. OECD Nuclear Energy Agency, "Benchmark Study of the Accident at the Fukushima Daiichi," NEA/CSNI/R(2015)18, 2015.
2. N. C. Andrews and R. O. Gauntt, "Insights Gained from Forensic Analysis with MELCOR of the Fukushima-Daiichi," Sandia National Laboratories, Albuquerque, NM, 2017.
3. L. L. Humphries, B. A. Beeny, F. Gelbard, D. L. Louie and J. Phillips, "MELCOR Computer Code Manuals Vol. 1: Primer and Users' Guide," U.S. Nuclear Regulatory Commission, Washington, D.C., 2017.
4. L. L. Humphries, B. A. Beeny, F. Gelbard, D. L. Louie and J. Phillips, "MELCOR Computer Code Manuals Vol. 2: Reference Manual," U.S. Nuclear Regulatory Commission, Washington, DC, 2017.
5. "State-of-the-Art Reactor Consequence Analyses Project: Uncertainty Analysis of the Unmitigated Long-Term Station Blackout of the Peach Bottom Atomic Power Station," U.S.NRC, Washington D.C., 2010.
6. "State-of-the-Art Reactor Consequence Analyses Project, Volume 1: Peach Bottom Integrated Analysis," U.S.NRC, Washington, D.C., 2013.
7. J. Cardoni, "Radionuclide Inventory and Decay Heat Quantification Methodology for Severe Accident Simulations," Sandia National Laboratories, Albuquerque, NM, 2014.

Acknowledgements



This work was jointly supported by the U.S. DOE-NE IUP Fellowship Program and the United States Nuclear Regulatory Commission. The views expressed in the article do not necessarily represent the views of the U.S. Department of Energy or the United States Government.

Sandia National Laboratories is a multimission laboratory managed and operated by National Technology & Engineering Solutions of Sandia, LLC, a wholly owned subsidiary of Honeywell International Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA0003525.

Thank you for your attention

1F1 Plant Parameters



Plant Parameter	Value
Rated Core Power [MW _{th}]	1380
Total RPV water inventory [kg]	147634
Number of fuel assemblies [#]	400
Number of control blades [#]	97
Total Mass of UO ₂ [kg]	77,403
Total Zircaloy Mass [kg]	30,431
Total Mass of Stainless Steel [kg]	47,767
Total Mass of B ₄ C [kg]	540
Mass of active region Zircaloy cladding [kg]	16779
Mass of upper core, non-active region Zircaloy cladding [kg]	2202
Mass of lower core, non-active region Zircaloy cladding [kg]	0
Mass of Zircaloy in fuel canister [kg]	11,451
Mass of stainless steel in control blades [kg]	9,000
Mass of stainless steel in top guide tube and upper tie plate [kg]	4,420
Mass of stainless steel in core support plate and "elephant's foot" [kg]	8,880
Mass of lower plenum structures [kg]	25,467

