

BSAF Phase II Final Results

Nathan Andrews, Troy Haskin, Christopher Faucett,
Randall Gauntt, Nathan Bixler, Dan Clayton




Sandia National Laboratories is a multimission laboratory managed and operated by National Technology and Engineering Solutions of Sandia, LLC, a wholly owned subsidiary of Honeywell International, Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA0003525.

Overview of BSAF Phase II





- Benchmark Study of the Accident at the Fukushima Daiichi Nuclear Power Station (BSAF) Project
 - Completed project
 - Currently drafting final report
- Three separate three week long MELCOR simulations
 - 1F1
 - 1F2
 - 1F3
- Single, combined MACCS simulation of the three MELCOR simulations
 - 2017 WRF Data
 - High-level benchmark of both:
 - Release to the environment from MELCOR
 - Dispersion and subsequent deposition following release











- **Reactor, Containment, Building, Venting Systems, Spent Fuel Pools**
- **Core Degradation and Severe Accident Phenomenology**
- **Operator Actions and Decisions**
- **Leakage Pathways and Component Failures**
- **Engineered Safety Features**
- **Fission Product Modeling**
- **Release and Source Terms**



MELCOR Core Abstraction



MELCOR Core Degradation Process – 1F1




RB & PCV Nodalization





Source: Tokyo Electric Power Company




FINAL 1F1 ANALYSES


Key Assumptions in 1F1

- Scenario assumptions
 - Main steam line break at 6.1 hours
 - Lower head failure at 10.5 hours
 - Vent at 23.5 hours
 - Explosion at 24.8 hours
- Determination of long-term water injection into containment
 - Monotonically increasing longterm leakage area, approximating liner melt-through
 - Beginning at 50 hours and increasing as indicated by TEPCO provided drywell pressure data
 - Varied alternative water injection rates to match drywell pressure trends when leakage area alone was not sufficient to match pressure


RPV Pressure




Drywell Pressure




Drywell Pressure




Injection




In-Core Hydrogen Generation



Combustible Gas Generation




RN Release Fractions to Environment





Source: Tokyo Electric Power Company




UPDATE OF 1F2 ANALYSES


Key Assumptions in 1F2

- Scenario assumptions
 - RCIC operation until 70 hours
 - Fuel failures at 79.9 hours
 - Lower head penetration failure at Ring 4
 - Containment failure at 89.9 hours
- Three-peaks period
 - Insight into core degradation process
 - Complex and requires understanding
 - Core degradation
 - SRV behavior
 - Water level
- Containment failure through a penetration on the 4th ring of the lower head


System Pressures




1F2 “Three Peaks” Results




Drywell Pressure



Drywell Pressure




RN Release Fractions to Environment





Source: Tokyo Electric Power Company




UPDATE OF 1F3 ANALYSES


Key Assumptions in 1F3

- Scenario assumptions
 - RCIC operation followed by HPCI operation
 - MSL rupture at 42.1 hours, 16.25% of pipe area
 - Fuel collapse
 - Ring 1: 43.2
 - Ring 2+3: 45.3
 - Containment failure at 58.1 hours
- Determination of long-term water injection into containment
 - Varied alternative water injection rates to match drywell pressure trends
 - Longterm leakage area, approximating progressive degradation, when leakage area alone was not sufficient to match pressure


RPV Pressure




RPV Pressure




Drywell Pressure



Drywell Pressure




RN Release Fractions to Environment





Source: Tokyo Electric Power Company




Combined 1F Atmospheric Dispersion and Deposition

MACCS ANALYSIS

Coupled MELCOR & MACCS


Assessment of Fukushima-Daiichi Accidents

1F1




- Evaluate viability of SNL MELCOR source terms by reasonably replicating ground deposition patterns
 - Focus on Cs-137
 - Specific focus on deposition toward the northwest
 - Also focus on overall deposition pattern
- Provide guidance in release timing and magnitude for source term analysts
- Benchmark models against real data
 - HYSPLIT particle tracking model

1F2




1F3




Coupled MELCOR & MACCS


Assessment of Fukushima-Daiichi Accidents

Observed Deposition



MELCOR/MACCS Predicted Deposition





QUESTIONS AND COMMENTS?

1F2 “Three Peaks” Data


- First Peak
 - Behavior: gradual, continuous RPV pressure increase with an SRV-like decrease coincident with a DW pressure increase
 - Assumed cause: SRV valve closure and re-open
- Second Peak
 - Behavior: sharp 2.7[MPa] spike in RPV pressure in a 10[min] window; a steady (linear) pressurization over 30[min]; rapid decrease in pressure; continuous DW pressure increase over the time
 - Assumed cause: Core collapse with SRV failure-to-close
- Third peak
 - Behavior: gradual, continuous RPV pressure increase with an SRV-like decrease
 - Assumed cause: SRV valve closure and re-open

1F2 “Three Peaks” Modelling


- First Peak
 - At 75.98[hr], SRV closes, experiences failure-to-close
 - Varied between 0.008 to 0.05 open fraction prior to full-open
 - At 78.52[hr], full-open actuation (2 SRVs per BSAF event sequence)
- Second Peak
 - At 79.9[hr], Ring 1 collapse for sharp increase in pressure
 - SRV closes, experiences failure-to-close
 - From 80[hr] to 80.71[hr], open fraction varies between 0.0001 and 0.0025
 - Allows steam pressurization without pressure excursion
 - At 80.84[hr], full-open actuation (second SRV assumed 0.5[-] open)
- Third Peak
 - At 81.31[hr], SRV experiences failure-to-close with 0.015 open fraction
 - At 82.24[hr], full-open actuation (1 SRV)

In-Core Hydrogen Generation


1F2




Alternative Water Injection



Core Water Level



Alternative Water Injection



In-Core Hydrogen Generation

