



# Comparisons of Design Changes on Footprint of Hydrogen Refueling Stations for Urban Sites

Brian Ehrhart

Gabriela Bran Anleu, Dongmei Ye, Ethan Hecht

Sandia National Laboratories

2019 Fuel Cell Seminar & Energy Exposition

Long Beach, CA

November 6, 2019

SAND2019-XXXX PE

This presentation does not contain any proprietary, confidential, or otherwise restricted information

Sandia National Laboratories is a multi-mission laboratory managed and operated by National Technology and Engineering Solutions of Sandia, LLC., a wholly owned subsidiary of Honeywell International, Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA0003525.



Sandia National Laboratories




Hydrogen Fueling Infrastructure Research Station Technology

- Past and current hydrogen refueling stations in California have capacities of 350 kg/day (or less)
  - Higher capacity stations needed to meet increasing demand
- Past stations with liquid hydrogen (LH<sub>2</sub>) storage range from 30,000 to >100,000 ft<sup>2</sup>
  - Urban locations require much smaller footprints
- **DOE FCTO Target: Reduce footprint of liquid stations by 40% by 2022, relative to 2016 baseline**
- Objective:
  - Create compact gaseous and liquid hydrogen reference station designs appropriate for urban locations, enabled by design changes and near-term technology and fire code changes


# Approach: Develop base cases and assess relative impact of non-compliance/technology improvements



- Focus on **reducing station footprint**
  - Previous reference station analyses focused on system layout, physical footprint, and cost
- Simplified, generic, rectangular stations
  - All requirements and setback distances met
- Make **comparisons** to base case designs for
  1. Delivered gas,
  2. Delivered liquid, and
  3. On-site production via electrolysis
- Assess the impact of:
  - New code requirements
  - New delivery methods
  - Gasoline refueling station co-location
  - Underground storage
  - Roof-top storage
  - Performance-based designs



# Specified components needed for three methods of hydrogen supply




1. Fueling stations supplied by LH<sub>2</sub> may utilize cryopumps in the long-term. Compressors were assumed for simplicity of modeling, as the footprint associated with a pump is likely to be comparable.

- Compressor
  - 25 kg/hr flow rate (constant 600 kg/day)
  - Outlet pressure of 94.4 MPa (13,688 psi)
- Chillers
  - 25.2 kW (7.2 tons) of refrigeration needed for each chiller
  - Aluminum cooling block of 1,330 kg (0.49 m<sup>3</sup>) needed for each
- Cascade
  - 10 cascade units, each containing 5 (1:1:3) pressure vessels
  - Outlet flow rate 60 kg/hr to each dispenser
- Dispensing
  - 4 fueling positions, 70 MPa, -40°C




## Base Case Gas: Delivery truck path (rather than setback distances) extends lot in two dimensions



- Lot Size: 126 x 140 ft
- Total Area: 17,640 ft<sup>2</sup>


*(Slightly larger than median of [small sample of] existing urban gas stations)*



# Base Case Electrolysis: Small footprint without delivery




- PEM electrolyzer (nominal 2 MW)
  - Sized for 24 hour/day use
  - Buffer storage used to smooth flow from electrolyzer to compressor
- No delivery truck
  - Greatly reduces footprint
  - Could reduce resiliency
    - No direct way to delivery emergency hydrogen if electrolyzer is down
- Lot Size: 117 x 103 ft
- Total Area: 12,051 ft<sup>2</sup>



Sandia National Laboratories

# Base Case Liquid: Large footprint due to delivery truck and non-reducible 75 ft. air intakes setback



- Bulk liquid storage
  - 800 kg, 11,299 L (2,985 gal)
- Lot size: 170 x 125 ft
- Total Area: 21,250 ft<sup>2</sup>



Sandia National Laboratories



Hydrogen Fueling Infrastructure Research Station Technology 7

# Identified challenges in interpretation and implementation of NFPA 2 leading to code updates



## Gaseous setback distances

- Large system can have “bulk storage” before and after compressor
- Complexity of system makes selection of single pressure and diameter challenging
  - Single system could take worst-case: maximum pressure from one area and maximum ID from other area
  - Could also calculate setback distances for each system section and select largest
    - In Appendix I, but nowhere else

*Calculations for larger system may lead to unintended setback distances*

## Liquid setback distances

- Hybrid system (liquid-to-gas) analyzed as all-liquid system
  - *Recently changed in 2020 Ed. of NFPA 55/2*
- Setback distances are different for most exposures, only a few able to be reduced

Group	Exposure	Reducible	Distance
1	1 Lot lines	Yes	15 m (50 ft)
	2 Air intakes		23 m (75 ft)
	3 Operable openings in buildings		23 m (75 ft)
	4 Ignition sources		15 m (50 ft)
2	5 Places of public assembly		23 m (75 ft)
	6 Parked cars		1.7 m (25 ft)
3	7(a)(1) Sprinklered non-combustible building	Yes	1.5 m (5 ft)
	7(a)(2)(i) Unsprinklered, without fire-rated wall	Yes	15 m (50 ft)
	7(a)(2)(ii) Unsprinklered, with fire-rated wall	Yes	1.5 m (5 ft)
	7(b)(1) Sprinklered combustible building	Yes	15 m (50 ft)
	7(b)(2) Unsprinklered combustible building	Yes	23 m (75 ft)
	8 Flammable gas systems (other than H2)	Yes	23 m (75 ft)
	9 Between stationary LH2 containers		1.5 m (5 ft)
	10 All classes of flammable and combustible liquids	Yes	23 m (75 ft)
	11 Hazardous material storage including LO2	Yes	23 m (75 ft)
	12 Heavy timber, coal	Yes	23 m (75 ft)
	13 Wall openings		15 m (50 ft)
	14 Inlet to underground sewers		1.5 m (5 ft)
	15a Utilities overhead: public transit electric wire		15 m (50 ft)
	15b Utilities overhead: other overhead electric wire		7.5 m (25 ft)
	15c Utilities overhead: hazardous material piping		4.6 m (15 ft)
	16 Flammable gas metering and regulating stations		4.6 m (15 ft)




# Developed new designs and compared them to base cases, based on a range of assumptions



- **Effects of 2020 Edition of NFPA 2**
  - Significant impact on minimum footprint
  - But other factors (traffic and delivery truck path) reduce impact on full layout
- **Alternate Delivery**
  - Smaller delivery trucks greatly reduce footprint
  - Higher pressure can maintain delivery capacity
- **Gasoline Co-Location**
  - Needs to meet NFPA 2/55 and NFPA 30/30A
  - Space for underground gasoline tanks and additional dispensers

*Different design changes have different impacts on station footprints*



Sandia National Laboratories

# Created elevated and underground storage station designs that reduce footprint






## Underground Storage

- Direct burial
- Vault
- Only buried components eliminate setbacks

## Elevated Storage

- Setback distances still apply to line-of-sight
- Very large weight of equipment
- Seismic loading and aesthetics are issues



Sandia National Laboratories



Hydrogen Fueling Infrastructure Research Station Technology 10

# Summary of lot sizes for all cases



Design	Total Lot Area (ft <sup>2</sup> )	Reduction from Base Case
Delivered Gas	Base Case Gas	17,640
	New NFPA Separation Distances	17,640
	New Delivery Single Truck	14,391
	New Delivery Double Truck	15,875
	Gasoline Co-Location	21,980
	Underground Direct-Bury	16,060
	Underground Vault	13,720
	Rooftop Storage	15,400
Delivered Liquid	Base Case Liquid	21,250
	New NFPA Separation Distances	18,252
	New Liquid Delivery	19,080
	Gasoline Co-Location	<b>25,330</b>
	Underground Direct-Bury	15,515
	Rooftop Storage	19,840
On-Site Electrolysis	Base Case	14,756
	New NFPA Separation Distances	<b>11,934</b>
	Gasoline Co-Location	21,980
	Underground Direct-Bury	13,340
	Underground Vault	16,240
	Rooftop Storage	11,466



## Siting results on delivered gas designs

- 7 cities in 5 states
  - CA, CT, MD, MA, NY
- Total of 227 gasoline stations analyzed
  - Located using Google Maps
- Lot size of each station obtained from county property tax records
- The lot size was compared to generic station designs
- The number of available stations that can be converted into hydrogen stations was identified

*Illustrates potential effect of reduction in lot sizes*

Design	Lot Area (ft <sup>2</sup> )	Reduction from Base Case	Lots available (out of 227) [%]
Base Case Gas	17,640	--	77 [34%]
New NFPA Separation Distances	17,640	0.00%	77 [34%]
New Delivery Single Truck	14,391	18.42%	107 [47%]
New Delivery Double Truck	15,875	10.01%	88 [39%]
Gasoline Colocation	21,980	-24.60% (increase)	52 [23%]
Underground Direct-Bury	16,060	8.96%	88 [39%]
Underground Vault	13,720	22.22%	112 [49%]
Rooftop Storage	15,400	12.70%	97 [43%]


# Demonstrated simplified economic impact of station design changes for underground



## Gaseous hydrogen underground direct-bury

- Sub-set of 40 gasoline stations analyzed
- Land unit price (\$/ft<sup>2</sup>) calculated from county property tax records
- Underground direct-bury cost estimated from underground propane tank installation cost: \$45.8/ft<sup>2</sup>
- Break-even line determined by ratio of burial area and the difference of lot size between base case and underground burial designs
- Multiple possible burial costs considered to show sensitivity vs land unit price

*Illustrates potential economic trade-off of design change relative to base case*




# Performed real station co-location case study to show impact of site-specific features



- San Francisco station on a corner
  - Delivery truck path is simplified
- One vehicle entry/exit blocked by hydrogen system
  - Still has 3 remaining
- Electrical cabinet was moved
- Air intakes on roof of convenience store would have to be moved
  - Must be 38 feet from hydrogen system

	SF Site Colocation	Generic Co-location
Lot Size	18,000 ft <sup>2</sup>	21,000 ft <sup>2</sup>
Convenience store size	3,256 ft <sup>2</sup>	1,500 ft <sup>2</sup>
Dispenser island	2,668 ft <sup>2</sup>	1,600 ft <sup>2</sup>

*Real-world locations will differ from generic designs*



- **Relevance and Impact**
  - Reduction of refueling station footprint identified by FCTO and H2USA as high priority
- **Approach**
  - Comparison of different design changes to base cases quantifies impact
  - Changes include NFPA 2 code changes, gasoline co-location, alternate delivery truck, underground storage, and risk-informed designs
- **Accomplishments and Progress**
  - 600 kg/day stations completed for delivered gas, delivered liquid, and on-site electrolysis
  - Footprints quantified for base cases, alternate delivery, upcoming fire code changes, underground and elevated storage, and gasoline co-location
  - Real-world co-location case study on San Francisco gas station
  - Siting study in US cities in California and Northeast shows impact of station lot size changes
  - Economic comparison shows trade-off trends for design changes over wide range of sensitivity
- **Future Work**
  - Final report preparation



## TECHNICAL BACK-UP SLIDES



Sandia National Laboratories



Hydrogen Fueling Infrastructure Research Station Technology 16

# Collaborations



- H2FIRST itself is a **SNL-NREL** co-led, collaborative project and members of both labs contributed heavily to this project.
- To be as relevant and useful as possible, the project integrates input and feedback from many stakeholders, such as:

- H2USA's Hydrogen Fueling Station Working Group **H2USA**
- California Fuel Cell Partnership
- California Energy Commission 
- California Air Resources Board 
- UC Berkeley 
- Argonne National Lab 
- H2 Logic 

- Hydrogenics 
- ITM Power 
- Linde 
- Nuvera 
- PDC Machines 
- Proton OnSite 
- Siemens AG 
- FirstElement 




# Non-hydrogen station components have large impact on footprint



## Assumptions and considerations:

- Delivery truck path
  - Trucks must be capable of turning without reversing
  - Corner lot not considered (entry and exit only on single lot side)
- Convenience store
  - 50 x 30 ft
- Parking/Traffic Flow
  - Convenience store parking
  - Fueling positions
  - UT Parking Lot Design Manual
- Kept consistent between designs
- System was idealized for comparison
  - Other location-specific factors will also have large impact on footprint



Texas DOT Road Design Manual



Sandia National Laboratories





Hydrogen Fueling Infrastructure Research Station Technology

## Alternative means



- Determine what performance criteria is applicable to each exposure.
  - NFPA 2 Annex I Table I.2(c) and (d) were used to determine the performance criteria and the hazardous material scenario
- Get numerical values that can be used to determine the separation distances for each exposure
  - Heat flux
  - Hydrogen flammable concentrations
  - Frequency of fatalities

Exposure	Heat flux	Notes
Personnel	1,577 W/m <sup>2</sup>	Threshold to which personnel with appropriate clothing can be continuously exposed. Used as the “no harm” value.
Personnel	4,732 W/m <sup>2</sup>	Threshold for exposure to employees for a maximum of 3 minutes.
Combustible materials	20,000 W/m <sup>2</sup>	Minimum heat flux for the nonpiloted ignition of combustible materials, such as wood.
Non-combustible materials	25,237 W/m <sup>2</sup>	Threshold heat flux imposed by the International Fire Code for noncombustible materials.




# Accomplishment: Minimum footprint determined from outdoor bulk gas setback distances



- Minimum Footprint
  - Hydrogen system only
- Based on pressure and ID of connecting piping

Grp	Description
1	a Lot lines
	b Air intakes (HVAC, compressors, other)
	c Operable openings in buildings and structures
	d Ignition sources such as open flames and welding
2	a Exposed persons other than those servicing the system
	b Parked cars
3	a Buildings of noncombustible non-fire-rated construction
	b Buildings of combustible construction
	c Flammable gas storage systems above or below ground
	d Hazardous materials storage systems above or below ground
	e Heavy timber, coal, or other slow-burning combustible solids
	f Ordinary combustibles, including fast-burning solids such as ordinary lumber, excelsior, paper, or combustible waste and vegetation other than that found in maintained landscaped areas
	g Unopenable openings in building and structures
	h Encroachment by overhead utilities (horizontal distance from the vertical plane below the nearest overhead electrical wire of building service)
	i Piping containing other hazardous materials
	j Flammable gas metering and regulating stations such as natural gas or propane



*Different Exposures Have Very Different Setback Distances*



# Accomplishment: Minimum footprint for outdoor bulk liquid differs significantly from gas



- Based on total amount of bulk liquid hydrogen
  - Not pressure or diameter of piping
- Groups 1, 2, and 3 still exist, but setback distances are not grouped

Exposure	Distance
1 Lot lines *	15 m (50 ft)
2 Air intakes	23 m (75 ft)
3 Operable openings in buildings	23 m (75 ft)
4 Ignition sources	15 m (50 ft)
5 Places of public assembly	23 m (75 ft)
6 Parked cars	1.7 m (25 ft)
7(a)(1) Sprinklered non-combustible building*	1.5 m (5 ft)
7(a)(2)(i) Unsprinklered, without fire-rated wall*	15 m (50 ft)
7(a)(2)(ii) Unsprinklered, with fire-rated wall*	1.5 m (5 ft)
7(b)(1) Sprinklered combustible building*	15 m (50 ft)
7(b)(2) Unsprinklered combustible building*	23 m (75 ft)
8 Flammable gas systems (other than H <sub>2</sub> )*	23 m (75 ft)
9 Between stationary LH <sub>2</sub> containers	1.5 m (5 ft)
10 All classes of flammable and combustible liquids*	23 m (75 ft)
11 Hazardous material storage including LO <sub>2</sub> *	23 m (75 ft)
12 Heavy timber, coal*	23 m (75 ft)
13 Wall openings	15 m (50 ft)
14 Inlet to underground sewers	1.5 m (5 ft)
15a Utilities overhead: public transit electric wire	15 m (50 ft)
15b Utilities overhead: other overhead electric wire	7.5 m (25 ft)
15c Utilities overhead: hazardous material piping	4.6 m (15 ft)
16 Flammable gas metering and regulating stations	4.6 m (15 ft)



- Project challenge: Station design choices are based on code requirements for general hazards applicable to all stations
  - Choice of basis affects resulting requirements
  - Difference between alternative means and performance-based design
- Industry challenge: Current setback distances only take credit for fire-rated wall
  - Other active or passive prevention or mitigation measures considered only on a case-by-case basis
  - Project challenge: no way to incorporate these credits into generic station designs
- Project challenge: Siting and economics are specific to each particular location
  - Illustrative comparisons are useful for showing trends