



Life Cycle Testing and Evaluation of Energy Storage Devices

Summer Ferreira, Wes Baca, Tom Hund
and David Rose
September 28, 2012



Sandia
National
Laboratories

*Exceptional
service
in the
national
interest*

The authors gratefully acknowledge the support of Dr. Imre Gyuk and the Department of Energy's Office of Electricity Delivery & Energy Reliability.



U.S. DEPARTMENT OF
ENERGY



Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000. SAND NO. 2011-XXXX

Mission:

Provide reliable, independent, third party testing and verification of advanced energy technologies for cells to MW systems

Problem:

- Current testing methods are inconsistent and the results confusing
- Potential storage customers, i.e. utilities, without experience in storage, are reluctant consumers.

Approach:

Develop advances through:

- exploration of test protocols, through direct research and standards activities
- high precision testing

Provide ongoing:

- expertise in testing programs to customers
- verification of specific technologies

SNL Energy Storage System Analysis Laboratory



Providing reliable, independent, third party testing and verification of advanced energy technologies for cell to MW systems

Testing Capabilities Include:

Expertise to design test plans to fit technologies and their potential applications

Cell, Battery and Module Testing

- 14 channels from 36 V, 25 A to 72 V, 1000 A for battery to module-scale tests
- Over 125 channels; 0 V to 10 V, 3 A to 100+ A for cell tests
- Potentiostat/galvanostats for spectral impedance
- Multimeters, shunts and power supply for high precision testing
- Temperature chambers
- IR camera



72 V 1000 A Bitrode (2 Channels)



Energy Storage Test Pad (ESTP)

System Testing

- Scalable from 5 KW to 1 MW, 480 VAC, 3 phase
- 1 MW/1 MVAR load bank for either parallel microgrid, or series UPS operations
- Subcycle metering in feeder breakers for system identification and transient analysis

Analysis Laboratory capabilities include:

- 125+ Cell test channels: 0 V to 10 V, 3 A to 100+ A
- 14 Battery test channels: 36 V, 25 A to 72 V, 1000 A

Expanded Capabilities in FY '12:

- **34 test channels from 5 V – 60 V to 15 A – 500 A**
- **Potentiostat/galvanostats for spectral impedance**
- **Multimeters, shunts and power supply for high precision testing**
- **Temperature chambers**
- **IR camera**

Expanded number of test channels by 25% including other lab capabilities



72 V 1000 A Bitrode (2 Parallel Channels)

Standards Activities



DOE Performance Protocol

- Working closely with PNNL, and have input from utility and manufacturing side




IEC

- CENELEC Workshop Agreement for Flow Batteries
- International Standard IEC 61427-2 Secondary Cells and batteries for renewable energy storage – Part 2: On-grid applications





Last Peer Review saw repeated calls for standard language and testing, with definitions. In response standards development has been a large priority in the past year

Cycling protocols employed in testing




VRLA Life cycle data S. Drouilhet, B.L. Johnson, 1997 NREL




Waveform Testing


State of the Art: Frequency Regulation




State of the Art: Load Leveling



Stacked Applications: Working with KEMA



Stochastic Application Modeling:



Future Projects



CUNY: Ni-Zn Flow battery modules August 2013



AllCell: Test Program under consideration



Encell: Testing anticipated February 2012



Altairnano: Generation II 13 Ah cells; Generation III 14 Ah



LiFe Batt: Cost share agreement for testing new generation



3rd party testing open to researchers and manufacturers in FY 2013

Summary of completed testing activities



East Penn


East Penn Ultrabattery® Module
20,347 10% PSOC utility cycles
422 Days and 229 PV deep discharge cycles



Furukawa



FurukawaUltrabattery® Module
7,012 10% PSOC utility cycles
498 Days and 280 PV deep discharge cycles

East Penn Ultrabattery® under Utility cycling performs well



Ultrabattery® performs much longer than VRLA


PSOC Utility Cycling



Furukawa Ultrabattery® operated at elevated temperatures, likely leading to thermally activated degradation

East Penn Ultrabattery® ran for more than 20,000 cycles without recovering the battery

Ultrabatteries® also perform much longer in energy applications than VRLA



Even at 40 day deficit charge, Ultrabatteries® have performance far surpassing traditional VRLA batteries even with as low as a 7 day deficit charge (without recovery by taper charge).

Ongoing testing activities

Cell Level Testing



East Penn Advanced
Battery Cells
(D. Enos 10:50 AM Thur.)



Altairnano Lithium-
titanate oxide cells
40,000 10% PSOC



International Battery
Li-FePO₄ Cells
20,000+ 10% PSOC

Module Level Testing




RedFlow 10kWh Zn-Br flow battery
module and system
(D. Rose)

International battery cell at 27K+ cycles



International battery Li-ion
 FePO_4 large format
prismatic 160 Ah cells




15% capacity loss after 27,000+ cycles

Altairnano Characterization

	Average	Standard Deviation
Capacity (Ah)	12.58	0.06
Voc (V)	2.531	0.006
R ($\mu\Omega$)	2642	147
Mass (kg)	0.367	0.001
3 Month Self Discharge	4.825%	0.025%




Lithium-titanate oxide cells




Altairnano Cycle-Life

2C 10% Utility cycles without rests



94% of initial capacity after 36K 10% PSOC utility 2C cycles without rests

100% DOD Cycles



Over 4,000 full discharge cycles at 2C rate.

Summary/conclusions to date

- Current advanced batteries are completing over 10,000 10% cycles with little loss in capacity, currently at over 40,000 cycles for Altairnano.
- Anticipate longer testing to reach EOL so we are exploring testing paths. More aggressive tests, and varied protocols including stacked testing under investigation.
- Participation in standards activities is becoming a priority; as we heard at last Peer Review a recurring call for standard language and testing.

Contact Information:

To take advantage of Sandia testing services or consultation:

Summer Ferreira: srferre@sandia.gov

Advanced Power Sources R&D

Manager Thomas Wunsch tfwunsc@sandia.gov

With grateful acknowledgment of Dr. Imre Gyuk for support of storage testing


SNL Battery Abuse Testing Laboratory

Sanjour
National
Laboratories

Battery testing, cell measurements, and materials development to support the development of inherently safe lithium-ion chemistries

- Safety and abuse tolerance evaluation of energy storage devices from cells to kWh batteries:
 - Mechanical abuse
 - Thermal abuse
 - Electrical abuse
- Understanding degradation mechanisms that lead to cell failure
- Provide experimental data to support abuse and thermal modeling
- Cell prototyping facility for materials development

Understanding abuse tolerance




50 Wh failure event



5 Wh failure event


Waveform Testing



Precision Testing Motivated by Jeff Dahn Group



Custom high-precision testers



Coulombic efficiency may be used to understand how cell chemistry affects performance, and even predict cycle life after minimal cycling.

FY11 Testing of Ultrabattery® modules



East Penn


- Both Ultrabattery® designs incorporate a supercapacitor in parallel with the negative electrode in a VRLA 12 cell, 1,000 Ah, 24V battery module.
- Tested with both a 'PV' and 'utility' cycle.



Furukawa

East Penn Ultrabattery® performs much longer than VRLA



PSOC Utility Cycling



Furukawa Ultrabattery® operated at elevated temperatures, likely leading to thermally activated degradation; capacity dropped below 80% of initial by 6,300


East Penn Ultrabattery® ran for more than 20,000 cycles without recovering the battery; cycling ended when temperatures rises prevented operation.

Elevated temperatures occurred in Furukawa Ultrabattery®




Furukawa Ultrabattery® operated at elevated temperatures, leading to thermally activated degradation


Efficiency drops between capacity (recovery) cycles




FW voltages in final utility cycling





Altairnano Characterization



Altairnano Characterization



Individual Application Test Protocols



Stacked Waveform Testing:

