

Nonradioactive Air Emissions Notice of Construction for Removal of 340A Building Tank Solids

Date Published
February 1997



United States
Department of Energy

P.O. Box 550
Richland, Washington 99352

Approved for Public Release

THIS PAGE INTENTIONALLY
LEFT BLANK

THIS PAGE INTENTIONALLY
LEFT BLANK

3-28-97

INFORMATION RELEASE REQUEST - (Long Form)

5

(GRAY SHADED AREAS NOT TO BE FILLED IN BY INITIATOR)

1. COMPLETE THIS SECTION FOR ALL DOCUMENTS

A. Information Category		B. Document ID Number (include rev., vol., etc.)
Speech or Presentation		DOE/RL-97-15, REV. 0
<input type="checkbox"/> Full Paper	<input type="checkbox"/> Journal Article	C. List attachments (i.e., copyright permission, copyright transfer)
<input type="checkbox"/> Summary	<input type="checkbox"/> Multimedia Presentation	
<input type="checkbox"/> Abstract	<input type="checkbox"/> Software	
<input type="checkbox"/> Visual Aid		
<input checked="" type="checkbox"/> Other <u>NOC</u>		

D. Document Title	E. WHC Project or Program
Nonradioactive Air Emissions Notice of Construction for Removal of 340A Building Tank Solids	300 Area Liquid Effluent Facilities

F. New or novel (patentable) subject matter? If "Yes", has disclosure been submitted by WHC?	<input checked="" type="checkbox"/> No or Yes	G. Information received from others in confidence, such as proprietary data, and/or inventions?	<input checked="" type="checkbox"/> No or Yes
<input type="checkbox"/> No or Yes If "Yes", Disclosure No(s):		<input checked="" type="checkbox"/> No or Yes	If "Yes", contact WHC General Counsel.

H. Copyrights?	<input checked="" type="checkbox"/> No or Yes	If "Yes", attach permission.	I. Trademarks?	<input checked="" type="checkbox"/> No or Yes	If "Yes", identify in document.
----------------	---	------------------------------	----------------	---	---------------------------------

2. COMPLETE THIS SECTION FOR ALL DOCUMENTS REQUIRING SUBMISSION TO OSTI

A. Unclassified Category	UC - 630	B. Budget & Reporting Code	B&R - A234K
--------------------------	----------	----------------------------	-------------

3. COMPLETE THIS SECTION ONLY FOR A JOURNAL SUBMISSION

A. Title of Journal

4. COMPLETE THIS SECTION ONLY FOR A SPEECH OR PRESENTATION

A. Title for Conference or Meeting	B. Group or Society Sponsoring
C. Date(s) of Conference or Meeting	D. City/State
	E. Will material be published in proceedings?
	Will material be handed out?
	<input checked="" type="checkbox"/> No or Yes
	<input checked="" type="checkbox"/> No or Yes

5. REVIEWS

Reviewers	Yes	Signature Indicates Approval as Requested unless otherwise indicated Name (Print)	Signature/Date	Limited-Use Info.
General Counsel	<input checked="" type="checkbox"/>	C. Willingham	<i>C. Willingham</i> 3-28-97	<input type="checkbox"/>
DOE-RL	<input checked="" type="checkbox"/>	See attached approval letter		<input type="checkbox"/>
Communications	<input type="checkbox"/>			<input type="checkbox"/>
Applied Technology-Export Controlled Information or International Program	<input type="checkbox"/>			<input type="checkbox"/>
Other	<input type="checkbox"/>			<input type="checkbox"/>
Other	<input type="checkbox"/>			<input type="checkbox"/>

6. Applied Technology Material Referenced	<input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes	INFORMATION RELEASE ADMINISTRATION APPROVAL
---	--	------------------------------	---


7. Release Level	<input checked="" type="checkbox"/> Public	<input type="checkbox"/> Limited Distribution	IRA Approval is required before release. Release is contingent upon resolution of mandatory comments. NOTE: This block for IRA use only.
------------------	--	---	--

8. Author/Requestor	
---------------------	--

J. K. Perry	<i>J. K. Perry</i>	2/18/97
(Print and Sign)		Date

9. Responsible Manager		
<i>H. M. Greager</i>		
E. M. Greager		3-18-97
(Print and Sign)		Date

Date Cancelled	Date Disapproved
----------------	------------------



THE INTENTIONALLY
BANK

THIS PAGE INTENTIONALLY
LEFT BLANK



Department of Energy
Richland Operations Office
P.O. Box 550
Richland, Washington 99352

MAR 26 1997

97-EAP-312

Mr. Marcel Szyzkowski, P.E.
Regulatory and Technical
Support Section
Nuclear Waste Program
State of Washington
Department of Ecology
P. O. Box 47600
Olympia, Washington 98504-7600

Dear Mr. Szyzkowski:

NONRADIOACTIVE AIR EMISSIONS NOTICE OF CONSTRUCTION (NOC) FOR REMOVAL OF 340A BUILDING TANK SOLIDS

This letter transmits a NOC to the State of Washington Department of Ecology (Ecology), pursuant to Washington Administrative Code 173-460. Enclosed, please find a NOC requesting Ecology's approval for construction/modification for removal of 340A Building tank solids.

Should you have any questions, please contact me or Hector M. Rodriguez, of my staff, at (509) 376-6421.

Sincerely,

A handwritten signature in cursive script that reads "James E. Rasmussen".

James E. Rasmussen, Director
Environmental Assurance, Permits,
and Policy Division

EAP:HMR

Enclosure

cc w/encl:
W. Adair, FDH
R. Jim, YIN
D. Powaukée, NPT
L. Roberts, RFSH
J. Wilkinson, CTUIR

cc w/o encl:
J. Luke, RFSH
C. Mattsson, FDH
L. Roberts, RFSH

NOT INTENTIONALLY
BLANK

CONTENTS

1
2
3
4 METRIC CONVERSION CHART v
5
6 1.0 FACILITY IDENTIFICATION AND LOCATION 1-1
7
8 2.0 BACKGROUND INFORMATION 2-1
9
10 3.0 PROJECT INFORMATION 3-1
11 3.1 PROCESS DESCRIPTION 3-1
12 3.1.1 340A Building Tank Description 3-1
13 3.1.2 Procedures for Removing Solids from the Tanks 3-2
14 3.2 VENTILATION AND EMISSIONS CONTROL SYSTEM DESCRIPTION 3-2
15 3.2.1 Powered Exhaust/Ventilation System Description 3-2
16 3.2.2 Temporary Controls 3-3
17 3.2.3 Control Equipment Efficiencies 3-3
18 3.2.4 Pollution Control Technology Standards 3-4
19 3.3 MONITORING DESCRIPTION 3-4
20
21 4.0 EMISSIONS ESTIMATION 4-1
22 4.1 TOXIC AIR POLLUTANTS PER WAC 173-460 4-1
23 4.1.1 WAC 173-460-040 Applicability 4-1
24 4.1.2 WAC 173-460-080 Applicability 4-1
25 4.2 CRITERIA POLLUTANTS PER WAC 173-400-030 4-1
26
27 5.0 SCHEDULE 5-1
28
29 6.0 REFERENCES 6-1
30

APPENDICES

31
32
33
34
35 A DISPERSION MODELING ISC3 RUN APP A-i
36
37 B CALCULATION OF POLLUTANT INVENTORY IN TANK SLUDGE APP B-i
38
39 C CALCULATION OF POLLUTANT INVENTORY RESUSPENDED INTO
40 TANK VAPOR SPACE APP C-i
41
42 D ESTIMATED AVERAGE TOXIC AIR POLLUTANTS CONCENTRATION AT THE
43 POINT-OF-RELEASE TO THE ENVIRONMENT DURING
44 TANK SOLIDS REMOVAL OPERATIONS APP D-i
45
46 E ESTIMATED EMISSIONS RATE OF CRITERIA POLLUTANTS APP E-i
47
48

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16

FIGURES

1. Hanford Site	1-2
2. Location of the 340A Facility within the 300 Area	1-3
3. Ventilation and Emissions Control System Diagram	3-5

TABLES

1. Toxic Air Pollutants Emissions	4-2
2. Criteria Pollutant Emissions	4-3

METRIC CONVERSION CHART

The following conversion chart is provided to the reader as a tool to aid in conversion.

Into metric units

Out of metric units

Into metric units			Out of metric units		
If you know	Multiply by	To get	If you know	Multiply by	To get
Length			Length		
inches	25.40	millimeters	millimeters	0.0393	inches
inches	2.54	centimeters	centimeters	0.393	inches
feet	0.3048	meters	meters	3.2808	feet
yards	0.914	meters	meters	1.09	yards
miles	1.609	kilometers	kilometers	0.62	miles
Area			Area		
square inches	6.4516	square centimeters	square centimeters	0.155	square inches
square feet	0.092	square meters	square meters	10.7639	square feet
square yards	0.836	square meters	square meters	1.20	square yards
square miles	2.59	square kilometers	square kilometers	0.39	square miles
acres	0.404	hectares	hectares	2.471	acres
Mass (weight)			Mass (weight)		
ounces	28.35	grams	grams	0.0352	ounces
pounds	0.453	kilograms	kilograms	2.2046	pounds
short ton	0.907	metric ton	metric ton	1.10	short ton
Volume			Volume		
fluid ounces	29.57	milliliters	milliliters	0.03	fluid ounces
quarts	0.95	liters	liters	1.057	quarts
gallons	3.79	liters	liters	0.26	gallons
cubic feet	0.03	cubic meters	cubic meters	35.3147	cubic feet
cubic yards	0.76456	cubic meters	cubic meters	1.308	cubic yards
Temperature			Temperature		
Fahrenheit	subtract 32 then multiply by 5/9ths	Celsius	Celsius	multiply by 9/5ths, then add 32	Fahrenheit
Force			Force		
pounds per square inch	6.895	kilopascals	kilopascals	1.4504×10^{-4}	pounds per square inch

Source: *Engineering Unit Conversions*, M. R. Lindeburg, PE., Second Ed., 1990, Professional Publications, Inc., Belmont, California.

1
2
3
4
5

This page intentionally left blank.

1 **NONRADIOACTIVE AIR EMISSIONS NOTICE OF CONSTRUCTION**
2 **FOR REMOVAL OF 340A BUILDING TANK SOLIDS**

3
4
5 **1.0 FACILITY IDENTIFICATION AND LOCATION**

6
7
8 The 340A Building tanks are located within the 340 Facility Complex in
9 the 300 Area of the Hanford Site. Figure 1 shows the location of the 300 Area
10 within the Hanford Site. Figure 2 shows the location of the 340 Facility
11 Complex within the 300 Area. The Washington State Plane Coordinates for the
12 340A Facility are: N54475 E15475.

13
14 Address:

15
16 U.S. Department of Energy, Richland Operations Office
17 Hanford Site
18 300 Area, 340 Facility
19 Richland, Washington 99352

20
21 The responsible manager's name and address are as follows:

22
23 Mr. T. K. Teynor
24 Waste Programs Division
25 U.S. Department of Energy, Richland Operations Office
26 P.O. Box 550, Mail Stop S7-55
27 Richland, Washington 99352
28 (509) 372-1926.
29
30




Figure 1. Hanford Site.




Figure 2. Location of the 340A Facility within the 300 Area.

1
2
3
4
5

This page intentionally left blank.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51

2.0 BACKGROUND INFORMATION

The 340 Complex is a less-than-90-day storage unit for mixed waste generated on the Hanford Site. The 340 Complex receives liquid waste from various buildings in the 300 Area via underground transfer lines, or by containers from generators supporting Hanford Site programs.

The tanks used for waste storage at the 340 Complex include two 57 kiloliter tanks within the 340 Underground Storage Vault and six 30 kiloliter tanks within the 340A Building. The two underground vault tanks provide primary waste storage while the six tanks in the 340A Building provide reserve storage capacity.

The 340A Building tanks are not equipped with agitation devices and/or equipment. Consequently, past usage of the tanks has resulted in the formation, deposition, and settling of waste water solids.

The deposited tank solids contain radioactive material that represent a source of radiation exposure to workers. For as low as reasonably achievable (ALARA) purposes, the solids must be removed periodically from the tanks. The most recent tank solids removal effort occurred in the early 1980s.

The removal of solids from the 340A Building tanks constitutes a modification, in accordance with WAC 173-460-020(14), and, in accordance with WAC 173-460-040, the proposed activities are subject to New Source Review. In accordance with WAC 173-460 and WAC 173-400, this document serves as a Notice of Construction (NOC) for periodically removing solids from the 340A Building tanks.

It should be noted that submittal of this document is intended to conditionally satisfy WAC 173-460 and WAC 173-400 NOC requirements for future tank solids removal campaigns. Future solids removal campaigns will be performed on an as-needed basis to support ALARA practices and/or principles, and there might be several years between campaigns. It is understood that future 340A Building tank solids removal campaigns will be considered to have satisfied WAC 173-460 and WAC 173-400 NOC requirements, if the following conditions are met (note: a campaign consists of the removal of all sludge in the subject tanks).

- Potential pollutant emissions from each campaign will not exceed the levels stated in this document.
- No more than one tank solids removal campaign will be performed during any given annual period.
- Potential toxic air pollutant (TAP) and Criteria Pollutant emissions shall be limited to those identified in this NOC.
- The pollution control measures stated in this document are implemented.

1
2
3
4
5

This page intentionally left blank.

1
2
3
4
5
6
7
8 **3.0 PROJECT INFORMATION**

9
10 Provided in this section are descriptions of applicable processes,
11 ventilation and emissions controls, and monitoring.
12
13

14 **3.1 PROCESS DESCRIPTION**

15
16 The following sections provide descriptions of the 340A Building tanks
17 and the proposed procedures for removing solids from the tanks.
18
19

20 **3.1.1 340A Building Tank Description**

21 The 340A Building tanks are described as follows.

- 22 • The tanks are housed in the 340A Building.
- 23 • The tanks consist of six aboveground stainless steel tanks.
- 24 • The approximate volume of each tank is 30 kiloliters.
- 25 • The dimensions for each tank are approximately 3 meters in
26 diameter and 4.2 meters high.
- 27 • The top of each tank is provided with an access port (access
28 lid) which is approximately 0.46 meter in diameter.
- 29 • Each tank is provided with a fill/drain port located on the
30 tank side wall, approximately 0.15 meters above the bottom
31 surface of the tank.
- 32 • The tank fill/drain ports, drain via hard piping, to the
33 340 Vault tanks.
- 34 • The tanks are interconnected via hard pipes.
- 35 • The tanks are maintained at negative pressure relative to the
36 atmosphere via the 340 Facility K1 powered exhaust/ventilation
37 system (the differential pressure is >6 inches water gauge).
- 38 • The combined volume of sludge in the six tanks is
39 approximately 1,670 liters.
- 40 • The tank sludge consist of water, radioactive particulates,
41 metals, and hard water mineral salts.
- 42
43
44
45
46
47
48
49

1 **3.1.2 Procedures for Removing Solids from the Tanks**

2
3 The following methods will be employed to remove solids from the
4 340A Building tanks.

- 5
6 • Temporary containment device(s) will be configured to maintain
7 negative pressure within the tanks by restricting the amount of air
8 that enters the tanks via the tank access ports.
9
10 • The access lid will be removed from the tanks.
11
12 • An agitating device (air sparger, liquid pressure washer, or
13 recirculating pump) and cleaning solution to aid in the solids
14 suspension will be inserted into the tank access ports.
15
16 • The agitating device will be activated.
17
18 • Tanks will be drained to the 340 Vault tanks via the tank fill/drain
19 valves.
20
21 • Solids agitation activities are expected to require approximately
22 2 hours per tank.
23
24 • After completing solids agitation and draining activities, the
25 agitation equipment will be removed from the tanks by retracting the
26 equipment into plastic sleeving.
27
28 • On removing the agitation equipment from tanks, the tank access lids
29 will be replaced.
30

31
32 **3.2 VENTILATION AND EMISSIONS CONTROL SYSTEM DESCRIPTION**

33 The following sections describe:

- 34
35 • Powered exhaust/ventilation system serving the 340A Building tanks
36
37 • Temporary controls to be implemented when accessing tanks
38
39 • Control equipment efficiencies
40
41 • Pollution control technology standards.
42
43
44

45 **3.2.1 Powered Exhaust/Ventilation System Description**

46 The 340 Facility K1 powered exhaust/ventilation system ventilates the
47 340A Building Tanks. Parameters associated with the operation of the K1
48 powered exhaust/ventilation system include the following:
49

- 50
51 • The exhaust stack inner diameter at point of release to the
52 environment is approximately 46 centimeters.

- 1 • Exhaust stack height is approximately 6.1 meters above ground level.
- 2
- 3 • Maximum flow rate of powered exhaust/ventilation system is
- 4 approximately 68 cubic meters per minute.
- 5
- 6 • Average (actual) powered exhaust/ventilation flow rate is
- 7 approximately 50.2 cubic meters per minute.
- 8
- 9 • Supply air for the 340 Facility K1 powered exhaust/ventilation system
- 10 is heated electrically in the winter to protect pipes from freezing.
- 11
- 12 • Powered exhaust/ventilation system pollution control equipment
- 13 consists of a prefilter and two banks of high efficiency particulate
- 14 filter media.
- 15
- 16 • An air flow diagram of the 340 Facility K1 powered exhaust/ventilation
- 17 system is provided in Figure 3.
- 18
- 19

20 3.2.2 Temporary Controls

21
22 As noted in Section 3.1.2, temporary pollution controls will be
23 implemented during the solids removal effort to prevent emissions of
24 pollutants from the tank access port. Controls will consist of temporary
25 barriers installed between the tank access port and the surrounding area. The
26 barriers will be configured such that the amount of air that enters the tank
27 via the tank access port is restricted sufficiently to maintain negative
28 pressure within the tank. It should be noted that during solids removal
29 activities, the tank differential negative pressures, with respect to the
30 atmosphere, might be less negative than the routinely maintained differential
31 pressures (as stated in Section 3.1.1, routine differential negative pressures
32 are >6 inches water gauge).

33
34 Temporary pollution controls also will be implemented during the removal
35 of equipment from the tanks. Emissions will be controlled by using plastic
36 sleeving to provide a barrier between the equipment and the surrounding work
37 area and the environment. Equipment removed from the tanks will be retracted
38 into a plastic sleeve. After the equipment has been retracted into the
39 plastic sleeve, the sleeve will be sealed.

40 41 42 3.2.3 Control Equipment Efficiencies

43
44 Particulate emissions will be controlled with a prefilter and two banks
45 of filters consisting of high-efficiency particulate filter media. The
46 high-efficiency particulate filters that will be used are subjected to annual
47 in-place tests, which require a particulate removal efficiency of
48 99.95 percent for particulates with a 0.3 micron median diameter.

49
50 To determine the overall particulate decontamination factor (DF) for the
51 control system, the individual component DFs were multiplied together. A DF

1 of 2,000 was used for each high-efficiency particulate filter. The overall DF
2 is 4.0 E+06.
3
4

5 **3.2.4 Pollution Control Technology Standards**
6

7 The 340 Facility K1 powered exhaust/ventilation system pollution control
8 equipment is managed in accordance with the following standards:
9

- 10 • 40 CFR 60, Appendix A, Method 2
- 11 • ANSI/ASME NQA-1.
12
13

14 **3.3 MONITORING DESCRIPTION**
15

16 The pollutant emissions estimation (Section 4.0) indicates that emissions
17 are sufficiently low to protect human health and safety from potential
18 carcinogenic and/or other toxic effects, pursuant to WAC 173-460-070
19 requirements. Therefore, no sampling/monitoring is proposed for
20 nonradioactive pollutant air emissions resulting from the proposed operations.
21
22
23
24

FACILITY:	340 Building NTEX System
EMISSION POINT:	300P340NTEX 001




Figure 3. Ventilation and Emissions Control System Diagram.

1
2
3
4
5

This page intentionally left blank.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50

4.0 EMISSIONS ESTIMATION

This section documents estimations of TAP and Criteria Pollutant emissions resulting from the proposed activities.

4.1 TOXIC AIR POLLUTANTS PER WAC 173-460

The following sections provide discussion of the applicability of WAC 173-460-040 and WAC 173-460-080 requirements for TAP emissions.

4.1.1 WAC 173-460-040 Applicability

Pursuant to WAC 173-460-040(2) requirements, increases in TAP emission rates that do not exceed levels cited in the WAC 173-460-080 Small Quantity Emission Rate (SQER) tables are not subject to New Source Review. However, the tables in WAC 173-460-080 do not provide SQERs for three of the TAPs that might be emitted during the proposed operations (Table 1). Therefore, under WAC 173-460-040 requirements, the proposed activities are subject to New Source Review.

4.1.2 WAC 173-460-080 Applicability

Pursuant to WAC 173-460-080 requirements, an Acceptable Source Impact Level (ASIL) analysis is required for Class A and Class B TAPs. The emissions estimation provided in this section has been prepared for the purpose of satisfying WAC 173-460-080 ASIL analysis requirements.

Table 1 provides the estimated average emission rates of TAPs at the point of release to the environment and the estimated incremental ambient values (TAP concentrations experienced by the hypothetical nearest public receptor). It should be noted that the maximum incremental impacts of Class A and Class B TAPs to the hypothetical nearest public receptor are less than the associated ASILs listed in WAC 173-460-150 and WAC 173-460-160 (Table 1).

4.2 CRITERIA POLLUTANTS PER WAC 173-400-030

Pursuant to WAC 173-400 requirements, estimated emissions of Criteria Pollutants are provided in this section. It should be noted that one Criteria Pollutant, lead, is expected to be emitted during the solids removal activities.

The estimated emission rates of Criteria Pollutants (lead) are provided in Table 2. Data in Table 2 indicate that the maximal expected emissions of lead resulting from the proposed activities are insignificant.

Table 1. Toxic Air Pollutants Emissions.

TAPs	CAS #	TAP class	ASIL (ug/m3)	SOE lbs/yr	Concentration of TAPs in tank sludge (mg/l)	Inventory of TAPs in tank sludge ¹ (lbs)	Inventory of TAP resuspended into tank vapor space ² (lbs)	Estimated average TAP concentration at point-of-release to environment during solids removal activities ³ ug/m ³	Estimated incremental ambient value ⁴ (ug/m3)	Below ASIL
Barium	C7440393	B	1.70	175	1.03e+01	0.0378	3.78e-05	1.19e-07	5.25e-11	Yes
Cadmium	7440439	AI, AII	0.0006	0	4.08e-01	0.0015	1.50e-06	4.74e-09	5.89e-15	Yes
Chromium	C7440473	AI, AII	0.0001	0	9.03e+01	0.3326	3.33e-04	1.05e-06	2.34e-16	Yes
Lead	7439921	AI, AIII	0.5000	50	5.04e+01	0.1856	1.86e-04	5.85e-07	4.62e-10	Yes
Silver	C7440224	B	0.0330	175	9.05e+00	0.0333	3.33e-05	1.05e-07	4.63e-11	Yes
Mercury	C7439976	B	0.1700	175	5.07e-01	0.0019	1.87e-06	5.88e-09	2.59e-12	Yes
Arsenic	C7440382	AI	0.0002	0	5.09e-01	0.0019	1.87e-06	5.91e-09	2.91e-16	Yes
Selenium	C7782492	B	0.6700	175	1.01e+01	0.0371	3.71e-05	1.17e-07	5.15e-11	Yes

- 1 The TAPS inventory was calculated by multiplying the TAPS sludge concentration by the total volume of sludge (1,670 liters). Additional information is provided in Appendix B.
- 2 The TAPS inventory resuspended into the tank vapor space was determined by multiplying the inventory of TAPS in the tank sludge by the 40 CFR 61, Appendix D release fraction for particulates (0.001). Additional information is provided in Appendix C.
- 3 The average TAPS concentration at the point of release to the environment, during the tank solids removal activities, was calculated by dividing the TAPS inventory resuspended into the tank vapor space by the volume of gas discharged from the powered exhaust/ventilation system during the tank solids removal activities (36,144 cubic meters) and by multiplying by the filtration system decontamination factor (2.5 E-07). Additional information is provided in Appendix D.
- 4 The estimated incremental ambient value is the concentration experienced by the hypothetical nearest public receptor. This value was calculated using atmospheric dispersion modeling parameters provided in Appendix A. In accordance with WAC 173-460-080, the dispersion modeling factors used for Lead (Pb) and Class B TAPS were derived from a 24-hour release atmospheric dispersion model, and the dispersion modeling factors used for Class AIII TAPS were derived from an annual average release atmospheric dispersion model.

ASIL = acceptable source impact level.
 CAS = Chemical Abstract Service.
 lbs = pounds.
 mg/l = milligram per liter.
 SOE = small quantity emissions.
 ug/m³ = microgram per cubic meter.

Table 2. Criteria Pollutant Emissions.

Criteria Pollutant	Inventory of pollutant in tank sludge ¹ (pounds)	Quantity of pollutant resuspended into tank vapor space ² (pounds)	Estimated emissions rate of pollutant ³ (pounds per year)
Lead	0.2	2 E-4	5 E-11

¹ The Criteria Pollutant inventory was calculated by multiplying the sludge concentration by the total volume of sludge (1,670 liters). Additional information is provided in Appendix B.

² The Criteria Pollutant inventory resuspended into the tank vapor space was determined by multiplying the pollutant inventory by the 40 CFR 61, Appendix D release fraction for particulates (0.001). Additional information is provided in Appendix C.

³ The Criteria Pollutant emissions rate was calculated by multiplying the pollutant inventory resuspended into the tank vapor space by the filtration system decontamination factor (2.5 E-07). Note: As stated in Section 2.0, the pollutant inventory resuspended into the tank vapor space is an annual value. Additional information is provided in Appendix E.

1
2
3
4
5

This page intentionally left blank.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18

5.0 SCHEDULE

In the coming years (through calendar year 2001 and possibly beyond), the 340 Complex will continue to serve as a less-than-90-day tank storage unit for mixed waste generated on the Hanford Site. Furthermore, the 340A Building tanks will continue to provide reserve waste storage capacity.

To support future 340 Complex operations, 340A Building tank solids removal activities will continue to be performed periodically. Future solids removal campaigns will be performed on an as-needed basis to support ALARA practices/principles, and there might be several years between campaigns.

The schedule for performing future solids removal activities is not provided. However, each tank solids removal campaign is expected to require approximately 6 months to complete.

1
2
3
4
5

This page intentionally left blank.

6.0 REFERENCES

1
2
3
4
5
6
7
8
9

EPA, 1996, *ISC3, Industrial Source Complex Dispersion Model*, screening procedures for estimating the air quality impact of stationary sources, EPA-454/B-95-003a, updated periodically, U.S. Environmental Protection Agency, Research Triangle Park, North Carolina.

1
2
3
4
5

This page intentionally left blank.

1
2
3
4

APPENDIX A

DISPERSION MODELING ISC3 RUN

1
2
3
4
5

This page intentionally left blank.

1
2

DISPERSION MODELING SUMMARY

September 27, 1996

From: Paul D. Rittmann
HO-31 376-8715

Subject: Unit Concentration Factors from ISC3

The ISC3 program (EPA-454/B-95-003a, "User's Guide for the Industrial Source Complex (ISC3) Dispersion Models", September 1995) was used to compute unit concentration factors for the Hanford Site boundary for 24 hour and annual releases from the 100-N (or 100-K), the 200 West, the 200 East, and 300 Areas. Hanford site wind data is used for these calculations. The data for each area was collected in that area. For the 24 hour releases, hourly data from 1992, 1993, 1994, and 1995 was used. For the annual releases the joint frequency summary for each area for the years 1986 to 1995 was used. Results are summarized in the first table below. These are the worst-case values for ground level releases from each area.

Table 1. Summary of Unit Concentration Factors for Ground Level Releases from Hanford Facilities

Release Locations	24 Hour Average		Annual Average	
	Concen. Factor	Site Boundary Location	Concen. Factor	Site Boundary Location
100-N & KW	4.17	8.5 km WNW	0.125	8.5 km WNW
200 West Area	3.46	12.6 km S	0.0585	22.0 km SE
200 East Area	2.79	17.1 km ESE	0.0793	17.1 km ESE
300 Area	38.1	1.1 km E	1.56	1.3 km NE

Note: Units for the Concentration Factors are $\mu\text{g}/\text{m}^3$ per g/s. Peak values are given.
 Note: Annual averages are based on Hanford Site wind data collected over the years 1986 to 1995.
 24 hour averages are based on hourly Hanford Site wind data for the years 1992, 1993, 1994, and 1995.

To use these factors, the rate at which a chemical is released into the air must be computed. To do this, the total amount (in grams) of the chemical released is divided by either 86,400 seconds (24 hours) or 31,557,600 seconds (1 year). This release rate is then multiplied by one of the factors on Table 1 to compute the average concentration at the Hanford site boundary in $\mu\text{g}/\text{m}^3$. The formula below summarizes the calculation.

$$\text{Air Conc } (\mu\text{g}/\text{m}^3) = \frac{(\text{Total Release, grams}) * (\text{Concen. Factor})}{\text{Release Period, seconds}}$$

As an example, suppose that 10 grams of ammonia is released over a 24 hour period from the 200 West Area. Then the largest observed air concentration at the Hanford site boundary over the past four years is $0.0004 \mu\text{g}/\text{m}^3$ at a location 12.6 km south of the 200 West Area.

$$\frac{(10 \text{ grams}) * (3.46 \mu\text{g}/\text{m}^3 \text{ per g/s})}{86,400 \text{ seconds}} = 4.0 \times 10^{-4} \mu\text{g}/\text{m}^3 (12.6 \text{ km S})$$

Method of Calculating the Concentration Factors

The first step was to estimate distances to the Hanford Site boundary from each of the areas of interest in all 16 wind transport directions. Table 2 shows the facilities selected and the distances obtained from the Hanford Map Distance (HMD) software by P.D. Rittmann.

Table 2. Distances (meters) to the Hanford Site Boundary

Dir	100-N and -K		200 West		200 East		300 Area	
	100 N	100 KW	CWC	REDOX	PUREX	WESF	324	333
N	9600	11000	17300	20300	24600	19400	7000	8700
NNW	8700	8900	15500	18100	21200	16700	46000	45500
NW	8300	8700	14600	17200	21300	18100	48600	48100
WNW	8500	10100	11800	13200	21200	19300	28500	28200
W	11500	12100	11500	13000	20700	18900	6000	6700
WSW	17300	15700	11800	13300	21100	19400	3500	4200
SW	20500	17400	13800	15500	17100	19900	2400	2900
SSW	28600	25600	15100	12800	16800	19600	2000	2700
S	28600	25200	14700	12600	19600	22800	1900	2400
SSE	34100	31000	19200	18200	19800	25500	1900	2400
SE	27300	32100	24700	22000	24300	19900	1500	1700
ESE	19100	21700	29900	28700	20200	17100	1200	1400
E	17300	20600	24300	25000	16000	16900	1100	1300
ENE	17300	20400	24600	23200	15300	21900	1100	1300
NE	16300	19900	27400	26400	18100	26400	1300	1500
NNE	13800	15200	25000	28800	23600	21100	1800	2200

The second step was to obtain Hanford Site wind data from Kenneth W. Burk at PNNL. The wind data for each area is then used in the ISC3 calculations.

The third step is to create input files for the ISC3 software. Two of the input files are attached for reference. The first is an annual average calculation using ISCLT, while the second is a 24 hour calculation using ISCST. Both use a release height of 2 meters, with an exhaust flow rate of 2000 cubic feet per minute (56,634 liters per minute) at a temperature of 20°C. These conditions model ground level releases.

The final step was to arrange the ISC3 results into Tables 3 and 4. The worst case concentration factor was taken for each area. These worst-case results are listed in Table 1.

1 **Table 3. Annual Average Concentration Factors ($\mu\text{g}/\text{m}^3$ per g/s)**
 2 **from Ground Level Releases**

Dir	100-N and -K		200 West		200 East		300 Area	
	100 N	100 KW	CWC	REDOX	PUREX	WESF	324	333
N	0.0500	0.0410	0.0249	0.0200	0.0136	0.0187	0.145	0.106
NNW	0.0656	0.0635	0.0311	0.0251	0.0216	0.0300	0.011	0.012
NW	0.1064	0.0993	0.0381	0.0303	0.0220	0.0276	0.014	0.014
WNW	0.1252	0.0973	0.0351	0.0299	0.0173	0.0197	0.017	0.017
W	0.0863	0.0803	0.0290	0.0243	0.0150	0.0171	0.059	0.050
WSW	0.0373	0.0427	0.0233	0.0196	0.0112	0.0126	0.079	0.060
SW	0.0234	0.0293	0.0212	0.0179	0.0154	0.0124	0.157	0.117
SSW	0.0126	0.0146	0.0246	0.0312	0.0153	0.0123	0.403	0.255
S	0.0136	0.0161	0.0366	0.0457	0.0147	0.0119	0.992	0.696
SSE	0.0131	0.0148	0.0368	0.0396	0.0189	0.0133	1.171	0.823
SE	0.0230	0.0186	0.0500	0.0585	0.0289	0.0380	1.248	1.036
ESE	0.0504	0.0423	0.0532	0.0562	0.0629	0.0793	1.142	0.917
E	0.0661	0.0520	0.0505	0.0486	0.0585	0.0542	1.184	0.933
ENE	0.0555	0.0442	0.0306	0.0331	0.0366	0.0224	1.382	1.082
NE	0.0389	0.0295	0.0182	0.0191	0.0207	0.0124	1.558	1.256
NNE	0.0318	0.0277	0.0153	0.0127	0.0117	0.0136	0.975	0.719

22 **Table 4. 24 Hour Average Concentration Factors ($\mu\text{g}/\text{m}^3$ per g/s)**
 23 **from Ground Level Releases**

Dir	100-N and -K		200 West		200 East		300 Area	
	100 N	100 KW	CWC	REDOX	PUREX	WESF	324	333
N	3.75	3.30	1.96	1.70	1.29	1.71	5.91	4.47
NNW	3.20	3.13	3.30	2.84	1.95	2.45	0.52	0.53
NW	2.29	2.17	0.78	0.64	0.53	0.62	0.29	0.30
WNW	4.17	3.51	2.16	1.94	1.16	1.28	1.12	1.13
W	2.51	2.35	3.24	2.91	1.74	1.89	4.25	3.66
WSW	1.42	1.57	1.90	1.69	0.29	0.32	6.05	5.08
SW	0.81	0.96	0.79	0.71	1.31	1.13	4.79	3.97
SSW	0.92	1.02	1.92	2.30	1.39	1.20	1.91	8.91
S	0.90	1.01	3.02	3.46	1.69	1.48	7.25	9.85
SSE	0.81	0.90	2.64	2.78	1.31	1.02	0.01	5.84
SE	0.51	0.41	0.99	1.12	1.00	1.29	6.44	3.08
ESE	1.62	1.44	2.51	2.61	2.36	2.79	8.42	4.65
E	3.23	2.76	2.44	2.38	1.73	1.64	8.11	0.78
ENE	2.71	2.30	1.69	1.78	1.10	0.73	7.63	2.98
NE	0.61	0.48	0.91	0.95	0.41	0.26	1.38	8.12
NNE	2.36	2.15	1.96	1.70	0.97	1.08	6.36	3.08

1 ISCLT Input File for 100-N Area

2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71

CO STARTING
 TITLEONE Ground Level Emissions from 100-N Area
 MODELOPT DFAULT CONC RURAL
 AVERTIME annual
 POLLUTID Unknown
 RUNORNOT RUN
 CO FINISHED

SO STARTING
 LOCATION Exhaust1 POINT 0.0 0.0 0.0
 ** 2000 cfm g/sec ht,m temp°C m/sec diam,m
 SRCPARAM Exhaust1 1.0 2.0 293.0 2.0 0.775
 SRCGROUP ALL
 SO FINISHED

RE STARTING
 ** These are the CAP88 order -- counter-clockwise from N
 ** Distances from 100-N are 1,3,5,...; Distances from 100-KW are 2,4,6,...
 DISCPOLR Exhaust1 9600 0.0
 DISCPOLR Exhaust1 11000 0.0
 DISCPOLR Exhaust1 8700 337.5
 DISCPOLR Exhaust1 8900 337.5
 DISCPOLR Exhaust1 8300 315.0
 DISCPOLR Exhaust1 8700 315.0
 DISCPOLR Exhaust1 8500 292.5
 DISCPOLR Exhaust1 10100 292.5
 DISCPOLR Exhaust1 11500 270.0
 DISCPOLR Exhaust1 12100 270.0
 DISCPOLR Exhaust1 17300 247.5
 DISCPOLR Exhaust1 15700 247.5
 DISCPOLR Exhaust1 20500 225.0
 DISCPOLR Exhaust1 17400 225.0
 DISCPOLR Exhaust1 28600 202.5
 DISCPOLR Exhaust1 25600 202.5
 DISCPOLR Exhaust1 28600 180.0
 DISCPOLR Exhaust1 25200 180.0
 DISCPOLR Exhaust1 34100 157.5
 DISCPOLR Exhaust1 31000 157.5
 DISCPOLR Exhaust1 27300 135.0
 DISCPOLR Exhaust1 32100 135.0
 DISCPOLR Exhaust1 19100 112.5
 DISCPOLR Exhaust1 21700 112.5
 DISCPOLR Exhaust1 17300 90.0
 DISCPOLR Exhaust1 20600 90.0
 DISCPOLR Exhaust1 17300 67.5
 DISCPOLR Exhaust1 20400 67.5
 DISCPOLR Exhaust1 16300 45.0
 DISCPOLR Exhaust1 19900 45.0
 DISCPOLR Exhaust1 13800 22.5
 DISCPOLR Exhaust1 15200 22.5
 RE FINISHED

ME STARTING
 INPUTFIL JF100N10.STA FREE
 ANEMHGHT 10.0
 SURFDATA 67656 1995 HANFORD100
 UAIRDATA 67656 1995 HANFORD100
 STARDATA ANNUAL
 ** WINDCATS 1.341 3.576 5.364 8.494 10.729
 AVESPEED 1.00 2.682 4.694 7.153 9.835 14.304
 AVETEMPS ANNUAL 6*285.3
 AVEM1XHT ANNUAL A 6*1000.0
 AVEM1XHT ANNUAL B 6*1000.0
 AVEM1XHT ANNUAL C 6*1000.0
 AVEM1XHT ANNUAL D 6*1000.0
 AVEM1XHT ANNUAL E 6*1000.0
 AVEM1XHT ANNUAL F 6*1000.0
 ME FINISHED

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70

OU STARTING
RECTABLE SRCGRP
MAXTABLE 10 INDSRC SOCONT
OU FINISHED

ISCST Input File for 200 West Area

CO STARTING
TITLEONE Ground Level Emissions from 200 West Area
MODELOPT MSGPRO CONC RURAL
AVERTIME 24
POLLUTID Unknown
RUNORNOT RUN
CO FINISHED

SO STARTING
LOCATION Exhaust1 POINT 0.0 0.0 0.0
** 2000 cfm g/sec ht,m temp °K m/sec diam,m
SRCPARAM Exhaust1 1.0 2.0 293.0 2.0 0.775
SRCGROUP ALL
SO FINISHED

RE STARTING
** Distances from CWC are 1,3,5,...; Distances from REDOX are 2,4,6,...
DISCPOLR Exhaust1 17300 0.0
DISCPOLR Exhaust1 20300 0.0
DISCPOLR Exhaust1 15500 337.5
DISCPOLR Exhaust1 18100 337.5
DISCPOLR Exhaust1 14600 315.0
DISCPOLR Exhaust1 17200 315.0
DISCPOLR Exhaust1 11800 292.5
DISCPOLR Exhaust1 13200 292.5
DISCPOLR Exhaust1 11500 270.0
DISCPOLR Exhaust1 13000 270.0
DISCPOLR Exhaust1 11800 247.5
DISCPOLR Exhaust1 13300 247.5
DISCPOLR Exhaust1 13800 225.0
DISCPOLR Exhaust1 15500 225.0
DISCPOLR Exhaust1 15100 202.5
DISCPOLR Exhaust1 12800 202.5
DISCPOLR Exhaust1 14700 180.0
DISCPOLR Exhaust1 12600 180.0
DISCPOLR Exhaust1 19200 157.5
DISCPOLR Exhaust1 18200 157.5
DISCPOLR Exhaust1 24700 135.0
DISCPOLR Exhaust1 22000 135.0
DISCPOLR Exhaust1 29900 112.5
DISCPOLR Exhaust1 28700 112.5
DISCPOLR Exhaust1 24300 90.0
DISCPOLR Exhaust1 25000 90.0
DISCPOLR Exhaust1 24600 67.5
DISCPOLR Exhaust1 23200 67.5
DISCPOLR Exhaust1 27400 45.0
DISCPOLR Exhaust1 26400 45.0
DISCPOLR Exhaust1 25000 22.5
DISCPOLR Exhaust1 28800 22.5

RE FINISHED
ME STARTING
INPUTFIL EPA92-95.2W
ANEMHGHT 10.0
SURFDATA 67656 1992 Hanford-200
UAIRDATA 67656 1992 Hanford-200
ME FINISHED

OU STARTING
RECTABLE ALLAVE FIRST
MAXTABLE ALLAVE 20
OU FINISHED

1
2
3
4

APPENDIX B

CALCULATION OF POLLUTANT INVENTORY IN TANK SLUDGE

1
2
3
4
5

This page intentionally left blank.

1 The inventory of pollutant in tank sludge (Inv) is calculated as follows:

2
3
$$\text{Inv} = (C)(SV)$$

4
5 C = Concentration of pollutant in tank sludge (refer to "Sample Data"
6 below).

7
8 SV = Volume of sludge in waste tanks. The combined volume of sludge in
9 the six tanks is 1,670 liters, based on calculation using an
10 average sludge depth of 3.81 centimeters and a tank radius of
11 152.4 centimeters.

12
13
$$(\pi)(\text{tank radius})^2(\text{avg. sludge depth per tank})(\text{number of tanks})$$

14
15 Sample Data: 340A Building tank solids have not been sampled/analyzed for
16 nonradiological pollutants. However, because the 340A Building tanks provide
17 reserve storage capacity for liquid effluents normally discharged to the
18 340 Vault tanks, nonradiological pollutant sample/analysis data from the
19 340 Vault tanks (average concentrations from 1991 to 1995) was used to
20 estimate pollutant concentrations in the 340A Building tanks. To account for
21 possible increased pollutant concentrations in the 340A Building tanks
22 (relative to concentrations in the 340 Vault tanks), pollutant concentrations
23 were assumed to be 10 times greater those in the 340 Vault tanks. The
24 following are the estimated concentrations of TAPs and Criteria Pollutants in
25 the 340A Building tanks.

- 26
27 • Barium (10.26 milligrams per liter)
28 • Cadmium (40.8 E-1 milligrams per liter)
29 • Chromium (90.34 milligrams per liter)
30 • Lead (50.42 milligrams per liter)
31 • Silver (90.5 E-1 milligrams per liter)
32 • Mercury (50.69 E-2 milligrams per liter)
33 • Arsenic (50.92 E-2 milligrams per liter)
34 • Selenium (10.07 milligrams per liter).

1
2
3
4
5

This page intentionally left blank.

1
2
3
4
5

APPENDIX C

CALCULATION OF POLLUTANT INVENTORY RESUSPENDED
INTO TANK VAPOR SPACE

1
2
3
4
5

This page intentionally left blank.

1 The inventory of pollutant resuspended into tank vapor space (InvR) is
2 calculated as follows:
3

4 $InvR = (Inv)(RF)$
5

6 Inv = Inventory of pollutant in tank sludge
7 (refer to text, Table 1).
8

9 RF = The release fraction for each pollutant is assumed to be
10 0.001 (based on information provided in 40 CFR 61,
11 Appendix D).
12
13

1
2
3
4
5

This page intentionally left blank.

1
2
3
4
5
6

APPENDIX D

ESTIMATED AVERAGE TOXIC AIR POLLUTANTS CONCENTRATION AT
THE POINT-OF-RELEASE TO THE ENVIRONMENT
DURING TANK SOLIDS REMOVAL ACTIVITIES

1
2
3
4
5

This page intentionally left blank.

1 The estimated average concentrations of TAPs at the point-of-release to the
2 environment during air tank solids removal activities (EATC) are calculated as
3 follows:

4
5 $EATC = (InvR)(1/V)(DF)$

6
7 $InvR =$ Inventory of TAPs resuspended into tank vapor space (refer
8 to text, Table 1).
9

10 $V =$ Volume of gas discharged from the 340 Facility K1 powered
11 exhaust/ventilation system during the tank solids removal
12 activities. This value is expected to be approximately
13 36,144 cubic meters. This value was determined by
14 multiplying the estimated length of time that tank solids
15 removal operations are expected to occur (12 hours, based
16 on the assumption that each tank will require
17 approximately 2 hours of solids removal activities) by the
18 exhaust/ventilation system flow rate (50.2 cubic meters
19 per minute).
20

21 $DF =$ Filtration system decontamination factor. The overall
22 particulate decontamination factor (DF) for the control
23 system was determined by multiplying the individual
24 component DFs together. A DF of .0005 [based on
25 99.95 percent removal efficiency (Section 3.2.3)] was used
26 for each high-efficiency particulate filter. The overall
27 DF is 2.5×10^{-7} .
28
29

1
2
3
4
5

This page intentionally left blank.

1
2
3
4

APPENDIX E

ESTIMATED EMISSIONS RATE OF CRITERIA POLLUTANTS

1
2
3
4
5

This page intentionally left blank.

1 The estimated emission rates of Criteria Pollutants (EERCP) are calculated as
2 follows:

3
4 $EERCP = (ICPRTVS)(DF)$

5
6 $ICPRTVS =$ Inventory of Criteria Pollutants resuspended into tank
7 vapor space (refer to text, Table 2).
8

9 $DF =$ Filtration system decontamination factor. The overall
10 particulate decontamination factor (DF) for the control
11 system was determined by multiplying the individual
12 component DFs together. A DF of .0005 [based on
13 99.95 percent removal efficiency (Section 3.2.3)] was used
14 for each high-efficiency particulate filter. The overall
15 DF is 2.5×10^{-7} .

This page intentionally left blank.

DISTRIBUTION

OFFSITE

MSIN

S. M. Alexander
Perimeter Section
Washington State Department of Ecology
1315 West Fourth Avenue
Kennewick, Washington 99336-6018

S. E. McKinney
Hanford Project Manager
Washington State Department of Ecology
P. O. Box 47600
Olympia, Washington 98504-7600

M. Szyszkowski
Nuclear Waste Program
Washington State Department of Ecology
P. O. Box 47600
Olympia, Washington 98504-7600

J. Wilkinson
Confederated Tribes of the Umatilla
Indian Nation
P. O. Box 638
Pendleton, Oregon 97801

D. Powauke
Nez Perce Tribe
P. O. Box 365
Lapwai, Idaho 93540

R. Jim, Manager
Environmental Restoration/
Waste Management Program
Yakama Indian Nation
P. O. Box 151
Toppenish, Washington 98948

ONSITE

U.S. Department of Energy,
Richland Operations Office

A. V. Beard
G. M. Bell
J. E. Rasmussen
H. M. Rodriguez
A. B. Sidpara
D. J. Williams
Reading Room (2)

S7-55
A4-52
A5-15
A5-15
S7-54
H2-53
H2-53

DISTRIBUTION (cont)

MSIN

Fluor Daniel Hanford, Inc.

J. A. Bates H6-36
B. D. Williamson B3-15

Lockheed Martin Services, Inc.

Central Files A3-88
DPC H6-08
EDMC (2) H6-08

Pacific Northwest National Laboratory

Hanford Technical Library K1-11

Rust Federal Services of Hanford Inc.

L. D. Berneski L6-40
B. L. Curn H6-36
W. E. Davis H6-36
L. P. Diediker H6-36
B. P. Gleckler H6-36
E. M. Greager H6-36
W. E. Green H6-36
D. L. Halgren L6-04
J. S. Hill H6-25
M. T. Jansky H6-21
J. J. Luke H6-25
L. W. Roberts L6-04
R. W. Szelmezcza L6-05
G. T. Wells H6-36
Air Operating Permit File H6-25