

BLDG	WONUM	DESCRIPTION	MAX #	HRS	REPORT DATE	ACTUAL FINISH
605	20081988981	*CF*BS*CK*GT* 605:STEAMPLANT TEMP BOILERS FAILURE XCL	1110741	31	03-Apr-08	08-Apr-08
605	20081993449	MAY 08 605:TEMP BOILER PLANT DAILY ROUTE	1116822	133	14-Apr-08	31-May-08
605	20081994773	MAY 08 605:BOILER #1 BI-WEEKLY COLD START AND PURGE CYCLE PM	1032876	1	16-Apr-08	19-May-08
605	20081996707	(mat'l only) 605:TEMP BOILER PLANT	1116822	0	21-Apr-08	30-Apr-08
605	20081997214	605:TEMP BOILER PLANT (relays)	1116822	0	22-Apr-08	23-May-08
605	20082000965	(mat'l only) 605:TEMP BOILER PLANT	1116822	0	29-Apr-08	07-May-08
605	20082002256	(mat'l only) 605:TEMP BOILER PLANT spare parts	1116822	0	30-Apr-08	27-May-08
605	20082024850	605:STATE CERTIFIED BI-ANNUAL BOILER # 3 INSPECTION	1116871	0.0125	01-May-08	02-Jun-08
605	20082024852	605:STATE CERTIFIED BI-ANNUAL BOILER # 4 INSPECTION	1116872	0.0125	01-May-08	02-Jun-08
605	20082024854	605:STATE CERTIFIED BI-ANNUAL BOILER # 2 INSPECTION	1116823	0.0125	01-May-08	02-Jun-08
605	20082024856	605:STATE CERTIFIED BI-ANNUAL BOILER # 1 INSPECTION	1116822	0.0125	01-May-08	02-Jun-08
605	20082024917	JUN 08 605:TEMP BOILER PLANT DAILY ROUTE	1116822	127.5	01-May-08	01-Jul-08
605	20082024957	JUN 08 605:BOILER #1 BI-WEEKLY COLD START AND PURGE CYCLE PM	1032876	0	01-May-08	12-May-08
605	20082026293	(mat'l only) 605:TEMP BOILER PLANT spare parts	1116822	0	05-May-08	21-May-08
605	20082026298	(mat'l only) 605:TEMP BOILER PLANT glass tubes	1116822	0	05-May-08	06-May-08
605	20082029137	JUN 08 605:BOILER #1 BI-WEEKLY COLD START AND PURGE CYCLE PM	1032876	4.5	12-May-08	05-Jun-08
605	20082029143	JUN 08 605:BOILER #1 BI-WEEKLY COLD START AND PURGE CYCLE PM	1032876	1.5	12-May-08	24-Jun-08
605	20082029729	605:LOW STEAM PRESSURE TEMP BOILER PLANT	1116822	5	13-May-08	15-May-08
605	20082029738	*CF*GT*CK*MW* 605:LOW STEAM PRESSURE TEMP BOILER PLANT XCL	1116822	16.5	13-May-08	20-May-08
605	20082033138	XCL MAY Please rekey doors to TEMP BOILER addition	249000	3	20-May-08	23-May-08
605	20082035335	ECI-TEMP BOILER DOWN	1036996	4	27-May-08	30-May-08
605	20082045578	JULY 08: 605:BOILER 1 TRANSMITTER RECORD PM XCL	1103434	9	02-Jun-08	08-Jul-08
605	20082058513	JUL 08 605:TEMP BOILER PLANT DAILY ROUTE	1116822	130.5	02-Jun-08	31-Jul-08
605	20082058573	JUL 08 605:BOILER #1 BI-WEEKLY COLD START AND PURGE CYCLE PM	1032876	1.5	02-Jun-08	08-Jul-08
605	20082058579	JUL 08 605:BOILER #1 BI-WEEKLY COLD START AND PURGE CYCLE PM	1032876	5	02-Jun-08	20-Aug-08
605	20082058585	JUL 08 605:BOILER #1 BI-WEEKLY COLD START AND PURGE CYCLE PM	1032876	0	02-Jun-08	28-Jul-08

605	20082092149	AUG 08 605:TEMP BOILER PLANT DAILY ROUTE	1116822	134.5	01-Jul-08	31-Aug-08
605	20082092234	AUG 08 605:BOILER #1 BI-WEEKLY COLD START AND PURGE CYCLE PM	1032876	0	01-Jul-08	31-Jul-08
605	20082092240	AUG 08 605:BOILER #1 BI-WEEKLY COLD START AND PURGE CYCLE PM	1032876	0	01-Jul-08	31-Jul-08
605	20082097473	TRAIN ON TEMPORARY BOILER DAILY ROUTE	258000	6	11-Jul-08	16-Jul-08
605	20082104152	EOC:BOILER #1 IN ALARM	258000	2	24-Jul-08	29-Jul-08
605	20082133287	SEPT 08 605:TEMP BOILER PLANT DAILY ROUTE	1116822	150	01-Aug-08	01-Oct-08
605	20082135225	**CIE** 605:TWO BOILERS HAVE FAILED	251000	3	05-Aug-08	05-Aug-08
605	20082138158	**CIE**-605:TWO BOILERS HAVE TRIPPED AND PRESSURE IS LOW	251000	3	11-Aug-08	12-Aug-08
605	20082139072	TROUBLESHOOT BOILER #1 FEED WATER PUMP	251000	4	12-Aug-08	14-Aug-08
605	20082174024	OCT 08 605:TEMP BOILER PLANT DAILY ROUTE	1116822	242.5	02-Sep-08	12-Nov-08
605	20082185223	REMOVE ACCESS HATCH TO BOILER # 3	258000	2.5	23-Sep-08	16-Oct-08
605	20090024386	NOV 08 605:TEMP BOILER PLANT DAILY ROUTE	1116822	120.5	01-Oct-08	04-Dec-08
605	20090027174	SUPPORT BOILER FAILURE AT BLDG 605 XCL	251000	19	03-Oct-08	06-Oct-08
605	20090027191	RESPOND TO BOILER FAILURE AT BLDG 605	251000	12	03-Oct-08	08-Oct-08
605	20090041143	605:STATE CERTIFIED BI-ANNUAL BOILER # 1 INSPECTION	1116822	0.5	29-Oct-08	25-Nov-08
605	20090041153	605:STATE CERTIFIED BI-ANNUAL BOILER # 2 INSPECTION	1116823	0.5	29-Oct-08	25-Nov-08
605	20090041161	605:STATE CERTIFIED BI-ANNUAL BOILER # 4 INSPECTION	1116872	0.5	29-Oct-08	25-Nov-08
605	20090041170	605:STATE CERTIFIED BI-ANNUAL BOILER # 3 INSPECTION	1116871	0.5	29-Oct-08	25-Nov-08
605	20090060119	Dec 08 605:TEMP BOILER PLANT DAILY ROUTE	1116822	92.5	03-Nov-08	05-Jan-09
605	20090092255	JAN 08 605:TEMP BOILER PLANT DAILY ROUTE	1116822	14	01-Dec-08	15-Jan-09
605	20090092619	(ATTACHMENT) JAN 09 605:BOILER # 1 (STEAM) PM	1116822	24	01-Dec-08	23-Feb-09
605	20090096427	Replace sight glass on TEMP BOILERS #1 & 3	258000	4	05-Dec-08	11-Dec-08
605	20090100354	INSTALL FUEL VALVE END SWITCH ON BOILER AT BLDG 605	251000	6.5	12-Dec-08	22-Dec-08
605	20090128972	FEB 09 605:TEMP BOILER PLANT DAILY ROUTE	1116822	107.5	05-Jan-09	27-Feb-09
605	20090129410	(ATTACHMENT) FEB 09 605:BOILER # 2 (STEAM) PM	1116823	12.5	05-Jan-09	26-Feb-09
605	20090132835	JAN 09 605:TEMP BOILER PLANT DAILY ROUTE	1116822	144.5	07-Jan-09	31-Jan-09
605	20090168250	Hold per Bob Washington: (ATTACHMENT) MAR 09 605:BOILER # 3 (STEAM) PM	1116871	0	02-Feb-09	18-May-09
605	20090168528	MAR 09 605:TEMP BOILER PLANT DAILY ROUTE	1116822	122.5	02-Feb-09	07-Apr-09
605	20090205811	Hold per Bob Washington: (ATTACHMENT) APR 09 605:BOILER # 4 (STEAM) PM	1116872	0	02-Mar-09	18-May-09
605	20090206034	APR 09 605:TEMP BOILER PLANT DAILY ROUTE	1116822	141.5	02-Mar-09	30-Apr-09
605	20090250168	605:STATE CERTIFIED BI-ANNUAL BOILER # 3 INSPECTION	1116871	0	01-Apr-09	21-May-09

605	20090250170	605:STATE CERTIFIED BI-ANNUAL BOILER # 4 INSPECTION	1116872	0	01-Apr-09	21-May-09
605	20090250173	605:STATE CERTIFIED BI-ANNUAL BOILER # 2 INSPECTION	1116823	0	01-Apr-09	21-May-09
605	20090250175	605:STATE CERTIFIED BI-ANNUAL BOILER # 1 INSPECTION	1116822	0	01-Apr-09	21-May-09
605	20090254944	Need Welch's Boiler to start-up TEMP BOILER after outage on April 5th.	1116871	0.0125	03-Apr-09	24-Apr-09
605	20090255842	605 PERFORM VISUAL INSPECTION OF BOILERS	258000	20	06-Apr-09	07-May-09
605	20090256520	605 PERFORM VISUAL INSPECTION OF BOILERS	258000	0	07-Apr-09	07-May-09
605	20090288778	605:TEMP BOILER PLANT DAILY ROUTE	1116822	0	01-May-09	07-May-09