


Impacts of Integrating Renewable Energies into the Electrical Grid

Jim Brainard
Charles Bryan
Joe Hardesty

US Electric Grid: Regions & BAs

Regions and
Balancing Authorities



Electrical Power Plants: All

About This Map »

Roll over the dots for detailed information about each power plant. Use the dropdown below to filter power plants by type.


POWER PLANTS

All plants ▼

Dots are sized with respect to each plant's annual net generation of power.


EXISTING LINES

Existing electric power grid




NOTE: Data for this map comes from the U.S. EPA's eGRID database. Not all power-generating facilities in the U.S. are plotted on this map.


Power Plants: Dispatchable




■ Coal




■ Natural Gas




■ Nuclear



■ Hydro



■ Oil




■ Biomass


■ Dispatchable:

□ Can generate on-demand to meet load

Power Plants: Nondispatchable




■ Wind



■ Solar

- Nondispatchable:
 - Can NOT generate on-demand to meet load

Electric Grid: Future Renewables



■ Wind energy transmission




■ Solar energy transmission



New Mexico BA: Load & Generators

Summer Peaks:
BA Transactions

■ Typical Load Profiles



New Mexico BA: Generator Types

NM Balance Area: Generator Type Properties


Generator (Type)	Unit size (MW)	Units/ plant (#)	Load Regulation (% available)	Min-Max Energy (MW/unit)	Stop- start (hours)	Startup (hours)	Ramp Rate (MW/min/unit)
Nuclear   	1000	1	0	200	n/a	n/a	0
Coal   	400	3	20	320-400	180	8	10
CC Gas  	200	1	30	140-200	180	2	20
Gas Turbine 	100	6	40	60-100	2	0.33	30
Wind 1 	204*	1	n/a	0-204	2	n/a	n/a
Wind 2 	90*	1	n/a	0-90	2	n/a	n/a

* 2007 wind farms modeled, current NM wind capacity is 496 MW

Legend:


-  Always on
-  Seasonal
-  Baseload (minimal on/off)
-  Peak Load Follow
-  Intermittent

New Mexico BA: Generators & Load



- Load-matching & Generator Differences:
 - Unit capacities
 - Unit ramp rates
 - Unit shut-down/restart limitations
- As load increases, follow capacity increases


New Mexico BA: Generators & Load



- Load-matching & Model Lookup Tables:
 - Summer: include CC Gas
 - Spring: no CC Gas
 - All seasons: Coal units shutdown/startup
 - Problematic condition

New Mexico BA: Wind

New Mexico - Wind Resource at 50 m



Wind Resources in NM:

- two wind farms in 2007
- 2007 capacity ~294 MW
- current utility wind ~496 MW


2007 wind farms

Wind Power Classification

Wind Power Class	Resource Potential	Wind Power Density at 50 m W/m ²	Wind Speed ^a at 50 m m/s	Wind Speed ^a at 50 m mph
1	Poor	0 - 200	0.0 - 5.9	0.0 - 13.2
2	Marginal	200 - 300	5.9 - 6.7	13.2 - 15.0
3	Fair	300 - 400	6.7 - 7.4	15.0 - 16.6
4	Good	400 - 500	7.4 - 7.9	16.6 - 17.7
5	Excellent	500 - 600	7.9 - 8.4	17.7 - 18.8
6	Outstanding	600 - 800	8.4 - 9.3	18.8 - 20.8
7	Superb	> 800	> 9.3	> 20.8


^a Wind speeds are based on a Weibull k of 2.0 at 1500 m elevation.

New Mexico BA: Wind Vs Load



- Wind generators are never turned off:
 - satisfy mandated renewable energy portfolios
 - model can consider this as “deducted load”
- Result is too much generation (where load penetrates baseload region)

New Mexico BA: Wind Vs Load






- Consider 3x 2007 wind generators (never turned off):
 - greater penetration into **baseload region**,
 - greater range of load change (min vs max load)
 - need **more generator ramping capacity at lower loads**
 - **wind generation** peaks and **load peaks** do not match

New Mexico BA: Model Structure


- Based on existing infrastructure of transmission and balance areas, what are considerations regarding multiple generator types/sources?
- Model stuff...
 - Model Graphic/diagram/flowchart
 - Model description

New Mexico BA: Model Results





- Base Case (Summer):
 - all generators, **no wind**
- Case 1 model:
 - all generators **+ 10x wind**
- Case 2 model:
 - all generators **minus 1 coal unit + 10x wind**
- Case 3 model:
 - **Case 1, no ramping**

New Mexico BA: Model Results



- Base Case (Summer):
 - all generators, **no wind**
- Case 1 model:
 - all generators + **10x wind**
- Case 2 model:
 - all generators **minus 1 coal unit + 10x wind**
- Case 3 model:
 - **Case 1, no ramping**



Renewable Generators: Intermittent!

■ Model Limitations:

- ❑ Generators
 - (solar absent, ramp rates, start lag, off-line intervals, etc.)
- ❑ Regulation (ACE, market economics)
- ❑ 24-hr forecasting (1-hr forecasting modeled)
- ❑ Storage systems
- ❑ Metrics (costs, GHG emissions, water use, etc.)

■ Penetration remedies:

- ❑ Storage (long term solution)
 - pumped hydro, compressed gas, batteries, solar thermal, fuel cells, flywheels, capacitors, etc.
- ❑ Improved renewable systems (intermediate term solution)
- ❑ Grid integration across sectors (long/intermediate solution)
 - better load matching from more renewable generators
 - more acceptance of 1-hr forecasting
- ❑ Shut down wind when loads low (short term solution)
 - use wind for peak loads only

Electrical Grid Storage: Types


Electrical Grid Storage Options:					(conversion) Power	(total) Energy		Energy Cost		
Type/description	Capacity (MWhrs)	Charge Rate (MW)	Discharge Rate (MW)	Min Charge State(%Capty)	Efficiency (%)	Efficiency (%)	Response time(cycle)	Cost (\$/MWh)	Notes/comments	References
Battery Systems										
> Lead-acid	5-160		0.001-50.0	40-50	85	75-80	<1/4	0.15-0.27	Poor energy density, short cycle life, high maintenance, toxic materials. Most cost-effective electrical storage known, most mature. Float charging = constant voltage applied to fully-charged battery, to counter self-discharge, ensures fully charged when needed. In 1999, 93.3% of battery lead recycled, and large % of plastic battery case.	(SandRprt-4247,2008) (Kaldellis,Energy,2007) (SandRprt-0765,2001) (Duflo-Lopez,EP,2009)
> VRLA/OPZS batteries	3	1.75-6 hrs		20				0.2		(SandRprt-4247,2008) (Duflo-Lopez,EP,2009) (Hund-Testing,2008)
> Ni-Cd	7		0.001-25.0			70-90		0.60	Deep discharge reduces life	(SandRprt-4247,2008) (Kaldellis,Energy,2007) (McDowall,JPS,2006)
> Na-S	1-7	recharge: 5-10hrs for Hi-pulse 2x30sec discharge/hr, or Hi-pulse 5min discharge/12hr	0.05-6.0	1-40 (10 typ)	86-90	75-85		0.17-0.35	High energy density (3x lead-acid), long life w/ deep discharge, most suitable economically for energy management. Environmentally benign, sealed, no emissions, >99% recyclable, inexpensive. Total capital cost for 10MW system = \$3.1-3.4/MW.	(SandRprt-4247,2008) (Kaldellis,Energy,2007) (SandRprt-0765,2001) (Duflo-Lopez,EP,2009) (Oshima,ACT,2004) (EPRI-DOE,2003)
> Ni-MH								0.35		(SandRprt-4247,2008)
> Na-NiCl (ZEBRA)	0.01-10	recharge: 1 hr (20KWh cell)		0	100			0.15	Related to Na-S batteries. High power density with repeated heavy discharges, long life. Batteries stored fully charged indefinitely, no maintenance. Suitable for load leveling, peak storing, power conditioning at 0.1-10MW/h.	(SandRprt-4247,2008) (BetaRsrch-App,2005) (Tilley,EVS-18,2001)
> Li-Ion								0.78		(SandRprt-4247,2008)
> flow batteries (Zn-Br, Vanadium redox, polysulfide Br)	0.02-100	recharge: 4hrs	0.02-100.0	1	75-85	60-70	<1/4	0.24-1.5	Total capital cost for 10MW system (Vanadium redox)= \$4.3-4.5/MW.	(Kaldellis,Energy,2007) (McDowall,JPS,2006) (SandRprt-4247,2008) (SandRprt-0765,2001)
Capacitors										
> Electrochemical								0.25	High-power, short-duration: capable of deep discharge and virtually unlimited cycle life.	(SandRprt-4247,2008)
> Ultracapacitors	0.0001	same	0.01-1.0			95	<1/4	82	Short-term (seconds duration), costs thus in \$/MW instead of \$/MWh.	(SandRprt-4247,2008)
> Lead-carbon (hybrid)		1.2 hrs (3x lead-acid rate) - 20hrs		0.1	95	90-95		0.24	Short term (seconds duration)	(Kaldellis,Energy,2007) (SandRprt-0765,2001) (McDowall,JPS,2006)
> Stores energy both chemically (battery) and statically (capacitor).										(SandRprt-4247,2008) (AxionPwr-Tech,2004) (Lam,JPS,2006)
Pumped Hydro	5,000-50,000		100-1000	5	85	65-80	minutes	0.02-2.0	Large storage can provide up to 1GW power for days. 22 GW at 150 facilities in 19 states -- almost exclusively utility-owned/operated, size up to 2.1 GW. Total capital cost for 1GW system = \$0.98/MW.	(Kaldellis,Energy,2007) (SandRprt-0765,2001) (EPRI-DOE,2003)
Flywheels										
> Low-speed	0.01-0.6	10sec-2.5min	0.1-2					0.3	Short term (10-30secs duration), one type up to 3hr duration	(Kaldellis,Energy,2007) (EPRI-DOE,2003)
> High-speed	<0.05	15sec-2.5hr	0.01-0.7			90		0.35-25	Short term (10-15sec).	(SandRprt-4247,2008) (SandRprt-0765,2001) (McDowall,JPS,2006)
> Short/med term (15sec-3hrs).										(SandRprt-4247,2008) (SandRprt-0765,2001) (McDowall,JPS,2006)
Compressed Air (CAES)										
> Large storage can provide up to 1GW for up to days. Total capital cost for 300MW system = \$0.65/MW	4000		25-350	30-45	80-85	70-80				(Kaldellis,Energy,2007) (EPRI-DOE,2003)
> aquifer	10,000	12hr full recharge	350					0.002		(SandRprt-0765,2001)
> pressure vesssels	200-400		25-100					0.4-0.8		(SandRprt-0765,2001)
Hydrogen/Fuel Cells										
> Stores energy both chemically (battery) and statically (capacitor).	0.1-24		0.05-5.0	10	40-70	25-45	seconds	0.4-1.33		(Kaldellis,Energy,2007) (SandRprt-0765,2001) (Duflo-Lopez,EP,2009)
SMES: superconducting magnetic energy storage										
> Short term (seconds duration)	1-5000		1-1000				<1/4			(Kaldellis,Energy,2007) (SandRprt-0765,2001) (EPRI-DOE,2003)

Acknowledgements:

- Abraham Ellis
 - Grid operations information
 - Data for load and generators
 - Model development feedback
- Georgianne Peek
 - Electrical storage technologies
- Abas Akhil
 - Grid operations information
- Dan Riley
 - Solar generation data

- **Take Home Message:**
 - Introduction of intermittent supply generators (wind, solar, tidal/ocean) results in significant (and sometimes rapid) imbalances in grid unless remedied.
 - More imbalances → more disruption of grid

Thank You!



It's 8pm -
do you know
how the US
power grid is
holding up?