

Designing Networks of Cogenerative Fuel Cell Systems for Reducing Greenhouse Gas Emissions, Energy Costs, and Barriers-to-Entry for Manufacturers

**Dr. Whitney G. Colella
Truman Research Fellow
Sandia National Laboratories**

**Thursday Dec. 6th, 2007
Fraunhofer Institute for Solar Energy Systems (ISE)
Freiburg, Germany**

Motivation


Potential Energy Savings of Fuel Cells: 1/5th of Consumption in USA



Potential Energy Savings of Fuel Cells: 1/5th of Consumption in California

Heat lost: 1570 Trillion BTU = 1/5th of total

Heat re-generated:
2400 Trillion BTU



Cogen or Combined Heat and Power (CHP)

Conservation of Energy (1st Law of Thermodynamics)

$$\Delta U = W_{\text{elec}} + Q_{\text{lost}} + Q_{\text{recov}},$$

ΔU = total internal energy of the fuel consumed at the power plant

W_{elec} = electric power output of the plant

Q_{lost} = heat losses from the plant

Q_{recov} = heat that is usefully consumed in an end-use application, such as heating an industrial process in a chemical plant, providing space heating for a building, or providing hot water heating.

Cogenerative Fuel Cell Systems Fueled by Natural Gas Make 1/3rd the CO₂ as Conventional Systems


	Source of Electricity or Heat	CO ₂ Emission Factor (g/kWh_e or g/kWh_heat)	Electricity Production (MWhr)	Heat Production (MWhr)	CO ₂ Emissions (kg)
Case 1: Conventional System	Coal Power Plant with Steam Turbine	860	2	0	1720
	Coal Fired Boiler / Furnace	410	0	1	410
	Total		2	1	2130
Case 2: Average System	Mix of 1999 US Electric Generation Plant	600	2	0	1200
	Boiler / Furnace (72% efficient)	280	0	1	280
	Total		2	1	1479
Case 3: Advanced System	Cogenerative Combined Cycle Gas Turbine	380	2	0.71	760
	Boiler / Furnace (92% efficient)	219	0	0.29	64
	Total		2	1	824
Case 4: Fuel Cell System fueled by natural gas	Cogenerative Molten Carbonate Fuel Cell	373	2	1	746
Case 5: Fuel Cell System fueled by renewable hydrogen	Cogenerative Molten Carbonate Fuel Cell	0	2	1	0

Greenhouse gas emissions can be greatly reduced with fuel cell systems designed to **recover heat**.

Background

Non-Networked vs. Networked


Non-Networked / Stand Alone



Fuel cells can NOT convey excess heat or electricity into the distribution grid to reach other buildings.

Electricity
Heat


Networked



Fuel cells CAN convey excess heat or electricity into the distribution grid to reach other buildings. Transmission Loss: Electrical ~0%, Thermal ~8%


Networks have energy distribution channels

Load following heat vs. electricity vs. constant output



Load following the electrical demand results in byproduct heat, and vice versa. No load following is constant output.

Fixed vs. Variable Heat-to-Power Ratio



- Thermal Energy Recovered (kW) with a Fixed Heat-to-Power Ratio ~ 1.3
- Maximum Thermal Energy Recovered (kW) with a Variable Heat-to-Power Ratio ~ 2.5

Methods to Achieve a Rapidly Variable Heat-to-Power Ratio; Colella, JPS, 2002


I Vary the ratio of reactants, the temperature, and/or the pressure in the fuel processing sub-system to alter the energy consumed or released by the fuel reforming reactions, and to alter the amount of fuel flowing to the fuel cell, and the heat it releases. (Exp. – operate reformer as SR, POX, or AR by changing S/C)

II Vary the fuel flow rate to the anode off-gas burner

III Vary the system's electrical configuration

IV Change the shape and/or position of the polarization curve during operation

V Use resistance heater but potentially with decreased cell lifetime and increased cell degradation



MTU (Daimler Benz) design – Options I and II: Bypass fuel flowing to fuel cell to combust in reformer

What are California's baseline CO₂ emissions
from electric power?

Federal and State CO₂ Estimates Differ by 34%

		1990	2000	2004	Average	Total
Row	CO ₂ Emissions from In-state Electricity Generation (MMTCO ₂ /yr)					
A	Department of Energy (DOE) Data	53.1	66.8	60.7	56.5	848
B	California Energy Commission (CEC) Data	36.5	51.9	47.1	42.4	636
Discrepancy (CEC - DOE Data) as a Percent of CO ₂ Emissions from						
C	In-State Electricity Generation	-45%	-29%	-29%	-34%	
D	Total CO ₂ Emissions in CA	-6%	-4%	-4%	-4%	

Federal CO₂ emission data series differ from state data series by 34% for the California in-state electricity sector.

Million Metric Tonnes of Carbon Dioxide per year (MMTCO₂/yr)

Normal font shows reported data; italic font shows calculated data.

DOE-EIA and CEC-LBNL Historical CO₂ Data Series Differ by 34% for Electricity in California

		1990	2000	2004	Average	Total
Row	CO ₂ Emissions from In-state Electricity Generation (MMTCO ₂ /yr)					
A	Department of Energy (DOE) Data	53.1	66.8	60.7	56.5	848
B	California Energy Commission (CEC) Data	36.5	51.9	47.1	42.4	636

Discrepancy (CEC - DOE Data) as a Percent of CO₂ Emissions from

C	In-State Electricity Generation	-45%	-29%	-29%	-34%
D	Total CO ₂ Emissions in CA	-6%	-4%	-4%	-4%

- Data series by DOE's Energy Information Administration (EIA) differs from data series by California Energy Commission (CEC) and Lawrence Berkeley National Laboratories (LBNL)

DOE and CEC CO₂ Data Series Use the Same Methods and Data Sources

- Both calculate CO₂ emissions (\underline{m}_{CO_2}) according to:

$$\underline{m}_F \bar{\gamma}_{F-CO_2} = \underline{m}_{CO_2} \quad \text{where}$$

\underline{m}_F = fuel consumption from power plants of one fuel type

$\bar{\gamma}$ = the average annual emission factor per unit of fuel
(constant all years)

- Both rely on data from the DOE's EIA for all values of m_F

Discrepancy in data series surprising given that
the same methods and data sources were applied

CEC-LBNL reported CO₂ Emissions **exclude** fuel for cogenerative heating, some fuel sources

Fuel Type	m_F Annual Fuel Consumption (Trillion BTUs - 10^{12} /yr)	$\bar{\gamma}_{F-CO_2}$ Average Annual CO ₂ Emission Factor per Unit of Fuel Consumption (MMTCO ₂ / Trillion BTU of Fuel)	m_{CO_2} CO ₂ Emissions (MMTCO ₂ /yr)
Natural Gas (NG)	1,061	0.0528	56.00
Coal (BIT)	0.9740	0.0935	0.0911
Total			56.09

$$m_F \bar{\gamma}_{F-CO_2} = m_{CO_2}$$

DOE-EIA reported CO₂ emissions – **include** fuel for cogenerative heating

Fuel Type	m_F Annual Fuel Consumption (Trillion BTUs - 10^{12} /yr)	$\bar{\gamma}_{F-CO_2}$ Average Annual CO ₂ Emission Factor per Unit of Fuel Consumption (MMTCO ₂ / Trillion BTU of Fuel)	m_{CO_2} CO ₂ Emissions (MMTCO ₂ /yr)
Natural Gas (NG)	1,197	0.0531	63.58
Coal (BIT)	41.12	0.0931	3.829
Petroleum Coke (PC)	28.66	0.1021	2.927
Distillate Fuel Oil (DFO)	8.061	0.0732	0.5901
Municipal Solid Waste (MSW)	8.080	0.0417	0.3368
Geothermal (Steam) (GEO)	256.0	0.0012	0.3099
Residual Fuel Oil (RFO)	3.089	0.0789	0.2437
Waste/Other Oil (WO)	1.724	0.0953	0.1642
Tire-derived Fuels (TDF)	0.0091	0.0860	0.0008
Gaseous Propane (PG)	0.0089	0.0631	0.0006
Jet Fuel (JF)	0.0076	0.0709	0.0005
Total			71.98

$$m_F \bar{\gamma}_{F-CO_2} = m_{CO_2}$$

DOE-EIA CO₂ Emissions – not reported – excludes fuel for cogenerative heating

Fuel Type	m_F Annual Fuel Consumption (Trillion BTUs - 10^{12} /yr)	$\bar{\gamma}_{F-CO_2}$ Average Annual CO ₂ Emission Factor per Unit of Fuel Consumption (MMTCO ₂ / Trillion BTU of Fuel)	m_{CO_2} CO ₂ Emissions (MMTCO ₂ /yr)
Natural Gas (NG)	1051	0.0531	55.81
Petroleum Coke (PC)	22.4	0.1021	2.287
Coal (BIT)	22.8	0.0931	2.121
Distillate Fuel Oil (DFO)	8.1	0.0732	0.5901
Municipal Solid Waste (MSW)	8.1	0.0417	0.3368
Geothermal (Steam) (GEO)	256.0	0.0012	0.3099
Residual Fuel Oil (RFO)	3.1	0.0789	0.2437
Waste/Other Oil (WO)	0.8	0.0953	0.0780
Tire-derived Fuels (TDF)	0.00875	0.0860	0.0008
Jet Fuel (JF)	0.00764	0.0709	0.0005
Gaseous Propane (PG)	0.00856	0.0631	0.0005
Total			61.77

Discrepancy partly, but not solely, from difference
in cogen heating

Sources of Discrepancy between DOE and CEC Data Series

CEC-LBNL data series **excludes**

- a portion of fuel/CO₂ from **coal** power plants
Reason => math error
- all fuel/CO₂ from plants **not fueled by natural gas or coal**
 - fuel/CO₂ from **petroleum coke, oil**
 - fuel/CO₂ from **non-fossil fuel** power plants
Reasons => math error; use of truncated EIA data set
- fuel/CO₂ for **cogen heating** from natural gas/other plants
 - Omitted for years 1990 to 1997 for natural gas
 - Re-allocated to “Industrial Sector” 1998-2004 for natural gas
 - Methods for other fuels unconfirmed; no answer to inquiries.


State data excludes CO₂ from coal, coke, oil, non-fossil fuels; re-allocates or omits cogen heating

Fraction of the Discrepancy between DOE and CEC CO₂ Data Allocated by Power Plant Fuel Type

Solid coloring = omissions;

hatched shading =

inconsistencies



We conclude Federal data is a more complete baseline.

Omissions or Inconsistencies?

Discrepancy between DOE and CEC data series is due to

- data omissions from 1990-1998, and
- omissions (53%) and inconsistencies (47%) from 1999-2004.

CEC: Arbitrary Segmentation of Heat Losses

$$\Delta U = X + Y$$

X = a portion of the total internal energy of the fuel consumed at the power plant that operators **choose** to associate with electricity production

Y = fuel consumption that operators **choose** to align with heat production

γ_{elec} = fraction of Q_{lost} that operators choose to align with electricity

$$X = W_{elec} + \gamma_{elec} Q_{lost}$$

$$Y = Q_{recov} + (1 - \gamma_{elec}) Q_{lost}$$

Electrical efficiency of power plants according to DOE method(η_D)

$$\eta_D = W_{elec} / \Delta U$$


Electrical efficiency of power plants according to CEC method(η_C)

$$\eta_C = W_{elec} / X$$

2001 Monthly Data Plotted

CEC reports lower magnitude, higher rate of increase

California's CO₂ Emission Factor For In-State Electricity Generation
Over Time: DOE vs. CEC Estimates



Results: Concerns with CEC Approach


- 1) Omitted Data for CHP Plants 1990-1997
- 2) Unverified Reallocation of Emissions
- 4) Diverse Method Applied for Imported Electricity
- 3) Arbitrary Segmentation of Heat Losses
- 5) Thermodynamic Consistency
- 6) Violation of International Standards on CO2 Accounting

Recommendations

- California Air Resources Board (CARB) should consider using original DOE-EIA data.
- National labs could act as a third-party reviewer of the state's CO₂ monitoring and reporting.
 - National lab assets: "honest broker," technically competent, no direct vested interests.

CEC Data Over-Estimates Power Plant Efficiency


Electrical Efficiency of Cogen Plants



2001 Monthly Data Plotted

What is the impact of the corrected CO₂ emission baseline on policy?

CA Legislated Goals Change



Results

- Differences between data series due to omissions in 1990-1999.
- Baseline emissions should be adjusted upwards.
- 2050 Total Targeted Reduction
 - CEC Baseline: 73.7 MMTCO₂
 - DOE Baseline: 82.5 MMTCO₂

How do CO₂ emissions from fuel cell systems compare
with California power generation
(using the correct baseline emissions)?

12 Scenarios: Change in CO₂ with Fuel Cell Systems

Fuel Cell Systems Replace Either 1) All Electric Generation, 2) All In-State Generation, or 3) All Electricity Imports in CA from 1990-2004


Non-Cogenerative FCS Consuming Natural Gas Fuel

Electrically Networked (ENW) -- Connected to the Distribution Grid Allowing the Inflow and Outflow of Electricity; Fixed Heat-to-Power (FHP) Ratio

Non-Load Following (NLF) at Maximum Electrical Efficiency (η_{e_max})

Four System Types:


- 1) Proton Exchange Membrane (PEMFC) $\eta_{e_max} \approx 32\%$
- 2) Phosphoric Acid Fuel Cell (PAFC) $\eta_{e_max} \approx 37\%$
- 3) Molten Carbonate Fuel Cell (MCFC) hybrid w/ downstream gas turbine $\eta_{e_max} \approx 54\%$
- 4) Solid Oxide Fuel Cell (SOFC) pressurized hybrid w/ downstream turbine $\eta_{e_max} \approx 60\%$




Plots: colors applied sigmoid function to data to highlight small variations in low positive and negative data values.

Blue & Green = Good (reduction in CO₂ emissions); Red and Black = Bad (increase in CO₂ emissions)


Fuel Cell Systems Replace 100% of Power



Fuel Cell Systems Replace In-State Power Only



Fuel Cell Systems Replace Imported Power Only



Results

For Non-Cogen FCS, ENW, FHP Ratio, NLF at ne_{max} :

Cumulative Change in CO ₂ 1990-2004 (MMT)				
Replace	PEM	PAFC	MCFC	SOFC
All Electricity Consumption	848	549	-54	-186
All In-State Generation	858	627	163	62
All Imports	-10	-78	-217	-247

1. All fuel cell types reduce CO₂ if replace imports.
2. Highest CO₂ reductions if MCFC or SOFC replace imports.
3. PEMFC and PAFC must operate cogeneratively with high effective heat recovery to reduce CO₂ effectively.

How do we install and operate fuel cell systems to maximize reductions in CO₂ emissions? And maximize financial savings?

- Focus on lower temperature systems (PAFC, PEMFC) because they are more tricky to implement for CO₂ reductions.
- Develop and apply custom simulation code for maximizing emission reductions and economic savings



Environmental and Financial Simulation

- Model optimizes FCS installation for a particular site, FCS type, and competitive environment.
- Examines game-changing operating strategies not common in commercial industry (HLF, VHP, NW)
- Model allows users to evaluate trade-offs among three competing goals – 1) cost savings to building owners, 2) GHG emission reductions, 3) FCS manufacturer profit
- Optimizes the percentage installation of FCS for minimum CO₂ emissions or maximum cost savings to building owners

Simulation Inputs

User Can Input

- Electricity and heating demand curves for buildings



- Operating and financial data for fuel cell systems and competing generators

	Amount Borrowed (or Credited) at Time t = zero	Annuity [P] (\$)	[A] (\$)
Fuel Cell System Costs -- Fixed Cost per year			
Capital Costs of 200 kW Fuel Cell System	\$ 950,000	\$ 137,869	
Installation Costs	\$ 250,000	\$ 36,281	
Commissioning Costs (Start-up, Testing, Tutorials for Operators)	\$ 20,000	\$ 2,903	
Shipping	\$ 20,000	\$ 2,903	
Premium Service Contract (Maintenance and Replacement) --			
Annuity Payments		\$ 60,000	
Fuel Cell System Incentives -- Federal and State			
California Self-Generation Incentive Program (CA SGIP) at \$2500/kWe	\$ 500,000	\$ 72,563	
Federal Investment Tax Credit (FITC) at \$1000/kWe	\$ 200,000	\$ 29,025	
Fuel Cell System Fixed Costs -- Total Yearly Fixed Costs			\$138,368

Fuel Cell System Operating Data	Quantity	Units
Maximum Electrical Output	200 kw	
Minimum Electrical Output	100 kw	
Maximum Heat-to-Electric Power Ratio	2.5	
Minimum Heat-to-Electric Power Ratio	1.3	
Baseline Heat-to-Electric Power Ratio for Fixed Heat-to-Pow	1.3	
Natural Gas Fuel Consumption (in Units of Energy) Per Unit of Electric Power Output	9,222	gas/kwh of electricity
Marginal Increase in Natural Gas Fuel Consumption (in Units of Energy) Per Unit of Additional Heat Demanded (Variable Heat to Power Ratio Scenarios Only)	3,791	BTU natural gas/kwh of electricity
Baseline System Electrical Efficiency	37%	
Baseline System Heat Recovery Efficiency	48%	
Baseline System Heat Losses (Percent)	15%	
Baseline System Combined Electrical and Heat Recovery Ef	85%	
Heat Recovery Efficiency of Burner-Heater for Marginal Heating (Variable Heat to Power Ratio Scenarios Only)	90%	

Simulation of Operating Strategies

Scenarios Evaluated

- Strategy I: Electrically and Thermally Networked (NW), Electricity Power Load Following (ELF), Variable Heat-to-power ratio (VHP)
- Strategy II: NW, Heat Load Following (HLF), VHP
- Strategy III: NW, Non-Load Following (NLF), Fixed Heat-to-power ratio (FHP)
- Strategy IV: Not Networked/ Stand Alone (SA), HLF, VHP
- Strategy V: SA, NLF, VHP

Example Results Shown for One Case Study

- PAFC vs. cogenerative combined cycle natural gas turbine
- A particular town's buildings and load curves

Scenario A: No state/federal incentives or carbon tax; Strategy I is only economical one

Strategy	Optimal installed fuel cell system capacity as a percent of average power (%)	Annual cost savings (%)	Change in CO ₂ compared with base case of no fuel cells (Metric Tonnes of CO ₂ /yr)
I	17%	3%	-29%
II	0%	0%	0%
III	0%	0%	0%
IV	0%	0%	0%
V	0%	0%	0%

Strategy I [NW, ELF, VHP]: economical with no subsidies

17% of average installed capacity, 3% savings, 29% less CO₂

Strategy I = *avant-garde*

Scenario B: State & federal incentives, no carbon tax; Strategy I = **most savings**, **least CO₂**; III = **most profit**

Strategy	Optimal installed fuel cell system capacity as a percent of average power (%)	Annual cost savings (%)	Change in CO ₂ compared with base case of no fuel cells (%)
I	24%	15%	-31%
II	38%	9%	-12%
III	46%	3%	-27%
IV	13%	1%	-20%
V	32%	2%	-25%

Strategy I: **24% of capacity, 15% savings, 31% less CO₂**

Strategy III [NW, NLF, FHP]: **46% of capacity, 3% savings, 27% less CO₂**

Dichotomy between optimal financial strategy for building owners and that for fuel cell manufacturers

Scenario B: Best Load Curves Strategies IV and V – Mudd/McCullough most savings; CIS most profit

Strategy IV

Building Type	Load Curve Based on this Building	Optimal Installed Fuel Cell System Capacity as a Percentage of Peak Power Demand throughout Energy Area (%)	Annual Cost Savings (%)
Wet Lab	Mudd (Seeley G) Chemistry	4%	1.5%
Dry Lab	McCullough (Jack A.)	1%	1.0%
Dry Lab	Mechanical Engineering Research La	1%	0.9%
Wet Lab	Center for Integrated Systems (CIS)	4%	0.8%
Dry Lab	Gates Computer Scier	1%	0.7%
Wet Lab	Gordon Moore Materials Research	1%	0.4%

Strategy V

Building Type	Load Curve Based on this Building	Optimal Installed Fuel Cell System Capacity as a Percentage of Average Power Demand throughout Energy Area (%)	Annual Cost Savings (%)
Dry Lab	McCullough (Jack A.)	2%	3.5%
Museum/Library	Cantor Center for Visual Arts	1%	3.2%
Dry Lab	Gates Computer Science	3%	3.2%
Dry Lab	Mechanical Engineering Research La	2%	3.2%
Wet Lab	Mudd (Seeley G) Chemistry	5%	3.1%
Housing	Wilbur Dining Hall	1%	3.0%
Wet Lab	Center for Integrated Systems (CIS)	9%	2.8%
Offices/Classrooms	Packard Electrical Engineering	1%	2.6%
Offices/Classrooms	Tresidder	1%	2.4%
Dry Lab	Ginzton (Edward L.) Labs & Annex	1%	2.4%
Housing	Lagunita Dining	1%	2.4%
Dry Lab	Green Earth Sciences	1%	1.2%

Scenario C: State & federal incentives, \$20/tonne CO₂

Strategy I = most savings, least CO₂; III = most profit

Strategy	Optimal installed fuel cell system capacity as a percent of average power (%)	Annual cost savings (%)	Change in CO ₂ compared with base case of no fuel cells (%)
I	28%	17%	-32%
II	44%	12%	-14%
III	49%	6%	-27%
IV	18%	2%	-25%
V	41%	4%	-31%

Strategy I: 28% of capacity, 17% savings, 32% less CO₂

Strategy III: 49% of capacity, 6% savings, 27% less CO₂

Scenario D: State & federal incentives \$100/tonne CO₂

Strategy I=most savings; III=most profit; V=least CO₂

Strategy	Optimal installed fuel cell system capacity as a percent of average power (%)	Annual cost savings (%)	Change in CO ₂ compared with base case of no fuel cells (%)
I	36%	25%	-32%
II	50%	20%	-15%
III	60%	13%	-30%
IV	28%	6%	-32%
V	51%	11%	-34%

Strategy I: 36% of capacity, 25% savings, 32% less CO₂


Strategy III: 60% of capacity, 13% savings, 30% less CO₂

Strategy V [SA, NLF, VHP]: 51% of capacity, 11% savings, 34% less CO₂

Three competing goals – 1) cost savings to building owners, 2) GHG emission reductions, 3) FCS manufacturer profit – maximized with three different strategies.


Highest savings for building owners with 1) Strategy I, 2) NW, 3) NW + ELF or HLF

Maximum Cost Savings with Fuel Cell Installations with an
Increasing Tax on Carbon Dioxide Emissions



Highest profit for fuel cell makers with Strategy III = close to status quo

Optimal Fuel Cell System Capacity Installed for Maximum Cost Savings
with an Increasing Tax on Carbon Dioxide Emissions



Highest CO₂ Reductions with Strategies I, III, V

Strategy	Optimal installed fuel cell system capacity as a percent of average power (%)	Change in CO ₂ compared with base case of no fuel cells (%)
I	40%	-32%
II	94%	-16%
III	85%	-32%
IV	57%	-23%
V	68%	-37%

1. **Highest cost savings with Strategy I (avant-garde)**
2. **Highest profitability with Strategy III (status quo)**
3. **Maximum CO₂ reductions with Strategy V (avant-garde) - most economical neither for buildings nor FCS makers - building load curves even more crucial (SA operation) -FCS must manipulate its operation to meet real-time electricity & heating demand w/o back-up**


Highest CO₂ Reductions for Stand-Alone Strategies with Certain Building Load Curves

Wet Laboratory Building Load Curve Has Highest CO₂ Reductions

Building Type	Load Curve Based on this Building	Optimal Number of Fuel Cell System Installations	Optimal Installed Fuel Cell System Capacity (MWe)	Optimal Installed Fuel Cell System Capacity as a Percentage of Peak Power Demand throughout Energy Area	Optimal Installed Fuel Cell System Capacity as a Percentage of Average Power Demand throughout Energy Area	Approximate CO ₂ Emissions from Electricity and Heat Provision (metric tonnes CO ₂ /yr)	Approximate Reduction in CO ₂ Emissions Compared with Base Case of No Fuel Cells (metric tonnes CO ₂ /yr)	Approximate Annual CO ₂ Emission Savings (%)
Wet Lab	Mudd (Seely G) Chemistry	9	1.8	7%	9%	12,240	5,730	32%
Offices/Classrooms	Braun Music	1	0.2	1%	1%	1,317	563	28%
Dry Lab	Ginzton (Edward L.) Labs & Annex	1	0.2	1%	1%	1,547	634	27%
Offices/Classrooms	Ceras	1	0.2	1%	1%	1,843	635	26%
Museum/Library	Cantor Center for Visual Arts	1	0.2	1%	1%	1,552	560	24%
Housing	Lagunita Dining	2	0.4	1%	2%	2,248	829	24%
Wet Lab	Gordon Moore Materials Research	6	1.2	4%	6%	6,815	2,291	23%
Dry Lab	Gates Computer Science	5	1	4%	5%	5,233	1,928	23%
Offices/Classrooms	Law Crown	3	0.6	2%	3%	4,793	1,401	23%
Offices/Classrooms	Tresidder	2	0.4	1%	2%	2,555	856	22%
Housing	Wilbur Dining Hall	2	0.4	1%	2%	2,021	638	22%
Other Type	Sweet	1	0.2	1%	1%	1,219	399	21%
Other Type	Faculty Club	1	0.2	1%	1%	1,219	399	21%
Wet Lab	Center for Integrated Systems (CIS)	12	2.4	9%	13%	16,918	5,297	21%
Housing	Stern Dining	2	0.4	1%	2%	2,247	605	21%
Offices/Classrooms	Packard Electrical Engineering	2	0.4	1%	2%	2,034	577	20%
Housing	Branner Hall	1	0.2	1%	1%	1,682	468	20%
Library	Green E	1	0.2	1%	1%	1,345	363	20%
Library	Meyer	1	0.2	1%	1%	1,345	363	20%
Offices/Classrooms	Lane History	0	0	0%	0%	891	82	9%
Dry Lab	McCullough (Jack A.)	3	0.6	2%	3%	3,394	0	6%
Housing	Florence Moore Kitchen	1	0.2	1%	1%	897	47	5%
Housing	Moore South	0	0	0%	0%	712	29	4%
Dry Lab	Mechanical Engineering Research Lab	3	0.6	2%	3%	4,154	0	4%
Dry Lab	Green Earth Sciences	3	0.6	2%	3%	3,735	0	3%
Housing	Xanadu	0	0	0%	0%	691	5	1%
Housing	Moore North	0	0	0%	0%	691	0	0%
Offices/Classrooms	Cummings Art	1	0.2	1%	1%	971	0	0%
Offices/Classrooms	TC Seq	0	0	0%	0%	850	0	0%
Dry Lab	Env Fluid Mech	0	0	0%	0%	597	0	0%

No particular building type = best

Top three load curves for reduced CO₂ (Mudd - red, Braun -black, Ginzten -green)



Results

1. FCS are marginally economical with no subsidies by changing to Strategy I (NW, ELF, VHP) *avant-garde*
2. Dichotomy between optimal financial strategy for building owners and that for fuel cell developers.
3. Maximum financial savings with particular load curves – wet and dry labs ~ 24-7 industrial facilities
4. With full state & federal incentives and a \$100/tonne CO₂ tax, three competing goals – 1) cost savings, 2) GHG emission reductions, 3) FCS maker profit – maximized with three different strategies:

Highest cost savings w/ Strategy I (*avant-garde*)

Highest CO₂ reductions w/ Strategy V (*avant-garde*)

Highest profitability w/ Strategy III (*status quo*)

Results II

1. Higher cost savings with NW
2. When NW, combining ELF or HLF with VHP has higher savings
3. Highest CO₂ reductions with Strategies I, III, V
(NW, ELF, VHP and HLF; SA, NLF, VHP)
4. Highest CO₂ reductions for stand alone installations V with certain building load curves (a particular wet laboratory's load curve), but not consistently for a building type (residence, etc.)
⇒ Crucial to use simulation to find best buildings

Conclusions


1. Must apply simulation to find the best installation strategy for a \$\$ or GHG goal
 1. No particular building *type* = best
 2. Load curves are crucial
 3. Maximum CO₂ reductions with Strategy V (SA)
 1. Load curves are even more crucial
2. *Avand guard* operating strategies can make FCS more economical and environmentally beneficial.

Recommendations

- 1. Create incentives for FCS makers to build VHP**
- 2. Encourage partnerships between FCS makers and energy service companies (ESCO)**
- 3. Focus on installing FCS within pre-existing thermal networks**
- 4. Apply simulations to identify specific building load curves ideal for installation**


Educating Policy Makers about Hydrogen

- “Designing Energy Supply Chains Based on Hydrogen [To Mitigate Climate Change],” by W. Colella in Climate Change Science and Policy: Stephen H. Schneider, Armin Rosencranz and Michael D. Mastrandrea, eds. 2008.
- Target audience: engineers & policy makers
- Editors are Stanford University researchers



Educating Engineers about Fuel Cells

- 1st Textbook on Fuel Cells: ***Fuel Cell Fundamentals***
O'hare, Cha, Colella, and Prinz
- Target audience: senior undergraduate or graduate student engineers
- Solved problems in textbox inserts and solutions guide
- Authors were Stanford University researchers



Acknowledgements

Stanford University: Professor Stephen H. Schneider

University of California at Berkeley: Professor Daniel M. Kammen

Sandia National Laboratories:

- Jay Keller, Andrew Lutz, Robert Schefer, Christopher Shaddix, Ronald Stoltz;
- Michael Hickner, Ellen Stechel, Nancy Clark, Abbas Akhil, Keith Vanderveen
- Susanna Gordon, Patricia Falcone, Don Hardesty

Department of Energy's (DOE) Energy Information Administration (EIA):

- Tom Leckey, Perry Lindstrom, Kevin Lillis, Channele Wirman, Orhan Yildiz

California Energy Commission:

- Gerry Bemis, Guido Franco, Adam Pan, Angela Tangetti, Ed Vine

California Air Resources Board: Richard Bode, Webster Tasat, Larry Hunsaker

LBNL: Stephane de la Rue du Can, Jayant Sathaye, Jonathan Koomey

Sun Microsystems: Kenneth Russell

Calpine Inc. (The Geysers): Barbara McBride, Mitch Stark

Competitive Power Ventures Inc.: Michael Hatfield

Extra

Future Work

- Develop more detailed fuel cell simulations
 - Quantify impact of seasonal variation in load curve
 - Change the operating strategy during the run – switch between operating strategies over time to minimize emissions or costs – find the mix of best operating strategies over time
 - More sophisticated power plant models (ASPEN chemical engineering / process modeling / system dynamics software)
 - Combine optimization code with more detailed FCS models (ASPEN)
 - Use NISAC's Platts power plant data – hourly supply data from every power plant in the US for electricity output, thermal output, and fuel consumption
 - Analyze the system impacts of high vs. low temperature PEM fuel cell systems for stationary power using Sandia's test data on PEM cells



What are California's CO₂ Emissions from Electricity Consumption?

Methodology:

- 1) EIA Monthly Electricity Sales Data 1990-2004
- 2) EIA Annual Direct Use Data 1990-2004 -- Monthly Sales Distribution Applied
- 3) Sales + Direct Use = Total Electricity Consumption
- 4) EIA Annual Net Generation Data 1990-2004 -- Monthly Sales Distribution Applied
- 5) Imports = Total Consumption – Net Generation
- 6) EIA Total CO₂ Emissions from Net Generation/EIA Net Generation = CO₂ Emissions Factor for Net Generation
- 7) EIA Total CO₂ Emissions from Net Generation (Monthly)
- 8) CEC Total CO₂ Emissions from Imports/CEC Electricity Imports = CO₂ Emissions Factor for Imports
- 9) EIA Imports * CO₂ Emissions Factor for Imports = Total CO₂ Emissions from Imports (Monthly)
- 10) Redistributed by Population

Visualizing CO₂ Emission Changes

- Custom Geographic Information System (GIS) application
- Linear, Logarithmic, Sigmoidal plots
- Logarithmic relationship between CO₂ concentrations and radiative forcing (heat trapping effect of global warming).
- CO₂ plotted at point of consumption, not generation, to link cause and effect. Environment indifferent to location of emission (unlike air pollution).
- Units: Metric Tonnes (MT) per month (Mo) per county (Cty)
- **Blue & Green** = Good; **Red and Black** = Bad
- EIA Logarithmic and Linear Plots:
 - EIA Logarithmic Plot: Colors applied logarithmically to the data to highlight variations at the low end. Top legend plots data values linearly. Bottom legend plots color spectrum linearly.
 - EIA Linear Plot: Colors applied linearly to the data. The legend shows the color spectrum linearly.



12 Scenarios: Change in CO₂ with FCS

FCS Replace Either 1) All Electric Generation, 2) All In-State Generation, or 3) All Electricity Imports in CA from 1990-2004


Non-Cogenerative FCS Consuming Natural Gas Fuel

Electrically Networked (ENW) -- Connected to the Distribution Grid Allowing the Inflow and Outflow of Electricity; Fixed Heat-to-Power (FHP) Ratio

Non-Load Following (NLF) at Maximum Electrical Efficiency (η_{e_max})

Four System Types:

- 1) Proton Exchange Membrane (PEMFC) $\eta_{e_max} \approx 32\%$
- 2) Phosphoric Acid Fuel Cell (PAFC) $\eta_{e_max} \approx 37\%$
- 3) Molten Carbonate Fuel Cell (MCFC) hybrid w/ downstream gas turbine $\eta_{e_max} \approx 54\%$
- 4) Solid Oxide Fuel Cell (SOFC) pressurized hybrid w/ downstream turbine $\eta_{e_max} \approx 60\%$



Proven efficiencies (η), except SOFC only modelled

Plots: colors applied sigmoid function to data to highlight small variations in low positive and negative data values.

DOE-EIA 906/920 Data Are Complete

- The DOE EIA calculations shown in **Table 2.0** are based on 906/920 databases. LBNL states, “we did not use the [DOE EIA’s] 906/920 for CALEB because these data do not include nonutility plants for years prior to 1999...and that would have resulted in a major hole in the data for 1990 to 1998.“
- However, by contrast, EIA states that “the 906/920 data set is complete (covers all producing sectors) from 2001 forward.”
- Furthermore, in response to the comment from LBNL above, EIA states, “There are no “major holes” in the EIA data series (plural). The analyst from Berkeley is not correct about what data are available from EIA. IF one were to try to use the EIA-906 to get consumption data series from 1989 to 2006, that would not be possible, because that particular Form (the 906/920) was not used prior to 2001. I guess the analyst wasn’t aware that the data were collected on other EIA forms. All the data were collected, but under different survey instruments. So no single survey instrument covers the entire time period. But there are no “major holes” because, TAKEN TOGETHER, the surveys collectively provide full coverage over the time period.”

LBNL-CEC Methodology

LBNL

- Transposed EIA fuel consumption data into CALEB database,
- Truncated this data (by using fossil fuel only data base), and
- Re-categorized this data (such as CHP-generated electricity and heat), and
- Multiplied some of the fuel consumption categories (excluding geothermal etc.) by emission factors to report CO₂ total emissions (CALEB CO₂).
 - Re-allocated the CO₂ emissions associated with CHP-generated heat and electricity from natural gas power plants into the industrial sector. Removed this data from the electricity sector.
 - *The same procedure applied to other fuels? (LBNL no respond to question.)*
 - Omitted CO₂ emission data from natural gas plant CHP-generated heat between 1990-1999 from the aggregate emission database entirely.

LBNL-CEC Methodology

CEC

- Copied CALEB fuel consumption data (originally EIA fuel consumption data) for natural gas and coal fuel consumption,
- Made a large typo in reporting coal consumption in the process (under-estimated fuel consumption and emissions by 98%),
- Truncated fuel consumption data by only considering two fuels.
- Did not report CO₂ emissions from CHP-generated heat under electricity sector emissions
- Did not report CO₂ emissions from CHP-generated heat under other sectors explicitly, so readers could identify this quantity.

Resulting value-added unclear.