

Sizing Behind-the-Meter Energy Storage and Solar for Electric Vehicle Fast-Charging Stations*



2020 DoE OE Energy Storage Peer Review
September 29th-October 1st 2020

PRESENTED BY

Rodrigo D. Trevizan, PhD

*R. D. Trevizan, T. A. Nguyen and R. H. Byrne, "Sizing Behind-the-Meter Energy Storage and Solar for Electric Vehicle Fast-Charging Stations," 2020 International Symposium on Power Electronics, Electrical Drives, Automation and Motion (SPEEDAM), Sorrento, Italy, 2020, pp. 583-588, doi: 10.1109/SPEEDAM48782.2020.9161848.

Introduction

Mass adoption of Electric Vehicles (EV) is under way

- Current EV fleet: 0.5%

Projections in 2040


- 57% of passenger vehicles sold
- 30% of world's fleet

Reducing cost of electricity in EV fast charging stations

- Net energy metering (NEM)
 - Opportunities for behind-the-meter (BTM) resources
- Battery energy storage systems (BESS)
 - Declining cost of Lithium-ion in 2010 – 2019: 0.50%
- Solar photovoltaic (PV) generation

This presentation

- Optimal sizing of PV + BESS
- Evaluation of potential cost savings



Problem formulation

Goal: maximize net present value (NPV) of investment

- Optimal sizing of PV and BESS
- Optimal dispatch of BESS
- Maximize cost savings
- Perfect load forecast – provide upper bound on NPV

$$\max_{q_t^c, q_t^d, \overline{q^m} \overline{S}, \overline{q_{PV}}} \sum_{k=1}^{n_y} \frac{R_k}{(1 + i_r)^k} - C_{in}, \forall t \in \Omega^t \quad (1)$$

s.t. (2) – (24)

q_t^c, q_t^d ESS charging,discharging power in time t , kW .
 $\overline{q^m}$ ESS rated charge and discharge power, in kW .
 $\overline{q_{PV}}$ Rated PV power output, in kW .
 R_k Total cost-saving in year k , in \$.
 C_{in} Total amount invested in PV and ESS, in \$.
 i_r Interest rate for payback.

Problem formulation

Cost savings: baseline (yearly) electricity costs minus cost with BESS and cost of degradation

$$R_k = \sum_{j \in \Omega_k^m} (\overline{C}_j - C_j - C_j^b), \forall k \in \{1, 2, \dots, n_y\} \quad (2)$$

Costs can include tariffs that feature

- Time-of-use (TOU) charges
- NEM
- Service cost
- Demand charges
- Energy charges

$$C_j = \underline{C} + D_j + E_j, \forall j \in \Omega_k^m \quad (4)$$

Problem formulation

TOU demand costs

- High peak, low peak and facility charges (last 12 months)

$$D_j = D_j^h + D_j^l + D_j^f, \forall j \in \Omega_k^m \quad (5)$$

TOU energy costs

- High peak, low peak and base rates

$$E_j = p_e^b \cdot e_j^b + p_e^l \cdot e_j^l + p_e^h \cdot e_j^h, \forall j \in \Omega_k^m \quad (17)$$

Degradation costs

- Throughput under warranty
- p_{th} is the ratio between cost of BESS warranty and throughput under warranty

$$C_j^b = p_{th} \cdot \sum_{i \in \Omega_k^t} q_t^d \cdot \Delta t \quad (13)$$

Problem formulation



NEM Policy – utility does not pay for surplus net energy

Battery Operation Constraints

- State-of-Energy (SoE) , maximum charging/discharging

$$0 \leq q_t^c \leq \overline{q^m}, \forall t \in \Omega^t \quad (20)$$

$$0 \leq q_t^d \leq \overline{q^m}, \forall t \in \Omega^t \quad (21)$$

$$0 \leq S_t \leq \overline{S}, \forall t \in \Omega^t \quad (22)$$

$$S_{t+1} = \Delta t \cdot \left(\gamma_s \cdot S_t + \gamma_c \cdot q_t^c - \frac{q_t^d}{\gamma_d} \right), \forall t \in \Omega^t \quad (23)$$

SoE in start of month

$$S_{t_0} = 0.5 \cdot \overline{S}, \forall t_0 \in \Omega^{t_0} \quad (24)$$



Los Angeles Department of Water and Power (LADWP) tariff A-2

- Large Commercial and Multi-Family Service (4.8kV)
- Demand over 30 kW
- NEM
- TOU

PARAMETERS OF LADW

Parameter	Summer
$\frac{C}{p_e^{b*}}$	\$28.00
p_e^l	\$0.01022/kWh
p_e^h	\$0.05595/kWh
n_e^h	\$0.06322/kWh

PARAMETERS OF LADWP TARIFF A-2


Parameter	Summer	Winter
C	\$28.00	\$28.00
p_e^{b*}	\$0.01022/kWh	\$0.01395/kWh
p_e^l	\$0.05595/kWh	\$0.05688/kWh
p_e^h	\$0.06322/kWh	\$0.05688/kWh
p_d^l	\$3.75/kW	—
p_d^h	\$10.00/kW	\$4.75/kW
p_f	\$5.36/kW	\$5.36/kW
d	\$30kW	\$30kW

* Includes electric vehicle discount rate of 2.5 cents per kWh.

Hour	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
January	¢1.395/kWh	¢5.688/kWh	¢5.688/kWh \$4.75/kW	¢5.688/kWh	¢1.395/kWh																			
February																								
March																								
April																								
May																								
June	¢1.022/kWh	¢5.595/kWh \$3.75/kW	¢6.322/kWh \$10.00/kW	¢5.595/kWh \$3.75/kW	¢1.022/kWh																			
July																								
August																								
September																								
October	¢1.395/kWh	¢5.688/kWh \$4.75/kW	¢5.688/kWh	¢1.395/kWh																				
November																								
December																								


Load profiles

- Based on EV Project data Los Angeles – 2013
- 4x type 2 chargers in station
 - 26.58kW constant load each



Load profiles


- Zero reactive power costs
- Data synthesized based on statistics of charging
- Distributions of time spent per charging session, energy used in each charging session



Case Study

Cost savings:

- Baseline vs costs with PV and ESS
- Following data, most costs are due to demand-related charges



Case Study

Resulting optimization problem is a Linear Program
Solution using Pyomo, a python-based optimization
toolbox

Time resolution of 15 minutes

- It is the same used to calculate demand and energy by meters

Solar profile created using PVWatts

Analysis over 10 years

- Solve for 1 year, assume similar results for coming years
- Assumed constant prices of electricity
- Assumed constant load

Results

Solution of the LP: 298 seconds (GLPK solver)


Energy equivalent of 170 cycles/year

No PV!

SUMMARY OF OPTIMIZATION RESULTS


	Variable	Value	Variable	Value
	PV cost	\$0.00	ESS cost	\$28551
	ROI	\$22374.50	n_y	10 yrs
	i_r	5%/yr	PV size	0.0kW
	ESS power	46.49 kW	ESS energy	28.26kWh
Base	Max demand	79.70kW	Energy	46.7MWh/yr
	Demand cost	\$10592.70/yr	Energy cost	\$1565.58/yr
	Service	\$336.0/yr	Total cost	\$12494.28/yr
ESS	Max demand	33.21kW	Energy	47.4MWh/yr
	Demand cost	\$3958.35/yr	Energy cost	\$1413.82/yr
	Throughput	4.8MWh/yr	Degradation	\$504.80/yr
	Total electr.	\$5708.17/yr	Total cost	\$6212.97/yr

Results




Results


ESS Charge and Discharge




Net Demand



State of charge



Results



Conclusion

BESS was able to provide significant cost savings

- Baseline costs dominated by demand charges (85%)

PV could not contribute

- PV can reduce energy charges, which are marginal in this problem

PV only makes sense if:

- Cost is reduced
- Charging/occupation rate of chargers increase
- Tariff of energy (kWh) increases significantly

Degradation results in significant reductions in ESS operations

Optimal sizing

- Enough energy to supply for a mean charge
- Enough power capacity to supply 2 chargers

Optimal operation

- Charge battery to restore SoE when demand for chargers and energy costs are low - night/early morning
- Discharge BESS when two or more chargers are being used

Publication

R. D. Trevizan, T. A. Nguyen and R. H. Byrne, "Sizing Behind-the-Meter Energy Storage and Solar for Electric Vehicle Fast-Charging Stations," 2020 International Symposium on Power Electronics, Electrical Drives, Automation and Motion (SPEEDAM), Sorrento, Italy, 2020, pp. 583-588, doi: [10.1109/SPEEDAM48782.2020.9161848](https://doi.org/10.1109/SPEEDAM48782.2020.9161848).

Acknowledgment

This research was funded by the energy storage program at the U.S. Department of Energy under the guidance of **Dr. Imre Gyuk**. Sandia National Laboratories is a multi-mission laboratory managed and operated by National Technology and Engineering Solutions of Sandia, LLC., a wholly owned subsidiary of Honeywell International, Inc., for the U.S. Department of Energy National Nuclear Security Administration under contract DE-NA-0003525. This paper describes objective technical results and analysis. Any subjective views or opinions that might be expressed in the paper do not necessarily represent the views of the U.S. Department of Energy or the United States Government.

Thank you!

Q&A?