



Permitting for a Gen 3 Pilot-Scale Sodium and Molten Salt System



Dimitri Madden¹, Kenneth M. Armijo¹ and Rip Winckel¹

¹Concentrating Solar Technologies Department 8823, Sandia National Laboratories, PO 5800 MS 1127, Albuquerque NM, USA 87185




Sandia National Laboratories is a multimission laboratory managed and operated by National Technology & Engineering Solutions of Sandia, LLC, a wholly owned subsidiary of Honeywell International Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA0003525.

Gen 3 Pilot-Scale Pathway




- A Generation 3 liquid-pathway, pilot-scale sodium and molten chloride salt concentrated solar power (CSP) system is in development at Sandia National Laboratories (SNL).
- The project will be developed at SNL's National Solar Thermal Test Facility (NSTTF), residing on U.S. Kirtland Air Force Base (KAFB).
- The 2 MW_{th} system will consist of a sodium receiver in conjunction with a ternary chloride salt loop for up to 6 hours of thermal energy storage (TES). The TES is connected to an sCO₂ power block.



ES&H WPC Process

- Work Planning & Controls (WPC) – ES&H hazard identification and mitigation.
 - WPC – Intent is to de-risk a project to an acceptable level of risk.
 - SNL risk management to avoid unacceptable consequences.
- Permitting and ES&H WPC are on track to date.
- SNL WPC Integrated Safety Management (ISM) process
 - For defining, analyzing & controlling project hazards.



Permitting

- Several permitting requirements are necessary to proceed with pilot-scale construction, pertaining to both the DOE and the U.S. Air Force.
- AF813 forms are a requirement for environment and hazard analysis.
- SNL NEPA controls include Air Quality Permits, Hazwaste stream & Stormwater requirements, and biological survey requirements.
- NFPA code requirements must be met including adherence to NFPA requirements (e.g. NFPA 400), Life Safety Systems Analysis, and Fire Hazard Analysis
- Primary Health Screening (PHS) is the primary beneficiary from staged sodium fires. The risks of sodium fires must be demonstrated for proper NFPA hazard analysis.

NEPA Additional Requirements

- Air Quality Requirements
 - Fugitive Dust Control Permit required prior to operations start.
 - Air Quality Control ES&H application with SNL & KAFB.
- Waste Stream & Stormwater Requirements
 - National Pollution Elimination Discharge System (NPDES) Construction General Permit (CGP) – Stormwater run-off.
 - For National Laboratories - requirements for waste removal from a project site.
 - Waste disposal description reports (WDDR) tool based on Safety Data Sheet (SDS).
 - Waste-related items: Salt sludge, waste construction debris, hazardous waste, emissions quantities, etc.
 - Managed in accordance with SNL Env. Compliance Coord. (ECC) & SNL Waste disposal program.
- Biological Requirements
 - Bio Survey required 3 wks. before project during breeding season (March 1- September 15)
 - Ecological open trenching/Hole excavation mitigation.
 - Notification of any bird mortalities to Ecology Program.

6 | Purpose of Sodium Fires

- The Gen-3 project requires extensive permitting to ensure code and environmental safety & health (ES&H) compliance.
- In order to understand risks and hazard mitigation for permitting, a series of staged sodium fires has been conducted.
- The staged fires demonstrated the unique risks of molten sodium, mitigation practices, and the repeatability of data from previous sodium studies, all for ease of permitting.
- The fires also served as demonstrations to the KAFB Fire Departments and SNL Emergency Management.


Sodium Tests Conducted

Test Date	Test #	Fire Type	Target Sodium Mass [kg]	Target Temperature (Celsius)	Fire Extinguishing Method	PPE	Instrumentation
Thurs, June 18	Shakedown A	Pool Fire	0.05	150	Soda Ash	Alkali Metal "Space Suit" - Hazard Level B PPE	High-Speed Cameras, TCs, IR, Air Humidity
Mon, June 22	Shakedown B	Pool Fire	0.05	150	Soda Ash	Alkali Metal "Space Suit" - Hazard Level B PPE	High-Speed Cameras, TCs, IR, Air Humidity
Mon - June 22	Shakedown C	Pool Fire	0.50	150	Soda Ash	Alkali Metal "Space Suit" - Hazard Level B PPE	High-Speed Cameras, TCs, IR, Air Humidity
Mon - June 22	Shakedown D	Pool Fire	1.00	500	Soda Ash	Alkali Metal "Space Suit" - Hazard Level B PPE	High-Speed Cameras, TCs, IR, Air Humidity
Mon - June 22	Shakedown I	Pool Fire with Concrete	1.00	500	Soda Ash	Alkali Metal "Space Suit" - Hazard Level B PPE	High-Speed Cameras, TCs, IR, Air Humidity
Tues- June 23	1	Pool Fire	2.00	500	Soda Ash	Alkali Metal "Space Suit" - Hazard Level B PPE	High-Speed Cameras, TCs, IR, Air Humidity
Tues- June 23	2	Pool Fire with Concrete	2.00	500	Soda Ash	Alkali Metal "Space Suit" - Hazard Level B PPE	High-Speed Cameras, TCs, IR, Air Humidity
Weds - June 24	3	Spray Fire	0.50	300	Soda Ash	Alkali Metal "Space Suit" - Hazard Level B PPE	High-Speed Cameras, TCs, IR, Air Humidity
Thurs - June 25	4	Solid Sodium Cutting	1.00	Room Temp	N/A	Safety Goggles, Chemical Handling Gloves	High-Speed Cameras, TCs, IR, Air Humidity
Thurs - June 25	5	Spray Fire with Concrete	2.00	500	Soda Ash	Alkali Metal "Space Suit" - Hazard Level B PPE	High-Speed Cameras, TCs, IR, Air Humidity

- Two variants of fires were staged, pool and spray fires.
- 9 fires were staged at varying temperature and sodium sample size.
- Fires were staged at a SNL explosive test pad, with all operations conducted remotely from within a bunker.


Test Rig

- For safe, remote conduction of the fire variants, a test rig was developed at the NSTTF allowing for both spray and pool fires.
- The test rig is divided in half with a system for pool fires on the left and a system for spray fires on the right.



9 | Pool Fire Test Rig

- Pool fires were staged using a propane burner, a 316 S.S. bowl, and a catch pan. Thermocouples were placed on the walls and center of the bowl.
- Desired quantities of sodium were cut, weighed, and placed in the bowl. Concrete was added to the bowl for certain tests.
- The bowl was centered on the propane burner, which was ignited and used to melt the sodium into a thick pool. After ignition, the molten sodium was left in the bowl to completely react out.





2.0kg Pool Fire with Concrete

10





0.057kg Pool Fire Data

- Three TC's placed at bottom of bowl where sodium was placed as blocks and melted non-uniformly.
- Relatively smooth temperature increase with a large excursion during ignition.




2.0kg Pool Fire Data

- Larger sodium blocks facilitated non-uniform heating and caused an initial spike in Temps.
- Ignition was observed to be more gradual than with the smaller volume.



Spray Fire Test Rig



- Spray fires were simulated using a custom-built spray cannister wrapped in heat trace.
- The cannister was constructed of 304 SS pipe with a welded end plate on the bottom and a manway cover with graphite gaskets on top.
- Argon cover gas was supplied through the side wall.
- A Swagelok pneumatically-actuated bellows valve was welded to the bottom.
- Sodium samples were placed inside and heated to the desired temperature before remote triggering of the Swagelok valve to dump the sodium



2.0kg Spray Fire



Spray Fire Data



Firefighting Observations

- KAFB Fire Department personnel extinguished sodium fires by cycling the addition of soda ash & stirring it. This was repeated multiple times in 10-15 minute increments.
- Fire personnel noted a crust of sodium/soda ash residue. Unreacted sodium remained within the residue, able to reignite and burn with visible popping and flames after primary testing was complete.
- The bowls of sodium and soda ash residue were dumped in a large metal container where they were completely reacted out.
- Within the container, the sodium was stirred with a metal rod and gradually sprayed with water to break up the lumps and react out remaining sodium.



Conclusions

- NEPA Flow-down requirements needed prior to construction.
 - Air Quality Requirements
 - Waste stream & stormwater requirements
 - Biological Requirements
- SNL Health & Safety (Primary Hazard Screening - PHS) – Ongoing.
- Sodium fire ignition occurred on average at approximately 317 °C, higher than literature suggested for our conditions.
- The time for sodium fires react out increased with the initial sodium mass.
 - 2.0 kg tests required over 1.5 hours to ignite.
- The addition of concrete to the pool fires resulted in spalling and higher sodium fire temperatures (>900 °C).
- Spray fires did not result in auto-ignition upon exposure to air unless the sodium particle size was significantly small


Acknowledgements

This work is funded in part or whole by the U.S. Department of Energy Solar Energy Technologies Office under DOE-1697-1544.

Disclaimer: report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Sandia National Laboratories is a multi-mission laboratory managed and operated by National Technology & Engineering Solutions of Sandia, LLC, a wholly owned subsidiary of Honeywell International Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA0003525.

Thank you.



Acknowledgements

Sandia National Laboratories is a multi-mission laboratory managed and operated by National Technology and Engineering Solutions of Sandia, LLC., a wholly owned subsidiary of Honeywell International, Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA0003525