




*Exceptional service in the national interest*



## Benchmark Study of the Accident at Fukushima (BSAF) Overview

R.O. Gauntt

Severe Accident Analysis Department, Sandia National Laboratories

CSARP/MCAP Meeting, Bethesda MD



Sandia National Laboratories is a multimission laboratory managed and operated by National Technology & Engineering Solutions of Sandia, LLC, a wholly owned subsidiary of Honeywell International Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA0003525. SAND2020-XXXX

# WHAT STARTED IT ALL




Naoto Kan  
Japanese prime minister

[guardian.co.uk](http://guardian.co.uk)

# Perspectives.....

- ~20,000 dead or missing from the tsunami
- 2 industrial deaths at Fukushima Nuclear power plant
- No radiation induced fatalities
- 150,000 people displaced from homes
- All 50 nuclear power plants in Japan shut down
- What happened?



# BSAF Phase 1

- OECD/NEA activity hosted by Japan Institute of Applied Energy
- Benchmark Study of the Accidents at Fukushima
- Partly severe accident code benchmarking
- Partly forensics study into causes and progression of accident building on clues (sparse measurements and ill defined boundary conditions)
- Major severe accident competent nations
  - USA, Japan, Spain, Switzerland, Germany, Finland, Russia ....
  - MELCOR, MAAP, ASTEC, SAMPSON, SOCRAT
- Focus on reactor and containment damage during first days of accidents

*Exceptional service in the national interest*



Photos placed in horizontal position  
with even amount of white space  
between photos and header

## The Accidents

# Earthquake Led to Loss of Offsite Power

- Seismic events disrupted roads and power lines
- Regional blackout isolated Fukushima station from power grid
- Reactors shut down
- Site operated by onsite diesel generators



Circuit Breaker damaged




Collapsed tower





# Daiichi Site was Inundated by Tsunami



- Site flooding initiated “Station Blackout”
- Unit 1 and Unit 2 lost DC batteries
- Unit 2 maintained uncontrolled “Emergency Core Cooling System”
- Unit 3 retained some DC power and controlled ECCS
- ***All reactors isolated from ultimate heat sink (Ocean)***

Used by permission from TEPCO

# Timeline of Major Fukushima Damage Events

Earthquake at 14:46: Loss of Offsite Power

Tsunami at 15:41: SBO

level loss

Fuel Damage

fresh water

sea water

- Loss of isolation condenser cooling following tsunami and station blackout produced “hands off” damage progression

low pressure emergency injection

Containment vent

▲ H<sub>2</sub> Explosion

RCIC operating

HPCI

Level loss

Unit 3

- Low pressure water injection was well aligned with operator depressurization
- Water injection believed to minimize core damage initially
- Loss of injection later believed to lead to significant core damage

▲ RPV Depressurization

more damage possible ?

Containment vents  
▲ H<sub>2</sub> Explosion

low pressure emergency injection

Fuel damage

RCIC - CST | RCIC from suppression pool

Level loss

Unit 2

- Unit 2 operated RCIC pump well beyond expected duration

▲ RPV Depressurization

low pressure emergency injection  
Possible Fuel damage  
Containment venting unsuccessful  
▲ Noise heard ?

Unit 4 (SFP)

▲ Explosion in Unit 4

Friday 11

Saturday 12

night


Sunday 13

Monday 14  
day

Tuesday 15



Wednesday 16

# Vessel Water Boil-Down in Unit-1




- MELCOR Code predictions
  - Fuel uncovered at 3 hr
  - Core damage and  $H_2$  generation by 4 hr
  - Steam line rupture at 6.5 hr
  - Reactor Vessel dry at 10 hr
  - Reactor Vessel melt-through between 12 and 14 hr

# Predicted Degradation of Reactor Core




- Core damage starts at  $\sim 4$  hours – Control Blade fails first
- Progressive fuel melting after 6 hours
- Core exit gas temperatures very high

# Hydrogen in 1F1




# Hydrogen Accumulation in 1F1



- Between ~12 hours and ~23 hours, steam and hydrogen leaks from drywell head flange and enters RB via shield plug seams
- Hydrogen, CO and steam rises to roof and spreads laterally
- Steam produced in MCCI and from emergency water injection
- Condensation in refueling bay depletes steam in hot layer and enriches hydrogen
- Mixture displaces air from building
- Steam mole fraction exceeds 50% - inert conditions prevent combustion

# Combustible Conditions Follow PCV Venting in 1F1



- At around ~23 hours, steam and hydrogen leakage from PCV greatly reduced
  - Water injection was stopped
  - PCV was depressurized by operator venting action
- Continuing condensation without steam source....
  - Reduces steam molar fraction to below 50% in refueling bay, and
  - Produces partial vacuum that draws in outside air
- Air ingress and steam condensation leads to conditions favoring combustion
- Hydrogen stratification produces flammable or detonable concentrations of  $H_2/O_2$

# Unit 1 Hydrogen Explosion




# Unit 3 Hydrogen Explosion

oztvwatcher




# Hydrogen Explosions



Containment Over-pressurization Led to Release of H<sub>2</sub> into Buildings

# BSAF


**Summary BSAF Phase I report (published by NEA – Feb. 2016)**



**Figure 1: Qualitative description of the plausible status after comparison of the best estimate case analyses; a) Unit 1 RPV failure, b) Unit 2 no RPV failure.**

# BSAF

**Summary BSAF Phase I report (published by NEA – March 2016)**




**Figure 2. Unit 3: Qualitative description of the plausible status after comparison of the best estimate case analyses; a): no RPV failure, b): RPV failure and limited Melt-Concrete Interaction**

# BSAF Phase 2



- Phase 2 focus is on fission product release
  - Airborne release to atmosphere
  - Aqueous release to groundwater
- Time duration is from initiation to 21 days
- Reactor damage
- Core concrete interactions
- Atmospheric transport
- Characterization of depositions in containment, reactor building and water-filled rooms

# Estimated Cs Release from Unit 1





# Extending Calculations – Why 3 Weeks?

- Significant releases well past initial BSAF Phase I simulations
  - Phase I extended to 6 days
- Large predicted Unit 2 releases to the NW after day 9
- Key times when wind blows to NW (vertical redlines on plot)
  - 98 hours (4.1 dy), March 15
  - 215 hours (9 dy), March 20
  - 264 hours (11 dy), March 22
  - 334 hours (13.9 dy), March 24
  - 456 hours (19 dy), March 30



# Aerial Measuring Results Joint US/Japan Survey Data

FUKUSHIMA DAIICHI  
JAPAN



# Phase 2 BSAF

- Work to continue through 2018
- Final report at end of project
- Real world validation of severe accident codes  
MELCOR and MACCS