



Exceptional service in the national interest

Energy Storage Peaker Plant Replacement: Battery/PV Sizing and Control

With Post-Optimization Cost
Benefits Analysis

Amanda West and David Rosewater (mentor)

August 19th 2021

SAND2021-10123 PE

Sandia National Laboratories is a multimission laboratory managed and operated by National Technology and Engineering Solutions of Sandia LLC, a wholly owned subsidiary of Honeywell International Inc. for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA0003525.





Outline

- My Background
- Peaker Plant Overview
- Case Study: PNM Reeves Power Generating Station
- Bilevel Optimization Problem of Sizing and Control
- Incorporation of Monetized Energy Justice Metrics
- Further Considerations
- Conclusion



Amanda West, PhD Student Summer Intern




U.S. AIR FORCE



tommaso79 / iStock / Getty Images



**Georgia
Tech**
**Plasma and
Dielectrics Lab**




**Sandia
National
Laboratories**



Peaker Plant Overview




Peaker Plants: Power production outweigh health impacts?



From: EIA Hourly Electric Grid Monitor

https://www.eia.gov/electricity/gridmonitor/dashboard/electric_overview/balancing_authority/PNM

- Peak Load Support
- Voltage Regulation
- Transmission Congestion Relief
 - 200 MW nameplate capacity
 - 10-15% capacity factor
 - NOx, CO₂, PM_{2.5}, or SO₂ greater than 0.01 tons/year



From: EPA Clean Air Markets Power Plants and Neighboring Communities

<https://www.epa.gov/airmarkets/power-plants-and-neighboring-communities>

- 1,803,116 people within 3-mile radius
 - Preterm and very preterm birth
 - Hospitalization for asthma, acute respiratory infections, chronic obstructive pulmonary disease



Case Study: PNM Reeves Power Plant

Location:	Albuquerque NM
Maximum Power:	146 MW [1]
Age:	61 years [1]
Capacity Factor:	11.5% [2]
Population (3 miles):	63,227 [2]
Expected retirement:	2030 [1]

[1] Phillips et al. "2020 integrated resource plan," Public Service of New Mexico, Tech. Rep., 2020.

[2] Krieger et al. Energy Policy, 2016.

Reeves dispatch data for 2018 and 2019 was collected from public EPA Air Markets Program Data: <https://ampd.epa.gov/ampd/>



From: "PNM Reeves Power Plant 3/25/10" Article posted by n3mra on 01/14/14
<https://menloservice.sandia.gov/><https://westernghosttowns.wordpress.com/2014/01/13/pnm-reeves-power-plant-32510/>



BESS+PV Sizing and BESS Control



Bilevel Optimization Problem of Sizing

Problem Statement: What combination of battery power, battery energy, and PV power capacity will match the peak load support service of a given peaker plant at minimum cost?

Peak Load Support

- Removed periods of continuous power output exceeding 10 hours per day*

Bilevel Optimization Problem

Top level Problem: Optimal Sizing

- Choose BESS+PV size to minimize capital cost

Bottom level problem: Optimal Control

- Dispatch BESS system to match peak load supply service
- Enforce physical constraints of the battery

* The analysis was performed based on duration limits of 4, 6, 8, 10, 12, 14, and 16 hours per day. A 10 hour per day limit was selected to represent peak load service.

Bilevel Optimization Problem: Peak Load Support Sizing and Control

$$\min_{\mathbf{x} \in \mathbb{R}^{3n+4}} C_{\text{BESS}}^{\text{MWh}} E_{\text{BESS}} + C_{\text{BESS}}^{\text{MW}} P_{\text{BESS}} + C_{\text{PV}}^{\text{MW}} P_{\text{PV}}$$

(1a)

Capital Cost

$$\text{s.t. } \mathbf{p}^- + \mathbf{p}^+ + P_{\text{PV}} \mathbf{p}_{\text{PV}} \geq \mathbf{p}_{\text{peak}}$$

(1b)

Peaker Power Matching

$$\mathbf{D}\varsigma = \mathbf{p}^- + \eta \mathbf{p}^+ + p_{\text{sd}}[1]$$

(1c)

Energy Reservoir Model

$$[0] \leq \varsigma \leq E_{\text{BESS}}[1]$$

(1d)

Battery Management
System Limits

$$\mathbf{p}^+ - \mathbf{p}^- \leq P_{\text{BESS}}[1]$$

(1e)

$$\varsigma_{[0]} = \varsigma_{[n]} = E_{\text{BESS}}$$

(1f)

Initial and Final SoE

A 604MWh 125MW Battery and 108 MW of PV can effectively replace the Reeves power plant **peak load support capabilities** at minimum capital cost.



Control Optimization Problem from Unmodified Reeves Dispatch

Problem Statement: How well would the BESS+PV sized for ≤ 10 hour periods perform when trying to match the unmodified Reeves dispatch power?

Optimization Problem

Control

- Dispatch BESS system to match total peaker plant service
- Enforce physical constraints of the battery

Control Optimization Problem from Unmodified Reeves Dispatch

$$\max_{\mathbf{y} \in \mathbb{R}^{3n+1} \times \{0,1\}^n} \sum \mathbf{g}$$

(1a)

Generation Boolean

s.t. $\mathbf{p}^- + \mathbf{p}^+ + P_{\text{PV}} \mathbf{p}_{\text{PV}} \geq \mathbf{p}_{\text{peak}} \mathbf{g}$

(1b)

Peaker Power Matching

$$\mathbf{D}\varsigma = \mathbf{p}^- + \eta \mathbf{p}^+ + p_{\text{sd}}[1]$$

(1c)

Energy Reservoir Model

$$[0] \leq \varsigma \leq E_{\text{BESS}}[1]$$

(1d)

Battery Management
System Limits

$$\mathbf{p}^+ - \mathbf{p}^- \leq P_{\text{BESS}}[1]$$


(1e)

Initial and Final SoE

$$\varsigma_{[0]} = \varsigma_{[n]} = E_{\text{BESS}}$$

(1f)

Sizing Results to Match Reeves Peak Load Support Capability



BESS+PV meets or exceed Reeves total generation 91% of the time (for both 2018 and 2019 data) and, by design, 100% of Reeves total generation of duration <10 hours per day.



Energy Justice Considerations



Monetize Associated Negative Health Affects and Estimate Carbon Price

- EPA CO-Benefits Risk Assessment (COBRA)
 - Monetary value normalized to population of each county within US
 - NOx, PM_{2.5}, or SO₂ considered
- Near-term to net-zero carbon emissions (NT2NZ)
 - \$93/ton CO₂ (2018 USD)

Kaufman et al. *Nature Climate Change* 2020



Emissions 2019

	NOx (tons/yr)	CO ₂ (tons/yr)	SO ₂ (tons/yr)	PM _{2.5} (tons/yr)
Reeves	285.4	142626	0.743	8.73
New CT	22.9	89292	0	0
BESS+PV	0	0	0	0



COBRA
Co-Benefits Risk Assessment
Health Impacts Screening and Mapping Tool

Cost Benefits Analysis





Further Research



More Considerations

- Assess Grid Level Integration
 - Improve Optimization Model
 - Voltage support
 - Transmission constraints/support
 - Include population equity comparison using a modified statistical measurement of inequity
- Cost Benefits Analysis Improvement
 - Consider more health factors of the population within a 3-mile radius



Conclusions

- 1,803,116 people in the US live in 3 mile radius of a peaker plant
 - Exposed to pollutants associated with negative health outcomes
 - Preterm birth, hospitalization due to asthma, acute respiratory infections, chronic obstructive pulmonary disease
- A 604MWh 125W Battery and 108 MW of PV system can meet or exceed the Reeves total power output 91% of the time
- In lieu of a globally recognized social cost of carbon, the NT2NZ price of carbon is used to address PNM's target to net zero carbon emissions by 2040
- BESS+PV is less costly and could provide more revenue than continuing using an old peaker plant or replacing the peaker plant with a new combustion turbine
- Monetized health factors can provide a useful metric for planners to assess renewable energy resource economic viability by reducing customers health costs

**Thank you David
Rosewater, Babu
Chalamala, and Sharon
Ruiz for a wonderful
summer!**