



14th IEA Heat Pump Conference
15-18 May 2023, Chicago, Illinois

A Review of Recent Residential Heat Pump Systems and Applications in Cold Climates

Hanlong Wan^{a,b}, Yunho Hwang^{a*}

^a4164 Glenn Martin Hall Bldg., Center for Environmental Energy Engineering

Department of Mechanical Engineering, University of Maryland, College Park, MD, 20742, United States

^bOak Ridge National Laboratory, Oak Ridge, TN, USA

Abstract

The heat pump (HP) system is one of the environmentally friendly solutions to reduce the carbon footprint of buildings due to its high efficiency and low added initial cost from the cooling only systems. This paper presents a literature review of the recent advances in HP systems applied in cold climate regions categorizing the systems into two major types depending on energy source types. First type is the systems with air source without additional energy sources, i.e., Air Source HP (ASHP) systems, which use various working fluids and configurations. However, several issues impede their widespread applications. When the systems work for space or water heating in cold climates, ASHP systems suffer a high discharge temperature and pressure ratio at low ambient temperature, which leads to low efficiency and heating capacity. Furthermore, some researchers reported that the defrost penalty reduced the energy efficiency by up to 40%, leading to a degradation of heating capacity by 43%. Second type is the systems with supererogatory energy sources, like solar-assisted HP systems, which can partly improve energy performance but have difficulties in coupling different sub-systems to achieve increased operational time and are limited to locations with enough solar radiation. This study identifies the future research directions as (1) developing multi-source heat pumps with efficient control; (2) utilizing waste heat for defrosting; and (3) optimizing HP configurations and minimizing refrigerant charge while achieving higher efficiency.

© HPC2023.

Selection and/or peer-review under the responsibility of the organizers of the 14th IEA Heat Pump Conference 2023.

Keywords: heat pump; cold climate; air source; multi-source; defrost;

1. Introduction

A number of researchers have reported that the high energy consumption of the building sector is among the significant global challenges for sustainable human development [1]. Space and water heating take up more than half of residential energy consumption [2]. This ratio increases significantly in cold climate regions [3]. Over the last two decades, residential buildings have widely adopted Heat Pump (HP) systems due to their simple structure and low added initial cost [2]. Several different HP technologies exist. Air Source Heat Pump (ASHP) systems take low-grade heat from the air and produce high-temperature heat for domestic heating or other purposes [4]. Solar Assisted Heat Pump (SAHP) systems, which combine thermal panels with heat pumps, have been widely used to provide residential hot water owing to their simple structure, low cost, stable operation, and effective solar energy collection [5]. Ground Source Heat Pump (GSHP) and Water Source Heat

* Corresponding author. Tel.: +1-301-405-5247

E-mail address: yhwang@umd.edu.

Notice: This manuscript has been authored by UT-Battelle, LLC under Contract No. DE-AC05-00OR22725 with the U.S. Department of Energy. The United States Government retains and the publisher, by accepting the article for publication, acknowledges that the United States Government retains a non-exclusive, paid-up, irrevocable, world-wide license to publish or reproduce the published form of this manuscript, or allow others to do so, for United States Government purposes. The Department of Energy will provide public access to these results of federally sponsored research in accordance with the DOE Public Access Plan (<http://energy.gov/downloads/doe-public-access-plan>).

Pump (WSHP) systems use heat energy naturally stored in either the ground or water, taking advantage of the relative constancy of temperatures of the earth or waterbody through the seasons [6].

However, there are many challenges when people are using HP systems in cold climate regions. This paper groups the so-called cold climate heat pump (CCHP) systems into two major types depending on energy sources for clear discussion. The first type is the systems with air source only without additional energy sources, i.e., ASHP systems. The second type is the systems coupled with supererogatory energy sources, like GSHP or SAHP systems.

2. Challenges of Heat Pump Application in Cold Climates

Challenges exist for almost all current CCHP systems. First, typical ASHP systems work under a high discharge temperature and pressure ratio at low ambient temperature, which leads to low efficiency and heating capacity [7]. For instance, with a decline in ambient temperature, a decreased heating capacity of the ASHP system may be insufficient to the consumer's requirement, and the high compression ratio may lead to an extremely high discharge temperature and system shut down. Furthermore, frost on the outdoor heat exchanger coil surface degrades the thermal performance by reducing airflow area due to the blockage caused by the layer of frost [8]. Also, an insulating area is built up over the evaporator coils, thereby reducing their ability to absorb heat from the outdoor environment [8]. Some researchers reported that the defrost penalty reduced energy efficiency by up to 40%, leading to further degradation of heating capacity by 43% [9].

In addition, SAHP systems face challenges as well. The constant operation of the heat pump in the systems usually leads to a large carbon footprint, significant electrical energy use, and an energy inefficient operation [10]. However, owing to the fluctuation of solar radiation throughout the day and radiation unavailability during the evening and night, the SAHP system may have a low efficiency without a proper control strategy [10]. As for the GSHP and WSHP systems, the installation region has restrictions and thus, cannot be applied everywhere.

3. Air Source Heat Pump

Zhang et al. (2018) [2] reviewed the literature about vapor compression ASHP systems from 2005 to 2017 and classified the systems into single-stage, dual-stage, and multi-stage compression systems. They concluded that the quasi-two-stage compression system showed enormous potential for heating performances and initial cost. No similar study exists after Zhang's work summarizing new CCHP techniques based on the authors' knowledge. This section mainly focuses on the experimental studies conducted in the recent five years, comparing the new works with three old studies [11–13].

Table 1 summarizes the authors and some features of the target studies. In the “cycle type” column, “cascade” refers to two-stage systems using two separate compressors [14,15], while “VI” refers to the systems using the Vapor Injection (VI) technique. “-” in this column refers to single-stage systems. In the “discharge temperature” column, “-” means the information is not given in the related studies. Among the studies, Zhang et al. (2017) and Fan et al. (2022) [16,17] highlighted the need to reduce defrosting process power consumption in cold climates. Zhang et al. (2019) developed and investigated a novel thermal storage refrigerant-heated radiator coupled with an ASHP heating system. Zhang et al. (2017), Wei et al. (2020), and Wu et al. (2022) [16,19,20] examined the long-term performance of the ASHP system in the field test.

Fig. 1 plots these studies using the ambient temperature as the x-axis and COP as the y-axis. The linear regression line of the data points shows that most of the ASHP systems can reach 1.5 COP under extreme conditions. One outstanding piece of research was carried out by Bertsch and Groll (2008) [11,12]. They applied a special low-pressure stage compressor with an oil tap in the VI system and mentioned that this compressor with a suction volume of approximately 90 cm³/rev was not commercially available, which might explain the impressive performance.

Overall, the data suggest that VI using R410A is the primary trend technique applied for cold climate ASHP system, firstly. However, the discharge temperature of the upper stage cycle typically exceeds 90 °C. Except for limit studies, the COP limitation exists under the extreme ambient conditions of -20 °C to -30 °C. Second, the defrost power consumption is non-negligible and can reduce energy efficiency by up to 40%, leading to further degradation of heating capacity by 43% [9]. Supply heat source, e.g., electric heater, seems necessary for cold climate ASHP systems.

In summary, from the existing studies, the maximum COP of the advanced system under low ambient temperature conditions based on the published literature is still a bit small from the viewpoint of the primary energy ratio. Secondly, its heating capacity deserves to be further enhanced to satisfy the consumers, especially

under extreme conditions. Finally, more research on low-temperature start-up technology and year-round control strategy is required to ensure the reliability of the advanced system.




Fig. 1. Comparison of existing studies under extremely cold conditions

Table 1. Existing ASHP performance under extreme conditions

Authors, year	COP	Ambient Temp. [°C]	Cycle Type	Refrigerant	Discharge Temp. [°C]
Bertsch and Groll, 2008 [11]	2.1	-30.0	VI	R410A	93.0~102.0
Xu et al., 2011 [12]	2.5	-17.8	VI	R410A	-
Kim and Kim, 2014 [13]	1.3	-15.0	cascade	R410A/R134a	80.0~90.0
Zhang et al., 2017 [16]	1.1	-20.9	-	R22	-
Kang et al., 2018 [21]	1.6	-20.0	VI	R410A	97.3~101.2
Xu et al., 2019 [22]	1.7	-21.0	cascade	R404A/R134a	93.9~91.4
Zhang et al., 2019 [18]	1.8	-18.4	-	R410A	-
Wei et al., 2020 [19]	1.4	-26.5	VI	R410A	90.6
Wu et al., 2022 [20]	1.6	-24.7	VI	R410A	-
Fan et al., 2022 [17]	3.0	-5.0	VI	R410A	-

4. Systems with supererogatory energy sources

4.1. Solar Assisted Heat Pump

Some researchers identified the merits of SAHP systems as flexibility, efficiency, and stability in cold regions [23]. Others argued that cold regions in winter usually lack solar energy [7]. Many studies exist to improve Thermal-SAHP systems performance: Ji et al. (2008) and Fu et al. (2012) [24,25] optimized the structure of the solar thermal panels and evaporator; Zhang et al. (2014) [26] studied the optimal geometrical sizes and capacity; Gorozabel Chata et al. (2005) and Kong et al. (2017) [27,28] concentrated on the refrigerant type; Chaturvedi et al. (1998) and Kong et al. (2018) [29,30] focused on the control strategy for compressor and electronic expansion valve; and, Chaturvedi et al. (2009) [31] combined the cascade structure with

Thermal-SAHP water heater to reach higher supply temperature. Nevertheless, none of the research mentioned how their proposed system could match the requirements under low ambient temperature or radiation conditions. Qiu et al. (2018) [32] investigated a low-temperature heat-collecting system and got a simulation COP result of only 1.6 with -25 °C ambient temperature and 200 W/m² solar radiation intensity. Only limited scholars studied Photovoltaic-thermal-SAHP (PV/T-SAHP). Li et al. (2015) [33] developed a mathematical model of a PV/T-SAHP system and optimized the flow distribution and velocity to reach the COP as high as 4.6 at 10 °C ambient conditions. However, this result was given with 400 W/m² radiation, and the author also mentioned that the performance could reduce to 21% when the outdoor air temperature was -5 °C. Cao et al. (2016) [34] simulated a PV/T-SAHP performance using Computational Fluid Dynamics (CFD). The COP could reach 3.5 when the ambient temperature was around 0 °C. However, they did not study the performance under further lower temperature conditions.

A comparative study of different seasonal Thermal Energy Storage (TES) systems using HPs with solar collectors identifies the heat pump's COP and the solar fraction as the main factors that influence the efficiency of the system, with both factors being a function of the collector area and storage volume [35]. Pensini et al. (2014) [36] undertake an economic analysis of using excess renewable energy for heating purposes, finding that HPs with centralized thermal storage meet heat demand at lower costs than conventional systems even if there is a charge for producing excess renewable energy. Kapsalis and Karamanis (2016) [37] consider solar thermal energy storage and heat pumps with Phase Change Materials (PCMs) and conclude that further investigation and experimental work are necessary to determine the combined effect PCMs in building components and HP operation within different climates.

In summary, SAHP could improve the COP sharply in cold regions with high solar radiation, but the benefit is limited in low solar radiation regions.

4.2. Ground Source Heat Pump

It was reported that Ground Source Heat Pump (GSHP) systems have relatively stable performance throughout a year but are location specific and thus own a potential to be applied in cold regions [38]. One study shows that such systems are 40% more energy efficient than ASHPs [39]. Huang et al. (2019) [40] reported that the GSHP system had marginally higher installation costs but higher energy efficiency and 10% lower costs across 10 years. Direct expansion GSHPs, a variant of the common GSHP that uses a buried copper piping network through which refrigerant is circulated, can deliver superior performance relative to GSHPs and ASHPs in Canadian and Canadian Chinese locations [41,42]. Mattinen et al. (2015) [43] compare carbon emissions across direct electric heating, ASHP, and GSHP systems and find that GSHPs perform better in colder climates due to higher COP at lower outdoor temperatures. Carbon emissions in ASHP systems are 40% lower than direct electric heating and 70% lower in the GSHP system. From an emissions perspective, this makes GSHP systems the best option; however, reducing emissions is only possible if the heat pumps are integrated with low-carbon power systems. Otherwise, deploying large quantities of heat pumps in a power system (or country) where there is a low level of decarbonization of electricity generation merely results in shifting emissions from one sector to another.

4.3. Water Source Heat pump

Water source heat pumps (WSHPs) use lakes, ponds, rivers, groundwater, and other water sources, as a source of heat. They convert low-grade heat from the water source to a higher grade. The temperature of the waterbody fluctuates less than that of air; thus, the performance of WSHP is relatively stable. Bach et al. (2016) [44] from Denmark found the seasonal variation of COP had little or no impact on the transmission and distribution networks of the district heating system, as COPs of water source heat pumps did not vary much throughout the year. Thus, such systems can work well in cold winter. However, WSHP applications are limited due to the requirement of large water bodies or storage tanks near dwellings. Moreover, the need to adhere to specific environmental regulations may further result in a low uptake rate of WSHPs.

5. Discussion

5.1. Existing studies

First, based on existing literature for ASHP systems, the two-stage compression system shows tremendous potential for performance and cost [2]. Furthermore, Table 1 suggests that VI systems using R410A are the

main trend technique. However, the discharge temperature of the upper stage cycle was usually high. Plus, the COP of all the systems is still a bit small from the viewpoint of the primary energy ratio. The defrost power consumption, low-temperature start-up technology, and year-round control strategy are significant but are seldom mentioned in current published literature.

Some studies conclude that SAHP and GSHP systems are better options than ASHP systems in colder regions [4]. However, the type of heat pump to be installed is location and application specific. This is due to the concern that ASHPs may not be able to meet the thermal comfort and energy efficiency requirements when ambient temperatures are immensely low. The requirement of solar radiation, ground thermal sources, and other environmental concerns limit SAHP, WSHP, and GSHP systems' overall uptake rate.

5.2. Current Barriers

Several issues that impede the widespread of above applications still exist: 1) the lack of clear decarbonization pathways, technology uptake, and funding are the primary sources of barriers to cold climate heat pump uptake [45]; 2) public acceptance and awareness issues, i.e., emanate from unwarranted fear, misperception, misinformation, and previous experiences on the reliability, also pose significant challenges in adopting the new technology [46]; 3) existing market structures combined with public perception can also hinder the penetration of cold climate heat pumps [47]; 4) barriers related to lack of standards and mandatory policies can also considerably constrain some special HP systems deployments, like GSHP and WSHP [48]; and 5) an essential barrier to widespread adoption of heat pumps in cold climate is the limitation of the electrical network, which may be further increased at peak periods and in turn may require additional electricity grid infrastructure investment to satisfy the demand [49].

5.3. Future work

The future research directions were identified: (1) multi-source heat pumps, for example, the systems using both solar energy and ground source energy, could be proposed; for these systems, an efficient control to coordinate each part is necessary; (2) waste heat or low-grade heat shall be used for heat pump defrosting in cold climate regions; digging more heat source other than the ground source or water source could be investigated; (3) people may also study advanced Heat Storage, and Exchange Unit technology; and (4) researcher may continue to optimize the configuration and refrigerant usage to achieve low discharge temperature in cold climate heat pumps.

6. Conclusion

Due to the great efficiency and minimal added initial cost compared to cooling-only systems, HP systems are one of the ecologically sustainable ways to lower the carbon footprint of buildings. The systems are divided into two main categories depending on supplementary energy sources in this research, which thoroughly assesses current developments in HP systems used in cold climate regions. Following is a list of the conclusions:

The two-stage compression system shows tremendous potential for performance and cost, and VI systems using R410A are the primary trend technique for ASHP systems. However, the discharge temperature of the upper stage cycle was usually high. In addition, the COPs of all the systems are still a bit low from the primary energy ratio viewpoint.

Some researchers reported that the defrost penalty reduced energy efficiency by up to 40%, leading to further degradation of heating capacity by 43%. Thus, defrost is a non-negligible factor for CCHP application.

Low-temperature start-up technology and year-round control strategy are significant but are seldom mentioned in published literature.

Some studies conclude that SAHP and GSHP systems are better options than ASHP systems in colder regions. However, the type of heat pump installed is location and application specific. This is due to the concern that ASHPs may not be able to meet the thermal comfort and energy efficiency requirements when the ambient temperature is immensely low. The requirement of solar radiation, ground thermal sources, and other environmental concerns limit SAHP, WSHP, and GSHP systems' overall uptake rate.

Current barriers to CCHP systems include policy limitation, public acceptance, economic reasons, a lack of standards and funding, and insufficient studies on an electronic network.

Future research should focus on the following topics: (1) multi-source heat pump with effective control; (2) heat pump defrosting capability utilizing waste heat; (3) advanced Heat Storage and Exchange Unit technology; and (4) optimized structure and refrigerant usage to obtain low discharge temperature.

Acknowledgements

We gratefully acknowledge the support of the Center for Environmental Energy Engineering (CEEE) at the University of Maryland.

References

- [1] D. Ürge-Vorsatz, L.F. Cabeza, S. Serrano, C. Barreneche, K. Petrichenko, Heating and cooling energy trends and drivers in buildings, *Renewable and Sustainable Energy Reviews*. 41 (2015) 85–98. <https://doi.org/10.1016/j.rser.2014.08.039>.
- [2] L. Zhang, Y. Jiang, J. Dong, Y. Yao, Advances in vapor compression air source heat pump system in cold regions: A review, *Renewable and Sustainable Energy Reviews*. 81 (2018) 353–365. <https://doi.org/10.1016/j.rser.2017.08.009>.
- [3] A. Hakkaki-Fard, Z. Aidoun, M. Ouzzane, Improving cold climate air-source heat pump performance with refrigerant mixtures, *Applied Thermal Engineering*. 78 (2015) 695–703. <https://doi.org/10.1016/j.aplthermaleng.2014.11.036>.
- [4] A.S. Gaur, D.Z. Fitwi, J. Curtis, Heat pumps and our low-carbon future: A comprehensive review, *Energy Research & Social Science*. 71 (2021) 101764. <https://doi.org/10.1016/j.erss.2020.101764>.
- [5] Y. Fan, X. Zhao, Z. Han, J. Li, A. Badiei, Y.G. Akhlaghi, Z. Liu, Scientific and technological progress and future perspectives of the solar assisted heat pump (SAHP) system, *Energy*. 229 (2021) 120719. <https://doi.org/10.1016/j.energy.2021.120719>.
- [6] I. Sarbu, C. Sebarchievici, General review of ground-source heat pump systems for heating and cooling of buildings, *Energy and Buildings*. 70 (2014) 441–454. <https://doi.org/10.1016/j.enbuild.2013.11.068>.
- [7] B. Shen, M.R. Ally, Energy and Exergy Analysis of Low-Global Warming Potential Refrigerants as Replacement for R410A in Two-Speed Heat Pumps for Cold Climates, *Energies*. 13 (2020) 5666. <https://doi.org/10.3390/en13215666>.
- [8] H.-J. Choi, B.-S. Kim, D. Kang, K.C. Kim, Defrosting method adopting dual hot gas bypass for an air-to-air heat pump, *Applied Energy*. 88 (2011) 4544–4555. <https://doi.org/10.1016/j.apenergy.2011.05.039>.
- [9] W. Wang, J. Xiao, Y. Feng, Q. Guo, L. Wang, Characteristics of an air source heat pump with novel photoelectric sensors during periodic frost–defrost cycles, *Applied Thermal Engineering*. 50 (2013) 177–186. <https://doi.org/10.1016/j.aplthermaleng.2012.06.019>.
- [10] A. Moreno-Rodríguez, N. García-Hernando, A. González-Gil, M. Izquierdo, Experimental validation of a theoretical model for a direct-expansion solar-assisted heat pump applied to heating, *Energy*. 60 (2013) 242–253. <https://doi.org/10.1016/j.energy.2013.08.021>.
- [11] S.S. Bertsch, E.A. Groll, Two-stage air-source heat pump for residential heating and cooling applications in northern U.S. climates, *International Journal of Refrigeration*. 31 (2008) 1282–1292. <https://doi.org/10.1016/j.ijrefrig.2008.01.006>.
- [12] X. Xu, Y. Hwang, R. Radermacher, Transient and steady-state experimental investigation of flash tank vapor injection heat pump cycle control strategy, *International Journal of Refrigeration*. 34 (2011) 1922–1933. <https://doi.org/10.1016/j.ijrefrig.2011.08.003>.
- [13] D.H. Kim, M.S. Kim, The effect of water temperature lift on the performance of cascade heat pump system, *Applied Thermal Engineering*. 67 (2014) 273–282. <https://doi.org/10.1016/j.aplthermaleng.2014.03.036>.
- [14] H. Lee, Y. Hwang, R. Radermacher, H.-H. Chun, Performance investigation of multi-stage saturation cycle with natural working fluids and low GWP working fluids, *International Journal of Refrigeration*. 51 (2015) 103–111.
- [15] H. Lee, Y. Hwang, R. Radermacher, H.-H. Chun, Potential benefits of saturation cycle with two-phase refrigerant injection, *Applied Thermal Engineering*. 56 (2013) 27–37.
- [16] Y. Zhang, Q. Ma, B. Li, X. Fan, Z. Fu, Application of an air source heat pump (ASHP) for heating in Harbin, the coldest provincial capital of China, *Energy and Buildings*. 138 (2017) 96–103. <https://doi.org/10.1016/j.enbuild.2016.12.044>.

- [17] Y. Fan, J. Li, X. Zhao, S. Myers, Y. Cheng, M. Yu, Y. Golizadeh Akhlaghi, X. Ma, S. Yu, A proof-of-concept study of a novel ventilation heat recovery vapour injection air source heat pump, *Energy Conversion and Management*. 256 (2022) 115404. <https://doi.org/10.1016/j.enconman.2022.115404>.
- [18] H. Zhang, L. Jiang, W. Zheng, S. You, T. Jiang, S. Shao, X. Zhu, Experimental study on a novel thermal storage refrigerant-heated radiator coupled with air source heat pump heating system, *Building and Environment*. 164 (2019) 106341. <https://doi.org/10.1016/j.buildenv.2019.106341>.
- [19] W. Wei, L. Ni, L. Xu, Y. Yang, Y. Yao, Application characteristics of variable refrigerant flow heat pump system with vapor injection in severe cold region, *Energy and Buildings*. 211 (2020) 109798. <https://doi.org/10.1016/j.enbuild.2020.109798>.
- [20] C. Wu, F. Liu, X. Li, Z. Wang, Z. Xu, W. Zhao, Y. Yang, P. Wu, C. Xu, Y. Wang, Low-temperature air source heat pump system for heating in severely cold area: Long-term applicability evaluation, *Building and Environment*. 208 (2022) 108594. <https://doi.org/10.1016/j.buildenv.2021.108594>.
- [21] D. Kang, J.H. Jeong, B. Ryu, Heating performance of a VRF heat pump system incorporating double vapor injection in scroll compressor, *International Journal of Refrigeration*. 96 (2018) 50–62. <https://doi.org/10.1016/j.ijrefrig.2018.09.027>.
- [22] Y. Xu, Y. Huang, N. Jiang, M. Song, X. Xie, X. Xu, Experimental and theoretical study on an air-source heat pump water heater for northern China in cold winter: Effects of environment temperature and switch of operating modes, *Energy and Buildings*. 191 (2019) 164–173. <https://doi.org/10.1016/j.enbuild.2019.03.028>.
- [23] X. Wang, L. Xia, C. Bales, X. Zhang, B. Copertaro, S. Pan, J. Wu, A systematic review of recent air source heat pump (ASHP) systems assisted by solar thermal, photovoltaic and photovoltaic/thermal sources, *Renewable Energy*. 146 (2020) 2472–2487. <https://doi.org/10.1016/j.renene.2019.08.096>.
- [24] J. Ji, G. Pei, T. Chow, K. Liu, H. He, J. Lu, C. Han, Experimental study of photovoltaic solar assisted heat pump system, *Solar Energy*. 82 (2008) 43–52. <https://doi.org/10.1016/j.solener.2007.04.006>.
- [25] H.D. Fu, G. Pei, J. Ji, H. Long, T. Zhang, T.T. Chow, Experimental study of a photovoltaic solar-assisted heat-pump/heat-pipe system, *Applied Thermal Engineering*. 40 (2012) 343–350. <https://doi.org/10.1016/j.aplthermaleng.2012.02.036>.
- [26] D. Zhang, Q.B. Wu, J.P. Li, X.Q. Kong, Effects of refrigerant charge and structural parameters on the performance of a direct-expansion solar-assisted heat pump system, *Applied Thermal Engineering*. 73 (2014) 522–528. <https://doi.org/10.1016/j.aplthermaleng.2014.07.077>.
- [27] F.B. Gorozabel Chata, S.K. Chaturvedi, A. Almogbel, Analysis of a direct expansion solar assisted heat pump using different refrigerants, *Energy Conversion and Management*. 46 (2005) 2614–2624. <https://doi.org/10.1016/j.enconman.2004.12.001>.
- [28] X.Q. Kong, Y. Li, L. Lin, Y.G. Yang, Modeling evaluation of a direct-expansion solar-assisted heat pump water heater using R410A, *International Journal of Refrigeration*. 76 (2017) 136–146. <https://doi.org/10.1016/j.ijrefrig.2017.01.020>.
- [29] S.K. Chaturvedi, D.T. Chen, A. Kheireddine, Thermal performance of a variable capacity direct expansion solar-assisted heat pump, *Energy Conversion and Management*. 39 (1998) 181–191. [https://doi.org/10.1016/S0196-8904\(96\)00228-2](https://doi.org/10.1016/S0196-8904(96)00228-2).
- [30] X. Kong, K. Jiang, S. Dong, Y. Li, J. Li, Control strategy and experimental analysis of a direct-expansion solar-assisted heat pump water heater with R134a, *Energy*. 145 (2018) 17–24. <https://doi.org/10.1016/j.energy.2017.12.114>.
- [31] S.K. Chaturvedi, T.M. Abdel-Salam, S.S. Sreedharan, F.B. Gorozabel, Two-stage direct expansion solar-assisted heat pump for high temperature applications, *Applied Thermal Engineering*. 29 (2009) 2093–2099. <https://doi.org/10.1016/j.aplthermaleng.2008.10.010>.
- [32] G. Qiu, X. Wei, Z. Xu, W. Cai, A novel integrated heating system of solar energy and air source heat pumps and its optimal working condition range in cold regions, *Energy Conversion and Management*. 174 (2018) 922–931. <https://doi.org/10.1016/j.enconman.2018.08.072>.
- [33] H. Li, C. Cao, G. Feng, R. Zhang, K. Huang, A BIPV/T System Design Based on Simulation and its Application in Integrated Heating System, *Procedia Engineering*. 121 (2015) 1590–1596. <https://doi.org/10.1016/j.proeng.2015.09.184>.
- [34] C. Cao, H. Li, G. Feng, R. Zhang, K. Huang, Research on PV/T – Air Source Heat Pump Integrated Heating System in Severe Cold Region, *Procedia Engineering*. 146 (2016) 410–414. <https://doi.org/10.1016/j.proeng.2016.06.422>.
- [35] A.G. Devecioğlu, Seasonal performance assessment of refrigerants with low GWP as substitutes for R410A in heat pump air conditioning devices, *Applied Thermal Engineering*. 125 (2017) 401–411. <https://doi.org/10.1016/j.aplthermaleng.2017.07.034>.
- [36] A. Pensini, C.N. Rasmussen, W. Kempton, Economic analysis of using excess renewable electricity to displace heating fuels, *Applied Energy*. 131 (2014) 530–543. <https://doi.org/10.1016/j.apenergy.2014.04.111>.

- [37] V. Kapsalis, D. Karamanis, Solar thermal energy storage and heat pumps with phase change materials, *Applied Thermal Engineering*. 99 (2016) 1212–1224. <https://doi.org/10.1016/j.applthermaleng.2016.01.071>.
- [38] A.A. Safa, A.S. Fung, R. Kumar, Comparative thermal performances of a ground source heat pump and a variable capacity air source heat pump systems for sustainable houses, *Applied Thermal Engineering*. 81 (2015) 279–287. <https://doi.org/10.1016/j.applthermaleng.2015.02.039>.
- [39] B. Huang, V. Mauerhofer, Life cycle sustainability assessment of ground source heat pump in Shanghai, China, *Journal of Cleaner Production*. 119 (2016) 207–214. <https://doi.org/10.1016/j.jclepro.2015.08.048>.
- [40] S. Huang, W. Zuo, H. Lu, C. Liang, X. Zhang, Performance comparison of a heating tower heat pump and an air-source heat pump: A comprehensive modeling and simulation study, *Energy Conversion and Management*. 180 (2019) 1039–1054. <https://doi.org/10.1016/j.enconman.2018.11.050>.
- [41] A. Hakkaki-Fard, P. Eslami-Nejad, Z. Aidoun, M. Ouzzane, A techno-economic comparison of a direct expansion ground-source and an air-source heat pump system in Canadian cold climates, *Energy*. 87 (2015) 49–59. <https://doi.org/10.1016/j.energy.2015.04.093>.
- [42] W. Yang, Experimental performance analysis of a direct-expansion ground source heat pump in Xiangtan, China, *Energy*. 59 (2013) 334–339. <https://doi.org/10.1016/j.energy.2013.07.036>.
- [43] M.K. Mattinen, A. Nissinen, S. Hyysalo, J.K. Juntunen, Energy Use and Greenhouse Gas Emissions of Air-Source Heat Pump and Innovative Ground-Source Air Heat Pump in a Cold Climate, *Journal of Industrial Ecology*. 19 (2015) 61–70. <https://doi.org/10.1111/jiec.12166>.
- [44] B. Bach, J. Werling, T. Ommen, M. Münster, J.M. Morales, B. Elmegaard, Integration of large-scale heat pumps in the district heating systems of Greater Copenhagen, *Energy*. 107 (2016) 321–334. <https://doi.org/10.1016/j.energy.2016.04.029>.
- [45] S. Nyborg, I. Røpke, Heat pumps in Denmark—From ugly duckling to white swan, *Energy Research & Social Science*. 9 (2015) 166–177. <https://doi.org/10.1016/j.erss.2015.08.021>.
- [46] S. Karytsas, I. Kostakis, Barriers and diffusion actions of residential ground source heat pump systems in Greece: An ordered regression model analysis, 2014.
- [47] Z. Wang, Heat pumps with district heating for the UK's domestic heating: individual versus district level, *Energy Procedia*. 149 (2018) 354–362. <https://doi.org/10.1016/j.egypro.2018.08.199>.
- [48] J. Globisch, M. Kühnbach, E. Dütschke, A. Bekk, The stranger in the German energy system? How energy system requirements misalign with household preferences for flexible heat pumps, *Energy Research & Social Science*. 67 (2020) 101604. <https://doi.org/10.1016/j.erss.2020.101604>.
- [49] T. Fawcett, N. Eyre, R. Layberry, Heat pumps and global residential heating, 2015.