

DOE/PC/94154--T1

DEVELOPMENT, TESTING, AND DEMONSTRATION OF AN  
OPTIMAL FINE COAL CLEANING CIRCUIT

DOE Project No. DE-AC22-94PC94154

RECEIVED  
JUN 19 1996  
OSTI

**Task 5**

**Evaluation of Bench-Scale Test Results and  
Equipment Selection for In-Plant Pilot Tests**

**Topical Report**

**14 December 1995**

**Prepared by**

**Cyprus Emerald Resources Corporation  
145 Elm Drive  
Waynesburg, PA 15370**

**Praxis Engineers, Inc.  
852 North Hillview Drive  
Milpitas, CA 95035**

**Prepared for**

**U.S. Department of Energy  
Pittsburgh Energy Technology Center  
Pittsburgh, PA 15236**

RECEIVED  
JUN 19 1996  
U.S. DEPARTMENT OF ENERGY  
DOE/PC/94154  
96 FEB - 8 AM 11:07  
DISTRIBUTION & ASSISTANCE UNIT

**MASTER**

**CLEARED BY  
PATENT COUNSEL**

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

OK

## **DISCLAIMER**

**Portions of this document may be illegible  
in electronic image products. Images are  
produced from the best available original  
document.**

## TABLE OF CONTENTS

<b>EXECUTIVE SUMMARY .....</b>	<b>1</b>
<b>1.0 INTRODUCTION .....</b>	<b>7</b>
<b>2.0 PROJECT OBJECTIVES .....</b>	<b>8</b>
<b>3.0 SAMPLE COLLECTION AND ANALYSIS .....</b>	<b>9</b>
<b>3.1 Sample Collection.....</b>	<b>9</b>
<b>3.2 Sample Analysis .....</b>	<b>10</b>
<b>3.3 Batch Flotation Tests .....</b>	<b>13</b>
<b>3.4 QA/QC Analysis .....</b>	<b>15</b>
<b>4.0 PLANT DATA AND FLOTATION CIRCUIT MATERIAL BALANCE ESTIMATES .....</b>	<b>18</b>
<b>4.1 Conventional Flotation.....</b>	<b>18</b>
<b>4.2 Advanced Flotation Circuit Material Balances.....</b>	<b>19</b>
<b>5.0 BENCH-SCALE TESTS .....</b>	<b>22</b>
<b>5.1 Introduction.....</b>	<b>22</b>
<b>5.2 Jameson Cell.....</b>	<b>22</b>
5.2.1 Parametric Studies: Discussion of Results.....	26
5.2.2 High-Capacity Tests .....	30
5.2.3 Recommended Operating Conditions .....	30
<b>5.3 Outokumpu Cell .....</b>	<b>31</b>
5.3.1 Recommended Operating Conditions .....	37
<b>5.4 Packed Column .....</b>	<b>37</b>
5.4.1 Raw Coal Parametric Tests.....	37
5.4.2 Second-Stage Test Work .....	44
5.4.3 Recommended Operating Conditions .....	46
<b>5.5 Open Column .....</b>	<b>46</b>
5.5.1 Reagent Dosage Tests.....	49
5.5.2 Factorial Tests.....	49
5.5.3 Residence Time Tests.....	50
5.5.4 High Volumetric Flow Rate Tests.....	51
5.5.5 Summary of Raw Coal Tests.....	51
5.5.6 Second-Stage Tests.....	54
5.5.7 Recommended Operating Conditions .....	57

<b>6.0 CONCEPTUAL DESIGN .....</b>	<b>57</b>
6.1 Design Procedures .....	57
6.2 Scale-Up to Commercial Scale .....	58
6.3 Material Balances.....	60
6.4 Preparation Plant Effects .....	67
6.5 Process Instrumentation and Control .....	67
6.7 Ancillary Requirements.....	68
6.7.1 Utilities.....	68
6.7.2 Site .....	69
<b>7.0 ECONOMICS .....</b>	<b>69</b>
7.1 Assumptions .....	70
7.2 Purchased Equipment.....	70
7.2.1 Jameson Cell.....	70
7.2.2 Outokumpu Cell.....	71
7.2.3 Open Column .....	71
7.2.4 Packed Column .....	71
7.2.5 Cost Scaling .....	72
7.3 Capital Costs .....	72
7.4 Operating Costs.....	72
7.4.1 Utilities.....	72
7.4.2 Consumables .....	73
7.4.3 Personnel .....	73
7.4.4 Maintenance .....	73
7.5 Circuit-Optimized Economics.....	73
7.6 Plant-Optimized Economics .....	76
7.7 Sensitivity Analysis .....	80
<b>8.0 TWO-STAGE OPERATION.....</b>	<b>86</b>
<b>9.0 EQUIPMENT SELECTION .....</b>	<b>88</b>

## LIST OF TABLES

Table 1. Summary of Bench-Scale Test Equipment.....	2
Table 2. Highlights of Bench-Scale Test Results (Raw Coal Sample).....	3
Table 3. Highlights of Bench-Scale Test Results (Tailings Sample) .....	4
Table 4. Economic Comparison of Flotation Circuits.....	5
Table 5. Plant Flotation Feed Coal Analysis .....	10
Table 6 . Plant Flotation Tailings Analysis.....	11
Table 7. Plant Flotation Feed Coal Washability Analysis (100M x0) .....	11
Table 8. Batch Flotation Tests on Plant Flotation Feed.....	14
Table 9. Batch Flotation Tests on Plant Flotation Tailings.....	15
Table 10. Analysis of Plant Flotation Feed and Tailings Samples .....	16
Table 11. Vendor Analysis of Feed Coal (Flotation Feed) to Test Cells .....	16
Table 12. Vendor Analysis of Feed Coal (Tailings) to Test Cells.....	17
Table 13. Comparison of Vendor and Independent Laboratory Analyses .....	17
Table 14. Historical Plant Flotation Performance .....	18
Table 15. Estimated Single-Stage Flotation Performance.....	20
Table 16. Estimated First-Stage Flotation Performance.....	20
Table 17. Plant Flotation Circuit Assumptions.....	20
Table 18. Estimated Single-Stage Material Balance .....	21
Table 19. Estimated Two-Stage Flotation Material Balance .....	21
Table 20. Bench-Scale Test Conditions for Jameson Cell .....	24
Table 21. Bench-Scale Test Results for Jameson Cell .....	25
Table 22. Jameson Cell: Superficial Velocities and Mass Loadings.....	26
Table 23. Jameson Cell: Recommended Operating Conditions, Single-Stage Operation .....	30
Table 24. Jameson Cell: Recommended Operating Conditions, First-Stage Operation .....	30
Table 25. Bench-Scale Test Conditions for Outokumpu HG Tank Cell .....	32
Table 26. Bench-Scale Test Results for Outokumpu HG Tank Cell .....	33
Table 27. Outokumpu HG Tank Cell: Superficial Velocities and Mass Loadings.....	33
Table 28. Outokumpu Cell: Recommended First-Stage Operating Conditions.....	37
Table 29. Bench-Scale Test Conditions for Packed Column.....	39
Table 30. Bench-Scale Test Results for Packed Column.....	40
Table 31. Packed Column: Superficial Velocities and Mass Loadings (Raw Coal).....	41

Table 32. Packed Column Test Conditions for Tailings Sample.....	44
Table 33. Packed Column Test Results for Tailings Sample.....	44
Table 34. Packed Column: Superficial Velocities and Mass Loadings .....	44
Table 35. Packed Column: Recommended Single-Stage Operating Conditions .....	46
Table 36. Packed Column: Recommended Second-Stage Operating Conditions .....	46
Table 37. Bench-Scale Test Conditions for Open Column (Raw Coal) .....	47
Table 38. Bench-Scale Test Results for Open Column (Raw Coal) .....	48
Table 39. Open Column: Superficial Velocities and Mass Loadings (Raw Coal).....	48
Table 40. Open Column Test Conditions for Tailings Sample.....	54
Table 41. Open Column Test Results for Tailings Sample.....	54
Table 42. Open Column: Superficial Velocities and Mass Loadings (Tailings Sample).....	54
Table 43. Open Column: Recommended Single-Stage Operating Conditions .....	57
Table 44. Open Column: Recommended Second-Stage Operating Conditions .....	57
Table 45. Assumed Plant Feedstock Analysis (dry basis).....	61
Table 46. Assumed Operating Conditions (Circuit Optimized) .....	62
Table 47. Jameson Cell: One-Stage Material Balance.....	63
Table 48. Outokumpu Cell: One-Stage Material Balance.....	63
Table 49. Open Column: One-Stage Material Balance .....	63
Table 50. Packed Column: One-Stage Material Balance .....	63
Table 51. Jameson Cell/Packed Column: Two-Stage Material Balance.....	64
Table 52. Jameson Cell/Open Column: Two-Stage Material Balance .....	64
Table 53. Outokumpu Cell/Packed Column: Two-Stage Material Balance.....	65
Table 54. Outokumpu Cell/Open Column: Two-Stage Material Balance .....	65
Table 55. Assumed Operating Conditions (Plant Optimized) .....	66
Table 56. Product Specification (As-Received Basis) .....	67
Table 57. Preparation Plant Flowsheet Assumptions.....	67
Table 58. Process Air Requirements .....	69
Table 59. Operating Assumptions.....	70
Table 60. Direct and Indirect Cost Estimation .....	72
Table 61. Unit Costs for Consumables .....	73
Table 62. Personnel Requirements.....	73
Table 63. Economic Model Inputs (Circuit-Optimized) .....	74

Table 64. Single-Stage Economic Results (Circuit-Optimized).....	75
Table 65. Two-Stage Economic Results (Circuit-Optimized).....	75
Table 66. Calculated Price Premium Requirement for Break-even Levelized Production Costs	76
Table 67. Economic Model Inputs (Plant-Optimized) .....	78
Table 68. One-Stage Economic Results (Plant-Optimized).....	79
Table 69. Two-Stage Economic Results (Plant-Optimized).....	79
Table 70. Levelized Incremental Cost Breakdown .....	80
Table 71. Capital and Operating Cost Sensitivity .....	81
Table 72. Plant Parameter Sensitivity Analysis .....	85

## LIST OF FIGURES

Figure 1. Particle Size Distribution of Plant Flotation Feed Coal .....	12
Figure 2. Historical Flotation Grade/Recovery Curve .....	19
Figure 3. Parametric Test Results for the Jameson Cell .....	27
Figure 4. Jameson Cell: Energy Recovery vs. Clean Coal Ash.....	27
Figure 5. Jameson Cell: Energy Recovery vs. Clean Coal Sulfur.....	28
Figure 6. Jameson Cell: Energy Recovery vs. Ash Rejection .....	29
Figure 7. Jameson Cell: Energy Recovery vs. Sulfur Rejection .....	29
Figure 8. Outokumpu HG Tank Cell: Energy Recovery vs. Clean Coal Ash.....	34
Figure 9. Outokumpu HG Tank Cell: Energy Recovery vs. Clean Coal Sulfur .....	35
Figure 10. Outokumpu HG Tank Cell: Energy Recovery vs. Ash Rejection .....	36
Figure 11. Outokumpu HG Tank Cell: Energy Recovery vs. Sulfur Rejection .....	36
Figure 12. Packed Column: Energy Recovery vs. Clean Coal Ash .....	42
Figure 13. Packed Column: Energy Recovery vs. Clean Coal Sulfur .....	42
Figure 14. Packed Column: Energy Recovery vs. Ash Rejection.....	43
Figure 15. Packed Column: Energy Recovery vs. Sulfur Rejection.....	43
Figure 16. Packed Column: Energy Recovery vs. Product Ash (Tailings Sample) .....	45
Figure 17. Packed Column: Energy Recovery vs. Clean Coal Sulfur (Tailings Sample).....	45
Figure 18. Packed Column: Energy Recovery vs. Ash Rejection (Tailings Sample) .....	45
Figure 19. Packed Column: Energy Recovery vs. Sulfur Rejection (Tailings Sample) .....	45
Figure 20. Open Column Parametric Test Results.....	50
Figure 21. Open Column: Energy Recovery vs. Clean Coal Ash .....	52

Figure 22. Open Column: Energy Recovery vs. Clean Coal Sulfur .....	52
Figure 23. Open Column: Energy Recovery vs. Ash Rejection .....	53
Figure 24. Open Column: Energy Recovery vs. Sulfur Rejection .....	53
Figure 25. Open Column: Energy Recovery vs. Clean Coal Ash (Tailings Sample) .....	56
Figure 26. Open Column: Energy Recovery vs. Product Sulfur (Tailings Sample) .....	56
Figure 27. Open Column: Energy Recovery vs. Ash Rejection (Tailings Sample).....	56
Figure 28. Open Column: Energy Recovery vs. Sulfur Rejection (Tailings Sample) .....	56
Figure 29. Model Raw Coal Energy Recovery vs. Clean Coal Ash .....	83
Figure 30. Model First-Stage Recovery vs. Frother Concentration .....	83
Figure 31. Model Second-Stage Column Recovery vs. Residence Time .....	84
Figure 32. Model Column Recovery vs. Frother Concentration.....	84

## DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

## EXECUTIVE SUMMARY

The overall objective of this research effort is to improve the efficiency of fine coal flotation in preparation plants above that of currently used conventional cells. In addition to evaluating single-stage operation of four selected advanced flotation devices, the project will also evaluate them in two-stage configurations. The project is being implemented in two phases. Phase I comprises bench-scale testing of the flotation units, and Phase II comprises in-plant, proof-of-concept (POC), pilot-scale testing of selected configurations at the Cyprus Emerald preparation plant. The Task 5 report presents the findings of the Phase I bench-scale test results and provides the basis for equipment selection for Phase II.

Four advanced flotation technologies selected for bench-scale testing are:

- Jameson cell
- Outokumpu HG tank cell
- Packed column
- Open column.

In addition to testing all four of the cells in single-stage operation, the Jameson and Outokumpu cells were tested as candidate first-stage cells because of their propensity for rapid attachment of coal particles with air bubbles and low capital and operating costs. The column cells were selected as candidate second-stage cells because of their high-efficiency separation of low-ash products from high-ash feed coals.

Samples of minus 150 $\mu$  (100-mesh) raw coal flotation feed and existing flotation circuit tailings (operated to produce tailings which simulated a second-stage feed coal) were collected at the Cyprus Emerald Plant. The raw coal samples were used to evaluate the performance of the selected cells in single-stage operation or as the first stage of a two-stage operation. The tailings sample was used to evaluate the performance of the cells in second-stage applications only. Three of the four cells were tested at vendor-recommended laboratory facilities. The fourth cell, i.e., the Outokumpu cell, was tested in the Cyprus plant because its high capacity made shipment of sufficient quantities of sample prohibitively expensive.

Table 1 describes the equipment used for the bench-scale work.

**Table 1. Summary of Bench-Scale Test Equipment**

<b>Flotation Unit</b>	<b>Effective Cross-Sectional Area, cm<sup>2</sup></b>	<b>Height, cm</b>	<b>Maximum Flow Rate Tested, l/min</b>
Jameson	182.3	122.0	14.7
Jameson	81.0	122.0	22.6
Outokumpu	716	59.0	94.5
Packed column	45.6	366.0	8.2
Open column	31.7	549.0	8.6

The vendors were given samples of the plant frother and the results of conventional bench-scale flotation tests to assist them in determining appropriate test conditions. Based on a preliminary evaluation of the plant economics, vendors were asked to target a clean coal product containing less than 5% ash at an energy recovery of approximately 85% for the feed coal sample.

### **Flotation Performance for the Feed Sample**

Between 20 and 40 tests were conducted for each cell. In general, the performance of each flotation machine was very good with respect to both grade and recovery. Three of the four cells exceeded the goal of a 5% ash product at 85% energy recovery. Total sulfur rejections noted during the project ranged from 25% to 40%. This would equate to pyritic sulfur rejections of 40-65%. Table 2 provides performance data from selected tests using a raw coal feed sample and shows the ability of all cells to work over a wide range of quality and energy recovery. The results of all other tests are given in Section 5 of this report.

In general, a number of process variables were found to be correlated to product ash.

- Addition of wash water was found to be beneficial for each of the cells tested, although it was not as significant as expected.
- Froth depth was observed to be significant with respect to product grade and recovery. Increased froth depth resulted in improved grade (i.e., lower product ash) but reduced recovery. However, the vendors noted that, in general, this coal could be processed with relatively shallow froth depths and still achieve an excellent grade of 4% product ash.
- Increased air flow rates led to slightly higher product ash contents and recoveries for the column cells.

**Table 2. Highlights of Bench-Scale Test Results (Raw Coal Sample)**

	<i>Jameson Cell</i>	<i>Outokumpu</i>	<i>Packed Column</i>	<i>Open Column</i>				
Feed Velocity (cm/s)	4.57	1.10	1.80	2.20	3.00	3.00	0.95	0.79
Aeration Rate (cm/s)	NA	NA	2.4	2.4	4.2	4.2	2.4	1.6
Wash Water Velocity (cm/s)	0.78	0.17	0.28	0.26	0.28	0.28	0.20	0.20
Froth Mass Loading (gm/min/cm <sup>2</sup> )	4.50	1.25	1.62	2.17	4.01	3.65	1.53	0.89
Product Ash (%)	3.80	4.70	7.30	7.90	4.90	3.50	5.30	4.10
Product Sulfur (%)	N/A	1.02	1.20	1.17	1.04	1.01	1.00	N/A
Energy Recovery (CMR, %)	72.9	85.4	68.5	66.0	87.2	80.5	93.0	86.0

Energy recovery was found to be primarily a function of reagent dosage and aeration rates. Frother was the most significant reagent for the Jameson and open column cells, with increasing frother addition leading to higher recoveries. The ratio of fuel oil to frother was fixed for the packed column tests, and increasing the rate of addition was found to increase recovery.

Cell capacity was generally dictated by froth mass loading considerations for the raw coal feed, especially for the Outokumpu and open column cells. High feed mass loadings resulted in reduced recoveries or placed limits on the capacity of the cell. The froth mass loading for the Jameson and packed column cells exceeded the levels observed for the open column. In the case of the Jameson cell, the ratio of feed pipe diameter (downcomer) to froth tank area was increased during the final set of tests to evaluate the first-stage capacity (high-capacity tests). These tests achieved a froth loading of 2.7 tph/m<sup>2</sup> (4.5 gm/min/cm<sup>2</sup>) with a recovery of 73%. This result indicates that the Jameson cell could be used at much higher capacities in first-stage applications compared to their usage as single-stage units.

### Flotation Performance for the Tailings Sample

Ten tests were run to evaluate the cleaning of the tailings using open and packed column cells as second-stage units. Typical results, shown in Table 3, indicate that a relatively low-ash product can be recovered from a feed containing 40-50% ash. This is equivalent to a combined first- and second-stage energy recovery of 93-96%. The column cells achieved good separation efficiency at feed velocities in the range of 1.8-3 cm/sec. The maximum froth loading measured in the second-stage test work was 0.9 tph/m<sup>2</sup> (1.53 gm/min/cm<sup>2</sup>). This constraint is within the anticipated requirements for processing dilute feed slurries expected for second-stage operations. The expected residence time requirement for second-stage column cell operation is 2-4 minutes.

**Table 3. Highlights of Bench-Scale Test Results (Tailings Sample)**

	<i>Packed Column</i>	<i>Open Column</i>
Test Numbers	T3	27
Feed Velocity (cm/s)	2.97	1.84
Aeration Rate (cm/s)	4.2	2.5
Wash Water Velocity (cm/s)	0.28	0.20
Froth Mass Loading (gm/min/cm <sup>2</sup> )	1.06	1.53
Product Ash (%)	6.5	8.1
Energy Recovery (CMR, %)	73.9	88.0

### Process Economics

Process economics were analyzed using two distinct approaches. In both cases, levelized costs were used as the basis of comparison. The first approach consists of viewing the fine coal circuit by itself. In this approach, four single-stage and four two-stage flotation circuits are compared on the basis of their levelized costs, which include capital costs, operating costs, and the amount of energy recovered from an equal amount of feed. These data are summarized in Table 4, which also shows the same parameters for the conventional flotation cells. In addition, the ash content of the various products is shown for purposes of comparison.

**Table 4. Economic Comparison of Flotation Circuits**

<b>Circuit</b>	<b>Levelized Cost, \$/MMBtu</b>	<b>Energy Recovery, %</b>	<b>Product Ash (db)</b>
Conventional flotation	0.20	85.0	7.5
Jameson	0.21	90.1	4.2
Outokumpu	0.20	85.0	8.0
Open column	0.16	93.0	5.3
Packed column	0.18	91.4	4.9
Jameson/Packed column	0.16	92.9	4.4
Jameson/Open column	0.14	96.8	4.9
Outokumpu/Packed column	0.16	91.8	7.1
Outokumpu/Open column	0.14	96.3	7.5

If only a single-stage circuit were to be designed and built, the open column has an advantage when both the product quality and leveled costs are considered. Two-stage circuits are generally more cost-effective than single-stage circuits. Further, their leveled costs are similar in all four cases, and as long as the fine coal circuit is considered in isolation, any of these four alternatives would perform equally well.

In the second approach, the flotation circuit is analyzed as a component in the whole cleaning plant. In this approach, the effects of the yield and quality in the fines circuit are studied interactively with the coarse coal cleaning circuits, e.g., heavy-media cyclones, in the plant. In this view, a two-stage circuit using a Jameson cell with an open or a packed column makes products with a significantly lower ash content while still achieving high energy recoveries. This improvement in the quality of the fines would allow the plant operators to increase the separation gravity in the coarse circuits, resulting in a slight increase in ash and yield for their products, while still maintaining the same overall quality, i.e., Btu, ash, moisture, etc., of the product on a plant-wide basis. An economic analysis carried out for a target plant product with 13,000 Btu/lb heating value (as-received basis) showed that an overall gain in the plant recovery of 0.8% can be achieved when using the Jameson/packed column two-stage option. When this increased energy recovery is factored into the leveled costs for this circuit, it results in the lowest overall cost of \$0.125/MMBtu in the product.

### Equipment Selection for POC Pilot-Scale Tests

After reviewing the performance data and related economics, the flotation machines and circuits recommended for POC testing at the pilot scale are:

- Single-stage Jameson cell
- Single-stage packed column
- First-stage Jameson cell, second-stage packed column.

The Jameson cell was selected for the first stage based on its good performance and low operating costs. The high-capacity tests indicated that it has a good potential for recovering a low-ash product with a high froth mass loading. Both the open and packed column cells achieved good process separations and demonstrated the potential for high-capacity operations with dilute feed slurries (second-stage feed conditions), and either cell would be suitable for demonstration of two-stage circuits. Both cells were capable of producing a product containing less than 4% ash from the raw coal. The packed column was selected in favor of the open column because of its:

- Potential for achieving high froth mass loading levels
- Potential for process control via regulation of froth depth
- Enhanced process separation efficiency when producing a low-ash product

## 1.0 INTRODUCTION

The work activities of this project are structured in two phases:

- Phase I: Bench-scale testing and equipment selection
- Phase II: In-plant, proof-of-concept (POC), pilot-scale testing.

This report presents the results of the Phase I work. The basic goal of this phase was to complete the bench-scale testing of the cells mentioned below and to recommend single- and two-stage circuits for testing at the POC scale in Phase II:

- Jameson cell
- Outokumpu HG tank cell
- Packed column
- Open column.

The report is structured in sections corresponding to each major work activity. The project objectives and the equipment selection criteria formulated at the start of the project are presented in Section 2.

Section 3 describes test sample collection and related sample analysis.

In Section 4, plant data and initial construction of a two-stage material balance are discussed.

In Section 5, the bench-scale test work is described and the results are analyzed. In general, the testing included the following:

- Each cell was tested for single-stage operation.
- The Jameson and Outokumpu cells were also tested for use as the first stage of a two-stage circuit.
- The open and packed column cells were tested for use as the second stage of a two-stage circuit.

In Section 6, a conceptual design based on the bench-scale test results is developed for both single- and two-stage circuits. The bench-scale test results are scaled up and circuit material balances are completed for the following eight configurations:

**Single-stage operation**

Jameson cell  
Outokumpu HG tank cell  
Open column  
Packed column

**Two-stage operation**

Jameson/open column  
Jameson/packed column  
Outokumpu/open column  
Outokumpu/packed column

Section 7 presents the economics of using each single- and two-stage circuit at the Cyprus plant. Levelized product costs are used as the basis for making comparisons between circuits. The economics include a sensitivity analysis of coal and process assumptions that impact the leveled costs.

Section 8 presents a discussion of the merits of two-stage circuits.

Equipment selection recommendations for the in-plant POC pilot-scale tests are presented in Section 9.

## **2.0 PROJECT OBJECTIVES**

The objective of the project is to test advanced flotation concepts in order to improve fine coal cleaning and develop an optimal circuit configuration. This project objective may be broken down into the following subsections:

- Evaluate emerging flotation equipment and practices and select four advanced flotation cells.
- Conduct bench-scale studies to establish the relationships between capacity and product recovery and ash content for each cell.
- Conduct economic analyses of the bench-scale results and select two of the most promising advanced flotation cells for POC testing.
- Design and construct a pilot-scale POC flotation circuit to conduct single- and two-stage flotation tests.
- Test and demonstrate single- and two-stage circuits to gather operating data for accurate estimation of full-scale plant operations.

The criteria for selection of advanced flotation equipment are summarized below.

- Good cleaning performance, i.e., ash and sulfur rejection, at high Btu recovery levels
- Sufficient data available at the laboratory scale, or larger, to substantiate process performance claims
- Demonstrated operations for coal or other mineral applications
- Ability to recover a high-grade coal product from a raw coal feed with high specific capacity. (This is important for rate-limited cells when used as first-stage units.)
- Efficient recovery of low-ash coal from a high-ash feed coal. (This is important for second-stage cells receiving a high-ash feed.)
- Amenability to process control under varying plant conditions.

The four flotation cells selected for bench-scale test work were:

- A Jameson cell
- An Outokumpu Mintec HG tank cell
- A Pyramid Resources, Inc. open column cell
- A packed column cell from Mineral Technologies International, Inc. (MTI).

Four equipment vendors with proven expertise in conducting bench-scale test work were selected for the work. The Jameson cell was tested at Southern Illinois University at Carbondale (SIUC), Carbondale, IL; the open column tests were conducted at the Pyramid Resources, Inc. facility in Salt Lake City, UT; the packed column tests were conducted at MTI facilities in Morgantown, WV; and the Outokumpu Mintec HG tank cell was tested at the Cyprus Emerald facility in Waynesburg, PA.

### **3.0 SAMPLE COLLECTION AND ANALYSIS**

#### **3.1 Sample Collection**

Representative samples of the  $150\mu \times 0$  (100M x 0) stream from the Emerald plant were collected to conduct the bench-scale test work. Multiple samples were collected to correspond to each flotation circuit to be tested. These were:

- Minus 100-mesh raw coal (classifying cyclone overflow) flotation feed
- Flotation tailings
- Froth flotation product from the existing flotation cells.

Relatively large quantities of the first two streams, i.e., feed and tailings, were collected in order to ship them to vendors for bench-scale testing. In addition, 5-gallon samples from all three streams were collected and set aside for analytical purposes.

A total of 45 drums in five sets (9 drums/set) of flotation feed and 10 drums in another five sets (2 drums/set) of the flotation tailings were collected.

The drums were filled using a flexible hose connected to the sampling port of the plant feed and tailings streams. During sample collection, the hose was transferred from one drum to another while attempting to minimize spillage. The samples were collected in increments of 5 gallons each. Sample collection lasted over five shifts.

### 3.2 Sample Analysis

The 5-gallon analytical samples collected over the entire sampling period were combined to form raw coal and tailings composite samples which were used for the preliminary analytical and characterization work. Coal characterization tests were conducted on plant flotation feed, product, and tailings samples to provide information necessary for bench-scale testing. The 150 $\mu$  x 0 (100M x 0) plant flotation feed coal and the tailings sample were fully characterized for proximate analysis as per ASTM standards (ASTM D 3173, D 3174, D 3175); total sulfur and forms of sulfur were determined based on ASTM D 2492. The plant feed coal analysis is presented in Table 5 and the plant tailings sample analysis is presented in Table 6.

**Table 5. Plant Flotation Feed Coal Analysis**

Parameter	Value
Ash	19.99
Sulfur forms	
Sulfatic sulfur	0.00
Pyritic sulfur	0.49
Organic sulfur	0.61
Total sulfur	1.10
Btu/lb	11,911

**Table 6 . Plant Flotation Tailings Analysis**

Parameter	Value
Ash	47.83
Sulfur forms	
Sulfatic sulfur	0.01
Pyritic sulfur	1.41
Organic sulfur	0.33
Total sulfur	1.75
Btu/lb	7,359

Figure 1 illustrates the particle size distribution of the plant feed which was determined using a Microtrac Analyzer.

Washability tests were also conducted on the plant feed coal based on ASTM D 4371 using the centrifuge sink/float technique, the results of which are presented in Table 7.

**Table 7. Plant Flotation Feed Coal Washability Analysis (100M x0)**

Specific Gravity Fraction	Elementary Data					Cumulative Computed Data					Analysis		
	Wt %	Ash	Sulfur	Btu*	SO2/ MBtu	Wt %	Ash	Sulfur	Btu	SO2/ MBtu	Btu Recovery	CMR %	Ash Rejection %
Float	25.4	2.2	0.90	14768	1.22	25.4	2.2	0.9	14768	1.22	30.7	30.3	96.9
1.3	34.4	5.6	0.99	14142	1.40	59.7	4.2	0.95	14408	1.32	70.6	69.9	86.2
1.4	14.6	10.4	0.95	13270	1.43	74.3	5.4	0.95	14184	1.34	86.5	85.9	77.8
1.5	6.2	11.8	0.82	13017	1.26	80.5	5.9	0.94	14095	1.34	93.1	92.5	73.8
1.6	3.3	21.1	0.87	11381	1.53	83.7	6.5	0.94	13990	1.34	96.1	95.6	70.0
1.8	78.0	2.09	2886	14.48		100.0	18.1	1.13	12184	1.85	100.0	100.0	0.0
Sink													

\* Estimated

These washability data provide a good estimate of the expected flotation circuit performance and indicate that at energy recoveries of 85% a product ash content of about 5.3% would be achieved while about 35% of the total sulfur would be rejected. Since most of the rejected sulfur is pyritic in nature, pyritic sulfur rejections may reach about 70%.

! to 999 (secs)

MICROTRAC DATA: MANUAL MODE  
measurem't/present'n#: 3675 - 1  
7997 0.69-704. SRA res: NORMAL  
chan select bounds: 0.69- 704.00  
progression: standard # chans:20  
sample date/time: 04/26/95 12:44  
sample ident: GEOCHEMICAL TESTING  
sample ID : R C COMP FLT FEED  
lot code:  
account #: printer: ON  
run time: 60 sec. run #: 100/ 3  
sample preparation code:  
notes:

Esc-exit


F2-commands

ch-top	%pass	%-ch
704.00	100.0	0.0
497.80	100.0	0.0
352.00	100.0	2.8
248.90	97.2	6.0
176.00	91.1	7.5
124.45	83.6	10.4
88.00	73.2	10.5
62.23	62.7	9.7
44.00	53.0	8.3
31.11	44.8	7.1
22.00	37.7	7.3
15.56	30.4	6.8
11.00	23.6	4.9
7.78	18.7	4.4
5.50	14.3	4.9
3.89	9.4	3.3
2.75	6.1	3.2
1.94	2.9	1.7
1.38	1.2	1.0
0.97	0.2	0.2

summary data
dv: 0.0280
%10: 4.05
%50: 39.33
%90: 168.69
mv: 64.18
os: 0.522
sd: 60.32
ma: 11.51

parameters	
name	value
smpl amt	
disprsn	
diso amt	
disp med	
dmed amt	
agitat'n	
agit tim	
circul'n	
circ tim	
param #1	
param #2	
param #3	

GEOCHEMICAL TESTING  
R C COMP FLT FEED  
Record Number: 3675



Esc-exit F2-clr key

Figure 1. Particle Size Distribution of Plant Flotation Feed Coal

### 3.3 Batch Flotation Tests

The batch feed and tailings samples were tested in a conventional (batch) flotation cell to determine a benchmark laboratory performance against which the performance of all the advanced flotation machines would be assessed. The froth product from a single-stage batch experiment was repulped and floated in a second stage. Second-stage froth recleaning was incorporated in an effort to simulate froth washing techniques used in advanced flotation equipment. The product of this two-stage bench flotation procedure was intended to represent the product expected from the advanced flotation cells. The results of the batch flotation testing of the raw coal and tailings samples are presented in Table 8 and Table 9.

The results for the two-stage flotation test on the feed coal show that advanced cells should be able to provide energy recoveries of 85-90% at 5% product ash values, while rejecting 30% of the total sulfur.

**Table 8. Batch Flotation Tests on Plant Flotation Feed**

**One Stage Flotation Using 5.2% Solids**

Collector (Fuel oil) 0.40 kg/tonne coal (.81 lb/ton)  
Frother (SM222) 0.17 kg/tonne coal (0.35 lb/ton)

Stage	Flotation Time	Product(Direct Values)			Product(Cumulative Values)			Performance		
		Wt %	Ash %	Sulfur %	Yield %	Ash %	Sulfur %	Btu Rec%	Ash Rej	
Rougher	30 sec	42%	6.6%	1.09%	42.0%	6.6%	1.09%	49.2%	86%	
	60 sec	9.9%	6.7%	1.09%	51.9%	6.6%	1.09%	60.8%	83%	
	120 sec	7.4%	9.2%	1.12%	59.3%	7.0%	1.09%	69.2%	80%	
	Tails	40.7%	39.9%	1.13%						
<b>Total</b>					<b>100.0%</b>	<b>20.4%</b>	<b>1.11%</b>			

**One Stage Flotation Using 5.2% Solids**

Collector (Fuel oil) 0.56 kg/tonne coal (1.11 lb/ton)  
Frother (SM222) 0.23 kg/tonne coal (0.47 lb/ton)

Stage	Flotation Time	Product(Direct Values)			Product(Cumulative Values)			Performance		
		Wt %	Ash %	Sulfur %	Yield %	Ash %	Sulfur %	Btu Rec%	Ash Rej	
Rougher	30 sec	51.0%	6.6%	1.10%	51.0%	6.6%	1.10%	60.7%	84%	
	60 sec	13.3%	7.4%	1.14%	64.2%	6.7%	1.11%	76.3%	80%	
	120 sec	9.9%	9.4%	1.22%	74.2%	7.1%	1.12%	87.8%	76%	
	Tails	25.8%	62.9%	1.01%						
<b>Total</b>					<b>100.0%</b>	<b>21.5%</b>	<b>1.09%</b>			

**Two Stage Flotation Using 2.9% Solids**

Collector (Fuel oil) 0.99 kg/tonne (1.98 lb/ton) & 1.13 kg/tonne (2.25 lb/ton) -1st and 2nd stage resp.

Frother (SM222) 0.42 kg/tonne (0.84 lb/ton) & 0.48 kg/tonne (0.96 lb/ton) -1st and 2nd stage resp.

Stage	Flotation Time	Product(Direct Values)			Product(Cumulative Values)			Performance		
		Wt %	Ash %	Sulfur %	Yield %	Ash %	Sulfur %	Btu Rec%	Ash Rej	
Cleaner	30 sec	64.7%	4.0%	1.09%	64.7%	4.0%	1.09%	76.1%	85.9%	
	60 sec	7.1%	6.6%	1.22%	71.8%	4.3%	1.10%	84.2%	83.4%	
	120 sec	5.9%	6.3%	1.22%	77.7%	4.4%	1.11%	91.0%	81.4%	
	Tails	2.4%	61.3%	1.77%	80.0%	6.1%	1.13%	92.1%	73.5%	
Rougher	Tails	20.0%	67.8%	1.21%						
	<b>Total</b>				<b>100.0%</b>	<b>18.4%</b>	<b>1.15%</b>			

**Table 9. Batch Flotation Tests on Plant Flotation Tailings**

**One Stage Flotation**

Collector (Fuel oil) 1.9 kg/tonne (3.8 lb/ton)

Frother (SM222) 0.7 kg/tonne (01.4 lb/ton)

Stage	Flotation Time	Product(Direct Values)			Product(Cumulative Values)			Performance		
		Wt %	Ash %	Sulfur %	Yield %	Ash %	Sulfur %	Btu Rec%	Ash Rej %	
Rougher	30 sec	22.50	15.17	1.75	15.2	22.5	1.8	30.2	90.7	
	60 sec	10.00	9.87	1.66	13.5	32.5	1.7	44.4	88.0	
	120 sec	7.50	14.05	1.12	13.6	40.0	1.6	54.6	85.2	
	Tails	60.00	52.14	2.09	100.0	36.7	1.68			
Total										

**Two Stage Flotation**

Collector (Fuel oil) 0.9 kg/tonne (1.8 lb/ton) in 2nd stage resp.

Frother (SM222) 0.4 kg/tonne (0.8 lb/ton) in both 1st and 2nd stage resp.

Stage	Flotation Time	Product(Direct Values)			Product(Cumulative Values)			Performance		
		Wt %	Ash %	Sulfur %	Yield %	Ash %	Sulfur %	Btu Rec%	Ash Rej %	
Cleaner	30 sec	16.05	5.64	1.57	16.1	5.6	1.57	24.0	97.5	
	60 sec	8.77	6.05	1.59	24.8	5.8	1.58	37.1	96.1	
Cleaner	Tails	13.28	24.10	2.31	38.1	12.2	1.83	53.0	87.4	
Rougher	Tails, +48 mesh	16.29	8.32	1.93						
Rougher	Tails, -48 mesh	45.61	67.79	2.11						
Total					100.0	36.9	1.82			

### 3.4 QA/QC Analysis

Verification of vendor analyses for ash and total sulfur was completed in two steps: (i) repeat analysis of project feed coal samples during testing and (ii) analysis of selected bench-scale samples by an independent laboratory. First, subsamples of the project samples sent to the vendors were analyzed at the Cyprus coal laboratory. The vendors were also requested to analyze the feed samples periodically during their test work. The analysis of the Cyprus plant flotation feed and tailings samples collected for the bench-scale test work is presented in Table 10. The corresponding vendor analysis is presented in Table 11 and Table 12.

As discussed in Section 5, a bench-scale Outokumpu HG tank cell was installed and tested at the Cyprus plant site using a slipstream of the plant flotation feed. Therefore, for this cell, comparison of the plant flotation feed analysis with the project sample analysis does not represent a check on analytical procedures. For this reason, the Outokumpu analysis is not presented in Table 12.

**Table 10. Analysis of Plant Flotation Feed and Tailings Samples**

Set ID	Sample	Ash	Sulfur	% Solids
A	Raw Coal	20.0	1.09	5.21
B	Raw Coal	19.0	1.07	5.20
C+D	Raw Coal	18.3	1.11	2.80
E	Raw Coal	18.1	1.11	2.75
	Tailings	47.8	1.75	N/A

**Table 11. Vendor Analysis of Feed Coal (Flotation Feed) to Test Cells**

Vendor (Test Site)	Ash, %	Sulfur, %
Jameson Cell (SIUC)		
Raw coal A	20.2	1.00
	20.4	
Raw coal B	19.5	
	21.5	
	20.0	
Packed Column (MTI)		
Raw coal A	20.6	1.12
	20.2	1.12
	21.0	1.10
	20.6	1.10
Raw coal B	20.0	1.12
	19.0	1.13
	19.6	1.10
Open Column (Pyramid)		
Raw coal B	20.2	.87
	20.6	1.26
Raw coals B&C	20.5	1.40
	19.6	1.60
Raw coal D	19.5	1.46
	19.7	0.87
	19.1	0.92
Raw coal E	19.1	
	19.9	
	18.5	
	18.6	

**Table 12. Vendor Analysis of Feed Coal (Tailings) to Test Cells**

Vendor (Test Site)	Ash, %	Sulfur, %
Packed Column (MTI)	46.1	2.10
Open Column (Pyramid)	46.6	1.30
	42.3	
	48.6	
	45.7	
	44.5	

The second step in checking the vendor analyses was to request that splits of the test samples be sent to an independent laboratory for analysis. A comparison of the independent laboratory analyses with the corresponding vendor results is shown in Table 13.

**Table 13. Comparison of Vendor and Independent Laboratory Analyses**

Sample	Vendor		Independent Laboratory	
	Ash, %	Sulfur, %	Ash, %	Sulfur, %
Jameson	20.7	N/A	20.7	1.00
	4.19	N/A	4.49	0.97
	55.9	N/A	50.2	1.10
	20.4	N/A	20.2	1.07
	3.67	N/A	4.19	0.92
	46.5	N/A	45.8	1.20
	21.5	N/A	21.7	1.01
	4.51	N/A	5.05	0.96
	56.0	N/A	55.5	1.12
Packed Column				
B-4 feed	20.0	1.12	19.3	1.11
	4.88	1.07	4.64	1.05
	70.4	1.37	71.2	1.25
B-16 feed	20.02	1.12	18.5	1.12
	4.88	1.04	4.68	1.03
	59.8	1.38	60.8	1.34
B-17	3.50	1.01	3.42	0.99
	51.4	1.40	52.7	1.34
C-1	19.7	N/A	19.9	1.15
	4.75	N/A	4.61	1.01
	50.6	N/A	51.0	1.27

The vendor analytical techniques are within ASTM specifications for ash and sulfur with the exception of the Pyramid open column analysis for sulfur, shown in Table 11. After a review of these results, Pyramid was requested to use an outside laboratory for this sulfur analysis.

Sulfur measurements for the Jameson cell were also completed by an outside laboratory. No other significant differences in the analyses between laboratories were detected.

## 4.0 PLANT DATA AND FLOTATION CIRCUIT MATERIAL BALANCE ESTIMATES

### 4.1 Conventional Flotation

Before the start of the test program, historical plant flotation data were reviewed to assess circuit performance. Sample sets of the flotation circuit feed, clean coal, and tailings were compiled as shown in Table 14.

Table 14. Historical Plant Flotation Performance

Feed	Ash % (db)			Sulfur % (db)			Energy Recovery	Total Sulfur Rejection, %
	Product	Tailings	Feed	Product	Tailings	Feed		
28.6	7.8	63.5	1.64	1.81	2.13	81.0	30.8	
26.7	8.4	76.1	1.62	1.65	2.09	91.1	25.8	
28.4	7.4	61.9	1.62	1.63	2.06	79.5	38.1	
31.0	7.6	65.5	1.62	1.59	1.94	79.9	41.4	
31.4	7.4	60.3	1.8	2.11	2.2	73.7	36.0	
26.9	6.7	73.2	1.89	1.77	1.96	88.9	34.8	
30.0	8.6	72.8	1.95	1.9	1.73	87.0	35.1	
25.0	6.4	36.0				46.5		
36.1	9.2	83.8				90.8		
36.0	7.7	80.3				88.0		
31.9	7.3	78.8				89.3		
30.5	7.8	79.8				90.9		
31.5	7.6	60.5	1.95	2.15	2.37	73.9	39.6	
29.7	7.2	71.3				85.7		
29.1	7.4	53.2				68.8		
26.5	7.9	67.8				86.4		
24.9	7.8	71.9				90.0		
25.8	7.7	48.3				69.1		
24.7	7.3	53.0				76.3		

The data represent a wide range in circuit operations, with feed ash ranging from 25% to 36% and recoveries varying between 46% and 91%. Figure 2 shows a plot of the flotation circuit data illustrating the trend in energy recovery versus clean coal ash. In addition to the average trend line, a second curve depicts the assumed grade/recovery curve for the case when the flotation feed ash content is 20% (ash content of the project sample). Using this low-ash coal feed grade/recovery curve, the projected performance of the existing flotation cells is 85% energy recovery at a clean coal ash content of 7.5%.




Figure 2. Historical Flotation Grade/Recovery Curve

#### 4.2 Advanced Flotation Circuit Material Balances

Material balance estimates of single- and two-stage flotation circuits were developed based on information in the literature, discussions with the equipment vendors, and the characterization test data (batch flotation tests and centrifuge float/sink analyses).

A review of the literature on advanced flotation cell operations indicated that:

- Properly applied wash water was effective in removing entrained ash from the froth.
- Product ash can approach the ash level measured by float 1.6 specific gravity (centrifuge sink/float method).

Estimates of the performance for both single-stage and two-stage flotation circuits were derived from consideration of the washability properties of the raw coal sample and bench-scale flotation test results as given in Section 3.3. Table 15 and Table 16 list the relevant data for these tests and the assumed performance for single-stage operation and for the first stage of a two-stage circuit, respectively. At this point, the overall performance of the two-stage circuit was assumed to be the same as that of the single-stage circuit.

Theoretically, the wash water is set in excess of the water carry-over by the froth to remove all of the process water from the froth and establish a net flow of wash water to the flotation tailings stream, i.e., negative bias.

**Table 15. Estimated Single-Stage Flotation Performance**

	<i>Raw Coal Washability Float 1.6 SG</i>	<i>Laboratory Flotation Test</i>	<i>Assumed Single-Stage Advanced Flotation Circuit Performance</i>
Weight yield, %	80.5	77.7	76.6
Btu recovery, %	92.5	91.0	91
Clean coal ash, %	5.9	4.4	5.0
Clean coal sulfur, %	0.94	1.11	1.0

**Table 16. Estimated First-Stage Flotation Performance**

	<i>Raw Coal Washability Float 1.4 SG</i>	<i>Laboratory Flotation Test</i>	<i>Assumed First-Stage Advanced Flotation Circuit Performance</i>
Weight yield, %	59.7 %	64.7	60
Btu recovery, %	70.6%	76.1	72
Clean coal ash, %	4.17 %	4.0	4.0
Clean coal sulfur, %	0.95%	1.09	1.0

The assumptions required to complete a material balance for the single-stage and two-stage circuits are given in Table 17. The feed conditions are taken from the plant flowsheet and the coal quality values are selected to be compatible with the project raw coal sample.

**Table 17. Plant Flotation Circuit Assumptions**

Feed Rate, tph	76
Flow Rate, gpm	9000
Feed % solids	3.3%
Feed ash, %	20
Feed sulfur, %	1.1

The plant feed conditions and circuit performance assumptions (Table 15, Table 16, and Table 17) were used to derive material balance estimates for the single-stage circuit, given in Table 18, and for a two-stage configuration, given in Table 19.

The important features of the assumed material balances are:

- Feed percent solids is 3.3%
- Overall product ash is 5% ash
- Energy recovery is 91%
- Second-stage feed ash is 44%
- Second-stage feed percent solids is 1.4%
- Second-stage flow rate is approximately equal to first-stage flow rate.

Table 18. Estimated Single-Stage Material Balance

	Solids, tph	Solids, %	Water, tph	Slurry, tph	Slurry Density	Slurry Flow Rate, gpm	Ash, %	Sulfur, %
Feed	76	3.35	2193	2269	1.008	9000	20.0	1.1
Wash water			250	250	1.000	1000		
Product	58	20	233	291	1.053	1107	5.0	1.0
Tailings	18	0.80	2210	2228	1.002	8893	69.2	1.4

Table 19. Estimated Two-Stage Flotation Material Balance

	Solids, tph	Solids, %	Water, tph	Slurry, tph	Slurry Density	Slurry Flow Rate, gpm	Ash, %	Sulfur, %
1st-stage balance								
Feed	76	3.3	2,193	2,269	1.008	9,000	20.0	1.1
Wash water			200	200	1.000	800		
Product	46	20.0	182	228	1.053	866	4.0	1.0
Tailings	3	1.4	2,211	2,241	1.003	8,934	44.0	1.3
2nd-stage balance								
Feed	30	1.4	2,211	2,241	1.003	8,934	44.0	1.3
Wash water			75	75	1.000	300		
Product	13	20.0	51	63	1.053	240	8.6	1.0
Tailings	18	0.8	2,235	2,253	1.002	8,993	69.2	1.4
Combined product	58		233	291	1.053	1,107	5.00	1.0

## 5.0 BENCH-SCALE TESTS

### 5.1 Introduction

As described in Section 4, coal characterization flotation tests and washability analyses conducted prior to bench-scale testing indicated that a product containing less than 5% ash could be achieved with high energy recovery. The flotation cell vendors were informed of these results before starting the bench-scale test work and were asked to achieve a minimum energy recovery of 85% at a product ash of 5% for a single-stage operation. The second-stage performance target (tailings sample) was set at production of a 5-10% ash product at a minimum 70% energy recovery. This would provide a total energy recovery of 90% or more in the two-stage operation.

The vendors were also instructed to determine cell operating conditions to produce a low-ash first-stage product at maximum capacity and lower-than-acceptable total energy recovery. A grade/recovery relationship for a second-stage operation was established using the plant tailings sample in the column cells. By determining the conditions for single-stage and two-stage flotation operations, a total grade/recovery relationship for the two stages could be calculated.

During the test work, a Praxis test engineer visited each test site to inspect the work in progress and to assure that appropriate QA/QC measures were adopted during test and analytical work. Flow rates, equipment calibration, and process calculations were verified to assure that the reported values were accurate. Cell operations were discussed with the vendors, and their recommendations for equipment scale-up were obtained. Test work on the Outokumpu HG tank cell was conducted in the Cyprus plant under the supervision of a test engineer from Praxis. The dimensions of the cells used for the bench-scale test work are given in Table 1. The bench-scale tests conducted for each flotation machine, along with the results obtained, are summarized in this section.

### 5.2 Jameson Cell

All bench-scale tests for this cell used only feed coal. The test work was conducted in two sequences. First, a series of 19 single-stage tests and 3 two-stage tests was completed, primarily to quantify the importance of major operating parameters (parametric studies). A

6-inch diameter cell was used for this series and the equipment configuration such as the downcomer diameter and orifice size was set to conform to sizes (24.5 mm and 3 mm, respectively) used for coal flotation in Australia.

A second series of tests was completed at very high feed flow rates in order to evaluate the Jameson cell for first-stage operations. A 4-inch diameter cell was used for these tests in order to minimize sample usage.

The major process parameters tested were:

- Reagent dosage
- Froth depth
- Feed rate
- Two-stage processing.

All tests were carried out on a semi-batch basis. Coal slurry was batched to a holding tank and agitated with a mixer. The feed slurry was also recirculated with a pump. Fuel oil was added to the feed coal batch and mixed (conditioned) for five minutes before the start of testing. Frother was added directly into the feed pipe. Air was adjusted to produce a stable froth in accordance with previous process parameter settings used for treating coal. The cell was operated for at least 600 seconds (10 minutes) until steady state was achieved, after which product and tailings samples were collected simultaneously. For each set of tests, a feed sample was taken prior to the start of testing.

During testing, it was observed that the downcomer operation was very consistent and the partial vacuum developed in it remained stable. Similarly, the froth depth was also consistent and did not vary more than  $\pm 0.635$  cm ( $\pm 0.25$  inches). The froth achieved was dense and viscous with a small bubble structure. However, the discharge from the cell was continuous and consistent.

The bench-scale tests conditions are shown in Table 20 and results are shown in Table 21. The various scale-up parameters for these tests are shown in Table 22. This table presents the Jameson cell test conditions after conversion to superficial velocity and mass loading values for purposes of comparison to the other flotation cells. Since the flow rate to the Jameson cell is

set by the downcomer jet action, the feed mass flow rate was tested over a narrow range of 1.14 to 1.44 tph/m<sup>2</sup> during the parametric tests (1.9 to 2.4 gm/min/cm<sup>2</sup>) with a feed superficial velocity of about 1.5-1.6 cm/s (3.0-3.2 ft/min) (calculation based on froth tank area and feed flow rate). The corresponding froth mass flow rate was 0.6-1.02 tph/m<sup>2</sup> (1.0-1.7 gm/min/cm<sup>2</sup>).

The prefixes designating test types in these tables stand for the following:

- VR: Reagent dosage variation
- LF: Low frother
- VF: Variable froth depth tests
- HT, DT: Feed rate variability
- TS: Two-stage tests
- HV: Series 2 tests with high volumetric feed rates.

**Table 20. Bench-Scale Test Conditions for Jameson Cell**

Test Number	Feed Flow Rate		Solids %	Mass Flow Rate		Fuel Oil		Frother		Froth Depth		Wash Water		Air	
	gpm	m <sup>3</sup> /s x 10 <sup>-3</sup>		gm/min	Kg/s	lb/ton	Kg/t	lb/ton	Kg/t	in	m	gpm	m <sup>3</sup> /s x 10 <sup>-3</sup>	l/min	m <sup>3</sup> /s x 10 <sup>-3</sup>
<i>15.2 cm (6 inch) diameter Jameson cell</i>															
VR-1	3.17	0.20	2.96	355	0.0059	1.33	0.67	0.67	0.34	15	0.38	0.50	0.032	NA	NA
VR-2	3.17	0.20	2.96	355	0.0059	1.67	0.84	0.80	0.40	18	0.46	0.50	0.032	NA	NA
VR-3	3.17	0.20	2.96	355	0.0059	2.00	1.00	1.00	0.50	20	0.51	0.50	0.032	NA	NA
VR-4	3.17	0.20	2.96	355	0.0059	2.33	1.17	1.17	0.59	21	0.53	0.50	0.032	NA	NA
VR-5	3.17	0.20	2.96	355	0.0059	2.67	1.34	1.33	0.67	22	0.56	0.50	0.032	NA	NA
VR-6	3.17	0.20	2.96	355	0.0059	3.00	1.50	1.50	0.75	22	0.56	0.50	0.032	NA	NA
VF-1	3.43	0.22	2.91	378	0.0063	2.67	1.34	1.33	0.67	23	0.58	0.50	0.032	NA	NA
VF-2	3.43	0.22	2.91	378	0.0063	2.67	1.34	1.33	0.67	17	0.43	0.50	0.032	NA	NA
VF-3	3.43	0.22	2.91	378	0.0063	2.67	1.34	1.33	0.67	13	0.33	0.50	0.032	NA	NA
VF-4	3.43	0.22	2.91	378	0.0063	2.67	1.34	1.33	0.67	10	0.25	0.50	0.032	NA	NA
VF-5	3.43	0.22	2.91	378	0.0063	2.67	1.34	1.33	0.67	7	0.18	0.50	0.032	NA	NA
HT-1	3.96	0.25	2.91	436	0.0073	2.67	1.34	1.33	0.67	5	0.13	0.50	0.032	NA	NA
HT-2	3.96	0.25	2.91	436	0.0073	2.67	1.34	1.33	0.67	4	0.1	0.50	0.032	NA	NA
DT-1	3.17	0.20	2.71	325	0.0054	2.67	1.34	1.33	0.67	7	0.18	0.50	0.032	NA	NA
DT-2	3.17	0.20	2.71	325	0.0054	2.67	1.34	1.33	0.67	5	0.13	0.50	0.032	NA	NA
LF-1	3.17	0.20	2.94	353	0.0059	3.00	1.50	1.00	0.50	6	0.15	0.50	0.032	NA	NA
LF-2	3.17	0.20	2.94	353	0.0059	3.50	1.75	0.80	0.40	6	0.15	0.50	0.032	NA	NA
LF-3	3.17	0.20	2.94	353	0.0059	4.00	2.00	0.50	0.25	2	0.05	0.50	0.032	NA	NA
TS-1	3.96	0.25	2.89	433	0.0072	2.67	1.34	1.33	0.67	5	0.13	0.50	0.032	NA	NA
TS-2*	3.30	0.21	0.91	114	0.0019	0.00	0.00	0.00	0.00	6	0.15	0.50	0.032	NA	NA
TS-3*	3.30	0.21	0.91	114	0.0019	1.30	0.65	0.80	0.40	6	0.15	0.50	0.032	NA	NA
TS-4*	3.30	0.21	0.91	114	0.0019	3.50	1.75	2.10	1.05	6	0.15	0.50	0.032	NA	NA
<i>10.2 cm (4 inch) diameter Jameson cell</i>															
HVR-1	5.87	0.37	2.67	593	0.0099	2.20	1.10	1.13	0.57	22	0.56	1.00	0.063	NA	NA
HVR-2	5.87	0.37	2.67	593	0.0099	1.70	0.85	0.85	0.43	19	0.48	1.00	0.063	NA	NA
HVR-3	5.87	0.37	2.67	593	0.0099	1.70	0.85	0.85	0.43	16	0.41	1.00	0.063	NA	NA
HVR-4	5.87	0.37	2.67	593	0.0099	1.70	0.85	0.85	0.43	6	0.15	1.00	0.063	NA	NA
HVTS-1	5.87	0.37	2.71	602	0.0101	2.00	1.00	0.75	0.38	22	0.56	1.00	0.063	NA	NA
HVTS-2*	5.87	0.37	1.03	229	0.0038	0.00	0.00	0.00	0.00	6	0.15	0.50	0.032	NA	NA
HVTS-3*	5.87	0.37	1.03	229	0.0038	0.20	0.10	0.00	0.00	13	0.33	0.50	0.032	NA	NA
HVTS-4*	5.87	0.37	1.03	229	0.0038	0.20	0.10	0.00	0.00	3	0.08	0.50	0.032	NA	NA

\* Two stage tests

Table 21. Bench-Scale Test Results for Jameson Cell

Test Number	Feed			Product			Tailings			Analysis				
	Ash %	Sulfur %	Pyr. S %	Ash %	Sulfur %	Pyr. S %	Ash %	Sulfur %	Pyr. S %	Yield, %	CMR, %	Ash Rej %	TSR %	PSR %
<i>15.2 cm (6 inch) diameter Jameson cell</i>														
VR-1	20.2			3.6	0.98		38.4			52	63	91		
VR-2	20.2			3.7			46.1			61	74	89		
VR-3	20.2			3.9			51.1			65	79	87		
VR-4	20.2	1.00	0.49	4.2	0.97	0.25	55.9	1.10	1.08	69	83	86	33.0	64.8
VR-5	20.2	1.00		3.7	1.01		53.9			67	81	88	32.2	
VR-6	20.2			4.0			45.7			61	74	88		
VF-1	20.4	1.07	0.57	3.7	0.92	0.24	46.5	1.20	1.01	61	74	89	47.6	74.3
VF-2	20.4			3.8			51.8			65	79	88		
VF-3	20.4			3.9			54.5			67	81	87		
VF-4	20.4			4.0			57.9			70	84	87		
VF-5	20.4			4.0			60.1			71	85	86		
HT-1	19.5			4.1	1.02		60.7			73	87	85		
HT-2	19.5			4.2			67.3			76	90	84		
DT-1	21.5	1.01	0.53	4.5	0.96	0.27	56.0	1.19	1.12	67	82	86	36.3	65.9
DT-2	21.5	1.01		4.7	1.02		61.4			70	85	85	29.0	
LF-1	20.0			4.4			49.9			66	79	86		
LF-2	20.0			4.0			53.6			68	81	86		
LF-3	20.0			7.2			79.8			82	96	70		
TS-1	19.5			4.1	1.04		60.7			73	87	85		
TS-2	57.9			7.5			80.8			31	69	96		
TS-3	57.9			8.1			82.7			33	73	95		
TS-4	57.9			7.9			81.9			32	71	96		
<i>10.2 cm (4 inch) diameter Jameson cell</i>														
HVR-1	37.6			3.7			66.0			46	70	96		
HVR-2	37.6			4.3			74.1			52	80	94		
HVR-3	37.6			4.0			68.3			48	73	95		
HVR-4	37.6			5.3			51.8			31	46	96		
HVTS-1	20.0			3.8			45.0			61	73	89		
HVTS-2	45.0			4.7			48.3			8	13	99		
HVTS-3	45.0			5.1			59.5			27	46	97		
HVTS-4	45.0			7.8			58.7			27	45	95		

\* Two stage tests

**Table 22. Jameson Cell: Superficial Velocities and Mass Loadings**

Test Number	Mean Residence Time		Superficial Velocities				Mass Loadings					
			Feed		Wash Water		Air		Feed			
	min	s	cm/s	m/s	cm/s	m/s	cm/s	m/s	gm/min/cm <sup>2</sup>	tph/m <sup>2</sup>	gm/min/cm <sup>2</sup>	tph/m <sup>2</sup>
<i>15.2 cm (6 inch) diameter Jameson cell</i>												
VR-1	1.27	76.41	1.10	0.011	0.17	0.002	NA	NA	1.95	1.17	1.02	0.61
VR-2	1.16	69.47	1.10	0.011	0.17	0.002	NA	NA	1.95	1.17	1.19	0.71
VR-3	1.08	64.83	1.10	0.011	0.17	0.002	NA	NA	1.95	1.17	1.28	0.77
VR-4	1.04	62.52	1.10	0.011	0.17	0.002	NA	NA	1.95	1.17	1.34	0.81
VR-5	1.00	60.20	1.10	0.011	0.17	0.002	NA	NA	1.95	1.17	1.31	0.78
VR-6	1.00	60.20	1.10	0.011	0.17	0.002	NA	NA	1.95	1.17	1.19	0.72
VF-1	0.89	53.50	1.19	0.012	0.17	0.002	NA	NA	2.07	1.24	1.26	0.76
VF-2	1.11	66.34	1.19	0.012	0.17	0.002	NA	NA	2.07	1.24	1.36	0.81
VF-3	1.25	74.90	1.19	0.012	0.17	0.002	NA	NA	2.07	1.24	1.40	0.84
VF-4	1.36	81.32	1.19	0.012	0.17	0.002	NA	NA	2.07	1.24	1.44	0.86
VF-5	1.46	87.74	1.19	0.012	0.17	0.002	NA	NA	2.07	1.24	1.47	0.88
HT-1	1.33	79.70	1.37	0.014	0.17	0.002	NA	NA	2.39	1.44	1.74	1.04
HT-2	1.36	81.56	1.37	0.014	0.17	0.002	NA	NA	2.39	1.44	1.81	1.09
DT-1	1.58	94.94	1.10	0.011	0.17	0.002	NA	NA	1.78	1.07	1.20	0.72
DT-2	1.66	99.57	1.10	0.011	0.17	0.002	NA	NA	1.78	1.07	1.25	0.75
LF-1	1.62	97.25	1.10	0.011	0.17	0.002	NA	NA	1.94	1.16	1.27	0.76
LF-2	1.62	97.25	1.10	0.011	0.17	0.002	NA	NA	1.94	1.16	1.31	0.79
LF-3	1.78	106.51	1.10	0.011	0.17	0.002	NA	NA	1.94	1.16	1.59	0.96
TS-1	1.33	79.70	1.37	0.014	0.17	0.002	NA	NA	2.38	1.43	1.73	1.04
TS-2	1.56	93.42	1.14	0.011	0.17	0.002	NA	NA	0.62	0.37	0.19	0.12
TS-3	1.56	93.42	1.14	0.011	0.17	0.002	NA	NA	0.62	0.37	0.21	0.12
TS-4	1.56	93.42	1.14	0.011	0.17	0.002	NA	NA	0.62	0.37	0.20	0.12
<i>10.2 cm (4 inch) diameter Jameson cell</i>												
HVR-1	0.24	14.45	4.57	0.046	0.78	0.008	NA	NA	7.32	4.39	3.34	2.00
HVR-2	0.27	16.12	4.57	0.046	0.78	0.008	NA	NA	7.32	4.39	3.83	2.30
HVR-3	0.30	17.78	4.57	0.046	0.78	0.008	NA	NA	7.32	4.39	3.50	2.10
HVR-4	0.39	23.34	4.57	0.046	0.78	0.008	NA	NA	7.32	4.39	2.23	1.34
HVTS-1	0.24	14.45	4.57	0.046	0.78	0.008	NA	NA	7.43	4.46	4.50	2.70
HVTS-2	0.39	23.34	4.57	0.046	0.39	0.004	NA	NA	2.82	1.69	0.21	0.13
HVTS-3	0.32	19.45	4.57	0.046	0.39	0.004	NA	NA	2.82	1.69	0.75	0.45
HVTS-4	0.42	25.01	4.57	0.046	0.39	0.004	NA	NA	2.82	1.69	0.76	0.46

\* Two stage tests

The results of various series of tests are discussed in the following sections.

### 5.2.1 Parametric Studies: Discussion of Results

The main conclusions of the parametric tests are that higher recoveries are achieved by:

- Increasing reagent dosages
- Reducing the froth depth, or
- Reprocessing the tailings in a second stage.

These conclusions are graphically illustrated in Figure 3.




Figure 3. Parametric Test Results for the Jameson Cell





Figure 4. Jameson Cell: Energy Recovery vs. Clean Coal Ash

Test results showed that the grade/recovery curve for this case is very steep, i.e., a large increase in recovery can be realized with only a small increase in the product ash content. This is indicative of a high degree of liberation. It can be seen in Figure 4 that product ash variation from about 3.5% to 4.4% can mean a shift in energy recovery from 65% to about 85%. Figure 5 shows the grade/recovery relationship in terms of energy recovery and the total sulfur of the clean coal product obtained after processing in the Jameson cell. This relationship also shows a similar trend in that a fairly large shift in energy recovery can occur without much impact on product sulfur. The reason for this phenomenon is that most of the sulfur remaining in the froth is organic, which does not change with recovery.

The relationship of ash and sulfur rejection with energy recovery is shown in Figure 6 and Figure 7. It can be seen that at 85% energy recovery, ash and sulfur rejections are 85% and 30% respectively.



**Figure 5. Jameson Cell: Energy Recovery vs. Clean Coal Sulfur**




Figure 6. Jameson Cell: Energy Recovery vs. Ash Rejection




Figure 7. Jameson Cell: Energy Recovery vs. Sulfur Rejection

### 5.2.2 High-Capacity Tests

Although the parametric tests indicated that good process separation efficiency could be realized, the capacity achieved was perceived to be low, especially for first-stage operation in a two-stage flotation circuit. A series of eight high-capacity tests was conducted to determine whether the separation efficiency could be maintained at high mass loadings in the froth. A 4-inch diameter test cell was used for these tests as a means of conserving the coal sample.

All relevant data for these tests are shown in Table 20, Table 21, and Table 22. The tests are prefixed with "HV." The high-capacity tests were run at four times the flow rate per cross-sectional area of the original tests for a superficial feed velocity of 4.57 cm/s. The wash water was proportioned to the expected froth mass loading. A deeper froth bed was used to provide sufficient time for removal of entrained ash. Lower reagent dosages were used for economical operations. The results indicate that low product ash could still be achieved under these conditions. The final test using the original project coal produced a 3.8% ash product with 73% energy recovery. The froth mass loading was 4.5 gm/min/cm<sup>2</sup>, and showed that much higher flow rates are possible when this cell is used in a first-stage application.

### 5.2.3 Recommended Operating Conditions

Based on the parametric test work, the recommended conditions for the Jameson cell are given in Table 23 for single-stage operation and in Table 24 for the first-stage application in a two-stage process.

**Table 23. Jameson Cell: Recommended Operating Conditions, Single-Stage Operation**

Parameter	Value
Feed velocity	1.2 cm/s (2.3 ft/min)
Frother to fuel oil ratio	1:2 to 1:3
Total reagent dosage	2 kg/t (4 lb/ton)
Froth depth	15.2 cm (6 inch)
Wash water flow rate	0.20 cm/s (0.4 ft/min)

**Table 24. Jameson Cell: Recommended Operating Conditions, First-Stage Operation**

Parameter	Value
Feed velocity	4.5 cm/s (8.9 ft/min)
Frother to fuel oil ratio	1:2.6
Total reagent dosage	1.38 kg/t (2.75 lb/ton)
Froth depth	56 cm (22 inch)
Wash water flow rate	0.78 cm/s (1.6 ft/min)

### 5.3 Outokumpu Cell

A total of 15 tests were conducted on the Outokumpu HG tank cell at the Cyprus Emerald plant as part of the bench-scale test work. The test conditions and results are shown in Table 25 and Table 26. The scale-up parameters for this cell are shown in Table 27. This table provides the test conditions for the Outokumpu cell after conversion to superficial velocity and mass loading values for purposes of comparison. The feed superficial velocity varied between 1.0 and 2.2 cm/s with a corresponding feed mass loading of 1.02 to 2.28 tph/m<sup>2</sup> (1.7 to 3.8 gm/min/cm<sup>2</sup>). The froth loading was as high as 1.8 tph/m<sup>2</sup> (3 gm/min/cm<sup>2</sup>); however, poor process efficiency was obtained at this loading. A froth loading of 1.08 tph /m<sup>2</sup> (1.8 gm/min/cm<sup>2</sup>) achieved acceptable results.

A slipstream of the minus 150 $\mu$  (100-mesh) classifying cyclone overflow was diverted to the cell. Reagents were added to the feed slurry using metering pumps. The water-soluble frother was diluted 1:10 to improve metering accuracy.

The major parameters tested were:

- Reagent dosage
- Wash water
- Froth depth
- Feed slurry flow rate or residence time.

After preliminary testing, the superficial air velocity was set to approximately 2.3-2.4 cm/s (4.6-4.8 ft/min) in accordance with vendor recommendations. The cell was operated for a minimum of 900 seconds (15 minutes) between tests. Product and tailings samples were taken simultaneously, and feed samples were collected immediately following the collection of product samples. The Outokumpu cell behaved differently from the other three cells in terms of froth mobility which showed a great deal of sensitivity to oil. During the first three tests conducted using 0.54-0.72 kg/t (1.08-1.45 lb/t) of fuel oil, the froth was viscous and did not discharge easily. Product ash contents were between 9.2 and 10% with energy recoveries in the 73-79% range.

In order to alleviate this difficulty, tests 4 through 11 were carried out with no oil addition. This had the desired effect of reducing froth viscosity but also led to a considerable loss of energy

recovery. Though some improvement was noticed in the product ashes, they still remained well above the 5% target.

The last set of four tests used about half of the oil used in the first tests. This improved the energy recovery, but still gave unacceptable product ashes.

The relationship of energy recovery with product ash and sulfur contents is shown in Figure 8 and Figure 9. Figure 10 and Figure 11 show the effect of energy recovery on ash and sulfur rejections. It can be seen that the Outokumpu cell did not meet the project targets. However, it must be recognized that it was run using an actual plant slipstream and its performance may have been somewhat affected by the changing behavior of the plant feed.

**Table 25. Bench-Scale Test Conditions for Outokumpu HG Tank Cell**

Test Number	Feed Flow Rate		Solids %	Mass Flow Rate		Fuel Oil		Frother		Froth Depth		Wash Water $m^3/s \times 10^{-3}$		Air $m^3/s \times 10^{-3}$	
	gpm	$m^3/s \times 10^{-3}$		gm/min	Kg/s	lb/ton	Kg/t	lb/ton	Kg/t	in	m	gpm	$m^3/s \times 10^{-3}$	cfm	$m^3/s \times 10^{-3}$
1	11	0.68	2.85	1187	0.02	1.45	0.72	1.12	0.56	2.5	0.06	2.00	0.13	3.4	1.60
2	16	1.01	2.60	1575	0.03	1.09	0.55	0.84	0.42	2.5	0.06	1.00	0.06	3.5	1.65
3	16	1.01	2.62	1587	0.03	1.08	0.54	0.58	0.29	2.5	0.06	1.00	0.06	3.5	1.65
4	25	1.58	2.54	2404	0.04	0.00	0.00	0.96	0.48	5.0	0.13	0.00	0.00	3.5	1.65
5	25	1.58	2.59	2451	0.04	0.00	0.00	0.94	0.47	5.0	0.13	3.00	0.19	3.5	1.65
6	20	1.26	2.59	1961	0.03	0.00	0.00	1.18	0.59	5.0	0.13	3.25	0.21	3.6	1.70
7	20	1.26	2.63	1991	0.03	0.00	0.00	1.45	0.73	5.0	0.13	3.00	0.19	3.6	1.70
8	20	1.26	2.63	1991	0.03	0.00	0.00	1.45	0.73	5.0	0.13	0.00	0.00	3.6	1.70
9	20	1.26	3.01	2279	0.04	0.00	0.00	1.44	0.72	5.0	0.13	0.00	0.00	3.6	1.70
10	20	1.26	3.01	2279	0.04	0.00	0.00	1.44	0.72	5.3	0.13	3.00	0.19	3.6	1.70
11	25	1.58	3.01	2849	0.05	0.00	0.00	1.01	0.51	5.3	0.13	3.00	0.19	3.6	1.70
12	25	1.58	2.66	2517	0.04	0.51	0.26	1.15	0.57	5.0	0.13	3.00	0.19	3.6	1.70
13	25	1.58	2.66	2517	0.04	0.46	0.23	1.30	0.65	5.0	0.13	3.00	0.19	3.6	1.70
14	25	1.58	2.90	2744	0.05	0.52	0.26	1.19	0.60	5.0	0.13	3.00	0.19	3.6	1.70
15	25	1.58	2.90	2744	0.05	0.47	0.24	1.19	0.60	5.0	0.13	3.00	0.19	3.6	1.70

**Table 26. Bench-Scale Test Results for Outokumpu HG Tank Cell**

Test Number	Feed		Product		Tailings		Analysis			
	Ash %	Sulfur %	Ash %	Sulfur %	Ash %	Sulfur %	Yield, %	CMR, %	Ash Rej %	TSR %
1	30.4	1.15	9.2	1.33	57.4	1.06	56	73	83	35
2	31.2	1.13	9.6	1.29	61.6	1.05	58	77	82	33
3	30.0	1.13	10.0	1.28	61.9	0.98	62	79	79	30
4	17.4	1.26	11.8	1.21	26.9	1.29	63	67	58	40
5	19.5	1.19	9.6	1.14	31.4	1.18	55	61	73	48
6	19.5	1.19	7.3	1.20	37.5	1.24	59	69	78	40
7	19.9	1.23	8.4	1.22	34.0	1.25	55	63	77	45
8	19.9	1.23	14.4	1.27	31.6	1.34	68	73	51	30
9	19.4	1.33	8.5	1.27	32.9	1.40	56	63	76	47
10	19.4	1.33	7.5	1.22	33.7	1.29	55	63	79	50
11	19.4	1.33	14.0	1.25	36.4	1.26	76	81	45	29
12	20.5	1.25	16.0	1.32	38.7	1.32	80	85	37	15
13	20.5	1.25	12.5	1.30	39.9	1.32	71	78	57	26
14	20.6	1.27	11.3	1.23	41.3	1.22	69	77	62	33
15	20.6	1.27	7.9	1.21	37.4	1.17	57	66	78	46

**Table 27. Outokumpu HG Tank Cell: Superficial Velocities and Mass Loadings**

Test Number	Superficial Velocities								Mass Loadings			
	Mean Residence Time		Feed		Wash Water		Air		Feed		Froth	
	min	s	cm/s	m/s	cm/s	m/s	cm/s	m/s	gm/min/cm <sup>2</sup>	tph/m <sup>2</sup>	gm/min/cm <sup>2</sup>	tph/m <sup>2</sup>
1	1.31	78.67	0.96	0.010	0.18	0.002	2.23	0.022	1.65	0.99	0.92	0.55
2	0.90	54.09	1.40	0.014	0.09	0.001	2.29	0.023	2.18	1.31	1.28	0.77
3	0.90	54.09	1.40	0.014	0.09	0.001	2.29	0.023	2.20	1.32	1.36	0.81
4	0.58	34.62	2.19	0.022	0.00	0.000	2.29	0.023	3.33	2.00	2.09	1.25
5	0.58	34.62	2.19	0.022	0.26	0.003	2.29	0.023	3.40	2.04	1.86	1.12
6	0.72	43.27	1.75	0.018	0.28	0.003	2.36	0.024	2.72	1.63	1.62	0.97
7	0.72	43.27	1.75	0.018	0.26	0.003	2.36	0.024	2.76	1.66	1.52	0.91
8	0.72	43.27	1.75	0.018	0.00	0.000	2.36	0.024	2.76	1.66	1.88	1.13
9	0.72	43.27	1.75	0.018	0.00	0.000	2.36	0.024	3.16	1.90	1.76	1.05
10	0.72	43.27	1.75	0.018	0.26	0.003	2.36	0.024	3.16	1.90	1.73	1.04
11	0.58	34.62	2.19	0.022	0.26	0.003	2.36	0.024	3.95	2.37	3.01	1.80
12	0.58	34.62	2.19	0.022	0.26	0.003	2.36	0.024	3.49	2.09	2.81	1.68
13	0.58	34.62	2.19	0.022	0.26	0.003	2.36	0.024	3.49	2.09	2.47	1.48
14	0.58	34.6168	2.19	0.022	0.26	0.003	2.36	0.024	3.81	2.28	2.62	1.57
15	0.58	34.62	2.19	0.022	0.26	0.003	2.36	0.024	3.81	2.28	2.17	1.30

Figure 8 illustrates the grade/recovery curve for this cell under various conditions tested in terms of energy recovery and product ash, and Figure 9 illustrates the relationship between product sulfur and energy recovery achieved for this cell.





Figure 8. Outokumpu HG Tank Cell: Energy Recovery vs. Clean Coal Ash



**Figure 9. Outokumpu HG Tank Cell: Energy Recovery vs. Clean Coal Sulfur**

The relationship of energy recovery with ash and total sulfur rejection is shown in Figure 10 and Figure 11. These figures show that the cell did not achieve recoveries of 85% or higher, and its ash and sulfur rejections were correspondingly lower.




Figure 10. Outokumpu HG Tank Cell: Energy Recovery vs. Ash Rejection




Figure 11. Outokumpu HG Tank Cell: Energy Recovery vs. Sulfur Rejection

### 5.3.1 Recommended Operating Conditions

The recommended conditions for the Outokumpu cell assuming first-stage operation are presented in Table 28. Recommended single-stage operation would use the same conditions except that the residence time would be increased from 1 minute to 2.5 minutes.

**Table 28. Outokumpu Cell: Recommended First-Stage Operating Conditions**

Parameter	Value
Residence time	40-60 sec (0.67-1 min) per cell
Fuel oil	0.1-0.25 Kg/t (0.2-0.5 lb/ton)
Frother	0.5-0.65 Kg/t (1.0-1.3 lb/ton)
Froth depth	20.3 cm (8 inches)

### 5.4 Packed Column

Packed columns were tested and evaluated for use as single-stage units as well as second-stage units for cleaning the tailings. In order to assess their performance in these applications, the following test program was conducted:

- Twenty-nine parametric tests were carried out for the raw coal sample in a 3-in. diameter x 12-ft tall column (shown in Table 29 as A-1 through B-8-5).
- Four tests were conducted on the tailings in a 3-in. diameter x 12-ft tall column to evaluate its use as the second stage.

#### 5.4.1 Raw Coal Parametric Tests

A total of 29 tests with the plant feed coal were conducted (shown in Table 29 as A-1 through B-8-5). The major parameters tested were:

- Feed slurry flow rate or residence time
- Reagent dosage
- Wash water
- Froth depth
- Aeration rate.

The reagent ratio was set at two parts fuel oil to one part frother, and was maintained at this level throughout the program. The reagents were emulsified prior to the start of each test to enable higher flow rates through the reagent pump, thereby facilitating accurate monitoring of reagent addition. The tests were conducted as a series of four major test runs, using a fixed flow rate for each test run. A minimum of 1200 seconds (20 minutes) was allowed between test points to ensure steady-state operation. Product and tailings samples were collected simultaneously. The feed coal was sampled whenever the coal sample barrel was switched. The bench-scale tests conditions are shown in Table 29, and results are shown in Table 30. In

general, it can be seen that all tests, except one, achieved the ash target of 5.0% and at least half of them also provided energy recoveries higher than 85%. The scaleable parameters for these tests are shown in Table 31.

As can be seen from the data for tests B-8-1 through B-8-5, the packed column was operated at high mass loadings with a feed of 3.34 tph/m<sup>2</sup> (5.4 gm/min/cm<sup>2</sup>) and froth at 2.4 tph/m<sup>2</sup> (4.0 gm/min/cm<sup>2</sup>), and still achieved good process efficiency. The results in Table 30 for these tests show that a high energy recovery of 87% was achieved at a product ash content of 4.9%. These data compare quite favorably with those of tests B-6 through B-10 where the mass loading is 33% lower and the energy recoveries are only marginally higher.

The drop in recovery as the feed rate is increased cannot be directly accounted for by the test work. This drop could either be related to the corresponding reduction in slurry residence time (bubble attachment) or may be the result of froth dropback as the froth mass flow increases. However, over the test range considered, the maximum froth loading was not determined and the possibility exists of higher loadings than 2.4 tph/m<sup>2</sup> (4.0 gm/min/cm<sup>2</sup>), used in Test B-8-3, may be improved further without sacrificing either recovery or quality.

**Table 29. Bench-Scale Test Conditions for Packed Column**

Test Number	Feed Flow Rate		Solids		Mass Feed Rate		Fuel Oil		Frother		Froth Depth		Wash Water		Air	
	l/min	$m^3/s \times 10^{-3}$	%	gm/min	Kg/s	lb/ton	Kg/t	lb/ton	Kg/t	in	m	gpm	$m^3/s \times 10^{-3}$	cfm	$m^3/s \times 10^{-3}$	
<i>7.6 cm (3 inch) diameter x 366 cm (12 ft.) tall</i>																
A-1	2.71	0.045	3.00	81.30	0.0014	4.42	2.21	2.21	1.11	65	1.65	0.20	0.013	0.50	0.236	
A-2	2.71	0.045	3.00	81.30	0.0014	4.42	2.21	2.21	1.11	87	2.21	0.20	0.013	0.50	0.236	
A-3	2.71	0.045	3.00	81.30	0.0014	2.00	1.00	1.00	0.50	89	2.26	0.20	0.013	0.50	0.236	
A-3A	2.71	0.045	3.00	81.30	0.0014	2.00	1.00	1.00	0.50	92	2.34	0.20	0.013	0.50	0.236	
A-4	2.71	0.045	3.00	81.30	0.0014	2.00	1.00	1.00	0.50	71	1.80	0.20	0.013	0.50	0.236	
A-5	2.71	0.045	3.00	81.30	0.0014	2.00	1.00	1.00	0.50	62	1.57	0.20	0.013	1.00	0.472	
A-6	2.71	0.045	3.00	81.30	0.0014	2.00	1.00	0.75	0.38	84	2.13	0.20	0.013	0.45	0.212	
A-7	2.71	0.045	3.00	81.30	0.0014	1.50	0.75	0.75	0.38	31	0.79	0.20	0.013	0.45	0.212	
A-8	2.71	0.045	3.00	81.30	0.0014	1.50	0.75	0.75	0.38	70	1.78	0.20	0.013	0.55	0.260	
A-9	2.71	0.045	3.00	81.30	0.0014	1.50	0.75	1.40	0.70	36	0.91	0.30	0.019	0.50	0.236	
A-10	2.71	0.045	3.00	81.30	0.0014	2.80	1.40	1.40	0.70	32	0.81	0.30	0.019	0.50	0.236	
A-11	2.71	0.045	3.00	81.30	0.0014	2.80	1.40	1.40	0.70	33	0.84	0.20	0.013	0.50	0.236	
A-12	2.71	0.045	3.00	81.30	0.0014	2.80	1.40	1.40	0.70	45	1.14	0.00	0.000	0.50	0.236	
A-13	2.71	0.045	3.00	81.30	0.0014	2.80	1.40	1.40	0.70	84	2.13	0.00	0.000	0.60	0.283	
B-1	2.71	0.045	3.00	81.30	0.0014	2.80	1.40	1.40	0.70	48	1.22	0.30	0.019	0.55	0.260	
B-2	2.71	0.045	3.00	81.30	0.0014	2.80	1.40	1.40	0.70	42	1.07	0.30	0.019	0.80	0.378	
B-3	2.71	0.045	3.00	81.30	0.0014	2.80	1.40	1.40	0.70	27	0.69	0.20	0.013	0.80	0.378	
B-4	2.71	0.045	3.00	81.30	0.0014	2.80	1.40	1.40	0.70	14	0.36	0.20	0.013	0.60	0.283	
B-5	2.71	0.045	3.00	81.30	0.0014	2.80	1.40	1.40	0.70	33	0.84	0.20	0.013	0.50	0.236	
B-6	5.42	0.091	3.00	162.60	0.0027	2.80	1.40	1.40	0.70	14	0.36	0.20	0.013	0.50	0.236	
B-7	5.42	0.091	3.00	162.60	0.0027	2.80	1.40	1.40	0.70	29	0.74	0.25	0.016	0.50	0.236	
B-8	5.42	0.091	3.00	162.60	0.0027	2.80	1.40	1.40	0.70	54	1.37	0.20	0.013	0.50	0.236	
B-9	5.42	0.091	3.00	162.60	0.0027	2.80	1.40	1.40	0.70	70	1.78	0.25	0.016	0.50	0.236	
B-10	5.42	0.091	3.00	162.60	0.0027	2.80	1.40	1.40	0.70	66	1.68	0.20	0.013	0.50	0.236	
B-8-1	8.20	0.137	3.00	246.00	0.0041	1.85	0.93	0.92	0.46	15	0.38	0.20	0.013	0.55	0.260	
B-8-2	8.20	0.137	3.00	246.00	0.0041	1.85	0.93	0.92	0.46	68	1.73	0.20	0.013	0.40	0.189	
B-8-3	8.20	0.137	3.00	246.00	0.0041	1.85	0.93	0.92	0.46	24	0.61	0.20	0.013	0.40	0.189	
B-8-4	8.20	0.137	3.00	246.00	0.0041	1.85	0.93	0.92	0.46	55	1.40	0.20	0.013	0.40	0.189	
B-8-5	8.20	0.137	3.00	246.00	0.0041	1.85	0.93	0.92	0.46	75	1.91	0.20	0.013	0.40	0.189	

**Table 30. Bench-Scale Test Results for Packed Column**

Test Number	Feed		Product		Tailings		Analysis			
	Ash %	Sulfur %	Ash %	Sulfur %	Ash %	Sulfur %	Yield %	CMR %	Ash Rej %	TSR %
<i>7.6 cm (3 inch) diameter x 366 cm (12 ft.) tall</i>										
A-1	20.6	1.12	3.2	1.00	64.3	1.34	72	87	89	36
A-2	20.6	1.12	3.1	0.99	63.5	1.41	71	87	89	37
A-3	20.2	1.12	1.8	0.95	23.2	1.16	14	17	99	88
A-3A	20.2	1.12	4.1	1.03	63.1	1.34	73	87	85	33
A-4	20.2	1.12	2.5	0.98	39.9	1.30	53	64	94	54
A-5	20.2	1.12	4.0	0.99	63.9	1.39	73	88	86	36
A-6	21.0	1.10	4.4	1.03	56.6	1.27	68	83	86	36
A-7	21.0	1.10	2.9	0.99	46.2	1.27	58	72	92	48
A-8	21.0	1.10	2.7	0.98	40.2	1.22	51	63	94	54
A-9	20.6	1.11	3.8	1.02	65.8	1.26	73	88	87	33
A-10	20.6	1.11	3.9	1.03	65.3	1.33	73	88	86	32
A-11	20.6	1.11	4.0	1.03	66.3	1.28	73	89	86	32
A-12	20.6	1.11	4.9	1.03	67.4	1.28	75	90	82	31
A-13	20.6	1.11	4.6	1.01	70.1	1.37	75	91	83	31
B-1	20.0	1.12	3.5	1.02	62.8	1.34	72	87	87	34
B-2	20.0	1.12	3.9	1.04	66.5	1.33	74	89	86	31
B-3	20.0	1.12	3.7	1.03	69.1	1.32	75	90	86	31
B-4	20.0	1.12	4.9	1.07	70.4	1.30	77	91	81	27
B-5	20.0	1.12	4.1	1.04	63.6	1.35	73	88	85	32
B-6	19.6	1.10	5.2	1.04	62.2	1.26	75	88	80	29
B-7	19.6	1.10	4.3	1.02	58.8	1.24	72	86	84	33
B-8	19.6	1.10	3.8	1.01	54.9	1.30	69	83	86	36
B-9	19.6	1.10	3.1	0.99	40.5	1.27	56	67	91	50
B-10	19.6	1.10	3.4	0.99	55.1	1.36	69	83	88	38
B-8-1	19.0	1.13	4.1	1.02	49.5	1.35	67	79	86	39
B-8-2	19.0	1.13	3.1	0.98	45.2	1.31	62	74	90	46
B-8-3	19.0	1.13	4.9	1.04	59.8	1.38	74	87	81	32
B-8-4	19.0	1.13	3.5	1.01	51.4	1.40	68	81	88	40
B-8-5	19.0	1.13	2.8	0.98	22.0	1.16	15	19	98	87

**Table 31. Packed Column: Superficial Velocities and Mass Loadings (Raw Coal)**

Test Number	Mean Residence Time		Superficial Velocities				Mass Loadings					
			Feed		Wash Water		Air		Feed			
	min	s	cm/s	m/s	cm/s	m/s	cm/s	m/s	gm/min/cm <sup>2</sup>	tph/m <sup>2</sup>	gm/min/cm <sup>2</sup>	tph/m <sup>2</sup>
<i>7.6 cm (3 inch) diameter x 366 cm (12 ft.) tall</i>												
A-1	3.37	202.50	0.99	0.0099	0.28	0.0028	5.18	0.0518	1.78	1.07	1.28	0.77
A-2	2.44	146.11	0.99	0.0099	0.28	0.0028	5.18	0.0518	1.78	1.07	1.27	0.76
A-3	2.35	140.98	0.99	0.0099	0.28	0.0028	5.18	0.0518	1.78	1.07	0.25	0.15
A-3A	2.22	133.29	0.99	0.0099	0.28	0.0028	5.18	0.0518	1.78	1.07	1.30	0.78
A-4	3.12	187.12	0.99	0.0099	0.28	0.0028	5.18	0.0518	1.78	1.07	0.94	0.56
A-5	3.50	210.19	0.99	0.0099	0.28	0.0028	10.36	0.1036	1.78	1.07	1.30	0.78
A-6	2.56	153.80	0.99	0.0099	0.28	0.0028	4.66	0.0466	1.78	1.07	1.22	0.73
A-7	4.83	289.65	0.99	0.0099	0.28	0.0028	4.66	0.0466	1.78	1.07	1.04	0.62
A-8	3.16	189.68	0.99	0.0099	0.28	0.0028	5.70	0.0570	1.78	1.07	0.91	0.55
A-9	4.61	276.83	0.99	0.0099	0.42	0.0042	5.18	0.0518	1.78	1.07	1.30	0.78
A-10	4.78	287.09	0.99	0.0099	0.42	0.0042	5.18	0.0518	1.78	1.07	1.30	0.78
A-11	4.74	284.52	0.99	0.0099	0.28	0.0028	5.18	0.0518	1.78	1.07	1.31	0.78
A-12	4.23	253.76	0.99	0.0099	0.00	0.0000	5.18	0.0518	1.78	1.07	1.33	0.80
A-13	2.56	153.80	0.99	0.0099	0.00	0.0000	6.21	0.0621	1.78	1.07	1.35	0.81
B-1	4.10	246.07	0.99	0.0099	0.42	0.0042	5.70	0.0570	1.78	1.07	1.29	0.77
B-2	4.36	261.45	0.99	0.0099	0.42	0.0042	8.28	0.0828	1.78	1.07	1.32	0.79
B-3	5.00	299.90	0.99	0.0099	0.28	0.0028	8.28	0.0828	1.78	1.07	1.34	0.80
B-4	5.55	333.23	0.99	0.0099	0.28	0.0028	6.21	0.0621	1.78	1.07	1.37	0.82
B-5	4.74	284.52	0.99	0.0099	0.28	0.0028	5.18	0.0518	1.78	1.07	1.31	0.78
B-6	2.78	166.61	1.98	0.0198	0.28	0.0028	5.18	0.0518	3.57	2.14	2.67	1.60
B-7	2.46	147.39	1.98	0.0198	0.35	0.0035	5.18	0.0518	3.57	2.14	2.57	1.54
B-8	1.92	115.35	1.98	0.0198	0.28	0.0028	5.18	0.0518	3.57	2.14	2.47	1.48
B-9	1.58	94.84	1.98	0.0198	0.35	0.0035	5.18	0.0518	3.57	2.14	2.00	1.20
B-10	1.67	99.97	1.98	0.0198	0.28	0.0028	5.18	0.0518	3.57	2.14	2.45	1.47
B-8-1	1.82	109.28	3.00	0.0300	0.28	0.0028	5.70	0.0570	5.40	3.24	3.62	2.17
B-8-2	1.07	64.38	3.00	0.0300	0.28	0.0028	4.14	0.0414	5.40	3.24	3.35	2.01
B-8-3	1.69	101.66	3.00	0.0300	0.28	0.0028	4.14	0.0414	5.40	3.24	4.01	2.40
B-8-4	1.26	75.39	3.00	0.0300	0.28	0.0028	4.14	0.0414	5.40	3.24	3.65	2.19
B-8-5	0.97	58.45	3.00	0.0300	0.28	0.0028	4.14	0.0414	5.40	3.24	0.83	0.50

Figure 12 illustrates the major trends observed in the raw coal tests in the packed column in terms of the relationship between energy recovery and ash content of the product coal. Along similar lines, Figure 13 illustrates the performance of the cell in terms of the sulfur content of the product coal. The relationship of energy recovery to ash and sulfur rejection is also shown in Figure 14 and Figure 15. As can be seen in Figure 15, total sulfur rejections of about 35% can be obtained at energy recoveries of 85%.




Figure 12. Packed Column: Energy Recovery vs. Clean Coal Ash




Figure 13. Packed Column: Energy Recovery vs. Clean Coal Sulfur




Figure 14. Packed Column: Energy Recovery vs. Ash Rejection




Figure 15. Packed Column: Energy Recovery vs. Sulfur Rejection

### 5.4.2 Second-Stage Test Work

Tests were conducted on a tailings sample at 1.4% solids, again using the 12-ft tall column. The conditions and results are included in Table 32 and Table 33. The operating conditions reduced to standard scaleable parameters such as superficial velocities, mass loading, and residence times are shown in Table 34. The tests were run at a feed velocity of 3 cm/s, which corresponds to a 2-minute residence time, and achieved froth loadings of up to 0.68 tph/m<sup>2</sup>. Table 34 presents the analysis of the test results. At these conditions, the tailings ash was about 75% and energy recovery was 74-76%. The clean coal ash content ranged between 6.5 and 10%, indicating good separation efficiency for second-stage operations.

Figure 16 and Figure 17 illustrate the overall performance of this cell in terms of the relationship between energy recovery and clean coal ash, and energy recovery and product sulfur respectively. Figure 18 and Figure 19 depict the relationship between energy recovery and ash rejection and sulfur rejection, respectively.

**Table 32. Packed Column Test Conditions for Tailings Sample**

Test Number	Feed Rate		Solids %	Feed Rate		Fuel Oil		Frother		Froth Depth		Wash Water		Air	
	l/min	m <sup>3</sup> /s x 10 <sup>-3</sup>		gm/min	Kg/s	lb/ton	Kg/t	lb/ton	Kg/t	in	m	gpm	x 10 <sup>-3</sup>	cfm	x 10 <sup>-3</sup>
T-1	8.11	0.135	1.40	113.54	0.0019	2.80	1.40	1.40	0.70	5	0.13	0.20	0.013	0.40	0.189
T-2	8.11	0.135	1.40	113.54	0.0019	2.80	1.40	1.40	0.70	5	0.13	0.20	0.013	0.40	0.189
T-3	8.11	0.135	1.40	113.54	0.0019	2.80	1.40	1.40	0.70	5	0.13	0.20	0.013	0.40	0.189
T-4	8.11	0.135	1.40	113.54	0.0019	2.80	1.40	1.40	0.70	12	0.30	0.20	0.013	0.40	0.189

**Table 33. Packed Column Test Results for Tailings Sample**

Test Number	Feed			Product			Tailings			Analysis				
	Ash %	Sulfur %	Pyr. S %	Ash %	Sulfur %	Pyr. S %	Ash %	Sulfur %	Pyr. S %	Yield %	CMR %	Ash Rej %	TSR %	PSR %
T-1	46.1	2.10		7.0	1.98		75.3	2.17		43	74	94	60	0
T-2	46.1	2.10		10.4	2.25		75.5	2.01		45	75	90	52	0
T-3	46.1	2.10	1.67	6.5	1.88	0.80	75.5	2.14	1.80	43	74	94	62	80
T-4	46.1	2.10		9.3	2.12		76.7	2.12		45	76	91	54	0

**Table 34. Packed Column: Superficial Velocities and Mass Loadings**

Test Number	Superficial Velocities								Mass Loadings					
	Mean Residence Time			Feed		Wash Water		Air		Feed		Froth		
	min	s	cm/s	m/s	cm/s	m/s	cm/s	m/s	cm <sup>2</sup>	m <sup>2</sup>	cm <sup>2</sup>	m <sup>2</sup>	cm <sup>2</sup>	m <sup>2</sup>
T-1	1.98	119.06	2.97	0.0297	0.28	0.0028	4.14	0.0414	2.49	1.49	1.06	0.64		
T-2	1.98	119.06	2.97	0.0297	0.28	0.0028	4.14	0.0414	2.49	1.49	1.12	0.67		
T-3	1.98	119.06	2.97	0.0297	0.28	0.0028	4.14	0.0414	2.49	1.49	1.06	0.64		
T-4	1.88	113.06	2.97	0.0297	0.28	0.0028	4.14	0.0414	2.49	1.49	1.13	0.68		




Figure 16. Packed Column: Energy Recovery vs. Product Ash  
(Tailings Sample)




Figure 18. Packed Column: Energy Recovery vs. Ash Rejection  
(Tailings Sample)




Figure 17. Packed Column: Energy Recovery vs. Clean Coal Sulfur  
(Tailings Sample)




Figure 19. Packed Column: Energy Recovery vs. Sulfur Rejection  
(Tailings Sample)

Figure 17. Packed Column: Energy Recovery vs. Clean Coal Sulfur  
(Tailings Sample)

### 5.4.3 Recommended Operating Conditions

The recommended conditions for packed column operation are given in Table 35 for single-stage operation and Table 36 for its use as a second-stage unit.

**Table 35. Packed Column: Recommended Single-Stage Operating Conditions**

Parameter	Value
Feed flow rate	3 cm/s (6 ft/min)
Residence time	150 seconds (2.5 min)
Froth depth	35.5 cm (14 inch) minimum
Fuel oil	1.0 kg/t (2 lb/ton)
Frother	0.6 kg/t (1.4 lb/ton) or 10 ppm
Aeration rate	4-5 cm/s (8-10 ft/min)
Wash water flow rate	0.15 cm/s (0.3 ft/min)

**Table 36. Packed Column: Recommended Second-Stage Operating Conditions<sup>(1)</sup>**

Parameter	Value
Feed flow rate	2-3 cm/s (4-6 ft/min)
Residence time	120-180 seconds (2-3 min)
Froth depth	25 cm (12 inch) minimum
Fuel oil	1.0 kg/t (2 lb/ton)
Frother	0.5 kg/t (1 lb/ton)
Aeration rate	6 cm/s (12 ft/min)
Wash water flow rate	0.28 cm/s (0.6 ft/min)

(1) Assumes 1.4% solids in feed

### 5.5 Open Column

A 2.5-in. diameter x 18-ft tall column was used for these tests. A total of 27 tests were conducted on the raw coal sample to determine the effects of the major operating variables. The test conditions for these tests are given in Table 37 and their results are given in Table 38. The scaleable parameters are given in Table 39.

The breakdown of these tests is as follows:

- Tests 1-9 were conducted to determine the reagent dosages.
- Tests 10-20 were conducted to determine the effects of feed rate, wash water addition, and aeration rates.
- Tests 21-23 were conducted to determine the effects of residence time.
- Tests 24-27 were conducted to determine the effects of high volumetric flow rates.

In all cases, the test procedure consisted of the following steps. A large batch of feed slurry was agitated and the solids content measured. Fuel oil was then added to the batch to achieve the desired reagent dosage prior to the start of the testing. A stirred 5-gallon tank was continuously fed slurry from this large batch. Frother was added to the stirred 5-gallon tank at a rate proportional to the column feed flow rate as a means of conditioning the coal before injecting it into the column. This approach was used to ensure that the frother maintained the same contact time with the coal for all tests. Frother solution equivalent to 10 ppm was also added into the air sparger water and used as wash water to ensure proper bubble size.

A minimum of 20 minutes was allowed between test points to achieve steady-state operation. Product and tailings samples were collected simultaneously. The mass flows of product and tailings were measured and used to reconstruct the feed coal quality. The results of the tests are discussed in the following sections.

**Table 37. Bench-Scale Test Conditions for Open Column (Raw Coal)**

Test Number	Feed Flow Rate		Solids %	Mass Flow Rate		Fuel Oil		Frother		Froth Depth		Wash Water		Air	
	ml/min	m <sup>3</sup> /s x 10 <sup>-3</sup>		gm/min	Kg/s	lb/ton	Kg/t	lb/ton	Kg/t	in	m	ml/min	m <sup>3</sup> /s	l/min	m <sup>3</sup> /s x 10 <sup>-3</sup>
1	1500	0.03	6.00	93.86	0.0016	1.00	0.50	0.59	0.30	40	1.02	380	6.35	3.00	0.050
2	1500	0.03	6.00	93.86	0.0016	1.00	0.50	0.59	0.30	40	1.02	380	6.35	3.00	0.050
4	1500	0.03	2.60	39.72	0.0007	1.00	0.50	0.50	0.25	24	0.61	380	6.35	3.00	0.050
5	1500	0.03	2.60	39.72	0.0007	1.75	0.88	0.50	0.25	24	0.61	380	6.35	3.00	0.050
6	1500	0.03	2.60	39.72	0.0007	2.00	1.00	0.50	0.25	24	0.61	380	6.35	3.00	0.050
7	1500	0.03	2.60	39.72	0.0007	2.00	1.00	1.14	0.57	24	0.61	380	6.35	3.00	0.050
8	1500	0.03	2.60	39.72	0.0007	1.75	0.88	1.14	0.57	24	0.61	380	6.35	3.00	0.050
9	1500	0.03	2.60	39.72	0.0007	1.25	0.63	1.14	0.57	24	0.61	380	6.35	3.00	0.050
10	1500	0.03	6.70	102.64	0.0017	1.04	0.52	0.41	0.21	30	0.76	570	9.52	4.20	0.070
11	1530	0.03	4.63	71.85	0.0012	1.04	0.52	0.59	0.30	30	0.76	570	9.52	1.90	0.032
12	1521	0.03	4.36	67.12	0.0011	1.04	0.52	0.52	0.26	30	0.76	190	3.17	4.18	0.070
13	1521	0.03	1.91	29.22	0.0005	1.04	0.52	1.20	0.60	30	0.76	190	3.17	1.90	0.032
14	2450	0.04	3.57	88.31	0.0015	1.04	0.52	0.53	0.27	30	0.76	380	6.35	3.04	0.051
15	2450	0.04	4.10	101.61	0.0017	1.04	0.52	0.46	0.23	30	0.76	380	6.35	3.04	0.051
16	3421	0.06	2.39	82.37	0.0014	1.04	0.52	0.62	0.31	30	0.76	190	3.17	1.90	0.032
17	3421	0.06	2.04	70.25	0.0012	1.04	0.52	0.73	0.37	30	0.76	190	3.17	4.18	0.070
18	3421	0.06	1.68	57.74	0.0010	1.04	0.52	1.02	0.51	30	0.76	570	9.52	4.18	0.070
19	3421	0.06	1.73	59.59	0.0010	1.04	0.52	0.99	0.50	30	0.76	570	9.52	1.90	0.032
20	2471	0.04	1.20	29.67	0.0005	1.04	0.52	1.58	0.79	30	0.76	380	6.35	3.04	0.051
21	1800	0.03	2.44	44.22	0.0007	2.00	1.00	1.11	0.55	30	0.76	380	6.35	4.50	0.075
22	1800	0.03	2.69	48.76	0.0008	2.00	1.00	1.00	0.50	30	0.76	380	6.35	4.50	0.075
23	1800	0.03	3.43	62.42	0.0010	2.00	1.00	0.79	0.39	30	0.76	380	6.35	4.50	0.075
24	3000	0.05	1.24	37.40	0.0006	2.00	1.00	1.53	0.76	30	0.76	380	6.35	4.20	0.070
25	5000	0.08	1.48	74.20	0.0012	2.00	1.00	1.05	0.53	30	0.76	380	6.35	4.20	0.070
26	7000	0.12	1.35	95.00	0.0016	2.00	1.00	1.05	0.52	30	0.76	380	6.35	4.20	0.070
27	8560	0.14	1.12	96.60	0.0016	2.00	1.00	1.25	0.62	30	0.76	380	6.35	4.20	0.070

**Table 38. Bench-Scale Test Results for Open Column (Raw Coal)**

Test Number	Feed			Product			Tailings			Analysis			
	Ash %	Sulfur %	Pyr. S. %	Ash %	Sulfur %	Pyr. S. %	Ash %	Sulfur %	Pyr. S. %	Yield, %	CMR, %	Ash Rej %	TSR %
1	20.4			2.0			29.8			34	42	97	
2	21.4			3.9			30.8			35	43	94	
4	21.0			3.1			31.8			38	46	95	
5	19.8			3.8			36.3			51	61	90	
6	19.7			3.8			36.1			51	61	90	
7	19.5			4.1			59.3			72	86	85	
8	18.9			3.8			50.3			68	80	86	
9	20.2			3.6			48.4			63	76	89	
10	20.2	1.05		3.1	0.94		25.2	1.06		22	27	97	80
11	20.6	1.05		2.9	0.94		23.7	1.29		15	18	98	87
12	21.3	1.04		3.4	1.00		25.8	0.95		20	24	97	81
13	22.0	1.07		3.5	0.92		29.2	1.09		28	35	96	76
14	20.5	1.02		3.3	1.08		25.2	1.55		21	26	97	77
15	19.6	1.01		3.2	0.92		25.0	1.00		25	30	96	77
16	21.3	1.02		3.6	0.83		21.7	1.01		2	2	100	99
17	21.3	0.97		4.4	0.92		50.3	1.37		63	77	87	40
18	21.6	0.98		3.6	0.93		50.4	1.26		62	76	90	44
19	21.3	1.07		3.8	0.97		37.6	1.12		48	59	91	56
20	21.5	1.04	0.49	4.0	0.94	0.24	59.3	1.19	1.01	68	84	87	38
21	19.5	1.06		8.2	0.97		83.4	1.18		85	97	64	22
22	19.1	1.01		5.3	0.99		80.9	1.13		82	96	77	20
23	19.7	1.06	0.47	5.3	1.00	0.26	74.3	1.35	1.46	79	93	79	25
24	19.1			4.2			50.5			68	80	85	
25	19.9			3.8			51.5			66	80	87	
26	18.5			3.6			46.7			65	77	87	
27	18.6			4.2			53.8			71	84	84	

measured feed ashes

**Table 39. Open Column: Superficial Velocities and Mass Loadings (Raw Coal)**

Test Number	Mean Residence Time		Superficial Velocities						Mass Loadings					
	min	s	cm/s	m/s	cm/s	m/s	cm/s	m/s	Feed	gm/min/cm <sup>2</sup>	tph/m <sup>2</sup>	Froth	gm/min/cm <sup>2</sup>	tph/m <sup>2</sup>
1	9.43	566.01	0.79	0.0079	0.20	0.0020	1.58	0.0158	2.97	1.78	1.01	0.60		
2	9.43	566.01	0.79	0.0079	0.20	0.0020	1.58	0.0158	2.97	1.78	1.04	0.62		
4	10.29	617.46	0.79	0.0079	0.20	0.0020	1.58	0.0158	1.25	0.75	0.47	0.28		
5	10.29	617.46	0.79	0.0079	0.20	0.0020	1.58	0.0158	1.25	0.75	0.64	0.38		
6	10.29	617.46	0.79	0.0079	0.20	0.0020	1.58	0.0158	1.25	0.75	0.64	0.38		
7	10.29	617.46	0.79	0.0079	0.20	0.0020	1.58	0.0158	1.25	0.75	0.91	0.54		
8	10.29	617.46	0.79	0.0079	0.20	0.0020	1.58	0.0158	1.25	0.75	0.85	0.51		
9	10.29	617.46	0.79	0.0079	0.20	0.0020	1.58	0.0158	1.25	0.75	0.79	0.47		
10	9.97	598.17	0.79	0.0079	0.30	0.0030	2.21	0.0221	3.24	1.95	0.73	0.44		
11	9.77	586.44	0.81	0.0081	0.30	0.0030	1.00	0.0100	2.27	1.36	0.34	0.20		
12	9.83	589.91	0.80	0.0080	0.10	0.0010	2.20	0.0220	2.12	1.27	0.42	0.25		
13	9.83	589.91	0.80	0.0080	0.10	0.0010	1.00	0.0100	0.92	0.55	0.26	0.15		
14	6.10	366.23	1.29	0.0129	0.20	0.0020	1.60	0.0160	2.79	1.67	0.60	0.36		
15	6.10	366.23	1.29	0.0129	0.20	0.0020	1.60	0.0160	3.21	1.93	0.80	0.48		
16	4.37	262.28	1.80	0.0180	0.10	0.0010	1.00	0.0100	2.60	1.56	0.05	0.03		
17	4.37	262.28	1.80	0.0180	0.10	0.0010	2.20	0.0220	2.22	1.33	1.40	0.84		
18	4.37	262.28	1.80	0.0180	0.30	0.0030	2.20	0.0220	1.82	1.09	1.12	0.67		
19	4.37	262.28	1.80	0.0180	0.30	0.0030	1.00	0.0100	1.88	1.13	0.91	0.55		
20	6.05	363.11	1.30	0.0130	0.20	0.0020	1.60	0.0160	0.94	0.56	0.64	0.39		
21	8.31	498.47	0.95	0.0095	0.20	0.0020	2.37	0.0237	1.40	0.84	1.19	0.71		
22	5.09	305.52	0.95	0.0095	0.20	0.0020	2.37	0.0237	1.54	0.92	1.26	0.76		
23	1.88	112.56	0.95	0.0095	0.20	0.0020	2.37	0.0237	1.97	1.18	1.56	0.94		
24	4.98	299.08	1.58	0.0158	0.20	0.0020	2.21	0.0221	1.18	0.71	0.80	0.48		
25	2.99	179.45	2.63	0.0263	0.20	0.0020	2.21	0.0221	2.34	1.41	1.55	0.93		
26	2.14	128.18	3.69	0.0369	0.20	0.0020	2.21	0.0221	3.00	1.80	1.96	1.18		
27	1.75	104.82	4.51	0.0451	0.20	0.0020	2.21	0.0221	3.05	1.83	2.17	1.30		

### **5.5.1 Reagent Dosage Tests**

During these tests, the volumetric feed rate was maintained constant, though some variations in percent solids were observed. The frother dosage was varied between 0.25 kg/ton to 0.57 kg/ton (0.5 lb/ton and 1.14 lb/ton). The results of tests 7 and 8 indicate that to achieve an acceptable performance the frother and fuel oil dosages had to be 0.5 kg/ton (1 lb/ton) and 1 kg/ton (2 lb/ton) respectively. These tests showed energy recoveries of 80% and 86% at ash contents of 3.8% and 4.1% respectively.

### **5.5.2 Factorial Tests**

After conducting the dosage tests, a three-factor, two-level series of tests was completed using the feed rate, wash water, and aeration rate as variables (tests 10-20). The reagent dosage was set at 1 kg/t (2 lb/ton) fuel oil and 0.5 kg/t (1 lb/ton) frother for these tests. Due to an error during sampling of the feed slurry its solids content was determined to be 1.7%, and the fuel oil was added accordingly. However, the actual percent solids was 3.1%, and the amount of reagents calculated on the basis of the low feed solids turned out to be insufficient and resulted in poor recoveries and performance.

Variations in the feed solids concentration were also detected during the testing based on the measured mass flow rates of the product and tailings samples. Fluctuations in the feed solids concentration measurements were possibly the result of non-steady-state recirculation of the slurry in the large batch tank, where stratification of the solids may have occurred.

The results of the parametric tests are shown in Figure 20 as a function of feed mass loading (equivalent to feed percent solids). The results indicate that energy recovery was dependent on mass loading, with high loadings leading to low recoveries. Increasing the air flow rates improved recovery over the range tested (1, 1.6, and 2.2 cm/s). The conclusions from these tests are:

- High air flow rates are required for maximum recovery
- Wash water flow rate had little effect on product quality over the range tested (0.1 to 0.3 cm/s)
- Higher levels of fuel oil are required to increase recovery




Figure 20. Open Column Parametric Test Results

### 5.5.3 Residence Time Tests

Prior to conducting these tests, the slurry mixing and reagent addition procedure were revised in order to ensure a more consistent performance. A constant feed rate was set for these tests and the residence time was varied by removing sections of the column. The column heights used were 5.67 m (17 ft), 3.67 (11 ft), and 1.67 (5 ft), respectively. The slurry residence time corresponding to the three column heights was 8.3, 5.1, and 1.9 minutes for tests number 21, 22, and 23, respectively in Table 37 and Table 38. The tests were run at a maximum aeration rate of 2.4 cm/s, using 1 Kg/t (2 lb/ton) fuel oil and 0.5 Kg/t (1 lb/ton) frother. The feed velocity was set at approximately 1 cm/sec. The higher fuel oil dosage improved operations considerably. The process efficiency was very good, and equaled that of the Jameson cell and packed column. The maximum froth loading achieved was 0.93 tph/m<sup>2</sup> (1.55 gm/min/cm<sup>2</sup>). Even a residence time of 1.9 minutes (test 23) resulted in high energy recovery of 93%. The product ash for this test was 5.33%, which is somewhat higher than the target value of 5% but is consistent with the correspondingly high energy recovery and indicates that a relatively efficient separation was achieved.

#### **5.5.4 High Volumetric Flow Rate Tests**

The final series of tests was run to evaluate the effects of operating the open column at high feed velocities. Raw coal samples were diluted to 1.4% solids and were tested in the open column after reassembling it to its full height of 18 ft. The flow rates for these tests (24 through 27 in Table 37 and Table 38) ranged from 1.6 to 4.5 cm/s with corresponding residence times of 5 minutes to 1.75 minutes. Frother addition was set to a minimal level of 0.35 to 0.5 kg/t (0.7 to 1.0 lb/t) or a concentration of 6-7 ppm. The resulting performance showed that while a clean product with low ash was made, energy recoveries were not as high as in the previous tests. Were this cell to be used as a first-stage unit, this performance would be acceptable. However, as a single-stage device this performance needs to be better.

#### **5.5.5 Summary of Raw Coal Tests**

The raw coal tests results have been summarized in four graphs. Figure 21 presents the trends in clean coal ash vs. recovery. Along similar lines, the grade/recovery curve for the open column cell was determined in terms of the product sulfur content, as shown in Figure 22. Figure 23 and Figure 24 illustrate the overall performance of this cell in terms of the relationship between energy recovery and ash rejection, and energy recovery and sulfur rejection, respectively. As shown in Figure 24, total sulfur rejections of between 30 and 35% were achieved at an energy recovery of 85%.




Figure 21. Open Column: Energy Recovery vs. Clean Coal Ash




Figure 22. Open Column: Energy Recovery vs. Clean Coal Sulfur




Figure 23. Open Column: Energy Recovery vs. Ash Rejection




Figure 24. Open Column: Energy Recovery vs. Sulfur Rejection

### 5.5.6 Second-Stage Tests

Six tailings sample tests were run (tests 28-33) using three levels of feed flow rate and two levels of aeration rate. The tailings feed tests were run at a relatively high feed solids content of 2.7-3% solids. The test conditions, results, and analysis are given in Table 40 and Table 41. The scaleable parameters are shown in Table 42.

The tailings tests demonstrate that a high-ash tailings could be achieved, in the range of 80 to 85%, with good separation at feed rates of up to 1.84 cm/s.

**Table 40. Open Column Test Conditions for Tailings Sample**

Test Number	Feed Flow Rate		Solids %	Mass Flow Rate		Fuel Oil		Frother		Froth Depth		Wash Water		Air $\text{m}^3/\text{s}$	
	ml/min	$\text{m}^3/\text{s} \times 10^3$		gm/min	Kg/s	lb/ton	Kg/t	lb/ton	Kg/t	in	m	ml/min	$\text{m}^3/\text{s}$	l/min	$\times 10^3$
28	1500	0.03	2.62	39.60	0.0007	2.00	1.00	1.14	0.57	30	0.76	380	6.35	3.40	0.057
29	2500	0.04	2.59	65.20	0.0011	2.00	1.00	0.89	0.45	30	0.76	380	6.35	3.40	0.057
30	3500	0.06	2.59	91.40	0.0015	2.00	1.00	0.78	0.39	30	0.76	380	6.35	3.40	0.057
31	3500	0.06	2.59	91.40	0.0015	2.00	1.00	0.78	0.39	30	0.76	380	6.35	4.70	0.078
32	2500	0.04	2.59	65.20	0.0011	2.00	1.00	0.89	0.45	30	0.76	380	6.35	4.70	0.078
33	1500	0.03	2.61	39.40	0.0007	2.00	1.00	1.14	0.57	30	0.76	380	6.35	4.70	0.078

**Table 41. Open Column Test Results for Tailings Sample**

Test Number	Feed			Product			Tailings			Analysis			
	Ash %	Sulfur %	Pyr. S. %	Ash %	Sulfur %	Pyr. S. %	Ash %	Sulfur %	Pyr. S. %	Yield, %	CMR, %	Ash Rej %	TSR %
28	42.3	1.69		8.5	1.75		76.0	1.33		50	79	90	48
29	48.6	1.72		8.6	1.84		78.7	1.73		43	76	92	54
30	46.8	1.58		7.8	1.97		79.1	1.84		45	79	92	44
31	44.5	1.76	1.39	8.1	1.94	1.06	85.8	1.49	1.49	53	88	90	41
32	44.5	1.58		9.5	1.99		87.1	1.56		55	89	88	31
33	45.7	1.30		9.0	1.82		86.0	1.20		52	88	90	27

**Table 42. Open Column: Superficial Velocities and Mass Loadings (Tailings Sample)**

Test Number	Superficial Velocities								Mass Loadings			
	Mean Residence Time		Feed		Wash Water		Air		Feed		Froth	
			cm/s	m/s	cm/s	m/s	cm/s	m/s	cm <sup>2</sup> /	m <sup>2</sup>	cm <sup>2</sup> /	m <sup>2</sup>
28	9.97	598.17	0.79	0.0079	0.20	0.0020	1.790	0.0179	1.25	0.75	0.63	0.38
29	5.98	358.90	1.32	0.0132	0.20	0.0020	1.790	0.0179	2.06	1.24	0.88	0.53
30	4.27	256.36	1.84	0.0184	0.20	0.0020	1.790	0.0179	2.89	1.73	1.31	0.78
31	4.27	256.36	1.84	0.0184	0.20	0.0020	2.475	0.0247	2.89	1.73	1.53	0.92
32	5.98	358.90	1.32	0.0132	0.20	0.0020	2.475	0.0247	2.06	1.24	1.13	0.68
33	9.97	598.17	0.79	0.0079	0.20	0.0020	2.475	0.0247	1.24	0.75	0.65	0.39

The results are summarized in Figure 25, Figure 26, Figure 27, and Figure 28. Figure 25 and Figure 26 illustrate the overall performance of this cell in terms of the relationship between energy recovery and clean coal ash, and energy recovery and product sulfur respectively.

The energy recovery was essentially constant over the range of flow rates tested (0.7 to 1.84 cm/s). The clean coal ash content was in the range of 8-9%, and energy recovery was approximately 78% for an aeration rate of 1.8 cm/s and 88% for an aeration rate of 2.5 cm/s. Again, the results suggest that a froth loading of 0.93 tph/m<sup>2</sup> (1.55 gm/min/cm<sup>2</sup>) can be achieved, but it is not known whether this value would apply to more dilute feed slurries at higher feed rates of say 3.7 cm/s.

Figure 27 and Figure 28 illustrate the overall performance of this cell in terms of the relationship between energy recovery and ash rejection, and energy recovery and total sulfur rejection respectively.




Figure 25. Open Column: Energy Recovery vs. Clean Coal Ash (Tailings Sample)




Figure 26. Open Column: Energy Recovery vs. Product Sulfur (Tailings Sample)




Figure 27. Open Column: Energy Recovery vs. Ash Rejection (Tailings Sample)




Figure 28. Open Column: Energy Recovery vs. Sulfur Rejection (Tailings Sample)

### 5.5.7 Recommended Operating Conditions

The recommended conditions based on the bench-scale test results are shown in Table 43 and Table 44.

**Table 43. Open Column: Recommended Single-Stage Operating Conditions**

Parameter	Value
Feed velocity	1.8 cm/s (3.5 ft/min)
Aeration rate	2.4 cm/s (4.7 ft/min)
Fuel oil	1 kg/ton (2 lb/ton)
Frother	0.5 kg/ton (1 lb/ton)
Froth mass loading	1.2 tph/m <sup>2</sup> (2.0 gm/min/cm <sup>2</sup> )
Retention time, minimum	120 sec (2 min)

**Table 44. Open Column: Recommended Second-Stage Operating Conditions**

Parameter	Value
Feed velocity	4 cm/s (7.8 ft/min)
Aeration rate	2.2 cm/s (4.5 ft/min)
Fuel oil	1 kg/ton (2 lb/ton)
Frother	0.7 kg/ton (1.4 lb/ton)
Froth mass loading	1.3 tph/m <sup>2</sup> (2.0 gm/min/cm <sup>2</sup> )
Retention time, minimum	120-240 sec (2-4 min)

## 6.0 CONCEPTUAL DESIGN

This section outlines the procedures and assumptions used for the conceptual design of the eight advanced flotation circuits selected for evaluation in this task. Aspects of the conceptual design including scale-up, material balances, process instrumentation and control, and ancillary requirements are discussed. The following eight circuits are included for analysis and evaluation:

### Single-stage operation

Jameson cell  
Outokumpu HG tank cell  
Open column  
Packed column

### Two-stage operation

Jameson/open column  
Jameson/packed column  
Outokumpu/open column  
Outokumpu/packed column

## 6.1 Design Procedures

A computer spreadsheet model was developed and used to evaluate each advanced circuit. Bench-scale test results were scaled-up to commercial size and used as the basis for material

balance and equipment sizing calculations. Using the material balance and equipment sizes, capital and operating cost estimates were prepared for each advanced circuit. Following this, an economic analysis was performed based on the PETC economic model developed by Eos Technologies, Inc. which is based on levelized, discounted cash flow principles.

Various operating conditions (i.e., different points on the grade/recovery curve) were evaluated and economically optimal conditions were selected for inclusion in the conceptual design. This evaluation was performed using two optimization criteria. The first criterion considered the circuit as a stand-alone entity during evaluation and is referred to as the circuit-optimized approach. The second criterion considered the effects of the circuit on the remainder of the preparation plant flowsheet and is called the plant-optimized approach. In this approach, any overall yield or recovery gains made on a plant-wide basis as a result of a more effective operation in the flotation circuit are credited to it during economic analysis.

## 6.2 Scale-Up to Commercial Scale

The bench-scale test work formed the basis for predicting full-scale equipment size and performance and associated capital and operating costs. The scale-up assumes that the slurry solids concentration and coal size consist and flotability are similar to properties tested during the bench-scale test work. Scale-up procedures were developed specifically for each flotation machine after consultation with the equipment vendors and a review of scale-up methods presented in the literature for similar equipment. The scale-up parameters of interest are: circuit flotation performance, reagent dosage, air consumption, residence time, and wash water consumption. Each of these scale-up parameters is discussed below for all circuits.

The full-scale circuit performance, with respect to energy recovery and ash and sulfur rejection, was projected to be equal to the bench-scale results. The fuel oil dosage was also assumed to be constant on a kg/t (lb/ton) basis. The frother dosage was assumed to be constant on a mass concentration basis (constant ppm frother in slurry) which is proportional to a Kg/t basis if the solids concentration is held constant. Wash water is assumed to be equal to the product of the wash water superficial velocity (cm/s) as measured from the bench-scale tests and the commercial-scale cross-sectional area at the froth discharge.

The other scale factors are discussed below for each cell.

### Jameson Cell

- The capacity of each downcomer is set by fixing the slurry velocity to a constant value as required to achieve proper jet operations. This value is approximately 40-45 cm/s (1.3-1.4 ft/sec).
- The ratio of the downcomer area to the froth tank surface area was initially fixed to a ratio of 2.8% and was established during development of the machine. After completion of the parametric tests, this ratio was increased to 6.25% for the high capacity tests.
- The aeration rate is set equal to the product of the air superficial velocity determined in the bench-scale tests and the cross-sectional area of the froth tank at the lip discharge. This can be achieved by induced suction created by the downcomer orifice.
- Froth mass loading: The maximum froth removal for this cell is estimated from mass loadings achieved during the bench-scale tests. The maximum froth mass flow is estimated at 0.9 tph/m<sup>2</sup> (1.5 g/min/cm<sup>2</sup>) for high-recovery single-stage operation. For high- capacity, first-stage operation, a froth loading of 2.7 tph/m<sup>2</sup> (4.5 g/min/cm<sup>2</sup>) was achieved.
- Power requirements (excluding air compression) are related to achieving 0.13 MPa (20 psi) pressure at the downcomer inlet. It has been assumed that 6 m (20 ft) of head can be achieved by elevation differences and the remainder must be achieved by pumping.

### Outokumpu Tank Cell

- Residence time: Determined by estimation of flotation kinetics as calculated from testing two flow rates. The residence time is estimated at 150 seconds (2.5 minutes).
- Froth mass loading: The maximum froth removal for each cell is estimated from mass loadings achieved during the bench-scale tests. The maximum froth mass flow is estimated at 1.1 tph/m<sup>2</sup> (1.8 g/min/cm<sup>2</sup>).
- The aeration rate is set equal to the product of the air superficial velocity determined during the bench-scale tests (2.3 cm/s) and the cross-sectional area between the froth cone and lip at the discharge.

### Packed Column

- Volumetric scaleup: The vendor recommends a volumetric scale-up to adjust between changes in cell dimensions. The proportion of the cell filled with froth or slurry would also be scaled proportionately. For instance, doubling the cell height would increase capacity by a factor of two provided that the froth depth is proportionately increased or doubled. This scale-up does not address froth mass loading and has been validated only for base metal applications where froth mass loading is not critical. A modified scale-up procedure has been applied that is more conservative in estimating the required cross-sectional flotation area. The scale-up is established by assuming that doubling the height of the cell would lead to only a 50% increase in cell capacity.

- Residence time: The minimum slurry residence time is set by the time required to achieve high energy recovery. This is estimated to be 2 minutes for single- and second-stage applications. A longer residence time will be used, if required, to satisfy the froth mass loading constraint.
- Froth mass loading: The maximum froth removal as estimated from mass loadings achieved during the bench-scale tests. The maximum froth mass loading for a raw coal feed was set at 1.8 tph/m<sup>2</sup> (3.0 gm/min/cm<sup>2</sup>) for a column height of 366 cm (12 ft) and 2.7 tph/m<sup>2</sup> (4.5 gm/min/cm<sup>2</sup>) for a column height of 732 cm (24 ft). The maximum forth mass loading for second stage operation (high ash feed) was 1.2 tph/m<sup>2</sup> (2 gm/min/cm<sup>2</sup>) and 1.8 tph/m<sup>2</sup> (3.0 gm/min/cm<sup>2</sup>) for a column height of 366 cm (12 ft) and 732 cm (24 ft), respectively.
- The aeration rate is set equal to the product of the air superficial velocity determined during the bench-scale tests (5.2-4.1 cm/s) times the height scale-up factor and cross-sectional area. This represents proportioning the air flow rate with the froth mass loading, i.e., the same solids loading on the air bubbles.

#### Open Column

- Residence time: Based on the slurry residence time required for high energy recovery when not mass-loading-limited. Residence time is estimated to be 2 minutes for single- and 4.3 minutes for second-stage applications. A longer residence time will be used, if required, to satisfy the froth mass loading constraint.
- Froth mass loading: The maximum froth removal as estimated from mass loadings achieved during the bench-scale tests. The maximum froth mass flow is estimated at 1.2 tph/m<sup>2</sup> (2.0 g/min/cm<sup>2</sup>) for raw coal and second stage feed coal.
- The aeration rate is set equal to the product of the air superficial velocity determined in the bench-scale tests (2.4 cm/s) and the cross-sectional area.

#### 6.3 Material Balances

The conceptual design of the optimal fine coal cleaning circuit assumes a Pittsburgh No. 8 feedstock. The plant feedstock analysis is provided in Table 45. Analyses for the +100M size fraction are used for the plant-optimization case.

**Table 45. Assumed Plant Feedstock Analysis (dry basis)**

Size	Fraction	Ash	HHV	Total
	%	%	Btu/lb	Sulfur %
2" x 10 M	71.5	23.0	11805	1.10
10 x 100M	22.3	20.0	12255	1.10
100M x 0	6.3	20.0	11911	1.10
Composite	100.0	22.1	11933	1.10

The feed conditions assumed are based on plant performance data as presented in Table 17 in Section 4. The circuit feed rate was set at 76 tph with a solids content of 3.35%.

Four single-stage configurations and four two-stage rougher-scavenger configurations of the advanced circuit were considered in the conceptual design and economic evaluation. Assumed operating conditions for the advanced circuits under consideration are presented in Table 46 and Table 55. As will be discussed in Section 7, Economics, the operation of the flotation circuit is influenced by the criteria used to optimize its performance. For the purposes of this report, two criteria have been developed: (i) circuit-optimized (Table 46) and (ii) plant-optimized (Table 55). The assumed optimization criteria have a small effect on the circuit operating conditions but do not affect the sizing of the equipment. Material balances for each of the advanced circuits assuming circuit-optimized conditions are presented in Table 47 through Table 54.

**Table 46. Assumed Operating Conditions (Circuit Optimized)**

	<i>One Stage</i> Jameson	<i>One Stage</i> Outokumpu	<i>One Stage</i> Open Column	<i>Packed</i> Column	<i>Jameson/</i> <i>Packed</i> <i>Column</i>	<i>Jameson/</i> <i>Open</i> <i>Column</i>	<i>Two Stage</i> Outokumpu/ <i>Packed</i> <i>Column</i>	<i>Two Stage</i> Outokumpu/ <i>Open</i> <i>Column</i>
<b><i>First Stage</i></b>								
Energy Recovery	%	90.1	85.0	93.0	91.4	72.9	72.9	68.5
Yield	%	75.2	73.9	78.6	76.9	60.6	59.1	59.1
Total Sulfur Rejection	%	29.0	20.0	25.3	26.6	47.0	40.0	40.0
Clean Coal Ash	%	4.2	8.0	5.3	4.9	3.8	7.3	7.3
Residence Time	min	N/A	2.50	2.00	2.00	N/A	1.00	1.00
Frother Dosage	kg/tonne	0.54	0.48	0.27	0.51	0.30	0.45	0.45
Fuel Oil Dosage	kg/tonne	1.34	0.10	1.00	1.40	1.00	1.40	1.00
Eff. Feed Velocity	cm/s	1.4	2.1	1.0	1.0	4.6	2.1	2.1
Air Flow Rate	cm/s	N/A	2.20	2.40	6.20	N/A	2.40	2.40
Wash Water Rate	cm/s	0.17	0.25	0.2	0.28	0.78	0.25	0.25
Froth Depth	cm	0	10	76.2	35.56	55.88	10	10
<b><i>Second Stage</i></b>								
Energy Recovery	%				73.9	88.1	73.9	88.1
Yield	%				43.5	52.7	48.7	59.1
Total Sulfur Rejection	%				61.9	41.1	61.9	41.1
Clean Coal Ash	%				6.5	8.1	6.5	8.1
Residence Time	m				2.0	4.3	2.0	4.3
Additional Frother	kg/tonne				0	0	0	0
Additional Fuel Oil	kg/tonne				0	0	0	0
Eff. Feed Velocity	cm/s				3.0	1.8	3.0	1.8
Air Flow Rate	cm/s				4.1	2.5	4.1	2.5
Wash Water Rate	cm/s				0.28	0.2	0.28	0.2
Froth Depth	cm				12.7	76	12.7	76

Table 47. Jameson Cell: One-Stage Material Balance

	Solids t/h	Solids %	Water t/h	Slurry t/h	Slurry Flow Rate gpm	Ash %	Sulfur %	HHV Btu/lb db
<b>First Stage</b>								
Feed	76.0	3.35	2193	2269	9000	20.0	1.10	11911
Wash Water			365	365	1459			
Product	57.2	20.0	229	286	1086	4.2	1.04	14269
Tails	18.8	0.80	2329	2348	9373	68.1	1.29	4747

Table 48. Outokumpu Cell: One-Stage Material Balance

	Solids t/h	Solids %	Water t/h	Slurry t/h	Slurry Flow Rate gpm	Ash %	Sulfur %	HHV Btu/lb db
<b>First Stage</b>								
Feed	76.0	3.35	2193	2269	9000	20.0	1.10	11911
Wash Water			454	454	1817			
Product	56.2	20.0	225	281	1067	8.0	1.19	13698
Tails	19.8	0.81	2422	2442	9749	54.0	0.84	6849

Table 49. Open Column: One-Stage Material Balance

	Solids t/h	Solids %	Water t/h	Slurry t/h	Slurry Flow Rate gpm	Ash %	Sulfur %	HHV Btu/lb db
<b>First Stage</b>								
Feed	76.0	3.35	2193	2269	9000	20.0	1.10	11911
Wash Water			667	667	2668			
Product	59.7	20.0	239	299	1134	5.3	1.03	14100
Tails	16.3	0.62	2621	2637	10533	73.9	1.34	3890

Table 50. Packed Column: One-Stage Material Balance

	Solids t/h	Solids %	Water t/h	Slurry t/h	Slurry Flow Rate gpm	Ash %	Sulfur %	HHV Btu/lb db
<b>First Stage</b>								
Feed	76.0	3.35	2193	2269	9000	20.0	1.10	11911
Wash Water			173	173	694			
Product	58.4	20.0	234	292	1111	4.9	1.05	14162
Tails	17.6	0.82	2133	2150	8583	70.3	1.27	4415

**Table 51. Jameson Cell/Packed Column: Two-Stage Material Balance**

	<b>Solids t/h</b>	<b>Solids %</b>	<b>Water t/h</b>	<b>Slurry t/h</b>	<b>Slurry Flow Rate gpm</b>	<b>Ash %</b>	<b>Sulfur %</b>	<b>HHV Btu/lb db</b>
<b>First Stage</b>								
Feed	76.0	3.35	2193	2269	9000	20.0	1.10	11911
Wash Water			479	479	1917			
Product	46.1	20.0	184	230	875	3.8	0.96	14330
Tails	29.9	1.19	2488	2518	10042	45.0	1.31	8191
<b>Second Stage</b>								
Feed	29.9	1.19	2488	2518	10042	45.0	1.31	8191
Wash Water			121	121	485			
Product	13.0	20.0	52	65	247	6.5	1.15	13926
Tails	16.9	0.66	2557	2574	10280	74.6	1.44	3782
<b>Combined Product</b>	<b>59.1</b>	<b>20.0</b>	<b>236</b>	<b>295</b>	<b>1122</b>	<b>4.4</b>	<b>1.00</b>	<b>14241</b>

**Table 52. Jameson Cell/Open Column: Two-Stage Material Balance**

	<b>Solids t/h</b>	<b>Solids %</b>	<b>Water t/h</b>	<b>Slurry t/h</b>	<b>Slurry Flow Rate gpm</b>	<b>Ash %</b>	<b>Sulfur %</b>	<b>HHV Btu/lb</b>
<b>First Stage</b>								
Feed	76.0	3.35	2193	2269	9000	20.0	1.10	11911
Wash Water			479	479	1917			
Product	46.1	20.0	184	230	875	3.8	0.96	14330
Tails	29.9	1.19	2488	2518	10042	45.0	1.31	8191
<b>Second Stage</b>								
Feed	29.9	1.19	2488	2518	10042	45.0	1.31	8191
Wash Water			316	316	1266			
Product	15.8	20.0	63	79	300	8.1	1.47	13688
Tails	14.2	0.51	2741	2756	11008	86.2	1.14	2062
<b>Combined Product</b>	<b>61.8</b>	<b>20.0</b>	<b>247</b>	<b>309</b>	<b>1175</b>	<b>4.9</b>	<b>1.09</b>	<b>14166</b>

Table 53. Outokumpu Cell/Packed Column: Two-Stage Material Balance

	Solids t/h	Solids %	Water t/h	Slurry t/h	Slurry Flow Rate gpm	Ash %	Sulfur %	HHV Btu/lb db
<b>First Stage</b>								
Feed	76.0	3.35	2193	2269	9000	20.0	1.10	11911
Wash Water			44	44	175			
Product	44.9	20.0	180	225	854	7.3	1.12	13802
Tails	31.1	1.49	2057	2088	8321	38.4	1.08	9177
<b>Second Stage</b>								
Feed	31.1	1.49	2057	2088	8321	38.4	1.08	9177
Wash Water			100	100	400			
Product	15.1	20.0	61	76	288	6.5	0.84	13921
Tails	15.9	0.75	2096	2112	8434	68.6	1.30	4670
<b>Combined Product</b>	<b>60.1</b>	<b>20.0</b>	<b>240</b>	<b>300</b>	<b>1141</b>	<b>7.1</b>	<b>1.05</b>	<b>13832</b>

Table 54. Outokumpu Cell/Open Column: Two-Stage Material Balance

	Solids t/h	Solids %	Water t/h	Slurry t/h	Slurry Flow Rate gpm	Ash %	Sulfur %	HHV Btu/lb db
<b>First Stage</b>								
Feed	76.0	3.35	2193	2269	9000	20.0	1.10	11911
Wash Water			44	44	175			
Product	44.9	20.0	180	225	854	7.3	1.12	13802
Tails	31.1	1.49	2057	2088	8321	38.4	1.08	9177
<b>Second Stage</b>								
Feed	31.1	1.49	2057	2088	8321	38.4	1.08	9177
Wash Water			275	275	1102			
Product	18.4	20.0	73	92	349	8.1	1.07	13683
Tails	12.7	0.56	2259	2272	9074	82.1	1.08	2669
<b>Combined Product</b>	<b>63.3</b>	<b>20.0</b>	<b>253</b>	<b>316</b>	<b>1202</b>	<b>7.5</b>	<b>1.10</b>	<b>13767</b>

**Table 55. Assumed Operating Conditions (Plant Optimized)**

	One Stage Jameson	One Stage Outokumpu	One Stage Open Column	One Stage Packed Column	Two Stage Jameson/ Packed Column	Two Stage Outokumpu/ Open Column	Two Stage Outokumpu/ Packed Column	Two Stage Outokumpu/ Open Column
<b>First Stage</b>								
Energy Recovery	%	85.4	85.0	93.3	80.5	72.9	68.5	68.5
Yield	%	71.2	73.9	78.9	66.7	60.6	59.1	59.1
Total Sulfur Rejection	%	31.6	20.0	25.3	39.6	47.0	40.0	40.0
Clean Coal Ash	%	4.0	8.0	5.3	3.5	3.8	7.3	7.3
Residence Time	min	N/A	2.50	2.00	N/A	N/A	1.00	1.00
Frother Dosage	kg/tonne	0.51	0.48	0.27	0.39	0.30	0.45	0.45
Fuel Oil Dosage	kg/tonne	1.00	0.10	1.00	0.93	1.40	1.40	1.00
Eff. Feed Velocity	cm/s	1.2	2.1	1.0	3.0	1.1	2.1	2.1
Air Flow Rate	cm/s	N/A	2.20	2.40	4.20	N/A	2.40	2.40
Wash Water Rate	cm/s	0.17	0.25	0.2	0.28	0.78	0.25	0.25
Froth Depth	cm	0	10	76	139.7	55.88	10	10
<b>Second Stage</b>								
Energy Recovery	%				73.9	88.1	73.9	88.1
Yield	%				43.5	52.7	48.7	59.1
Total Sulfur Rejection	%				61.9	41.1	61.9	41.1
Clean Coal Ash	%				6.5	8.1	6.5	8.1
Residence Time	m				2.0	4.3	2.0	4.3
Additional Frother	kg/tonne				0	0	0	0
Additional Fuel Oil	kg/tonne				0	0	0	0
Eff. Feed Velocity	cm/s				3.0	1.8	3.0	1.8
Air Flow Rate	cm/s				4.1	2.5	4.1	2.5
Wash Water Rate	cm/s				0.28	0.2	0.28	0.2
Froth Depth	cm				12.7	76	12.7	76

#### 6.4 Preparation Plant Effects

Adjustments were made to the overall preparation plant operation in the plant-optimized case in an effort to accurately reflect the impact that an advanced flotation circuit would have on the overall product recovery at a fixed quality. Specifically, increases or decreases in cleaned fine coal quality will cause corresponding changes in overall clean coal quality. In actual plant operations, adjustments would be made to the cleaning operation to bring the overall clean coal product back to the product specification. Table 56 lists the specifications used for the plant-optimized case. Table 57 describes the major equipment assumed to be in use for the overall preparation plant flowsheet for the plant-optimized case.

**Table 56. Product Specification (As-Received Basis)**

<b>Property</b>	<b>Specification</b>
Moisture	Not to exceed 8.5%
Heating value	Not less than 13,000 Btu/lb
Ash	No specified limit but limited in practice by the heating value specification and moisture content

**Table 57. Preparation Plant Flowsheet Assumptions**

Capacity	1200 tph (db)
Coal Supply	Pittsburgh No. 8
<i>Unit Operations</i>	
Coarse (2" x 10M)	Heavy media separation at S.G. ~1.6
Intermediate (10 x 100M)	Water-only cyclones with tailings reclean using spiral concentrators
Fines (-100M)	Advanced flotation: various configurations as specified

#### 6.5 Process Instrumentation and Control

An elementary level of process instrumentation and control requirements have been assumed for each advanced circuit under consideration. The level of instrumentation and control assumed includes level control for the flotation cells, measurement of column feed rates,

measurement of the air addition rate, and measurement of reagent addition rates. The level of control was determined based on a number of factors including the constant nature of coal cleaning operations, the level of instrumentation provided at similar installations, and the level of control required to operate the advanced circuit effectively.

The flotation cell level control loop consists of a single differential pressure transmitter to measure the pulp-froth interface height regulating a control valve on the column feed piping using a PID controller. Consideration was given to using a second differential pressure transmitter to obtain a better measurement of the pulp density which in turn will provide a better indication of interface height; however, it was not deemed necessary as the operation of the column is at a set volumetric loading and air addition.

Measurements of the feed rate and air addition rate to the flotation cell were also included in the instrumentation for the advanced circuit. Reagent addition was accomplished by using metering pumps which add reagent at an adjustable volumetric rate.

## **6.7 Ancillary Requirements**

The ancillary requirements for the advanced circuit are identified below. The discussion is limited to the anticipated impact of installing an advanced flotation circuit at a conventional preparation plant. The ancillary requirements for the advanced circuit are not significantly different from those for a conventional flotation circuit used for fines processing.

### **6.7.1 Utilities**

The process utilities required for the advanced circuit are similar to those required by a conventional flotation circuit and include electricity and process water. In general, the advanced circuit requires more electrical power than a conventional flotation process because additional energy is needed to introduce air into the cell, either through an air compressor or a blower. In the case of the Jameson cell, additional pump power is also used to develop suction for air introduction via a venturi orifice. The capital expenditure required to accommodate the increase in electrical load is estimated in the economic analysis.

Each process also requires an air supply at a pressure which depends on the flotation equipment used. However, this air is provided by process equipment and not by plant utilities. A tabulation of process air requirements is provided in Table 58.

**Table 58. Process Air Requirements**

<b>Cell Type</b>	<b>Pressure psig</b>	<b>Comments</b>
Jameson	~0	Air inducted through downcomer
Outokumpu	5	
Packed column	15	
Open column	45	
Jameson/Packed column	15	Based on packed column design
Jameson/Open column	45	Based on open column design
Outokumpu/Packed column	15	Based on packed column design
Outokumpu/Open column	45	Based on open column design

#### **6.7.2 Site**

The building requirements for the advanced circuit are dependent on the size and configuration of the equipment used. For column-type equipment, ceiling height also becomes a consideration. The economic analysis assumes that a building addition to the existing plant will be constructed to accommodate the new circuit. Equipment floor space and height requirements are considered in the capital cost estimate. As a practical matter, a preparation plant replacing a conventional circuit with an advanced circuit will size equipment to utilize existing space whenever practical.

## **7.0 ECONOMICS**

The bench-scale work presented in Section 5 demonstrates that the advanced circuits can achieve improved process performance when compared to conventional flotation processes for fine coal cleaning. However, it is necessary to assure that this process improvement is also economically viable. The assumptions, estimation procedure, cost estimates, and economic analyses for the eight selected advanced fine coal cleaning circuits are presented in this section and contrasted with conventional flotation. The economic merits of each advanced circuit configuration are determined by calculating its leveled costs for the two optimization criteria discussed earlier, i.e., on a circuit-optimized and a plant-optimized basis. Lastly, a sensitivity analysis examining the effects of process assumptions is also included.

## 7.1 Assumptions

The following economic evaluation assumes that the advanced circuit is to be installed at an existing coal preparation plant to process coal fines. The capital and operating costs of the equipment used to process the coarse fractions of coal are not considered. However, the production impact of the advanced circuit on coarse coal circuit operations is considered in the plant-optimized cases and any yield improvements are credited to the advanced fine coal circuit in question.

Several assumptions regarding the design basis for the advanced circuit have been incorporated in the conceptual design. These assumptions, as well as other assumptions required for the economic analysis, are presented in Table 59.

**Table 59. Operating Assumptions**

Annual operating hours	4500 hours
Plant feed rate	1,200 tph dry basis
Fines circuit feed rate	76 tph dry basis
Plant life	20 years
Royalties	none
Financing	100% equity
Construction duration	1 year
Inflation rate	4%
Corporate tax rate	38%
Rate of return	25%

It was assumed that the circuit will be constructed at an existing preparation plant and that the plant will have sufficient land for constructing the building for it.

## 7.2 Purchased Equipment

The costs for major plant equipment items and their power requirements are based on vendor quotations, prices of similar equipment, and estimating guidelines. The costs are reported in 1995 dollars. Selection and scale-up of major plant equipment is discussed below.

### 7.2.1 Jameson Cell

For the conceptual plant design, the Jameson Cell Model 6000/10 was selected. For a single-stage configuration, four cells are required. Each cell is approximately 6 meters long by 2 meters wide and is priced at \$159,500, including remote instrumentation and controls. The shipping weight of each cell is 31,739 lb.

For first-stage operation, 16 m<sup>2</sup> of froth tank area was assumed and the cost was calculated proportionately.

#### **7.2.2 *Outokumpu Cell***

The Outokumpu Tank Cell Flotation Unit Model TC 10 was selected for the conceptual plant design. For a single-stage configuration, two lines of cells containing four cells each were required (12.5 minutes residence time). The cost of all eight units is \$320,000 and includes instrumentation, controls, and air supply equipment. A blower with a blower motor is used to supply air to the cells.

For first-stage operation, a 1-minute residence time was assumed on three Model TC 10 cell.

#### **7.2.3 *Open Column***

For the open column single-stage design, four 12-ft diameter by 20-ft tall flotation column cells from Pyramid Resources were selected. Each column costs \$92,400 F.O.B. and includes a sparger system, wash water system, and level control.

For second-stage operation, 33 m<sup>2</sup> of column cell area was assumed based on the scale-up criteria given in Section 6.2, or approximately one-third of the single-stage area. The cost was calculated accordingly.

#### **7.2.4 *Packed Column***

Two GL&V self-supported packed columns, 8 ft by 12 ft by 24 ft high, were selected for the single-stage design of the packed column circuit. Each column costs \$220,300 F.O.B. and includes distributors for feed inlet, air inlet, and wash water. Instrumentation was not included in the cost estimate for this item and was assumed to be \$35,000.

For second-stage operation, 11 m<sup>2</sup> of column cell area was assumed (see Section 6.2), and the cost was proportioned accordingly.

### 7.2.5 Cost Scaling

Equipment costs for cells and columns with sizes different than those presented above were scaled proportionally to flotation area. This scaling represents the fact that multiple equipment items were used in the design and variations in required area from the base equipment can be accommodated by purchasing additional (or fewer) units. Cell and column heights were assumed constant in the conceptual design.

## 7.3 Capital Costs

Capital costs such as installation, structures, piping, instrumentation other than cell instrumentation, and foundations were estimated directly based on the scope of work and were not factored from purchased equipment costs. Flotation cell/column instrumentation costs were included in the purchased cost of the equipment. Electrical costs were estimated taking into account the gross electrical requirements of each circuit. Building construction costs were estimated on the basis of the floor plan area required by each circuit. Indirect capital costs were then estimated from the total direct fixed costs. The bases used to estimate direct and indirect capital costs are summarized in Table 60.

Table 60. Direct and Indirect Cost Estimation

<i>Cost Item</i>	<i>Basis for Estimation</i>
<i>Direct Costs</i>	
Purchased equipment	Manufacturer's estimate
Installation	Direct estimate
Piping	Direct estimate
Instrumentation	Direct estimate*
Electrical	Determined by electrical needs
Buildings	Determined by equipment size
<i>Indirect Costs</i>	
Engineering	25% of direct costs

\* Does not include cell instrumentation which is included in the flotation cell/column equipment cost

## 7.4 Operating Costs

### 7.4.1 Utilities

Electrical power consumption was estimated for each item in the equipment list. Power costs were estimated using an industrial rate of \$0.05/kW-hr.

#### 7.4.2 Consumables

The consumables used in the advanced flotation circuit are shown in Table 61. The dosages and addition rates of each item vary depending on the process. Details on the addition rates are provided in the material balance presented in Section 6.

**Table 61. Unit Costs for Consumables**

<i>Item</i>	<i>Unit Cost</i>
Frother	\$0.64/lb
Fuel oil #2	\$0.10/lb
Flocculant	\$0.90/lb

#### 7.4.3 Personnel

It is estimated that manpower requirements for operation of the advanced circuit will be similar to those for operation of a conventional flotation circuit. Personnel requirements and associated annual costs are summarized in Table 62.

**Table 62. Personnel Requirements**

<i>Position</i>	<i>Operator</i>	<i>Maintenance</i>
Salary	\$35,000	\$45,000
Benefits	50% of salary	50% of salary
Shifts per day	2	2
Utilization	25%	5%
Annual cost	\$26,250	\$6,750
Total Annual Cost		\$33,000

For purposes of the economic evaluation, there is no net gain or loss in manpower when comparing the advanced flotation circuit and the conventional flotation circuit.

#### 7.4.4 Maintenance

Annual equipment maintenance costs were estimated to be 5% of the purchased equipment cost for each advanced circuit.

### 7.5 Circuit-Optimized Economics

Each of the advanced circuits was evaluated as a stand-alone entity using the PETC economic model developed by Eos Technologies, Inc. Levelized incremental product costs were calculated on a \$/ton and \$/MMBtu basis. Also, desulfurization costs were calculated on a \$/ton of SO<sub>2</sub> removed basis. The circuit-specific input data set used for the economic model is provided in Table 63.

**Table 63. Economic Model Inputs (Circuit-Optimized)**

	One Stage		One Stage		One Stage		Two Stage		Two Stage		Two Stage	
	Jameson	Outokumpu	Jameson	Outokumpu	Jameson/ Packed	Jameson/ Open	Jameson/ Packed	Jameson/ Open	Outokumpu/ Packed	Outokumpu/ Open	Outokumpu/ Packed	Outokumpu/ Open
Direct Processing	\$x1000	1,011	547	823	790	816	923	648	761	0	0	0
Emission/Waste Equipment		0	0	0	0	0	0	0	0	0	0	0
Off-Site Utilities		0	0	0	0	0	0	0	0	0	0	0
Total Direct Capital	\$x1000	1,011	547	823	790	816	923	648	761	0	0	0
On-Site Assembly	\$x1000	142	142	142	142	142	142	142	142	142	142	142
Working Capital	\$x1000	0	0	0	0	0	0	0	0	0	0	0
Engineering	\$x1000	288	172	241	233	239	266	197	226	0	0	0
Contingency	\$x1000	0	0	0	0	0	0	0	0	0	0	0
Site Modifications	\$x1000	0	0	0	0	0	0	0	0	0	0	0
Total Indirect Capital	\$x1000	430	314	383	375	381	408	339	367	0	0	0
Expensible Capital	\$x1000	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Fixed O&M	\$x1000	99	66	84	85	83	91	73	80	0	0	0
Variable O&M	\$x1000	741	481	598	758	649	691	685	721	0	0	0
Ins. & Prop. Tax/yr.	0	0	0	0	0	0	0	0	0	0	0	0
PLANT DATA												
Plant Capacity Factor		51.3%	51.3%	51.3%	51.3%	51.3%	51.3%	51.3%	51.3%	51.3%	51.3%	51.3%
Coal Input	tons/hr	76.0	76.0	76.0	76.0	76.0	76.0	76.0	76.0	76.0	76.0	76.0
Heating Value	Btu/lb	11911	11911	11911	11911	11911	11911	11911	11911	11911	11911	11911
Sulfur	%	1.10%	1.10%	1.10%	1.10%	1.10%	1.10%	1.10%	1.10%	1.10%	1.10%	1.10%
Coal Output	tons/hr	56.2	56.2	59.7	58.4	59.1	61.8	61.8	60.1	63.3	63.3	63.3
Heating Value	Btu/lb	14269	13698	14100	14162	14241	14166	14166	13832	13767	13767	13767
Sulfur	%	1.04%	1.19%	1.05%	1.05%	1.00%	1.00%	1.00%	1.00%	1.05%	1.05%	1.05%

The results of the economic analysis are presented in Table 64 and Table 65.

**Table 64. Single-Stage Economic Results (Circuit-Optimized)**

	<i>Conventional Flotation</i>	<i>Jameson</i>	<i>Outokumpu</i>	<i>Open Column</i>	<i>Packed Column</i>
<i>Levelized Product Costs</i>					
Incremental, \$/MMBtu	0.201	0.206	0.198	0.158	0.182
Total, \$/MMBtu	0.79	0.79	0.79	0.74	0.77
Total, \$/ton	21.71	22.63	21.51	21.00	21.78
Desulfurization, \$/ton SO <sub>2</sub>	3158	897	3108	740	854
Energy recovery, %	85.0	90.1	85.0	93.0	91.4
Clean coal ash, % (db)	7.5	4.2	8.0	5.3	4.9

**Table 65. Two-Stage Economic Results (Circuit-Optimized)**

	<i>Conventional Flotation</i>	<i>Jameson/ Packed Column</i>	<i>Jameson/ Open Column</i>	<i>Outokumpu/ Packed Column</i>	<i>Outokumpu/ Open Column</i>
<i>Levelized Product Costs</i>					
Incremental, \$/MMBtu	0.201	0.162	0.142	0.163	0.138
Total, \$/MMBtu	0.79	0.75	0.73	0.75	0.73
Total, \$/ton	21.71	21.33	20.65	20.75	19.96
Desulfurization, \$/ton SO <sub>2</sub>	3158	631	788.0	836	967
Energy recovery, %	85	92.9	96.8	91.8	96.3
Clean coal ash, % (db)	7.5	4.4	4.9	7.1	7.5

The above single-stage circuit-optimized results indicate that both column cells will result in lower costs than a conventional flotation circuit. The open column costs were the lowest for the single-stage configuration. In the case of two-stage operation, all four circuits were more economical than the conventional circuit.

The results of the circuit-optimized economic analysis correspond with the overall energy recovery, as expected. The energy recovery value correlates to the clean coal ash content in that tests with lower product ash contents also have lower energy recoveries. The problem with a circuit-optimized approach is that no constraints on product quality have been introduced and that the tests being compared are at different points on the grade/recovery relationship. If the fine coal circuit results represented a final product, then price adjustment factors could, in general, be applied to compensate for changes in product quality. Price adjustments (price premiums) have been computed for each circuit-optimized case to determine the break-even levelized production cost for each circuit. The Outokumpu/open column circuit, which has the

lowest circuit-optimized leveled cost, was selected as the base case. Annual revenue requirements were computed for the other circuits that resulted in the same leveled cost as the Outokumpu/open column case. Table 66 summarizes the price premiums required to achieve the break-even production cost. For instance, the open column case will produce a clean coal product with an energy content that is 332 Btu/lb higher than the Outokumpu/open column case and requires an increase in revenues of \$0.016/MMBtu to achieve the break-even leveled cost of \$0.73/MMBtu. The issue is whether the marketplace would support a 1.6 ¢/MMBtu premium for coal with a 332 Btu/lb higher calorific value.

**Table 66. Calculated Price Premium Requirement for Break-even Levelized Production Costs**

Incremental Levelized Production Cost = \$0.14/MMBtu, leveled product cost = \$0.73/MMBtu

<i>Circuit</i>	<i>Increase in</i>				
	<i>Product</i> <i>Ash</i> <i>%</i>	<i>Product</i> <i>Btu/lb</i> <i>(db)</i>	<i>Revenue</i> <i>Requirement</i> <i>\$x1000/yr</i>	<i>Price</i> <i>Premium</i> <i>\$/MMBtu</i>	<i>Btu/lb</i> <i>Increase</i>
Conventional	7.50	13,772	375	0.054	5
Flotation					
Jameson	4.16	14,269	423	0.058	502
Outokumpu	8.00	13,698	350	0.051	-70
Open column	5.30	14,100	124	0.016	332
Packed column	4.88	14,162	273	0.037	395
Jameson/Packed column	4.39	14,241	149	0.020	474
Jameson/Open column	4.89	14,166	22	0.003	399
Outokumpu/Packed column	7.10	13,832	156	0.021	65
Outokumpu/Open column	7.53	13,767	0	0	0

However, discussing the relative merits of producing high-calorific fine coal tends to oversimplify the economics of fine coal cleaning. In the case of existing coal preparation plants, the recovered fines will always be blended with the coarse coal product. Therefore, operation of the fine coal circuit is dependent upon the quality of the coal from the coarse coal circuit in addition to the contract specifications for coal quality. The following section modifies the economics presented above to consider the total coal product as the basis for economic comparisons.

## 7.6 Plant-Optimized Economics

Each of the eight advanced circuits was reevaluated using the PETC economic model. However, the operating conditions were selected using a different criterion for defining optimal

economic performance, termed plant-optimized economics. The goal is to derive operating conditions simultaneously for the fine coal circuit and other circuits in the plant such that the leveled costs of producing the plant product are minimized. This approach assumes that the fine coal circuit is constructed at an existing plant. Plant-optimized economic performance includes the operating and capital costs of the advanced circuit, energy recovered from the advanced circuit, and additional energy recovery (or losses) from changes in coarse coal circuit operations.

A model of the Cyprus Emerald Plant has been used as a basis for all recovery calculations.

- The analysis is presented in a similar fashion to the circuit-optimized cases. A key difference between the plant-optimized and the circuit-optimized criteria is that a coal quality specification for the plant clean coal is specified for the plant-optimized case and the operation of each plant circuit is adjusted to produce the overall clean coal specification at maximum profits. In the case of the Cyprus Emerald plant, the clean coal specification is for a 13,000 Btu/lb product on an as-received basis.

The plant-optimized approach was to evaluate each bench-scale test using a plant model. The model computed the effect of changes in the coarse coal separating gravity required to produce the specified product quality on total plant recovery. The leveled costs were then based on the net change in energy recovery from the coarse circuit in addition to the recovery from the fine circuit. The model assumes no change in the middle size fraction spiral/ water-only cyclone circuit. The bench-scale test result which produced the lowest leveled costs was assumed to be the optimal operating condition. This approach does not rely on extrapolations of cell performance but it does restrict the evaluation to range in energy recovery measured from the test work. Using this approach, the optimal conditions and associated leveled costs were found for each of the eight circuits.

The flotation circuit-specific input data set used for the plant-economic model is provided in Table 67. The results of the economic analysis are presented in Table 68 and Table 69.

**Table 67. Economic Model Inputs (Plant-Optimized)**

	One Stage Jameson	One Stage Outokumpu	One Stage Open Column	One Stage Packed Column	Two Stage Jameson/ Packed Column	Two Stage Jameson/ Open Column	Two Stage Outokumpu/ Packed Column	Two Stage Outokumpu/ Packed Column	Two Stage Outokumpu/ Packed Column
Direct processing	968	547	724	738	816	923	648	648	761
Emission/Waste equipment	0	0	0	0	0	0	0	0	0
Off-site utilities	0	0	0	0	0	0	0	0	0
Total direct capital	968	547	724	738	816	923	648	648	761
On-site assembly	142	142	142	142	142	142	142	142	142
Working capital	0	0	0	0	0	0	0	0	0
Engineering	277	172	216	220	239	266	197	197	226
Contingency	0	0	0	0	0	0	0	0	0
Site modifications	0	0	0	0	0	0	0	0	0
Total indirect capital	419	314	358	362	381	408	339	339	367
Expensible capital	0%	0%	0%	0%	0%	0%	0%	0%	0%
Fixed O&M	96	66	77	81	83	91	73	73	80
Variable O&M	666	480	694	567	649	691	685	685	721
Ins. & property tax/yr.	0%	0%	0%	0%	0%	0%	0%	0%	0%
PLANT DATA									
Plant capacity factor	51.3%	51.3%	51.3%	51.3%	51.3%	51.3%	51.3%	51.3%	51.3%
Coal input	tons/hr	76.0	76.0	76.0	76.0	76.0	76.0	76.0	76.0
Heating value	Btu/lb	11,911	11,911	11,911	11,911	11,911	11,911	11,911	11,911
Sulfur	%	1.10%	1.10%	1.10%	1.10%	1.10%	1.10%	1.10%	1.10%
Coal output	tons/hr	63.9	53.6	63.7	62.2	63.2	60.8	54.9	58.1
Heating value	Btu/lb	13,641	13,823	13,671	13,762	13,999	14,222	14,073	13,989
Sulfur	%	1.17%	1.19%	1.17%	1.08%	1.04%	1.09%	1.04%	1.10%

**Table 68. One-Stage Economic Results (Plant-Optimized)**

	<i>Conventional Flotation</i>	<i>Jameson</i>	<i>Outokumpu</i>	<i>Open Column</i>	<i>Packed Column</i>
<i>Levelized Product Costs</i>					
Incremental, \$/MMBtu	0.201	0.147	0.228	0.134	0.138
Total, \$/MMBtu	0.79	0.73	0.81	0.72	0.72
Total, \$/ton	21.71	20.01	22.52	19.70	19.95
Desulfurization, \$/ton SO <sub>2</sub>	3158	1901	3065	1745	865
Energy recovery, %	85.0	85.4	85.0	86.0	87.2
Clean coal ash, %	7.5	4.0	8.0	4.1	4.9

**Table 69. Two-Stage Economic Results (Plant-Optimized)**

	<i>Conventional Flotation</i>	<i>Jameson/ Packed Column</i>	<i>Jameson/ Open Column</i>	<i>Outokumpu/ Packed Column</i>	<i>Outokumpu/ Open Column</i>
<i>Levelized Product Costs</i>					
Incremental, \$/MMBtu	0.201	0.125	0.152	0.219	0.190
Total, \$/MMBtu	0.79	0.71	0.74	0.81	0.78
Total, \$/ton	21.71	19.95	21.01	22.70	21.73
Desulfurization, \$/ton SO <sub>2</sub>	3158	586	813	1021	1203
Energy recovery, %	85.0	92.9	96.8	91.8	96.3
Clean coal ash, %	7.5	4.4	4.9	7.1	7.5

The plant-optimized analysis results in a different operational perspective for fine coal circuit operations. This approach penalizes the inclusion of ash and water with the fines and promotes the recovery of coarse middlings particles if higher overall plant recoveries result. As a result, lower leveled production costs are realized for the Jameson/packed column than for the circuit-optimized approach (\$0.125 vs. \$0.142/MMBtu) despite the fact that no change has taken place in its performance. This improvement in leveled production costs results from increasing the coarse coal yield which was made possible by the low ash product from the advanced flotation circuit. In Table 70 the leveled incremental costs given in Table 68 and Table 69 are subdivided into the three major cost categories for coal cleaning processes in order to analyze them more thoroughly:

- Energy loss: loss of heating value in the refuse
- Operating costs: annual costs associated with circuit operations
- Capital costs: costs for construction of the circuit.

The operating costs are in the range of \$0.054-\$0.071/MMBtu and the capital costs are in the range of \$0.043-\$0.062/MMBtu. The major difference in costs is related to the energy loss costs. The energy loss cost is calculated on a net plant loss basis. It is determined by calculating the loss of energy content from the flotation circuit minus the incremental energy recovered from the coarse circuit by raising the media gravity. It reflects the full impact of installing each flotation circuit on annual energy losses from the plant. The energy losses are high for the Outokumpu cell because of the relatively high-ash product (8% vs. 7.5% ash from a conventional circuit) produced which results in an additional loss of coal from the coarse coal circuit. The lowest energy loss, on a plant-wide basis, is for the Jameson/packed column circuit which has both high recovery and low product ash.

**Table 70. Levelized Incremental Cost Breakdown**

	Conventional Flotation	Jameson	Outokumpu	Open Column	Packed Column	Jameson/ Packed Column	Jameson/ Open Column	Outokumpu/ Packed Column	Outokumpu/ Open Column
Btu loss cost, \$/MMBtu	0.107	0.022	0.130	0.023	0.031	0.014	0.028	0.101	0.066
Operating cost, \$/MMBtu	0.054	0.066	0.055	0.065	0.055	0.062	0.071	0.061	0.066
Capital cost, \$/MMBtu	0.045	0.059	0.043	0.046	0.045	0.050	0.062	0.047	0.057
Btu loss cost, % of total	52.2%	15.3%	57.0%	17.1%	23.6%	11.1%	17.3%	48.2%	35.1%
Operating cost, % of total	26.1%	44.7%	24.2%	48.6%	42.4%	49.0%	44.1%	29.1%	34.7%
Capital cost, % of total	21.7%	40.1%	18.8%	34.3%	34.1%	39.9%	38.6%	22.7%	30.2%

Optimal operation of the flotation circuit has been shown to depend on the properties of the coal and operation of the other circuits. The plant model used in this analysis is representative of the plant conditions for the project coal sample. However, as described in the following section, changing the coal property assumptions alters the conditions for optimal flotation operations.

## 7.7 Sensitivity Analysis

The process economics for each circuit are based on a number of estimates and assumptions. Both cost and process parameter assumptions can have a significant impact on levelized costs.

In an effort to better quantify the effect of these assumptions, two series of sensitivity analyses were performed. First, changes in capital and operating costs are considered, followed by changes in the plant parameters used in the economic model.

A two-stage Jameson/packed column configuration was selected to conduct the sensitivity analysis for capital and operating costs. The base case costs (shown in Table 67) were \$1.2 million for capital costs and \$0.732 million for annual operating costs, which led to a leveled incremental cost of \$0.125/MMBtu. These costs have been varied as shown in Table 71 to assess the change in incremental leveled cost. An increase of \$200,000 in the capital costs or an increase of \$150,000/yr in operating costs results in an increase in the leveled incremental costs by \$0.01/MMBtu. These changes are equivalent to a 17% and 20% increase in the capital and operating costs, respectively. The capital and cost estimate would be expected to be in this range or have a  $\pm$  \$0.01/MMBtu incremental leveled cost.

**Table 71. Capital and Operating Cost Sensitivity**

	Base Case	Capital Cost Change			Operating Cost Change		
		+200K	+400K	-200K	+100K	+200K	-100K
Levelized Incremental Cost, \$/MMBtu	0.125	0.135	0.145	0.114	0.132	0.140	0.117

The second sensitivity analysis to be considered is the impact of plant parameters. The plant parameters are an integral part of the optimization process because the parameters indirectly determine the optimal grade/recovery operating point for the flotation circuit. On average, the clean coal quality at the Emerald mine coincides with the product specifications (13,000 Btu/lb (as-received) at 8% moisture). However, to construct a plant model several assumptions were required that are not normally measured, such as minus 100-mesh clean coal moisture. Parameter estimates were based on available plant data and experience at similar coal preparation plants where necessary. In an effort to better understand the plant-optimized process, a sensitivity analysis was performed to evaluate the effects of moisture and ash distribution assumptions on the optimal energy recovery from the fines circuit.

The plant parameter sensitivity analysis requires prediction of fine coal flotation over a wide range in energy recovery. The bench-scale data provide a measure of the grade/recovery curve for each of the circuits considered but do not provide a consistent trend for this relationship over the required range needed for sensitivity analysis to ensure optimal operations. A two-stage flotation model has been constructed to estimate flotation circuit performance as a means of providing a consistent grade/recovery relationship. The model assumes that the Jameson cell is used for the first stage and a column cell is used for the second stage. The column cell could be either an open or a packed column since the performance of these cells was essentially the same except that the packed column was operated at a slightly lower energy recovery point (with lower clean coal ash) than the open column during testing of second-stage operation.

The two-stage model first uses the raw coal washability to define the raw coal grade/recovery relationship (Figure 29). The recovery from the Jameson cell (first stage) is then related to frother concentration, as shown in Figure 30. The column cell recovery is modeled as a function of cell residence time and frother concentration. The range of frother concentration considered was 6-16 ppm and the range of residence time was 1-6 minutes. The column model is based on first-order flotation kinetics with the flotation rate constant set proportional to frother concentration. The model was fitted to the bench-scale column test results for the tailings coal sample by adjustment of two model constants. Using the given residence time and frother concentration, the column recovery is computed. The total circuit recovery is then computed and the total circuit product coal ash is determined by using the raw coal model. The coal quality of the second-stage product is then determined as the difference between the total and first-stage performance. An example of how the model second-stage performance changes as a function of residence time is given in Figure 31. The importance of frother concentration for the second-stage column cell is depicted in Figure 32 with the residence time set to 4 minutes.




Figure 29. Model Raw Coal Energy Recovery vs. Clean Coal Ash




Figure 30. Model First-Stage Recovery vs. Frother Concentration




Figure 31. Model Second-Stage Column Recovery vs. Residence Time




Figure 32. Model Column Recovery vs. Frother Concentration

The model was used to derive fine coal circuit performance for six cases of preparation plant model parameters. The cases shown in Table 72 represent six combinations of water and ash assumptions that produce 13,000 Btu/lb clean coal using a 1.6 separating gravity in the coarse coal circuit and conventional fine coal flotation. High and low fine coal moisture are evaluated in cases 1 and 3. For example, in case 1, the fine coal moisture is assumed to be 24.9% which requires an increase in the coarse coal moisture to 5% to achieve an 8% total product moisture. Cases 4-6 evaluate the effect of lowering the coarse coal product ash from 6.6% to 6.25% at a 1.6 separating gravity. A base case for the decreased coarse coal ash scenario is established by raising the conventional fine coal flotation recovery to 90% at 9.0% ash to again achieve the 13,000 Btu/lb total product specification. The three levels of fine coal moisture are repeated for the new ash assumptions.

For each sensitivity case, a range of frother dosage (6-16 ppm) and column cell residence times (1-6 minutes) was evaluated. The conditions that produce the lowest levelized costs for each case have been tabulated in Table 72.

Table 72. Plant Parameter Sensitivity Analysis

	Case One	Case Two	Case Three	Case Four	Case Five	Case Six (a)	Case Six (b)
Fine coal moisture, %	24.9	28.4	31.4	24.9	28.4	31.4	31.4
Coarse coal moisture, %	5.0	4.5	4.0	5.0	4.5	4.0	4.0
Coarse coal F1.6 ash, %	6.6	6.6	6.6	6.25	6.25	6.25	6.25
Levelized product cost Incremental, \$/MMBtu	0.128	0.131	0.125	0.06	0.073	0.073	0.073
Optimal conditions:							
Frother concentration, ppm	7	6.5	6	8	6.5	6	7.5
Residence time, min.	4	4	4	6	6	6	4
Clean coal ash, %	4.9	4.7	4.5	5.5	5.3	5.2	5.0
Energy recovery, %	90	88	86	95	93	92	91

The results indicate that the optimal fine coal recovery changes depending on the plant parameters. Increasing the fine coal moisture leads to lower optimal energy recovery (see recovery trends for cases 1-3 and 4-6). When the ash content of the coarse coal is assumed to be lower, the optimal recovery from the fine coal circuit increases (cases 4-1, 5-2, and 6-3) and higher separating gravities are used in the coarse coal circuit resulting in lower levelized costs. The column cell residence time is related to the optimal energy recovery and increases from 4

to 6 minutes when recoveries above 90% are optimal. The frother dosage was low, ranging from 8 ppm to 6 ppm. The simulation suggests that the best method for increasing coal recovery is by increasing residence time and maintaining frother dosage below a level of about 8 ppm.

Since the above analysis is based on empirical simulation of a two-stage circuit, the absolute values of the model outputs, such as residence time, may not be accurate but the trend in outputs, such as optimal energy recovery decreasing with higher fines moisture is valid.

Although the base case is assumed to be the most accurate estimation of the plant conditions, these parameters are not expected to be constant during plant operations. In Section 3, conventional flotation data were shown where the product ash ranged from 6% to 9.5%. The coarse coal cumulative float 1.6 ash is known to vary. Recent drill core data suggest that the range for this ash value is 5.7% to 7.1% (12 samples). Therefore, the optimal flotation recovery over time will change with changing plant conditions. This illustrates the need for control of the flotation circuit recovery. For continuous optimal operations, the flotation circuit must be capable of achieving efficient separations over a wide range in recovery. The sensitivity analysis suggests that the recovery range required is 86% to 95% with a lower limit of 80% to 85%, given that the model becomes less accurate at lower frother concentrations because of limited test data in this region.

## 8.0 TWO-STAGE OPERATION

One of the major objectives of this project is to evaluate the use of two-stage circuits for an optimal flotation circuit design. The premise of the project is that column cells are froth mass loading-limited and cannot be operated at maximum feed velocities for relatively low-ash feed coals such as the Pittsburgh seam. The test work completed by Pyramid has shown that the open column is indeed froth mass loading-limited when processing the raw coal fines at 3% solids. Their work also shows that feed velocities can be substantially increased, from 1 cm/s to 1.84 cm/s, and possibly as high as 4.5 cm/sec, when a portion of the clean coal is recovered in a first-stage flotation step. The packed column tests are less conclusive with regard to froth mass loading since the maximum froth mass loading could not be determined for the 12-ft tall test column due to feed pump limitations. The test work did demonstrate that a high froth mass

loading of 2.4 tph/m<sup>2</sup> (4 gm/min/cm<sup>2</sup>) was possible with a feed velocity of 3 cm/sec for a raw coal feed. These results suggest that it is possible to devise a two-stage circuit in which both the column froth mass loading and feed velocities (residence times) are maximized by appropriate use of a two-stage circuit.

Economical use of a two-stage circuit requires that the feed velocities be higher in both flotation steps than for a comparable single-stage operation while achieving high energy recovery. Increasing the feed velocity in the first stage was shown to lead to higher froth loadings in the tests on the Outokumpu cell, where feed rates of 75.6 l/min (20 gpm) produced approximately 1.9 g/min/cm<sup>2</sup> loadings and feed rates of 94.5 l/min (25 gpm) produced about 2.5 g/min/cm<sup>2</sup>, or a proportional increase in coal recovery. The high capacity tests for the Jameson cell resulted in a substantial increase in froth mass loading (4.5 vs. 1.7 gm/min/cm<sup>2</sup>) while producing a clean coal product containing less than 4% ash. As previously noted, the tailings sample tests completed indicate that feed velocities can be also be increased for second stage operations, where residence time considerations are the constraint on capacity.

Another issue concerning two-stage operations is the consumption of reagents. A hypothesis of this project was that reagent consumption for two-stage operations could be reduced compared to a single-stage operation. The rationale for this hypothesis was that high proportion of the fine low-ash coal particles could be floated in the first stage with a small amount of reagents. Removal of this low-ash coal fraction would then allow the reagent dosage to be set appropriately for the more difficult-to-float particles in the second stage, leading to a net reduction in total reagent consumption. The two-stage Jameson cell tests showed that very high energy recoveries are possible (96%) with little or no additional reagent. Definitive confirmation of this hypothesis can only be obtained by testing a two-stage circuit directly (as is planned for the POC module). However, the test results to date are consistent with this hypothesis given the low frother concentrations (10 ppm) used in the second-stage tests.

The economics of two-stage operations, presented in Sections 6 and 7, is based on an increase in feed velocities to each stage compared to single-stage operations. In the case of the Jameson cell the feed velocity is increased from 1.3 to 4 cm/s. In the case of a column second stage, the feed velocity is increased from about 1 cm/sec to 2-4 cm/sec.

The two-stage circuits achieved the lowest levelized costs. The capital cost, however, is about \$115,000 higher than that of the best single-stage operation. This suggests favorable overall economics for the two-stage operation. However, this is a very tentative analysis and two-stage pilot-scale tests must be conducted to demonstrate the validity of this concept.

## 9.0 EQUIPMENT SELECTION

The primary objective of the bench-scale test work was to provide data required to select the two most appropriate flotation machines for further testing at the pilot scale. During the in-plant POC pilot-scale tests, these machines will be fully characterized in single- and two-stage operations. The criteria established at the start of the project for development of a two-stage circuit were that it should:

1. Achieve a low-ash product from the first stage with high froth mass loading
2. Achieve an efficient separation in the second stage given a high-ash, dilute feed
3. Minimize operating and capital costs on a levelized cost basis.

The objective of Task 5 was to select either the Jameson or the Outokumpu cell as the first-stage flotation machine and either the packed or open column cell as the second-stage machine. After reviewing the performance data and related economics, the flotation machines and circuits recommended for pilot testing are:

- Single-stage Jameson cell
- Single-stage packed column
- First-stage Jameson cell, second-stage packed column.

The Jameson cell has been selected for the first stage based on its good performance and low operating costs since it does not require compressed air. It has also demonstrated the potential for being used as a first-stage machine by achieving the highest froth mass loading levels measured while producing a 4% ash product.

In general, the performance of both the open and packed columns was very good. Both cells achieved good process separations and demonstrated the potential for high-capacity operations with dilute feed slurries (second-stage feed conditions). Both cells were capable of producing a product with less than 4% ash from a raw coal feed. The packed column, however,

demonstrated a higher capacity with the raw coal feed with corresponding higher froth mass loadings. The open column achieved higher recoveries with the high-ash feed coal (second-stage feed) but also required longer residence times than the packed column. It appears that both cells had a similar product ash/recovery relationship for the high-ash second-stage feed, and the two-stage economics for both cells is excellent. The packed column was selected in favor of the open column because of its:

- Potential for achieving high froth mass loading levels
- Potential for process control via regulation of froth depth
- Enhanced process separation efficiency when producing a low-ash product.

The packed column achieved twice the froth mass loading of the open column cell and has the potential for higher loadings. The froth depth can be adjusted over a wider range of operation than with the open column and was demonstrated to operate with depths up to 84 inches. The packed column produced the lowest ash product from the tailings sample. Overall, the packed column will provide a greater degree of testing flexibility because it can be operated over a wide range of energy recovery values at near theoretical efficiency. This is important since the economics indicated that the optimal energy recovery depends on coal parameters that have been shown to vary. Therefore, continuous optimal circuit operation will require control of energy recovery over a range of 95% to 85% and possibly as low as 80% in response to changing plant conditions.