


1995 INEL National Emission Standard for Hazardous Air Pollutants - Radionuclides

*Annual Report
June 1996*

RECEIVED
AUG 22 1996
OSTI



EH

MASTER

Idaho National Engineering Laboratory

U.S. Department of Energy • Idaho Operations Office



DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

RP

DISCLAIMER

**Portions of this document may be illegible
in electronic image products. Images are
produced from the best available original
document.**

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

**1995 Idaho National
Engineering Laboratory (INEL)
National Emission Standards
for Hazardous Air Pollutants
(NESHAPs) - Radionuclides
Annual Report**

June 1996

**U.S. Department of Energy
Idaho Operations Office**

U. S. DEPARTMENT OF ENERGY
RADIONUCLIDE AIR EMISSIONS ANNUAL REPORT
(under Subpart H of 40 CFR 61)
CALENDAR YEAR 1995

Site Name: Idaho National Engineering Laboratory

Operations Office Information

Office: Department of Energy - Idaho Operations Office
Address: 785 DOE Place
Idaho Falls, Idaho 83401
Contact: John Medema
Phone: (208) 526-1407

Site Information: For information regarding facilities on the INEL, contact the Idaho Operations Office above.

TABLE OF CONTENTS

ACRONYMS	vii
EXECUTIVE SUMMARY	ix
I. FACILITY INFORMATION	1
Site Description	1
Area and Source Descriptions	4
II. AIR EMISSIONS DATA	12
III. DOSE ASSESSMENTS	31
Summary	31
Description of Dose Model and Summary of Input Parameters	35
Compliance Assessment	37
Operational Area Modeling	48
IV. CONSTRUCTION/MODIFICATION PROJECTS	50
V. REFERENCES	51

APPENDICES

A. Naval Reactors Facility Radionuclide Air Emissions Report	A-1
B. INEL Research Center Report	B-1
C. 1995 Meteorology Data for CAP-88 Computer Code	C-1
D. Input Parameter Values for CAP-88 Computer Code	D-1
E. Supplemental Information	E-1

FIGURES

1. Idaho National Engineering Laboratory and major facilities.	2
2. ANL-W Emission Sector Map.	38
3. CFA Emission Sector Map.	39
4. ICPP Emission Sector Map.	40
5. NRF Emission Sector Map.	41
6. PBF Emission Sector Map.	42
7. RWMC Emission Sector Map.	43
8. TAN Emission Sector Map.	44
9. SMC Emission Sector Map.	45
10. TRA Emission Sector Map.	46

TABLES

II-1.	ANL-W Radiological Air Emission Sources which had Emissions in CY 1995	14
II-2.	CFA Radiological Air Emission Sources	15
II-3.	ICPP Radiological Air Emission Sources	16
II-4.	PBF Area Radiological Air Emission Sources	18
II-5.	RWMC Radiological Air Emission Sources	19
II-6.	TAN Radiological Air Emission Sources	20
II-7.	TRA Radiological Air Emission Sources	21
II-8.	Point Source Radionuclides (Continuously Compliance Monitored Sources) From INEL Facilities During 1995	22
II-9.	Point Source Radionuclides (All Other Release Points) From INEL Facilities During 1995	23
II-10.	Non-Point Source Radionuclides (Diffuse Emission Sources) from INEL Facilities During 1995	25
III-1.	Summary of Annual Effective Dose Equivalents from Continuously Compliance Monitored Release Points at INEL	32
III-2.	Summary of 1995 Annual Effective Dose Equivalents from Other Release Points at INEL	33
III-3.	Summary of 1995 Effective Dose Equivalents from Diffuse Sources at INEL	34
III-4.	Sources of Wind Data for 1995 CAP-88 Atmospheric Dispersion Modeling of Releases from INEL Facilities	36
III-5.	INEL Stack Data for Releases Modeled as Stack Releases	36
III-6.	MEI Determination Table	47

APPENDICES TABLES

B-1.	40 CFR 61 Appendix E Compliance Table	B-1
C-1.	Meteorology Data Used for 1995 ANL Ground Level Releases	C-1
C-2.	Meteorology Data Used for 1995 ANL Elevated Releases	C-2
C-3.	Meteorology Data Used for 1995 CFA Releases	C-3
C-4.	Meteorology Data Used for 1995 ICPP Ground Level Releases	C-4
C-5.	Meteorology Data Used for 1995 ICPP Elevated Releases	C-5
C-6.	Meteorology Data Used for 1995 NRF Releases	C-6
C-7.	Meteorology Data Used for 1995 PBF Releases	C-7
C-8.	Meteorology Data Used for 1995 RWMC Releases	C-7
C-9.	Meteorology Data Used for 1995 TAN Ground Level Releases	C-8
C-10.	Meteorology Data Used for 1995 TAN Elevated Releases	C-9
C-11.	Meteorology Data Used for 1995 TRA Releases	C-10
D-1.	Input Parameter Values for CAP-88 Computer Code	D-1

ACRONYMS

ANL	Argonne National Laboratory
ANL-W	Argonne National Laboratory - West
ATR	Advanced Test Reactor
CAM	constant air monitor
CFA	Central Facilities Area
DOE	Department of Energy
DOE-ID	Department of Energy, Idaho Operations Office
DU	depleted uranium
EBR-II	Experimental Breeder Reactor-II
EDE	effective dose equivalent
FASB	Fuel Assembly and Storage Building
FAST	Fluorinel and Storage Facility
FCF	Fuel Conditioning Facility
FMF	Fuel Manufacturing Facility
HEPA	high-efficiency particulate air
HFEF	Hot Fuel Examination Facility
HLW	high-level waste
HP	health physics
HPIIL	Health Physics Instrumentation Laboratory
HVAC	heating, ventilating, and air conditioning
ICPP	Idaho Chemical Processing Plant
INEL	Idaho National Engineering Laboratory
IRC	INEL Research Center
LITCO	Lockheed Idaho Technologies Company
MDF	Materials Development Facility
MEI	maximally exposed individual
MTR	Material Test Reactor
NESHAPs	National Emission Standards for Hazardous Air Pollutants
NRF	Naval Reactors Facility
PBF	Power Burst Facility
PEW	Process Equipment Waste
PNR	Pittsburgh Naval Reactors
PRF	Process Reclamation Facility
RAL	Remote Analytical Laboratory
RESL	Radiological and Environmental Sciences Laboratory
RLWTF	Radioactive Liquid Waste Treatment Facility
RWMC	Radioactive Waste Management Complex
RWMIS	Radioactive Waste Management Information System
SCMS	Sodium Component Maintenance Shop
SDA	Subsurface Disposal Area
SMC	Specific Manufacturing Capability
SNF	spent nuclear fuel
SWEPP	Stored Waste Examination Pilot Plant
TAN	Test Area North
TRA	Test Reactor Area
TREAT	Transient Reactor Test Facility
TSA	Transuranic Storage Area

ACRONYMS (continued)

TSF	Technical Support Facility
WEC	Westinghouse Electric Corporation
WERF	Waste Experimental Reduction Facility
WIPP	Waste Isolation Pilot Plant
WROC	Waste Reduction Operation Complex
ZPPR	Zero Power Physics Reactor

EXECUTIVE SUMMARY

Under Section 61.94 of Title 40, Code of Federal Regulations (CFR), Part 61, Subpart H, "National Emission Standards for Emissions of Radionuclides Other Than Radon From Department of Energy Facilities," each Department of Energy (DOE) facility must submit an annual report documenting compliance. This report addresses the Section 61.94 reporting requirements for operations at the Idaho National Engineering Laboratory (INEL) for calendar year 1995. The Idaho Operations Office of the DOE is the primary contact concerning compliance with the National Emission Standards for Hazardous Air Pollutants (NESHAPs) at the INEL.

For calendar year 1995, airborne radionuclide emissions from INEL operations were calculated to result in a maximum individual dose to a member of the public of 1.80E-02 mrem (1.80E-07 Sievert). This effective dose equivalent (EDE) is well below the 40 CFR 61, Subpart H, regulatory standard of 10 mrem per year (1.0E-04 Sievert per year).

This report was prepared using the format suggested by DOE Headquarters. Section I provides an overview of INEL facilities and a brief description of the radioactive materials and processes at the facilities. Section II identifies radioactive air effluent release points (i.e., vents and stacks) and diffuse sources at the INEL and actual releases during 1995. Section II also describes the effluent control systems for each potential release point. Section III provides the methodology and EDE calculations for 1995 INEL radioactive emissions. Section IV provides information regarding construction or modification activities that occurred during 1995. Appendix A contains information specific to the Naval Reactors Facility (NRF) located within the INEL reservation. However, the EDE information for NRF is reported in the EDE for the INEL in order to demonstrate INEL compliance with the 40 CFR 61, Subpart H, dose standard of 10 mrem per year (1.0E-04 Sievert per year). Appendix B contains information specific to the INEL Research Center (IRC) because the IRC is not part of the INEL's contiguous site (per the NESHAP's definition of "facility"). Appendices C and D provide supporting documentation used as input parameters for the CAP-88 computer code. Data, calculations, model runs, and other documentation used to develop this report are maintained on file at the INEL in accordance with 40 CFR 61.95.

I. FACILITY INFORMATION

Site Description

The Idaho National Engineering Laboratory (INEL) of the Department of Energy (DOE) was established by the Federal Government in 1949 to conduct research and further the development of nuclear reactors and related equipment. Major DOE Programs at the INEL include test irradiation services, waste management, light-water-cooled reactor safety testing and research, operation of research reactors, environmental restoration, and naval reactor training programs. The INEL is operated for DOE by various contractors. Major contractors at INEL include Lockheed Idaho Technologies Company (LITCO), Westinghouse Electric Corporation (WEC), and Argonne National Laboratory (ANL). These contractors conduct the various INEL programs under the administration of three DOE field offices: the Idaho Operations Office (DOE-ID), the Chicago Operations Office (DOE-CH), and the Pittsburgh Naval Reactors Idaho Branch Office (PNR). DOE-ID is the primary contact concerning compliance with the National Emission Standards for Hazardous Air Pollutants (NESHAPs) at the INEL.

The INEL encompasses approximately 890 square miles on the upper Snake River Plain in southeastern Idaho (Figure 1). Nearest INEL boundaries to population centers are approximately 22 miles west of Idaho Falls, Idaho, 23 miles northwest of Blackfoot, Idaho, 44 miles northwest of Pocatello, Idaho, 7 miles east of Arco, Idaho, and 1 mile north of Atomic City, Idaho. In addition, individual farms and ranches are located near the INEL boundaries. These receptors represent the locations used for demonstration of compliance with the NESHAPs' dose standard of 10 mrem per year effective dose equivalent (EDE). Section III provides information concerning distances from INEL emission sources to these locations and population densities from each operational area.

Climatology of the INEL is characterized as semi-arid. The location of the INEL in a relatively flat valley surrounded by mountains, coupled with its approximately 5000-foot altitude, affects its overall climate and day-to-day weather systems. Air masses entering the Snake River Plain from the west have lost most of their moisture to precipitation before passing over the INEL. Therefore, annual precipitation at the INEL is light. The orientation of the Snake River Plain and bordering mountain ranges channel the winds so that a southwest wind predominates over the INEL. The second most frequent winds are from the northeast.

LEGEND

-  Bureau of Land Management/Grazing
-  National Forest Land
-  Private Land - Non-Cultivated
-  Private Land - Cultivated
-  State Land
-  Mountains & Buttes
-  State Roads
-  INEL Roads
-  Streams
-  INEL Boundary




Figure 1. Idaho National Engineering Laboratory and major facilities.

The annual average air temperature at the INEL [measured at the Central Facilities Area (CFA)] is 42.0 degrees Fahrenheit (5.6 degrees Celsius) with extremes of -47 degrees Fahrenheit (-44 degrees Celsius) and 101 degrees Fahrenheit (38 degrees Celsius). The average annual wind speed at CFA (20-ft level) is 7.5 mph (3.4 meters per second). The minimum average monthly wind speed of 5.1 mph (2.3 meters per second) occurs in December, and the maximum average monthly wind speed of 9.3 mph (4.2 meters per second) occurs in April and May. Calm conditions prevail approximately 11 percent of the time (Clawson et al. 1989).

Average annual precipitation over the INEL (as measured at CFA) is approximately 9 inches. Yearly totals have ranged from 4.5 inches to 14.4 inches. A portion of this precipitation is received as snowfall, which averages 28 inches per year (Clawson et al. 1989).

Topography of the INEL is representative of the upper Snake River Plain as a whole. The INEL surface is a combination of basalt, eolian and alluvial sedimentary deposits. Vegetation and wildlife on the INEL are typical of a cool, desert shrub biome.

The INEL is subject to 40 CFR 61, Subpart H, "National Emission Standards for Emissions of Radionuclides Other Than Radon From Department of Energy Facilities." While the INEL consists of a variety of operations spread over the 890-square-mile reservation, for purposes of compliance demonstration with the 40 CFR 61, Subpart H, dose standard of 10 mrem per year, the INEL is defined as one facility. The final rule promulgating 40 CFR 61, issued December 15, 1989, specified ". . . that all buildings, structures and operations within one contiguous site shall be considered a single facility."

Operations that potentially emit radionuclides are located at various areas on the INEL and can be grouped into eight distinct locations on the INEL:

- Argonne National Laboratory - West (ANL-W)
- Central Facilities Area (CFA)
- Idaho Chemical Processing Plant (ICPP)
- Naval Reactors Facility (NRF).
- Power Burst Facility (PBF) area, including the Waste Reduction Operation Complex (WROC)
- Radioactive Waste Management Complex (RWMC)
- Test Area North (TAN), which encompasses the Specific Manufacturing Capability (SMC) operation
- Test Reactor Area (TRA)

Figure 1 shows the location of these areas at the INEL. A more detailed description of each of these areas, excluding the NRF, is provided below. The NRF area description is in Appendix A of this report.

Area and Source Descriptions

Argonne National Laboratory - West

The ANL-W site is located on the southeastern corner of the INEL in Bingham County, Idaho. ANL-W is operated for the US Department of Energy by the University of Chicago through the US DOE Chicago Operations Office. ANL-W is a research facility which has contributed significantly to knowledge advancements in liquid metal fast breeder reactor technology and extreme condition fuels and reactor materials behavior

The Experimental Breeder Reactor-II (EBR-II) is being defueled and did not operate in CY1995. The reactor building is still being ventilated and monitored. The continuous monitoring is supplemented with post-filtration sampling and analysis for particulates. CY1995 ancillary emissions associated with EBR-II operations included limited cover gas pressure releases for maintenance purposes and characterization of potential emissions from a suspect waste tank and fumehood. Characterization of these ancillary emissions for CY1995 reporting purposes relied on active sampling and conservative industry standard release calculation methodologies.

The Fuel Conditioning Facility (FCF) conducted operations in CY1995 with only non-irradiated surrogate test materials. The facility is constantly ventilated. The ventilation stream of FCF is filtered and combined with the filtered and previously monitored EBR-II ventilation stream and collectively continuously monitored for all potentially-present radiological emissions. The continuous monitoring is supplemented with sampling and analysis for particulates, radioiodines and typically gaseous radionuclides. Emissions from FCF during CY1995 are reported herein.

The Hot Fuel Examination Facility (HFEF), completed and operating since 1975, houses two large shielded hot cells, one each with air and inert atmospheres. At the present time, HFEF examination capabilities are being used to characterize mixed wastes within the DOE complex. HFEF emissions are filtered and continuously monitored for all types of potential radiological emissions. The continuous monitoring is supplemented with continuous sampling and subsequent analysis for particulates and radioiodines (both of which typically yield collections below detection limits) and monthly hot cell grab sampling for typically gaseous radionuclides. Particulate emissions from HFEF during CY1995 are reported herein. Longer-lived gaseous fission product Kr-85 exists in the HFEF inert atmosphere cell and was released in minor amounts as

a result of keeping the inert atmosphere cell at a negative pressure. Finally, the small quantity of activation product Ar-41 released from HFF during CY1995 is also reported herein.

The Fuel Manufacturing Facility (FMF) began operation in 1986 as a specialized facility built to cast uranium based fuels for DOE-complex sodium cooled reactors. Some 13 casting operations were conducted in CY1995 principally in support of experimental activities using either stainless steel or rare-earth doped depleted uranium. The FMF building is constantly ventilated with its emissions being sampled and analyzed for particulate characterization, the CY1995 results of which are reported herein.

The Transient Reactor Test Facility (TREAT) did not operate in CY1995. The building ventilation system was operated only a few hours a month to keep the fan bearings lubricated. The ventilation system is sampled and analyzed for particulates whenever the fans are operated even when the reactor has not been operating. The particulate results reported this year for this stack are from that few hours a month of building ventilation for equipment maintenance purposes.

The Laboratory and Office Building (L&O) houses the majority of ANL-W's chemical and radiological analytical capabilities. The main hot cell which vents through the L&O main stack was completed in 1964 and is equipped to conduct destructive assays of irradiated fuel and therefore serves as a potential point of release for particulate and longer-lived gaseous fission products. The L&O main stack is actively monitored and sampled for particulate characterization. The Nondestructive Assay (NDA) wing of the L&O Building was completed in 1976. Only particulate matter has the potential of being in the NDA ventilation stream which is filtered and sampled for particulate characterization. The CY1995 sampling results from both stacks are reported herein.

The Zero Power Physics Reactor (ZPPR) did not operate in CY1995. Though the reactor is not operating, the building is actively ventilated to minimize the buildup of naturally occurring Rn-222 progeny in the facility which results from Rn-222 diffusion into the facility from outside soil. The ventilation stream is still actively sampled and analyzed for particulate matter, the results of which are reported herein.

The Fuel Assembly and Storage Building (FASB) has been in use since 1972 as a multipurpose facility housing a variety of operations including storage of reactor hardware and blanket subassemblies, assembly of blanket elements and jackets, metallurgical laboratory operations including welding, electron microscope analyses and special sample preparations involving both irradiated and non-irradiated materials. This year's operations in FASB were principally limited to metallurgical work with nonfissile materials. The FASB building is constantly ventilated with its emissions being sampled and analyzed for particulates, the CY1995 results of which are reported herein.

The Sodium Components Maintenance Shop (SCMS), which began operations in 1977 as facility for cleansing sodium-laden parts taken from the EBR-II reactor for repair or replacement purposes, conducted 11 such washing operations in CY1995. Emissions from the washing process are sampled and analyzed for particulates with the results reported herein. A series of support tanks containing recycled contaminated ethanol used in the SCMS wash process are not expected to have releases. However, ANL-W very conservatively applies industry standard tank flow through analysis methodologies along with periodic ethanol grab sample analyses to determine worst case potential emissions from the support tanks.

The Radioactive Liquid Waste Treatment Facility (RLWTF), which began operation in 1982, received and evaporated 16 transfers of aqueous waste (12,680 gallons) from other ANL-W facilities in CY1995. All emissions were sampled and analyzed for particulates, the results of which are reported herein. All tritium emissions were characterized by liquid batch sampling with the presumption of 100% release in the form of tritiated water vapor.

Central Facilities Area

The CFA is located in the south-central section of the INEL and provides support services for the INEL. This area includes the DOE Radiological and Environmental Sciences Laboratory (RESL), the Environmental Science and Research Foundation (Foundation), maintenance shops, vehicle maintenance facilities, environmental monitoring and calibration labs, communications and security systems, fire protection, medical services, warehouses, and other support services facilities. With the exception of RESL and the Foundation, CFA is operated for DOE-ID by LITCO.

Minor releases occur from facilities at CFA where work is routinely conducted with small quantities of radioactive materials. This includes operations at RESL, the Environmental Chemistry Laboratory, and the Health Physics Instrumentation Laboratory (HPIL). RESL provides analytical services for environmental sampling programs. Only small (tracer) quantities of radioactive materials are used at this facility. The HPIL mainly uses sealed sources. Therefore, no routine emissions are associated with these operations. However, one hood is used approximately once per year for instrument decontamination at the HPIL.

Idaho Chemical Processing Plant

The ICPP is located in the south-central portion of the INEL. The facility was constructed in 1950 and is operated under DOE-ID administration by LITCO. The ICPP is a multipurpose plant containing approximately 230 buildings and structures.

The mission of the ICPP has changed significantly in light of the decision to discontinue reprocessing of spent nuclear fuel (SNF) in April 1992. Activities having radioactive emissions in 1995 at the ICPP are broken down into the following areas, which are discussed below:

- SNF Management
- Waste Management
- Technology Development

Spent Nuclear Fuel Management. Prior to 1992, SNF was shipped to the ICPP for temporary storage prior to reprocessing for uranium recovery. Although fuel reprocessing was discontinued, DOE and Navy fuel continues to arrive for storage. This fuel is transferred to storage until final disposition (e.g., placement in a geologic repository) and conditioning needs and methods have been determined.

Fuel receipt and storage areas include the Fuel Storage Building (CPP-603), the Fluorinel and Storage (FAST) Facility (CPP-666), the Underground Fuel Storage Facility (CPP-749), and the Unirradiated Fuels Storage Facility (CPP-651). CPP-603 has fuel handling units (FHUs) stored in water pools or in the dry Irradiated Fuel Storage Facility; currently CPP-666 has only wet storage; CPP-749 has only dry storage; and CPP-651 has dry unirradiated fuel storage. All fuel elements are in retrievable storage. No new fuel is being received and transferred into CPP-603 underwater storage basins.

The FAST facility stack (CPP 767-001) was redesignated to be a less than 0.1 mrem/yr (unabated) source during 1995. CY 1995 emissions for the FAST facility were based on the FAST Stack monitor. The remaining fuel storage facilities have a constant air monitor (CAM) that is used to determine air emissions, or air emissions are calculated based on process knowledge.

Waste Management. Interim storage space for high-level waste before calcination is provided by eleven 300,000-gal underground tanks (WM-180 to -190) and four 18,400-gal tanks (WL-101, WM-100, WM-101, and WM-102) housed in vaults at the north side of the Waste Disposal Building (CPP-604). WM-190 is the designated reserve tank if the other tanks leak. Additional storage can be provided by four 30,000-gal underground tanks (WM-103 to -106) that rest on concrete pads with curbing. These tanks are kept empty and are used only by special DOE authorizations for segregation of wastes from nonroutine campaigns. Emissions from these tanks are monitored via the Main Stack (CPP 708-001).

Calcination activities at the ICPP did not occur in 1995. In the calcining process, radioactive liquid mixed with calcium nitrate and sometimes aluminum nitrate is sprayed continuously into a fluidized bed calcining vessel, where the droplets contact hot solid particles. Water evaporates while acids and other compounds

decompose. Dissolved solids (i.e., metals and salts) are thus converted to dry, granular, calcined particles. This calcine is stored in stainless-steel bins contained in concrete vaults. Radiological air emissions from the first 3 bin sets are monitored via the Main Stack (CPP 708-001). Radiological air emissions from the remaining bin sets are negligible and are based on Constant Air Monitor (CAM) data. Particulate emissions from the calcining off-gas are continuously monitored through the Main Stack per 40 CFR 61 requirements. Emissions from the New Waste Calcining Facility processing cells and decontamination areas are also continuously sampled on the CPP-659 HVAC stack, although continuous monitoring is not required since air emissions are below the 0.1 mrem threshold for unabated emissions in 40 CFR 61.

Low-level radioactive liquid wastes are collected and concentrated in the Process Equipment Waste (PEW) Facility (CPP-604). The concentrate (e.g., bottoms) is then processed as a high-level (sodium-bearing) radioactive waste. The PEW overheads are processed through the Liquid Effluent Treatment and Disposal (LET&D) Facility where emissions are accounted for via the ICPP Main Stack.

Minor sources of radioactive emissions from waste management activities include the radiological and hazardous waste accumulation area (CPP-1617), unloading and transfer of low-level radioactive liquids from CPP-1619, the Anti-C/Safety Equipment Handling Facility, and small, miscellaneous emissions from radioactively contaminated buildings and liquids in tanks.

Fugitive (diffuse) emissions from the percolation ponds and the area inside and surrounding the ICPP are summarized in Table II-10 of this report.

Technology Development. LITCO technology development efforts support the objectives of safe and efficient interim storage of SNF and radioactive waste, as well as the development of a process or processes to ultimately prepare SNF and radioactive wastes for final disposal.

Most radioactive emissions from these activities are from laboratories and pilot plants in the CPP-602, CPP-627, CPP-637, and CPP-684 buildings. The largest emission among these facilities is from the Remote Analytical Laboratory (RAL, CPP-684).

Power Burst Facility Area

The PBF area is located in the south-central portion of the INEL. This area was originally used to support studies of nuclear reactors under normal and off-normal operating conditions. These studies were concluded in 1985 and the PBF area facilities have been modified to accommodate new missions or are no longer in use. The PBF Area is operated for the DOE-ID by LITCO.

The only potential sources of radioactive emissions in the PBF area are the PBF reactor and the Waste Experimental Reduction Facility (WERF). The PBF reactor is currently in a shutdown mode.

The WERF is an experimental facility for research and development of techniques for handling and reducing the volume of radioactive and mixed wastes. Operations at the WERF include metal sizing, compaction, incineration, and stabilization of radioactively contaminated wastes.

Emissions from the PBF area result from WERF operations and periodic maintenance activities at PBF, i.e., cleanup and decontamination activities. Emissions from WERF are extremely small and result from the processing of waste contaminated with fission and activation products. Emissions from the North and East Stacks, which ventilate the incineration and waste handling activities, are continuously monitored. Air emission data for calendar year 1995 from the PBF area are provided in Section II.

Radioactive Waste Management Complex

The RWMC was established in the southwest corner of the INEL in 1952 to accommodate the radioactive wastes generated by INEL operations. In addition to receipt of radioactive wastes generated at the INEL, the RWMC has also received wastes from other DOE facilities including the Rocky Flats Plant. The RWMC is operated for the DOE-ID by LITCO.

Areas at the RWMC include the Subsurface Disposal Area (SDA), the Transuranic Storage Area (TSA) and the Operations Area. Low-level radioactive wastes are disposed of in pits and vaults at the SDA. The TSA includes the Stored Waste Examination Pilot Plant (SWEPP), the Drum Vent Facility (DVF) and the Waste Storage Facilities (WSF). Transuranic wastes are stored on an interim basis at the TSA. At the SWEPP facility, transuranic wastes are examined by various non-destructive techniques. A Health Physics laboratory fume hood is located in the Operations Area. In addition, environmental restoration techniques are being investigated at the RWMC. Emissions from these sources are based on engineering calculations derived from process knowledge with the exception of the DVF which is based on a Constant Air Monitor (CAM).

Test Area North

The TAN complex is located at the north end of the INEL. TAN has been used for a variety of projects and currently has two major facilities: the Specific Manufacturing Capability (SMC) facility, and the Technical Support Facility (TSF) TAN Hot Shop. The TAN Hot Shop and the SMC facility are both operated for DOE-ID by LITCO.

The TSF TAN Hot Shop contains decontamination and hot cell areas: Operations include decontamination of radioactively contaminated equipment and remote examination of radioactive materials.

The SMC Project is a multi-phased manufacturing operation that produces an armor package for the U.S. Department of the Army. The Project was assigned to the INEL in mid-1983. Several existing facilities were modified and new facilities constructed to contain state-of-the-art manufacturing and processing equipment. The SMC Project consists of the Materials Development Facility (MDF), TAN-629 Fabrication and Assembly, TAN-679 Rolling Operation, and support facilities.

The MDF was established to support the identification, evaluation, and development of manufacturing processes for the SMC project. Operations involve fabrication and assembly work to produce test-size armor assemblies. Standard metal working equipment such as punches, shears, brakes, and lasers are used to fabricate depleted uranium (DU) material. Other activities include development of tools and fixtures, and preparation and testing of metallurgical specimens.

The TAN-629 facility, located within the TAN hangar, contains specific production unit areas and space for offices, support functions, and service areas. TAN-675 is located on the north side of the hangar and houses utilities. TAN-677 is located on the south side for truck receiving and controlled access to the facility.

Production units are semiautomatic systems that perform the same types of operations as MDF, except on an automated basis to produce full-size assemblies at a higher throughput. The DU parts are sheared, punched, laser cut, cleaned, and painted. The assemblies are packaged and shipped to their final destination.

The TAN-679 facility consists of a manufacturing area and a Process Reclamation Facility (PRF), TAN-681. TAN-679 operations include a process production line, office area, support functions, and service areas. DU material is processed and subsequently used as feedstock for TAN-629 operations. Processes include a preheat and hot roll operation, shearing to length and width, acid etching, water rinsing, and final inspection.

The PRF operations include the collection, recycling, and disposition of waste material. All contaminated liquid waste streams are collected in storage tanks for treatment/reuse.

Radiological air emissions from the TAN area are associated with the Hot Shop operations and the SMC. Potential emissions from the Hot Shop area include noble gases, iodines, and particulates. Emissions from this facility are operation specific and are not associated with any continuous process. Section II provides data on air emissions from the TAN Hot Shop area for calendar year 1995.

Radiological air emissions from SMC are associated with processing of DU. Potential emissions are uranium isotopes and associated radioactive progeny. Section II provides data on air emissions from the SMC for calendar year 1995.

Test Reactor Area

The TRA is located in the south-central section of the INEL near the ICPP. Operations at TRA are conducted by LITCO, under the administration of DOE-ID. The TRA has facilities for studying the performance of reactor materials and equipment components under high neutron flux conditions. The major facility at TRA is the Advanced Test Reactor (ATR). Other operations at TRA include hot cell operations, research and development, site remediation, and analytical laboratory services.

Radioactive emissions from the TRA are primarily associated with operation of the ATR. These emissions include noble gases, iodines, and other mixed fission and activation products. Other radioactive emissions are associated with hot cell operations, sample analysis, site remediation, and research and development activities. Air emission data for TRA are provided in Section II.

II. AIR EMISSIONS DATA

As discussed in Section I, the INEL contains a number of operations that have the potential to emit radionuclides. Tables II-1 through II-7 identify all stacks and vents at the INEL that represent potential radiological air emission sources. Data on NRF emission sources are provided in Appendix A. The tables are organized according to the major INEL operational areas described in Section I. The tables describe each potential emission point and the effluent controls and their efficiencies, if applicable. The tables also identify emission sources that require monitoring and/or sampling on a continuous basis.

The nearest receptor to the operational area is listed at the top of each table. This (in most cases) is not the one true INEL maximally exposed individual (MEI). Information on the INEL MEI, as well as location from these operational areas to the INEL MEI, can be found in section III of the report.

Not all potential radionuclide emission points are monitored on a continuous basis at INEL. Section 61.93(b) of 40 CFR 61, Subpart H, provides prescriptive requirements for continuous monitoring of those emission points that have a potential to emit radionuclides in quantities that could result in an EDE to a member of the public in excess of 1% of the NESHAPs' dose standard of 10 mrem (1.0E-04 Sievert) per year, i.e., 0.1 mrem (1.0E-06 Sievert) per year. In evaluating the potential of a release point to discharge radionuclides into the air for the purposes of this regulation, the estimated radionuclide release rates are based on the discharge of the effluent stream that would result if all pollution control equipment did not exist but the facility operations were otherwise normal [40 CFR 61.93(b)(4)(ii)]. All other potential emission sources require periodic confirmatory measurements to verify the low emissions.

In response to NESHAPs' requirements, the INEL conducted a study to determine radiological emission points subject to the 40 CFR 61.93(b) monitoring requirements. The methodology and results of the evaluation are presented in the report DOE/ID-10310, *NESHAPs 40 CFR 61.93 Monitoring Requirements for Radiological Emission Sources at INEL*, November 1990. A reassessment of all INEL emission sources was completed in 1992 at the request of EPA Region 10. In addition, INEL has implemented a "periodic confirmatory measurements" program in response to these 40 CFR 61.93(b) requirements.

The above evaluations identified six emission points that require continuous monitoring under 40 CFR 61.93(b). The six sources are: the ICPP Main Stack (CPP-708-001), the ICPP Fluorinel and Storage Facility Stack (CPP-767-001) [Note: This source was redesignated during 1995 as no longer requiring continuous monitoring under 40 CFR 61.93(b)], the WERF north stack (PER-755-001), the WERF east stack (PER-765-001), the HFEF main stack (ANL-785-001), and the ANL-W 200-ft stack (ANL-764-001). All other potential

emission points were determined to have potential EDEs of less than 0.1 mrem (1.0E-06 Sievert) per year (Actual emissions from these points are based on sampling and/or engineered calculations based on process knowledge).

Tables II-8 and II-9 list the point source radionuclide emissions for calendar year 1995 associated with each operational area at the INEL. Table II-8 lists emissions from all continuous compliance monitored sources, and Table II-9 lists the estimated radionuclide emissions from all other point sources. Table II-10 lists the non-point source radionuclide emissions for calendar year 1995 at the INEL.

In some cases, results shown in Table II-8 and Table II-9 are reported as gross alpha and gross beta. In these instances, these emissions were assumed to be plutonium-239 for gross alpha and strontium-90 in equilibrium with Y-90 for gross beta and gross beta/gamma. This conservative assumption was based on the fact that these two radionuclides have extremely low concentration values in Table 2 of 40 CFR 61, Appendix E. However, it is not expected that these isotopes are always present due to the nature of the varying operations at these INEL facilities.

Table II-1.

ANL-W Radiological Air Emission Sources which had Emissions in CY 1995

ARGONNE NATIONAL LABORATORY-WEST (ANL-W)				Nearest Reception - 8679 in SSE	
AREA	BLDG	VENT	SOURCE DESCRIPTION	EFFLUENT CONTROL DESCRIPTION	EFFICIENCY ^a
ANL	704	008	FUEL MANUFACTURING FACILITY (FMF) MAIN STACK	CASTING AREA - TWO HEPA FILTER BANKS IN SERIES GLOVE BOX AREA - TWO HEPA FILTER BANKS IN SERIES REMAINDER - HEPA FILTER BANK	99.97% EACH
ANL	752	004	MAIN LABORATORY AND OFFICE (L&O) BUILDING STACK	TWO HEPA FILTER BANKS IN SERIES	99.97% EACH
ANL	752	005	NONDESTRUCTIVE ASSAY LABORATORY STACK IN THE LABORATORY AND OFFICE (L&O) BUILDING	EFL AREA - TWO HEPA FILTER BANKS IN SERIES REMAINDER - HEPA FILTER BANK	99.97% EACH
ANL	764	001	FCF AND EBR-II REACTOR EMISSIONS EXHAUST THROUGH THIS 200-FOOT MAIN STACK	EBR-II - HEPA FILTER BANK FCF HOT CELL - TWO HEPA FILTER BANKS IN SERIES REMAINDER OF FCF - HEPA FILTER BANK	99.97% EACH
ANL	766	056	SECONDARY ARGON COVER GAS PURGE VENT	NONE	NONE
ANL	768	105	SUSPECT WASTE TANK FROM DECONTAMINATION SHOWER IN HEALTH PHYSICS AREA OF POWER PLANT	HEPA FILTER BANK	99.97%
ANL	768	108	HP AREA FUMEHOOD IN POWER PLANT	HEPA FILTER BANK	99.97%
ANL	777	002	ZPPR	REACTOR CELL - TWO HEPA FILTER BANKS IN SERIES REMAINDER - HEPA FILTER BANK	99.97% EACH
ANL	785	018	HOT FUEL EXAMINATION FACILITY (HFEF) MAIN STACK ^c	HOT CELLS - TWO HEPA FILTER BANKS IN SERIES REMAINDER - HEPA FILTER BANK	99.97% EACH
ANL	787	001	FUEL ASSEMBLY AND STORAGE BUILDING (FASB) MAIN STACK	HEPA FILTER BANK	99.97%
ANL	793	001	SODIUM COMPONENT MAINTENANCE SHOP (SCMS) MAIN STACK ^d	HEPA FILTER BANK	99.97%
ANL	793	027	TANK T-712, ALCOHOL STORAGE TANK VENT	NONE	NONE
ANL	798	017	RADIOACTIVE LIQUID WASTE EVAPORATOR EXHAUST	EVAPORATORS - TWO HEPA FILTER BANKS IN SERIES REMAINDER - HEPA FILTER BANK	99.97% EACH
ARGONNE NATIONAL LABORATORY-WEST (ANL-W) TRANSIENT REACTOR TEST (TREAT) FACILITY					
ANL	720	007	TRANSIENT REACTOR TEST FACILITY REACTOR COOLING AIR EXHAUST	TWO BANKS HEPA FILTERS IN SERIES	99.97% EACH

a. A single HEPA filter will remove 99.97% of particulates that are 0.3 microns in diameter.

b. Air emission sources that require continuous monitoring are based on an unabated emission potential of 0.1 microm兪 or greater.

c. Three exhaust systems contribute to this source:

(1) Building-Laboratory exhaust system passes through one bank of diethyl phthalate (DOP)-tested HEPA filters; 42,875 cfm.

(2) Main Cell exhaust flows through three banks of HEPA filters, only one bank of which is DOP-tested; 0,500 cfm.

(3) Decon Cell exhaust flows through three stages of HEPA filters, two stages of which are DOP-tested; 3030-3660 cfm.

d. Three ventilation systems contribute to the SCMS main stack exhaust:

(1) Water Wash vessel exhaust flows through one stage of DOP-tested HEPA filters.

(2) High Bay ventilation is also filtered by a single DOP-tested HEPA filter bank.

(3) Process ventilation is double (DOP-tested) HEPA filtered.

Table II-2. CFA Radiological Air Emission Sources

CENTRAL FACILITIES AREA (CFA)			Nearest Receptor - 14487 m SE		
AREA	BLDG	VENT	SOURCE DESCRIPTION	EFFLUENT CONTROL	DESCRIPTION
CFA	625	010	VENTS LABORATORY HOODS IN WHICH RADIOLOGICAL SAMPLES ARE PREPARED FOR CHEMICAL ANALYSIS	PRE-FILTERS HEPA FILTER BANK OF 9	99.97% each filter
CFA	633	067	HEALTH PHYSICS HOOD USED FOR DECONTAMINATION OF SMALL HEALTH PHYSICS INSTRUMENTS PRIOR TO CALIBRATION. NO RELEASE.	ONE HEPA FILTER WITH PRE-FILTER	99.97%
CFA	690	001	RADIOLOGICAL AND ENVIRONMENTAL SCIENCES LABORATORY (RESL)	NONE	NONE
CFA	690	002	RESL	NONE	NONE
CFA	690	003	RESL	NONE	NONE
CFA	690	004	RESL	NONE	NONE
CFA	690	005	RESL	NONE	NONE
CFA	690	006	RESL	NONE	NONE
CFA	690	007	RESL	NONE	NONE
CFA	690	008	RESL	NONE	NONE
CFA	690	009	RESL	NONE	NONE
CFA	690	010	RESL	NONE	NONE
CFA	690	015	RESL	NONE	NONE
CFA	690	042	RESL	NONE	NONE
CFA	690	045	RESL	NONE	NONE
CFA	690	047	RESL	NONE	NONE
CFA	690	049	RESL	NONE	NONE
CFA	690	059	RESL	NONE	NONE

a. A single HEPA filter will remove 99.97% of particulates that are 0.3 microns in diameter.

b. Air emission sources that require continuous monitoring are based on an unabated emission potential of 0.1 rem/yr or greater.

Table II-3. ICPP Radiological Air Emission Sources

IDAHO CHEMICAL PROCESSING PLANT (ICPP)				Nonref. Receptor - 17143 m ³ SSE		
AREA	BLDG	VENT	SOURCE DESCRIPTION	ÉMISSION/CONTROL DESCRIPTION	EFFICIENCY ^a	CONTINUOUSLY MONITORED ^b
CPP	601	024	HEXONE STORAGE AND FEED TANKS	NONE	NONE	
CPP	602	012	MAIN LAB EXHAUST FROM LABORATORY HOODS, GLOVE BOXES AND DENITRATOR IN BUILDING 602	HEPA FILTER OR TWO HEPA FILTERS IN SERIES	99.97% each filter	
CPP	602	014	LABORATORY 224 CAVE IN 602	HEPA FILTER	99.97%	
CPP	602	031	PERCHLORIC ACID HOOD EXHAUST IN 602	DEMISTER	NONE	
CPP	603	001	IFSF	HEPA FILTER	99.97%	
CPP	603	019	UNDERWATER FUEL STORAGE AREA	NONE	NONE	
CPP	627	007	VENTS LABORATORY HOODS AND RADIOACTIVE GLOVE BOXES (SPECIAL ANALYSIS LAB, ACID FUME HOODS)	HEPA FILTER OR TWO HEPA FILTERS IN SERIES	99.97% each filter	
CPP	627	008	SPECIAL ANALYSIS LABORATORY HOODS, EMISSIONS SPECTROSCOPY CAVE	TWO HEPA FILTERS IN SERIES	99.97% each filter	
CPP	627	010	MULTICURIE CELL	HEPA FILTER	99.97%	
CPP	627	013	HOT CHEMISTRY LAB HOODS, GLOVE BOXES - DECON DEVELOPMENT LAB	HEPA FILTER	99.97%	
CPP	627	016	LABORATORY AIR SAMPLING SYSTEM USED FOR WET CHEMISTRY OF RADIOACTIVE SAMPLES - FASS	HEPA FILTER	99.97%	
CPP	630	011	LABORATORY HOODS AND OTHER EXHAUSTS FROM LABS IN 630	TWO HEPA FILTERS IN SERIES	99.97% each filter	
CPP	630	012	LABORATORY HOODS AND EXHAUSTS FROM PART OF BUILDING 602 - 300 LABORATORIES	TWO HEPA FILTERS IN SERIES	99.97% each filter	
CPP	637	010	MAIN EXHAUST FOR ALL FUME HOODS IN LABORATORY SECTION OF BUILDING (7 LABS, 22 HOODS)	HEPA FILTER OR TWO HEPA FILTERS IN SERIES	99.97% each filter	
CPP	648	002	VENT FOR THE SLUDGE STORAGE TANK (VES-SFE-106) (NOT TESTED)	HEPA FILTER (NOT TESTED)	99.97%	
CPP	659	033	EXHAUSTS BUILDING VENTILATION AIR FROM THE CALCINER AND DECONTAMINATION AREAS.	TWO HEPA FILTERS IN SERIES	99.97% each filter	
CPP	663	002	663 HOT SHOP EXHAUST	HEPA FILTER	99.97%	
CPP	684	001	REMOTE ANALYTICAL LABORATORY (RAL)	TWO HEPA FILTERS IN SERIES	99.97% each filter	
CPP	694	007	TANK VENTS FOR ORGANIC SOLVENT STORAGE TANK ^c	TWO HEPA FILTERS IN SERIES	99.97% each filter	
CPP	694	008	TANK VENTS FOR ORGANIC SOLVENT STORAGE TANK ^c	TWO HEPA FILTERS IN SERIES	99.97% each filter	
CPP	694	009	EXHAUST VENTILATION AIR FROM THE ORGANIC SOLVENT STORAGE TANK BUILDING ^c	HEPA FILTER (NOT TESTED)	99.97%	
CPP	694	010	TANK VENTS FOR ORGANIC SOLVENT STORAGE TANK ^c	TWO HEPA FILTERS IN SERIES	99.97% each filter	

Table II-3. ICPP Radiological Air Emission Sources (continued)

IDAHO CHEMICAL PROCESSING PLANT (ICPP)				Nearest Receptor: 17143 m SSE		
AREA	BLDG	VENT	SOURCE DESCRIPTION	EFFLUENT CONTROL DESCRIPTION	EFFICIENCY	CONTINUOUSLY MONITORED?
CPP	708	001	CPP MAIN STACK INCLUDING THE NEW WASTE CALCINING FACILITY	HEPA FILTER OR UP TO THREE HEPA FILTERS IN SERIES	99.97% each filter	X
CPP	732	001	BIN SET #1 - VENTS THE VAULT SURROUNDING THE STORAGE BINS (NOT FILTERED). VAULT AREA NO LONGER A SOURCE. STORAGE BINS SINGLE HEPA-FILTERED IN POG APS.	NONE (VAULT) HEPA FILTER (BINS)	99.97%	
CPP	742	001	BIN SET #2 - VENTS THE VAULT SURROUNDING THE STORAGE BINS (NOT FILTERED). VAULT AREA NO LONGER A SOURCE. STORAGE BINS SINGLE HEPA-FILTERED IN POG APS.	NONE (VAULT) HEPA FILTER (BINS)	99.97%	
CPP	746	001	BIN SET #3 - VENTS THE VAULT SURROUNDING THE STORAGE BINS (NOT FILTERED). VAULT AREA NO LONGER A SOURCE. STORAGE BINS SINGLE HEPA-FILTERED IN POG APS.	NONE (VAULT) HEPA FILTER (BINS)	99.97%	
CPP	760	002	BIN SET #4 - VENTS THE VAULT SURROUNDING THE STORAGE BINS (NOT HEPA-FILTERED) AND THE STORAGE BINS (TWO HEPA FILTERS INSTALLED BUT NOT TESTED)	NONE (VAULT) TWO HEPA FILTERS IN SERIES INSTALLED BUT NOT TESTED	99.97%	
CPP	764	002	VENT FOR VAULT CONTAINING HOT WASTE TANK (VES-SFE-126)	NONE (VAULT) HEPA FILTER (NOT TESTED)	99.97%	
CPP	765	003	BIN SET #5 - VENTS THE VAULT SURROUNDING THE STORAGE BINS AND THE STORAGE BINS	NONE (VAULT) TWO HEPA FILTERS IN SERIES (BINS)	99.97% each filter	
CPP	767	001	FAST STACK. VENTS THE FLUORINE AND STORAGE (FAST) FACILITY.	HEPA FILTER OR TWO HEPA FILTERS IN SERIES	99.97% each filter	X
CPP	791	004	BIN SET #6 - VENTS THE VAULT SURROUNDING THE STORAGE BINS AND THE STORAGE BINS	NONE (VAULT) TWO HEPA FILTERS IN SERIES (BINS)	99.97% each filter	
CPP	795	004	BIN SET #7 - INACTIVE	INACTIVE		
CPP	1608	001	MANIPULATOR REPAIR CELL	TWO HEPA FILTERS IN SERIES	99.97% each filter	
CPP	1611	AREA 1	PERCOLATION POND 2 (NON-POINT SOURCE)	NONE	NONE	
CPP	1612	AREA 1	PERCOLATION POND 1 (NON-POINT SOURCE)	NONE	NONE	
CPP	1617	001	RADIOLOGICAL AND HAZARDOUS WASTE ACCUMULATION AREA	NONE	NONE	
CPP	1619	001	UNLOADING AND TRANSFER OF LOW-LEVEL RADIOACTIVE LIQUIDS	HEPA FILTER	99.97%	
CPP	1646	001	ANTI-C/SAFETY EQUIPMENT HANDLING FACILITY	TWO HEPA FILTERS IN SERIES	99.97% each filter	

a. A single HEPA filter will remove 99.97% of particulates that are 0.3 microns in diameter.

b. Air emission sources that require continuous monitoring are based on an unabated emission potential of 0.1 mrem/yr or greater.

c. Not a source term for 1995.

Table II-4. PBF Area Radiological Air Emission Sources

AREA	BLDG	VENT	POWER BURST FACILITY (PBF) AREA		Nearest Reception [223] in SSE	CONTINUOUSLY MONITORED ^b
			SOURCE DESCRIPTION	EFFLUENT CONTROL DESCRIPTION		
PER	620	016	PBF REACTOR MAIN STACK - REACTOR IS ON STANDBY	ONE BANK HEPA FILTERS	99.97% each filter 98.5%	
			ONE BANK SILVER ZEOLITE FILTER			
PER	620	041	VENT FROM A DECONTAMINATION SINK - DECON ROOM	HEPA FILTER	99.97%	
PER	765 ^c	001 ^c	VENTS COMPACTOR AND NEW SIZING ROOM. WERF EXHAUST EAST STACK.	TWO BAG HOUSE FILTERS IN SERIES ONE HEPA FILTER BANK.	90% 99.97%	X
PER	755	001	WERF EXHAUST NORTH STACK	BAG HOUSE FILTER ONE HEPA FILTER BANK	90% 99.97%	X
PER	756	001	WERF EXHAUST SOUTH STACK	ONE BANK HEPA FILTERS	99.97%	

a. A single HEPA filter will remove 99.97% of particulates that are 0.3 microns in diameter.

b. Air emission sources that require continuous monitoring are based on an unabated emission potential of 0.1 mrem/yr or greater.

c. This emission source replaces PER-622-003.

Table II-5. RWMC Radiological Air Emission Sources

RADIOACTIVE WASTE MANAGEMENT COMPLEX (RWMC)				Nearest Receptor - 7976-m SSW	CONTINUOUSLY MONITORED ^b
AREA	BLDG	VENT	SOURCE DESCRIPTION	EFFLUENT CONTROL DESCRIPTION	
WMF	601	009	HP LABORATORY HOOD USED FOR ENVIRONMENTAL SAMPLE PREPARATION FOR RADIOLOGICAL ANALYSIS	ONE 24 x 24-INCH HEPA FILTER	99.97%
WMF	615	001	DRUM VENTING FACILITY STACK & HEAD SPACE GAS SAMPLING AND CONTROL SYSTEM	ONE INLINE HEPA FILTER TO STACK ONE HEPA FILTER IN SERIES WITH A BANK (THREE) OF ADSORBERS	99.97% each filter
WMF	628	001	WSF STACK ^c	NONE	NONE
WMF	629	001	WSF STACK ^c	NONE	NONE
WMF			OU 7-08 THREE VAPOR VACUUM EXTRACTION TREATMENT UNITS (MOBILE CERCLA UNITS)	NONE	NONE

a. A single HEPA filter will remove 99.97% of particulates that are 0.3 microns in diameter.

b. Air emission sources that require continuous monitoring are based on an unabated emission potential of 0.1 mrem/yr or greater.

c. No longer a radiological source.

Table II-6. TAN Radiological Air Emission Sources

TEST AREA NORTH (TAN)		TEST AREA NORTH (TAN) SMG FACILITIES					
AREA	BLDG	VENT	VENT				
		SOURCE DESCRIPTION	DESCRIPTION				
TAN	607	049	HOT SHOP CHANGE ROOM EXHAUST - ROOM EXHAUST FOR STEP-OFF PAD AREA FOR HOT SHOP. INSIDE OF VENT IS CONTAMINATED. THERE IS A POTENTIAL FOR RELEASE SIMILAR TO WHAT IS RELEASED FROM THE MAIN STACK. NOT IN OPERATION.	NONE	NONE	NONE	CONTINUOUSLY MONITORED
TAN	666	001	VENT FOR TANKS USED FOR RECEIVING AND STORING LOW-LEVEL RADIOACTIVE LIQUID WASTES.	NONE	NONE	NONE	
TAN	726	001	RADIOACTIVE WATER STORAGE. VENTS FOR TANKS.	NONE	ONE TO THREE HEPA FILTERS IN SERIES	99.97%	
TAN	734	001	MAIN EXHAUST STACK FOR THE TAN HOT CELL AND HOT CELL ANEX AREA	HEPA	HEPA	99.97%	
TAN	607	136	EQUIPMENT DECONTAMINATION ROOM ^c	NONE	NONE	NONE	
TAN			OU 1-07B GROUNDWATER TREATMENT FACILITY				
TEST AREA NORTH (TAN)		TEST AREA NORTH (TAN) SMG FACILITIES					
TAN	607	039	RESEARCH AND DEVELOPMENT PROCESS STACK (RAD STACK #1)	TWO HEPA FILTER BANKS	99.97%		
TAN	607	119	QUALITY CONTROL LAB (RAD STACK #2)	TWO HEPA FILTER BANKS	99.97%		
TAN	629	012	MANUFACTURING PROCESS (RAD STACK #5)	TWO HEPA FILTER BANKS	99.97%		
TAN	629	013	LINE 2A (RAD STACK #3) - MANUFACTURING PROCESS	TWO HEPA FILTER BANKS	99.97%		
TAN	629	014	MANUFACTURING PROCESS (RAD STACK #4)	TWO HEPA FILTER BANKS	99.97%		
TAN	679	022	NORTH PROCESS (RAD STACK #11) MANUFACTURING PROCESS (EF-206) AND INCLUDES EMISSIONS FROM THE QC LAB	TWO HEPA FILTER BANKS	99.97%		
TAN	679	023	NORTH PROCESS (RAD STACK #10) MANUFACTURING PROCESS (EF-205) AND INCLUDES EMISSIONS FROM THE QC LAB	TWO HEPA FILTER BANKS	99.97%		
TAN	679	024	NORTH PROCESS (RAD STACK #9) - MANUFACTURING PROCESS (EF-204) AND INCLUDES EMISSIONS FROM THE QC LAB	TWO HEPA FILTER BANKS	99.97%		
TAN	679	025	SOUTH PROCESS (RAD STACK #8) MANUFACTURING PROCESS (EF-203)	TWO HEPA FILTER BANKS	99.97%		
TAN	679	026	SOUTH PROCESS (RAD STACK #7) MANUFACTURING PROCESS (EF-202)	TWO HEPA FILTER BANKS	99.97%		
TAN	679	027	SOUTH PROCESS (RAD STACK #6) MANUFACTURING PROCESS (EF-201)	TWO HEPA FILTER BANKS	99.97%		
TAN	681	012	PROCESS RECLAMATION FACILITY FOR NITRIC ACID WITH SCRUBBER FOR NO _x AND HEPA FILTERS FOR RAD (EF-209) (RAD STACK #14)	TWO HEPA FILTER BANKS SCRUBBER	99.97% 50%		
TAN	681	018	PROCESS RECLAMATION FACILITY INCLUDING DRYER HOOD, CALCINER HOOD (RAD STACK #13)	TWO HEPA FILTER BANKS	99.97%		
TAN	681	020	PROCESS RECLAMATION FACILITY (RAD STACK #12)	TWO HEPA FILTER BANKS	99.97%		

a. A single HEPA filter will remove 99.97% of particulates that are 0.3 microns in diameter.

b. Air emission sources that require continuous monitoring are based on an unabated emission potential of 0.1 mrem/yr or greater.

c. Not a source term for 1995.

Table II-7. TRA Radiological Air Emission Sources

TEST REACTOR AREA (TRA)			Nearest Receptor - 19172 m SSW		
AREA	BLDG	VENT	SOURCE DESCRIPTION	EFFLUENT CONTROL DESCRIPTION	EFFICIENCY ^a & MONITORED ^b
TRA	604	035	TRA RADIOCHEMISTRY LABORATORY FUMEHOOD EXHAUST (661/604)	HEPA FILTER	99.97%
TRA	604	072	PERCHLORIC ACID HOOD EXHAUST IN 604	NONE	NONE
TRA	604	073	PERCHLORIC ACID HOOD EXHAUST IN 604	NONE	NONE
TRA	604	074	PERCHLORIC ACID HOOD EXHAUST IN 604	NONE	NONE
TRA	632	015	DECONTAMINATION ROOM EXHAUST HOOD (not used during 1995)	HEPA FILTER	99.97%
TRA	632	019	HOT CELL USED FOR DECONTAMINATION OPERATIONS, ASSEMBLING, DISASSEMBLING, OR DESTRUCTION OF RADIOACTIVE MATERIALS	HEPA FILTER	99.97%
TRA	632	030	HOT CELL USED FOR DECONTAMINATION OPERATIONS, ASSEMBLING, DISASSEMBLING, OR DESTRUCTION OF RADIOACTIVE MATERIALS - ALSO METALLOGRAPHY	HEPA FILTER	99.97%
TRA	632	041	HOT CELL USED FOR DECONTAMINATION OPERATIONS, ASSEMBLING, DISASSEMBLING, OR DESTRUCTION OF RADIOACTIVE MATERIALS	HEPA FILTER	99.97%
TRA	660	004	FUMEHOOD ^c	HEPA FILTER	99.97%
TRA	661	008	VENTS THE NEW RADIOCHEMISTRY WING EXTENSION (7 HOODS AND 2 STORE ROOMS)	HEPA FILTER	99.97%
TRA	668	013	LABORATORY 98 FUMEHOOD EXHAUST ^c	NONE	NONE
TRA	668	015	LABORATORY 100 FUMEHOOD EXHAUST ^c	NONE	NONE
TRA	670	074	SAMPLE HOOD FOR PRIMARY AND SECONDARY COOLING WATER IN ADVANCED TEST REACTOR (ATR)	HEPA FILTER	99.97%
TRA	670	086	LABORATORY 131 FUMEHOOD EXHAUST	HEPA FILTER	99.97%
TRA	670	098	EXHAUST FROM TWO WET CHEMISTRY HOODS AND THE HEALTH PHYSICS OFFICE AT ATR	HEPA FILTER	99.97%
TRA	710	001	MATERIAL TEST REACTOR (MTR) MAIN STACK (REACTOR SHUT DOWN), THE TRA TRITIUM LABORATORY, CATCH TANK VENT (FROM 604, 661, 632 AREAS), TRA-604/661 LAB HOT CELL VENT SCRUBBER, AND TRA-605 BUILDING EXHAUST VENT OUT THIS STACK.	TRA-604 - 661 HOT CELL VENT SCRUBBER IS VENTED THROUGH A HEPA FILTER. ALL OTHER SOURCES LISTED HAVE ONE HEPA FILTER OR NO EFFLUENT CONTROL.	99.97% each filter
TRA	770	001	ATR MAIN STACK	NONE	NONE

a. A single HEPA filter will remove 99.97% of particulates that are 0.3 microns in diameter.

b. Air emission sources that require continuous monitoring are based on an unabated emission potential of 0.1 mrem/yr or greater.

c. Not a source term for 1995.

Table II-8. Point Source Radionuclides (Continuously Monitored Sources) From INEL Facilities During 1995

Radionuclide	ANL-764-001	ANL-785-018	CPP-708-001	CPP-767-001 ^d	PER-765-001	PER-765-001
Ar-41	4.37E+0					
C-14		2.94E-2 ^e		2.22E-8	2.32E-3 ^e	
Co-57						
Co-60		4.85E-7				
Cs-134		2.87E-4	9.02E-8			
Cs-137/Ba-137m						
Eu-154		1.72E-7				
Gross Alpha ^b	3.13E-5	1.39E-7			0	0
Gross Beta/Gamma ^c	6.80E-7	1.11E-7			0	0
H-3		4.39E+0 ^e	9.78E-3 ^e	3.49E-2 ^e	9.50E-4 ^e	
I-129			9.60E-3 ^e	5.17E-11 ^e	7.44E-10 ^e	2.66E-5 ^e
Kr-85		6.06E+0		6.60E-4 ^e		
Kr-85m						
Kr-87						
Kr-88						
Mn-54						
Pu-238			8.81E-7	3.96E-8		
Pu-239			9.70E-8	3.80E-8		
Ru-106/Rh-106				2.06E-5	2.88E-5	
Sb-125/Tc-125m				5.41E-6	4.49E-5	
Sr-90/Y-90				4.44E-5	3.19E-8	
Xe-133						
Xe-135						
Xe-135m						
Xe-138						

a. 1 Curie is equal to 37 Giga Bequerel

b. Assumed to be Pu-239

c. Assumed to be Sr-90/Y-90

d. No longer a Continuously Compliance Monitored Source (See Text)

e. Emissions conservatively estimated based on engineering calculations, these specific nuclides do not constitute >10% of the potential effective dose equivalent.

Table II-9. Point Source Radionuclides (All Other Release Points) From INEL Facilities During 1995

Radionuclide	Actual Estimated Release (Ci) ^a							
	ANL-W	CFA	ICPP	NRF	PBF	RWMC	TAN	TRA
Ac-227		1.5E-9						
Ac-228		1.1E-7						
Ag-110		2.0E-6						
Am-241		1.0E-6	3.4E-11					1.1E-11
Am-243		7.0E-7	2.5E-13					
Ar-41				5.4E-2				1.3E+3
Ba-139								1.3E-3
Ba-140								4.8E-5
C-14				7.7E-1				
Ce-141								6.1E-11
Ce-144			1.4E-7					
Cm-242			1.9E-11					
Cm-244			1.6E-11					
Co-57			8.6E-7					
Co-58								3.3E-11
Co-60			1.2E-6			7.2E-14	3.9E-7	1.1E-4
Cr-51								1.0E-3
Cs-134			2.7E-8					8.5E-7
Cs-137/Ba-137m		6.0E-7	1.5E-4		1.4E-8	7.2E-14	2.7E-7	1.3E-5
Cs-138								1.7E-1
Eu-152		5.3E-7	8.4E-6					
Eu-154			1.3E-6					
Eu-155			1.3E-6					
Gd-148		1.5E-10						
Gross Alpha ^b	2.79E-7				4.0E-8		4.2E-8	1.3E-6
Gross Beta ^c				1.0E-5	1.6E-7		2.1E-6	7.8E-4
Gross Beta/Gamma ^c	1.2E-5							
H-3	5.9E-2		2.1E-4	9.3E-2			6.8E-3	1.3E+1
Hf-181								1.4E-11
Hg-203								5.1E-5
I-129		1.8E-9						
I-131				5.4E-6				1.8E-3
I-132								2.6E-3
I-133								1.9E-3
I-134								3.2E-3
I-135								3.2E-3
Ir-192								5.6E-7
Kr-85			4.3E-1					
Kr-85m								5.1E+0
Kr-87								2.9E+0
Kr-88								8.5E+0
La-140								9.1E-5
Mn-54								1.1E-5
Mo-99								9.2E-5
Na-24								2.8E-4
Nb-95			3.1E-8					
Np-237		5.3E-8	1.4E-11					
Np-239								2.0E-10

**Table II-9. Point Source Radionuclides (All Other Release Points) From INEL Facilities During 1991
(continued)**

Radionuclide	Actual Estimated Release (Ci) ^a							
	ANL-W	CFA	ICPP	NRF	PBF	RWMC	TAN	TRA
Os-191								1.6E-5
Pa-234/Pa-234m			7.8E-13				4.4E-6	
Pm-147			8.2E-8					
Pr-144			1.4E-7					
Pu-238		9.4E-7	2.6E-7					
Pu-239		1.4E-7	5.8E-7					1.2E-6
Pu-240			3.8E-11					
Pu-241			1.9E-7					
Pu-242			3.3E-13					
Ra-226		1.0E-7						
Ra-228		8.7E-6						
Rb-88								3.2E+0
Rb-89								1.1E-2
Re-186								3.2E-10
Re-188								4.3E-5
Ru-103								2.6E-12
Ru-106/Rh-106			3.1E-8					
Sb-124								1.6E-12
Sb-125/Te-125m			7.1E-7					
Sm-151			1.6E-9					
Sm-153								2.5E-10
Sr-90/Y-90			2.0E-4				6.0E-9	1.1E-5
Sr-91								1.5E-4
Sr-92								2.6E-5
Tc-99m								2.0E-3
Th-228		6.3E-8						
Th-229		2.0E-7						
Th-231			5.6E-12					
Th-232		2.4E-7						
Th-234			7.8E-13				4.4E-6	
U-232		4.4E-8						
U-233		1.5E-7						
U-234			3.5E-6				5.7E-7	
U-235			8.7E-8					
U-236			1.1E-11					
U-238			1.8E-6				4.4E-6	
W-187								7.4E-4
Xe-133								6.4E+0
Xe-135								2.9E+1
Xe-135m								1.5E+0
Xe-138								3.2E+0
Y-91m								1.8E-3
Zn-65								5.4E-5
Zr-95			1.5E-8					

a. 1 Curie is equal to 37 Giga Becquerel

b. Assumed to be Pu-239

c. Assumed to be Sr-90/Y-90

Table II-10. Non-Point Source Radionuclides (Diffuse Emission Sources) from INEL Facilities During 1995^a

Source	Area	Met. Location	Concentration (pCi/g unless stated)	Inventory (Ci)	Release (Ci)	
PBF	ARA-I and II and SL-1	a. 5 acres (20,200 m ²) (Chemical evaporation pond).	PBF	Co-60 76 Sr-90 20 Cs-134 44 Cs-137 1180	3.1E-2 8.1E-3 1.8E-2 4.8E-1	9.7E-7 2.5E-7 5.6E-7 1.5E-5
		b. 111.4 acres (451,000 m ²)		Co-60 0.2 Cs-137 100 Sr-90 20	1.8E-3 9.0E-1 1.8E-1	5.7E-8 2.8E-5 5.7E-6
		c. 98,200 ft ² (9,100 m ²)		Pu-238 0.025	4.6E-6	1.4E-10
Areas S.W. of ARA-II	15.6 acres (63,100 m ²)		PBF	Co-60 0.2 Sr-90 20 Cs-137 100	2.5E-4 2.5E-2 0.13	4.1E-6
ARA-III Pond	562,000 ft ² (52,200 m ²)		PBF	Co-60 38 Sr-90 0.3 Cs-137 6 Ag-108m 40	4.0E-2 3.1E-4 6.3E-3 4.1E-2	1.3E-6 9.8E-9 2.0E-7 1.3E-6
SPERT-IV Leach Pond	0.53 acres (2,145 m ²)		PBF	Co-60 2.29 Sr-90 5.4 Cs-137 12.5 U-235 86 Pu-239/40 0.14 U-238 4.5 U-234 18	9.8E-5 2.3E-4 5.4E-4 3.7E-3 6.0E-6 1.9E-4 7.7E-4	3.1E-9 7.3E-9 1.7E-8 1.2E-7 1.9E-10 6.1E-9 2.4E-8
PBF Reactor Canal			PBF	H-3 (100% Release)	0	0
Total for PBF Area			Co-60 Sr-90 Ag-108m Cs-134 Cs-137 U-235 Pu-238 Pu-239/40 U-234 U-238		2.3E-6 6.8E-6 1.3E-6 5.6E-7 4.7E-5 1.2E-7 1.4E-10 1.9E-10 2.4E-8 6.1E-9	
CFA	Organic Moderated Reactor Experiment	1.84 acres (745 m ²)	CFA	Co-60 43 Sr-90 18 Cs-137 63	6.4E-3 2.6E-3 9.3E-3	2.0E-7 8.2E-8 2.9E-7
CFA Sewage Plant Drain Field	5.3 acres (21,450 m ²)		CFA	Co-60 127 Sr-90 50 Sb-125 2.1 Cs-134 4 Cs-137 600 Eu-152 3.6 Eu-154 5 Eu-155 1.6 U-235 0.01	5.4E-2 2.1E-2 9.0E-4 1.7E-3 0.25 1.5E-3 2.1E-3 6.9E-4 4.3E-6 0.01	1.7E-6 6.6E-7 2.8E-8 5.4E-8 7.9E-6 4.7E-8 6.6E-8 2.2E-8 1.4E-10

Table II-10. Non-Point Source Radionuclides (Diffuse Emission Sources) from INEL Facilities During 1995^a (continued)

Source	Area	Act. location	Concentration (pCi/g unless noted)	Inventory (Ci)	Released (Ci/yr)
CFA - 674 Area	0.05 acres (202 m ²)	CFA	Cs-137 2.13 pCi/cm ²	4.3E-6	1.4E-10
CFA Tritium to air from Misc. aquifer water use	1.0 acre (4,047 m ²) (conservative assumption)	CFA	H-3 (present in aquifer water pumped and used at CFA)	na	6.3E+0
CFA Ditch and Pit	1 1/2 acre (4,047 m ²)	CFA	Co-60 26.4 Cs-134 0.9 Cs-137 2988.0 Eu-154 9.9	2.1E-3 7.3E-5 2.4E-1 8.0E-4	6.6E-8 2.3E-9 7.6E-6 2.5E-8
OU 4-09		CFA	Co-60 Sr-90 Ag-110m Cs-137 U-234 U-238 Pu-238 Pu-239 Pu-240 Am-241		1.0E-8 4.4E-8 3.0E-9 1.8E-7 1.1E-8 9.9E-9 1.9E-8 1.3E-8 1.3E-8 3.1E-10
Total for CFA Area			H-3 Co-60 Sr-90 Sb-125 Cs-134 Cs-137 Bk-152 Eu-154 Eu-155 U-235 Ag-110m U-234 U-238 Pu-238 Pu-239 Pu-240 Am-241		6.6E-0 2.0E-6 7.8E-7 2.8E-8 5.6E-8 1.6E-5 4.7E-8 9.1E-8 2.2E-8 1.4E-10 3.0E-9 1.1E-8 9.9E-9 1.9E-8 1.3E-8 1.3E-8 3.1E-10
RWMC		RWMC	Cs-137 108 Sr-90 2.9	1.9E-2 5.2E-4	6.0E-7 1.6E-8
EBR-I	a. 2.2 acres (8,903 m ²)	RWMC	Cs-137 2090 Sr-90 2.5	0.37 4.4E-4	1.2E-5 1.4E-8
	b. 2.2 acres (8,903 m ²)				
BORAX-I	0.64 acres (2,590 m ²)	RWMC	Cs-137 227 U-235 5.82	1.2E-2 3.0E-4	3.7E-7 9.5E-9
BORAX-V	1.6 acres (6,480 m ²)	RWMC	Cs-137 158.7 Co-60 0.19	2.1E-2 2.5E-5	6.5E-7 7.8E-10
SDA Gaseous Releases from Buried Waste	Treat as a point source at Pit 17 (conservative)	RWMC	H-3 C-14		9.0E-2 3.5E-1

Table II-10. Non-Point Source Radionuclides (Diffuse Emission Sources) from INEL Facilities During 1995^a (continued)

Source	Area	Met. Location	Concentration (pCi/g unless stated)	Inventory (Ci)	Release (Ci/yr)
Total for RWMC Area		H-3 C-14 Cs-137 Sr-90 U-235 Co-60			9.0E+2 3.5E-1 1.4E-5 3.0E-8 9.5E-9 7.8E-10
ICPP					
ICPP Percolation Pond (Dry)	4.47E+05 ft ² (41,509 m ²)	GRD3	Am-241 0.15 Sr-125 0.60 Cs-144 0.63 Cs-134 1.75 Cs-137 46.8 Co-60 0.31 I-129 2.6 Np-237 1.1 Pu-238 0.9 Pu-239 0.27 [all Pu modeled as Pu-238]	7.0E-5 2.8E-4 2.9E-4 8.1E-4 2.2E-2 1.4E-4 1.2E-3 5.1E-4 4.2E-4 4.0E-9 [1.7E-8 Pu]	2.2E-9 8.8E-9 9.2E-9 2.6E-8 6.9E-7 4.5E-9 3.8E-8 1.6E-8 1.3E-8 4.0E-9 [1.7E-8 Pu]
Inside ICPP Fence	150 acres (6.07E+05 m ³)	GRD3	Cs-137 12.0 Eu-152 3.0 Nb-95 0.08 Ru-106 0.07 Rh-106 0.07 Sr-125 0.6	1.5E-1 3.6E-2 9.7E-4 8.5E-4 8.5E-4 7.3E-3	4.6E-6 1.1E-6 3.1E-8 2.7E-8 2.7E-8 2.3E-7
Outside ICPP Fence	19.2 acres (77,700 m ²)	GRD3	Cs-137 46.1	7.2E-2	2.3E-6

Table II-10. Non-Point Source Radionuclides (Diffuse Emission Sources) from INEL Facilities During 1995^a (continued)

Source	Area	Yield	Concentration (pCi/g unless stated)	Inventory (Ci)	Release (Ci/yr)	
Total for ICPP Area		GRD3	Am-241 Sb-125 Cs-144 Cs-134 Cs-137 Co-60 I-129 Np-237 Pu-238 Pu-239 [all Pu modeled as Pu-238] Ru-106 Rh-106 Sr-90 Y-90 H-3 U-234 U-235 U-238 [all U modeled as U-234] Nb-95 Eu-152	2.2E-9 2.4E-7 9.2E-9 2.6E-8 7.6E-6 4.5E-9 3.8E-8 1.6E-8 1.3E-8 4.0E-9 [1.7E-8 Pu] 7.2E-8 7.2E-8 9.5E-9 9.5E-9 8.9E-9 1.1E-8 1.0E-9 1.2E-8 [2.4E-8 U] 3.1E-8 1.1E-6	2.2E-9 2.4E-7 9.2E-9 2.6E-8 7.6E-6 4.5E-9 3.8E-8 1.6E-8 1.3E-8 4.0E-9 [1.7E-8 Pu] 7.2E-8 7.2E-8 9.5E-9 9.5E-9 8.9E-9 1.1E-8 1.0E-9 1.2E-8 [2.4E-8 U] 3.1E-8 1.1E-6	
TRA	TRA Sewage Plant Leach Ponds (dry areas)	32,500 ft ² (3,019 m ²)	TRA	Co-60 Ag-102m Cs-137 Eu-152 Eu-154 Sr-90 U-234 U-238 Pu-238 Pu-239 Am-241	327.0 6.5 590.1 5.9 5.7 1.4 5.2 1.9 0.1 0.5 2.6	2.0E-2 3.8E-4 3.6E-2 3.6E-4 3.4E-4 8.5E-5 3.1E-4 1.1E-4 6.0E-6 3.0E-5 1.6E-4
TRA	TRA Warm Waste Evaporation Pond		TRA	H-3 [100% Release]	8.0E+1	8.0E+1
TRA	TRA Warm Waste Evaporation Pond (Periodically wetted areas)		TRA	Ce-141 Co-60 Cr-51 Cs-137 Mn-54 Na-24 Sr-89 Sr-90 Zn-65 Hf-181		1.44E-07 6.19E-05 2.15E-04 1.19E-05 6.27E-07 1.84E-06 1.28E-06 1.01E-05 3.12E-07 2.29E-07
TRA	TRA North Storage Area		TRA	Cs-137 Cs-137	12.32 pCi/cm ² 123.29 pCi/cm ²	2.9E-4 2.9E-3

a. 25,000 ft² (2,323 m²)
b. 25,000 ft² (2,323 m²)

Table II-10. Non-Point Source Radionuclides (Diffuse Emission Sources) from INEL Facilities During 1995^a (continued)

Source	Area	Met. Location	Concentration (pCi/g unless stated)	Inventory (Ci)	Release (Ci/yr)	
MTR Area	25,000 ft ² (2,323 m ²)	TRA	Co-60 Zn-65 Co-60 Sr-90 Ag-108m Cs-137	8.60 39 16	0.39 1.8E-3 7.4E-4	1.2E-5 5.7E-3 2.4E-3
Total for TRA Area		TRA	Cr-51			2.2E-4
OU 10-06		TRA	Zn-65 Eu-152 Eu-154 Eu-155 Th-228 Th-230 Th-232 U-234 U-238 Pu-238 Pu-239 Am-241 H-3 Na-24 Mn-54 Sr-89 Hf-181 Ce-141			3.7E-7 7.4E-5 1.0E-5 1.2E-5 1.3E-5 1.1E-3 9.9E-9 3.5E-9 1.9E-10 9.4E-10 5.0E-9 8.0E+1 1.8E-6 6.3E-7 1.3E-6 2.3E-7 1.4E-7
OU 10-06		TRA	Co-60 Sr-90 Cs-137			1.3E-4 5.8E-3 4.1E-3
TAN		TAN	Co-60 Sr-90 Pu-238 Pu-240 U-238 U-235 U-234			3.7E-4 6.1E-3 6.2E-6 1.8E-6 2.6E-6 1.5E-6 5.8E-7 1.2E-6 1.0E-5 7.0E-7 6.9E-7 2.8E-4
TAN Radioactive Parts Storage Security Area (RPSSA)	600,000 ft ² (55,740 m ²)	TAN	Cs-137	56.5	6.3E-2	2.0E-6
			Co-60	4.1	4.6E-3	1.4E-7
			Sr-90	5.4	6.0E-3	1.9E-7
			Pu-240	0.060	6.7E-5	2.1E-9
			Pu-238	0.054	6.0E-5	1.9E-9
			U-238	1.1	1.2E-3	3.8E-8
			U-235	0.050	5.6E-5	1.8E-9
			U-234	1.4	1.6E-3	5.0E-8
TAN Triangular area South East of RPSSA	100 ft ² (9.3 m ²)	TAN	Cs-137	5.33 pCi/cm ²	4.9E-7	1.5E-11

Table II-10. Non-Point Source Radionuclides (Diffuse Emission Sources) from INEL Facilities During 1995^a (continued)

Source	Area	Alt.	Location	Concentration (pCi/m ³ unless specified)	Inventory (Ci)	Release (Ci/s)
TAN North of Smoke Ave., West of TAN-607	1,500 ft ² (139 m ²)		TAN	Cs-137 53 pCi/cm ²	7.3E-5	2.3E-9
TAN V1, V2 and V3 Tank Area	5,500 ft ² (511 m ²)		TAN	Cs-137 1.07E3 Co-60 Cs-134 Eu-154	1.1E-2 3.9E-4 9.2E-6 1.3E-5	3.5E-7 1.2E-8 2.9E-10 4.1E-10
TAN Disposal Pond - High Area	40,000 ft ² (3,716 m ²)		TAN	Cs-137 48 Co-60 1.4	3.6E-3 1.0E-4	1.1E-7 3.2E-9
TAN Disposal Pond -Depressions	8,000 ft ² (743 m ²)		TAN	Cs-137 3 Co-60 0.4	4.4E-5 6.0E-6	1.4E-9 1.9E-10
TAN Disposal Pond - Pond Bottom	80,000 ft ² (7,432 m ²)		TAN	Cs-137 46 Co-60 88	6.8E-3 1.3E-2	2.1E-7 4.1E-7
	Total Area 1.19E+4 m ²			Total Cs-137 Total Co-60		3.21E-7 4.13E-7
TAN Warm Shop			TAN			0
TAN Prepp Area			TAN			0
TAN Hot Shop Annex			TAN			0
TAN Storage Pool			TAN	H-3 (100% Release)	5.9E-2	5.9E-2
Total for TAN Area				H-3 Cs-137 Co-60 Sr-90 Pu-238 Pu-240 U-238 U-235 U-234 Cs-134 Eu-154		5.9E-2 2.7E-6 5.7E-7 1.9E-7 2.1E-9 1.9E-9 3.8E-8 1.8E-9 5.0E-8 2.9E-10 4.1E-10

a. Diffuse emission sources for NRR are listed in Appendix A.

III. DOSE ASSESSMENTS

Summary

Tables III-1 and III-2 summarize the 1995 INEL emission points for continuously compliance monitored sources and all other point sources, respectively, and the EDE associated with each. Table III-3 summarizes the 1995 diffuse emission sources at the INEL, and the EDE associated with each. 40 CFR 61, Subpart H, requires that "compliance with the standard be determined by calculating the highest effective dose equivalent to any member of the public at any off-site point where there is a residence, school, business or office." The EDE to the one true MEI calculated for emissions from continuously compliance monitored release points during 1995 is 2.88E-03 mrem (2.88E-08 Sievert). The EDE to the one true MEI for the remaining point sources is 2.83E-03 mrem (2.83E-08 Sievert). The diffuse source EDE to the one true MEI is 1.23E-02 mrem (1.23E-07 Sievert). These EDEs, when summed, result in a calculated 1995 total EDE to the one true MEI from the entire INEL of 1.80E-02 mrem (1.80E-07 Sievert).

The following sections provide the methodology used to calculate radiological dose impacts, and the dose impacts associated with each INEL operations area.

Table III-1. Summary of 1995 Effective Dose Equivalents to the MEI from Continuously Compliance Monitored Release Points at INEL

	<u>Release Point</u>	<u>EDE</u> (mrem) ^a
<u>ANL-W</u>		
1. EBR-II and FCF (ANL-764-001)		7.77E-06
2. HFEF (ANL-785-018)		3.11E-06
TOTAL		1.09E-05
<u>CFA</u>	CFA has no Continuous Compliance Monitored Sources	
<u>ICPP</u>		
1. ICPP FAST Stack (CPP-767-001) ^b		4.99E-07
2. ICPP Main Stack (CPP-708-001)		2.86E-03
TOTAL		2.86E-03
<u>NRF</u>	NRF has no Continuous Compliance Monitored Sources	
<u>PBF</u>		
1. WERF North (PER-755-001)		1.67E-07
2. WERF East (PER-765-001)		4.25E-06
TOTAL		4.42E-06
<u>RWMC</u>	RWMC has no Continuous Compliance Monitored Sources	
<u>TAN</u>	TAN has no Continuous Compliance Monitored Sources	
<u>TRA</u>	TRA has no Continuous Compliance Monitored Sources	
ALL FACILITIES		2.88E-03

a. The EDE shown is to the INEL MEI.

b. No longer a Continuously Compliance Monitored Source (See Text)

Table III-2. Summary of 1995 Effective Dose Equivalents from Other Release Points at INEL

	<u>Release Point</u>	<u>EDE</u> (mrem) ^a
<u>ANL-W</u>		
1. ANL-W Ground Level Releases ^b		2.73E-07
TOTAL:		2.73E-07
<u>CFA</u>		
1. RESL		1.53E-05
2. CFA Ground Level Releases ^b		0
TOTAL:		1.53E-05
<u>ICPP</u>		
1. ICPP Ground Level Releases ^b		2.32E-05
TOTAL:		2.32E-05
<u>NRF</u>		
1. NRF (A1W, A1W-RWDS, ECF, S1W, S5G)		4.05E-04
TOTAL:		4.05E-04
<u>PBF</u>		
1. PBF (PER-620-016)		1.33E-07
2. WERF South (PER-756-001)		0
TOTAL:		1.33E-07
<u>RWMC</u>		
1. Drum Venting Facility (WMF-615-001)		0
2. RWMC Ground Level Releases ^b		5.21E-11
TOTAL:		5.21E-11
<u>TAN</u>		
1. SMC (SMC Stacks S1-S14)		1.51E-06
2. TSF Exhaust (TAN-734-001)		8.36E-08
3. Remaining TAN Sources (Composite Ground Level Release) ^b		2.04E-12
TOTAL:		1.59E-06
<u>TRA</u>		
1. Alpha Lab (TRA-604-001), TRA Hot Cell (TRA-632), and Chem. Lab. Addition (TRA-661-008)		1.71E-06
2. MTR (TRA-710-001)		1.49E-06
3. ATR (TRA-770-001)		2.38E-03
4. Remaining TRA Sources (Composite Ground Level Release) ^b		7.03E-07
TOTAL:		2.38E-03
ALL FACILITIES		2.83E-03

a. The EDE shown is to the INEL MEI.

b. Includes stack releases being modeled as ground level releases due to building wake effects.

Table III-3. Summary of 1995 Effective Dose Equivalents from Diffuse Sources at INEL

<u>Release Area</u>	EDE (mrem) ^a
ANL-W	0
CFA	4.16E-05
ICPP	5.06E-07
NRF	2.19E-06
PBF	1.88E-06
RWMC	9.92E-03
TAN	3.92E-07
TRA	5.83E-04
OU10-06	1.80E-03
ALL FACILITIES	1.23E-02

a. The EDE shown is to the INEL MEI.

Description of Dose Model and Summary of Input Parameters

General

The CAP-88 computer code (EPA 1990) was used to calculate the effective dose equivalent (EDE) from INEL releases. CAP-88 is approved for use by the U.S. Environmental Protection Agency (EPA) for demonstrating compliance with 40 CFR 61, Subpart H. Because the maximally exposed individual for emissions from INEL facilities is more than 3 km from all emission sources, the COMPLY code was not used. The output from CAP-88 is the EDE, which includes the 50-year committed EDE (CEDE) from internal exposure through the ingestion and inhalation pathways and the external EDE from ground deposition and air immersion. The dose conversion factors are from the RADRISK dosimetric data base.

Site-specific 1995 wind data collected by the National Oceanic and Atmospheric Administration (NOAA) were used as input to the CAP-88 computer code (see Appendix B), with calm wind periods incorporated into the lowest wind speed class. Most INEL facilities have NOAA stations onsite; the exception is ICPP, where Grid III station data were used. Grid III is located approximately 1.1 mi (1.8 km) north-northwest of ICPP. Table III-4 summarizes met tower locations and heights of wind measurements. The sector-averaged option was chosen for the atmospheric dispersion calculations since this reflects annual average conditions within a sector.

The majority of the input data used in this analysis were default data from CAP-88. Input parameters differing from the CAP-88 defaults are listed in Appendix D with the associated value and reference.

Where appropriate, daughter progeny were included explicitly in the source term for the releases. Examples of parent/progeny pairs incorporated in the analyses are Cs-137/Ba-137m, Sr-90/Y-90, Ru-106/Rh-106, Sb-125/Te-125m, and Kr-88/Rb-88. The first three progeny of the U-238 decay series (Th-234, Pa-234, and Pa-234m) were modeled as being in secular equilibrium with U-238.

Point Sources

Emission points were modeled as either stack or ground-level releases based on EPA guidance (EPA 1989) and NCRP guidance (NCRP 1989). This guidance states that if the release height is less than or equal to 2.5 times the building height from which the stack emerges, then building downwash will lower the release height and a ground-level release should be used for modeling purposes. Stack-specific data for the INEL emission points which were modeled as stack releases are provided in Table III-5.

Diffuse Sources

Diffuse sources at the INEL include contaminated soil areas, fuel storage pools, evaporation ponds, etc. For

this report, soil areas that were radiologically controlled (i.e., posted as a SOIL CONTAMINATION AREA) were considered potential source terms for diffuse emissions. The source term data for soils included conservative estimates of the surface area of each source and an estimate of the activity concentrations of specific radionuclides per unit mass or area. These data were used to estimate an annual release rate for each radionuclide, with units of Ci/yr, for input to CAP-88. Details of the source term calculations and the basis for the resuspension rate of 1E-12 s⁻¹ for undisturbed soils are provided in Engineering Design File NES-94-002.1 maintained at the INEL. Again, CAP-88 was used to calculate the resulting EDE. Diffuse sources were modeled as ground-level releases. Table II-10 (Section II) identified each release point for diffuse emissions, area of source, concentration, radionuclide inventory and the release (Ci/g).

Table III-4. Sources of Wind Data for 1995 CAP-88 Atmospheric Dispersion Modeling of Releases from INEL Facilities

<u>Facility</u>	<u>Met Tower Location</u>	<u>Measurement Level (m)</u>	<u>Averaging Period</u>
ANL-W	ANL	10	1995
		80	
CFA ICPP	CFA Grid III	10	1995
		10	
NRF PBF RWMC TAN	NRF PBF RWMC TAN	61	1995
		10	
PBF RWMC TAN	PBF RWMC TAN	10	1995
		10	
TRA	TRA	45	1995
		10	

Table III-5. INEL Stack Data for Releases Modeled as Stack Releases

<u>Release Point</u>	<u>Measurement Level (m)</u>	<u>Stack Height (m)</u>	<u>Stack Diameter (m)</u>	<u>Stack Radius (m)</u>	<u>Stack Flow (m³/s)</u>	<u>Stack Velocity (m/s)</u>
ANL-764-001	80	61	1.55	0.78	23.1	12.2
CPP-767-001	61	48.8	1.65	0.82	41.2	19.3
CPP-708-001	61	76.2	1.98	0.99	51.6	16.7
PER-620-016	10	22.9	0.51	0.25	2.4	11.6
TAN-734-001	45	48.8	1.14	0.57	8.5	8.3
TRA-710-001	10	76.2	1.52	0.76	5.7	3.1
TRA-770-001	10	76.2	1.52	0.76	21.2	11.6

Compliance Assessment

MEI Determination

In previous reports, the approach used for demonstrating compliance for the INEL was to calculate the offsite dose for a maximally exposed individual (MEI) for each INEL area and then sum the EDE from those areas. This approach was taken in previous years because the CAP-88 code cannot readily calculate EDE contributions from facilities not located in close proximity.

However, for this report the MEI was calculated based on a single receptor point, and the EDE reported is all of the area's contributions to that one receptor point. In order to calculate the MEI location, a series of batch files were prepared for the CAP-88 computer code, one for each major release point to each of the 63 potential MEI locations. Figures 2 through 10 illustrate the sector maps from each INEL area and the 63 potential MEI locations. The output from these batch runs were then electronically transferred onto a spreadsheet and the offsite dose was calculated at each of the 63 potential MEI locations. This spreadsheet is provided as Table III-6. The INEL MEI was then readily obtained by selecting the offsite point with the highest EDE. Once the MEI was located, emissions from all point and diffuse sources were modeled to this INEL MEI point. For CY 1995, the MEI was receptor #1.

ANL Emission Sector Map




Figure 2. ANL-W Emission Sector Map




Figure 3. CFA Emission Sector Map




Figure 4. ICPP Emission Sector Map




Figure 5. NRF Emission Sector Map

PBF Emission Sector Map



Legend

- Emission Source
- ▲ Receptor Point

Population Within
50 Miles Of
PBF Operational Area
152,008

ENVIRONMENTAL
ASSESSMENT
TECHNOLOGIES

0 10 20 30 40 50 Kilometers
0 10 20 30 Miles





Figure 6. PBF Emission Sector Map

Figure 7. RWMC Emission Sector Map



TAN Emission Sector Map

Legend

- Emission Source
- ▲ Receptor Point

Population Within
50 Miles Of
TAN Operational Area
146,459

ENVIRONMENTAL
ASSESSMENT
TECHNOLOGIES

0 10 20 30 40 Miles
0 10 20 30 40 Kilometers




Figure 8. TAN Emission Sector Map




Figure 9. SMC Emission Sector Map

Figure 10. TRA Emission Sector Map




Table III-6. MEI Determination Table

Location	ANL Main	ICPP Main	ICPP Gaseous	ANL HFFP	NRF	RWMC	TRA ATR	TRA OU10-06	Total INEL
1	7.77E-06	8.27E-06	2.85E-03	3.11E-06	4.05E-04	9.92E-03	2.37E-03	1.80E-03	1.74E-02
2	6.25E-06	1.11E-05	3.25E-03	2.11E-06	3.35E-04	5.79E-03	2.23E-03	1.37E-03	1.30E-02
3	2.99E-06	1.24E-06	2.95E-04	1.16E-06	2.33E-04	1.10E-03	3.00E-04	3.89E-04	2.32E-03
4	2.80E-06	1.41E-06	3.23E-04	1.01E-06	2.08E-04	9.72E-04	2.35E-04	3.23E-04	2.07E-03
5	2.02E-06	1.47E-06	3.60E-04	1.14E-06	2.22E-04	1.35E-03	3.41E-04	3.49E-04	2.63E-03
6	2.62E-06	2.40E-06	7.42E-04	1.77E-06	3.34E-04	1.08E-03	7.39E-04	6.19E-04	3.52E-03
7	2.77E-06	2.09E-06	5.85E-04	1.96E-06	4.26E-04	1.85E-03	5.54E-04	4.86E-04	3.91E-03
8	2.92E-06	1.99E-06	5.35E-04	2.15E-06	3.97E-04	1.74E-03	1.27E-03	8.49E-04	4.80E-03
9	5.82E-06	1.59E-06	2.47E-04	1.74E-06	1.60E-04	8.50E-04	2.40E-04	2.74E-04	1.78E-03
10	5.65E-06	1.50E-06	2.15E-04	1.65E-06	1.50E-04	8.10E-04	2.13E-04	2.51E-04	1.65E-03
11	5.37E-06	1.42E-06	1.88E-04	1.51E-06	1.42E-04	7.76E-04	1.91E-04	2.28E-04	1.53E-03
12	5.62E-06	1.45E-06	1.97E-04	1.64E-06	1.44E-04	7.86E-04	1.97E-04	2.35E-04	1.57E-03
13	5.80E-06	1.47E-06	2.04E-04	1.73E-06	1.46E-04	7.92E-04	2.02E-04	2.40E-04	1.59E-03
14	6.04E-06	1.51E-06	2.21E-04	1.86E-06	1.51E-04	8.11E-04	2.14E-04	2.52E-04	1.66E-03
15	6.23E-06	1.55E-06	2.33E-04	1.97E-06	1.54E-04	8.25E-04	2.24E-04	2.60E-04	1.71E-03
16	6.73E-06	1.64E-06	2.66E-04	2.25E-06	1.70E-04	1.66E-03	5.79E-04	4.52E-04	3.14E-03
17	6.93E-06	1.67E-06	2.78E-04	2.37E-06	1.74E-04	1.69E-03	6.00E-04	4.64E-04	3.22E-03
18	7.24E-06	1.71E-06	2.94E-04	2.56E-06	1.78E-04	1.72E-03	6.26E-04	4.78E-04	3.31E-03
19	7.68E-06	1.79E-06	3.24E-04	2.83E-06	1.88E-04	1.79E-03	6.81E-04	5.05E-04	3.50E-03
20	7.63E-06	2.74E-06	6.44E-04	2.79E-06	1.83E-04	1.75E-03	6.52E-04	4.91E-04	3.73E-03
21	7.58E-06	2.70E-06	6.24E-04	2.76E-06	1.79E-04	1.73E-03	6.31E-04	4.80E-04	3.66E-03
22	1.09E-05	2.61E-06	5.86E-04	3.09E-06	1.72E-04	1.68E-03	5.93E-04	4.60E-04	3.51E-03
23	1.21E-05	2.78E-06	6.62E-04	3.65E-06	1.84E-04	1.77E-03	6.60E-04	4.95E-04	3.79E-03
24	1.27E-05	2.86E-06	6.97E-04	3.94E-06	1.89E-04	1.80E-03	6.91E-04	5.11E-04	3.91E-03
25	1.27E-05	2.86E-06	6.97E-04	3.94E-06	1.89E-04	1.80E-03	6.91E-04	5.11E-04	3.91E-03
26	1.33E-05	3.01E-06	7.64E-04	4.24E-06	2.01E-04	1.88E-03	7.60E-04	5.44E-04	4.17E-03
27	1.46E-05	3.16E-06	8.27E-04	4.87E-06	2.11E-04	1.95E-03	8.18E-04	5.71E-04	4.40E-03
28	1.49E-05	3.20E-06	8.45E-04	5.05E-06	2.14E-04	1.97E-03	8.35E-04	5.79E-04	4.47E-03
29	1.51E-05	3.22E-06	8.57E-04	5.16E-06	2.15E-04	1.98E-03	8.46E-04	5.84E-04	4.51E-03
30	1.54E-05	3.25E-06	8.68E-04	5.28E-06	2.17E-04	1.99E-03	8.57E-04	5.89E-04	4.55E-03
31	1.46E-05	3.10E-06	8.00E-04	4.89E-06	2.05E-04	1.92E-03	7.87E-04	5.57E-04	4.29E-03
32	1.43E-05	3.02E-06	7.65E-04	4.76E-06	1.98E-04	1.88E-03	7.50E-04	5.39E-04	4.16E-03
33	1.44E-05	3.01E-06	7.60E-04	4.79E-06	1.97E-04	1.87E-03	7.44E-04	5.36E-04	4.13E-03
34	1.49E-05	3.05E-06	7.81E-04	5.02E-06	2.00E-04	1.89E-03	7.63E-04	5.45E-04	4.20E-03
35	1.55E-05	3.05E-06	7.80E-04	5.36E-06	1.37E-04	1.89E-03	7.56E-04	5.42E-04	4.13E-03
36	1.67E-05	3.08E-06	7.93E-04	5.97E-06	1.36E-04	1.91E-03	2.93E-04	2.93E-04	3.45E-03
37	2.54E-05	1.81E-06	3.87E-04	5.91E-06	1.27E-04	1.83E-03	2.90E-04	2.91E-04	2.96E-03
38	1.64E-05	3.00E-06	7.58E-04	5.83E-06	1.32E-04	1.87E-03	2.84E-04	2.86E-04	3.36E-03
39	2.44E-05	1.71E-06	3.45E-04	5.58E-06	1.18E-04	2.63E-03	3.04E-04	3.01E-04	3.73E-03
40	2.40E-05	1.69E-06	3.36E-04	5.44E-06	1.16E-04	2.60E-03	3.12E-04	3.06E-04	3.70E-03
41	2.29E-05	1.63E-06	3.11E-04	5.08E-06	1.12E-04	2.54E-03	3.71E-04	3.45E-04	3.71E-03
42	2.38E-05	1.65E-06	3.21E-04	5.37E-06	1.13E-04	2.57E-03	3.49E-04	3.31E-04	3.72E-03
43	2.41E-05	1.66E-06	3.24E-04	5.47E-06	1.13E-04	2.58E-03	3.90E-04	3.56E-04	3.80E-03
44	2.33E-05	1.61E-06	3.05E-04	5.20E-06	1.09E-04	2.53E-03	2.77E-04	2.82E-04	3.53E-03
45	2.20E-05	1.55E-06	2.78E-04	4.79E-06	1.05E-04	2.45E-03	2.56E-04	2.65E-04	3.38E-03
46	1.95E-05	1.56E-06	2.80E-04	3.16E-06	7.68E-05	2.49E-03	7.00E-05	1.40E-04	3.08E-03
47	2.05E-05	1.60E-06	3.01E-04	3.43E-06	7.90E-05	2.55E-03	7.44E-05	1.48E-04	3.18E-03
48	2.11E-05	1.64E-06	3.14E-04	3.59E-06	8.07E-05	2.59E-03	7.74E-05	1.53E-04	3.24E-03
49	2.52E-05	6.42E-07	1.17E-04	4.67E-06	8.74E-05	2.79E-03	9.22E-05	1.74E-04	3.29E-03
50	2.75E-05	1.88E-06	4.17E-04	5.30E-06	9.18E-05	2.89E-03	1.01E-04	1.85E-04	3.72E-03
51	1.35E-05	6.37E-07	1.15E-04	2.28E-06	8.43E-05	2.74E-03	8.92E-05	1.70E-04	3.22E-03
52	1.25E-05	6.14E-07	1.06E-04	2.01E-06	8.01E-05	2.69E-03	8.23E-05	1.60E-04	3.13E-03
53	1.20E-05	6.05E-07	1.03E-04	1.48E-06	6.81E-05	2.69E-03	7.94E-05	1.56E-04	3.11E-03
54	1.28E-05	6.32E-07	1.13E-04	1.68E-06	7.08E-05	2.79E-03	8.66E-05	1.66E-04	3.24E-03
55	7.24E-05	8.88E-07	2.24E-04	1.75E-05	1.26E-04	4.75E-03	1.78E-04	3.02E-04	5.67E-03
56	6.86E-05	1.04E-06	2.91E-04	1.62E-05	1.48E-04	5.66E-03	2.33E-04	3.57E-04	6.78E-03
57	5.33E-05	1.60E-06	5.97E-04	1.16E-05	2.27E-04	5.22E-03	3.78E-04	6.26E-04	7.12E-03
58	5.17E-05	1.80E-06	7.03E-04	1.11E-05	2.44E-04	5.96E-03	4.51E-04	7.24E-04	8.15E-03
59	1.34E-05	6.36E-07	1.15E-04	2.27E-06	8.44E-05	2.80E-03	8.90E-05	1.70E-04	3.28E-03
60	6.54E-05	1.11E-06	3.65E-04	1.02E-05	2.16E-04	4.59E-03	3.28E-04	5.51E-04	6.13E-03
61	1.52E-05	2.95E-06	7.37E-04	5.19E-06	1.31E-04	1.85E-03	7.12E-04	5.21E-04	3.98E-03
62	1.68E-05	3.04E-06	7.76E-04	6.02E-06	1.34E-04	1.89E-03	3.80E-04	3.50E-04	3.56E-03
63	2.47E-05	1.67E-06	3.30E-04	5.66E-06	1.14E-04	2.60E-03	2.97E-04	2.96E-04	3.67E-03

Operational Area Modeling

Argonne National Laboratory - West

One emission point was modeled as a stack. Table III-5 contains the stack data used in the analyses.

- ANL-764-001 - Experimental Breeder Reactor II (EBR-II) and Fuel Conditioning Facility (FCF)

ANL-785-018 - Hot Fuel Examination Facility (HFEF) was modeled separately as a ground-level release. All remaining sources were modeled as a composite ground-level release.

The location of the INEL MEI to ANL-W was a residence, 37219 meters (23.1 miles) west-southwest of ANL-W.

Central Facilities Area

The RESL laboratory vents were modeled as a composite ground-level release. The remaining sources were vents or short stacks, and were modeled as a composite ground-level release.

The location of the INEL MEI to CFA was a residence, 14359 meters (8.9 miles) southwest of CFA.

Idaho Chemical Processing Plant

Two emission points were modeled as stacks. Table III-5 contains the stack data used in the analyses.

- ICPP FAST stack (CPP-767-001)
- ICPP Main stack (CPP-708-001).

All remaining sources were modeled as a composite ground-level release.

The location of the INEL MEI to ICPP was a residence, 18718 meters (11.6 miles) south-southwest of ICPP.

Naval Reactors Facility

See Appendix A.

The location of the INEL MEI to NRF was a residence, 26675 meters (16.6 miles) south-southwest of NRF.

Power Burst Facility Area

One emission point was modeled as a stack. Table III-5 contains the stack data used in the analyses.

- PBF (PER-620-016)

All remaining sources were modeled as a composite ground-level release.

The location of the INEL MEI to PBF was a residence, 20141 meters (12.5 miles) southwest of PBF.

Radioactive Waste Management Complex

All RWMC sources were modeled as a composite ground-level release.

The location of the INEL MEI to RWMC was a residence, 7976 meters (4.9 miles) south-southwest of RWMC.

Test Area North (including Specific Manufacturing Capability)

One emission point was modeled as a stack. Table III-5 contains the stack data used in the analyses.

- TAN TSF Exhaust (TAN-734-001).

The location of the nearest receptor for this stack was a residence/farm 13.0 km north-northeast of TAN. The remaining release points at TAN were modeled as a composite ground-level release. The location of the INEL MEI to TAN was a residence, 54612 meters (33.9 miles) south-southwest of TAN.

The 14 SMC emission points were modeled as a composite ground-level release. The location of the INEL MEI to SMC was a residence, 54405 meters (33.8 miles) south-southwest of SMC.

Test Reactor Area

Two emission points were modeled as stacks. Table III-5 contains the stack data used in the analyses.

- MTR Stack (TRA-710-001)
- ATR Stack (TRA-770-001).

The Alpha Lab, TRA Hot Cell and Chem. Lab. Addition emission points were modeled as a composite ground-level release. The remaining sources were vents or short stacks, and were modeled as composite ground-level releases.

The location of the INEL MEI to TRA was a residence, 19172 meters (11.9 miles) south-southwest of TRA.

IV. Construction/Modification Projects

Section 61.94(b)(8) of 40 CFR 61 requires that an annual report identify and briefly describe all construction and modifications (completed in the applicable calendar year) for which the requirement to apply for approval to construct or modify was waived under Section 61.96. For calendar year 1995, no additional new construction or modification was completed at the INEL that would result in a potential increase in radionuclide airborne emissions. NRF construction and modifications are discussed in Appendix A.

V. REFERENCES

Clawson, K.L., G. E. Start, and N. R. Ricks, 1989, *Climatology of the Idaho National Engineering Laboratory 2nd Edition*, DOE/ID-12118.

DOE (U.S. Department of Energy), 1991, *Draft Environmental Impact Statement for the Siting, Construction, and Operation of New Production Reactor Capacity, Volumes 1-4*, DOE/EIS-0144D, April.

DOE, 1987, *Fuel Processing Restoration at the Idaho National Engineering Laboratory*, DOE/EA-0306.


EPA (U.S. Environmental Protection Agency), 1990, *The Clean Air Act Assessment Package - 1988 (CAP-88), A Dose and Risk Assessment Methodology for Radionuclide Emissions to Air, Volumes 1-3*, prepared by D. A. Beres, SC&A, Inc., for the U.S. Environmental Protection Agency.

EPA, 1989, *Procedures Approved for Demonstrating Compliance with 40 CFR 61, Subpart I*, EPA 520/1-89-001.

Miller, G.V., and S. J. Maher, 1991, *Software Verification and Validation Plan for CAP-88 Codes*, EGG-CATT-9975.

NCRP (National Council on Radiation Protection and Measurement), 1989, *Screening Techniques for Determining Compliance with Environmental Standards*, NCRP Commentary No. 3.

TRA-ATR-808, *Sectorized Landuse and Population Information Centered on the Test Reactor Area, Idaho National Engineering Laboratory*.



APPENDIX A

Naval Reactors Facility

Radionuclide Air Emissions Report

BETTIS-IDAHO
Calendar Year 1995

1995

Naval Reactors Facility (NRF)
National Emission Standards
for Hazardous Air Pollutants
(NESHAPs) - Radionuclide
Annual Report

Prepared for the U.S. Department of Energy
by the Westinghouse Electric Corporation
Under Contract No. DE-AC11-93PN38195



**U. S. Department of Energy
Radionuclide Air Emissions Annual Report
(under Subpart H of 40 CFR Part 61)
Calendar Year 1995**

Site Name: Idaho National Engineering Laboratory

Area: Naval Reactors Facility (NRF)

Site Information (NRF)

Operator: Westinghouse Electric Corporation
Address: P. O. Box 2068
Idaho Falls, Idaho 83403-2068
Contact: J. L. Lucas
Phone: (208) 533-5526

Operations Office Information (NRF)

Office: Pittsburgh Naval Reactors Office
Address: Idaho Branch Office
P. O. Box 2469
Idaho Falls, Idaho 83403-2469
Contact: T. M. Bradley
Phone: (208) 533-5317

I. FACILITY INFORMATION

Site Description

The Naval Reactors Facility (NRF) is operated for the Department of Energy (DOE) by Westinghouse Electric Corporation and is located on the Idaho National Engineering Laboratory (INEL) Site (Figure 1). NRF is located approximately 8.1 miles (13,100 meters) north of the Central Facilities Area (CFA) and 6.7 miles (10,800 meters) from the nearest INEL border. The nearest population center is Howe which is located approximately 10.1 miles (16,200 meters) from NRF. Howe has approximately 20 residents. In addition, there are individual homes, farms, and ranches located in close proximity to the INEL boundaries surrounding NRF. Section III provides specific information concerning the distances to locations used for dose modeling.

The climate of the INEL is characterized as semi-arid. The INEL is located on the Snake River Plain with an elevation of approximately 5000 feet (1500 meters), and it is surrounded by mountains. Air masses entering the Snake River Plain from the west lose most of their moisture to precipitation prior to encountering the INEL; therefore, annual precipitation at the INEL is light. Winds are channeled over the Snake River Plain by bordering mountain ranges so that a southwest wind predominates over the INEL. The second most frequent winds are from the northeast. The average air temperature, average wind speed, and the average precipitation are included in the CAP-88 calculations.

The Expended Core Facility (ECF) and three naval nuclear prototypes (S1W, A1W, and S5G) are located on the developed portion of NRF, which covers 84 acres (34 hectares). ECF is a large laboratory designed to receive, handle, examine, measure, and test naval nuclear reactor fuel modules and engineering test specimens. The three prototypes, when operating, were utilized to test advanced Naval Reactors components and to train United States Navy personnel for service aboard nuclear-powered ships. The S1W, A1W, and S5G prototypes concluded operation in October 1989, January 1994, and May 1995, respectively. At present, the S1W prototype is defueled and in systems layup; the A1W and the S5G prototypes are shutdown in preparation for defueling and systems layup.

Source Description

NRF receives spent fuel and radioactive components from the U. S. Naval Nuclear Propulsion Program, shipped in DOE/Nuclear Regulatory Commission (NRC) approved shipping containers in accordance with Department of Transportation requirements. The shipments are processed and examined at the Expended Core

RELATION OF NRF TO THE INEL




FIGURE 1

Facility. After processing and examination, the naval fuel is transported to the Idaho Chemical Processing Plant (ICPP).

Radioactive materials at NRF include enriched uranium fuel with associated fission products, activation products, and activated corrosion and wear products. The principal activation products of concern are carbon-14 and tritium; during prototype operation, short-lived argon-41 was also an activation product. The corrosion and wear products are present as insoluble metal oxide particles with cobalt-60 being the predominant radionuclide. Various sources are used for calibrating and checking equipment, verifying shielding, and performing radiography. The sources include cobalt-60, cesium-137, and iridium-192. Soil with low levels of cobalt-60 and cesium-137 from fallout and from past operations is also present at NRF.

Radioactive materials are handled and processed in several areas at NRF, including shielded cells, chemical and metallurgical laboratories, machine shops, and radioactive material storage containers. Physical, chemical, and metallurgical testing of small quantities of highly radioactive material specimens is performed in the ECF shielded cells. Radioactive work is performed in appropriate containment; storage and movement of radioactive materials is under strict control. Machine shops are used to perform machining operations such as turning, milling, and drilling on a variety of metal components. Though infrequently used, special laboratory facilities are available for the chemical analysis of potentially radioactive and low-level radioactive samples.

All radioactive material is controlled by a Radioactive Material Accountability system and maintained in designated storage areas. All movements of radioactive material within the facility are performed under escort of qualified radiological controls personnel and recorded in the accountability system.

Radioactive liquids are utilized in support facilities. The majority of radioactive liquids are processed through a series of filters and demineralizers for reuse. Radioactive liquids which cannot be reused are solidified for storage or disposal as radioactive waste.

Disposable materials and waste products associated with the handling of radioactive materials are controlled and tracked as radioactive wastes. These waste materials are segregated into compactible wastes, non-compactible wastes, dewatered resin/carbon media, and solidified liquids. The wastes are temporarily stored on-site in designated storage areas until sufficient quantities accumulate to comprise a shipment to a DOE low-level disposal site.

Radionuclide emissions to the atmosphere can come from six main sources at NRF. These are (1) A1W, (2) A1W Radioactive Waste Processing System (RWPS), (3) S5G, (4) S1W, (5) ECF, and (6) fugitive and temporary sources.

- (1) The shutdown A1W prototype plant (Buildings 616 and 617) handles chromated water and plant discharge water, which is reused after radionuclides and impurities are removed. As part of the defueling preparations, A1W also handles contaminated materials such as tools, equipment, anti-contamination clothing, and contaminated waste.
- (2) The A1W RWPS (Building 628) is used for the removal of radionuclides and impurities from primary plant water drained from the A1W prototype plant during defueling preparations.
- (3) The S5G prototype plant (Building 633) handles chromated water and plant discharge water, which is reused after radionuclides and impurities are removed. A radioactive waste processing system is used for the removal of radionuclides and impurities from primary plant water from the S5G prototype plant. As part of the defueling preparations, S5G also handles contaminated materials such as tools, equipment, anti-contamination clothing, and contaminated waste.
- (4) The S1W prototype (Building 601) is no longer operational and has been inactivated; however, there are some ventilation systems which are still in use. Work is done with radioactive material during chemistry analyses in the NRF Chemistry wing of this building. Other ventilation systems in the building are in use to control the buildup of naturally occurring radon.
- (5) The Expended Core Facility (ECF Building 618) handles spent fuel from naval cores and contaminated materials such as anti-contamination clothing, tools, and other equipment. Radioactive water is present in the pits where fuel is located. Analyses are performed on radioactive materials in chemistry laboratories in this building. ECF uses excess decontaminated water from the A1W and S5G prototypes to replenish evaporation from the large water pits.
- (6) Fugitive and temporary sources are diffuse emissions not associated with a specific building vent. These sources represent fugitive soil emissions and portable blowers used on temporary containments. Portable blowers are used to ensure negative pressure in containments, provide particulate control, and, in some confined spaces, maintain occupational health and safety standards. Fugitive soil sources are emissions from defined areas surrounding NRF which potentially contain low levels of radioactivity that are exposed to the wind.

II. Air Emissions Data

NRF has a number of stacks and vents with the potential to emit low quantities of radionuclides. These emissions are monitored and calculated by NRF and the results are reported to the INEL Radioactive Waste Management Information System (RWMIS) on a monthly basis. The data is included in the calculation of the INEL's annual EDE to members of the public.

Continuous monitoring is required by 61.93(b) of 40 CFR 61, Subpart H, for emission points that have a potential to emit radionuclides in quantities that could result in an EDE to a member of the public in excess of 1% of the 10 mrem per year NESHAPs' standard, which is 0.1 mrem. As part of the INEL assessment of radiological emission points, NRF evaluated all emission sources in 1990, as reported in DOE/ID-10310, *NESHAPs 40 CFR 61.93 Monitoring Requirements for Radiological Emission Sources at INEL*. An evaluation was again performed for the 1995 INEL Title V, Tier I Operating Permit Application. None of the emission points at NRF qualify for the continuous monitoring requirement; all emission points are below the 0.1 mrem per year criteria. Confirmatory evaluations are performed annually to verify that emissions are below 1% of the standard.

Table II.1 identifies potential point sources of radionuclide air emissions. The table contains: identification codes for area, building, and vent; a general description for each of the potential emission points; a description of the effluent controls and their efficiencies, if applicable; and those emission sources which were monitored.

Table II.2 lists the combined radionuclide emissions from the point sources for calendar year 1995. This data represents those sources which are routinely monitored. Unmonitored emissions, which are calculated, are also included.

Table II.3 identifies fugitive and temporary sources for radionuclide air emissions. This category contains two types of sources. The first type includes portable filtered blowers on temporary containments and tents which can be moved if the operations move. The second type identifies areas where fugitive soils are exposed to the wind. The table contains: codes for area, building or location, and an identification code for tracking; a general description for each of the potential emission points; a description of the effluent controls and their efficiencies, if applicable; and those emission sources which were monitored.

Table II.4 lists the combined radionuclide emissions from the fugitive and temporary sources for calendar year 1995. This table includes measured values for those sources which are routinely monitored and calculated values for unmonitored emissions.

Tables II.2 and II.4 include unidentified gross beta. For determining the effective dose equivalent, the unidentified gross beta is modeled as strontium-90 with yttrium-90 daughter progeny; this is consistent with other facilities located on the INEL site. For fugitive soil sources, cesium-137 and the daughter progeny barium-137m are included.

TABLE II.1 NRF POTENTIAL POINT SOURCES FOR RADIOLOGICAL AIR EMISSIONS

NAVAL REACTORS FACILITY (NRF)			Nearest Receptor location - 13.7 km N				
AREA	BLDG	VENT	SOURCE DESCRIPTION		EFFLUENT CONTROL DESCRIPTION	EFFICIENCY ¹	MONITORED ²
NRF	601	019A	SIW MAIN STACK: chemistry laboratory fume hoods		HEPA FILTER	99.95%	X
NRF	601	019C	SIW MAIN STACK: D4 fan system		NONE		X
NRF	601	023	SIW REACTOR COMPARTMENT EXHAUST (used infrequently; system is defueled and in systems layup.)		HEPA FILTER	99.95%	<input type="checkbox"/>
NRF	601	HBRV	SIW HIGH BAY VENTS (073-076, 079, 081)		NONE		<input type="checkbox"/>
NRF	605	NA	SIW PUMP HOUSE		NONE		<input type="checkbox"/>
NRF	616	012	A1W OPERATIONS BUILDING MAIN STACK		HEPA FILTER	99.95%	X
NRF	616	039	A1W RADIOCHEMISTRY AND COUNTING ROOMS		HEPA FILTER	99.95%	X
NRF	616A	002	A1W REACTOR COMPARTMENT EMERGENCY EXHAUST (The reactor compartments are normally ventilated through NRF-617-013,020, and 021.)		HEPA FILTER	99.95%	X
NRF	616	PCMA	A1W PCMAE VENTILATION EXHAUST		HEPA FILTER	99.95%	<input type="checkbox"/>
NRF	617	002	A1W MACHINERY ROOM SPACE EXHAUST (will be used infrequently during defueling)		NONE		<input type="checkbox"/>
NRF	617	013	A1W REACTOR COMPARTMENT 3A VENTILATION EXHAUST (reactor is shutdown)		NONE		X
NRF	617	020, 021	A1W REACTOR COMPARTMENT 3B VENTILATION EXHAUST (reactor is shutdown)		NONE		X
NRF	618	HBRV	ECF HIGH BAY ROOF VENTS (18) (multiple emission points for the High Bay)		NONE		X
NRF	618	099, 103	ECF EAST & WEST STACK: number 1 and number 2 (multiple emission points for the shielded cells)		HEPA FILTER CARBON FILTER	99.95% 99.9%	<input type="checkbox"/>
NRF	628A	006	A1W RWPS VENTILATION		HEPA FILTER	99.95%	X
NRF	631	NA	RADIOACTIVE COMPONENT STORAGE WAREHOUSE: containment ventilation		HEPA FILTER	99.95%	X

TABLE II.1 NRF POTENTIAL POINT SOURCES FOR RADIOLOGICAL AIR EMISSIONS (continued)

NAVAL REACTORS FACILITY (NRF)			Nearest Receptor location - 13.7 km N		EFFLUENT CONTROL DESCRIPTION	EFFICIENCY ¹	MONITORED ²
AREA	BLDG	VENT	SOURCE DESCRIPTION				
NRF	633A	057	SSG RADIOACTIVE AREA VENTILATION SYSTEM STACK		HEPA FILTER	99.95%	⊗
NRF	633	IIIRV	SSG HIGH BAY ROOF VENTS (multiple emission points for high bay area; used infrequently during normal operations)		NONE		X
NRF	642	NA	CELITE TANK HOUSE; temporary containments and remediation water processing		HEPA FILTER	99.95%	□

1. High Efficiency Particulate Air (HEPA) Filters are tested by the manufacturer prior to delivery to NRF and by NRF during the life of the filter. The manufacturer tests the efficiency for 0.3 micron monodispersed dioctylphthalate (DOP) particles to a minimum of 99.97%. NRF tests the efficiency for 0.7 micron polydispersed DOP particles to a minimum of 99.95%.

2. An X indicates that the point source is monitored. A ⊗ indicates that the point source has both monitored and unmonitored emissions in this report. A □ indicates that the source is monitored when required.

TABLE II.2 1995 INDIVIDUAL POINT SOURCE RELEASES FROM NRF

Radionuclide	Annual Release (curies)	Annual Release (becquerels)*
H-3	9.0E-02	3.3E +09
C-14	7.7E-01	2.9E +10
Ar-41	5.5E-02	2.0E +09
Kr-85	4.3E-01	1.6E +10
Gross Beta (Modeled as Sr-90/Y-90)	8.9E-06	3.3E +05
I-131	5.4E-06	2.0E +05

* Note: 1 curie equals 3.7E+10 becquerels.

TABLE II.3 NRF POTENTIAL FUGITIVE AND TEMPORARY SOURCES OF RADIOLOGICAL AIR EMISSIONS

NAVAL REACTORS FACILITY (NRF)			Nearest Receptor location - 13.7 km NNW		
AREA	BLDG/ LOCATION	I.D. CODE	SOURCE DESCRIPTION	EFFLUENT CONTROL DESCRIPTION	EFFICIENCY ¹
NRF	601	MSC AFX	SUBCONTRACTOR PORTABLE BLOWER: containment tent	HEPA FILTER	99.95% X
NRF	605	MSC AFX	SUBCONTRACTOR PORTABLE BLOWER: containment tent	HEPA FILTER	99.95% X
NRF	616	MSC NNRS	SUBCONTRACTOR PORTABLE BLOWERS: 5 defueling preparation containments and tents	HEPA FILTER	99.95% X
NRF	633	MSC NNRS	SUBCONTRACTOR PORTABLE BLOWERS: defueling preparation containments and tent	HEPA FILTER	99.95% X
NRF	642	MSC AFX	SUBCONTRACTOR PORTABLE BLOWER: containment tent	HEPA FILTER	99.95% X
NRF	NRF (outside)	MSC AFX	SUBCONTRACTOR TEMPORARY CANVAS SHELTER: outside, movable weather tent	NONE	X
NRF	SOIL	001	SIW LEACHING PIT (NOT IN USE): fugitive soil surrounding covered area	NONE	
NRF	SOIL	002	AIW LEACHING PIT (NOT IN USE) AND SURROUNDING AREA: fugitive soil	NONE	
NRF	SOIL	003	SOUTHWEST SEWAGE LAGOON: fugitive soil in dry sewage	NONE	
NRF	SOIL	004	NRF PERIMETER AREA: fugitive soil	NONE	

- High Efficiency Particulate Air (HEPA) Filters are tested by the manufacturer prior to delivery to NRF and by NRF during the life of the filter. The manufacturer tests the efficiency for 0.3 micron monodispersed dioctylphthalate (DOP) particles to a minimum of 99.97%. NRF tests the efficiency for 0.7 micron polydispersed DOP particles to a minimum of 99.95%.
- An X indicates that the source is monitored. A blank indicates that the emissions are not monitored.

TABLE II.4 1995 FUGITIVE AND TEMPORARY SOURCE RELEASES FROM NRF

Radionuclide	Annual Release (curies)	Annual Release (becquerels)*
Co-60	2.3E-05	8.5E+05
Gross Beta (Modeled as Sr-90/Y-90)	1.1E-06	4.1E+04
Cs-137/Ba-137m	5.4E-05	2.0E+06

* Note: 1 curie equals 3.7E+10 becquerels.

III. DOSE ASSESSMENTS

Summary

Various receptors near the INEL boundary were evaluated when calculating the highest effective dose equivalent for 1995. The nearest receptor to NRF is a residence located approximately 8.5 miles (13.7 kilometers) to the north-northwest of NRF, but it did not receive the highest dose. The receptor that received the highest dose is a residence located approximately 9.8 miles (15.8 kilometers) to the north of NRF. The nearest receptor did not receive the highest dose, because it was not in the direction of the prevailing winds.

Table III.1 summarizes the EDE results for point sources, for fugitive and temporary sources, and for all sources combined. The table includes: (a) the effective dose equivalent, (b) the dose associated with each exposure pathway (ingestion, inhalation, air immersion, and ground surface deposition), (c) the organ receiving the maximum dose and the associated dose, and (d) the primary radionuclide contributing to the effective dose equivalent and the associated dose.

Subpart H of 40 CFR 61 requires that emissions of radionuclides to the ambient air from Department of Energy facilities shall not exceed those amounts which would cause any member of the public to receive in any year an effective dose equivalent of 10 millirem (100 microsievert) per year. "Member of the public" is any offsite point where there is a residence, school, business, or office. For compliance purposes, this EDE is calculated for all emission sources on the INEL. The EDE calculated for NRF is for information only; the emissions used for the NRF EDE have been included in the INEL calculation of the EDE for the maximally exposed individual.

Description of Dose Model

The CAP-88 computer code is used to calculate the effective dose equivalent from NRF releases. CAP-88 is approved for use by the Environmental Protection Agency (EPA) for demonstrating compliance with 40 CFR 61 Subpart H, "National Emission Standards for Emissions of Radionuclides Other Than Radon From Department of Energy Facilities." Two other approved computer codes are available for calculating the EDE. The COMPLY computer code was not used because the maximally exposed individual for emissions is more than 3 km from emission sources. The AIRDOS-PC code was not used because it does not include several radionuclides that are released from facilities at the INEL.

The output from CAP-88 is the EDE, which includes the 50-year committed and external EDEs. The committed EDE calculates internal exposure from ingestion and inhalation pathways, while the external EDE determines exposure from ground deposition and air immersion. The dose conversion factors are from the RADRISK dosimetric data base.

Summary of Input Parameters

The population data set used in the CAP-88 calculations is based on the 1990 census. Locations were measured during the INEL 1995 aerial survey. It is assumed that members of the population grow their own vegetables and raise their own beef and dairy cattle.

The wind file used in the CAP-88 calculations is derived from data obtained from the National Oceanic and Atmospheric Administration (NOAA). The wind data was collected during 1995 at the NRF 10-meter meteorological tower. Calm hours are apportioned into the lowest wind speed class. The sector-averaged option is used for the atmospheric dispersion calculations, because this reflects annual average conditions within a sector.

Since none of the emission points at NRF are more than 2.5 times the building height, all emissions were considered to occur at ground level. All emissions from NRF were modeled as a single release point.

Where appropriate, daughter progeny were included in the source term for releases. Gross beta is modeled as strontium-90 with yttrium-90 daughter progeny; this is consistent with other facilities located on the INEL site. The daughter progeny barium-137m is included for cesium-137.

Compliance Assessment

The effective dose equivalent at the receptor receiving the highest dose is 4.3×10^{-4} millirem (4.3×10^{-3} microsievert) and occurred at a location 15.8 km north of NRF. This effective dose equivalent is for information only. The emissions for which this dose was calculated have been included in the INEL calculation of total effective dose equivalent. It is the INEL total effective dose equivalent that is used to demonstrate compliance with the 40 CFR 61.92 standard of 10 millirem per year.

TABLE III.1 SUMMARY OF THE EFFECTIVE DOSE EQUIVALENT FOR THE NESHAPS 1995 ANNUAL REPORT


Release Point	EDE millirem	Ingestion EDE millirem	Inhalation EDE millirem	Air Immersion EDE millirem	Ground Surface EDE millirem	Maximum Organ EDE millirem	Maximum Radionuclide	Maximum Radionuclide EDE millirem
1. Point Sources	4.3E-04	4.3E-04	1.0E-07	1.8E-07	2.1E-10	Endosteum	1.8E-03	C-14
2. Fugitive and Temporary Sources	2.3E-06	6.1E-07	4.1E-08	3.4E-10	1.7E-06	Gonads & Thyroid	2.5E-06	Ba-137m
TOTAL: All Sources	4.3E-04	4.3E-04	1.4E-07	1.8E-07	1.7E-06	Endosteum	1.8E-03	C-14

Note: 100 rem equal 1 sievert, or 1 millirem equals 10 microsievert (μ sievert).

Statement of Certification

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this report, the 1995 Naval Reactors Facility National Emission Standards for Hazardous Air Pollutants (NESHAPs) - Radionuclide Annual Report. Based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment. See, 18 U.S.C. 1001.

Owner Signature:



(T. M. Bradley)

Title:

Manager, Naval Reactors Idaho Branch Office

For:

Naval Reactors Facility

Date:

6 June 1996

IV. Additional Information

The EPA requires in 40 CFR 61 Subpart H that a brief description of all construction and modifications which were completed in 1995, but for which the requirement to apply for approval to construct or modify was waived, be included. No new construction or modification was completed in 1995 which would result in a potential increase in radionuclide airborne emissions.

The effective dose equivalent from fugitive and temporary sources is 2.3×10^{-6} millirem (2.3×10^{-5} microsievert). Table III.1, in the previous section, provides a summary of the fugitive and temporary source effective dose equivalent results. The CAP-88 computer code was used to determine the effective dose equivalent as described in Section III.

Fugitive soil releases, included in fugitive and temporary sources, were calculated using soil resuspension rates of approximately one percent per year. The method used for determining resuspension rates is described in DOE/TIC-22800, Transuranic Elements in the Environment, by Wayne C. Hanson.

Supplemental Information

to the 1995 Bettis-Idaho Naval Reactors Facility (NRF)
National Emission Standards for Hazardous Air Pollutants
(NESHAPs) - Radionuclide
Annual Report

V. Supplemental Information

The information in this section is not required by the National Emission Standards for Hazardous Air Pollutants regulations under 40 CFR Section 61.94. The Department of Energy has requested this information for their guidance development and for future interactions with the Environmental Protection Agency.

Population Dose

Request: Provide an estimate of the collective effective dose equivalent for 1995 releases.

Response: The computer code CAP-88 was used to determine the collective effective dose equivalent. The collective effective dose equivalent is the sum of the effective dose equivalents for people living within a 50 mile (80 kilometer) radius of the Naval Reactors Facility (125,332 people based on the 1990 census). For 1995, the collective effective dose equivalent for point sources is 4.4×10^3 person-rem (4.4×10^5 person-sievert). For fugitive and temporary sources, the collective effective dose equivalent is 1.3×10^5 person-rem (1.3×10^7 person-sievert). The 1995 collective effective dose equivalent for all sources combined is 4.4×10^3 person-rem (4.4×10^5 person-sievert).

40 CFR Part 61 Subparts Q and T Compliance

Request: Provide information on the status of compliance with Subparts Q and T of 40 CFR Part 61 if pertinent.

Response: Subpart Q of 40 CFR Part 61, National Emission Standards for Radon Emissions From Department of Energy Facilities, is not applicable to the Naval Reactors Facility. Subpart T of 40 CFR Part 61, National Emission Standards for Radon Emissions From the Disposal of Uranium Mill Tailings, is not applicable to the Naval Reactors Facility.

Radon-220 Emissions

Request: Provide information on radon-220 emissions from sources containing uranium-232 and thorium-232 where emissions potentially can exceed 0.1 millirem (1 microsievert) per year to the public or 10 percent of the non-radon dose to the public.

Response: The Naval Reactors Facility does not have any sources of uranium-232 or thorium-232 emissions that potentially can exceed 0.1 millirem (1 microsievert) per year to the public or 10 percent of the non-radon dose to the public.

Radon-222 Emissions

Request: Provide information on non-disposal and non-storage sources of radon-222 emissions where emissions potentially can exceed 0.1 millirem per year to the public or 10 percent of the non-radon dose to the public.

Response: The Naval Reactors Facility does not have any non-disposal or non-storage sources of Radon-222 emissions that potentially can exceed 0.1 millirem (1 microsievert) per year to the public or 10 percent of the non-radon dose to the public.

40 CFR Part 61 Subpart H Compliance

Request: For the purpose of assessing facility compliance with the National Emission Standards for Hazardous Air Pollutants effluent monitoring requirements of Subpart H under Section 61.93(b), give the number of emission points subject to the continuous monitoring requirements, the number of these emission points that do not comply with the Section 61.93(b) requirements, and if possible, the cost for upgrades. Describe site periodic confirmatory measurement plans. Indicate the status of the quality assurance program described by Appendix B, Method 114.

Response: The Naval Reactors Facility does not have any emission points that require continuous monitoring under Section 61.93(b).

Periodic confirmatory measurements were accomplished by calculating the maximum unabated emissions for radiological emission points at NRF.

Though NRF does not require continuous monitoring, a quality assurance program is incorporated into the environmental monitoring program. The QA program includes equipment calibration, the use of blanks and known standards, and the annual review and validation of radioactive airborne emission data by independent peer reviewers.

APPENDIX B

INEL Research Center Report



Compliance with 40 CFR 61.94 for the INEL Research Center

40 CFR 61.94(a) Compliance with this standard is demonstrated by use of 40 CFR 61 appendix E. A comparison of the January 1, 1995 inventory plus all receipts received during the calendar year with the Appendix E limits appears in Table B-1 (See section (b)(2)). This table shows the quantity of radioactive material possessed during the calendar year is less than the Appendix E limits.

40 CFR 61.94(b) In addition to paragraph (a), the annual report will include the following information:

40 CFR 61.94(b)(1) The name and location of the facility.

Idaho National Engineering Laboratory (INEL) Research Center (IRC) facilities are located on a partially developed 14.3-hectare (35.5-acre) plot on the north side of the City of Idaho Falls. Though programs and operations at the IRC are affiliated with the INEL, the IRC is located within the city limits of Idaho Falls and is not contiguous with the INEL site, whose nearest boundary is located approximately 22 miles west of Idaho Falls.

Facilities at the IRC include office, laboratory, and technical support buildings. The largest is a 3-story office building connected by an enclosed walkway to a one-story laboratory building containing 66 laboratories. Other buildings at the IRC include the Research Office Building, Physics Building, Electric Vehicle Building, and Systems Analysis Facility.

40 CFR 61.94(b)(2) A list of the radioactive materials used at the facility.

See Table B-1.

40 CFR 61.94(b)(3) A description of the handling and processing that the radioactive materials undergo at the facility.

The laboratory/office building is principally an experimental research facility dedicated to a wide range of research areas, including industrial microbiology; geochemistry; materials characterization; welding; ceramics; thermal fluids behavior; materials testing; nondestructive evaluation of materials using a standard industrial x-ray device, x-ray diffusion, and x-ray fluorescence; analytical and environmental chemistry; and biotechnology. Sample analysis, including assay of biological samples for radioactive contamination, and other INEL support functions are also conducted at IRC facilities.

Table B-1 40 CFR 61 Appendix E Compliance Table

Radionuclide	IRC Possession Quantity (Ci) Includes 1/1/95 Inventory Plus All Materials Received in CY 1995	Physical State of Inventory	Appendix E Possession Quantity Limit (Ci)
Am-241	1.6E-08	Liquid/Powder	2.3E-03
Ba-133	2.8E-06	Liquid/Powder	4.9E-02
C-14	4.6E-06	Liquid/Powder	2.9E+02
Cl-36	1.2E-07	Liquid/Powder	1.9E-01
Co-60	2.7E-07	Liquid/Powder	1.6E-02
Cs-137	3.0E-05	Liquid/Powder	2.3E-02
Fe-55	2.1E-06	Liquid/Powder	1.4E+02
Fe-59	5.8E-06	Liquid/Powder	1.3E+00
H-3	1.0E-04	Liquid/Powder	1.5E+04
I-129	1.8E-08	Liquid/Powder	2.6E-01
Ni-63	2.1E-06	Liquid/Powder	1.4E+02
P-32	1.0E-03	Liquid/Powder	1.7E+01
Pb-210	1.0E-11	Liquid/Powder	5.5E-02
Pu-239	9.0E-10	Liquid/Powder	2.5E-03
Pu-241	2.6E-08	Liquid/Powder	1.3E-01
S-35	1.0E-03	Liquid/Powder	7.5E+01
Sr-85	8.7E-06	Liquid/Powder	1.9E+00
Tc-99	1.6E-06	Liquid/Powder	9.0E+00
Th-232	1.2E-06	Liquid/Powder	6.0E-04
U-234	1.2E-05	Liquid/Powder	7.6E-03
U-235	5.4E-07	Liquid/Powder	7.0E-03
U-238	1.2E-05	Liquid/Powder	8.6E-03

40 CFR 61.94(b)(4) A list of the stacks or vents or other points where radioactive materials are released to the atmosphere.

Radiological releases from the IRC could arise from uncontrolled laboratory fumehoods within the facility. Exhaust from most of the fume hoods is released directly to the outside atmosphere via the heat recovery fan (HRF) system of the facility HVAC system. The HRF system exhausts to the outside via three vertical vents on the north side of the mechanical penthouse on top of the IRC laboratory building. Stack height of these vents is 7.6 m (25 ft). The exhausts from other fume hoods (not exhausted to the HRF) are released to the atmosphere via a 2.1 m (7.0 ft) stack above the roof or two 8.5 m (28 ft) stacks above the roof.

40 CFR 61.94(b)(5) A description of the effluent controls that are used on each stack, vent, or other release point and an estimate of the efficiency of each control device.

None. There is no effluent control equipment associated with any of the IRC's release points.

40 CFR 61.94(b)(6) Distances from the points of release to the nearest residence, school, business or office and the nearest farms producing vegetables, milk, and meat.

Consistent with 40 CFR 61 appendix E no person lives within 10 meters of the IRC and no milk, meat, or vegetables are produced within 100 meters of the IRC.

40 CFR 61.94(b)(7) The values used for all other user-supplied input parameters for the computer models (e.g., meteorological data) and the source of these data.

Not Applicable. 40 CFR 61 appendix E used for compliance.

40 CFR 61.94(b)(8) A brief description of all construction and modifications which were completed in the calendar year for which the report is prepared, but for which the requirement to apply for approval to construct or modify was waived under § 61.96 and associated documentation developed by DOE to support the waiver.

None



APPENDIX C

1995 Meteorology Data

for CAP-88 Computer Code



Table C-1. Meteorology Data Used for 1995 ANL Ground Level Releases

	A	B	C	D	E	F	G	PERD
	OUDCAT, HARMONIC AVERAGE WIND SPEEDS (WIND TOWARDS)							WIND FREQ.
N	1.960	3.422	6.871	6.583	4.645	3.251	.000	.078
NNW	1.836	3.279	5.988	6.050	5.915	3.152	.000	.055
NW	2.460	3.092	5.952	5.888	4.865	3.086	.000	.020
WNW	1.956	3.174	5.070	5.788	4.270	2.926	.000	.018
W	1.976	2.080	5.435	4.915	4.548	3.042	.000	.027
WSW	1.973	3.019	6.319	5.213	4.865	3.073	.000	.062
SW	1.846	2.329	5.406	6.093	4.983	3.366	.000	.102
SSW	1.727	2.295	4.729	6.346	4.890	2.961	.000	.090
S	1.558	2.102	4.627	5.820	4.656	3.225	.000	.056
SSE	1.439	2.081	4.560	5.844	3.904	3.025	.000	.044
SE	1.401	1.867	4.179	5.922	4.757	3.099	.000	.031
ESE	1.498	2.365	5.803	6.989	5.070	3.000	.000	.021
E	1.535	2.593	5.784	6.945	5.110	2.959	.000	.028
ENE	1.863	2.627	6.349	8.727	3.969	3.140	.000	.079
NE	1.703	3.099	6.673	9.600	5.207	3.125	.000	.168
NNE	1.976	2.949	6.751	8.197	5.484	3.142	.000	.122
OUDAV, ARITHMETIC AVERAGE WIND SPEEDS (WIND TOWARDS)								
N	2.222	3.716	7.031	7.706	5.192	3.547	.000	
NNW	2.142	3.577	6.227	6.709	6.254	3.442	.000	
NW	2.460	3.374	6.482	6.343	5.386	3.367	.000	
WNW	2.219	3.465	5.290	6.584	5.106	3.172	.000	
W	2.231	3.084	5.700	5.349	5.015	3.315	.000	
WSW	2.229	3.288	6.666	5.576	5.357	3.352	.000	
SW	2.149	2.960	5.882	6.989	5.385	3.663	.000	
SSW	2.064	2.630	5.088	7.498	5.277	3.216	.000	
S	1.919	2.586	4.998	7.166	5.112	3.521	.000	
SSE	1.797	2.608	5.154	7.065	4.378	3.294	.000	
SE	1.753	2.481	5.081	6.812	5.253	3.381	.000	
ESE	1.860	3.104	6.062	7.722	5.290	3.264	.000	
E	1.896	3.170	6.044	7.618	5.338	3.214	.000	
ENE	2.160	2.930	6.627	10.180	5.424	3.428	.000	
NE	2.044	3.381	6.960	10.840	5.999	3.411	.000	
NNE	2.231	3.489	6.999	9.083	5.903	3.430	.000	
1	DATE	Thu Apr 25 16:46:16 1996						
0 FOR EACH STABILITY CLASS								
	A	B	C	D	E	F	G	
OFRAW, FREQUENCIES OF STABILITY CLASSES (WIND TOWARDS)								
N	4.73E-02	3.55E-02	4.58E-02	5.27E-01	1.64E-01	1.80E-01	.00E+00	
NNW	5.05E-02	1.89E-02	2.95E-02	3.81E-01	3.39E-01	1.81E-01	.00E+00	
NW	8.52E-02	6.25E-02	2.84E-02	1.82E-01	1.76E-01	4.66E-01	.00E+00	
WNW	1.21E-01	1.27E-02	1.91E-02	2.23E-01	1.21E-01	5.03E-01	.00E+00	
W	8.66E-02	1.73E-02	8.66E-03	2.51E-01	2.60E-01	3.77E-01	.00E+00	
WSW	6.16E-02	3.17E-02	3.17E-02	3.08E-01	3.36E-01	2.31E-01	.00E+00	
SW	5.57E-02	2.61E-02	5.45E-02	5.06E-01	1.85E-01	1.73E-01	.00E+00	
SSW	6.39E-02	6.01E-02	5.88E-02	5.45E-01	1.33E-01	1.39E-01	.00E+00	
S	1.29E-01	8.13E-02	1.04E-01	3.90E-01	1.46E-01	1.50E-01	.00E+00	
SSE	1.82E-01	7.92E-02	9.50E-02	4.09E-01	9.50E-02	1.40E-01	.00E+00	
SE	2.60E-01	7.55E-02	9.81E-02	3.09E-01	7.55E-02	1.81E-01	.00E+00	
ESE	3.41E-01	7.82E-02	9.50E-02	1.73E-01	3.35E-02	2.79E-01	.00E+00	
E	1.92E-01	1.00E-01	1.04E-01	3.00E-01	7.08E-02	2.33E-01	.00E+00	
ENE	8.16E-02	4.52E-02	7.87E-02	6.10E-01	6.61E-02	1.18E-01	.00E+00	
NE	3.80E-02	3.31E-02	6.63E-02	7.19E-01	7.98E-02	6.42E-02	.00E+00	
NNE	3.79E-02	3.79E-02	5.78E-02	6.43E-01	1.14E-01	1.10E-01	.00E+00	
TOT	8.12E-02	4.44E-02	6.15E-02	5.05E-01	1.46E-01	1.63E-01	.00E+00	

Table C-2.

Meteorology Data Used for 1995 ANL Elevated Releases

	A	B	C	D	E	F	G	PERD
OUDCAT, HARMONIC AVERAGE WIND SPEEDS (WIND TOWARDS)								
N	2.112	3.982	5.126	7.620	5.727	1.843	.000	.057
NNW	2.076	4.004	3.494	5.160	5.369	1.545	.000	.021
NW	2.203	3.842	3.873	5.457	3.535	1.533	.000	.010
WNW	1.994	2.460	2.894	4.614	4.584	1.792	.000	.009
W	2.245	3.513	3.631	4.635	3.296	1.790	.000	.013
WSW	1.594	2.490	3.914	3.984	4.949	2.211	.000	.034
SW	1.351	2.495	2.670	4.528	4.711	2.824	.000	.128
SSW	1.763	2.941	2.969	4.252	3.906	2.575	.000	.128
S	1.505	2.690	2.756	3.740	3.653	1.869	.000	.063
SSE	1.600	2.805	2.760	3.813	3.428	1.851	.000	.052
SE	1.397	2.044	3.126	3.791	2.585	1.640	.000	.035
ESE	1.672	2.440	3.736	3.739	2.287	1.883	.000	.029
E	1.777	2.785	3.341	4.388	3.805	1.877	.000	.036
ENE	2.008	3.591	3.841	7.464	5.448	2.488	.000	.113
NE	2.111	3.461	4.540	8.248	5.595	2.119	.000	.171
NNE	2.068	3.991	4.085	7.627	5.764	1.704	.000	.100
OUDAV, ARITHMETIC AVERAGE WIND SPEEDS (WIND TOWARDS)								
N	2.365	4.169	5.472	9.115	6.299	2.609	.000	
NNW	2.353	4.328	4.596	6.582	6.231	2.118	.000	
NW	2.351	4.068	4.620	6.250	4.791	2.160	.000	
WNW	2.325	2.460	3.130	5.588	5.007	2.793	.000	
W	2.609	3.800	4.695	5.540	4.805	2.486	.000	
WSW	2.325	2.925	4.297	4.843	5.752	3.586	.000	
SW	2.254	3.003	3.438	5.992	5.896	4.291	.000	
SSW	2.135	3.659	3.308	6.316	5.024	3.640	.000	
S	1.904	3.303	3.541	5.394	4.635	2.739	.000	
SSE	2.077	3.370	3.522	5.912	4.681	2.770	.000	
SE	1.779	2.881	4.489	5.844	3.754	2.250	.000	
ESE	2.083	3.247	4.665	4.923	3.427	2.492	.000	
E	2.252	3.425	4.671	6.483	4.958	2.635	.000	
ENE	2.341	4.084	4.823	9.690	6.643	3.553	.000	
NE	2.528	3.894	5.120	10.220	6.708	2.679	.000	
NNE	2.332	4.174	4.820	9.007	6.440	2.329	.000	
1 DATE	Thu Apr 11 11:36:10 1996							
0 FOR EACH STABILITY CLASS								
	A	B	C	D	E	F	G	
OFRAW, FREQUENCIES OF STABILITY CLASSES (WIND TOWARDS)								
N	5.54E-02	4.11E-02	5.13E-02	5.75E-01	2.18E-01	5.95E-02	.00E+00	
NNW	1.35E-01	6.18E-02	6.18E-02	4.27E-01	2.30E-01	8.43E-02	.00E+00	
NW	1.61E-01	1.15E-01	6.90E-02	2.99E-01	2.18E-01	1.38E-01	.00E+00	
WNW	2.38E-01	1.25E-02	3.75E-02	3.88E-01	1.25E-01	2.00E-01	.00E+00	
W	1.79E-01	8.04E-02	5.36E-02	2.05E-01	2.23E-01	2.59E-01	.00E+00	
WSW	6.67E-02	4.91E-02	6.32E-02	3.44E-01	3.30E-01	1.47E-01	.00E+00	
SW	3.87E-02	2.21E-02	4.33E-02	4.67E-01	3.21E-01	1.08E-01	.00E+00	
SSW	3.32E-02	2.58E-02	3.59E-02	4.59E-01	3.03E-01	1.43E-01	.00E+00	
S	8.02E-02	4.66E-02	6.53E-02	4.12E-01	2.09E-01	1.87E-01	.00E+00	
SSE	9.07E-02	3.63E-02	7.03E-02	4.17E-01	2.52E-01	1.34E-01	.00E+00	
SE	1.78E-01	4.38E-02	9.76E-02	3.43E-01	1.62E-01	1.75E-01	.00E+00	
ESE	2.07E-01	5.79E-02	6.20E-02	2.31E-01	1.53E-01	2.89E-01	.00E+00	
E	1.37E-01	4.25E-02	8.17E-02	3.69E-01	1.70E-01	1.99E-01	.00E+00	
ENE	5.41E-02	3.53E-02	5.82E-02	5.94E-01	2.04E-01	5.51E-02	.00E+00	
NE	3.44E-02	2.82E-02	5.64E-02	7.23E-01	1.29E-01	2.96E-02	.00E+00	
NNE	3.75E-02	3.99E-02	6.92E-02	6.83E-01	1.37E-01	3.28E-02	.00E+00	
TOT	6.62E-02	3.61E-02	5.73E-02	5.20E-01	2.16E-01	1.04E-01	.00E+00	

Table C-3. Meteorology Data Used for 1995 CFA Releases

A	B	C	D	E	F	G	PERD
OUDCAT, HARMONIC AVERAGE WIND SPEEDS (WIND TOWARDS)							
N	2.064	3.099	3.717	4.439	2.984	1.533	.000
NNW	1.942	2.241	2.813	3.510	2.680	1.645	.000
NW	1.628	1.820	2.350	3.357	2.606	1.787	.000
WNW	1.434	3.174	3.369	2.850	2.733	1.316	.000
W	1.554	2.143	3.047	3.076	2.280	1.307	.000
WSW	1.657	2.088	3.298	3.926	2.701	1.526	.000
SW	1.372	2.452	2.688	4.256	3.108	1.364	.000
SSW	1.566	2.325	2.630	3.294	3.097	1.581	.000
S	1.772	2.271	2.593	3.469	2.505	1.638	.000
SSE	1.574	2.254	2.977	2.609	2.128	1.511	.000
SE	1.747	2.365	4.433	2.826	2.332	1.507	.000
ESE	1.478	3.369	3.914	3.234	2.297	1.495	.000
E	1.652	3.174	3.805	3.583	2.592	1.505	.000
ENE	1.594	3.481	3.829	5.537	3.039	1.757	.000
NE	1.892	3.054	4.420	6.639	3.011	1.681	.000
NNE	2.008	3.352	3.894	5.239	2.875	1.806	.000
							.077
OUDAV, ARITHMETIC AVERAGE WIND SPEEDS (WIND TOWARDS)							
N	2.281	3.381	4.148	5.462	3.485	1.894	.000
NNW	2.210	2.793	3.699	4.027	3.270	1.997	.000
NW	1.982	2.330	3.211	3.858	3.014	2.108	.000
WNW	1.791	3.465	3.666	3.270	2.907	1.647	.000
W	1.915	2.521	3.321	4.056	2.492	1.636	.000
WSW	2.007	2.625	3.747	5.042	3.122	1.888	.000
SW	1.719	2.775	3.185	5.418	3.600	1.708	.000
SSW	1.926	2.777	3.026	4.194	3.454	1.940	.000
S	2.097	2.912	3.170	4.568	2.983	1.991	.000
SSE	1.934	2.772	4.056	3.448	2.402	1.873	.000
SE	2.079	3.104	4.694	4.067	2.483	1.868	.000
ESE	1.839	3.666	4.297	4.096	2.640	1.857	.000
E	2.003	3.465	4.173	4.489	3.162	1.867	.000
ENE	1.952	3.771	4.405	6.830	3.458	2.086	.000
NE	2.179	3.611	4.655	7.901	3.588	2.027	.000
NNE	2.250	3.650	4.244	5.977	3.449	2.121	.000
1	DATE	Thu Apr 25 16:50:00 1996					
0 FOR EACH STABILITY CLASS							
A	B	C	D	E	F	G	
OFRAW, FREQUENCIES OF STABILITY CLASSES (WIND TOWARDS)							
N	1.41E-01	6.65E-02	7.48E-02	4.13E-01	1.33E-01	1.72E-01	.00E+00
NNW	2.11E-01	5.75E-02	6.51E-02	3.03E-01	1.49E-01	2.15E-01	.00E+00
NW	3.64E-01	4.35E-02	6.52E-02	2.12E-01	1.03E-01	2.12E-01	.00E+00
WNW	4.63E-01	4.88E-02	4.07E-02	1.30E-01	7.32E-02	2.44E-01	.00E+00
W	4.06E-01	5.80E-02	5.07E-02	1.09E-01	1.09E-01	2.68E-01	.00E+00
WSW	2.38E-01	8.92E-02	7.81E-02	3.64E-01	8.18E-02	1.49E-01	.00E+00
SW	8.13E-02	3.95E-02	8.58E-02	5.88E-01	1.25E-01	8.01E-02	.00E+00
SSW	5.46E-02	2.73E-02	4.82E-02	5.76E-01	2.11E-01	8.28E-02	.00E+00
S	8.47E-02	4.23E-02	4.84E-02	4.05E-01	1.83E-01	2.36E-01	.00E+00
SSE	9.67E-02	2.67E-02	5.33E-02	2.37E-01	1.80E-01	4.07E-01	.00E+00
SE	6.92E-02	4.84E-02	4.50E-02	2.87E-01	1.49E-01	4.01E-01	.00E+00
ESE	9.38E-02	1.74E-02	3.13E-02	3.40E-01	2.01E-01	3.16E-01	.00E+00
E	4.59E-02	3.21E-02	2.75E-02	4.93E-01	1.95E-01	2.06E-01	.00E+00
ENE	2.65E-02	2.04E-02	3.89E-02	6.78E-01	1.39E-01	9.73E-02	.00E+00
NE	2.21E-02	2.38E-02	5.64E-02	7.88E-01	5.41E-02	5.52E-02	.00E+00
NNE	8.75E-02	7.39E-02	9.80E-02	4.90E-01	1.01E-01	1.49E-01	.00E+00
TOT	8.61E-02	3.76E-02	5.76E-02	5.40E-01	1.32E-01	1.46E-01	.00E+00

Table C-4.

Meteorology Data Used for 1995 ICPP Ground Level Releases

	A	B	C	D	E	F	G	PERD
OUDCAT, HARMONIC AVERAGE WIND SPEEDS (WIND TOWARDS)								
N	1.933	2.718	2.831	3.778	2.635	1.541	.000	.051
NNW	1.776	2.319	2.724	2.898	2.378	1.437	.000	.029
NW	1.746	1.899	2.376	2.617	2.291	1.388	.000	.015
WNW	1.578	1.899	3.559	3.369	2.460	1.455	.000	.014
W	1.654	1.678	3.047	3.136	2.227	1.442	.000	.016
WSW	1.662	2.495	2.740	3.928	2.672	1.403	.000	.052
SW	1.507	2.235	2.675	3.567	2.787	1.512	.000	.130
SSW	1.483	2.037	2.702	3.015	2.482	1.499	.000	.102
S	1.425	2.061	3.055	3.433	2.076	1.388	.000	.063
SSE	1.452	2.439	4.789	4.105	1.898	1.330	.000	.036
SE	1.504	2.641	2.545	2.763	1.829	1.236	.000	.020
ESE	1.592	3.000	4.345	3.596	2.111	1.396	.000	.021
E	1.804	2.029	3.842	3.880	2.397	1.442	.000	.030
ENE	1.607	3.259	4.196	4.585	2.950	1.453	.000	.084
NE	1.818	2.896	3.675	5.972	3.039	1.555	.000	.216
NNE	2.077	3.067	4.014	4.775	2.647	1.584	.000	.121
OUDAV, ARITHMETIC AVERAGE WIND SPEEDS (WIND TOWARDS)								
N	2.205	3.244	3.542	4.806	3.071	1.903	.000	
NNW	2.100	2.668	3.418	3.586	2.808	1.794	.000	
NW	2.078	2.581	3.023	3.079	2.490	1.738	.000	
WNW	1.938	2.581	4.158	3.666	2.460	1.814	.000	
W	2.004	2.024	3.321	4.061	2.816	1.800	.000	
WSW	2.011	3.003	3.123	5.195	3.329	1.756	.000	
SW	1.869	2.617	3.062	4.600	3.282	1.874	.000	
SSW	1.844	2.614	3.217	3.843	2.893	1.861	.000	
S	1.781	2.677	4.013	4.553	2.576	1.738	.000	
SSE	1.811	3.308	4.931	5.779	2.373	1.666	.000	
SE	1.865	3.407	3.763	4.198	2.455	1.534	.000	
ESE	1.950	3.264	4.498	5.193	2.802	1.748	.000	
E	2.120	2.791	4.068	5.048	2.882	1.800	.000	
ENE	1.964	3.556	4.609	5.845	3.451	1.812	.000	
NE	2.130	3.319	4.349	7.402	3.590	1.916	.000	
NNE	2.288	3.476	4.253	5.878	3.142	1.943	.000	
1	DATE	Thu Apr 25 17:06:13 1996						
0 FOR EACH STABILITY CLASS								
	A	B	C	D	E	F	G	
OFRAW, FREQUENCIES OF STABILITY CLASSES (WIND TOWARDS)								
N	1.79E-01	7.35E-02	4.14E-02	3.33E-01	1.26E-01	2.46E-01	.00E+00	
NNW	2.08E-01	4.89E-02	4.49E-02	2.57E-01	1.88E-01	2.53E-01	.00E+00	
NW	3.20E-01	3.20E-02	6.39E-02	1.68E-01	1.28E-01	2.88E-01	.00E+00	
WNW	3.57E-01	3.47E-02	4.34E-02	8.68E-02	8.68E-02	3.92E-01	.00E+00	
W	3.41E-01	5.07E-02	5.07E-02	1.38E-01	1.01E-01	3.19E-01	.00E+00	
WSW	1.71E-01	5.48E-02	6.39E-02	4.08E-01	1.28E-01	1.74E-01	.00E+00	
SW	6.77E-02	3.43E-02	7.57E-02	5.81E-01	1.57E-01	8.49E-02	.00E+00	
SSW	8.88E-02	3.69E-02	6.10E-02	4.55E-01	2.20E-01	1.38E-01	.00E+00	
S	8.45E-02	3.00E-02	5.62E-02	3.88E-01	2.06E-01	2.35E-01	.00E+00	
SSE	1.09E-01	4.27E-02	5.26E-02	3.22E-01	1.38E-01	3.36E-01	.00E+00	
SE	1.03E-01	5.16E-02	2.87E-02	1.89E-01	8.61E-02	5.41E-01	.00E+00	
ESE	1.15E-01	2.74E-02	8.78E-02	1.98E-01	8.78E-02	4.84E-01	.00E+00	
E	1.41E-01	3.53E-02	1.96E-02	3.33E-01	1.25E-01	3.46E-01	.00E+00	
ENE	5.17E-02	1.54E-02	5.17E-02	5.54E-01	1.62E-01	1.65E-01	.00E+00	
NE	2.78E-02	1.69E-02	4.74E-02	7.14E-01	1.13E-01	8.13E-02	.00E+00	
NNE	7.78E-02	4.27E-02	7.48E-02	5.29E-01	1.38E-01	1.38E-01	.00E+00	
TOT	9.49E-02	3.42E-02	5.73E-02	4.92E-01	1.46E-01	1.75E-01	.00E+00	

Table C-5. Meteorology Data Used for 1995 ICPP Elevated Releases

	A	B	C	D	E	F	G	PERD
OUDCAT, HARMONIC AVERAGE WIND SPEEDS (WIND TOWARDS)								
N	2.147	3.032	3.279	4.339	3.492	1.770	.000	.040
NNW	1.641	3.000	2.146	3.134	2.817	1.440	.000	.027
NW	1.657	1.765	2.211	2.395	2.052	1.485	.000	.016
WNW	1.642	2.703	3.313	1.936	2.248	1.808	.000	.015
W	1.670	2.025	3.277	2.993	2.441	1.760	.000	.020
WSW	1.687	2.655	2.738	4.254	3.934	2.195	.000	.069
SW	1.769	2.612	2.853	4.099	4.142	2.702	.000	.198
SSW	1.873	2.041	2.732	3.703	3.863	2.366	.000	.103
S	1.549	2.063	3.455	5.199	2.960	1.692	.000	.035
SSE	1.750	4.470	4.392	6.176	3.325	1.686	.000	.023
SE	1.800	4.470	5.680	4.733	3.462	1.510	.000	.015
ESE	1.429	3.712	4.573	5.877	2.474	1.708	.000	.017
E	1.851	4.252	5.272	6.019	4.105	1.959	.000	.028
ENE	1.447	3.311	4.545	7.016	4.828	2.109	.000	.099
NE	1.952	2.952	4.092	8.123	5.128	1.921	.000	.202
NNE	1.998	3.580	3.904	5.653	3.967	1.973	.000	.091
OUDAV, ARITHMETIC AVERAGE WIND SPEEDS (WIND TOWARDS)								
N	2.324	3.452	4.182	5.800	4.521	2.433	.000	
NNW	1.993	3.264	2.959	3.960	3.594	1.913	.000	
NW	2.007	2.622	3.238	3.310	3.252	2.096	.000	
WNW	2.066	2.862	3.875	2.889	3.621	2.327	.000	
W	2.132	2.548	3.773	4.180	3.093	2.467	.000	
WSW	2.120	3.187	3.102	6.101	4.756	3.140	.000	
SW	2.128	3.117	3.326	5.363	5.090	3.915	.000	
SSW	2.212	2.983	3.700	5.014	4.611	3.365	.000	
S	2.020	3.117	4.993	7.377	4.546	2.322	.000	
SSE	2.164	4.470	6.090	8.542	4.324	2.253	.000	
SE	2.324	4.470	5.946	5.859	3.912	2.002	.000	
ESE	1.858	3.968	4.958	7.234	3.423	2.412	.000	
E	2.270	4.520	5.524	7.406	5.066	2.616	.000	
ENE	1.869	3.609	5.278	8.772	6.044	2.914	.000	
NE	2.277	3.411	4.879	10.010	6.269	2.931	.000	
NNE	2.320	3.858	4.487	7.419	5.028	2.656	.000	
1	DATE	Thu Apr 11 11:41:02 1996						
0 FOR EACH STABILITY CLASS								
	A	B	C	D	E	F	G	
OFRAW, FREQUENCIES OF STABILITY CLASSES (WIND TOWARDS)								
N	1.67E-01	1.16E-01	5.95E-02	3.78E-01	1.40E-01	1.40E-01	.00E+00	
NNW	2.15E-01	4.39E-02	4.39E-02	2.41E-01	2.15E-01	2.41E-01	.00E+00	
NW	2.70E-01	2.19E-02	6.57E-02	1.97E-01	1.46E-01	2.99E-01	.00E+00	
WNW	3.41E-01	3.88E-02	4.65E-02	1.24E-01	1.47E-01	3.02E-01	.00E+00	
W	2.44E-01	6.40E-02	4.65E-02	2.09E-01	1.92E-01	2.44E-01	.00E+00	
WSW	9.28E-02	4.98E-02	6.70E-02	4.07E-01	2.25E-01	1.58E-01	.00E+00	
SW	2.94E-02	1.74E-02	4.68E-02	4.90E-01	3.02E-01	1.14E-01	.00E+00	
SSW	4.06E-02	2.32E-02	4.98E-02	4.22E-01	3.13E-01	1.52E-01	.00E+00	
S	9.83E-02	6.44E-02	7.46E-02	4.37E-01	1.19E-01	2.07E-01	.00E+00	
SSE	9.95E-02	4.19E-02	6.81E-02	4.50E-01	7.85E-02	2.62E-01	.00E+00	
SE	1.83E-01	8.73E-02	3.97E-02	2.22E-01	7.94E-02	3.89E-01	.00E+00	
ESE	1.57E-01	2.86E-02	7.86E-02	2.93E-01	1.00E-01	3.43E-01	.00E+00	
E	1.13E-01	3.77E-02	2.93E-02	4.39E-01	1.72E-01	2.09E-01	.00E+00	
ENE	2.99E-02	1.68E-02	4.91E-02	6.07E-01	2.13E-01	8.38E-02	.00E+00	
NE	3.13E-02	1.65E-02	4.60E-02	7.31E-01	1.47E-01	2.83E-02	.00E+00	
NNE	1.10E-01	6.00E-02	7.56E-02	5.22E-01	1.68E-01	6.52E-02	.00E+00	
TOT	7.67E-02	3.38E-02	5.32E-02	5.01E-01	2.07E-01	1.26E-01	.00E+00	

Table C-6. Meteorology Data Used for 1995 NRF Releases

	A	B	C	D	E	F	G	PERD
0UDCAT, HARMONIC AVERAGE WIND SPEEDS (WIND TOWARDS)								
N	1.780	2.978	3.154	4.158	2.405	1.506	.000	.060
NNW	1.884	2.460	2.146	3.505	2.849	1.330	.000	.029
NW	1.727	3.047	2.653	3.196	2.341	1.388	.000	.021
WNW	1.531	2.043	1.574	3.282	2.090	1.403	.000	.018
W	1.802	1.867	2.193	3.048	1.912	1.474	.000	.030
WSW	1.758	2.377	2.736	3.768	3.174	1.433	.000	.064
SW	1.544	2.034	2.741	3.502	2.791	1.496	.000	.141
SSW	1.770	2.309	2.883	3.385	2.625	1.372	.000	.102
S	1.438	2.447	3.204	3.325	2.140	1.362	.000	.053
SSE	1.644	2.146	3.177	5.206	1.963	1.298	.000	.052
SE	1.526	2.365	3.340	4.556	2.700	1.174	.000	.020
ESE	1.594	3.074	4.709	4.235	1.959	1.234	.000	.017
E	1.697	2.894	5.156	4.596	1.757	1.339	.000	.022
ENE	1.726	2.959	3.969	5.810	2.782	1.437	.000	.070
NE	1.953	3.038	4.185	5.944	3.115	1.534	.000	.171
NNE	1.908	3.086	4.104	4.458	2.893	1.632	.000	.130
0UDAV, ARITHMETIC AVERAGE WIND SPEEDS (WIND TOWARDS)								
N	2.103	3.238	3.852	5.152	2.942	1.868	.000	
NNW	2.174	2.460	2.959	4.216	3.345	1.666	.000	
NW	2.064	3.321	4.255	3.784	2.810	1.738	.000	
WNW	1.893	2.269	2.252	4.112	2.533	1.756	.000	
W	2.119	2.277	2.876	3.476	2.440	1.835	.000	
WSW	2.087	2.771	3.321	4.726	3.465	1.790	.000	
SW	1.905	2.466	3.013	4.459	3.285	1.857	.000	
SSW	2.095	2.912	3.590	4.341	3.028	1.718	.000	
S	1.796	2.985	3.992	4.615	2.554	1.706	.000	
SSE	1.996	2.959	4.095	6.887	2.770	1.623	.000	
SE	1.888	3.104	3.998	5.432	3.338	1.435	.000	
ESE	1.952	3.353	4.821	4.524	2.365	1.531	.000	
E	2.039	3.130	5.393	5.398	2.366	1.677	.000	
ENE	2.062	3.214	4.536	7.273	3.316	1.795	.000	
NE	2.217	3.310	4.633	7.391	3.565	1.895	.000	
NNE	2.189	3.474	4.409	5.561	3.349	1.985	.000	
1	DATE	Thu Apr 11 12:17:24 1996						
0 FOR EACH STABILITY CLASS								
	A	B	C	D	E	F	G	
0FRRAW, FREQUENCIES OF STABILITY CLASSES (WIND TOWARDS)								
N	1.21E-01	5.86E-02	6.81E-02	4.08E-01	1.49E-01	1.95E-01	.00E+00	
NNW	2.53E-01	3.56E-02	3.95E-02	3.00E-01	8.30E-02	2.89E-01	.00E+00	
NW	2.73E-01	3.83E-02	2.73E-02	1.37E-01	1.09E-01	4.15E-01	.00E+00	
WNW	2.70E-01	5.03E-02	3.14E-02	1.13E-01	1.26E-01	4.09E-01	.00E+00	
W	2.93E-01	5.41E-02	2.32E-02	1.20E-01	1.24E-01	3.86E-01	.00E+00	
WSW	1.67E-01	6.56E-02	5.67E-02	3.48E-01	1.74E-01	1.90E-01	.00E+00	
SW	7.15E-02	4.47E-02	6.34E-02	5.61E-01	1.59E-01	1.01E-01	.00E+00	
SSW	5.16E-02	3.48E-02	6.96E-02	4.77E-01	2.03E-01	1.64E-01	.00E+00	
S	1.34E-01	4.53E-02	7.11E-02	4.07E-01	1.47E-01	1.96E-01	.00E+00	
SSE	1.02E-01	1.11E-02	5.75E-02	5.77E-01	7.08E-02	1.81E-01	.00E+00	
SE	9.04E-02	3.95E-02	9.04E-02	2.82E-01	1.36E-01	3.62E-01	.00E+00	
ESE	2.21E-01	6.04E-02	4.70E-02	1.68E-01	7.38E-02	4.30E-01	.00E+00	
E	1.53E-01	3.16E-02	4.21E-02	2.84E-01	8.95E-02	4.00E-01	.00E+00	
ENE	3.75E-02	2.61E-02	4.57E-02	6.54E-01	8.32E-02	1.53E-01	.00E+00	
NE	2.93E-02	1.73E-02	6.60E-02	7.22E-01	9.33E-02	7.20E-02	.00E+00	
NNE	5.47E-02	4.77E-02	9.36E-02	5.72E-01	1.39E-01	9.36E-02	.00E+00	
TOT	9.61E-02	3.84E-02	6.37E-02	5.02E-01	1.31E-01	1.69E-01	.00E+00	

Table C-7. Meteorology Data Used for 1995 PBF Releases

A	B	C	D	E	F	G	PERD	
0UDCAT, HARMONIC AVERAGE WIND SPEEDS (WIND TOWARDS)						WIND FREQ.		
N	1.902	3.140	2.920	4.063	2.590	1.326	.000	.077
NNW	1.706	3.712	3.643	4.359	2.955	1.382	.000	.047
NW	1.634	2.564	4.470	4.459	3.481	1.254	.000	.019
WNW	1.616	2.772	3.934	3.298	3.513	1.247	.000	.014
W	1.729	4.470	3.174	3.468	3.254	1.437	.000	.017
WSW	1.766	2.543	3.446	3.557	3.072	1.460	.000	.055
SW	1.650	2.823	2.767	4.211	3.055	1.444	.000	.131
SSW	1.781	2.493	2.791	3.678	2.636	1.593	.000	.121
S	1.378	2.467	3.224	4.216	2.033	1.303	.000	.049
SSE	1.652	2.033	2.851	4.384	2.119	1.151	.000	.033
SE	1.498	2.753	3.949	3.394	1.992	1.216	.000	.024
ESE	1.674	2.772	3.655	4.064	1.804	1.181	.000	.020
E	1.648	2.613	3.093	4.101	2.004	1.212	.000	.031
ENE	1.674	2.959	4.004	6.322	2.374	1.214	.000	.078
NE	1.814	3.442	4.290	6.701	2.336	1.257	.000	.177
NNE	1.815	3.051	3.863	4.890	2.502	1.368	.000	.105
0UDAV, ARITHMETIC AVERAGE WIND SPEEDS (WIND TOWARDS)								
N	2.186	3.428	3.666	5.197	3.154	1.660	.000	
NNW	2.047	3.968	3.912	5.154	3.628	1.731	.000	
NW	1.988	3.156	4.470	5.008	3.771	1.561	.000	
WNW	1.972	2.963	4.135	3.668	3.800	1.551	.000	
W	2.065	4.470	3.465	3.897	3.551	1.794	.000	
WSW	2.093	3.018	3.739	4.404	3.394	1.819	.000	
SW	2.001	3.034	3.449	5.257	3.477	1.803	.000	
SSW	2.103	2.829	3.250	4.763	3.118	1.952	.000	
S	1.726	2.884	3.764	5.674	2.631	1.629	.000	
SSE	2.003	3.043	3.844	6.125	2.526	1.396	.000	
SE	1.860	3.410	4.599	5.877	2.427	1.503	.000	
ESE	2.021	2.963	3.922	5.366	2.609	1.447	.000	
E	1.999	3.108	3.787	5.625	2.645	1.497	.000	
ENE	2.021	3.214	4.272	7.612	3.038	1.500	.000	
NE	2.127	3.736	4.571	8.122	3.094	1.566	.000	
NNE	2.128	3.522	4.502	6.136	3.112	1.714	.000	
1	DATE	Thu Apr 11 12:55:20 1996						
0 FOR EACH STABILITY CLASS								
A	B	C	D	E	F	G		
0FRAW, FREQUENCIES OF STABILITY CLASSES (WIND TOWARDS)								
N	8.35E-02	4.02E-02	6.55E-02	4.79E-01	1.28E-01	2.04E-01	.00E+00	
NNW	6.29E-02	2.89E-02	4.34E-02	4.82E-01	1.33E-01	2.50E-01	.00E+00	
NW	1.55E-01	7.17E-02	1.19E-02	2.49E-01	1.36E-01	3.76E-01	.00E+00	
WNW	1.77E-01	3.21E-02	4.82E-02	1.77E-01	4.82E-02	5.17E-01	.00E+00	
W	2.35E-01	6.70E-03	1.34E-02	1.54E-01	2.34E-01	3.57E-01	.00E+00	
WSW	9.51E-02	3.11E-02	2.27E-02	3.86E-01	2.77E-01	1.89E-01	.00E+00	
SW	6.72E-02	3.04E-02	4.17E-02	5.74E-01	1.70E-01	1.16E-01	.00E+00	
SSW	5.30E-02	3.79E-02	8.03E-02	5.50E-01	1.36E-01	1.43E-01	.00E+00	
S	1.12E-01	7.03E-02	6.99E-02	3.75E-01	1.21E-01	2.51E-01	.00E+00	
SSE	1.63E-01	4.22E-02	5.86E-02	3.41E-01	7.59E-02	3.19E-01	.00E+00	
SE	2.22E-01	6.29E-02	3.37E-02	1.73E-01	8.18E-02	4.26E-01	.00E+00	
ESE	1.99E-01	4.53E-02	6.23E-02	2.15E-01	7.36E-02	4.05E-01	.00E+00	
E	1.47E-01	5.89E-02	5.13E-02	3.26E-01	8.80E-02	3.28E-01	.00E+00	
ENE	6.17E-02	2.34E-02	5.27E-02	6.31E-01	5.71E-02	1.74E-01	.00E+00	
NE	3.89E-02	3.36E-02	6.02E-02	7.23E-01	5.56E-02	8.92E-02	.00E+00	
NNE	8.09E-02	6.89E-02	7.96E-02	4.99E-01	1.09E-01	1.62E-01	.00E+00	
TOT	8.42E-02	4.08E-02	5.68E-02	5.10E-01	1.18E-01	1.88E-01	.00E+00	

Table C-8. Meteorology Data Used for 1995 RWMC Releases

	A	B	C	D	E	F	G	PERD
0UDCAT, HARMONIC AVERAGE WIND SPEEDS (WIND TOWARDS)								
N	1.484	2.573	2.951	4.507	3.092	1.293	.000	.025
NNW	1.313	3.174	3.542	4.077	2.663	1.312	.000	.018
NW	1.381	2.629	3.000	3.602	2.805	1.380	.000	.016
WNW	1.648	2.292	3.542	2.894	2.862	1.334	.000	.017
W	1.661	2.680	2.909	2.739	2.565	1.502	.000	.025
WSW	1.833	2.424	2.674	3.955	2.681	1.346	.000	.070
SW	1.475	2.661	2.842	3.910	3.060	1.518	.000	.120
SSW	1.481	3.092	3.151	3.280	2.671	1.430	.000	.043
S	1.376	2.531	4.573	3.238	1.805	1.332	.000	.021
SSE	1.448	3.513	3.038	4.339	2.255	1.262	.000	.018
SE	1.505	2.629	3.742	4.507	2.015	1.253	.000	.026
ESE	1.355	2.275	3.942	3.495	1.741	1.208	.000	.036
E	1.454	2.313	3.011	2.346	1.502	1.253	.000	.080
ENE	1.505	2.816	3.461	3.951	1.846	1.308	.000	.136
NE	1.726	2.566	3.706	5.563	3.009	1.434	.000	.233
NNE	1.616	2.472	3.768	5.269	3.337	1.551	.000	.117
0UDAV, ARITHMETIC AVERAGE WIND SPEEDS (WIND TOWARDS)								
N	1.845	3.069	3.769	5.649	3.374	1.616	.000	
NNW	1.643	3.465	4.024	4.766	3.213	1.642	.000	
NW	1.729	2.747	3.264	4.281	3.370	1.728	.000	
WNW	2.000	2.710	4.024	3.494	3.088	1.671	.000	
W	2.010	3.270	3.309	3.316	2.865	1.863	.000	
WSW	2.140	2.697	3.259	4.915	3.121	1.686	.000	
SW	1.836	3.020	3.089	4.952	3.430	1.880	.000	
SSW	1.842	3.274	3.900	4.495	3.178	1.786	.000	
S	1.724	3.546	4.958	4.473	2.280	1.668	.000	
SSE	1.806	3.800	4.127	5.063	2.497	1.572	.000	
SE	1.867	2.747	4.439	5.627	2.708	1.559	.000	
ESE	1.698	2.737	4.385	4.765	2.283	1.491	.000	
E	1.813	2.898	3.752	3.666	1.999	1.560	.000	
ENE	1.867	3.505	4.249	6.305	2.491	1.637	.000	
NE	2.062	3.252	4.376	7.004	3.587	1.791	.000	
NNE	1.972	2.983	4.334	6.147	3.765	1.912	.000	
1	DATE	Thu May 16 17:48:32 1996						
0 FOR EACH STABILITY CLASS								
	A	B	C	D	E	F	G	
0FRRAW, FREQUENCIES OF STABILITY CLASSES (WIND TOWARDS)								
N	2.86E-01	6.45E-02	5.99E-02	3.23E-01	5.07E-02	2.17E-01	.00E+00	
NNW	3.61E-01	5.16E-02	5.16E-02	1.81E-01	9.03E-02	2.65E-01	.00E+00	
NW	3.45E-01	5.04E-02	7.19E-02	2.37E-01	1.15E-01	1.80E-01	.00E+00	
WNW	3.66E-01	6.90E-02	5.52E-02	2.00E-01	1.10E-01	2.00E-01	.00E+00	
W	2.79E-01	5.94E-02	4.57E-02	2.88E-01	1.19E-01	2.10E-01	.00E+00	
WSW	1.01E-01	6.18E-02	1.12E-01	4.85E-01	1.28E-01	1.12E-01	.00E+00	
SW	6.27E-02	2.47E-02	5.23E-02	6.16E-01	1.77E-01	6.75E-02	.00E+00	
SSW	9.95E-02	2.96E-02	4.30E-02	3.84E-01	2.12E-01	2.31E-01	.00E+00	
S	1.59E-01	3.30E-02	6.04E-02	2.14E-01	1.10E-01	4.23E-01	.00E+00	
SSE	1.31E-01	3.75E-02	5.63E-02	1.25E-01	8.13E-02	5.69E-01	.00E+00	
SE	7.89E-02	3.07E-02	8.77E-02	2.59E-01	6.14E-02	4.82E-01	.00E+00	
ESE	4.50E-02	2.89E-02	4.18E-02	3.12E-01	1.22E-01	4.50E-01	.00E+00	
E	4.69E-02	2.27E-02	4.40E-02	3.55E-01	2.33E-01	2.98E-01	.00E+00	
ENE	4.52E-02	3.02E-02	4.52E-02	5.50E-01	1.40E-01	1.89E-01	.00E+00	
NE	3.39E-02	1.87E-02	4.81E-02	7.25E-01	1.18E-01	5.60E-02	.00E+00	
NNE	7.35E-02	4.51E-02	6.57E-02	6.24E-01	1.29E-01	6.27E-02	.00E+00	
TOT	8.70E-02	3.33E-02	5.63E-02	5.20E-01	1.39E-01	1.65E-01	.00E+00	

Table C-9.

Meteorology Data Used for 1995 TAN Ground Level Releases


A	B	C	D	E	F	G	PERD
OUDCAT, HARMONIC AVERAGE WIND SPEEDS (WIND TOWARDS)							
N	1.846	2.690	3.207	4.015	2.857	1.629	.000
NNW	2.100	2.292	2.903	3.180	2.662	1.434	.000
NW	1.648	2.687	2.625	2.816	2.129	1.320	.000
WNW	1.560	1.898	1.914	2.646	2.350	1.537	.000
W	1.564	2.055	1.943	2.402	2.319	1.439	.000
WSW	1.655	2.092	2.298	2.848	2.069	1.401	.000
SW	1.569	1.910	2.283	3.107	2.806	1.517	.000
SSW	1.489	2.117	2.629	3.111	2.480	1.522	.000
S	1.390	2.324	3.151	3.148	2.437	1.660	.000
SSE	1.554	2.029	3.590	4.683	2.622	1.469	.000
SE	1.258	3.000	3.329	3.371	2.170	1.329	.000
ESE	1.212	3.174	4.470	5.744	2.292	1.252	.000
E	1.355	2.520	4.728	5.261	2.406	1.322	.000
ENE	1.403	3.074	4.111	4.703	2.347	1.329	.000
NE	1.849	3.043	3.709	6.045	3.028	1.443	.000
NNE	1.800	3.246	3.593	4.576	3.259	1.364	.000
							.075
OUDAV, ARITHMETIC AVERAGE WIND SPEEDS (WIND TOWARDS)							
N	2.149	2.843	3.568	4.647	3.385	1.983	.000
NNW	2.299	2.710	3.242	3.828	3.087	1.790	.000
NW	1.999	2.837	3.080	3.621	2.782	1.653	.000
WNW	1.921	2.289	2.723	3.182	3.211	1.898	.000
W	1.925	2.541	2.423	3.030	2.668	1.797	.000
WSW	2.005	2.395	2.763	3.640	2.538	1.753	.000
SW	1.929	2.465	2.643	3.971	3.259	1.879	.000
SSW	1.850	2.746	3.112	4.048	2.779	1.884	.000
S	1.741	2.660	3.881	4.011	2.723	2.009	.000
SSE	1.915	2.791	3.867	6.877	3.069	1.829	.000
SE	1.566	3.264	4.363	4.693	2.789	1.664	.000
ESE	1.497	3.465	4.470	6.376	2.710	1.557	.000
E	1.698	3.391	4.848	5.622	2.820	1.655	.000
ENE	1.756	3.353	4.851	6.158	2.886	1.664	.000
NE	2.151	3.578	4.251	7.487	3.523	1.801	.000
NNE	2.117	3.542	4.049	5.317	3.556	1.709	.000
1	DATE	Wed May 8 15:34:27 1996					
0 FOR EACH STABILITY CLASS							
A	B	C	D	E	F	G	
OFRAW, FREQUENCIES OF STABILITY CLASSES (WIND TOWARDS)							
N	3.07E-01	6.27E-02	7.16E-02	2.54E-01	1.13E-01	1.91E-01	.00E+00
NNW	3.86E-01	5.08E-02	8.12E-02	1.73E-01	1.02E-01	2.08E-01	.00E+00
NW	4.48E-01	8.33E-02	8.85E-02	1.15E-01	8.85E-02	1.77E-01	.00E+00
WNW	5.18E-01	7.85E-02	7.85E-02	9.42E-02	3.14E-02	1.99E-01	.00E+00
W	3.63E-01	1.39E-01	1.16E-01	1.58E-01	4.63E-02	1.78E-01	.00E+00
WSW	2.67E-01	1.38E-01	1.21E-01	2.44E-01	5.39E-02	1.77E-01	.00E+00
SW	9.87E-02	6.43E-02	9.65E-02	4.75E-01	1.03E-01	1.63E-01	.00E+00
SSW	7.02E-02	3.75E-02	5.24E-02	4.46E-01	1.91E-01	2.03E-01	.00E+00
S	4.54E-02	2.14E-02	3.17E-02	4.56E-01	2.11E-01	2.35E-01	.00E+00
SSE	2.13E-02	6.84E-03	1.52E-02	5.79E-01	2.24E-01	1.54E-01	.00E+00
SE	9.90E-02	1.71E-02	3.41E-02	1.95E-01	1.91E-01	4.64E-01	.00E+00
ESE	1.18E-01	4.97E-02	4.35E-02	1.18E-01	6.21E-02	6.09E-01	.00E+00
E	1.53E-01	3.57E-02	6.63E-02	6.63E-02	1.28E-01	5.51E-01	.00E+00
ENE	1.22E-01	2.82E-02	7.21E-02	4.76E-01	8.46E-02	2.16E-01	.00E+00
NE	7.18E-02	2.13E-02	6.60E-02	6.88E-01	7.47E-02	7.86E-02	.00E+00
NNE	1.35E-01	9.88E-02	1.11E-01	4.73E-01	8.36E-02	9.88E-02	.00E+00
TOT	1.27E-01	4.68E-02	6.30E-02	4.30E-01	1.37E-01	1.94E-01	.00E+00

Table C-10. Meteorology Data Used for 1995 TAN Elevated Releases

A	B	C	D	E	F	G	PERD
OUDCAT, HARMONIC AVERAGE WIND SPEEDS (WIND TOWARDS)							WIND FREQ.
N	1.798	2.711	3.068	4.295	3.672	1.779	.000
NNW	1.829	2.298	2.572	3.785	3.039	1.801	.000
NW	1.600	2.195	2.028	2.851	2.235	1.489	.000
WNW	1.747	1.884	2.501	1.917	2.454	1.812	.000
W	1.631	2.527	2.023	2.508	2.539	1.453	.000
WSW	1.629	2.112	2.292	2.930	2.589	1.618	.000
SW	1.526	1.911	2.205	3.480	3.379	1.835	.000
SSW	1.348	2.407	2.646	3.343	3.166	2.197	.000
S	1.484	2.348	3.221	3.569	3.255	1.849	.000
SSE	1.787	2.080	2.853	5.977	3.034	1.806	.000
SE	1.306	3.369	4.229	2.873	2.215	1.383	.000
ESE	1.299	2.495	3.311	2.915	3.369	1.250	.000
E	1.239	4.470	5.018	5.435	2.736	1.502	.000
ENE	1.613	3.712	4.268	6.372	2.655	1.679	.000
NE	1.725	2.762	3.896	7.646	4.195	1.918	.000
NNE	2.007	2.790	3.420	5.694	5.406	1.896	.091
OUDAV, ARITHMETIC AVERAGE WIND SPEEDS (WIND TOWARDS)							
N	2.235	3.459	3.961	6.588	4.816	2.291	.000
NNW	2.155	2.816	3.794	4.650	4.422	2.261	.000
NW	1.979	2.655	3.223	3.916	3.668	2.035	.000
WNW	2.098	2.669	3.154	3.123	3.756	2.344	.000
W	2.039	3.195	2.568	3.430	3.201	1.887	.000
WSW	1.998	2.618	2.951	3.764	3.437	2.104	.000
SW	1.95	2.662	2.744	4.666	4.345	2.457	.000
SSW	1.737	2.841	3.248	4.562	3.916	2.868	.000
S	1.845	3.285	4.179	4.800	3.923	2.435	.000
SSE	2.179	2.755	4.179	9.410	4.228	2.624	.000
SE	1.634	3.666	4.806	5.588	3.275	1.820	.000
ESE	1.624	3.559	4.656	4.536	3.666	1.608	.000
E	1.538	4.470	5.227	6.631	3.624	1.968	.000
ENE	2.094	3.968	5.471	7.504	3.762	2.270	.000
NE	2.061	3.445	4.750	9.877	5.550	2.562	.000
NNE	2.339	3.659	4.657	8.072	6.233	2.710	.000
1	DATE	Thu Apr 25 17:17:01 1996					
0 FOR EACH STABILITY CLASS							
A	B	C	D	E	F	G	
OFRAW, FREQUENCIES OF STABILITY CLASSES (WIND TOWARDS)							
N	2.86E-01	7.70E-02	8.45E-02	2.68E-01	1.49E-01	1.36E-01	.00E+00
NNW	4.69E-01	5.79E-02	5.85E-02	1.54E-01	9.03E-02	1.71E-01	.00E+00
NW	4.36E-01	6.25E-02	9.87E-02	1.44E-01	8.04E-02	1.78E-01	.00E+00
WNW	4.58E-01	5.39E-02	1.03E-01	1.28E-01	5.39E-02	2.04E-01	.00E+00
W	3.72E-01	1.04E-01	1.29E-01	2.39E-01	6.58E-02	8.99E-02	.00E+00
WSW	2.25E-01	1.10E-01	1.30E-01	3.36E-01	6.77E-02	1.32E-01	.00E+00
SW	7.90E-02	5.61E-02	1.04E-01	4.66E-01	1.65E-01	1.29E-01	.00E+00
SSW	4.47E-02	2.15E-02	4.23E-02	4.39E-01	3.06E-01	1.47E-01	.00E+00
S	3.53E-02	2.20E-02	3.66E-02	4.76E-01	2.72E-01	1.57E-01	.00E+00
SSE	2.07E-02	1.26E-02	1.65E-02	6.04E-01	2.11E-01	1.35E-01	.00E+00
SE	7.77E-02	1.48E-02	2.97E-02	4.28E-01	1.81E-01	2.69E-01	.00E+00
ESE	1.41E-01	5.17E-02	8.79E-02	2.22E-01	7.07E-02	4.27E-01	.00E+00
E	1.55E-01	2.45E-02	7.97E-02	1.66E-01	1.08E-01	4.67E-01	.00E+00
ENE	1.42E-01	2.98E-02	9.11E-02	4.07E-01	1.26E-01	2.04E-01	.00E+00
NE	5.45E-02	3.33E-02	5.16E-02	6.65E-01	1.13E-01	8.23E-02	.00E+00
NNE	8.94E-02	5.71E-02	8.66E-02	5.80E-01	1.29E-01	5.86E-02	.00E+00
TOT	1.11E-01	4.07E-02	6.40E-02	4.56E-01	1.81E-01	1.46E-01	.00E+00

Table C-11. Meteorology Data Used for 1995 TRA Releases

A	B	C	D	E	F	G	PERD
OUDCAT, HARMONIC AVERAGE WIND SPEEDS (WIND TOWARDS)							WIND FREQ.
N	1.960	2.612	3.202	4.165	2.808	1.626	.000
NNW	1.719	2.931	2.724	3.852	2.671	1.393	.000
NW	1.523	2.175	3.062	2.622	2.629	1.608	.000
WNW	1.594	1.574	2.149	2.353	2.772	1.327	.000
W	1.594	1.990	2.055	2.394	1.747	1.441	.000
WSW	1.612	1.984	2.360	3.636	3.056	1.325	.000
SW	1.445	2.117	2.728	3.718	3.009	1.413	.000
SSW	1.458	2.120	2.897	3.340	2.293	1.366	.000
S	1.594	2.211	2.384	3.419	2.371	1.319	.000
SSE	1.273	2.365	3.872	3.017	1.892	1.181	.000
SE	1.951	2.894	4.905	3.681	2.018	1.315	.000
ESE	1.855	2.959	4.173	4.252	2.055	1.217	.000
E	1.703	3.513	4.470	4.224	2.701	1.310	.000
ENE	1.512	2.737	3.648	5.190	2.969	1.481	.000
NE	1.873	2.680	4.041	6.008	3.237	1.620	.000
NNE	2.038	3.553	3.860	4.594	2.802	1.513	.000
							.097
OUDAV, ARITHMETIC AVERAGE WIND SPEEDS (WIND TOWARDS)							
N	2.222	3.117	3.736	5.092	3.184	1.980	.000
NNW	2.057	3.178	3.418	4.433	3.240	1.744	.000
NW	1.885	2.514	3.916	3.474	2.747	1.965	.000
WNW	1.952	2.252	3.460	3.132	2.963	1.655	.000
W	1.952	2.557	2.541	3.472	2.079	1.799	.000
WSW	1.968	2.349	2.752	4.577	3.512	1.659	.000
SW	1.803	2.580	3.260	4.591	3.445	1.767	.000
SSW	1.818	2.792	3.438	4.329	2.818	1.712	.000
S	1.952	2.844	3.585	4.975	2.812	1.651	.000
SSE	1.589	3.104	5.144	4.615	2.217	1.447	.000
SE	2.216	3.130	5.085	5.111	2.474	1.646	.000
ESE	2.155	3.214	4.539	5.735	2.541	1.505	.000
E	2.044	3.800	4.470	5.295	3.155	1.639	.000
ENE	1.873	3.296	4.317	6.706	3.525	1.842	.000
NE	2.167	3.270	4.502	7.388	3.675	1.975	.000
NNE	2.266	3.835	4.223	5.803	3.333	1.875	.000
1	DATE	Thu Apr 11 12:50:56 1996					
0 FOR EACH STABILITY CLASS							
A	B	C	D	E	F	G	
OFRAW, FREQUENCIES OF STABILITY CLASSES (WIND TOWARDS)							
N	1.78E-01	8.08E-02	6.68E-02	3.93E-01	9.47E-02	1.87E-01	.00E+00
NNW	2.36E-01	6.25E-02	4.91E-02	3.21E-01	1.20E-01	2.10E-01	.00E+00
NW	3.58E-01	6.08E-02	6.75E-02	1.89E-01	9.45E-02	2.30E-01	.00E+00
WNW	4.22E-01	3.70E-02	5.18E-02	1.48E-01	5.92E-02	2.82E-01	.00E+00
W	4.28E-01	8.56E-02	6.85E-02	1.20E-01	4.57E-02	2.52E-01	.00E+00
WSW	1.90E-01	8.60E-02	9.83E-02	3.65E-01	1.31E-01	1.29E-01	.00E+00
SW	5.50E-02	3.47E-02	5.93E-02	5.88E-01	1.74E-01	9.00E-02	.00E+00
SSW	6.66E-02	3.86E-02	6.66E-02	4.38E-01	2.27E-01	1.63E-01	.00E+00
S	6.43E-02	2.32E-02	4.29E-02	4.24E-01	1.98E-01	2.47E-01	.00E+00
SSE	1.16E-01	2.90E-02	5.38E-02	2.70E-01	1.74E-01	3.58E-01	.00E+00
SE	1.23E-01	4.43E-02	3.93E-02	1.87E-01	1.43E-01	4.64E-01	.00E+00
ESE	7.03E-02	3.75E-02	6.09E-02	2.77E-01	1.41E-01	4.14E-01	.00E+00
E	7.30E-02	1.99E-02	1.99E-02	4.41E-01	1.29E-01	3.16E-01	.00E+00
ENE	2.91E-02	1.68E-02	4.70E-02	6.61E-01	1.30E-01	1.17E-01	.00E+00
NE	2.72E-02	2.72E-02	5.29E-02	7.45E-01	8.49E-02	6.30E-02	.00E+00
NNE	7.42E-02	4.47E-02	8.71E-02	5.70E-01	1.04E-01	1.20E-01	.00E+00
TOT	8.95E-02	3.84E-02	5.94E-02	5.21E-01	1.34E-01	1.56E-01	.00E+00



APPENDIX D

Input Parameter Values

for CAP-88 Computer Code

Table D-1. Input Parameter Values for CAP-88 Computer Code

<u>RADIOMUCLIDE-INDEPENDENT PARAMETERS</u>	<u>VALUE</u>	<u>REFERENCE</u>
TIME DELAY--INGESTION OF LEAFY VEGETABLES BY MAN (HR)	24.0	NRC (1977)
TIME DELAY--INGESTION OF PRODUCE BY MAN (HR)	1440.0	NRC (1977)
AGRICULTURAL PRODUCTIVITY BY UNIT AREA (PRODUCE OR LEAFY VEG INGESTED BY MAN (KG/SQ METER))	2.0	NRC (1977)
RATE OF INGESTION OF PRODUCE BY MAN (KG/YR)	520.0	NRC (1977)
RATE OF INGESTION OF MILK BY MAN (LITERS/YR)	310.0	NRC (1977)
RATE OF INGESTION OF MEAT BY MAN (KG/YR)	110.0	NRC (1977)
RATE OF INGESTION OF LEAFY VEGETABLES BY MAN (KG/YR)	64.0	NRC (1977)
PERIOD OF LONG-TERM BUILDUP FOR ACTIVITY IN SOIL (YEARS)	15.0	NRC (1977)
EFFECTIVE SURFACE DENSITY OF SOIL (KG/SQ. M), DRY WEIGHT. (ASSUMES 15-CM PLOW LAYER)	225.0	DOE (1987)
FRACTION OF RADIOACTIVITY RETAINED ON LEAFY VEGETABLES AND PRODUCE AFTER WASHING	1.0	DOE (1987)

SITE INFORMATION

HEIGHT OF LID	800 (M)
RAINFALL RATE	30.0 (CM/Y)
AVERAGE AIR TEMPERATURE	5.8 (DEG C) [279.0 (K)]
SURFACE ROUGHNESS LENGTH (Z0)	0.010 (M)
VERTICAL TEMPERATURE GRADIENTS: (K/M)	
STABILITY E	0.073
STABILITY F	0.109
STABILITY G	0.145

FOOD SUPPLY FRACTIONS

	<u>LOCAL</u>	<u>REGIONAL</u>	<u>IMPORTED</u>	<u>REFERENCE</u>
VEGETABLE:	0.700	0.000	0.300	EPA (1989)
MEAT:	0.442	0.000	0.558	EPA (1989)
MILK:	0.399	0.000	0.601	EPA (1989)

Note: Variables not listed here are assigned the default values for CAP-88.

DEPOSITION VELOCITIES, SCAVENGING COEFFICIENTS, AND SETTLING VELOCITIES

<u>CATEGORY</u>	<u>DEPOSITION VELOCITY (m/s)</u>
Noble gases	0.0
Reactive gases	0.035
Organic iodine	0.00018
Particulates	0.0018

References

DOE (U.S. Department of Energy), 1987, *Environmental Assessment: Fuel Processing Restoration at the Idaho National Engineering Laboratory*, DOE/EA-0306.

EPA (U.S. Environmental Protection Agency), 1989, *Risk Assessments Methodology, Environmental Impact Statement, NESHAPS for Radionuclides, Background Information Document - Volume 1*, EPA/520/1-89-005.

ICRP (International Commission on Radiological Protection), 1975, *International Commission on Radiological Protection, Task Group Report on Reference Man, ICRP Publication 23*, Pergamon Press, NY.

NRC (U.S. Nuclear Regulatory Commission), 1977, *Regulatory Guide 1.109 Calculation of Annual Doses to Man From Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance With 10 CFR Part 50 Appendix I*, Revision 1.

APPENDIX E

Supplemental Information

SUPPLEMENTAL INFORMATION

The following information is provided at the request of DOE Headquarters and is not required as part of the annual NESHAPs reporting requirements.

REQUEST: Provide an estimate of collective effective dose equivalent (person-rem/yr) for 1995 releases.

An estimate of collective effective dose equivalent (person-rem/yr) is provided in the *Idaho National Engineering Laboratory Site Environmental Report for Calendar Year 1995 (DOE/ID-12082(95))*. This collective EDE is calculated using the MESODIF model and not CAP-88.

REQUEST: Provide information on the status of compliance with subparts Q and T of 40 CFR Part 61 if pertinent.

Subparts Q and T of 40 CFR 61 are not pertinent to the INEL.

REQUEST: Although exempt from Subpart H, provide information on Rn-220 emission from sources containing U-232 and Th-232 where emissions potentially can exceed 0.1 mrem/yr to the public or 10% of the non-radon dose to the public.

Not applicable at the INEL.

REQUEST: Provide information on non-disposal/non-storage sources of Rn-222 emissions where emissions potentially can exceed 0.1 mrem/yr to the public or 10% of the non-radon dose to the public.

Not applicable at the INEL.

REQUEST: For the purpose of assessing facility compliance with the NESHAPs effluent monitoring requirements of Subpart H under Section 61.93(b), give the number of emission points subject to the continuous monitoring requirement, the number of these emission points that do not comply with the Section 61.93(b) requirements, and if possible, the cost for upgrades. Describe site periodic confirmatory measurement plans. Indicate the status of the QA program described by Appendix B, Method 114.

During CY 1995, the INEL had six emission points that were subject to continuous compliance monitoring requirements as required by NESHAPs. All six emission points comply with 40 CFR 61.93(b) requirements during normal operations. However, the FAST facility Stack (CPP 767-001) was redesignated to be a less than 0.1 mrem/yr (unabated) source during 1995.

DOE-ID has implemented an INEL Periodic Confirmatory Measurements Program. The guidance was issued in 1992. Radiological atmospheric release points were divided into categories for implementing confirmatory measurements. Those emission points with a potential unabated emission greater than or equal to 0.1 mrem/year require continuous compliance monitoring per 40 CFR 61.93. Periodic confirmatory measurements in the form of annual grab samples are required for emission sources where unabated emissions could result in an EDE between 0.01 and 0.1 mrem/year. For an estimated EDE of less than 0.01 mrem/year for a release point, as a minimum the source must be evaluated annually based upon process knowledge and the last 12 months of operation.

In 1995, each contractor performed the required periodic confirmatory measurements. Each vent was characterized and evaluated through continuous monitoring, grab sampling, or process knowledge. The results of the confirmatory measurements are on file with each contractor. Six radiological release points at the INEL require continuous monitoring, approximately 45 additional release points were confirmed with either grab sampling or continuous sampling (not required by 40 CFR 61.93), and the remaining release points were confirmed through process knowledge and the last 12 months of operation.

Quality Assurance requirements specific to NESHAPs are specified in the *INEL Environmental Monitoring Plan*. As a minimum, each INEL facility with an emission potential of 0.1 mrem/yr (assuming no allowance for pollution control equipment) is required to implement the NESHAPs QA requirements. To verify compliance, contractor QA plans have been reviewed against the NESHAPs QA requirements.