

CONTRACTOR REPORT

SAND98-1904
Unlimited Release

Analysis of the Value of Battery Storage with Wind and Photovoltaic Generation to the Sacramento Municipal Utility District

H. W. Zaininger
Zaininger Engineering Company, Inc.
775 Sunrise Avenue, Suite 210
Roseville, California 95661

Prepared by
Sandia National Laboratories
Albuquerque, New Mexico 87185 and Livermore, California 94550

Sandia is a multiprogram laboratory operated by Sandia Corporation,
a Lockheed Martin Company, for the United States Department of
Energy under Contract DE-AC04-94AL85000.

Approved for public release; distribution is unlimited.

Printed August 1998



Sandia National Laboratories

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

MASTER

Issued by Sandia National Laboratories, operated for the United States Department of Energy by Sandia Corporation.

NOTICE: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government, nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors, or their employees, make any warranty, express or implied, or assume any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represent that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government, any agency thereof, or any of their contractors or subcontractors. The views and opinions expressed herein do not necessarily state or reflect those of the United States Government, any agency thereof, or any of their contractors.

Printed in the United States of America. This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from
Office of Scientific and Technical Information
P.O. Box 62
Oak Ridge, TN 37831

Prices available from (615) 576-8401, FTS 626-8401

Available to the public from
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Rd
Springfield, VA 22161

NTIS price codes
Printed copy: A03
Microfiche copy: A01



DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

SAND98-1904
Unlimited Release
Printed August 1998

Analysis of the Value of Battery Storage with Wind and Photovoltaic Generation to the Sacramento Municipal Utility District*

H.W. Zaininger
Zaininger Engineering Company, Inc.
775 Sunrise Ave. Suite 210
Roseville, California 95661

Abstract

The U.S. Department of Energy's Energy Storage Systems Program at Sandia National Laboratories funded a study to determine the economic and operational value of battery storage to wind and photovoltaic technologies on the Sacramento Municipal Utility District system. This report presents the performance predictions and preliminary benefit-cost results for battery storage added to the Solano wind plant and the Hedge photovoltaic plant.

* The work described in this report was performed for Sandia National Laboratories under Contract No. AA-5094.

Acknowledgments

Sandia National Laboratories would like to acknowledge and thank the U.S. Department of Energy's Office of Utility Technologies for the support and funding of this work. We would like to acknowledge the Sacramento Municipal Utility District's operating, planning and design personnel for providing extensive access to the District's planning and resource information and reports, which contributed to the data and assumptions upon which this analysis is based. Sandia staff member Abbes Akhil is recognized for providing initial guidance and planning for this analysis. Thanks are also due to Paul Butler from Sandia's Energy Storage Analysis and Development Department for providing valuable technical review prior to publication.

Contents

1. Introduction	1-1
2. Wind and Photovoltaic Plant Performance.....	2-1
Solano 5-MW Wind Plant Performance	2-1
Photovoltaic Plant Performance.....	2-1
3. Potential Battery Storage Benefits to Wind and PV Plants.....	3-1
Capacity Benefits.....	3-1
Spinning Reserve Benefits.....	3-2
Transmission and Distribution Benefits.....	3-11
Other Potential Battery Storage Benefits	3-13
Loss Reduction.....	3-13
Regulation Benefits.....	3-13
4. Preliminary Benefit-Cost Results.....	4-1
Economic and Financial Assumptions	4-1
Enhancement of Solano Wind Plant Value with Battery Storage	4-1
Enhancement of Hedge Photovoltaic Plant Value With Battery Storage.....	4-2
5. Conclusions and Recommendations.....	5-1
Conclusions.....	5-1
Recommendations.....	5-1

Figures

2-1	Aggregated kW Output of the Solano Wind Plant for July 1994.....	2-2
2-2	Aggregated kW Output of the Solano Wind Plant for August 1994.....	2-2
2-3	Aggregated kW Output of the Solano Wind Plant for September 1994.....	2-3
2-4	Aggregated kW Output of the Solano Wind Plant for October 1994.....	2-3
2-5	Aggregated kW Output of the Solano Wind Plant for November 1994.....	2-4
2-6	Aggregated kW Output of the Solano Wind Plant for December 1994.....	2-4
2-7	Aggregated kW Output Exceeding 5,000 kW for the Solano Wind Plant for July 1994.....	2-5
2-8	Aggregated kW Output of the Solano Wind Plant at 6:00 p.m. for July and August 1994.....	2-5
2-9	SMUD Single-Axis Tracking PV Seasonal Percent of Power Rating.....	2-6
3-1	Expected Daily Battery Discharge Requirement to Shave Peak—Projected 112°F Peak Day Residual Load.....	3-3
3-2	Expected Daily Battery Discharge Requirement to Shave Peak—July 14, 1994, Residual Load.....	3-3
3-3	Expected Daily Battery Discharge Requirement to Shave Peak—August 16, 1994, Residual Load.....	3-4
3-4	Expected Daily Battery Discharge Requirement to Shave Peak—January 1992 Day Load Shape.....	3-4
3-5	Expected Daily Battery Discharge Requirement to Shave Peak—February 1992 Peak Day Load Shape.....	3-5
3-6	Expected Daily Battery Discharge Requirement to Shave Peak—March 1992 Peak Day Load Shape.....	3-5
3-7	Expected Daily Battery Discharge Requirement to Shave Peak—April 1992 Peak Day Load Shape.....	3-6
3-8	Expected Daily Battery Discharge Requirement to Shave Peak—May 1992 Peak Day Load Shape.....	3-6
3-9	Expected Daily Battery Discharge Requirement to Shave Peak—June 1992 Peak Day Load Shape.....	3-7
3-10	Expected Daily Battery Discharge Requirement to Shave Peak—July 1992 Peak Day Load Shape.....	3-7
3-11	Expected Daily Battery Discharge Requirement to Shave Peak—August 1992 Peak Day Load Shape.....	3-8
3-12	Expected Daily Battery Discharge Requirement to Shave Peak—September 1992 Peak Day Load Shape.....	3-8
3-13	Expected Daily Battery Discharge Requirement to Shave Peak—October 1992 Peak Day Load Shape.....	3-9
3-14	Expected Daily Battery Discharge Requirement to Shave Peak—November 1992 Peak Day Load Shape.....	3-9
3-15	Expected Daily Battery Discharge Requirement to Shave Peak—December 1992 Peak Day Load Shape.....	3-10
3-16	Annual SMUD Marginal Capacity Costs.....	3-10
3-17	Annual Marginal Transmission and Subtransmission Capacity Costs.....	3-12
3-18	Representative Daily Elk Grove Florin/Gerber Substation Load Shape.....	3-12

3-19. Annual SMUD Marginal Energy Costs, Summer Peak Period.....	3-14
--	------

Figures (cont.)

4-1 Potential Benefits of Adding a 3.5-MW/2-Hr Battery at Solano (Case 1).....	4-2
4-2 Case 1 Break-Even Battery Capital Investment.....	4-2
4-3 Potential Benefits of Adding a 225-kV/2-Hr Battery at Hedge (Case 2).....	4-3
4-4 Case 2 Break-Even Battery Capital Investment.....	4-3

Tables

2-1. Monthly Solano Wind Plant Capacity Factors	2-1
3-1. Planned SMUD Wind and PV Plant Resource Additions	3-1

Acronyms

ACE	area control error
O&M	operation and maintenance
PG&E	Pacific Gas and Electric
PSA	Power Service Agreement
PV	photovoltaic
PWRR	present worth of revenue requirement
SMUD	Sacramento Municipal Utility District
SNL	Sandia National Laboratories
T&D	transmission and distribution

Intentionally Left Blank

1. Introduction

This report describes the results of an analysis to determine the economic and operational value of battery storage to wind and photovoltaic (PV) generation technologies to the Sacramento Municipal Utility District (SMUD) system.

This project was jointly funded by SMUD and Sandia National Laboratories (SNL). The project scope consisted of performing the following work:

- Identify two sites for potential installation of battery energy storage on the SMUD system. One site will service a PV system, and the second will service the SMUD Solano wind project.
- Quantify the costs and benefits of batteries when used in each of these applications. Major emphasis will be placed on assessing the capability of battery energy storage to enhance the variable outputs of PV systems and wind plants.

The analysis approach consisted of performing a benefit-cost economic assessment using established SMUD financial parameters, system expansion plans, and current system operating procedures.

The work was completed in early 1995 and consisted of the following tasks:

- Screen battery benefits and gather SMUD data;
- Select appropriate wind and PV plant sites;

- Identify potential battery storage benefits;
- Perform preliminary battery storage benefit-cost assessment;
- Obtain battery storage cost estimates from manufacturers; and
- Prepare report.

This report presents the results of the analysis. Section 2 describes expected wind and PV plant performance. Section 3 describes expected benefits to SMUD associated with employing battery storage. Section 4 presents preliminary benefit-cost results for battery storage added at the Solano wind plant and the Hedge PV plant. Section 5 presents conclusions and recommendations resulting from this analysis.

The results of this analysis should be reviewed subject to the following caveat. The assumptions and data used in developing these results were based on reports available from and interaction with appropriate SMUD operating, planning, and design personnel in 1994 and early 1995 and are compatible with financial assumptions and system expansion plans as of that time. Assumptions and SMUD expansion plans have changed since then. In particular, SMUD did not install the additional 45 MW of wind that was planned for 1996. Current SMUD expansion plans and assumptions should be obtained from appropriate SMUD personnel.

Intentionally Left Blank

2. Wind and Photovoltaic Plant Performance

This section describes wind plant and PV plant electrical performance data collected as part of this analysis.

Solano 5-MW Wind Plant Performance

Monthly capacity factors for the Solano 5-MW wind plant from July through December 1994 are summarized in Table 2-1. Energy production is highest in the summer months and lowest in the winter months.

Table 2-1. Monthly Solano Wind Plant Capacity Factors

July 1994	69.5%
August 1994	46.3%
September 1994	38.9%
October 1994	21.0%
November 1994	12.4%
December 1994	3.8%

The total aggregated output for July 1994 through December 1994 of the 17 turbines that make up the 5-MW Solano wind plant is shown in Figures 2-1 through 2-6. These figures illustrate the nature of wind plant output. In some hours, the wind plant output can exceed the 5-MW, wind-plant nameplate capacity. For example, Figure 2-7 presents a plot of the hourly integrated kilowatt wind plant output exceeding the 5-MW, wind-plant capacity rating during July 1994. In July, the wind-plant hourly output exceeded 5 MW over 20 times, sometimes by as much as 300 kW, or 6%. The wind plant output also exceeded 5 MW in other months. On the other hand,

wind plant output is zero in many other hours, even during peak wind resource months.

In SMUD's 1993 *Integrated Resource Plan Update*,¹ wind plants were assigned a 0% capacity factor for planning purposes. As of 1994, conversations with SMUD personnel indicated that wind plants were being assigned a 15% capacity factor in the latest draft of the 1995 *Integrated Resource Plan Update*.² The basis for the 15% capacity factor was other utility studies showing that wind plants provide some degree of increased reliability. For example, Southern California Edison assigned a 25% capacity factor to wind in the early 1990s.

The peak load of the daily SMUD system load shape generally occurs around 6:00 p.m. Pacific daylight time during the peak load months of July and August. The 6:00 p.m. aggregated kW output for July and August 1994 of the 17 turbines that make up the Solano wind plant is shown in Figure 2-8. Some days the wind plant generated 5 MW or more. Some days the wind plant output was very low. Hence, this plot illustrates the relatively weak correlation between wind plant output and daily system peak load during the summer peak period. These data support the capacity factor assigned to wind plants by SMUD.

Photovoltaic Plant Performance

Expected hourly PV plant output obtained from PVUSA is presented in Figure 2-9 for single-axis tracking PV designs installed on the SMUD system. This expected hourly PV output is compatible with the 55% capacity factor assigned to single-axis PV plants by SMUD in the 1993 and 1995 *Integrated Resource Plan Update*.

¹ 1993 *Integrated Resource Plan Update*, SMUD, Vol. I and II, October 4, 1993.

² 1995 *Integration Resource Plan Update*, SMUD, recent draft.




Figure 2-1. Aggregated kW Output of the Solano Wind Plant for July 1994.




Figure 2-2. Aggregated kW Output of the Solano Wind Plant for August 1994.




Figure 2-3. Aggregated kW Output of the Solano Wind Plant for September 1994.




Figure 2-4. Aggregated kW Output of the Solano Wind Plant for October 1994.




Figure 2-5. Aggregated kW Output of the Solano Wind Plant for November 1994.




Figure 2-6. Aggregated kW Output of the Solano Wind Plant for December 1994.




Figure 2-7. Aggregated kW Output Exceeding 5,000 kW for the Solano Wind Plant for July 1994.




Figure 2-8. Aggregated kW Output of the Solano Wind Plant at 6:00 p.m. for July and August 1994.




Figure 2-9. SMUD Single-Axis Tracking PV Seasonal Percent of Power Rating.

3. Potential Battery Storage Benefits to Wind and PV Plants

The purpose of this section is to identify potential battery storage benefits to SMUD wind and PV plants, compensating for variations in real-time wind and PV plant output.

Capacity Benefits

Currently the capacity factor assigned to wind plants by SMUD is 15% of nameplate megawatt capacity. The capacity factor assigned to PV plants by SMUD is 55% of nameplate megawatt capacity.³ The wind and PV performance data presented in Section 2 support these capacity factors.

Adding battery storage to wind and PV plants can make them dispatchable and increase the capacity factors of the renewable resources. In general, to increase solar- and wind-plant capacity factors, the battery storage megawatt and megawatt-hour requirements must be compatible with SMUD generation system reliability criteria and daily system load shape characteristics. In addition, SMUD must have a need for new capacity in the time frame being studied.

The 1993 SMUD *Integrated Resource Plan Update* indicates that both wind and PV resource additions are tentatively planned over the next several years, as shown in Table 3-1.⁴

5 MW of wind turbines are now on line at Solano, and their performance from July 1, 1994, through December 31, 1994, is presented in Section 2 of this report. Conversations with SMUD personnel in 1994 indicated that 45 MW more of wind turbines were tentatively scheduled to be added at Solano in 1996 rather than, as shown in Table 3-1, in 1997. Thus, for this analysis, it was assumed that 50 MW of wind turbines would be operating at Solano in 1996 and that the 50-MW wind-plant capacity factor is 15% of nameplate megawatts, or 7.5 MW (without battery

storage). *Note: The additional 45 MW of wind is no longer being planned.*

**Table 3-1. Planned SMUD Wind and
PV Plant Resource Additions**

Year	Nameplate MW	Renewable Resource Description
1994	5	Wind
1995	1	PV
1996	1	PV
1997	45	Wind
1997	1	PV
1998	1	PV
1999	1	PV
2000	50	Wind
2000	1	PV
2001	1	PV
2002	1	PV
2003	1	PV
2004	3	PV
2005	12	PV
2006	12	PV
2007	12	PV
2008	12	PV
2009	12	PV
2010	12	PV
2011	12	PV
2012	12	PV
2013	12	PV
2014	12	PV

Existing SMUD PV resources include 2 MW at Rancho Seco, 200 kW at Hedge, and 100 4-kW residential PV installations at various locations throughout the SMUD service area. In 1994, conversations with SMUD personnel indicated that SMUD planned to add an additional 300 kW of PV at Hedge. For this analysis, it was assumed that 500 kW of PV would be installed at Hedge in 1996 and that the resulting 500-kW Hedge PV plant capacity factor is 55% of nameplate kilowatts, or 275 kW (without battery storage). *Note: As of early 1997, an additional 218 kW*

³ Both the 1993 and 1995 *Integrated Resource Plan Update* assign 55% capacity factor to PV.

⁴ Table 2, Page 17, 1993 *Integrated Resource Plan Update*, Vol. 1, Final Draft, October 4, 1993.

of PV was added at Hedge, and over 350 4-kW PV systems have been installed.

In order to increase the capacity factors of the wind and PV resources, battery plant energy storage capability must be adequate to shave the daily peak load during reasonable "worst case" scenario days, when there are low winds or low solar insolation. For the SMUD system, battery energy storage requirements will increase as renewable resource penetration increases on the system, as more kilowatt-hours are required to shave the daily peak loads. In this study, near-term battery storage penetration levels to increase the capacity factors of 50 MW of wind at Solano and the 500-kW Hedge PV plant are considered. Potential battery penetration levels to firm up these and other potential SMUD wind and PV plant additions over the next few years are expected to total less than 50 MW.

Figure 3-1 shows the daily battery discharge requirements for a 50-MW battery to shave the projected SMUD 112°F peak day residual load.⁵ Approximately 50 MWh or 1 hour of storage is required to shave the peak day load shape. Figures 3-2 and 3-3 show the daily battery discharge requirements to shave the monthly July (July 14, 1994) and August (August 16, 1994) peaks with 50 MW of batteries. In July, approximately 75 MWh are required over 2 hours, and in August, approximately 99 MWh are required over 3 hours. (A 50-MW battery can shave approximately 100 MWh over 2 hours or 150 MWh over 3 hours; i.e., discharge capacity = 50 MW × number of hours.)

It may also be necessary for battery storage to shave the residual daily peak loads throughout the year to firm up the wind and PV resources. Figures 3-4 through 3-15 show the requirements for a 50-MW battery to shave monthly SMUD peak loads throughout the year assuming 1992 SMUD monthly load data.⁶ For all months except April, the daily battery discharge requirements are less than 100 MWh even though the daily load shapes change significantly throughout the year. For the April peak day, the daily battery storage required to shave the peak 50 MW is approximately 125 MWh delivered over a 3-hour period.

Two hours of battery storage appears adequate to back up the wind and PV resources throughout the year until cumulative battery storage penetration approaches 50 MW. Although the batteries have to be available to operate, they do not necessarily have to be operated on a daily charge/discharge cycle to enhance solar and wind capacities to SMUD. Thus, relatively inexpensive light-duty batteries (cycling less than 50 times per year vs. heavy-duty and more costly batteries cycling daily up to 250 times per year) are adequate to back up the wind and PV resources and enhance their capacity factors.

SMUD performed a marginal cost study⁷ that presents projected marginal capacity and energy costs from 1995 through 2014 to be used in evaluating alternative supply- and demand-side resources. The annual marginal generation capacity costs for generation with outages are shown in Figure 3-16. These costs are derived from Schedule 2.01 in the 1994 SMUD *Marginal Cost Study* and are used to determine the annual benefits of battery storage in this analysis. After 2014, annual capacity costs are escalated at the study inflation rate of 3.5%.

Spinning Reserve Benefits

The 1994–1996 *SMUD Resource Operating Plan*⁸ describes current SMUD operating reserve requirements, including both spinning- and quick-start-(10-minute) reserve requirements. Currently, SMUD must maintain a minimum continuous spinning-reserve margin of 7% of the system load less firm power purchases within the Pacific Gas & Electric (PG&E) control area. In addition, SMUD must maintain spinning reserves equal to 100% of the non-firm power imports.

Both wind and PV plants are intermittent resources and will therefore require SMUD to maintain a spinning-reserve margin of 7% or more. Conversations with SMUD systems operations personnel indicated that assigning a 7% spinning-reserve requirement for PV and wind resources was compatible with SMUD's operating reserve policy and a reasonable assumption for this analysis.

⁵ 1993 SMUD *Integrated Resource Plan Update*, Vol. II, Page 18.

⁶ 1992 *Class Load Study*, SMUD Rate Department, December 1993.

⁷ 1994 *Marginal Cost Study*, SMUD Resource Planning and Evaluation, Vol. 1 and II, June 2, 1994.

⁸ 1994–1996 *Resource Operating Plan*, SMUD Power Systems Operations, Final Draft, February 1994.




Figure 3-1. Expected Daily Battery Discharge Requirement to Shave Peak—Projected 112°F Peak Day Residual Load.




Figure 3-2. Expected Daily Battery Discharge Requirement to Shave Peak—July 14, 1994, Residual Load.




Figure 3-3. Expected Daily Battery Discharge Requirement to Shave Peak—August 16, 1994, Residual Load.




Figure 3-4. Expected Daily Battery Discharge Requirement to Shave Peak—January 1992 Day Load Shape.




Figure 3-5. Expected Daily Battery Discharge Requirement to Shave Peak—February 1992 Peak Day Load Shape.




Figure 3-6. Expected Daily Battery Discharge Requirement to Shave Peak—March 1992 Peak Day Load Shape.




Figure 3-7. Expected Daily Battery Discharge Requirement to Shave Peak—April 1992 Peak Day Load Shape.




Figure 3-8. Expected Daily Battery Discharge Requirement to Shave Peak—May 1992 Peak Day Load Shape.




Figure 3-9. Expected Daily Battery Discharge Requirement to Shave Peak—June 1992 Peak Day Load Shape.




Figure 3-10. Expected Daily Battery Discharge Requirement to Shave Peak—July 1992 Peak Day Load Shape.




Figure 3-11. Expected Daily Battery Discharge Requirement to Shave Peak—August 1992 Peak Day Load Shape.




Figure 3-12. Expected Daily Battery Discharge Requirement to Shave Peak—September 1992 Peak Day Load Shape.




Figure 3-13. Expected Daily Battery Discharge Requirement to Shave Peak—October 1992 Peak Day Load Shape.




Figure 3-14. Expected Daily Battery Discharge Requirement to Shave Peak—November 1992 Peak Day Load Shape.




Figure 3-15. Expected Daily Battery Discharge Requirement to Shave Peak—December 1992 Peak Day Load Shape.




Figure 3-16. Annual SMUD Marginal Capacity Costs.

Battery storage has the capability to be quickly started or changed from charging to discharging in the millisecond time frame. Therefore, battery storage can be added to SMUD wind and PV plants to supply the spinning-reserve requirement for the plants.

Battery storage would be expected to operate infrequently to supply spinning-reserve capability. It is also expected that the batteries would only have to operate until other SMUD generation could be started or replacement power purchased after a sudden generation outage. Thus, battery storage used for spinning reserve would probably not require large megawatt-hour storage capability.

Calculating the potential economic benefits associated with employing battery storage for this application requires determining the expected operating cost penalties resulting from supplying the 7% spinning-reserve requirement without batteries. Spinning reserve typically includes unused megawatt capability of SMUD hydrogeneration and other on-line generation plus purchases from PG&E and others, as described in the 1994-1996 resource operating plan.

For this analysis, it is assumed that incremental increases in spinning-reserve requirements would be supplied by the PG&E Power Service Agreement power purchase, as this is one of the primary sources of SMUD spinning reserve. The PG&E purchase is

supplied on a daily basis in 50-MW blocks. In January 1995, the average cost for an unloaded 50-MW block of power was \$20.06/MW/day.⁹ The minimum load energy requirement is 25% of the 50-MW block.

In 1996, spinning-reserve requirements for 50 MW of wind at Solano would be 3.5 MW, assuming the 7% spinning-reserve margin. The 3.5-MW increase in spinning reserve is expected to require an additional 50-MW block of PG&E spinning reserve about 7% of the time, or 26 days per year, costing about \$1,000 per day, or \$26,000 per year. There also would be an energy cost penalty during these 26 days, because 12.5 MW of PG&E power during these days is expected to cost significantly more than other available transactions such as economy energy (economy energy is the cheapest electricity available on the spot market). Assuming a \$10/MWh penalty, this translates into \$3,000 per day, or \$78,000 per year. The total annual spinning-reserve penalty for 50 MW of wind at Solano could be as much as \$104,000 per year, or \$29.74/kW/yr in 1995 dollars.

The \$29.74/kW/yr spinning-reserve penalty will also be assumed for the 500-kW PV plants at Hedge.

Transmission and Distribution Benefits

The SMUD 1994 *Marginal Cost Study* presents marginal cost data for transmission, subtransmission, and distribution capacity costs and losses, as well as for generation capacity costs. Schedule 2.11 in the study presents 20 years of demand-related transmission costs from 1995 through 2014. Schedule 2.16 presents 20 years of demand-related subtransmission costs from 1995 through 2014. Schedule 2.20 presents 20 years of demand-related average distribution costs from 1995 through 2014 for the total SMUD system. Schedules 2.21 through 2.30 present area-specific, demand-related distribution costs for the South Natomas, Antelope, Carmichael, Rancho Cordova, Folsom, Pocket, Elk Grove/Laguna, Undeveloped, Galt, and Rancho Murieta areas.

These marginal transmission and distribution (T&D) costs were developed to compare the relative costs of alternative generation resources installed at different voltage levels in the SMUD service area. The costs of

resources outside the SMUD service area with specific T&D deferral information are not available. Figure 3-17 presents the projected annual SMUD marginal transmission, and subtransmission, demand-related costs used in this analysis. In this analysis, these transmission and subtransmission cost benefits are applied to battery storage added to the 500-kW PV plant connected to the distribution primary system at Hedge, which is located in the SMUD service area. These T&D benefits are not available to battery storage located at the Solano wind plant because Solano is outside the SMUD service area.

The Hedge PV site is connected to a 12-kV feeder served by the Elk Grove Florin/Gerber 20-MVA 69-kV to 12-kV substation. Because PV is an intermittent source, no T&D capacity benefits are currently available. If dispatchable battery storage is added to the Hedge PV plant, the battery plant must have adequate energy storage to shave the daily substation peak load during local peak-load conditions to attain T&D capacity benefits.

Figure 3-18 shows the daily substation load shape for two days in August 1994 when the temperature exceeded 100°F. Two hours of energy storage appears adequate to shave this local peak for a 225-kW battery storage plant installed at Hedge. In addition, the time of day for this local daily load peak appears to correlate well with the expected total-system daily load during projected annual peak-load conditions, as shown in previous figures. Thus, battery storage located at Hedge would be expected to attain both generation capacity and transmission and subtransmission capacity benefits. Also, transmission and subtransmission facility outage contingencies occur infrequently. Hence, batteries are expected to operate infrequently to back up these transmission and subtransmission facilities, and light-duty batteries are expected to be adequate for this application.

Significant site-specific, distribution capacity benefits may also be obtained for future battery applications that are placed in locations where distribution-substation transformer additions can be deferred. However, no specific transformer addition deferrals could be identified during discussions with SMUD distribution personnel. Distribution capacity benefits may also be attained in addition to transmission and subtransmission capacity benefits for battery storage systems with future residential PV applications in cases where the daily local distribution load shape also correlates with the system native load shape. However, because the distribution system is radial,

⁹ Conversation with SMUD Systems Operations personnel.




Figure 3-17. Annual Marginal Transmission and Subtransmission Capacity Costs.




Figure 3-18. Representative Daily Elk Grove Florin/Gerber Substation Load Shape.

batteries must always be discharged to shave the distribution peak to obtain the distribution capacity benefits. Hence, batteries installed in future residential PV applications are expected to be charged and discharged more frequently to attain the distribution capacity benefits.

As stated previously, the above transmission, subtransmission, and distribution-capacity value benefits are not available to battery storage located at the Solano wind plant, which is outside of SMUD's service area. However, adding battery storage to the Solano wind plant may significantly increase Solano wind

plant energy production if the full 50 MW of wind turbines are installed at Solano in 1996.

In this case, PG&E will provide 15 MW of reserved (firm) transmission service throughout the year and an additional 35 MW of interruptible transmission service. Conversations with SMUD personnel indicate that the 15 MW of reserved transmission service limit is based on transmission capacity limits in the transmission path from the Solano wind plant to the SMUD service area.

Extrapolating the 5-MW Solano wind plant performance for a good summer wind month represented by

July 1994 (shown in Figure 2-1) to 50 MW, almost 60% of the time a 50-MW, wind-plant, hourly megawatt output would exceed 15 MW. In addition, for a small portion of the time, a 50-MW Solano wind-plant hourly output will exceed 50 MW—the combined firm plus interruptible transmission limit. Thus, it is likely that a significant amount of Solano wind plant energy may be lost due to transmission limits, especially during the peak load (and high wind) summer months when the transmission system is heavily loaded.

Battery storage located at the Solano wind plant can be used to store wind energy that would be lost during hours when transmission service is constrained, allowing the energy to be delivered later. In this analysis, the value of potential lost Solano wind plant energy is determined using the summer peak energy costs in Figure 3-19.¹⁰ After 2014, the costs are escalated at the inflation rate. These assumptions are also compatible with current SMUD energy costs obtained from SMUD system operations personnel.

Other Potential Battery Storage Benefits

Two other ways that battery storage can enhance the value of PV and wind plants to SMUD have been identified as described below.

Loss Reduction

Battery storage can reduce losses by PV plants located in SMUD's service area. Batteries can reduce SMUD transmission, subtransmission, and distribution losses by shifting loads from peak periods to off-peak periods during low solar insolation periods, when PV plants are not generating at full output. To provide a significant reduction in annual losses, the batteries must cycle frequently throughout the year. Calculating the benefit requires modeling the expected PV plant output throughout the year, as well as modeling expected variations in system production cost and T&D power flows. Previous experience indicates that the magnitude of these loss reduction benefits can vary widely between specific battery applications and must be evaluated on a case-by-case basis.

The potential reduction in losses from adding batteries to the Hedge PV plant has not been evaluated in this analysis because the reduction does not appear to be large. First, the PV plants on the SMUD system are already obtaining significant loss-reduction benefits as described in the 1994 *Marginal Cost Study*.¹¹ Second, the other potential SMUD battery capacity benefits and spinning-reserve applications do not require frequent battery charge/discharge cycling, which tends to result in small loss-reduction benefits.

Regulation Benefits

SMUD's minute-to-minute area regulation requirements are presented in its 1994-1996 *Resource Operating Plan*. SMUD is assessed penalties for area control error (ACE) not crossing zero within 10 minutes more than 12 times per day and for not maintaining a specific ACE-deviation bandwidth.

These regulation requirements and corresponding SMUD-generation regulation assignments are based on expected minute-to-minute system load fluctuations. If the SMUD 50-MW Solano wind plant comes on line, there may be increased minute-to-minute regulation requirements imposed on the rest of the SMUD generation system to accommodate potential minute-to-minute, wind-plant megawatt output fluctuations in addition to minute-to-minute system load fluctuations.

Adding battery storage that can be quickly charged and discharged under control of an automatic generation control system can smooth out wind-plant minute-to-minute output fluctuations. Expected minute-to-minute, Solano wind-plant, output-fluctuation information was not readily available for this analysis, and potential battery storage regulation benefits were not calculated.

¹⁰ 1994 *Marginal Cost Study*, Vol. II, Schedule 6.04.

¹¹ 1994 *Marginal Cost Study*, Vol. II, Schedules 4.1 and 4.2, June 2, 1994.




Figure 3-19. Annual SMUD Marginal Energy Costs, Summer Peak Period.

4. Preliminary Benefit-Cost Results

This section presents the preliminary benefit-cost evaluation for battery storage added to two sites—50 MW of wind at Solano and the 500-kW Hedge PV plant.

Economic and Financial Assumptions

The following preliminary benefit-cost assessment is performed in a manner compatible with current SMUD planning practices, using the following general financial parameters¹² obtained from SMUD planning personnel:

- Discount rate equals 5.9%;
- Inflation rate equals 3.5%.

The benefit-cost calculations are performed using a 30-yr present worth of revenue requirement (PWRR) economic analysis. Annual SMUD benefits are determined through 2014 as described in Section 3. After 2014, annual benefits are increased at the 3.5% inflation rate. All annual benefits are then discounted to the beginning of the study period using the 5.9% discount rate.

For these preliminary parametric benefit-cost calculations, battery replacement is assumed every 10 years at a cost of one-third the total battery storage plant capital investment, escalated at the 3.5% inflation rate. Annual battery plant operations and maintenance (O&M) costs are ignored in these preliminary benefit-cost calculations.

Enhancement of Solano Wind Plant Value with Battery Storage

As discussed in Section 3, battery storage can be added to the Solano wind plant site to enhance its capacity value. Assuming a 7.5-MW (15%) capacity of the expected 50-MW Solano wind plant, up to 7.5 MW of battery storage can be added without exceeding the 15-MW firm transmission capability. Review of potential “worst case” battery discharge scenarios

indicates that 2 hr of battery storage would be adequate for this application. The first 3.5 MW of battery storage can supply 7% spinning reserve for the wind plant. The next 4 MW of battery storage could provide spinning-reserve benefits for the rest of the system.

In Case 1, a 3.5-MW battery storage plant with 2 hr of storage (7 MWh) is added to the Solano wind plant in 1996. In Case 1a, these batteries increase the wind plant capacity rating 3.5 MW and provide 7% spinning reserve for the intermittent wind resource. In Case 1b, the batteries are also assumed to increase wind plant energy production by delivering 7 MWh of wind plant energy up to 40 times/yr during the summer peak period, energy that is assumed to be lost due to transmission limitations.

Figure 4-1 presents the resulting potential annual benefits of adding a 3.5-MW, 2-hr battery storage plant at the Solano wind plant. Capacity benefits are determined using the SMUD marginal capacity costs presented in Section 3 under “Capacity Benefits.” Spinning-reserve benefits are determined using the costs presented in Section 3 under “Spinning Reserve Benefits.” The transmission limitation benefits are calculated using the costs presented in Section 3 under “Transmission and Distribution Benefits.”

Figure 4-2 presents a parametric analysis of the resulting benefit-to-cost ratio versus battery plant capital investments in 1996 dollars for Case 1—adding a 3.5-MW, 2-hr battery at Solano. In Case 1a, which includes capacity value and spinning-reserve benefits, the break-even battery-plant capital investment is about \$1,250/kW. In Case 1b, when transmission limits are also considered, the break-even battery-plant capital investment increases to about \$1,300/kW. These benefit-cost results are expected to apply to megawatt-scale battery storage plants of up to 7.5 MW capacity with 2 hr of storage located at Solano.

The potential Solano wind-plant battery storage application is expected to require about 20 to 60 battery charge/discharge cycles a year. Hence, less expensive light-duty batteries are expected to be adequate for a potential megawatt-scale battery storage plant.

¹² 1994-2014 Economic Outlook Update: Demographics, Economic Factors, Cost and Fuel Escalation, SMUD Resource Planning and Evaluation Department, December 1993.




Figure 4-1. Potential Benefits of Adding a 3.5-MW/2-Hr Battery at Solano (Case 1).




Figure 4-2. Case 1 Break-Even Battery Capital Investment.

Enhancement of Hedge Photovoltaic Plant Value With Battery Storage

As discussed in Section 3, battery storage can be added to the Hedge PV site to enhance the capacity value of the PV plant. Assuming the 275-kW (55%) capacity for the planned 500-kW Hedge PV plant, adding 225 kW of battery storage capacity with 2 hr of storage would be adequate to increase the Hedge PV plant capacity to the full 500-kW capacity. The 225-kW battery storage plant can supply spinning-reserve benefits for the Hedge PV plant as well as the rest of the system and can obtain transmission and subtransmission benefits.

In Case 2, a 225-kW battery plant with 2 hr of storage is added to the 500-kW Hedge PV plant in 1996. The

battery plant increases the Hedge PV plant capacity to 500 kW and supplies 225 kW of spinning reserve. Because the battery plant is located in the SMUD service area, transmission and subtransmission capacity benefits of the Hedge PV plant are increased 225 kW.

Figure 4-3 presents the potential annual benefits of adding a 225-kW/2-hr battery storage plant at the Hedge PV site. Capacity, spinning-reserve, and transmission and subtransmission capacity benefits are determined using the SMUD marginal cost data presented in Section 3.

Figure 4-4 presents a parametric analysis of resulting benefit to cost ratio versus battery plant capital investment in 1996 dollars for Case 2—adding a 225-kW battery plant at Hedge. In Case 2, the break-even battery capital investment is about \$1,300/kW.




Figure 4-3. Potential Benefits of Adding a 225-kV/2-Hr Battery at Hedge (Case 2).

Error! Not a valid embedded object.

Figure 4-4. Case 2 Break-Even Battery Capital Investment.

The potential Case 2 Hedge PV-plant battery storage application is expected to require less than 50 battery charge/discharge cycles a year to obtain the above

benefits. Hence, less expensive light-duty batteries are expected to be adequate for this Hedge PV plant application.

Intentionally Left Blank

5. Conclusions and Recommendations

Conclusions

Below are some conclusions and observations:

- The results of this analysis indicate that battery storage can significantly enhance the economic and operational value of the Solano wind plant and the Hedge PV plant.
- The preliminary benefit-cost calculations indicate that the break-even capital investment for battery storage installed to enhance the value of the expected 50-MW Solano wind plant ranges from about \$1,250/kW to \$1,300/kW. This applies to megawatt-scale battery storage plants of up to 7.5 MW capacity with 2 hr of storage located at the Solano wind plant site.
- The preliminary benefit-cost calculations indicate that the break-even capital investment for battery storage installed to enhance the benefits of the 500-kW Hedge PV plant is about \$1,300/kW. This applies to battery storage plants up to 225 kW with 2 hr of storage located at the Hedge PV plant site.
- Approximately 20 to 60 battery charge/discharge cycles a year are required for both the Solano wind plant and Hedge PV plant applications.

Thus, less expensive light-duty batteries will be adequate.

- The break-even battery storage capital investments determined during this analysis preliminary evaluation for both Solano and Hedge applications are comparable with battery storage plant cost estimates.

Recommendations

- It is recommended that SMUD obtain cost estimates from vendors for a 1-to-4-MW battery storage plant with 2 hr of storage for possible use with the Solano wind plant. Cost estimates for Solano should include both light-duty and heavy-duty batteries, as plans are to investigate potential regulation benefits.
- It is recommended that SMUD obtain cost estimates from vendors for a 200-to-250-kW battery storage plant with 2 hr of storage for possible use with the Hedge PV plant. Cost estimates for Hedge should include only light-duty batteries.
- It is recommended that the cost estimates to be obtained from battery storage vendors contain both purchase and leasing options.

Intentionally Left Blank

Distribution

ABB Power T&D Co., Inc.
Attn: P. Danfors
16250 West Glendale Drive
New Berlin, WI 53151

American Electric Power Service Corp.
Attn: C. Shih
1 Riverside Plaza
Columbus, OH 43215

Applied Power Corporation
Attn: Tim Ball
Solar Engineering
1210 Homann Drive, SE
Lacey, WA 98503

Ascension Technology
Attn: Edward Kern
Post Office Box 6314
Lincoln Center, MA 01773

Anchorage Municipal Light & Power
Attn: Meera Kohler
1200 East 1st Avenue
Anchorage, AK 99501

Bechtel Corporation
Attn: W. Stolte
P.O. Box 193965
San Francisco, CA 94119-3965

Berliner Kraft und Licht (BEWAG)
Attn: K. Kramer
Stauffenbergstrasse 26
1000 Berlin 30
GERMANY

Business Management Consulting
Attn: S. Jabbour
24704 Voorhees Drive
Los Altos Hills, CA 94022

C&D Charter Power Systems, Inc. (2)
Attn: Dr. Sudhan S. Misra
Attn: Dr. L. Holden
Washington & Cherry Sts.
Conshohocken, PA 19428

Argonne National Laboratories (2)
Attn: W. DeLuca
G. Henriksen
CTD, Building 205
9700 South Cass Avenue
Argonne, IL 60439

Arizona Public Service (2)
Attn: R. Hobbs
Herb Hayden
400 North Fifth Street
P.O. Box 53999, MS-8931
Phoenix, AZ 85072-3999

AVO International
Attn: Gary Markle
510 Township Line Rd.
Blue Bell, PA 19422

Babcock & Wilcox
Attn: Glenn Campbell
P.O. Box 785
Lynchburg, VA 24505

California State Air Resources Board
Attn: J. Holmes
Research Division
P.O. Box 2815
Sacramento, CA 95812

Calpine Corp.
Attn: R. Boucher
50 W. San Fernando, Ste. 550
San Jose, CA 95113

Chugach Electric Association, Inc. (2)
Attn: T. Lovas
J. Cooley
P.O. Box 196300
Anchorage, AK 99519-6300

Consolidated Edison (2)
Attn: M. Lebow
N. Tai
4 Irving Place
New York, NY 10003

Corn Belt Electric Cooperative
Attn: R. Stack
P.O. Box 816
Bloomington, IL 61702

Delphi Energy and Engine
Management Systems (3)
Attn: J. Michael Hinga
R. Galyen
R. Rider
P.O. Box 502650
Indianapolis, IN 46250

Alaska State Division Of Energy (3)
Attn: P. Frisbey
P. Crump
B. Tiedeman
333 West Fourth Ave, Suite 220
Anchorage, AK 99501-2341

EA Technology, Ltd.
Attn: J. Baker
Chester CH1 6ES
Capenhurst, England
UNITED KINGDOM

Eagle-Picher Industries
Attn: J. DeGruson
C & Porter Street
Joplin, MO 64802

Electrosource
Attn: Michael Dodge
P.O. Box 7115
Loveland, CO 80537

Eltech Research Corporation
Attn: Dr. E. Rudd
625 East Street
Fairport Harbor, OH 44077

Energetics, Inc. (3)
Attn: H. Lowitt
P. Taylor
L. Charles
7164 Gateway Drive
Columbia, MD 21046

Energetics, Inc. (4)
Attn: M. Farber
R. Scheer
J. Schilling
P. DiPietro
501 School St. SW, Suite 500
Washington, DC 20024

Energy and Environmental Economics, Inc.
Attn: Greg J. Ball
353 Sacramento St., Suite 1540
San Francisco, CA 94111

International Energy Systems, Ltd.
Attn: G. Barker
Chester High Road
Nestor, South Wirral
L64 UE UK
UNITED KINGDOM

East Penn Manufacturing Co., Inc.
Attn: M. Stanton
Deka Road
Lyon Station, PA 19536

Electric Power Research Institute (3)
Attn: S. Chapel
S. Eckroad
R. Schainker
P. O. Box 10412
Palo Alto, CA 94303-0813

Electrochemical Engineering Consultants, Inc.
Attn: P. Symons
1295 Kelly Park Circle
Morgan Hill, CA 95037

Electrochemical Energy Storage Systems, Inc.
Attn: D. Feder
35 Ridgedale Avenue
Madison, NJ 07940

Energy Systems Consulting
Attn: A. Pivec
41 Springbrook Road
Livingston, NJ 07039

Firing Circuits, Inc.
Attn: J. Mills
P.O. Box 2007
Norwalk, CT 06852-2007

General Electric Company
Attn: N. Miller
Building 2, Room 605
1 River Road
Schenectady, NY 12345

General Electric Drive Systems
Attn: D. Daly
1501 Roanoke Blvd.
Salem, VA 24153

GE Industrial & Power Services
Attn: Bob Zrebiec
640 Freedom Business Center
King of Prussia, PA 19046

Giner, Inc.
Attn: A. LaConti
14 Spring Street
Waltham, MA 02254-9147

Golden Valley Electric Association, Inc.
Attn: S. Haagensen
Box 71249
758 Illinois Street
Fairbanks, AK 99701

GNB Technologies (4)
Industrial Battery Company
Attn: G. Hunt
J. Szymborski
R. Maresca
J. Boehm
Woodlake Corporate Park
829 Parkview Blvd.
Lombard, IL 60148-3249

Lawrence Berkeley Laboratory (3)
Attn: E. Cairns
K. Kinoshita
F. McLarnon
University of California
One Cyclotron Road
Berkeley, CA 94720

Longitude 122 West
Attn: S. Schoenung
1241 Hobart St.
Menlo Park, CA 94025

Lucent Technologies
Attn: C. Mak
3000 Skyline Drive
Mesquite, TX 75149

Lucent Technologies, Inc.
Attn: J. Morabito
Director, Global Research and Development
P.O. Box 636
600 Mountain Avenue
Murray Hill, NJ 07974-0636

GNB Technologies
World Headquarters
Attn: S. Deshpande
375 Northridge Road
Atlanta, GA 30350

Hawaii Electric Light Co.
Attn: C. Nagata
P.O. Box 1027
Hilo, HI 96720

ILZRO (3)
Attn: J. Cole
P. Moseley
C. Parker
P.O. Box 12036
Research Triangle Park, NC 27709

Imperial Oil Resources, Ltd.
Attn: R. Myers
3535 Research Rd NW
Calgary, Alberta
CANADA T2L 2K8

Innovative Power Sources
Attn: Ken Belfer
1419 Via Jon Jose Road
Alamo, CA 94507

Metlakatla Power & Light
Attn: H. Achenbach
P.O. Box 359
Metlakatla, AK 99926

Micron Corporation
Attn: D. Nowack
158 Orchard Lane
Winchester, TN 37398

ZBB Technologies, LTD.
Attn: Robert J. Parry
Managing Director
16 Emerald Tce.
West Perth
Western Australia 6005

National Renewable Energy Laboratory (6)

Attn: L. Flowers

J. Green

S. Hock

R. DeBlasio

B. Stafford

H. Thomas

1617 Cole Blvd.

Golden, CO 80401-3393

New York Power Authority

Attn: B. Chezar

1633 Broadway

New York, NY 10019

NC Solar Center

Attn: Bill Brooks

Corner of Gorman and Western

Box 7401 NCSU

Raleigh, NC 27695-740

Northern States Power

Attn: D. Zurn

414 Nicollet Mall

Minneapolis, MN 55401

NPA Technology

Attn: Jack Brown

Suite 700, Two University Place

Durham, NC 27707

Oak Ridge National Laboratory (3)

Attn: B. Hawsey, Bldg. 3025, MS-6040

J. Stoval, Bldg. 3147, MS-6070

J. VanCoevering, Bldg. 3147, MS-6070

B. Kirby, Bldg. 3147, MS-6070

P.O. Box 2008

Oak Ridge, TN 37831

Public Service Company of New Mexico

Attn: J. Neal

Manager, Premium Power Services

Alvarado Square MS-BA52

Albuquerque, NM 87158

PEPCO

Attn: Brad Johnson

1900 Pennsylvania NW

Washington, DC 20068

Oglethorpe Power Company

Attn: C. Ward

2100 E. Exchange Place

P.O. Box 1349

Tucker, GA 30085-1349

Chief Technology Officer

Attn: Robert Wills

Advanced Energy Systems

Riverview Mill

Post Office Box 262

Wilton, NH 0308

Omnion Power Engineering Corporation

Attn: H. Meyer

2010 Energy Drive

P.O. Box 879

East Troy, WI 53120

Orion Energy Corp.

Attn: Doug Danley

10087 Tyler Place #5

Ijamsville, MD 21754

Public Service Company of New Mexico

Attn: R. Flynn

Senior Vice President

Alvarado Square MS-2838

Albuquerque, NM 87158

International Business and Technology
Services Inc.

Attn: J. Neal

Administrator Research and Development

9220 Tayloes Neck Rd.

Nanjemoy, MD 20662

Gridwise Engineering Company

Attn: B. Norris

121 Starlight Place

Danville, CA 94526

Pacific Northwest Laboratory (2)

Attn: J. DeSteeze, K5-02

D. Brown

Battelle Blvd.

Richland, WA 99352

Power Technologies, Inc.
Attn: P. Prabhakara
1482 Erie Blvd.
P.O. Box 1058
Schenectady, NY 12301

Puerto Rico Electric Power Authority
Attn: W. Torres
G.P.O. Box 4267
San Juan, Puerto Rico 00936-426

Solar Electric Specialists Co.
Mr. Jim Trotter
232-Anacapa St.
Santa Barbara, CA 93101

ENERTEC
Attn: D. Butler
349 Coronation Drive
Auchenflower, Queensland, 4066
P.O. Box 1139 Milton BC Qld 4064
AUSTRALIA

Southern Company Services, Inc. (2)
Research and Environmental Affairs
14N-8195
Attn: B. R. Rauhe, Jr.
K. Vakhshoorzadeh
600 North 18th Street
P.O. Box 2625
Birmingham, Al 35202-2625

Trace Technologies (2)
Attn: Michael Behnke
W. Erdman
6952 Preston Avenue
Livermore, CA 94550

TRACE Engineering
Attn: B. Roppenecker
President
5916 195th Northeast
Arlington, Washington 98223

RMS Company
Attn: K. Ferris
87 Martling Ave.
Pleasantville, NY 10570

Powercell Corporation (2)
Attn: Reznor I. Orr
Rick Winter
101 Main Street, Suite 9
Cambridge, MA 02142-1519

Raytheon Engineers and Constructors
Attn: A. Randall
700 South Ash St.
P.O. Box 5888
Denver, CO 80217

Siemens Solar
Attn: Clay Aldrich
4650 Adohn Lane
Post Office Box 6032
Camarillo, CA 93011

R&D Associates
Attn: J. Thompson
2100 Washington Blvd.
Arlington, VA 22204-5706

California Energy Commission
Attn: Jon Edwards
1516 Ninth Street, MS-46
Sacramento, CA 95814

Sentech, Inc. (2)
Attn: R. Sen
K. Klunder
4733 Bethesda Avenue, Suite 608
Bethesda, MD 20814

Sentech, Inc.
Attn: Robert Reeves
9 Eaton Road
Troy, NY 12180

Santa Clara University
Attn: Charles Feinstein, Ph.D.
Department of Decision and Information
Sciences
Leavey School of Business and
Administration
Santa Clara, CA 95053

SAFT Research & Dev. Ctr.
Attn: Guy Chagnon
107 Beaver Court
Cockeysville, MD 21030

Salt River Project (2)
Attn: H. Lundstrom
G.E. "Ernie" Palomino, P.E.
MS PAB 357, Box 52025
Phoenix, AZ 85072-2025

Southern California Edison
Attn: R. N. Schweinberg
6070 N. Irwindale Ave., Suite I
Irwindale, CA 91702

Soft Switching Technologies
Attn: D. Divan
2224 Evergreen Rd., Ste. 6
Middleton, WI 53562

Solarex
Attn: G. Braun
630 Solarex Court
Frederick, MD 21701

The Solar Connection
Attn: Michael Orians
P.O. Box 1138
Morro Bay, CA 93443

Trojan Battery Company
Attn: Jim Drizos
12380-Clark Street
Santa Fe Springs, CA 90670

U.S. Department of Energy
Attn: C. Platt
EE-12 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: K. Heitner
Office of Transportation Technologies
EE-32 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: R. Brewer
EE-10 FORSTL
Washington, DC 20585

SEIA
Attn: S. Sklar
122 C Street NW
4th Floor
Washington, DC 20001-2104

SRI International
Attn: C. Seitz
333 Ravenswood Ave.
Menlo Park, CA 94025

Stored Energy Engineering (2)
Attn: George Zink
J.R. Bish
7601 E. 88th Place
Indianapolis, IN 46256

Stuart Kuritzky
347 Madison Avenue
New York, NY 10017

Superconductivity, Inc. (2)
Attn: Jennifer Billman
Michael Gravely
P.O. Box 56074
Madison, WI 53705-4374

Switch Technologies
Attn: J. Hurwitch
4733 Bethesda Ave., Ste. 608
Bethesda, MD 20814

U.S. Department of Energy
Attn: P. Patil
Office of Transportation Technologies
EE-32 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: T. Duong
EE-32 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: J. Daley
EE-12 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: A. Jelacic
EE-12 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: N. Rossmeissl
EE-13 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: Jim Rannels
Photovoltaic Program
EE-11 FORSTL
1000 Independence Ave., S.W.
Washington, DC 20585-0121

U.S. Department of Energy
Attn: J. P. Archibald
EE-90 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: M. B. Ginsberg
EE-90 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: G. Buckingham
Albuquerque Operations Office
Technology Development Division
P.O. Box 5400
Albuquerque, NM 87185

TU Electric
R&D Programs
Attn: James Fangue
P.O. Box 970
Fort Worth, TX 76101

University of Missouri - Rolla
Attn: M. Anderson
112 Electrical Engineering Building
Rolla, MO 65401-0249

U.S. Department of Energy
Attn: R. Eynon
Nuclear and Electrical Analysis Branch
EI-821 FORSTL
Washington, DC 20585

R. Weaver
777 Wildwood Lane
Palo Alto, CA 94303

U.S. Department of Energy
Attn: A. Hoffman
Office of Utility Technologies
EE-10 FORSTL
Washington, DC 20585

U.S. Navy
Attn: Wayne Taylor
Code 83B000D
China Lake, CA 93555

U.S. Department of Energy
Attn: A. G. Crawley
EE-90 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: P. N. Overholt
EE-11 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: J. Cadogan
EE-11 FORSTL
Washington, DC 20585

U.S. Department of Commerce
Attn: Dr. Gerald P. Ceasar
Building 101, Rm 623
Gaithersburg, MD 20899

Virginia Power
Attn: Gary Verno
Innsbrook Technical Center
5000 Dominion Boulevard
Glen Ellen, VA 23233

Walt Disney World Design and Eng'g.
Attn: Randy Bevin
P.O. Box 10,000
Lake Buena Vista, FL 32830-1000

Yuasa, Inc. (3)
Attn: N. Magnani
F. Tarantino
G. Cook
P.O. Box 14145
2366 Bernville Road
Reading, PA 19612-4145

The Technology Group, Inc.
Attn: Tom Anyos
63 Linden Ave.
Atherton, CA 94027-2161

ZBB Technologies, Inc.
Attn: P. Eidler
11607 West Dearborn
Wauwatosa, WI 53226-3961

U.S. Department of Energy
Attn: R. Eaton
Golden Field Office
1617 Cole Blvd.
Building 17
Golden, CO 80401

Westinghouse
Attn: Tom Matty
P.O. Box 17230
Baltimore, MD 21023

Westinghouse STC
Attn: H. Saunders
1310 Beulah Road
Pittsburgh, PA 15235

W. R. Grace & Company
Attn: S. Strzempko
62 Whittemore Avenue
Cambridge, MA 02140

Yuasa-Exide, Inc.
Attn: R. Kristiansen
35 Loch Lomond Lane
Middleton, NY 10941-1421

Crescent EMC
Attn: R. B. Sloan
Executive Vice President
P.O. Box 1831
Statesville, NC 28687

HL&P Energy Services
Attn: George H. Nolin, CEM, P.E.
Product Manager Premium Power Services
P.O. Box 4300
Houston, TX 77210-4300

UFTO
Attn: Edward Beardsworth
951 Lincoln Ave.
Palo Alto, CA 94301-3041

Distributed Utility Associates
Attn: Joseph Iannucci
1062 Concannon Blvd.
Livermore, CA 94550

SAFT America, Inc.
Attn: Ole Vigerstol
National Sales Manager
711 Industrial Blvd.
Valdosta, GA 13601

ECG Consulting Group, Inc.
Attn: Daniel R. Bruck
Senior Associate
55-6 Woodlake Road
Albany, NY 12203

Westinghouse Electric Corporation
Attn: Gerald J. Keane
Manager, Venture Development
Energy Management Division
4400 Alafaya Trail
Orlando, FL 32826-2399

The Brattle Group
Attn: Thomas J. Jenkin
44 Brattle Street
Cambridge, MA 02138-3736

Exide Electronics
Attn: John Breckenridge
Director, Federal Systems Division
8609 Six Forks Road
Raleigh, NC 27615

Northern States Power Company
Attn: Gary G. Karn, P.E.
Consultant Electric Services
1518 Chestnut Avenue North
Minneapolis, MN 55403

Frost & Sullivan (2)
Attn: Steven Kraft
Dave Coleman
2525 Charleston Road
Mountain View, CA 94043

C&D Powercom
Attn: Larry S. Meisner
Manager Product Marketing
1400 Union Meeting Road
P.O. Box 3053
Blue Bell, PA 19422-0858

Tampa Electric Company
Attn: Terri Hensley, Engineer
P.O. Box 111
Tampa, FL 33601-0111

U.S. Department of Energy
Attn: R. J. King
EE-11 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: A. O. Bulawka
EE-11 FORSTL
Washington, DC 20585

American Superconductor Corporation
Attn: S. Amanda Chiu, P.E.
Manager, Strategic Marketing
Two Technology Drive
Westborough, MA 01581

University of Texas at Austin
Attn: John H. Price
Research Associate
Center for Electromechanics
J. J. Pickel Research Campus
Mail Code R7000
Austin, TX 78712

U.S. Department of Energy
Attn: W. Butler
PA-3 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: J. A. Mazer
EE-11 FORSTL
Washington, DC 20585

VEDCO Energy
Attn: Rick Ubaldi
12 Agatha Lane
Wayne, New Jersey 07470

Intercon Limited (2)
Attn: David Warar
6865 Lincoln Avenue
Lincolnwood, IL 60646

Utility PhotoVoltaic Group
Attn: Steve Hester
1800 M Street, N.W.
Washington, DC 20036-5802

U.S. Department of Energy
Attn: P. Maupin
ER-14
G-343/GTN
Germantown, MD 20874-1290

Southern California Edison
Attn: N. Pinsky
P.O. Box 800
2244 Walnut Grove Ave., Rm 418
Rosemead, CA 91770

U.S. Department of Energy
Attn: D. T. Ton
EE-11 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: J. Galdo
EE-10 FORSTL
Washington, DC 20585

Queensland Department of Mines and Energy
Attn: N. Lindsay
Senior Project Officer
Energy Planning Division
GPO Box 194 Brisbane 4001, Qld. Australia

Utility Power Group
Attn: Mike Stern
9410-G DeSoto Avenue
Chatsworth, CA 91311-4947

Amber Gray-Fenner
7204 Marigot Rd. NW
Albuquerque, NM 87120

ABB Power T&D Company, Inc.
Attn: H. Weinerich
1460 Livingston Avenue
North Brunswick, New Jersey

MS-0513, R. Eagan (1000)
MS-0953, W.E. Alzheimer (1500)
MS-0953, J.T. Cutchen (1501)
MS-0741, S. Varnado (6200)
MS-0212, A. Phillips, (10230)
MS-0340, J. Braithwaite (1832)
MS-0343, W. Cieslak (1832)
MS-0613, A. Akhil (1525)
MS-0613, D. Doughty (1521)

MS-0613, G. Corey (1525)
MS-0614, G.P. Rodriguez, (1523)
MS-0613, I. Francis (1525)
MS-0614, J.T. Crow (1523)
MS-0614, T. Unkelhaeuser (1523)
MS-0614, D. Mitchell (1522)
MS-0614, K. Grothaus (1523)
MS-0613, N. Clark (1525)
MS-0613 R. Jungst (1521)
MS-0704, P.C. Klimas (6201)
MS-0708, H. Dodd (6214)
MS-0752, M. Tatro (6219)
MS-0753, C. Cameron (6218)
MS-0753, R. Bonn (6218)
MS-0753, T. Hund (6218)
MS-0753, W. Bower (6218)
MS-1193, D. Rovang (9531)
MS-0614, A Jimenez (1523)
MS-0537, S. Atcitty (2314)
MS-0613, J.D. Guillen (1525)
MS-9403, Jim Wang (8713)
MS-0613, P. Butler (1525) (20)
MS-0619, Review & Approval Desk For DOE/OSTI (12690) (2)
MS-0899, Technical Library (4916) (2)
MS-9018, Central Technical Files (8940-2)