

JUL 15 1997
Sta. 37 (20)

ENGINEERING DATA TRANSMITTAL

Page 1 of 1

1. EDT 607691

2. To: (Receiving Organization) Distribution	3. From: (Originating Organization) Nuclear Safety	4. Related EDT No.: N/A
5. Proj./Prog./Dept./Div.: Spent Nuclear Fuel Project	6. Design Authority/ Design Agent/Cog. Engr.: L. J. Garvin/D. E. Krahn	7. Purchase Order No.: N/A
8. Originator Remarks: This document is being distributed for approval and release.		9. Equip./Component No.: N/A
		10. System/Bldg./Facility: CSB
11. Receiver Remarks: 11A. Design Baseline Document? ☐ Yes ☒ No		12. Major Assm. Dwg. No.: N/A
		13. Permit/Permit Application No.: N/A
		14. Required Response Date: N/A

15. DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Design- ator	Reason for Trans- mittal	Origi- nator Dispo- sition	Receiv- er Dispo- sition
1	HNF-SD-SNF-HIE-001		0	Canister Storage Building Hazard Analysis Report	ESQ	1-2	1	

16. KEY			
Approval Designator (F)	Reason for Transmittal (G)	Disposition (H) & (I)	
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)	1. Approval 2. Release 3. Information 4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)	1. Approved 2. Approved w/comment 3. Disapproved w/comment	4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)											
(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN
1	1	Design Authority	G. D. Bazins	7/14/97	58-06						
		Design Agent									
1	1	Cog.Eng.	L. J. Garvin	7/15/97	83-15						
1	1	Cog. Mgr.	R. P. Omberg	7/15/97	83-15						
1	1	QA	T. D. Hays	7/14/97	58-06						
1	1	Safety	T. D. Merkling	7/14/97	79						
1	1	Env.	J. E. Turnbaugh	7/15/97	83-15						

18. Signature of EDT Originator D. E. Krahn 7-14-97	19. Authorized Representative Date for Receiving Organization B. R. Omberg 7/14/97	20. Design Authority/ Cognizant Manager B. R. Omberg 7/14/97	21. DOE APPROVAL (if required) Ctrl. No. ☐ Approved ☐ Approved w/comments ☐ Disapproved w/comments
---	--	--	---

Canister Storage Building Hazard Analysis Report

D. E. Krahn/L. J. Garvin

Fluor Daniel Northwest, Richland, WA 99352

U.S. Department of Energy Contract DE-AC06-96RL13200

EDT/ECN: 607691

UC: 721

Org Code: ~~2T640~~ 04E00

Charge Code: LG070

B&R Code: ~~E231354~~

Total Pages: 116

39EW70400

Key Words: Hazard Analysis, Canister Storage Building


Abstract: This report describes the methodology used in conducting the Canister Storage Building (CSB) hazard analysis to support the final CSB safety analysis report (SAR) and documents the results.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: Document Control Services, P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

Lance Bishop
Release Approval

7-15-97
Date



Release Stamp

Approved for Public Release

**CANISTER STORAGE BUILDING
HAZARD ANALYSIS REPORT**

**HNF-SD-SNF-HIE-001
Revision 0**

July 1997

This page intentionally left blank.

CONTENTS

1.0 INTRODUCTION	1-1
2.0 SCOPE OF THE HAZARD ANALYSIS	2-1
3.0 HAZARD ANALYSIS METHODOLOGY	3-1
3.1 HAZARD IDENTIFICATION	3-1
3.2 HAZARD EVALUATION	3-2
3.3 CANDIDATE ACCIDENT SELECTION	3-4
4.0 REFERENCES	4-1

ATTACHMENTS

1 CANISTER STORAGE BUILDING OPERATIONS FLOW DIAGRAM	A1-1
2 CANISTER STORAGE BUILDING HAZARD ANALYSIS TEAM MEMBERS	A2-1
3 RELEASE CHARACTERISTICS FOR HAZARDOUS CONDITIONS ASSOCIATED WITH OFFSITE (SITE BOUNDARY) AND ONSITE (COLLOCATED WORKER) RECEPTORS	A3-1

LIST OF FIGURES

3-1. Hazardous Material/Energy Source Checklist: Example	F3-1
3-2. Hazardous Material/Energy Source Checklist: Truck Vestibule	F3-2
3-3. Hazardous Material/Energy Source Checklist: Service Area	F3-3
3-4. Hazardous Material/Energy Source Checklist: Operating Area	F3-4
3-5. Hazardous Material/Energy Source Checklist: Vault	F3-5
3-6. Hazardous Material/Energy Source Checklist: Support Building	F3-6
3-7. Hazardous Material/Energy Source Checklist: Outside	F3-7

LIST OF TABLES

3-1. Standard Industrial Hazards: Truck Vestibule	T3-1
3-2. Standard Industrial Hazards: Service Area	T3-2
3-3. Standard Industrial Hazards: Operating Area	T3-3
3-4. Standard Industrial Hazards: Vault	T3-4
3-5. Standard Industrial Hazards: Support Building	T3-5
3-6. Standard Industrial Hazards: Outside	T3-6
3-7. Canister Storage Building Material at Risk	T3-7
3-8. Canister Storage Building Operations Hazardous Energy Source Characterization — Location in Facility: Truck Vestibule	T3-8
3-9. Canister Storage Building Operations Hazardous Energy Source Characterization — Location in Facility: Service Area	T3-12
3-10. Canister Storage Building Operations Hazardous Energy Source Characterization — Location in Facility: Operating Area	T3-17
3-11. Canister Storage Building Operations Hazardous Energy Source Characterization — Location in Facility: Vault	T3-23
3-12. Canister Storage Building Operations Hazardous Energy Source Characterization — Location in Facility: Support Building	T3-25
3-13. Canister Storage Building Operations Hazardous Energy Source Characterization — Location in Facility: Outside	T3-27
3-14. Canister Storage Building Hazard Analysis: Truck Vestibule	T3-29
3-15. Canister Storage Building Hazard Analysis: Service Area	T3-36
3-16. Canister Storage Building Hazard Analysis: Operating Area	T3-46
3-17. Canister Storage Building Hazard Analysis: Vault	T3-56
3-18. Canister Storage Building Hazard Analysis: Support Building	T3-58
3-19. Canister Storage Building Hazard Analysis: Outside	T3-60

This page intentionally left blank.

CANISTER STORAGE BUILDING HAZARD ANALYSIS REPORT

1.0 INTRODUCTION

This report describes the methodology used in conducting the Canister Storage Building (CSB) hazard analysis to support the final CSB safety analysis report (SAR) and documents the results. The hazard analysis was performed in accordance with DOE-STD-3009-94, *Preparation Guide for U.S. Department of Energy Nonreactor Nuclear Facility Safety Analysis Reports*, and implements the requirements of DOE Order 5480.23, *Nuclear Safety Analysis Reports*.

This page intentionally left blank.

2.0 SCOPE OF THE HAZARD ANALYSIS

The scope of the CSB hazard analysis was limited to normal, intended, CSB operations, based on the design and operations described in Chapters 2.0 and 4.0 of HNF-SD-SNF-RPT-004, *Canister Storage Building Safety Analysis Report — Phase 3: Safety Analysis Documentation Supporting Canister Storage Building Construction* (Garvin 1997). The analysis included review of a draft operation flow diagram and draft operating procedures. The CSB operations considered were those involved with bringing the transportation cask containing a multicanister overpack (MCO) into the facility on the transporter, moving the cask-MCO to the service area and removing the cask lid, transporting the MCO from the service area to the storage tube with the MCO handling machine (MHM), conducting activities during MCO staging and interim storage, and transporting the MCO from the storage tube to the Hot Conditioning System Annex and returning it to the storage tube after hot conditioning. The details of the hot conditioning process were not within the scope of the hazard analysis. They will be analyzed in the Hot Conditioning System hazard analysis.

One purpose of the hazard analysis effort was to identify information that remained to be developed before the hazard analysis could be completed in support of the final CSB SAR. A number of issues and open items were identified in the course of the hazard evaluation. While many have since been closed, several items remain open at this time. All remaining specific open action items and issues necessary to complete the hazard analysis are identified in the remarks column of the hazard analysis tables. In addition to the specific items and issues, the following generic issues important to the completion of the hazard and accident analysis were identified.

1. The means of detecting off-normal conditions during CSB operations and the plans for recovery actions need to be developed. These recovery actions also need to be examined for their potential to initiate additional hazardous conditions or accidents.
2. The hazard evaluation reflects a high degree of confidence that the CSB criteria for acceptance of an MCO into the facility (evidence of pressure test at the end of cold vacuum drying and adherence to the shipping window time limits identified in HNF-SD-SNF-SARP-017, *Preliminary Safety Analysis Report for Packaging (Onsite) Multiple Canister Overpack Cask* [RFS 1996]) will provide a safety margin sufficient to avoid a high pressure blowdown of the MCO before it is placed in the storage tube. The supporting analysis for this confidence has yet to be developed and documented.
3. Design of important components is not yet finalized. Of particular importance to the hazard evaluation and accident analysis are completion of MCO design, particularly the pressure relief systems, MHM and receiving crane design, and service cart design and intended use.

Both the specific open action items identified in the tables and the generic issues listed above will be closed out through future revisions to this document. All items will be closed before submittal of the final SAR for DOE approval.

The following key sources of information were used to evaluate the hazards:

- Chapters 2.0 and 4.0 of HNF-SD-SNF-RPT-004 (Garvin 1997) for facility design and operations information
- Chapter 3.0 of HNF-SD-SNF-RPT-004 (Garvin 1997) for the facility radioactive materials inventory and Appendix 3A for the results of the preliminary hazard analysis
- Chapter 6.0 of HNF-SD-SNF-RPT-004 (Garvin 1997) to evaluate the potential for hazards from nuclear criticality events
- Fluor Daniel, Inc., drawing SK-120916 (3 sheets), "Operational Sequence Top Level Block Diagram," "Operating Sequence MCO Service Station Block Diagram," "Operating Sequence MHM Operations MCO Service Operations Block Diagram" (see Attachment 1)
- Draft operating procedures, currently located on the Hanford local area network shared drive \\AP013\SNFP
- HNF-SD-SNF-FHA-002, *Preliminary Fire Hazard Analysis for the Canister Storage Building* (Sadanaga 1996); Ares Report 951107-001, *Canister Storage Building Fire Code Equivalency Evaluation* (Ares 1996a); Ares Report 951107-002, *White Paper Presenting Recommended Approach to Fire Protection of the Operating Area of the Canister Storage Building* (Ares 1996b); Letter 9655218, *Project W-379, Spent Nuclear Fuel Canister Storage Building Request for Deviation from the United States Department of Energy Order 6430.1A — Automatic Sprinkler Protection Requirements* (Williams 1996a); and Letter 9655233, *Project W-379, Spent Nuclear Fuel Canister Storage Building Request for Exemption from the United States Department of Energy Order 5480.7A — Automatic Fire Suppression System Requirements* (Williams 1996b)
- HNF-SD-TP-SARP-017, *Preliminary Safety Analysis Report for Packaging (Onsite) Multiple Canister Overpack Cask* (RFS 1996), for coverage of accidents involving the transporter and transportation cask and for definition of assumptions inherent in defining the transportation window
- Two representatives from facility operations for details of proposed operating modes and procedures
- HNF-SD-SNF-SARR-005, *Multicanister Overpack Topical Report* (Lorenz 1997), for criteria and assumptions related to MCO design
- Representatives of the design authority for receiving crane and MHM for details of the current (incomplete) design of those components.

3.0 HAZARD ANALYSIS METHODOLOGY

This section presents the methodology used to perform the CSB hazard analysis. First the hazard identification process systematically and comprehensively identified hazards that can contribute to the uncontrolled release of radioactive or hazardous materials or that can threaten the safety of facility workers. The hazard evaluation process identified hazardous conditions, determined causes and preventive and mitigative features, and qualitatively estimated the consequences and frequency of occurrence. Results of the hazard evaluations were used to select candidate accidents for quantitative analysis. Results of the hazard and accident analyses were then used to identify safety structures, systems, and components (SSCs); technical safety requirements; and other controls required to protect the public, workers, and environment. The hazard and accident analysis results also supported determination of the final facility hazard classification.

3.1 HAZARD IDENTIFICATION

The hazard analysis included identification of the hazards associated with CSB design and operations. Hazards were defined as material, referred to as material at risk, that may have a potentially adverse effect on people, the CSB facility, or the environment, and as energy sources that could contribute to uncontrolled release of radioactive or hazardous material or to injury to personnel.

Hazard identification for the CSB was based on examination of the facility and operations descriptions provided in Chapters 2.0 and 4.0 of HNF-SD-SNF-RPT-004 (Garvin 1997), on a draft operation flow diagram and draft operating procedures, and on discussions with design representatives from Flour Daniel, Inc. The facility was divided into six areas:

- Truck vestibule
- Service area
- Operating area
- Vault
- Support building
- Outside.

A standardized checklist, Figure 3-1, was used to identify potentially hazardous materials and energy sources present in each of the six areas. Figures 3-2 through 3-7 show the hazard identification results for each area. The hazard identification checklists were developed by a subgroup of the hazard analysis team and reviewed and accepted by the entire team. The team included representatives of the CSB design authority and CSB operations personnel.

3.2 HAZARD EVALUATION

The hazard evaluation was a structured and systematic examination of the CSB facility and its operations using standard industry (American Institute of Chemical Engineers) hazard evaluation techniques. It was performed by a team of cognizant CSB operations and design personnel, safety analysts familiar with the CSB, and technical experts in specialty areas. Attachment 2 lists the members of the hazard analysis team and describes the background and experience of each. Information from a preliminary hazard analysis (Garvin 1997) that was performed at the conceptual design stage for the facility was used as a check for completeness.

The first step in the hazard evaluation was to screen the potentially hazardous materials and energy sources for those that present only standard industrial hazards. These are defined in DOE-STD-3009-94 as those hazards that "are routinely encountered in general industry and construction, and for which national consensus codes and/or standards (e.g., Occupational Safety and Health Administration, transportation safety) exist to guide safe design and operation without the need for special analysis to define safe design and/or operational parameters." Tables 3-1 through 3-6 provide the listing of standard industrial hazards by facility area. The industrial safety requirements for U.S. Department of Energy sites are covered by Title 29, *Code of Federal Regulations*, Part 1910, "Occupational Safety and Health Standards." The following parts of that document apply to the protection of workers from the hazards identified in the tables:

Subpart A	General
Subpart D	Walking - Working Surfaces
Subpart E	Means of Egress
Subpart F	Powered Platforms, Manlifts, and Vehicle-Mounted Work Platforms
Subpart G	Occupational Health and Environmental Control
Subpart H	Hazardous Materials
Subpart I	Personal Protective Equipment
Subpart J	General Environmental Controls
Subpart K	Medical and First Aid
Subpart L	Fire Protection
Subpart M	Compressed Gas and Compressed Air Equipment
Subpart N	Materials Handling, and Storage
Subpart O	Machinery and Machine Guarding
Subpart P	Hand and Portable Powered Tools and Other Hand-Held Equipment
Subpart Q	Welding, Cutting, and Brazing
Subpart S	Electrical
Subpart Z	Toxic and Hazardous Substances.

The hazard analysis team agreed by consensus to the results of the screening.

The remaining hazards were characterized to support the hazard evaluation process. Table 3-7 identifies the type, form, and quantity of the material at risk at the CSB facility. Tables 3-8 through 3-13 characterize the hazardous materials and energy sources that can contribute to the uncontrolled release of the material at risk identified in Table 3-7. The values in

the tables are not intended to represent limits. They were used solely to indicate relative magnitude of the various hazards to aid in the evaluation and binning process. Some design and operations information is not yet available in the detail needed to completely characterize the hazards. The tables indicate "TBD" for those items that need to be identified before this hazard analysis can be finalized to support the final CSB SAR.

The characterized hazards were then entered into the hazard analysis tables by facility area. Using the tables as a guide, the team identified and recorded each hazardous condition and the potential accidents arising from the presence of the hazardous condition, potential causes and consequences of the hazardous condition, existing design features to prevent the condition or mitigate the consequences, planned administrative features to prevent the hazardous condition or mitigate the consequences, and estimates of the likelihood and consequences of the hazardous condition.

The hazard analysis tables, Tables 3-14 through 3-19, show the results of the hazard evaluation as compiled by the hazard analysis team. The hazard analysis tables contain descriptions of causes for hazardous conditions. Identification of causes was based on the hazard identification results, reviews of the systems designs and planned operations, existing safety documentation, and the experience of hazard analysis team members. Typical potential causes of the postulated hazardous conditions include equipment failures, operational errors, abnormal operating conditions, poor operating practices, and environmental conditions. The potential causes of a postulated hazardous condition were identified to support a qualitative frequency evaluation.

Each hazardous condition was assessed to determine a qualitative likelihood of occurrence and consequence. The assessment of likelihood and consequence for each hazardous condition was a collective, qualitative judgment made by the hazard analysis team. The assessment took into consideration the impact of designed passive features (e.g., structures, barriers) when estimating likelihoods and consequences but not active features or planned controls (e.g., valves, shipping restrictions).

The likelihood assessments were based on occurrences over the facility lifetime. The qualitative criteria for likelihood assessments are as follows.

- F3 The hazardous condition based on the causes postulated is likely to occur during facility lifetime.
- F2 The hazardous condition based on the causes postulated is foreseeable, but unlikely.
- F1 The hazardous condition based on the causes postulated is perhaps possible, but extremely unlikely.
- F0 The hazardous condition based on the causes postulated is considered too improbable to warrant further consideration.

The consequence assessments were based on potential effects of an MCO release on the health and safety of people and on the environment. The qualitative criteria for consequence assessments are as follows.

- S3 On the basis of material at risk and causes postulated, there is sufficient material and release energy to affect a receptor at the nearest point of uncontrolled public access.
- S2 On the basis of material at risk and causes postulated, there is sufficient material and energy to affect an onsite receptor (collocated worker) 100 m from the source of the release.
- S1 On the basis of material at risk and causes postulated, the release is confined to the facility and affects facility workers.
- S0 On the basis of material at risk and causes postulated, there is insufficient material released to affect facility workers.

The more severe consequence categories encompass the less severe consequence categories. For example, a hazardous condition assessed as having onsite consequences (S2) is also considered to have facility worker consequences (S1).

The hazard analysis tables contain identified preventive or mitigative design features and proposed administrative controls that have the potential to reduce the estimated likelihood of a postulated hazardous condition or to reduce its consequences. Only passive design features were factored into the likelihood and consequence assessment. Proposed administrative controls were identified primarily by the draft operating procedures and the contribution of operations personnel on the hazard evaluation team.

3.3 CANDIDATE ACCIDENT SELECTION

The hazardous conditions identified by the hazard evaluation have been used to select candidate accidents for more detailed, quantitative analysis in the final CSB SAR. The general selection criteria used were consistent with DOE-STD-3009-94: "The range of accident scenarios analyzed in a SAR should be such that a complete set of bounding conditions to define the envelope of accident conditions to which the operation could be subjected are evaluated and documented." This section describes the approach used to select candidate accidents. The results of the activity are contained in Attachment 3.

The concept of selecting candidate accidents from all hazardous conditions identified is based on the feasibility of characterizing risk from, and developing controls for, a representative set of hazardous conditions. A hazardous condition is generally considered to be representative of other hazardous conditions if it has similar release characteristics and involves similar initiators. Hazardous conditions that represent the most severe consequences and the highest risk (a

combination of frequency and consequences) within each set of representative hazards are selected as candidate accidents for further analysis in the SAR.

In accordance with DOE-STD-3009-94 and consistent with the graded approach, the risks of a facility may be characterized and appropriate controls developed using the detailed analysis of a representative set of hazardous conditions. The representative hazardous conditions bound conditions with lesser but similar potential consequences, represent the highest risk, or, while not necessarily bounding, present some unique but important phenomenological challenge to system safety. The selection process comprises five steps:

1. Initial screening
2. Assignment of release attributes
3. Creation of hazardous material release bins
4. Selection of representative bounding hazardous conditions for each release attribute category
5. Selection of unique hazardous conditions.

Initial Screening. All hazardous conditions whose unmitigated consequences are assessed as S3 (offsite consequences) or S2 (collocated worker consequences) are chosen for consideration for representative accident selection through a ranking of relative risk (see Table A3-1). Those assessed as S1 (facility worker consequences) do not warrant detailed accident analysis and are instead addressed qualitatively in the SAR using the hazard analysis results. Those assessed as having no consequences (S0) are dropped from consideration.

Assignment of Release Attributes. Each hazardous condition is described with certain release attributes related to uncontrolled release of the material at risk (see Table A3-2). This is done to ensure that at least one candidate accident is selected to represent each unique set of release conditions. The hazardous material release attributes used are as follows:

- Initial energy available to release the hazardous material (high, medium, or low)
- Initial release location
- The release initiator.

Creation of Hazardous Material Release Bins. Once the release attributes are assigned to each hazardous condition, they are collected to form release categories, or "bins." Collecting hazardous conditions into bins involves grouping all hazardous conditions with common initiators and ranking them by estimated consequence, available energy for release, and frequency.

Selection of Representative Bounding Hazardous Conditions for each Release Attribute Category. Within each release attribute bin, the most severe hazardous condition, considering consequences, and the highest risk accident, based on a likelihood and consequence

ranking matrix as described in DOE-STD-3009-94 (see Attachment 3, Table A3-1), were selected. In some cases, they were the same hazardous condition.

Selection of Unique Hazardous Conditions. Hazardous conditions were selected to represent additional, unique causes within each release attribute bin. This was done to support development of controls for accidents with similar consequences but with different causes.

The final list of candidate accidents represents all S3 (offsite) and S2 (onsite) hazardous conditions identified by the hazard analysis. These hazardous conditions are grouped by candidate accident to facilitate incorporation of the information and conclusions from the accident analysis into the hazard analysis results when considering controls and hazard classification.

Individual release bins may need to be broken into several smaller bins in the future as a result of ongoing accident analysis activities. This is often driven by a determination that separate sets of controls are necessary for hazardous conditions in the same release bin to reduce the likelihood or consequence of the hazards involved. Any modifications to the binning categories will be incorporated into this document to support the final CSB SAR.

Figure 3-1. Hazardous Material/Energy Source Checklist: Example.

NODE:

YNA. Electrical	YNJ. Explosives/Prophorics	YNM. Hazardous Materials
00 1. Battery banks	00 1. Caps	00 1. Alkali metals
00 2. Cable runs	00 2. Primer cord	00 2. Asphyxiants
00 3. Diesel generators	00 3. Dynamite	00 3. Biogicals
00 4. Electrical equipment	00 4. Scrub chemicals	00 4. Carcinogens
00 5. HVAC heaters	00 5. Dusts	00 5. Corrosives
00 6. High voltage	00 6. Hydrogen	00 6. Oxidizers
00 7. Motors	00 7. Gases, others	00 7. Toxics
00 8. Pumps	00 8. Nitrates	00 8. Heavy metals
00 9. Power tools	00 9. Peroxides	00 9. Other _____
00 10. Switchgear	00 10. Pu and U metal	
00 11. Service outlets, fittings	00 11. Sodium	
00 12. Transformers	00 13. Other _____	
00 13. Transmission lines		
00 14. Underground wires	YNK. Nuclear Criticality	
00 15. Mining	00 1. Vaults	
00 16. Other _____	00 2. Temporary storage areas	
	00 3. Shipping and receiving area	
	00 4. Filers	
	00 5. Casks	
	00 6. Burial ground	
	00 7. Storage racks	
	00 8. Canals and basins	
	00 9. Decontamination solution	
	00 10. Trucks, forklifts, dollies	
	00 11. Hand carry	
	00 12. Cranes/lifts	
	00 13. Hot cells, assembly, inspection	
	00 14. Laboratories	
	00 15. Other _____	
YNB. Thermal	YNL. Flammable Materials	YNP. External Events
00 1. Bunsen burner/not plates	00 1. Packing materials	00 1. Explosion
00 2. Electrical equipment	00 2. Rags	00 2. Fire
00 3. Furnaces/boilers/heater	00 3. Gasoline	00 3. Other sites
00 4. Steam lines	00 4. Lub oil	
00 5. Welding torch/arc	00 5. Diesel oil	
00 6. Diesel unit/fire box/exhaust line	00 6. Paint	
00 7. Radioactive decay heat	00 7. Paint solvent	
00 8. Exposed components	00 8. Diesel fuel	
00 9. Power tools	00 9. Buildings & contents	
00 10. Convective	00 10. Trailers and contents	
00 11. Solar	00 11. Grease	
00 12. Cryogenic	00 12. Hydrogen	
00 13. Other _____	00 13. Nitric acid	
	00 14. Organics	
	00 15. Gases - others	
	00 16. Liquids - others	
	00 17. Other _____	
YNC. Friction	YNH. Pressure - Volume	YNO. Vehicles in Motion (external to facility)
00 1. Belts	00 1. Boilers	00 1. Airplane
00 2. Bearings	00 2. Surge tanks	00 2. Helicopter
00 3. Fans	00 3. Autoclave	00 3. Train
00 4. Gears	00 4. Wet traps	00 4. Truck/bus/car
00 5. Motors	00 5. Gas bolts	00 5. Other _____
00 6. Power tools	00 6. Pressure vessels	
00 7. Other _____	00 7. Stressed members	
	00 8. Gas receivers	
YND. Corrosives	00 9. Negative pressure collapse	
00 1. Acids	00 10. Steam headers and lines	
00 2. Caustics	00 11. Other _____	
00 3. Natural chemicals		
00 4. Decontamination solution		
00 5. High temperature waste		
00 6. Other _____		

Figure 3-2. Hazardous Material/Energy Source Checklist: Truck Vestibule.

Location: Truck Vestibule

Y N A. Electrical ☐ 1. Battery banks ☐ 2. Cable runs (cable cabinets) ☐ 3. Diesel generators ☐ 4. Electrical equipment ☐ 5. HVAC heaters ☐ 6. High voltage ☐ 7. Motors (cable) ☐ 8. Pumps ☐ 9. Switchgear ☐ 10. Sulfuric acid ☐ 11. Service outlets, fittings ☐ 12. Transformers ☐ 13. Transmission lines ☐ 14. Underground wires ☐ 15. Wiring ☐ 16. Other _____	Y N E. Kinetic - Rotational ☐ 1. Centrifuges ☐ 2. Motors ☐ 3. Pumps ☐ 4. Cooling tower fans ☐ 5. Laundry equipment ☐ 6. Shop equipment ☐ 7. Other _____	Y N F. Kinetic - Linear ☐ 1. Cars, trucks, buses ☐ 2. Forklifts, dollies, carts (service carts) ☐ 3. Railroad ☐ 4. Obstructions ☐ 5. Crane loads ☐ 6. Pressure vessel blowdown ☐ 7. Other _____	Y N G. Mass, Gravity, Height ☐ 1. Human effort ☐ 2. Stairs ☐ 3. Lifts and cranes ☐ 4. Bucket and ladder ☐ 5. Trucks ☐ 6. Shirts ☐ 7. Pallets ☐ 8. Exposed components ☐ 9. Power tools (no cutting tools) ☐ 10. Solar ☐ 11. Pits and excavations ☐ 12. Elevated doors ☐ 13. Vessels ☐ 14. Other _____	Y N B. Thermal ☐ 1. Bunsen burner/hot plates ☐ 2. Electrical equipment ☐ 3. Furnace/boilers/heater ☐ 4. Steam lines ☐ 5. Welding torch/arc ☐ 6. Diesel unit/fine box/exhaust line ☐ 7. Radioactive decay heat ☐ 8. Exposed components ☐ 9. Power tools (no cutting tools) ☐ 10. Solar ☐ 11. Cryogenic ☐ 12. Other brakes ☐ 13. Other _____	Y N H. Pressure - Volume ☐ 1. Boilers ☐ 2. Bearings ☐ 3. Fans ☐ 4. Gears ☐ 5. Motors ☐ 6. Power tools (no cutting tools) ☐ 7. Other _____	Y N D. Corrosives ☐ 1. Acids ☐ 2. Caustics ☐ 3. Natural chemicals ☐ 4. Decontamination solution ☐ 5. High temperature waste ☐ 6. Other _____	Y N J. Exothermic Reactions ☐ 1. Caps ☐ 2. Primer cord ☐ 3. Dynamite ☐ 4. Solub chemicals ☐ 5. Corrosives ☐ 6. Hydrogen ☐ 7. Gases, others ☐ 8. Nitrites ☐ 9. Peroxides ☐ 10. Pu and U metal ☐ 11. Sodium ☐ 12. Other _____	Y N K. Nuclear Criticality ☐ 1. Vaults ☐ 2. Temporary storage areas ☐ 3. Shipping and receiving area ☐ 4. Fillers ☐ 5. Casks ☐ 6. Burial ground ☐ 7. Storage racks ☐ 8. Casks and basins ☐ 9. Decontamination solution ☐ 10. Handwritten, dories ☐ 11. Handwritten, dories ☐ 12. Cans/salts ☐ 13. Hot cells, assembly, inspection ☐ 14. Laboratories ☐ 15. Other _____	Y N L. Flammable Materials ☐ 1. Packing materials ☐ 2. Rags ☐ 3. Gasoline ☐ 4. Lube oil ☐ 5. Coolant oil ☐ 6. Paint solvent ☐ 7. Diesel fuel ☐ 8. Buildings & contents ☐ 9. Trailers and contents ☐ 10. Grease ☐ 11. Hydrogen ☐ 12. Nitric acid ☐ 13. Organics ☐ 14. Gases - others ☐ 15. Liquids - others ☐ 16. Other hydraulic fluid	Y N M. Hazardous Materials ☐ 1. Alkali metals ☐ 2. Asphyxiants ☐ 3. Biologicals ☐ 4. Corrosives ☐ 5. Corrosives ☐ 6. Oxidizers ☐ 7. Toxics ☐ 8. Heavy metals (battery lead) ☐ 9. Other _____	Y N N. Ionizing Radiation Sources ☐ 1. Fissile material ☐ 2. Radiography equipment ☐ 3. Radioactive material ☐ 4. Radioactive sources ☐ 5. Other _____	Y N P. External Events ☐ 1. Explosion ☐ 2. Fire ☐ 3. Other sites	Y N Q. Vehicles in Motion (external to facility) ☐ 1. Airplane ☐ 2. Helicopter ☐ 3. Train ☐ 4. Truck/bus/car ☐ 5. Other _____	Y N R. Natural Phenomena ☐ 1. Earthquake ☐ 2. Flood ☐ 3. Lightning ☐ 4. Rain ☐ 5. Snow, freezing weather ☐ 6. Straight wind ☐ 7. Dust devil ☐ 8. Tornado ☐ 9. Ashfall ☐ 10. Range fire
---	--	--	---	---	--	---	--	---	---	---	---	---	--	---

Figure 3-3. Hazardous Material/Energy Source Checklist: Service Area.

Location: MCO Service Area

Y N A. Electrical ☐ 1. Battery banks (M&M backup power) ☐ 2. Cable runs ☐ 3. Diesel generators ☐ 4. Electrical equipment ☐ 5. HVAC ☐ 6. High voltage ☐ 7. Motors (fixed) ☐ 8. Pumps ☐ 9. Power tools ☐ 10. Switchgear ☐ 11. Service outlets, fittings ☐ 12. Transformers ☐ 13. Transmission lines ☐ 14. Underground wires ☐ 15. Wiring ☐ 16. Other <u> </u>	Y N E. Kinetic - Rotational ☐ 1. Centrifuges ☐ 2. Rotors ☐ 3. Cooling tower fans ☐ 4. Laundry equipment ☐ 5. Ship equipment ☐ 6. Other <u>M&M turret</u> Y N F. Kinetic - Linear ☐ 1. Cars, trucks, buses ☐ 2. Forklifts, dollies, carts ☐ 3. Railroad ☐ 4. Obstructions ☐ 5. Crane loads (includes M&M cranes) ☐ 6. Pressure vessel blowdown ☐ 7. Other <u>M&M movement</u>	Y N M. Exothermic Reactions ☐ 1. Acids ☐ 2. Peroxide ☐ 3. Dynamite ☐ 4. Scrub chemicals ☐ 5. Dusts ☐ 6. Hydrogen ☐ 7. Gases, others ☐ 8. Nitrates ☐ 9. Peroxides ☐ 10. Pu and U metal ☐ 11. Sodium ☐ 12. Other <u> </u>	Y N M. Hazardous Materials ☐ 1. Alkaline ☐ 2. Asphyxiants ☐ 3. Biologicals ☐ 4. Carcinogens ☐ 5. Corrosives ☐ 6. Oxidizers ☐ 7. Toxics ☐ 8. Heavy metals ☐ 9. Other <u> </u>	Y N N. Ionizing Radiation Sources ☐ 1. Fissile material ☐ 2. Radiography equipment ☐ 3. Radioactive material ☐ 4. Radioactive sources ☐ 5. Other <u> </u>	Y N P. External Events ☐ 1. Explosion ☐ 2. Fire ☐ 3. Other sites <u> </u>	Y N Q. Vehicles in Motion (external to facility) ☐ 1. Airplane ☐ 2. Helicopter ☐ 3. Train ☐ 4. Truck/bus/car ☐ 5. Other <u> </u>	Y N R. Natural Phenomena ☐ 1. Earthquake ☐ 2. Flood ☐ 3. Lightning ☐ 4. Rain ☐ 5. Snow, freezing weather ☐ 6. Straight wind ☐ 7. Straight down ☐ 8. Tornado ☐ 9. Ashfall ☐ 10. Range fire
Y N B. Thermal ☐ 1. Burners burner/hot plates ☐ 2. Electrical equipment ☐ 3. Furnaces/boilers/heater ☐ 4. Steam lines ☐ 5. Boilers/boilers/boilers ☐ 6. Radiative decay heat ☐ 7. Radiative decay heat ☐ 8. Exposed components ☐ 9. Power tools ☐ 10. Convective ☐ 11. Solar ☐ 12. Cryogenic ☐ 13. Other crane brakes & M&M	Y N G. Mass Gravity, Height ☐ 1. Human effort ☐ 2. Stairs ☐ 3. Ladders and cranes ☐ 4. Ladders and ladders ☐ 5. Trucks ☐ 6. Slings ☐ 7. Hoists ☐ 8. Elevators ☐ 9. Jacks ☐ 10. Scaffold and ladders ☐ 11. Pits and excavations ☐ 12. Elevated doors ☐ 13. Vessels ☐ 14. Other <u> </u>	Y N L. Flammable Materials ☐ 1. Packing materials ☐ 2. Rags ☐ 3. Gasoline ☐ 4. Lubricant ☐ 5. Coolant oil ☐ 6. Paint solvent ☐ 7. Diesel fuel ☐ 8. Buildings & contents (w/ent enclosure) ☐ 9. Ashfall ☐ 10. Range fire	Y N O. Vehicles in Motion (external to facility) ☐ 1. Airplane ☐ 2. Helicopter ☐ 3. Train ☐ 4. Truck/bus/car ☐ 5. Other <u> </u>	Y N P. External Events ☐ 1. Explosion ☐ 2. Fire ☐ 3. Other sites <u> </u>	Y N Q. Vehicles in Motion (external to facility) ☐ 1. Airplane ☐ 2. Helicopter ☐ 3. Train ☐ 4. Truck/bus/car ☐ 5. Other <u> </u>	Y N R. Natural Phenomena ☐ 1. Earthquake ☐ 2. Flood ☐ 3. Lightning ☐ 4. Rain ☐ 5. Snow, freezing weather ☐ 6. Straight wind ☐ 7. Straight down ☐ 8. Tornado ☐ 9. Ashfall ☐ 10. Range fire	Y N S. Corrosives ☐ 1. Acids ☐ 2. Bases ☐ 3. Chemicals ☐ 4. Decontamination solution ☐ 5. High temperature waste ☐ 6. Other <u> </u>

Figure 3-4. Hazardous Material/Energy Source Checklist: Operating Area.

Location: CSB Operating Area

Y N A. Electrical ☐ 1. Battery banks (service carts and M-HM) ☐ 2. Cable runs ☐ 3. Cable retraction ☐ 4. Electrical equipment ☐ 5. HVAC heaters ☐ 6. High voltage ☐ 7. Motors ☐ 8. Pumps ☐ 9. Power tools ☐ 10. Switchgear (M-HM) ☐ 11. Service outlets, fittings ☐ 12. Transformers (M-HM) ☐ 13. Transmission lines ☐ 14. Underground wires ☐ 15. Wiring ☐ 16. Other lights, CAMs, detectors	Y N E. Kinetic - Rotational ☐ 1. Centrifuges ☐ 2. Motors ☐ 3. Pumps ☐ 4. Ceiling tower fans ☐ 5. Laundry equipment ☐ 6. Shop equipment ☐ 7. Other M-HM turret	Y N F. Kinetic - Linear ☐ 1. Cars, trucks, buses ☐ 2. Forklifts, dollies, carts ☐ 3. Railroad ☐ 4. Obstructions (floor embeds) ☐ 5. Crane loads ☐ 6. Pressure vessel blowdown ☐ 7. Other M-HM movement	Y N G. Mass Gravity Height ☐ 1. Human effort ☐ 2. Stairs ☐ 3. Lifts and cranes ☐ 4. Ladders and ladders ☐ 5. Trucks ☐ 6. Slings (to remove tube plug embed covers) ☐ 7. Hoists ☐ 8. Elevators ☐ 9. Jacks ☐ 10. Scaffold and ladders ☐ 11. Pits and excavations ☐ 12. Elevated doors ☐ 13. Vessels ☐ 14. Other dropped tube plugs, impact absorbers, etc.	Y N B. Thermal ☐ 1. Burners burner/heat plates ☐ 2. Electrical equipment ☐ 3. Furnace/boilers/heater (space lines) ☐ 4. Steam lines ☐ 5. Welding torches ☐ 6. Radiative heat exchanger line ☐ 7. Radiative decay heat ☐ 8. Exposed components (not areas on cart) ☐ 9. Power tools ☐ 10. Convective ☐ 11. Solar ☐ 12. Cryogenic ☐ 13. Other operating deck floor	Y N C. Friction ☐ 1. Belts ☐ 2. Bearings ☐ 3. Fans ☐ 4. Gears ☐ 5. Motors ☐ 6. Power tools ☐ 7. Other brakes on M-HM and tube cart	Y N D. Corrosives ☐ 1. Acids ☐ 2. Caustics ☐ 3. Natural chemicals ☐ 4. Decontamination solution ☐ 5. High temperature waste ☐ 6. Other	Y N J. Exothermic Reactions ☐ 1. Caves ☐ 2. Primer cord ☐ 3. Dynamite ☐ 4. Scrub chemicals ☐ 5. Dusts ☐ 6. Hydrogen ☐ 7. Gases, others ☐ 8. Nitrates ☐ 9. Peroxides ☐ 10. Pu and U metal ☐ 11. Sodium ☐ 12. Other	Y N K. Nuclear Criticality ☐ 1. Vaults ☐ 2. Temporary storage areas ☐ 3. Shipping and receiving area ☐ 4. Filters (air and tube plug)	Y N L. Flammable Materials ☐ 1. Packing materials ☐ 2. Rags ☐ 3. Gasoline ☐ 4. Lub oil ☐ 5. Coolant oil ☐ 6. Melt solvent ☐ 7. Diesel fuel ☐ 8. Bulky liquids and contents ☐ 9. Trailers and contents ☐ 10. Greases ☐ 11. Hydrogen ☐ 12. Nitric acid ☐ 13. Organics (M-HM neutron absorber, DOP) ☐ 14. Gases - others ☐ 15. Liquids - others (hydraulic fluid for tube cart plug cover hoist) ☐ 16. Other	Y N M. Hazardous Materials ☐ 1. Alkali metals ☐ 2. Asphyxiants ☐ 3. Biologicals ☐ 4. Carcinogens ☐ 5. Corrosives ☐ 6. Oxidizers ☐ 7. Toxics ☐ 8. Heavy metals (lead from batteries) ☐ 9. Other	Y N N. Ionizing Radiation Sources ☐ 1. Fissile material ☐ 2. Radiography equipment ☐ 3. Radioactive material ☐ 4. Radioactive sources ☐ 5. Other	Y N P. External Events ☐ 1. Explosion ☐ 2. Fire ☐ 3. Other sites	Y N Q. Vehicles in Motion (external to facility) ☐ 1. Airplane ☐ 2. Helicopter ☐ 3. Train ☐ 4. Truck/bus/car ☐ 5. Other	Y N R. Natural Phenomena ☐ 1. Earthquake ☐ 2. Flood ☐ 3. Lightning ☐ 4. Rain ☐ 5. Snow, freezing weather ☐ 6. Straight wind ☐ 7. Dust devil ☐ 8. Tornado ☐ 9. Ashfall ☐ 10. Range fire
--	--	---	---	---	---	---	--	--	--	---	---	---	--	---

Figure 3-5. Hazardous Material/Energy Source Checklist: Vault.

Location: Vault (includes intake structure and exhaust stack)

Y N A. Electrical	Y N E. Kinetic - Rotational	Y N J. Exothermic Reactions	Y N M. Hazardous Materials
☐ 1. Battery banks	☐ 1. Conduits	☐ 1. Cages	☐ 1. Alkali metals
☐ 2. Cable runs	☐ 2. Motors	☐ 2. Primer cord	☐ 2. Asphyxiants
☐ 3. Diesel generators	☐ 3. Pumps	☐ 3. Dynamite	☐ 3. Biologicals
☐ 4. Diesel equipment	☐ 4. Cooling tower fans	☐ 4. Scrub chemicals	☐ 4. Carcinogens
☐ 5. HVAC heaters	☐ 5. Laundry equipment	☐ 5. Dusts	☐ 5. Corrosives
☐ 6. High voltage	☐ 6. Shop equipment	☐ 6. Hydrogen	☐ 6. Oxidizers
☐ 7. Motors	☐ 7. Other _____	☐ 7. Gases, others	☐ 7. Toxics (Pu and U)
☐ 8. Pumps		☐ 8. Nitrates	☐ 8. Heavy metals
☐ 9. Power tools	Y N F. Kinetic - Linear	☐ 9. Peroxides	☐ 9. Other _____
☐ 10. Switchgear	☐ 1. Cars, trucks, buses	☐ 10. Pu and U metal	
☐ 11. Service outlets, fittings	☐ 2. Forklifts, dollies, carts	☐ 11. Sodium	Y N N. Ionizing Radiation Sources
☐ 12. Transformers	☐ 3. Railroad	☐ 12. Other _____	☐ 1. Fissile material
☐ 13. Transmission lines	☐ 4. Obstructions		☐ 2. Radiography equipment
☐ 14. Underground wires	☐ 5. Crane loads	Y N K. Nuclear Criticality	☐ 3. Radioactive material
☐ 15. Wiring	☐ 6. Pressure vessel blowdown	☐ 1. Vaults	☐ 4. Radioactive sources
☐ 16. Other _____	☐ 7. Other _____	☐ 2. Shipping and receiving area	☐ 5. Other (MCO radiation)
Y N B. Thermal	Y N G. Mass, Gravity, Height	☐ 3. Shipping and receiving area	Y N P. External Events
☐ 1. Burners burner/hot plates	☐ 1. Human effort	☐ 4. Filters	☐ 1. Explosion
☐ 2. Electrical equipment	☐ 2. Stairs	☐ 5. Casks	☐ 2. Fire
☐ 3. Furnaces/boilers/heater	☐ 3. Lifts and cranes	☐ 6. Burial ground	☐ 3. Other sites (underground fire water pipes)
☐ 4. Steam lines	☐ 4. Bucket and ladder	☐ 7. Storage racks	
☐ 5. Welding torch/larc	☐ 5. Trucks	☐ 8. Canals and basins	Y N Q. Vehicles in Motion (external to facility)
☐ 6. Diesel unit/air box/exhaust line	☐ 6. Slings	☐ 9. Tanks, slurry solution	☐ 1. Airplane
☐ 7. Radiative decay heat	☐ 7. Hoists	☐ 10. Trucks, forklifts, dollies	☐ 2. Helicopter
☐ 8. Exposed components	☐ 8. Elevators	☐ 11. Hand carry	☐ 3. Train
☐ 9. Power tools	☐ 9. Jacks	☐ 12. Conneffits	☐ 4. Truck/bus/car
☐ 10. Convector	☐ 10. Scaffold and ladders	☐ 13. Hot calls, assembly inspection	☐ 5. Other _____
☐ 11. Solar	☐ 11. Pits and excavations (intake structures)	☐ 14. Laboratories	
☐ 12. Cryogenic	☐ 12. Elevated doors	☐ 15. Other _____	Y N R. Natural Phenomena
☐ 13. Other _____	☐ 13. Vessels		☐ 1. Earthquake
Y N C. Friction	☐ 14. Other _____	Y N L. Flammable Materials	☐ 2. Flood
☐ 1. Belts		☐ 1. Packing materials	☐ 3. Lightning
☐ 2. Bearings	Y N H. Pressure - Volume	☐ 2. Rags	☐ 4. Rain
☐ 3. Fans	☐ 1. Boilers	☐ 3. Gasoline	☐ 5. Snow, freezing weather
☐ 4. Gears	☐ 2. Surge tanks	☐ 4. Lube oil	☐ 6. Straight wind
☐ 5. Motors	☐ 3. Autoclave	☐ 5. Coolant oil	☐ 7. Dust devil
☐ 6. Power tools	☐ 4. Test loops	☐ 6. Paint solvent	☐ 8. Tornado
☐ 7. Other _____	☐ 5. Gas bottles	☐ 7. Diesel fuel	☐ 9. Astral
Y N D. Corrosives	☐ 6. Pressure vessels	☐ 8. Buildings & contents	☐ 10. Range fire
☐ 1. Acids	☐ 7. Stressed members	☐ 9. Grease	
☐ 2. Caustics	☐ 8. Gas receivers	☐ 10. Hydrogen	
☐ 3. Natural chemicals	☐ 9. Negative pressure collapse	☐ 11. Nitric acid	
☐ 4. Decontamination solution	☐ 10. Steam headers and lines	☐ 12. Organic	
☐ 5. High temperature waste	☐ 11. Other _____	☐ 13. Liquids - others	
☐ 6. Other _____		☐ 14. Liquids - others	
		☐ 15. Other _____	
		☐ 16. Other _____	

Figure 3-6. Hazardous Material/Energy Source Checklist: Support Building.

Location: *Support Building*

Y N A. Electrical ☐ 1. Battery banks (UPS) ☐ 2. Cable runs ☐ 3. Diesel generators ☐ 4. Electrical equipment ☐ 5. HVAC heaters ☐ 6. High voltage (440 volt switch gear) ☐ 7. Motors ☐ 8. Pumps ☐ 9. Power tools ☐ 10. Switchgear ☐ 11. Service outlets, fittings ☐ 12. Transformers ☐ 13. Transmission lines ☐ 14. Underground wires ☐ 15. Wiring ☐ 16. Other (AC inverters)	Y N E. Kinetic - Rotational ☐ 1. Centrifuges ☐ 2. Minors ☐ 3. Dynamite ☐ 4. Cooling tower fans ☐ 5. Laundry equipment ☐ 6. Shop equipment ☐ 7. Other _____ Y N F. Kinetic - Linear ☐ 1. Cars, trucks, buses ☐ 2. Forklifts, dollies, carts ☐ 3. Railroad ☐ 4. Obstructions ☐ 5. Crane loads ☐ 6. Pressure vessel blowdown (compressors) ☐ 7. Other _____	Y N J. Exothermic Reactions ☐ 1. Caps ☐ 2. Primer cord ☐ 3. Dynamite ☐ 4. Scub chemicals ☐ 5. Dusts ☐ 6. Hydrogen ☐ 7. Gases, others ☐ 8. Nitrates ☐ 9. Peroxides ☐ 10. Pu and U ☐ 11. Sodium ☐ 12. Other _____ Y N K. Nuclear Criticality ☐ 1. Vents ☐ 2. Temporary storage areas ☐ 3. Shipping and receiving area ☐ 4. Filters ☐ 5. Casks ☐ 6. Burial ground ☐ 7. Storage racks ☐ 8. Canals and basins ☐ 9. Decontamination solution ☐ 10. Trucks, forklifts, dollies ☐ 11. Hand carry ☐ 12. Cranes/lifts ☐ 13. Hot cells, assembly, inspection ☐ 14. Laboratories ☐ 15. Other _____	Y N M. Hazardous Materials ☐ 1. Alkali metals ☐ 2. Asphyxiants (diesel exhaust) ☐ 3. Biologicals ☐ 4. Carcinogens ☐ 5. Corrosives ☐ 6. Oxidizers ☐ 7. Toxics ☐ 8. Heavy metals (lead from batteries) ☐ 9. Other _____ Y N N. Ionizing Radiation Sources ☐ 1. Radioactive material ☐ 2. Radiography equipment ☐ 3. Radioactive material (HVAC filters) ☐ 4. Radioactive sources (instrument calibration source) ☐ 5. Other _____ Y N P. External Events ☐ 1. Explosion ☐ 2. Fire ☐ 3. Other sites Y N Q. Vehicles in Motion (external to facility) ☐ 1. Airplane ☐ 2. Helicopter ☐ 3. Train ☐ 4. Truck/bus/car ☐ 5. Other _____ Y N R. Natural Phenomena ☐ 1. Earthquake ☐ 2. Flood ☐ 3. Lightning ☐ 4. Rain ☐ 5. Snow, freezing weather ☐ 6. Straight wind ☐ 7. Dust devil ☐ 8. Tornado ☐ 9. Ashfall ☐ 10. Range fire
Y N B. Thermal ☐ 1. Burner/boiler ☐ 2. Electrical equipment ☐ 3. Furnaces/pot/heat ☐ 4. Steam lines ☐ 5. Welding torch/arc ☐ 6. Diesel unit/fine box/exhaust line ☐ 7. Radioactive decay heat ☐ 8. Exposed components ☐ 9. Power tools ☐ 10. Convective ☐ 11. Solar ☐ 12. Cryogenic ☐ 13. Other (soldering in shop)	Y N L. Flammable Materials ☐ 1. Packing materials ☐ 2. Rags ☐ 3. Gasoline ☐ 4. Grease ☐ 5. Coconut oil ☐ 6. Paint solvent ☐ 7. Diesel fuel (generators) ☐ 8. Buildings & contents (HVAC filter fire) ☐ 9. Trailers and contents ☐ 10. Grease ☐ 11. Hydrogen ☐ 12. Nitric acid ☐ 13. Organics ☐ 14. Gases - others ☐ 15. Liquids - others ☐ 16. Other (solvents)	Y N C. Friction ☐ 1. Belts (compressors) ☐ 2. Bearings ☐ 3. Fans ☐ 4. Gears ☐ 5. Motors ☐ 6. Power tools ☐ 7. Other _____ Y N D. Corrosives ☐ 1. Acids ☐ 2. Caustics ☐ 3. Natural chemicals ☐ 4. Decontamination solution ☐ 5. High temperature waste ☐ 6. Other _____	

Figure 3-7. Hazardous Material/Energy Source Checklist: Outside.

Location: *Outside*

Y N A. Electrical ☐ 1. Battery banks ☐ 2. Cable runs ☐ 3. Diesel generators ☐ 4. Electrical equipment ☐ 5. HVAC heaters ☐ 6. High voltage ☐ 7. Motors ☐ 8. Pumps ☐ 9. Power tools ☐ 10. Switchgear ☐ 11. Transformers, fittings ☐ 12. Transformers ☐ 13. Transmission lines ☐ 14. Underground wires ☐ 15. Wiring ☐ 16. Other (lighting)	Y N E. Kinetic - Rotational ☐ 1. Centrifuges ☐ 2. Motors ☐ 3. Pumps ☐ 4. Cooling tower fans ☐ 5. Laundry equipment ☐ 6. Shop equipment ☐ 7. Other (CIVAC units)	Y N F. Kinetic - Linear ☐ 1. Cars, trucks, buses ☐ 2. Forklifts, dollies, carts ☐ 3. Railroad ☐ 4. Obstructions ☐ 5. Crane loads ☐ 6. Pressure vessel blowdown ☐ 7. Other	Y N G. Mass, Gravity, Height ☐ 1. Human effort ☐ 2. Stairs (stack) ☐ 3. Lifts and cranes ☐ 4. Buckets and ladder ☐ 5. Trucks ☐ 6. Slings ☐ 7. Hoists ☐ 8. Elevators ☐ 9. Jacks ☐ 10. Scaffold and ladders ☐ 11. Photo elevators (in/side structures) ☐ 12. Elevated doors ☐ 13. Vessels ☐ 14. Other	Y N H. Pressure - Volume ☐ 1. Boilers ☐ 2. Surge tanks ☐ 3. Autoclave ☐ 4. Gears ☐ 5. Test loops ☐ 6. Gas bottles ☐ 7. Stressed members ☐ 8. Gas receivers ☐ 9. Negative pressure collapse ☐ 10. Steam headers and lines ☐ 11. Other	Y N D. Corrosives ☐ 1. Acids (vehicle batteries) ☐ 2. Caustics ☐ 3. Natural chemicals ☐ 4. Decontamination solution ☐ 5. High temperature waste ☐ 6. Other	Y N J. Exothermic Reactions ☐ 1. Caps ☐ 2. Primer cord ☐ 3. Dynamite ☐ 4. Solid chemicals ☐ 5. Sulfur ☐ 6. Hydrogen ☐ 7. Gases ☐ 8. Nitrites ☐ 9. Peroxides ☐ 10. Pu and U metal ☐ 11. Sodium ☐ 12. Other	Y N K. Nuclear Criticality ☐ 1. Vaults ☐ 2. Temporary storage areas ☐ 3. Shipping and receiving area ☐ 4. Filters ☐ 5. Casks ☐ 6. Burial ground ☐ 7. Storage racks ☐ 8. Canals and basins ☐ 9. Decontamination solution ☐ 10. Trucks, forklifts, dollies ☐ 11. Hand carry ☐ 12. Cranes/lifts ☐ 13. Fuel cells, assembly, inspection ☐ 14. Laboratories ☐ 15. Other	Y N L. Flammable Materials ☐ 1. Packing materials (dumppster) ☐ 2. Rags ☐ 3. Gasoline ☐ 4. Lube oil ☐ 5. Coolant oil (transformers) ☐ 6. Paint solvent ☐ 7. Diesel fuel ☐ 8. Buildings & contents ☐ 9. Trailers and contents ☐ 10. Grease ☐ 11. Hydrogen ☐ 12. Nitric acid ☐ 13. Organics ☐ 14. Gases - others ☐ 15. Liquids - others ☐ 16. Other	Y N M. Hazardous Materials ☐ 1. Alkali metals ☐ 2. Polyphosphates (diesel exhaust) ☐ 3. Biocides (grasses, spiders) ☐ 4. Cyanides ☐ 5. Corrosives (battery acid) ☐ 6. Oxidizers ☐ 7. Toxics ☐ 8. Heavy metals (battery lead) ☐ 9. Other	Y N N. Ionizing Radiation Sources ☐ 1. Fissile material ☐ 2. Radiography equipment ☐ 3. Radioactive material ☐ 4. Radioactive sources ☐ 5. Other	Y N P. External Events ☐ 1. Explosion ☐ 2. Fire ☐ 3. Other sites	Y N Q. Vehicles in Motion (external to facility) ☐ 1. Airplane ☐ 2. Helicopter ☐ 3. Train ☐ 4. Tractor ☐ 5. Other	Y N R. Natural Phenomena ☐ 1. Earthquake ☐ 2. Flood ☐ 3. Lightning ☐ 4. Rain ☐ 5. Snow, freezing weather ☐ 6. Straight wind ☐ 7. Dust devil ☐ 8. Tornado ☐ 9. Ashfall ☐ 10. Range fire
--	--	--	--	---	---	--	---	--	--	---	---	--	---

This page intentionally left blank.

Table 3-1. Standard Industrial Hazards: Truck Vestibule.

Hazard category	Hazard type	Checklist designator
Electrical	Vehicle batteries	TV A 1
	Crane cabling	TV A 2
	Crane motor	TV A 7
	Power tools	TV A 9
	Service outlets, fittings	TV A 11
	Wiring	TV A 15
Thermal	Diesel units/exhaust lines on vehicles	TV B 6
	Radioactive decay heat from fuel within MCO	TV B 7
	Convective heat from transportation cask	TV B 10
	Vehicle brakes	TV B 13
Friction	Belts	TV C 1
	Bearings	TV C 2
	Fans	TV C 3
	Gears	TV C 4
	Motors	TV C 5
	Power tools (no cutting tools)	TV C 6
Corrosives	Vehicle battery acid	TV D 1
Kinetic - rotational	Crane motor	TV E 2
Mass, gravity, height	Human effort (dropped items)	TV G 1
	Lifts and cranes	TV G 3
	Slings	TV G 6
	Hoists	TV G 7
	Scaffold and ladders (receiving crane maintenance)	TV G 10
	Elevated doors	TV G 12
Pressure - volume	Stressed members (cask tiedowns)	TV H 7
Flammable materials	Lube oil	TV L 4
	Diesel fuel	TV L 7
	Grease	TV L 10
	Other (hydraulic fluid)	TV L 16
Hazardous materials	Asphyxiants	TV M 2
	Carcinogens	TV M 4
	Corrosives (battery acid)	TV M 5
	Heavy metals (battery lead)	TV M 8

MCO = multicarrier overpack.

Table 3-2. Standard Industrial Hazards: Service Area.

Hazard category	Hazard type	Checklist designator
Electrical	Cable runs (crane cabling)	SA A 2
	Motors (hoist)	SA A 7
	Power tools	SA A 9
	Switchgear	SA A 10
	Service outlets, fittings	SA A 11
	Wiring	SA A 15
	Other (blowers)	SA A 16
Thermal	Power tools (no cutting tools)	SA B 9
	Other (crane and MHM brakes)	SA B 13
Friction	Bearings	SA C 2
	Fans	SA C 3
	Gears	SA C 4
	Motors	SA C 5
	Power tools (no cutting tools)	SA C 6
	Other (crane and MHM brakes)	SA C 7
Kinetic - rotational	Motors	SA E 2
	Exposed parts on rotating MHM turret	SA E 7
Kinetic - linear	MHM gas bottle blowdown (missile and whipping hazard)	SA F 6
Mass, gravity, height	Hoists	SA G 7
	Scaffolds and ladders	SA G 10
	Pits and excavations	SA G 11
	Elevated doors	SA G 12
Pressure - volume	Other (pressurized inert gas line)	SA H 11
Hazardous materials	Asphyxiants	SA M 2

MHM = multicanister overpack handling machine.

Table 3-3. Standard Industrial Hazards: Operating Area. (2 sheets)

Hazard category	Hazard type	Checklist designator
Electrical	Battery banks (service carts)	OA A 1
	Cable runs	OA A 2
	High voltage	OA A 6
	Motors	OA A 7
	Pumps	OA A 8
	Switchgear (MHM)	OA A 10
	Service outlets, fittings	OA A 11
	Transformers (MHM)	OA A 12
	Wiring	OA A 15
	Other (lighting, CAMs, detectors)	OA A 16
Thermal	Furnaces/boilers/heater (cart sample line)	OA B 3
	Exposed components (exposed area on cart)	OA B 8
	Convective	OA B 10
	Cryogenic	OA B 12
	Other (operating deck)	OA B 13
Friction	Bearings	OA C 2
	Fans	OA C 3
	Gears	OA C 4
	Motors	OA C 5
	Other (brakes on the MHM and tube cart)	OA C 7
Kinetic - rotational	Motors	OA E 2
	Pumps	OA E 3
Kinetic - linear	Obstruction (removed floor embeds)	OA F 4
	Crane loads	OA F 5
	MHM and service cart gas bottle blowdown (missile and whipping hazards)	OA F 6
Mass, gravity, height	Lifts and cranes	OA G 3
	Slings (to remove tube plug cover)	OA G 6
	Hoists	OA G 7
	Scaffold and ladders	OA G 10
	Pits and excavations	OA G 11

Table 3-3. Standard Industrial Hazards: Operating Area. (2 sheets)

Hazard category	Hazard type	Checklist designator		
Pressure - volume	Gas bottles on service cart and MHM (missile and whipping hazard)	OA	H	5
	Gas receivers	OA	H	8
Hazardous materials	Asphyxiants	OA	M	2
	Heavy metals (battery lead)	OA	M	8

CAM = continuous air monitor.

MHM = multicarrier overpack handling machine.

Table 3-4. Standard Industrial Hazards: Vault.

Hazard category	Hazard type	Checklist designator		
Thermal	Exposed components	VL	B	8
Mass, gravity, height	Pits and excavations	VL	G	11

Table 3-5. Standard Industrial Hazards: Support Building.

Hazard category	Hazard type	Checklist designator
Electrical	Battery banks (uninterruptible power supply)	SB A 1
	Cable runs	SB A 2
	Diesel generators	SB A 3
	Electrical equipment	SB A 4
	Heating, ventilating, and air conditioning heaters	SB A 5
	High voltage	SB A 6
	Motors	SB A 7
	Pumps	SB A 8
	Switchgear	SB A 10
	Service outlets, fittings	SB A 11
	Transformers	SB A 12
	Wiring	SB A 15
	Other (AC invertors)	SB A 16
Thermal	Electrical equipment	SB B 2
	Furnaces/boilers/heater	SB B 3
	Diesel units/fire box/exhaust line	SB B 6
	Convective	SB B 10
	Other (soldering in shop)	SB B 13
Friction	Belts (compressors)	SB C 1
	Bearings	SB C 2
	Fans	SB C 3
	Gears	SB C 4
	Motors	SB C 5
Corrosives	Acids (sealed batteries)	SB D 1
Kinetic - rotational	Motors	SB E 2
	Pumps	SB E 3
Kinetic - linear	Forklifts, dollies, carts (service carts)	SB F 2
	Obstructions	SB F 4
	Pressure vessel blowdown (air compressors)	SB F 6
Mass, gravity, height	Elevated doors	SB G 12
Pressure - volume	Gas receivers (air)	SB H 8
	Other (high pressure inert gas line)	SB H 11
Hazardous materials	Asphyxiants (diesel exhaust)	SB M 2
	Carcinogens	SB M 4
	Heavy metals (battery lead)	SB M 8
Ionizing radiation sources	Radioactive sources (instrument calibration sources)	SB N 4

Table 3-6. Standard Industrial Hazards: Outside.

Hazard category	Hazard type	Checklist designator		
Electrical	Electrical equipment	OU	A	4
	High voltage	OU	A	6
	Motors	OU	A	7
	Pumps	OU	A	8
	Switchgear	OU	A	10
	Service outlets, fittings	OU	A	11
	Transformers	OU	A	12
	Transmission lines	OU	A	13
	Underground wires	OU	A	14
	Wiring	OU	A	15
	Other (lighting)	OU	A	16
Thermal	Electrical equipment	OU	B	2
	Diesel units/fire box/exhaust line	OU	B	6
	Exposed components	OU	B	8
	Convective	OU	B	10
	Solar	OU	B	11
Friction	Bearings	OU	C	2
	Fans	OU	C	3
	Gears	OU	C	4
	Motors	OU	C	5
Corrosives	Vehicle batteries	OU	D	1
	Natural chemicals	OU	D	3
Kinetic - rotational	Motors	OU	E	2
	Pumps	OU	E	3
	Other (heating, ventilating, and air conditioning units)	OU	E	7
Mass, gravity, height	Stairs (stack)	OU	G	2
	Pits and excavations (air intake structures)	OU	G	11
Flammable materials	Packing materials (dumpster)	OU	L	1
	Gasoline	OU	L	3
	Lube oil	OU	L	4
	Coolant oil (transformers)	OU	L	5
Hazardous materials	Asphyxiants (diesel exhaust)	OU	M	2
	Biologicals (snakes, spiders)	OU	M	3
	Corrosives (battery acid)	OU	M	5
	Heavy metals (battery lead)	OU	M	8

Table 3-7. Canister Storage Building Material at Risk (Type, Form, and Quantity).

Field name or location	MAR - subject	MAR - description	MAR - classification	Capacity	Material type	Physical form	Volume or activity	Transient	Quantity	Comments
Truck vestibule	MCO in cask	SNF and particulate matter in MCO	SNF in MCO	1,000 L per MCO, one loaded scarp basket and four loaded fuel baskets MCO estimated to contain 300 kg of particulate matter after cold vacuum dry and shipping to CSB (upper bound)	Mark IV spent fuel from N Reactor (upper bound)	Solid consisting of fuel and particulate corrosion products	6.90 MTU at 3.84 E+04 CM/TU (see Table 3-6)	Yes, particulate is transient	Upper bound mass is 6.90 tonnes uranium per MCO	
Service area	Truck fuel tank	Diesel fuel	Diesel fuel	40 gal	NA	Liquid	Up to 40 gal	Yes	One tank	
	MCO lifted from cask	SNF and particulate matter in MCO	Finely divided SNF, clumps of fuel possible if MCO is sheared	MCO estimated to contain 300 kg of particulate matter after cold vacuum dry and shipping to CSB (upper bound)	NA	Solid	0.3 MTU at 3.84 E+04 CM/TU	Yes, particulate is transient	0.3 MTU per MCO	
Operating area	MHM loading MCO into vault	SNF and particulate matter in MCO	Finely divided SNF, clumps of fuel possible if MCO is sheared	One loaded scarp basket and four loaded fuel baskets MCO estimated to contain 300 kg of particulate matter after cold vacuum dry and shipping to CSB and after hot conditioning (upper bound)	Mark IV spent fuel from N Reactor (upper bound)	Solid consisting of fuel and particulate corrosion products	6.90 MTU at 3.84 E+04 CM/TU (see Table 3-6)	Yes, particulate is transient	6.90 tonnes uranium per MCO including 0.6 tonnes particulate per MCO	
	Contents of a loaded vault tube	SNF and particulate matter in two MCOs	NA	Two MCOs each loaded with one scarp basket and four fuel baskets	Mark IV spent fuel from N Reactor (upper bound)	Solid consisting of fuel and particulate corrosion products	13.8 MTU at 3.84 E+04 CM/TU	Yes, particulate is transient	13.8 tonnes uranium including 0.6 tonnes particulate per MCO	
Vault	Contents of all loaded MCOs in vault 1	SNF and particulate matter in MCOs	NA	220 storage tubes each loaded with two MCOs	Various types of SNF from N Reactor	Solid consisting of fuel and particulate corrosion products	[0.96 MTU per MCO (TBD) x 440 MCO] as avg CM/TU (TBD)	Yes, particulate is transient	TBD tonnes uranium including 132 tonnes maximum particulate	
Support building	Particulate on HVAC filters	Finely divided radioactive particulate from MCOs	Radioactive particulate matter	Unknown	NA	Solid	Unknown	Yes, particulate is transient	Unknown	
	Fuel for emergency generators	Diesel fuel in two day tanks	Diesel fuel	Two 50-gal diesel storage tanks	NA	Liquid	100 gal	Yes	100 gal	
Outside area	Fuel for emergency generators	Diesel fuel in two above-ground tanks	Diesel fuel	Two 500-gal diesel storage tanks	NA	Liquid	Up to 1,000 gal	Yes	Two tanks at 500 gal per tank	Overflow protection is provided
	Fuel delivery truck	Diesel fuel delivered to emergency generator tanks	Diesel fuel	One tanker truck	NA	Liquid	Delivers fuel to two 500-gal above-ground fuel tanks	Yes	TBD	Standard fuel hose and dispenser nozzle is used
	Inert gas storage	Helium used to inert MCOs, storage tubes, and MHM	Helium	Two identical 3,400 m ³ storage tubes on trailer	NA	Gas	NA	Yes	Two identical 3,400 m ³ storage tanks on trailer	

MTU = metric tons of uranium
 NA = not applicable
 SNF = spent nuclear fuel
 TBD = to be determined

CSB = Canister Storage Building
 HVAC = heating, ventilation, and air conditioning (filter)
 MAR = material at risk
 MCO = multicanister overpack
 MHM = multicanister overpack handling structure

Table 3-8. Canister Storage Building Operations Hazardous Energy Source Characterization — Location in Facility: Truck Vestibule. (sheet 1 of 4)

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Linear kinetic - loaded transporter truck collides with personnel or equipment	TV-F-1	- Truck speed = TBD - Truck mass = 47 tonne	
Linear kinetic - receiving crane with yoke and loaded cask collides with object	TV-F-5	- Maximum gantry speed = 12 m/min (40 ft/min) - Maximum trolley speed = 12 m/min (40 ft/min) - Crane lifting capacity = 54 tonne (60 ton) - Crane load: - Mass of loaded cask = 27 tonne (30 ton) - Mass of cask lifting beam = 340 kg	The gantry and trolley creep speeds are 1 ft/min per Design Basis Document, Rev. 1, Section 8.7.1
Mass, gravity, height - cask on transporter falls off	TV-G-5 and TV-G-13	- Mass of loaded cask = 27 tonne - Distance to floor = 1 m (3.3 ft)	
Mass, gravity, height - cask is dropped	TV-G-13	- Mass of loaded cask = 27 tonne - Maximum lift height off floor = TBD - Receiving crane lifting capacity = 54 tonne (60 ton)	
Pressure, volume - MCO relieves pressure, releases gases into cask	TV-H-6	- Loaded cask free space volume = 325 L - Cask design pressure = 1.0 MPa gauge (150 lb/in² gauge) - MCO relief pressure: - Valve = 830 kPa differential (120 lb/in² differential) - Rupture disk = 1.0 MPa differential (150 lb/in² differential) - MCO design pressure = 1.0 MPa gauge (150 lb/in² gauge) - Cask pressure = 71 kPa gauge (10 lb/in² gauge) after release from valve - Initial helium pressure in cask = 21 kPa gauge (3 lb/in² gauge) at 25 °C (77 °F) - Cask pressure = 635 kPa gauge (92 lb/in² gauge) after release from rupture disk	Valve is primary pressure relief device; rupture disk is backup relief device. Valve reset pressure is assumed to be 10% of set pressure or 108 lb/in ² gauge.

Table 3-8. Canister Storage Building Operations Hazardous Energy Source
 Characterization — Location in Facility: Truck Vestibule. (sheet 2 of 4)

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Explosives or pyrophorics, flammable material- hydrogen released from cask-MCO mixed with air plus ignition source (cask seal leaks)	TV-J-6	U-H ₂ O reaction: • Maximum estimated water in MCO after cold vacuum drying is 10% of particulate matter (≈ 15 kg) • Reaction temperature ≈ 75 °C (167 °F) with a U surface area of 120,000 cm² • H₂ generation rate ≈ 0.3 moles/h • Valve relief pressure ≈ 830 kPa differential (120 lb/in² differential) • Valve reseal pressure ≈ 740 kPa differential (108 lb/in² differential) • Number of valve releases ≈ 50	
Explosives or pyrophorics - uranium, plutonium, or zirconium metal (metals exposed to air because of breached MCO and cask seal)	TV-J-10	• Contents of one scrap basket in an MCO is most vulnerable, 1,300 kg* • Scrap could burn first then ignite rest of MCO fuel, $\approx 5,000$ kg**	*A conservative estimate offered in WHC-SD-SNF-TI-023, Rev. 1, p. 12* **Based on 54 assemblies of 'E'-length MKIV fuel per basket x 4 baskets x 23.5 kg uranium per assembly
Nuclear criticality - cask	TV-K-5 TV-K-12	One MCO in cask with $\approx 6,800$ kg of spent nuclear fuel	
Flammable material - hydrogen	TV-L-11	---	Refer to "Explosives or pyrophorics - hydrogen" for an evaluation of this hazard
Hazardous material: toxics - for example, plutonium, uranium, strontium, beryllium	TV-M-7	See release by pyrophorics	
Ionizing radiation - MCO contents	TV-N-1 TV-N-3	• Cask shielding ≈ 20 cm (7.7 in.) of steel • Operational limit for contact dose is < 100 mrem/h • Estimated dose rate at 2 m is < 10 mrem/h; 2 mrem/h in the tractor cab	
Ionization radiation - surface contamination through loss of contamination control	TV-N-3	Unknown	
External events - explosion outside the truck vestibule, (e.g., propane delivery truck)	TV-P-1	See "External events" under Service Area	

Table 3-8. Canister Storage Building Operations Hazardous Energy Source
Characterization — Location in Facility: Truck Vestibule. (sheet 3 of 4)

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
External events - fire, smoke, and heat limits accessibility and visibility	TV-P-2	Heat and smoke quantity unknown	Depends on material that burns and wind direction
External events - nearby facility (e.g., radioactive material, toxics, or direct radiation into facility)	TV-P-3	Unknown	Depends on facility accident and wind direction at time of accident
Kinetic linear - vehicle in motion impacts truck vestibule	TV-Q-4	Selected loaded cement truck at ≈ 48 km/h (30 mi/h) with a mass of ≈ 32 tonne (70,000 lb)	Ongoing construction at CSB brings cement truck into area.
Natural phenomena - earthquake	TV-R-1	Forces exerted on facility from lateral and horizontal accelerations: 0.35 g horizontal, 0.23 g vertical (see Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - lightning strikes truck vestibule	TV-R-3	Electrical discharge of millions of volts	Lightning protection shall be provided for facility as required by NFPA 780 ^c
Natural phenomena - rain intrusion	TV-R-4	Facility drainage designed for a 6-hour probable maximum precipitation of 23 cm (9.2 in.) (see Section 1.4.1.1.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - snow, freezing weather	TV-R-5	Roof designed for snow loading of 98 kg/m ² (20 lb/ft ²) (see Section 1.4.1.1.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - straight wind causes flying debris, wind pressure, and dust	TV-R-6	Facility designed for a wind speed of 129 km/h (80 mi/h), which is the design basis for the Hanford Site (see Section 1.4.1.1.4 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - dust devil creates dust and flying debris	TV-R-7	Unknown	Cleanup of dust and debris would be needed
Natural phenomena - tornado	TV-R-8	Facility designed to withstand tornado wind speeds of 322 km/h (200 mi/h) total, 258 km/h (160 mi/h) rotational, and 64.4 km/h (40 mi/h) translational (see Section 1.4.1.1.4 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	

Table 3-8. Canister Storage Building Operations Hazardous Energy Source Characterization — Location in Facility: Truck Vestibule. (sheet 4 of 4)

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Natural phenomena - volcanic ash/fall	TV-R-9	Facility designed to withstand a ground ash load of 117 kg/m ² (24 lb/ft ²) (see Section 1.4.3.8.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - range fire	TV-R-10	Vegetation control in an 18-m (60-ft) clear space around CSB shall be provided (see Section 1.3.1.1 of HNF-SD-SNF-RPT-004 ^b)	

^aPajunen, A. L., and R. G. Cowan, 1996, *Bounding Particulate Contents of Multi-Canister Overpack*, WHC-SD-SNF-TI-023, Rev. 1, Westinghouse Hanford Company, Richland, Washington.

^bGarvin, L. J., 1997, *Canister Storage Building Safety Analysis Report — Phase 3: Safety Analysis Documentation Supporting Canister Storage Building Construction*, HNF-SD-SNF-RPT-004, Rev. 7, Duke Engineering and Services Hanford for Fluor Daniel Hanford, Incorporated, Richland, Washington.

^cNFPA, 1995, *Lightning Protection Systems*, NFPA 780, National Fire Protection Association, Quincy, Massachusetts.

CSB = Canister Storage Building.

MCO = multicanister overpack.

TBD = to be determined.

Table 3-9. Canister Storage Building Operations Hazardous Energy Source
Characterization — Location in Facility: Service Area. (sheet 1 of 5)

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Rotational kinetic - MHM turret shears MCO	SA-E-7	Shearing plane is ≈ 1.5 m (5 ft) above floor level; shear force is TBD	
Linear kinetic - receiving crane with loaded cask collides with object	SA-F-5	- Maximum gantry speed ≈ 12 m/min (40 ft/min) - Maximum trolley speed ≈ 12 m/min (40 ft/min) - Loaded receiving crane mass ≈ 150 tonne - Crane lifting capacity ≈ 54 tonne (60 ton) - Mass of loaded cask ≈ 27 tonne - Mass of lifting beam ≈ 340 kg	Gantry and trolley creep speed is 1 ft/min according to the Design Basis Document, Rev. 1, Section 8.7.1*
Linear kinetic - pressure vessel, MCO blowdown from 1.0 MPa gauge (150 lb/in ² gauge) with gas impingement	SA-F-6	- MCO rupture disk diameter ≈ 2.5 cm (1.0 in.) - Maximum MCO blowdown rate ≈ 0.38 kg/sec (0.84 lbm/sec) - Impingement force ≈ 395 N	
Linear kinetic - MHM lateral movement results in collision with personnel or equipment	SA-F-7	- MHM gantry* bridge speed ≈ 12 m/min (40 ft/min) - Maximum MHM trolley* speed ≈ 12 m/min (40 ft/min) - MHM mass with plug and MCO ≈ 450 tonne**	*Gantry bridge and trolley creep speed is 30.5 cm/min (1 ft/min) according to the Design Basis Document, Rev. 1, Section 8.7.1* **See Section 4.3.4.4.1 of HNF-SD-SNF-RPT-004^b
Mass, gravity, height - human effort allows tools or other objects to be dropped	SA-G-1	Unknown	
Mass, gravity, height - human error allows small parts off 5-ton gantry crane to fall off into service pit	SA-G-1	Load cell on MHM grapple stops lift at 1,000 lb to prevent load damage	
Mass, gravity, height - - Transport cask is dropped by receiving crane - MCO is dropped by MHM during load-out from service pit	SA-G-3 SA-G-13	- Cask lift height above floor $\approx$ TBD - Mass of cask ≈ 27 tonne - MCO lift height above bottom of service pit $\approx$ TBD - Mass of MCO ≈ 8.6 tonne	
Pressure, volume - damaged gas bottles (backup inert gas supply on MHM) result in uncontrolled release of gas	SA-H-5	- Gas bottle pressure ≈ 17 MPa gauge (2,500 lb/in² gauge) - Gas bottle nozzle diameter $\approx$ TBD - Mass flow rate of gas $\approx$ TBD at sonic velocity - Resultant force $\approx$ TBD	

Table 3-9. Canister Storage Building Operations Hazardous Energy Source
 Characterization — Location in Facility: Service Area. (sheet 2 of 5)

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Pressure, volume - process delay results in release of gas from MCO into sealed cask*	SA-H-6	- Loaded cask free space volume $\approx$ 325 L - Cask design pressure $\approx$ 1.0 MPa gauge (150 lb/in² gauge) - MCO relief pressure: - Valve, 830 kPa differential (120 lb/in² differential) - Rupture disk, 1.0 MPa differential (150 lb/in² differential) - MCO design pressure $\approx$ 1.0 MPa gauge (150 lb/in² gauge) - Cask pressure $\approx$ 71 kPa gauge (10 lb/in² gauge) after release from valve - Cask pressure $\approx$ 635 kPa gauge (92 lb/in² gauge) after release from rupture disk	Valve is primary pressure relief device; rupture disk is backup relief device. Valve reseal pressure is assumed to be 10% of set pressure or 108 lb/in² gauge. <i>*See Calculations for Hydrogen Release and Combustion in the Service Tent Enclosure of the CSB, HNF-SD-SNF-CN-020.*</i>
Pressure, volume - uncontrolled release of inert gas supply for MHM inerting system	SA-H-8	- Festoon line pressure $\approx$ 120 lb/in² gauge - Festoon line size $\approx$ TBD - MCO service line pressure $\approx$ 550 kPa gauge (80 lb/in² gauge) - MCO service line size $\approx$ 5 cm (2 in.)	
Explosives or pyrophorics - in service pit, hydrogen release from MCO mixes with air then ignition source causes combustion*	SA-J-6	- MCO relief pressure: - Valve $\approx$ 830 kPa gauge (120 lb/in² gauge) - Valve reseal pressure $\approx$ 740 kPa gauge (110 lb/in² gauge) - H₂ release quantity from one valve release $\approx$ 14 gram-moles - Relief pressure of rupture disk $\approx$ 1.0 MPa differential (150 lb/in² differential) - Minimum flammability of H₂ in air $\approx$ 4% by volume - Maximum H₂ release quantity through rupture disk $\approx$ 210 gram-moles - After combustion, maximum gas temperature in service pit $\approx$ 1,800 °C (3,300 °F) and maximum pressure $\approx$ 1,380 Pa gauge (200 lb/in² gauge)**	<i>*See Calculations for Hydrogen Release and Combustion in the Service Pit of the CSB, HNF-SD-SNF-CN-024.*</i> **A pressure impulse of 1,380 kPa gauge (200 lb/in² gauge) acting on the underside of the shield hatch assembly on the service pit is great enough to lift it.
Explosives or pyrophorics - plutonium, uranium, and zirconium metal is exposed to air	SA-J-10	Minimum ignition temperature of plutonium, uranium, and zirconium: Fuel ignition tests in lab showed minimum ignition temperatures ranging from 329 °C to 473 °C (624 °F to 883 °F). See PNNL "Ignition Testing of As-Cut Conditioned SNF Samples," 10/16/96.*	Reaction rate is temperature and surface area dependent; these metals are more inclined to ignite in the finely divided state than in the massive state; contents of scrap basket are most vulnerable.

Table 3-9. Canister Storage Building Operations Hazardous Energy Source
 Characterization — Location in Facility: Service Area. (sheet 3 of 5)

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Nuclear criticality	SA-K-1 SA-K-4 SA-K-5 SA-K-12	---	Addressed in Chapter 6.0 of HNF-SD-SNF-RPT-004; ^b no new hazards were identified.
Flammable materials - building and contents (in tent enclosure, hydrogen and tent material; on MHM, neutron absorber)	SA-L-8, SA-L-11, and SA-L-13	See HNF-SD-SNF-FHA-002 ^f	These hazards are addressed by HNF-SD-SNF-FHA-002. ^f
Hazardous materials - toxic metals (e.g., plutonium, uranium, beryllium) entrained in pressurized gas release from MCO	SA-M-7	- Bounding range of particulate matter in MCO $\approx$ 150 to 300 kg (330 to 660 lb) - Unmitigated release fraction range from MCO blowdown, RF $\approx$ 10^{-4} to 10^{-3} - Range of particulate matter released: 15 to 300 g (0.03 to 0.66 lb); the respirable fraction of that release $\approx$ 0.1	
Ionizing radiation sources - fissile or radioactive material entrained in pressurized gas release from MCO	SA-N-1 SA-N-3	- Bounding range of particulate matter in MCO $\approx$ 150 to 300 kg (330 to 660 lb) - Unmitigated release fraction range from MCO blowdown, RF $\approx$ 10^{-4} to 10^{-3} - Range of particulate matter released: 15 to 300 g (0.03 to 0.66 lb) - Unit dose $\approx$ 4.35×10^{-5} rem/g*	*Calculated from data in Table 3-6 of HNF-SD-SNF-RPT-004. ^b
External events - Gasoline or propane delivery truck explodes nearby causing shock wave, projectiles, heat, and dust that effect service area - Storage tanks* at nearby facility explode due to fire	SA-P-1	- Delivery truck capacity $\approx$ TBD - Distance from CSB $\approx$ TBD - Blast overpressure at CSB $\approx$ TBD - Propane storage tank* capacity $\approx$ 7,300 L (1,900 gal) - Estimated distance from CSB = 760 m (2,500 ft) - Blast overpressure at CSB $\approx$ TBD from boiling liquid expanding vapor explosion	*Two horizontal cylindrical storage tanks (1,000 gal and 940 gal) of propane are located outside approximately 0.5 mi from CSB at 2711-E Building.
External events - fire	SA-P-2	See HNF-SD-SNF-FHA-002 ^f	
External events - nearby facility accident releases radioactive or toxic material into service area	SA-P-3	--	See Chapter 1.0 of HNF-SD-SNF-RPT-004. ^b

**Table 3-9. Canister Storage Building Operations Hazardous Energy Source
Characterization — Location in Facility: Service Area. (sheet 4 of 5)**

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Natural phenomena - earthquake forces damage SSCs	SA-R-1	Forces exerted on facility from lateral and horizontal accelerations: 0.35 g horizontal, 0.23 g vertical (see Table 1-23 of HNF-SD-SNF-RPT-004 ^a)	
Natural phenomena - lightning strikes CSB	SA-R-3	Electrical discharge of millions of volts	Lightning protection shall be provided for facility as required by NFPA 780. ^a Computer control systems are especially vulnerable to lightning strikes.
Natural phenomena - rain intrusion	SA-R-4	Facility drainage designed for 6-hour probable maximum precipitation of 23 cm (9.2 in.) (see Section 1.4.1.1.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - snow, freezing weather	SA-R-5	Roof designed for snow loading of 98 kg/m ² (20 lb/ft ²) (see Section 1.4.1.1.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena -straight wind causes flying debris, wind pressure, and dust	SA-R-6	Facility designed for a wind speed of 129 km/h (80 mi/h), which is the design basis for the Hanford Site (see Section 1.4.1.1.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - dust devil creates dust and flying debris	SA-R-7	Unknown	Cooling air intake for vault is mounted on a 17.4-m- (57-ft-) high concrete tower.
Natural phenomena - tornado	SA-R-8	Facility designed to withstand tornado wind speeds of 322 km/h (200 mi/h) total, 258 km/h (160 mi/h) rotational, and 64.4 km/h (40 mi/h) translational (see Section 1.4.1.1.4 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - volcanic ashfall	SA-R-9	Facility designed to withstand ground ash load of 117 kg/m ² (24 lb/ft ²) (see Section 1.4.1.1.4 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	

Table 3-9. Canister Storage Building Operations Hazardous Energy Source
Characterization — Location in Facility: Service Area. (sheet 5 of 5)

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Natural phenomena - range fire	SA-R-10	Vegetation control in an 18-m (60-ft) clear space around CSB shall be provided (see Section 1.3.1.1 of HNF-SD-SNF-RPT-004 ^b)	

^aBedell, P. J., 1996, *SNF Canister Storage Building* (Letter FRP-112 to M. K. Mahaffey, Westinghouse Hanford Company, October 25), Fluor Daniel, Incorporated, Richland, Washington.

^bGarvin, L. J., 1997, *Canister Storage Building Safety Analysis Report — Phase 3: Safety Analysis Documentation Supporting Canister Storage Building Construction*, HNF-SD-SNF-RPT-004, Rev. 7, Duke Engineering and Services Hanford for Fluor Daniel Hanford, Incorporated, Richland, Washington.

^cScott, D. L., 1997, *Calculations for Hydrogen Release and Combustion in the Service Tent Enclosure of the CSB*, HNF-SD-SNF-CN-020, Rev. 0, Draft, Fluor Daniel Northwest for Fluor Daniel Hanford, Incorporated, Richland, Washington.

^dScott, D. L., 1997, *Calculations for Hydrogen Release and Combustion in the Service Pit of the CSB*, HNF-SD-SNF-CN-024, Rev. 0, Draft, Fluor Daniel Northwest for Fluor Daniel Hanford, Incorporated, Richland, Washington.

^e*Ignition Testing of As-Cut Conditioned SNF Samples*, Pacific Northwest National Laboratory, Richland, Washington.

^fSadanaga, C. T., 1996, *Preliminary Fire Hazard Analysis for the Canister Storage Building*, HNF-SD-SNF-FHA-002, Rev. 2, DynCorp Tri-Cities Services, Incorporated, for Fluor Daniel Hanford, Incorporated, Richland, Washington.

^gNFPA, 1995, *Lightning Protection Systems*, NFPA 780, National Fire Protection Association, Quincy, Massachusetts.

CSB = Canister Storage Building.

MCO = multicanister overpack.

MHM = multicanister overpack handling machine.

SSC = structure, system, and component.

TBD = to be determined.

**Table 3-10. Canister Storage Building Operations Hazardous Energy Source
Characterization — Location in Facility: Operating Area. (sheet 1 of 6)**

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Thermal - radioactive decay heat and chemical reaction create hot gases and surfaces below storage tube plug	OA-B-7	- Maximum allowable MCO wall temperature $\approx 130^{\circ}\text{C}$ (270°F) - Maximum allowable temperature in MCO $\approx 200^{\circ}\text{C}$ (400°F) - Maximum allowable temperature at underside of concrete deck $\approx 65^{\circ}\text{C}$ (150°F) - Maximum expected storage tube gas and wall temperature* $\approx 120^{\circ}\text{C}$ (250°F)	*This expected storage tube gas and wall temperature is a calculated maximum MCO surface temperature based on a hot summer day air temperature of 46°C (115°F) and the hottest spot in a fully loaded vault (see Section 2.5.2 of HNF-SD-SNF-RPT-004*).
Corrosives - leaking acids from cart batteries	OA-D-1	- Number of batteries per service cart $\approx$ TBD - Type of acid used is TBD - Estimated volume of acid in each battery $\approx$ TBD - Total volume of battery acid $\approx$ TBD	
Rotational kinetic - MHM turret shears MCO	OA-E-7	- Shearing plane is $\approx 1.5\text{ m}$ (5 ft) above floor level - Shear force is $\approx$ TBD	
Linear kinetic - forklift, dolly, service cart and trailer collisions	OA-F-2	- Forklift speed $\approx$ TBD - Forklift mass $\approx$ TBD - Dolly speed $\approx$ TBD - Dolly mass $\approx$ TBD - Service cart speed $\approx$ TBD - Service cart mass $\approx$ TBD	
Linear kinetic - MHM movement (MHM impacts personnel or equipment)	OA-F-7	- Maximum MHM gantry bridge* speed $\approx 12\text{ m/min}$ (40 ft/min) - Maximum MHM trolley* speed $\approx 12\text{ m/min}$ (40 ft/min) - MHM mass with plug and MCO $\approx 450\text{ tonne}$**	*Gantry bridge and trolley creep speed is 30.5 cm/min (1 ft/min) according to the Design Basis Document, Rev. 1, Section 8.7.1.^b **See Section 4.3.4.4.1 of HNF-SD-SNF-RPT-004.*
Mass, gravity, height - MCO falls on - Turntable - Top and sides of storage tube - Bottom impact absorber - Intermediate impact absorber	OA-G-13	- MCO mass $\approx 8.6\text{ tonne}$ - MCO fall distance to - Turntable $\approx$ TBD - Storage tube opening $\approx 2\text{ m}$ (7 ft) - Bottom impact absorber $\approx 13\text{ m}$ (44 ft) - Intermediate impact absorber $\approx 9\text{ m}$ (30 ft)	The design basis is a 8.80 tonne MCO concentric drop $\approx 13\text{ m}$ (44 ft) into a storage tube (see Section 4.3.4.4.1 of HNF-SD-SNF-RPT-004*).

Table 3-10. Canister Storage Building Operations Hazardous Energy Source
 Characterization — Location in Facility: Operating Area. (sheet 2 of 6)

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Mass, gravity, height - items dropped: • Tube plug • Intermediate impact absorber • Cover plate assembly • Rigging equipment	OA-G-14	• Tube plug mass $\approx$ 2.6 tonne • Tube plug drop height $\approx$ 2.9 m (9.5 ft) • Intermediate impact absorber mass $\approx$ TBD • Intermediate impact absorber drop height $\approx$ 9.5 m (31 ft) • Standard cover plate assembly* mass $\approx$ 670 kg (1,500 lb) overall • Center hatch of cover plate mass $\approx$ 193 kg (425 lb) • Cover plate assembly drop height $\approx$ 30 cm (1 ft) • Rigging equipment mass $\approx$ TBD • Rigging equipment drop height $\approx$ TBD	*See drawing of cover plate (H-2-120912) in HNF-SD-SNF-RPT-004.*
Volume, pressure - • Gas bottles (an uncontrolled release of inert gas from a failed regulator valve or gas bottle breach on either the MHM or service cart) • Gas bottles (inadvertent overpressurization of seal between the MHM nose piece and the floor during MCO removal from the transportation cask)	OA-H-5	Service cart: • Number of gas bottles $\approx$ TBD • Maximum pressure in gas bottle $\approx$ TBD MHM inerting system: • Number of gas bottles $\approx$ TBD • Maximum pressure in gas bottle $\approx$ TBD MHM nose piece: • Maximum allowable pressure $\approx$ TBD MHM chamber: • Maximum allowable pressure $\approx$ TBD	
Volume, pressure - pressure vessels (excessive gas generation in MCO overpressurizes MCO with MCO in storage tube)	OA-H-6a	• MCO relief pressure: - Valve $\approx$ 0.8 MPa gauge (120 lb/in² gauge) - Rupture disk $\approx$ 1.0 MPa differential (150 lb/in² differential) • MCO design pressure $\approx$ 1.0 MPa gauge (150 lb/in² gauge)	

**Table 3-10. Canister Storage Building Operations Hazardous Energy Source
Characterization — Location in Facility: Operating Area. (sheet 3 of 6)**

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Volume, pressure - pressure vessel (storage tube receives gas from MCO)	OA-H-6b	- Maximum number of MCOs per storage tube = 2 - Loaded storage tube free space volume - With one MCO present $\approx 3,100 \text{ L}^*$ - With two MCOs present $\approx 2,100 \text{ L}^*$ - Storage tube design pressure $\approx 5.2 \text{ MPa}$ gauge (750 lb/in^2 gauge) at 21°C (70°F) - Leak rate of storage tube plug O-ring seals $\approx 10^{-4}$ standard cm^3/sec at 27 kPa gauge (4 lb/in^2 gauge) - Tube plug weighs $3,850 \text{ kg}$ ($8,500 \text{ lb}$) and will lift at 520 kPa gauge (76 lb/in^2 gauge) - Pressure relief valves in storage tube plugs: - HEPA filter on outlet = yes - Primary relief valve set pressure = 62 kPa gauge (9 lb/in^2 gauge) - Secondary relief valve set pressure = 76 kPa gauge (11 lb/in^2 gauge)	*Both impact absorbers are assumed to be in place with no credit taken for porosity.
Volume, pressure - gas receivers (high pressure inert gas fill line or manifold fails)	OA-H-8	- Inert gas line pressure $\approx \text{TBD}$ - Inert gas outside storage tank capacity $\approx 3,400 \text{ m}^3$	
Explosives or pyrophorics - flammable hydrogen mixture and ignition source	OA-J-6	Maximum possible hydrogen release is from MCO rupture disk release into storage tube followed by release through storage tube plug to the CSB operating deck; estimated maximum quantity of hydrogen released $\approx 100 \text{ gmols}$ along with $\approx 69 \text{ gmols}$ of helium	
Explosives or pyrophorics - plutonium, uranium, and zirconium metal is exposed to air because of breached MCO and air ingress	OA-J-10	Minimum ignition temperature of plutonium, uranium, and zirconium in air: Fuel ignition tests in lab showed minimum ignition temperatures ranging from 329°C to 473°C (624°F to 883°F). See PNNL "Ignition Testing of As-Cut Conditioned SNF Samples," 10/16/96. ^c	Reaction rate is temperature- and surface area-dependent; these metals are more inclined to ignite in the finely divided state than in the massive state; contents of scrap basket are most vulnerable.
Nuclear criticality - vaults	OA-K-1	---	Addressed in Chapter 6.0 of HNF-SD-SNF-RPT-004; ^a no new hazards were identified.

**Table 3-10. Canister Storage Building Operations Hazardous Energy Source
Characterization — Location in Facility: Operating Area. (sheet 4 of 6)**

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Nuclear criticality -filters (cart and tube plugs)	OA-K-4	---	Addressed in Chapter 6.0 of HNF-SD-SNF-RPT-004; ^a no new hazards were identified.
Nuclear criticality - crane lifts	OA-K-12	---	Addressed in Chapter 6.0 of HNF-SD-SNF-RPT-004; ^a no new hazards were identified.
Flammable materials - hydrogen	OA-L-11	---	Refer to "Explosives or pyrophorics-hydrogen" for an evaluation of this hazard.
Flammable materials - organics (MHM neutron absorber)	OA-L-13	---	See HNF-SD-SNF-FHA-002, ^d the white paper on occupational classification, ^e and the deviation and exemption request letters that cover this topic. ^{6a}
Flammable materials - hydraulic fluid for tube service cart plug cover hoist leaks out and burns	OA-L-15	Volume of hydraulic fluid at risk = TBD	Alternative, non-flammable fluids are being considered. The PFHA ^d addresses fires that fully involve the cart except internal low-level contaminant release.
Hazardous materials - corrosives from batteries leak out	OA-M-5	---	See "Corrosives -acid" (OA-D-1) for an evaluation of this hazard.
Hazardous materials - toxic materials in particulate matter, primarily plutonium and uranium, are carried out of MCO and storage tube by gases under pressure	OA-M-7	Estimated maximum particulate matter in MCO after hot conditioning is 300 kg (660 lb) Unmitigated airborne release fraction from MCO blowdown = 0.001; the respirable fraction of that release is 0.1	Particulate matter in gases must find a leak path out of the storage tube.
Ionizing radiation sources • Fissile or radioactive material release by gases under pressure • Radiation shine from adjacent storage tubes	OA-N-1 and OA-N-3	The dose rate shielding goal for the MHM is 2.0×10^{-3} mSv/hr (0.2 mrem/hr)	

**Table 3-10. Canister Storage Building Operations Hazardous Energy Source
Characterization — Location in Facility: Operating Area. (sheet 5 of 6)**

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
External events - explosion (gasoline or propane delivery truck explodes nearby causing shock wave, projectiles, heat, and dust)	OA-P-1	See "External events" under Service Area	
External events - fire	OA-P-2	---	See HNF-SD-SNF-FHA-002. ^d
External events - nearby facility accident releases radioactive, toxic material into operating area	OA-P-3	---	See Chapter 1.0 of HNF-SD-SNF-RPT-004. ^a
Natural phenomena - earthquake forces damage SSCs	OA-R-1	Forces exerted on facility from lateral and horizontal accelerations: 0.35 g horizontal, 0.23 g vertical (see Table 1-23 of HNF-SD-SNF-RPT-004 ^a)	
Natural phenomena - lightning strikes CSB	OA-R-3	Electrical discharge of millions of volts	Lightning protection shall be provided for facility as required by NFPA 780. ^b
Natural phenomena - rain intrusion	OA-R-4	Facility drainage designed for a 6-hour probable maximum precipitation of 23 cm (9.2 in.) (see Section 1.4.1.1.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^a)	
Natural phenomena - snow, freezing weather	OA-R-5	Roof designed for snow loading of 98 kg/m ² (20 lb/ft ²) (see Section 1.4.1.1.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^a)	
Natural phenomena - straight wind causes flying debris, wind pressure, and dust	OA-R-6	Facility designed for a wind speed of 129 km/h (80 mi/h), which is the design basis for the Hanford Site (see Section 1.4.1.1.4 and Table 1-23 of HNF-SD-SNF-RPT-004 ^a)	
Natural phenomena - tornado	OA-R-8	Facility designed to withstand tornado wind speeds of 322 km/h (200 mi/h) total, 258 km/h (160 mi/h) rotational, and 64.4 km/h (40 mi/h) translational (see Section 1.4.1.1.4 and Table 1-23 of HNF-SD-SNF-RPT-004 ^a)	
Natural phenomena - volcanic ashfall	OA-R-9	Facility designed to withstand a ground ash load of 117 kg/m ² (24 lb/ft ²) (see Section 1.4.3.8.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^a)	

Table 3-10. Canister Storage Building Operations Hazardous Energy Source
Characterization — Location in Facility: Operating Area. (sheet 6 of 6)

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Natural phenomena - range fire	OA-R-10	Vegetation control in an 18-m (60-ft) clear space around CSB shall be provided (see Section 1.3.1.1 of HNF-SD-SNF-RP 004*)	

*Garvin, L. J., 1997, *Canister Storage Building Safety Analysis Report — Phase 3: Safety Analysis Documentation Supporting Canister Storage Building Construction*, HNF-SD-SNF-RPT-004, Rev. 7, Duke Engineering and Services Hanford for Fluor Daniel Hanford, Incorporated, Richland, Washington.

*Bedell, P. J., 1996, *SNF Canister Storage Building* (Letter FRP-112 to M. K. Mahaffey, Westinghouse Hanford Company, October 25), Fluor Daniel, Incorporated, Richland, Washington.

**Ignition Testing of As-Cut Conditioned SNF Samples*, Pacific Northwest National Laboratory, Richland, Washington.

*Sadanaga, C. T., 1996, *Preliminary Fire Hazard Analysis for the Canister Storage Building*, HNF-SD-SNF-FHA-002, Rev. 2, DynCorp Tri-Cities Services, Incorporated, for Fluor Daniel Hanford, Incorporated, Richland, Washington.

*Ares, 1996, *White Paper Presenting Recommended Approach to Fire Protection of the Operating Area of the Canister Storage Building*, Report 951107-002, Ares Corporation, Richland, Washington.

*Williams, N. H., 1996, *Project W-379, Spent Nuclear Fuel Canister Storage Building Request for Deviation from the United States Department of Energy Order 6430.1A — Automatic Sprinkler Protection Requirements* (Letter 9655218 to E. D. Sellers, U.S. Department of Energy, Richland Operations Office, November 14), Fluor Daniel Hanford, Incorporated, Richland, Washington.

*Williams, N. H., 1996, *Project W-379, Spent Nuclear Fuel Canister Storage Building Request for Exemption from the United States Department of Energy Order 5480.7A — Automatic Fire Suppression System Requirements* (Letter 9655233 to E. D. Sellers, U.S. Department of Energy, Richland Operations Office, November 14), Fluor Daniel Hanford, Incorporated, Richland, Washington.

*NFPA, 1995, *Lightning Protection Systems*, NFPA 780, National Fire Protection Association, Quincy, Massachusetts.

CSB = Canister Storage Building.

HEPA = high-efficiency particulate air (filter).

MCO = multicanister overpack.

MHM = multicanister overpack handling machine.

SSC = structure, system, and component.

TBD = to be determined.

Table 3-11. Canister Storage Building Operations Hazardous Energy
Source Characterization — Location in Facility: Vault
(Including Air Intake and Exhaust). (sheet 1 of 2)

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Thermal - radioactive decay heat and chemical reaction heat (high temperature in vault tubes and MCOs caused by blockage of natural convection flow)	VL-B-7 VL-B-10 VL-R-7 VL-R-9 VL-R-10	- Maximum expected air natural convection flow rate $\approx 770 \text{ m}^3/\text{min}$ ($27,000 \text{ m}^3/\text{min}$)* - Minimum required flow rate $\approx$ TBD - Maximum allowable fuel centerline temperature $\approx 200 \text{ }^\circ\text{C}$ ($400 \text{ }^\circ\text{F}$) - Maximum allowable MCO wall temperature $\approx 130 \text{ }^\circ\text{C}$ ($270 \text{ }^\circ\text{F}$) - Maximum estimated MCO wall temperature $\approx 120 \text{ }^\circ\text{C}$ ($250 \text{ }^\circ\text{F}$) - Maximum allowable temperature of vault concrete $\approx 65 \text{ }^\circ\text{C}$ ($150 \text{ }^\circ\text{F}$) - Maximum expected temperature of vault concrete $\approx 56 \text{ }^\circ\text{C}$ ($130 \text{ }^\circ\text{F}$)	The natural convection flow rate depends on how many MCOs are loaded into storage tubes.
Volume, pressure - pressure vessel (rupture disk rupture on MCO pressurizes storage tube)	VL-H-6	- Number of MCOs per storage tube $= 2$ - Loaded storage tube free space volume - With one MCO present $= 3,100 \text{ L}$ - With two MCOs present $= 2,100 \text{ L}$ - Storage tube working pressure $= 5.2 \text{ MPa gauge}$ ($750 \text{ lb/in}^2 \text{ gauge}$) at $21 \text{ }^\circ\text{C}$ ($70 \text{ }^\circ\text{F}$) - Maximum calculated service pressure $= 520 \text{ kPa gauge}$ ($76 \text{ lb/in}^2 \text{ gauge}$) - Leak rate of storage tube plug O-ring seals $\approx 10^{-4}$ standard cm^3/sec at 27 kPa gauge ($4 \text{ lb/in}^2 \text{ gauge}$) - Tube plug weighs $3,850 \text{ kg}$ ($8,500 \text{ lb}$) and will lift at 520 kPa gauge ($76 \text{ lb/in}^2 \text{ gauge}$) - Relief valves in storage tube plugs: - HEPA filter on outlet $= \text{yes}$ - Primary relief valve set pressure $= 62 \text{ kPa gauge}$ ($9 \text{ lb/in}^2 \text{ gauge}$) - Secondary relief valve set pressure $= 76 \text{ kPa gauge}$ ($11 \text{ lb/in}^2 \text{ gauge}$)	
Explosives or pyrophorics - hydrogen leaks into vault area (from breached storage tubes), mixes with air to form a flammable mixture, and spark ignites mixture	VL-J-6	Maximum possible hydrogen release is from MCO rupture disk release into storage tube followed by release from storage tube into vault; estimated maximum quantity of hydrogen released $\approx 100 \text{ gmole}$ along with $\approx 69 \text{ gmole}$ of helium	
Flammable materials - hydrogen	VL-L-11	---	Refer to "Explosives or pyrophorics-hydrogen" for an evaluation of this hazard.

**Table 3-11. Canister Storage Building Operations Hazardous Energy
Source Characterization — Location in Facility: Vault
(Including Air Intake and Exhaust). (sheet 2 of 2)**

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Ionizing radiation sources - radioactive sources	VL-N-4	---	There is no access to this area, so this hazard, while present, is not a concern for worker safety.
Natural phenomena - earthquake forces damage SSCs	VL-R-1	Forces exerted on facility from lateral and horizontal accelerations: 0.35 g horizontal, 0.23 g vertical (see Table 1-23 of HNF-SD-SNF-RPT-004*)	
Natural phenomena - rain intrusion	VL-R-4	Facility drainage designed for a 6-hour probable maximum precipitation of 23 cm (9.2 in.) (see Section 1.4.1.1.2 and Table 1-23 of HNF-SD-SNF-RPT-004*)	
Natural phenomena - snow, freezing weather	VL-R-5	Roof designed for snow loading of 98 kg/m ² (20 lb/ft ²) (see Section 1.4.1.1.2 and Table 1-23 of HNF-SD-SNF-RPT-004*)	

*Garvin, L. J., 1997, *Canister Storage Building Safety Analysis Report — Phase 3: Safety Analysis Documentation Supporting Canister Storage Building Construction*, HNF-SD-SNF-RPT-004, Rev. , Duke Engineering and Services Hanford for Fluor Daniel Hanford, Incorporated, Richland, Washington.

CSB = Canister Storage Building.

HEPA = high-efficiency particulate air (filter).

MCO = multiccanister overpack.

SSC = structure, system, and component.

TBD = to be determined.

**Table 3-12. Canister Storage Building Operations Hazardous Energy Source
Characterization — Location in Facility: Support Building. (sheet 1 of 2)**

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Flammable materials: • Building contents • Packing materials • Rags • Lubricating oil • Diesel fuel • Grease • Hydrogen • Organics • Clothing	SB-L-01 SB-L-02 SB-L-04 SB-L-07 SB-L-08 SB-L-10 SB-L-11 SB-L-13 SB-L-16	Mass of materials (kg) TBD	
Ionization radiation sources - radioactive material in HVAC filters burns	SB-N-03	Mass of radioactive material in filters ≈ TBD	
External events - explosion of propane or gasoline delivery truck introduces shockwave, projectiles, heat and dust into support building	SB-P-01	• Propane volume ≈ TBD • Gasoline volume ≈ TBD • Distance from support building ≈ TBD • Shockwave overpressure ≈ TBD	
External events - fire introduces heat and smoke into building	SB-P-02	A fire inside the building has greatest consequences, which are covered by the preliminary fire hazards analysis ^a	
External events - accidents at nearby facilities that release radioactive material and direct radiation cause personnel injury and render the facility uninhabitable	SB-P-03	Descriptions of potential accidents at nearby facilities and their resulting consequences are addressed in Chapter 1.0 of HNF-SD-SNF-RPT-004 ^b	
Natural phenomena - earthquake forces cause collapse of structure resulting in loss of primary power, ventilation, and inert gas supply; HVAC filter failure results in radiation release	SB-R-01	Forces exerted on facility due to lateral and horizontal accelerations of 0.35 g horizontal, 0.23 g vertical (see Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	The support building is designed to withstand a design basis earthquake.
Natural phenomena - lightning strikes support building	SB-R-03	Electrical discharge of millions of volts	Lightning protection shall be provided for facility as required by NFPA 780; ^c control systems are especially vulnerable to lightning strikes.
Natural phenomena - rain intrusion	SB-R-04	Facility drainage designed for a 6-hr probable maximum precipitation of 23 cm (9.2 in.) (see Section 1.4.1.1.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	

Table 3-12. Canister Storage Building Operations Hazardous Energy Source
Characterization — Location in Facility: Support Building. (sheet 2 of 2)

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Natural phenomena - snow, freezing weather	SB-R-05	Roof designed for snow loading of 98 kg/m ² (20 lb/ft ²) (see Section 1.4.1.1.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - straight wind causes flying debris, wind pressure, and dust	SB-R-06	Facility designed for a wind speed of 80 mi/h, which is the design basis for the Hanford Site (see Section 1.4.1.1.4 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - tornado	SB-R-08	Facility designed to withstand tornado wind speeds of 322 km/h (200 mi/h) total, 258 km/h (160 mi/h) rotational, and 64.4 km/h (40 mi/h) translational (see Section 1.4.1.1.4 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - volcanic ashfall	SB-R-09	Facility designed to withstand a ground ash load of 117 kg/m ² (24 lb/ft ²) (see Section 1.4.3.8.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - range fire	SB-R-10	Vegetation control in an 18-m (60-ft) clear space around CSB shall be provided (see Section 1.3.1.1 of HNF-SD-SNF-RPT-004 ^b)	

^aSadanaga, C. T., 1996, *Preliminary Fire Hazard Analysis for the Canister Storage Building*, HNF-SD-SNF-FHA-002, Rev. 2, DynCorp Tri-Cities Services, Incorporated, for Fluor Daniel Hanford, Incorporated, Richland, Washington.

^bGarvin, L. J., 1997, *Canister Storage Building Safety Analysis Report — Phase 3: Safety Analysis Documentation Supporting Canister Storage Building Construction*, HNF-SD-SNF-RPT-004, Rev. 7, Duke Engineering and Services Hanford for Fluor Daniel Hanford, Incorporated, Richland, Washington.

^cNFPA, 1995, *Lightning Protection Systems*, NFPA 780, National Fire Protection Association, Quincy, Massachusetts.

CSB = Canister Storage Building.

HVAC = heating, ventilating, and air conditioning.

TBD = to be determined.

**Table 3-13. Canister Storage Building Operations Hazardous Energy
Source Characterization — Location in Facility: Outside. (sheet 1 of 2)**

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Linear kinetic - trucks, forklifts, and crane loads collide with inert gas supply, diesel tanks, new MCOs, gas bottles, transformer	OU-F-01 OU-F-02 OU-F-05 OU-Q-04	- Truck: mass $\approx$ TBD; speed $\approx$ TBD - Forklift: mass $\approx$ TBD; speed $\approx$ TBD - Crane: load mass $\approx$ TBD; drop distance $\approx$ TBD - Number of diesel tanks = 2 - Volume of one diesel tank $\approx$ 1,900 L (500 gal) - Inert gas supply tube trailer capacity: - Volume $\approx$ 3,400 m³ - Pressure $\approx$ TBD	
Volume pressure - inert gas tube trailer is impacted by linear kinetic equipment	OU-H-05 OU-H-06	Inert gas supply tube trailer capacity: - Volume $\approx$ 3,400 m³ - Pressure $\approx$ TBD	
Flammable materials - diesel fuel carrier or tank is impacted by linear kinetic equipment	OU-L-07	- Diesel storage tank total volume $\approx$ 3,800 L (1,000 gal) - Delivery tank truck volume $\approx$ TBD	
External events - explosion of propane or gasoline delivery truck introduces shockwave, projectiles, heat, and dust into outside facility	OU-P-01	- Propane volume $\approx$ TBD - Gasoline volume $\approx$ TBD - Distance from outside facility $\approx$ TBD - Shockwave overpressure $\approx$ TBD	
External events - fire introduces heat and smoke outside facility	OU-P-02	A fire inside the building has greatest consequences, which are covered by the preliminary fire hazards analysis ^a	
External events - accidents at nearby facilities that release radioactive material and direct radiation cause personnel injury and render the facility uninhabitable	OU-P-03	Descriptions of potential accidents at nearby facilities and their resulting consequences are addressed in Chapter 1.0 of HNF-SD-SNF-RPT-004 ^b	
Natural phenomena - earthquake forces cause collapse of structure resulting in loss of primary power, ventilation, and inert gas supply; HVAC filter failure results in radiation release	OU-R-01	Forces exerted on facility due to lateral and horizontal accelerations of 0.35 g horizontal, 0.23 g vertical (see Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - lightning strikes outside facility	OU-R-03	Electrical discharge of millions of volts	Lightning protection shall be provided for facility as required by NFPA 780; ^c control systems are especially vulnerable to lightning strikes.

**Table 3-13. Canister Storage Building Operations Hazardous Energy
Source Characterization — Location in Facility: Outside. (sheet 2 of 2)**

Hazard energy source/material description	Designation per checklist	Capacity/quantity	Comments
Natural phenomena - rain intrusion	OU-R-04	Facility drainage designed for a 6-hr probable maximum precipitation of 23 cm (9.2 in) (see Section 1.4.1.1.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - snow, freezing weather	OU-R-05	Roof designed for snow loading of 98 kg/m ² (20 lb/ft ²) (see Section 1.4.1.1.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - straight wind causes flying debris, wind pressure, and dust	OU-R-06	Facility is designed for a wind speed of 80 mi/h, which is the design basis for the Hanford Site (see Section 1.4.1.1.4 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - dust devil creates dust and flying debris	OU-R-07	Unknown	Cleanup of debris would be needed.
Natural phenomena - tornado	OU-R-08	Facility designed to withstand tornado wind speeds of 322 km/h (200 mi/h) total, 258 km/h (160 mi/h) rotational, and 64.4 km/h (40 mi/h) translational (see Section 1.4.1.1.4 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - volcanic ashfall	OU-R-09	Facility designed to withstand a ground ash load of 117 kg/m ² (24 lb/ft ²) (see Section 1.4.3.8.2 and Table 1-23 of HNF-SD-SNF-RPT-004 ^b)	
Natural phenomena - range fire	OU-R-10	Vegetation control in an 18-m (60-ft) clear space around CSB shall be provided (see Section 1.3.1.1 of HNF-SD-SNF-RPT-004 ^c)	

^aSadanaga, C. T., 1996, *Preliminary Fire Hazard Analysis for the Canister Storage Building*, HNF-SD-SNF-FHA-002, Rev. 2, DynCorp Tri-Cities Services, Incorporated, for Fluor Daniel Hanford, Incorporated, Richland, Washington.

^bGarvin, L. J., 1997, *Canister Storage Building Safety Analysis Report — Phase 3: Safety Analysis Documentation Supporting Canister Storage Building Construction*, HNF-SD-SNF-RPT-004, Rev. , Duke Engineering and Services Hanford for Fluor Daniel Hanford, Incorporated, Richland, Washington.

^cNFPA, 1995, *Lightning Protection Systems*, NFPA 780, National Fire Protection Association, Quincy, Massachusetts.

CSB = Canister Storage Building.

HVAC = heating, ventilating, and air conditioning.

MCO = multicanister overpack.

TBD = to be determined.

Table 3-14. Canister Storage Building Hazard Analysis: Truck Vestibule. (sheet 1 of 7)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
Truck vestibule TVF-01	1, 34	Linear kinetic transporter trucks	Transporter collision	Human error Mechanical failure Mislocated equipment	Collision with - Facility structures, systems, or components - Personnel	Transporter impacts can cause - Damage to the transportation cask (but no breach) - Damage to facility structures, systems, or components (e.g., inner overhead door, loading crane) - Damage to the transporter - Personnel injury Damage to the MCO inside the transportation cask Any of these consequences could result in operational delays, delays that cause the MCO to exceed its available transport window may result in MCO storage tube misplacement within the storage tube	The transportation cask and the MCO within are designed to survive impacts within the CSB facility while the transporter is moving down to the transporter while in transport The truck vestibule has wheel stops to alert the driver to his position. The approach into the truck vestibule is restricted by design, and indicates speed limits.	The drivers of the transporters are trained and qualified to perform their duties safely, which includes transporting the transporter to the transport and obeying all speed limits. Receiving controls limit the conditions under which a transporter could arrive at the CSB (e.g., weather/hot conditions, transporter-cask configurations). Regular maintenance is performed on the transporter to ensure it is in good working order.	S1	F3	The consequence and frequency column take credit for the transportation cask and truck design.
Truck vestibule TVF-05	1, 34	Linear kinetic transporter (with yoke, cask)	Crane collision	Human error Mechanical failure Mislocated equipment	Collision with - Transporter - Equipment out of place - Personnel - Inner overhead door	Damage to transportation cask and/or transporter Damage to receiving crane, yoke, or other systems, structures, or components Loss of inner overhead door could cause a loss of zone between the service area and the truck vestibule and/or allow exhaust gases from the transporter cab to enter the service area Personnel injury Any of these consequences could result in operational delays, delays that cause the MCO to exceed its available transport window may result in MCO storage tube misplacement within the storage tube	The transportation cask is designed to survive all credible impacts from the receiving crane. The receiving crane design includes such features as restricted speed, load limit, micropositioner, and auditory movement alarms. The inner overhead door provides indication (auditory and/or visual) of its position (i.e., whether fully open or not).	The operators of the receiving crane are trained and qualified to perform their duties safely, which includes transporting the transporter to the operation of the crane and handling of the transportation cask. Regular maintenance is performed on the receiving crane to ensure it is in good working order.	S1	F3	The consequence column takes credit for the transportation cask design.
Truck vestibule TVF-05	2, 4	Mass, gravity, height - truck (transporter)	Elevated cask sitting on yoke (>2 ft off ground)	Seismic event Operator error Mechanical failure of transporter	Cask falls off transporter after the clamshell hold downs are removed but before the yoke is stowed	Damage to the transportation cask Damage to facility structures, systems, components (e.g., inner overhead door, receiving crane) Damage to the transporter Personnel injury Damage to the MCO inside the transportation cask	The transportation cask and the MCO within are designed to survive credible transportation accidents, including a fall or upsurge from the transporter.	The operators of the receiving crane are trained and qualified to perform their duties safely, which includes following procedures for safe handling of the transportation cask. Regular maintenance is performed on the transporter to ensure it is in good working order.	S1	F2	Frequency column takes credit for clamshell hold downs and attaching yoke to cask. ACTION ITEM: The possibility of credible drops onto an unyielding surface in the truck vestibule that exceed the design basis is under consideration. The results must be included in the hazard analysis. (Action Item #69)

Table 3-14. Canister Storage Building Hazard Analysis: Truck Vestibule. (sheet 2 of 7)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
Truck vestibule TV-G-13	5	Mass, gravity, height, vessels (transportation cask)	Raised cask on trucks, crane falls (The maximum hook is 4 to 6 ft off floor)	Hoist failure Yoke failure Human error	Cask fall from receiving cask to transporter or vestibule floor	Damage cask Personnel injury Damaged transporter Loss of time (schedule) Loss of time transport window Damaged vestibule floor	The hoist design includes - Interlocks to preclude lift and horizontal motion at same time - Dual brakes - No free fall capacity Cask (with MCO) and truck vestibule floor are designed to withstand the impact of a drop from the transportation cask onto the truck vestibule floor.	Sequence of operations for crane operation (basis for procedures) Qualified crane operators Maintenance and operations manuals and details to be provided by crane vendors	S1	F2	Consequence and frequency column take credit for cask design. ACTION ITEM: The possibility of credible crane failure and cask surface in the truck vestibule that exceed the design basis is under consideration. The results must be included in the hazard analysis in the hazard analysis (Action item #46)
Truck vestibule TV-H-06	Between 1 and 5	Pressure, volume - pressure vessels (cask, MCO system)	Gases or/or high pressure hydrogen reach for use pressure	Delay in excess of transport window Inadequate conditioning (i.e., insufficient quantity of water removed) before receipt at CSB	MCO rupture disk ruptures (overpressure, bad rupture disk) Cask leak - Lid seal - Drain port ball valve failure - Drain port or vent port - Vent port failure Personnel contamination (radioactive gas, dust, steam, transporter personnel)	Release of MCO gases and particulate into cask annulus (MCO still contained by cask) Release from cask (only a problem if MCO release or breach occurs) - If relief valve actuates, hydrogen and radioactive gas or fission gases could be released - If rupture disk ruptures, hydrogen and radioactive or toxic materials could be released - Radioactive contamination of cask	The cask is designed to not allow release from MCO breach - Cask design materials to preclude breach - Design pressure of 150 lbm ² for cask - Vestibule CMVs - Conditioning process	CSB acceptance criteria assure that MCOs not meeting the minimum requirements for acceptance (e.g., shipping window, packaging conditions) are not unloaded from the transporter Receipt survey (sequence of operations basis for procedures)	S2	F2	ACTION ITEM: The acceptance criteria for CSB receipt of MCOs that have been conditioned for shipment at the CSB must be determined. (Action item #12)
Truck vestibule TV-J-06	2,5	Explosives or pyrophorics - hydrogen	Flammable hydrogen mixture created and ignition source present	Hydrogen leaks from pressurized cask, mixing with air, ignition source present Hydrogen leak because of connections failing and/or weird drain plates failing	Degradation or deterioration combustion	Burn victims Operational delays Damage to structures, systems, or components Low levels of contamination	Cask design Likely leakage is small because of design (complex potential leak path) HVAC design (when outer door closed) Cask head seals (two in series)	Shipping window provides assurance of low pressures CSB procedure impacts seals and sealing surfaces before closing cask Smoking not allowed within the facility	S1	F1	ACTION ITEM: The acceptance criteria for CSB receipt of MCOs that have been conditioned for shipment at the CSB must be determined. (Action item #12)
Truck vestibule TV-J-10	Between 2 and 5	Explosives or pyrophorics (uranium and/or plutonium metal zirconium)	Pyrophoric material is exposed to air and sufficient temperature are present	Breached MCO and cask	The exposed pyrophoric material reacts with the air and sufficient temperature are present	Personnel injury (burns) Contamination release Damage to cask Damage to MCO	The MCO and the transportation cask are designed to survive all transportation accidents and design reduces the likelihood of breaches leading to the exposure of pyrophoric material to air.	CSB personnel are trained in full MCO procedures for meeting the requirements for receipt of cask before shipment to the CSB	S3	F1	A full cask-MCO breach is necessary to have a reaction that is not self- limited
Truck vestibule TV-K-05	2,4	Nuclear criticality - casks					CSB cannot be flooded by rain or water main break	General training of operators; operator will not disassemble an MCO		F0	Addressed in HNF-SD-SNF-001; 004, Chapter 6 - no new hazards identified

T3-31

July 1997

Table 3-14. Canister Storage Building Hazard Analysis: Truck Vestibule. (sheet 4 of 7)

Location/ checklist entry	Operating sequence model/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq category	Freq category	Remarks
							Engineering features	Administrative features			
Truck vestibule TV-P-01	1-5	External events - explosion outside of the truck vestibule	Shock wave from explosion introduces dust, heat, and/or toxic material into the truck vestibule	Explosion of nearby gas delivery truck, or gas station	The shock wave from the explosion impacts the building Flying debris hits personnel Workers are exposed to heat from the explosion	- The blast effect on the truck vestibule could cause: - Structural damage or failure - The transportation cask to drop from the receiving crane - Personnel injury from flying debris - Operational delays could result from: - Personnel injury or a cask is damaged and/or a transport is delayed that need to evacuate the facility, delays that cause the MCO to exceed its available pressure relief before placement within the storage tube.	The CSB is isolated from major roads, reducing the possibility of explosions outside the facility affecting the CSB. The facility structure is designed to withstand significant external straight winds. The transporter and transportation cask are designed to survive specific drop conditions that would bound this hazard.*	CSB personnel are trained in sitewide and facility-specific emergency response procedures that include steps to place the facility in the safest possible condition.	S1	F2	For additional details on the hazards associated with a dropped cask, refer to TV-G-13, "Mass, gravity height - vessels."
Truck vestibule TV-P-02	1-5	External events - fire	Heat and smoke introduced into the truck vestibule (low visibility)								Based upon the current design, there is no external energy source that would have greater consequences than a fire inside the facility. These hazards are addressed by the preliminary fire hazards analysis. Refer to the white papers on occupational classification* and the decision and exemption request sheets* that cover the topic.
Truck vestibule TV-P-03	1-5	External events - nearby facilities	Radioactive material, toxic material, and debris introduced into the facility	Descriptions of potential accidents at nearby facilities and their resulting consequences are addressed in Chapter 1.0 of HNF-SD-SNF-RPT-004.*	Descriptions of potential accidents at nearby facilities and their resulting consequences are addressed in Chapter 1.0 of HNF-SD-SNF-RPT-004.*	- Procedural measures to radioactive and toxic material from the nearby facility - Contamination of the CSB from nearby facility releases potentially making the building uninhabitable - Operational delays as a result of a need to evacuate the facility or take cover that cause the MCO to exceed its available pressure relief before placement within the storage tube	The distance of the CSB from other nearby facilities and the facility structure provides reduction in consequences of external events on the CSB.	CSB personnel are trained in sitewide and facility-specific emergency response procedures that include steps to place the facility in the safest possible condition.	S1	F1	
Truck vestibule TV-Q-04	1-5	Vehicles in motion - cars, trucks, buses	Impact on the CSB facility	Human error or mechanical failure	A vehicle could potentially impact: - The transporter in the truck vestibule or the tractor cab - Truck vestibule systems, structures, or components - Facility personnel	- Damage to the transporter and/or the facility could potentially lead to guide vehicles around the facility, which limits their potential to impact the facility. - The transporter and transportation cask are designed to survive vehicle impacts without releasing radioactive or toxic materials.	Speed limits are posted in the vicinity of the CSB to keep vehicle speeds low.	There will be no more than one transporter in the CSB boundary at one time, reducing the potential for impacts involving two or more transporters.	S1	F2	Transporter effects are not specifically considered for determining consequence, as this is addressed by the SNRP.* Aircraft impacts are not considered as they are deemed incredible in Chapter 1.0 of HNF-SD-SNF-RPT-004.

Table 3-14. Canister Storage Building Hazard Analysis: Truck Vestibule. (sheet 5 of 7)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
Truck vestibule TVR-01	1-5	Natural phenomena - earthquake (both DBE and -DBE)	Excess exerted on the facility by lateral and horizontal accelerations	Earthquake	An earthquake could result in - Structural damage or collapse - Damage to facility systems, structures, or components - Damage to the transportation cask caused by the earthquake - rollover, or impact from a falling receiving crane	The potential consequences of an earthquake include - Personnel injury - Release of radiation from a breached transportation cask and MCO - Loss of facility power Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within the storage tube	The facility (including the structure and crane) is designed with consideration of impacts to safety systems from the failure of non- safety systems. CSS is built to appropriate seismic criteria The transportation cask and the MCO within are designed to survive all credible impacts within the CSA facility while on the transporter. In addition, the cask is securely tied down to the transporter while in transport.	CSS personnel are trained in the facility's emergency response procedures that include steps to place the facility in the safest possible condition.	S2	F2	ACTION ITEM: The possibility of the crane dropping onto an underlying structure is not considered in the exceed the design basis is under consideration. The results must be verified against current assumptions for the hazard analysis. (Action Item #69)
Truck vestibule TVR-03	1-5	Natural phenomena - lightning	High electrical energy	Lightning strike	Strike on the truck vestibule such as receiving crane components Flooded floors	The potential consequences of a lightning strike on the truck vestibule include - Loss of power - Damage to systems, structures, or components - Personnel injury Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within the storage tube	The CSS facility is equipped with lightning rods, grounding, and ground fault detectors. The facility provides shelter for workers.	CSS personnel are trained in the facility's emergency response procedures that include steps to place the facility in the safest possible condition.	S1	F2	
Truck vestibule TVR-04	1-5	Natural phenomena - rain	Water intrusion into the truck vestibule	Leaks around doors or through the roof Volume of rain exceeds the capacity of the facility grading and drainage system to carry off rainwater	Water in electrical systems such as receiving crane components Flooded floors	The facility is designed to prevent water intrusion and to provide shelter for workers. The receiving crane is designed to minimize the potential for water intrusion into its electrical components. The electrical design within the facility minimizes potential consequences (electrical conduit inhibits fire spread). The site grading is designed to prevent rain intrusion into the facility. The facility design takes into consideration the need for flexible (non-slip) surfaces.			S1	F3	

Table 3-14. Canister Storage Building Hazard Analysis: Truck Vestibule. (sheet 6 of 7)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
Truck vestibule TV-R-05	1-5	Natural phenomena - snow, freezing weather	Snow loading Extreme cold	Snow storm, cold weather	Roof collapse	Personnel injury from collapsed roof or exposure to the cold Ice buildup Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within the storage tube	The building is designed to withstand anticipated snow loads. The truck vestibule is heated. The facility provides shelter for workers.	The SARP prohibits MCO shipping during adverse weather conditions. The facility provides shelter for workers.	S1	F3	ACTION ITEM: The SARP definition of "adverse weather conditions" - should be included here. (Action Item #64)
Truck vestibule TV-R-06	1-5	Natural phenomena - straight wind	Wind pressure Flying debris Dust	Pressure gradient	Personnel struck by flying debris Systems, structures, or components damaged by flying debris Visibility reduced Accumulated debris	Personnel injury Restricted access to the facility Operational delays from damaged equipment or the need to clear debris from the facility may result in MCO pressure relief before placement within the storage tube	The facility structure and outer door are designed to withstand a 200 mph wind. The facility provides shelter for workers.		S1	F3	Winds in excess of the design basis were not considered.
Truck vestibule TV-R-07	1-5	Natural phenomena - dust devil	Flying debris Dust	Pressure gradient	Personnel struck by flying debris Visibility reduced Accumulated debris	Personnel injury Operational delays from injury or the need to clear debris that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within the storage tube	The facility provides shelter for workers.		S1	F3	
Truck vestibule TV-R-08	1-5	Natural phenomena - translational missiles, 40 mph; wind loads, 200 mph	Wind pressure Flying debris Dust	Pressure gradient	Personnel struck by flying debris Systems, structures, or components damaged by flying debris (e.g., fire or explosion, falling object, responder, reeling crane)	Personnel injury Restricted access to the facility Operational delays from damaged equipment or the need to clear debris from the facility may result in MCO pressure relief before placement within the storage tube	The facility superstructure is designed to withstand the forces of missiles with tornado missiles and wind loads. The facility provides shelter for workers.	CSB personnel are trained in satellite and facility-specific hazardous materials response that include steps to place the facility in the safest possible condition.	S1	F1	
Truck vestibule TV-R-09	1-5	Natural phenomena - ash fall	Ash loading on roof	Volcanic eruption	Roof collapse Ash intrusion	Personnel injury Equipment damage Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within the storage tube	The building is designed to withstand anticipated ash loadings.		S1	F2	
Truck vestibule TV-R-10	1-5	Natural phenomena - range fire	Windborne embers Smoke	Dry conditions and ignition	Loss of power Reduced visibility Secondary fire caused by flying embers	Personnel injury Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within the storage tube	The facility is designed with non- combustible materials (Type I-N).	The facility controls or clears the vegetation in the vicinity of the CSB to reduce the impact of range fires.	S1	F3	

Table 3-14. Canister Storage Building Hazard Analysis: Truck Vestibule. (sheet 7 of 7)

Location/ checklist entry	Operating sequence/ mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features			Conseq categ	Freq categ	Remarks
							Engineering features		Administrative features			
attendees	Fluor Daniel Northwest	Duke Engineering and Services Hanford, Incorporated	XWest Group	Nurmalco Hanford Corporation	Fluor Daniel, Incorporated	Science Applications International Corporation						

* FES, 1996, Preliminary Safety Analysis Report for Packaging (Canister) Multiple Canister Overpack Coak, HNF-SD-TB-SARP-017, Rev. 0, Rust Federal Services Northwest for Fluor Daniel Hanford, Incorporated, Richland, Washington.
* Garvin, L. J., 1997, Canister Storage Building Safety Analysis Report — Phase 3: Safety Analysis Documentation Supporting Canister Storage Building Construction, HNF-SD-SNF-RPT-004, Rev. 7, Duke Engineering and Services, Incorporated, Richland, Washington.
* Sadanaga, C. T., 1996, Preliminary Fire Hazard Analysis for the Canister Storage Building, HNF-SD-SNF-RHA-002, Rev. 2, DRAFT, DynCorp Tri-Cities Services, Incorporated, for Fluor Daniel Hanford, Incorporated, Richland, Washington.
* Ares, 1996, Canister Storage Building Fire Code Equivalency Evaluation, Report 951107-001, Rev. 0, Ares Corporation, Richland, Washington.
* Ares, 1996, Canister Storage Building Recommended Approach to Fire Protection of the Operating Area of the Canister Storage Building, Report 951107-002, Ares Corporation, Richland, Washington.
* Williams, N. H., 1996, Project M-376, Special Nuclear Fuel Canister Storage Building Request for Exemption from the United States Department of Energy Order 6450.1A — Automatic Sprinkler Protection Requirements (Letter 9555219 to E. D. Sellers, U.S. Department of Energy, Richland Operations Office, November 14), Fluor Daniel Hanford, Incorporated, Richland, Washington.
* Williams, N. H., 1996, Project M-376, Special Nuclear Fuel Canister Storage Building Request for Exemption from the United States Department of Energy Order 3450.7A — Automatic Fire Suppression System Requirements (Letter 9555235 to E. D. Sellers, U.S. Department of Energy, Richland Operations Office, November 14), Fluor Daniel Hanford, Incorporated, Richland, Washington.

ALARA = as low as reasonably achievable.
CAMI = continuous air monitor.
CSB = Canister Storage Building.
CVD = Cold Vacuum Drying Facility.
CO2 = carbon dioxide.
HEPA = high-efficiency particulate air (filter).
HVAC = heating, ventilating, and air conditioning.
MCO = multicanister overpack.
SARP = safety analysis report for packaging.

Table 3-15. Canister Storage Building Hazard Analysis: Service Area. (sheet 1 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
MCO service area SA-E-07	Blocks 14-19	Rotational kinetic - MHM turret	Rolling MHM turret experiences a collision with a lowered MCO or a supporting lifting cable and pneumatic lines of the MHM	- Mechanical failure of the MHM - Failure of the MHM's electrical interlocks - Human error in activating turret rotation	- Shearing forces puncture or rip the MCO resulting in a breach - Shearing forces on the lifting cable and pneumatic lines in the service pit, with no controls or ungrapping capability	- Damage to the MCO center cover hatch - Loss of primary containment (i.e. the MCO) resulting in contamination of the transport cask, service pit, and/or MHM - MHM drive damaged and locked up - Lifting cable and/or pneumatic lines sheared off	- Interlocks (electrical and mechanical) prohibit any horizontal movement, rotation, or lifting of the MCO is loaded but not fully raised. - MHM resolver indicates MCO's relative position within the service pit and/or MHM while it is being raised. - The MHM is provided with backup graphic disengagement capability. - Secondary confinement provided by the MHM-service pit interface with active, HEPA-filtered ventilation.	Personnel are trained to MHM-specific procedures regarding its safe operation.	S2	F1	The design is not yet complete relative to MHM interlocks and permissive switches. ISSUE: Water may be added to the transportation cask void as the MCO is removed to caution a drop in the water level. This is not a baseline and is not considered in this evaluation. (Issue #8)
MCO service area SA-F-05	Blocks 5, 31	Linear kinetic - receiving crane	The receiving crane (with or without a load) experiences a collision	- Human error in moving the receiving crane and its loads - Human error in misloading a load into the receiving crane susceptible to crane impacts - Mechanical failure of the receiving crane - Electrical interlock failure of the receiving crane	- Impact with - The MHM (of particular concern when the MHM is in the service pit or extracting pit MCO from the service pit) - Subsystems placed in the path of the receiving crane - Personnel - Service area enclosure - The 5-ton gantry crane	- Damage to the transport cask - Collapse of receiving crane and damage to operating disk, storage tubes, and MCOs - Damage to facility systems, structures, or components (such as the transport cask yoke) - Damage to the service area enclosure - Damage to the 5-ton gantry crane - Personnel injury - Damaged equipment leads to operational delays that cause the MCO to be delayed in its movement, resulting in MCO pressure relief before placement within the storage tube	- The receiving crane is designed to ASME NCC-1 to preclude tipping. - The "frogs" on the receiving crane's tracks have stops. - Electrical interlocks relative to receiving crane and MHM positioning along their respective tracks preclude the presence of both the MHM and the receiving crane in the service area simultaneously. - The receiving crane has auditory indication of its movement (i.e., alarms). - The receiving crane is limited to relatively slow movement.	Personnel are trained to procedures detailing the safe sequence of operations. These procedures prohibit interferences between the receiving crane and the MHM.	S2	F2	To be considered "S-2", multiple failures must be assumed (e.g., damage to the MCO, the service area enclosure). However, such an assumption may not be a result of common mode failures.
MCO service area SA-F-06	Blocks 14, 15	Linear kinetic - pressure vessel (MCO)	Gases within the MCO reach failure pressure	- Faulty MCO rupture disk or relief valve (occurring at pressures below the design values - 150 lb/in² for the rupture disk and approximately 200 lb/in² for the relief valve) - Damaged MCO rupture disk or relief valve - MCO process ports improperly closed at the CVDF	- Blowdown lifts objects, creating a missile hazard - Excessive noise and sonic effects - Release of contamination (radioactive and gases including hydrogen) from within the MCO	- Missiles damage the service area enclosure (e.g., lighting, ventilation, material) or other equipment - Missiles, excessive noise, and releases injure personnel - Contamination resulting in personnel doses - Flammable atmosphere within the service area enclosure - Operational delays that cause the MCO to exceed its allowable transport window, may result in further MCO pressure relief	- The MCO rupture disk is protected by design (it is recessed and is protected by a steel plate). - The rupture disk plate inhibits missile generation (i.e., from pieces of disk being expelled). - The MCO relief valve is recessed and contains a HEPA filter. - The service area enclosure provides secondary confinement with active, HEPA-filtered ventilation.	- CVDF personnel are trained in the proper procedures for closing the MCO process ports. - A pressure test is performed on the transport cask before the lid is closed. This prevents releases associated with exposing an MCO that has already experienced pressure relief.	S1 for MCOs under nominal pressure S2 for MCOs under rupture disk and relief design pressures	F2 F1	Although this event could occur before or after the listed process features are in place at these times. Therefore, blocks 14 and 15 represent the most conservative situation for review.

Table 3-15. Carister Storage Building Hazard Analysis: Service Area. (sheet 2 of 10)

Location/ checklist entry	Operating sequence/ mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
MCO service area SAF-07	Blocks 19-24	Linear kinetic - MHM lateral movement	MHM collision creates a shearing force (at floor level) on a lowered MCO causing damage to lifting cable and pneumatic lines of the MHM	Human error in moving the MHM Human error in mislocating equipment where it is susceptible to MHM impacts Personal Mechanical failure of the MHM Electrical interlock failure of the MHM	Collision with - The receiving crane - Subsystems placed in the path of the MHV - Personnel - Service area enclosure - The 5-ton gantry crane Shearing forces puncture or rip the MCO, resulting in a breach Shearing forces on the lifting cable and pneumatic lines cause the MCO being stuck in the service pit, with no controls or ungrappling capability	Damage to facility systems, structures, or components (e.g., receiving crane, service area enclosure, 5-ton gantry crane) Personnel injury Damage to the MCO center cover hatch Loss of primary containment (i.e., the MCO) resulting in contamination of the transport cask, service pit, and/or MHM Loss of secondary containment (i.e., the MHM) MHM drive damaged and locked up Lifting cable and/or pneumatic lines sheared off Damaged equipment may lead to operational delays that cause the MCO to exceed its available transport window for placement within the storage tube	The MHM is designed to ASME NCC-1 to preclude tipping. The "Trops" on the MHM's tracks have stops. Electrical interlocks relative to the receiving crane and the MHM prevent the MHM from moving along its tracks while the presence of both the MHM and the receiving crane in the service area simultaneously. The MHM has auditory indication of its movement (i.e., alarms). The MHM has a collision avoidance system that detects obstacles to its movement. The MHM is limited to relatively slow movement. Interlocks (electrical and mechanical) prohibit any horizontal movement, linear or rotational, while an MCO is loaded but not fully raised. The MHM resolver indicates the MCO's relative position within the service pit and/or MHM while it is being raised. The MHM is provided with backup grapple disengagement capability.	Personnel are trained in procedures detailing the safe sequence of operations. These procedures prevent interferences between the receiving crane and the MHM. Personnel are trained in MHM- specific procedures regarding its safe operation.	S-2	F-2	To be considered "S-2," multiple failures must be assumed (e.g., multiple failures of the same area enclosure). However, such failures may be credible as a result of common mode failures. The design is not yet complete relative to MHM interlocks and permissive switches. ISSUE: Water may be added to the transportation cask void as the MCO is removed to cushion a drop. This is not part of the current baseline, and is not considered in this evaluation. (Issue #8) ISSUE: It is currently unclear to the hazards analysis team whether the frog stops are adequate to stop the receiving crane or the MHM. (Issue #6) ACTION ITEM: The design calculations for frog stops relative to the receiving crane and the MHM must be verified. (Action item #28)
MCO service area SA-G-01	Blocks 9-18	Mass, gravity, height - human effort	Dropped equipment (e.g., slings, bolts, tools)	Human error resulting in bolts or other items being dropped from the service area, and more importantly, in the service pit	Breach MCO primary containment (by breaking a relief valve or puncturing a rupture disk) Tripping hazard Items dropped into the service pit between the MCO and transportation cask may cause slaking or galling of the MCO as it is lifted	Breach of the MCO may cause missile damage to the service area enclosure (e.g., lighting, ventilation, material) or other equipment because of possible MCO pressure vessel blowdown A resultant blowdown also has the potential for personnel injury caused by missiles, excessive noise, and contamination releases Gas releases from a resultant blowdown to the service area may result in a potential for a flammable atmosphere within the service area enclosure Tripping hazards may cause personnel to fall into the service pit Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within a storage tube	The immediate area around the service pit is inspected and cleaned before lifting the cask lid. Personnel are trained in procedures that identify the proper operational steps to be performed within the service area enclosure.	S-2	F-3		

Table 3-15. Canister Storage Building Hazard Analysis: Service Area. (sheet 3 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
MCO service area SAG-03a	Blocks 6-18	Mass, gravity, height - 5-ton gantry crane	Small parts from the gantry fall into the service area, and more importantly, into the service pit	Human error	Breach of MCO primary confinement (by breaking a cover plate or puncturing a rupture disk) Items dropped into the service pit between the MCO and the MCO grapple may cause sticking or galling of the MCO as it is lifted	A breach of the MCO may cause missile damage to the service area enclosure (e.g., lighting, ventilation, material) or other equipment because of possible MCO pressure vessel blowdown A resultant blowdown also has the potential to cause damage from missiles, excessive noise, and contamination releases Gas releases from a resultant blowdown to the service area may result in a potential for a flammable atmosphere within the service area enclosure Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within a storage tube	The MCO ports are protected from damage by cover plates. A load cell on the MHM grapple assembly monitors the resistance force of the MCO as it is being removed. This will detect sticking or excessive forces before they become destructive. The service pit is normally covered with either a pit cover or a shield hatch assembly.	Procedures detail maintenance of the 5-ton gantry crane.	S2	F3	
MCO service area SAG-03b	Blocks 19-24	Mass, gravity, height - 5-ton gantry and service area enclosure linear movement	5-ton gantry or service area enclosure collision	Human error (in mislocating equipment in the path of the gantry or service area enclosure) Human inattention Crane failure	Collision with: • Equipment • Personnel • Transportation cask lid • The shield hatch assembly	Damage to the service area enclosure Damage to the gantry crane Personnel injury Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within a storage tube	The 5-ton gantry crane and service area enclosure have a limited movement area. They operate inside the span of both the MHM and the receiving crane rails. The 5-ton gantry crane is limited to a relatively slow movement, and the service area enclosure is moved manually. The crane and service area enclosure have been designed to prevent tipping.	Personnel are trained to operate the gantry and service area enclosure according to facility-specific procedures, which include related equipment and related gantry crane and service area enclosure movement.	S1	F3	
MCO service area SAG-13	Blocks 4, 5, 31	Mass, gravity, height - vessels (transportation cask, MCO)	A drop of the transportation cask or MCO without a loaded receiving crane	Human error (either in rigging the yoke for the transportation cask or in forcing a release from the MHM) Mechanical failure of the receiving crane or MHM	The transportation cask could impact either the facility floor or the bottom of the service pit if the MCO is not properly MCO impact to either the bottom of the transportation cask in the service pit or the hatch in the MHM	A drop of the transportation cask results in damage to the cask or damage to the MCO resulting in a release of gas or relief valve) results in a release of gas and contamination from the MCO A drop of the MCO results in damage to the MCO pressure vessel and the MCO, significant damage to the MCO (such as the failure of the rupture disk or relief valve) could result in a release of gas and contamination from the MCO	The drying process at the CVDF provides a calculated transport window in which MCO operations are completed. This will ensure MCO release are relatively low during the receiving process. Personnel are trained to facility- specific procedures in the proper handling of the transportation cask, MCO, receiving crane, and MHM.	S2	F2	During any postulated event, secondary confinement is maintained around the spent fuel the transportation cask for a cask drop and the MCO service pit interface for an MCO drop). ACTION ITEM: An analysis of a cask/MCO drop into the service pit must be conducted, and may result in a requirement for an impact limiter in the service pit. (Action Item #51)	

Table 3-15. Canister Storage Building Hazard Analysis: Service Area. (sheet 4 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Freq categ	Remarks
							Engineering features	Administrative features		
MCO service area SAH-05	Blocks 4, 5, 31	Pressure, volume - gas bottles (backup inert gas supply on the MHM)	An uncontrolled release of high pressure gas from the inert gas bottles on the MHM	Broken or damaged/regulator valve, or a gas bottle breach	An overpressurization of the MHM while transporting an MCO The gas bottle (or its components) becomes a missile hazard The gas bottle hose causes a whipping hazard An overpressurization of the seals between the MHM hose piece and the floor during MCO removal from the transportation cask A loss of backup inert gas for the MHM	Higher than normal external pressures applied to an MCO Containment releases through the floor seals while an MCO is being removed from the transportation cask (the cask interior is expected to contain small levels of contamination) Personnel injury from whipping and missile hazards Damage to facility structures, systems, or components from missile hazards Operational delays that cause the MCO to be placed in storage prior to its placement within a storage t-33	The bottle rack on the MHM is designed to seismic qualifications. The MHM is designed with a "low pressure" panel to relieve excessive pressures. The transporter and transportation casks are designed to survive specific drops and punctures that should bound this hazard.	S1	F2	The backup inert gas supply for the MHM provides a 12-hour supply of inert gas.
MCO service area SAH-06	Blocks 4, 5, 31	Pressure, volume - (MCO and MCO-transportation cask system)	Uncontrolled release of high pressure under pressure within the MCO	A process delay that causes the calculated transport window before placement in a storage tube Improper or insufficient conditioning performed on the MCO before its receipt at the CSB Failure of the MCO relief valve because of manufacturing flaws or damage Failure of the MCO rupture disk because of manufacturing flaws or damage Improper closing of the MCO process ports at the CVDF	MCO rupture disk rupture Pressurized gases released from the MCO Failure of the rupture disk at manufacturing flaws or damage Transportation cask releases pressurized gases because of: - A leak in the seal lid - Drain port ball valve failure - Vent port failure	The MCO rupture disk is designed to survive seismic events with a recessed location and a protective steel plate to minimize the potential for damage. The relief valve is recessed to minimize the potential for damage. The relief valve contains a HEPA filter to prevent the release of radioactive particulate release. The service area enclosure provides additional secondary containment in event of MCO pressure release. Hydrogen and small amounts of fission gases released to service area (possible without radioactive particulate if the MCO relieves pressure through a HEPA-filtered vent). If a transportation cask releases its contents following an MCO reseat/breach, or the MCO release occurs after the seal lid is closed, several consequences are possible: - Hydrogen and small amounts of fission gases released to service area (possible without radioactive particulate if the MCO relieves pressure through a HEPA-filtered vent). - The resulting hydrogen could lead to the development of flammable atmosphere in service area - Radioactive particulate released to the service area - Personnel contamination from radioactive and/or hazardous material releases from the transportation cask - The service area enclosure (including lighting, fabric, and the ventilation system) or core facility systems, structural components damaged by missile effects - Personnel injury from excessive noise or missile effects - Operational delays could result from any of these consequences	Personnel are trained to facility-specific procedures in the proper installation and maintenance of gas bottles on the MHM. The drying process at the CVDF overpressurization is precluded. This will ensure MCO pressures are primarily low during the receiving process.	S2	F2	The hazards analysis team reached a general consensus that "pressure release" would be considered as high of a level of operational safety as would be achieved if the MCO were continuously vented through transportation cask. This would greatly reduce the potential for sudden high-pressure releases.

Table 3-15. Canister Storage Building Hazard Analysis: Service Area. (sheet 5 of 10)

Location/ checklist entry	Operating sequence/ mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
MCO service area SA-H-06	Blocks 4, 5, 31	Pressure, volume - gas receivers (MHM primary inerting system) (120 lb/in ² fission cable) (80 lb/in ² MCO service line)	Uncontrolled release of high pressure gas from the inert gas supply to the MHM	Broken or damaged regulator valve Broken or damaged relief valve Fitting failure Supply line failure caused by impact from an outside source	Overpressurization of the MHM while transporting an MCO Overpressurization of the MHM caused by gas leakage from the MCO removal from the transportation cask Missile hazards Cryogenic burns Sonic effects Air introduced into the MHM interior (refer to SA-J-10) Fission cable causes a whipping hazard Potential for asphyxiation exists if the inert gas is argon	Higher than normal external pressures applied to an MCO Contamination releases through the floor seals while an MCO is being removed from the transportation cask (the cask interior is expected to contain small levels of contamination) Personal injury from whipping and missile hazards Damage to facility structures, systems, or components from missile hazards Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within a storage tube	The design of the supports for the fission cable includes greater than MCO weight and the inert gas supply supports per final foot. The MHM is designed with a blow out panel to relieve excessive pressures. The MHM and MCO have a robust design that allows them to withstand high levels of pressure or stress.	Personnel are trained to facility- specific procedures in the proper removal of the inert gas supply from the MHM.	S1	The consequence and frequency does not address multiple failures except when operational delays result in a MCO being in the transportation window. In this case, the relief valve may be actuated. No damage was assumed to occur to the MCO. No automatic shutoff feature is described into the inert gas supply system (and is not required by national codes).	
MCO service area SA-J-06	Blocks 14-18	Explosives or Pyrophorics - hydrogen	A flammable hydrogen-air mixture and an ignition source, causing combustion	Relief valve actuation or disk rupture	Deflagration or detonation may occur within the service pit and/or the service area enclosure, the pressure from this event may cause the center of the shield hatch assembly to lift slightly	Spread of contamination Personnel injury from burns Damage to nearby facility systems, structures, or components Operational delays	The transportation cask occupies the volume of the service pit, reducing the total volume of available air when the service pit is covered. The MCO pressure relief valve is HEPA filtered to minimize the potential for contamination spread. The service area enclosure, in conjunction with its active ventilation, will sweep the service area enclosure of hydrogen, minimizing the potential to form flammable mixtures. The shield hatch assembly will provide secondary confinement.	The drying process at the CVDF provides a calculated transport window in which MCO overpressurization is precluded. This will ensure MCO pressures are relieved low during the receiving process. No smoking is allowed within the facility.	S3	F1	
MCO service area SA-J-10	Blocks 4, 5, 31	Explosives or pyrophorics - plutonium and uranium metal, Zirconium	Pyrophoric material exposed to air and sufficient surface area and temperature are present	MCO breach Human error in failing to inert the MCO	Pyrophoric material ignites	Personnel injury Contamination release Damage to the MCO	The structural design of the MCO is such that breaches have a very low probability of occurring. Penetrations into the MCO are limited in size to reduce the rate of air flow into the MCO.	CVDF personnel will be trained according to CVDF-specific procedures regarding the inerting process for the MCO before shipment to the CSB.	S3	F1	F-1 was selected until the potential for air ingress (such as through a relief valve) is evaluated. It may then be changed to F-0.
MCO service area SA-K-01	Blocks 36-43, 53-62	Nuclear criticality - vaults					CSB cannot be flooded by rain or a water main break	General training of operators; operators will not disassemble an MCO		F0	This hazard is addressed in HNF-SD-SNF-RPT-004, Chapter 6.0; no new hazards were identified.
MCO service area SA-K-04	Blocks 36-43, 53-62	Nuclear criticality - filters (cart and tube plug)					CSB cannot be flooded by rain or a water main break	General training of operators; operators will not disassemble an MCO		F0	This hazard is addressed in HNF-SD-SNF-RPT-004, Chapter 6.0; no new hazards were identified.

Table 3-15. Canister Storage Building Hazard Analysis: Service Area. (sheet 6 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
MCO service area SA-K-05	2-4	Nuclear criticality - casks					CSB cannot be flooded by rain or a water main break	General training of operators; operators will not disassemble an MCO	F0		Addressed in HNF-SD-SNF-RPT- 004, Chapter 6; no new hazards identified.
MCO service area SA-K-12	Blocks 36-43; 53-62	Nuclear criticality - casks and lifts					CSB cannot be flooded by rain or a water main break	General training of operators; operators will not disassemble an MCO	F0		This hazard is addressed in HNF-SD-SNF-RPT-004, Chapter 6.0; no new hazards were identified.
MCO Service Area SA-L-06 SA-L-11 SA-L-13 SA-L-15		Flammable materials - buildings and contents (service area enclosure) Hydrogen Oxygen (enclosure material)									These hazards are addressed by the preliminary fire hazards analysis. ¹ Refer also to the white papers on occupational and environmental health decision and exemption request letters ¹ t that cover this topic.
MCO service area SA-M-07	Blocks 14, 15	Hazardous materials - boxes (plutonium, uranium, beryllium, heavy metals)	Release of toxic materials entrained in pressurized gases within the MCO	A process delay that causes the MCO to remain in calculated transport window before placement in a storage tube Improper or insufficient conditioning performed on the MCO before its receipt at the CSB Failure of the MCO relief valve because of manufacturing flaws or damage Failure of the MCO rupture disk because of manufacturing flaws or damage	MCO rupture disk ruptures and releases toxic materials Excessive pressures within the MCO Failure of the rupture disk at lower pressures (because of manufacturing flaws or damage)	An MCO release inside the cask, by the MCO rupture disk, releases beyond contamination of the transportation cask with toxic materials (recovery actions are dealt with contains the release If a transportation cask releases its contents following an MCO release or MCO rupture disk failure, the release while the transportation cask lid is removed, toxic materials could be released to the service area	The MCO rupture disk is designed to rupture at a pressure above the increased location and a protective steel plate to minimize the potential for damage. The relief valve is necessary to minimize the potential for damage. The relief valve contains a HEPA filter to prevent the release of toxic particulate releases. The service area enclosure provides containment in the event of MCO pressure release. The shield hatch assembly provides containment in the event of an MCO that has already experienced pressure relief.	Personnel are trained to facility, MCO process ports, and MCO shipping, movement, and handling. The drying process at the CVDF plant, at which MCO transport overpressurization is precluded. This will ensure MCO pressures are relatively low during the receiving process. CVDF personnel are trained in the proper procedures for closing the MCO process ports. A pressure test is performed on the transport cask before the lid is removed. This prevents toxic materials from escaping an MCO that has already experienced pressure relief.	S2	F3	Although this event could occur inside or outside the MCO process blocks, different MCO features are in place at these times. Therefore, blocks 14 and 15 represent the most conservative situation for review.

Table 3-15. Canister Storage Building Hazard Analysis: Service Area. (sheet 7 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
MCO service area SAN-01 SAN-03	Blocks 14, 15	Ionizing radiation sources - fissile and radioactive material	Contact exposure Release of fissile and/or radioactive material pressurized gases within the MCO	A process delay that causes the MCO to exceed its allowable pressure before placement in a storage tube Improper or insufficient conditioning performed on the MCO before its receipt at the CSB Failure of the MCO relief valve because of manufacturing flaws or damage Failure of the MCO rupture disk because of manufacturing flaws or damage Improper closing of the MCO process ports at the CVDF	MCO rupture disk ruptures and releases fissile or radioactive materials Excessive pressures within the MCO Failure of the rupture disk at lower pressures (due to manufacturing flaws or damage)	An MCO release inside the cask, by itself, has no safety consequences beyond contamination of the transportation cask with fissile/radioactive materials. Recovery actions are dealt with separately; the transportation cask contains the release contents following an MCO release or breach, or the MCO release occurs after the cask is sealed and is removed. Fissile and/or radioactive materials could be released to the service area. Contamination spread during MWM or tube plug servicing at the maintenance pit	The MCO rupture disk is designed with protective features such as a recessed location and a protective cover to minimize the potential for damage. The relief valve is recessed to minimize the potential for damage. The relief valve contains a HEPA filter to minimize the potential for radioactive particulate releases. The service area enclosure provides containment in the event of MCO pressure release. The shield hatch assembly provides secondary confinement when the service area enclosure is moved away.	Personnel are trained to facility- specific procedures regarding MCO shipping, movement, handling, and the radiological control. The drying process at the CVDF provides a calculated transport allowance within MCO pressure envelopes. This will ensure MCO pressures are relatively low during the receiving process. CVDF personnel are trained in the proper procedures for closing the MCO process ports. A pressure test is performed on the transport cask before the lid is removed. This prevents fissile and radioactive releases associated with cask lid removal and already experienced pressure relief.	S2	F3	Although this event could occur before or after the listed process blocks, additional confinement features are in place at these locations and the event would represent the most conservative situation for review.
MCO service area SAN-04	Blocks 36-43, 53-62	Ionizing radiation sources - radiation source	Exposure to direct radioactive shine	Direct shine associated with MCO during transfer	Shine from MCO during transport if MWM shield skirt is not in place	Worker exposure caused by shine from MCO during transfer	MWM, shielding		S1	F1	
MCO service area SAP-01	Blocks 5-31	External events - explosion	External explosion resulting in a shock wave introduces dust, heat, and/or projectiles into the service area	Explosion of nearby gas delivery truck, or gas station	The shock wave from the explosion impacts the building Flying debris hits personnel Workers exposed to heat from the explosion	Structural damage or failure Transportation cask drop from the receiving crane Personnel injury from flying debris Operational delays could result from structural damage, personnel injury, or a transportation cask drop or from the need to restrict the facility; delays that could impact the MCO release pressure relief before placement within the storage tube	The CSB is isolated from major roads, reducing the possibility of impacts outside the facility from affecting the CSB. The facility structure is designed to withstand significant external phenomena (e.g., tornado missiles, straight winds). The transporter and transportation cask are designed to survive external events without hazardous or radioactive material release. ¹	CSB personnel are trained in facility-specific procedures regarding emergency response procedures that include steps to place the facility in the safest possible condition.	S2	F2	For additional details on the hazards associated with a dropped cask, refer to TV-G-13, Mass, gravity, height, & results. ²
MCO service area SAP-02	Blocks 5-31	External events - fire	External fire introduces heat and smoke into the service area (low visibility)								Based upon the current design, there is no external energy source that would have greater consequences than a fire inside the facility. These hazards are addressed by the preliminary fire hazards analysis. ³ Refer also to the white papers on occupational classification ² and the deviation and exemption request letters ⁴ that cover this topic.

Table 3-15. Canister Storage Building Hazard Analysis: Service Area. (sheet 8 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
MCO service area SA-R-03	Blocks 5-31	External events - nearby facilities	Radioactive material, and direct radiation introduced into the facility	Descriptions of potential accidents at nearby facilities and their resulting consequences are addressed in Chapter 1.0 of HNF-SD- SNF-RPT-004."	Descriptions of potential accidents at nearby facilities and their resulting consequences are addressed in Chapter 1.0 of HNF-SD- SNF-RPT-004."	Personnel exposure to radioactive and toxic material from the nearby facility Contamination of the CSB from nearby facility releases potentially making the building uninhabitable Operational delays could occur as a result of a need to evacuate the facility or take cover; delays that cause the MCO to exceed its available transport window could result in a need for relief before placement within the storage tube	The distance of the CSB from other facilities and the shielding the facility provides reduces the consequences of external events on the CSB.	CSB personnel are trained in sitewide and facility-specific emergency response procedures that include steps to place the facility in the safest possible condition.	S2	F1	
MCO service area SA-R-01	Blocks 5-31	Natural phenomena - earthquake (equal to or less than the DBE)	Excess vibration on the facility from lateral and horizontal accelerations	Earthquake	Structural damage or collapse Damage to facility systems, structures, or components (e.g., receiving crane, cable trays, WHM) Damage to the transportation cask or MCO (while in cask, service pit, or WHM) Relief valve actuation on the MCO	Personnel injury Release of radiation from a breached MCO Loss of facility power Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within the storage tube	The facility (including both the facility structure and systems) such as the transportation cask and MCO are designed with consideration of impacts to safety systems from the failure of non-safety systems. The CSB is built to appropriate seismic criteria.	CSB personnel are trained in sitewide and facility-specific emergency response procedures that include steps to place the facility in the safest possible condition.	S2	F2	
MCO service area SA-R-03	Blocks 5-31	Natural phenomena - lightning	High electrical energy	Lightning strike	Strike on the facility	Loss of power Damage to systems, structures, or components Personnel injury Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within the storage tube	The CSB facility is equipped with lightning protection that includes lightning rods, grounding, and ground fault detectors. The facility provides shelter for workers.	CSB personnel are trained in sitewide and facility-specific emergency response procedures that include steps to place the facility in the safest possible condition.	S2	F2	
MCO service area SA-R-04	Blocks 5-31	Natural phenomena - rain	Water intrusion into the service area	Leaks through the roof Volume of rain exceeds the capacity of the drainage system and drainage system to carry off rainwater	Water in electrical systems such as cable trays or receiving crane components Flooded floors (including service pit)	Personnel injury caused by slips Loss of power Loss of equipment or personnel injury from electrical shorts Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within the storage tube	The facility is designed to prevent water intrusion and to provide shelter for workers. The receiving crane is designed to minimize the potential for water intrusion into its electrical components. The electrical design within the facility minimizes potential consequences (electrical conduit inhibits the spread). The site grading is designed to prevent rain intrusion into the facility. The facility design takes into consideration the need for tactile (non-skid) surfaces.		S1	F1	

Table 3-15. Canister Storage Building Hazard Analysis: Service Area. (sheet 9 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Consq categ	Freq categ	Remarks
							Engineering features	Administrative features			
MCO service area SA-R-05	Blocks 5-31	Natural phenomena - snow, freezing weather	Snow loading Extreme cold	Snow storm, cold weather	Roof collapse	Personnel injury from collapsed roof or cold exposure Ice buildup Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within the storage tube	The building is designed to withstand anticipated snow loads. The service area is heated. The facility provides shelter for workers.	The MCO shipping is prohibited during adverse weather conditions. ^	S2	F3	ACTION ITEM: The Safety Analysis Report for Packaging definition of adverse weather conditions when established, will be included here (Action Item #64)
MCO service area SA-R-06	Blocks 5-31	Natural phenomena - straight wind	Wind pressure Flying debris Dust	Pressure gradient	Personnel may be struck by flying debris. Systems, structures, or equipment damaged by flying debris Visibility reduced Debris accumulates	Personnel injury Restricted access to the facility Operational delays could arise from damaged equipment that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within the storage tube	The facility structure is designed to withstand a 200 mph wind. The facility provides shelter for workers.		S1	F3	Winds in excess of the design basis were not considered. The consequences of this phenomenon are less than they were in the truck vestibule. This area is less susceptible to straight winds.
MCO service area SA-R-06	Blocks 5-31	Natural phenomena - 160 mph rotational, missiles, 40 mph, wind loads, 200 mph)	Wind pressure Flying debris Dust	Pressure gradient	Personnel struck by flying debris Systems, structures, or components damaged by flying debris (e.g., receiving crane, MCM service area enclosure) A tornado missile strikes MCO in the service pit while the crane is removed and the shield base assembly is not yet installed Visibility reduced Debris accumulates	Personnel injury Restricted access to the facility Operational delays could arise from damaged equipment or the need to clear debris; delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within the storage tube	The facility superstructure is designed to withstand the forces of design basis tornado missiles and wind loads. The facility provides shelter for workers. A probability analysis for the vulnerability of all safety-class systems to tornado missiles shows that it is incredible for a tornado missile to strike the safety class systems within the CSS.	CSS personnel are trained in shelter and facility-specific emergency response procedures that include steps to place the facility in the safest possible condition.	S3	P0	
MCO service area SA-R-06	Blocks 5-31	Natural phenomena - ashfall	Ash loading on roof	Volcanic eruption	Roof collapse Ash intrusion	Personnel injury Equipment damage Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within the storage tube	The building is designed to withstand anticipated ash loadings.		S1	F2	
MCO service area SA-R-10	Blocks 5-31	Natural phenomena - range fire	Windborne embers Smoke	Dry conditions and ignition	Loss of power Reduced Visibility Secondary fire from flying embers	Personnel injury Operational delays that cause the MCO to exceed its available transport window may result in MCO pressure relief before placement within the storage tube	The facility is designed with esp- combustible materials (Type II, IV).	The facility controls and clears the vegetation within the SSP to reduce the impact of range fires.	S2	F3	The service area is less vulnerable to range fires than the truck vestibule because of the fire protection in the area of loss of power.

T3-45

July 1997

CSB = Canister Storage Building.
CVDF = Cold Vacuum Drying Facility.
DBE = design basis earthquake.
HEPA = high-efficiency particulate air (filter).
MCO = multicarrier overpack.
MHM = multicarrier overpack handling machine.

Table 3-16. Canister Storage Building Hazard Analysis: Operating Area. (sheet 1 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
CSB operating area OAE-07	Blocks 35-62	Thermal - radioactive chemical reaction	Hot gases Hot surface (below standard plug cover assembly)	Decay heat and chemical reactions	Exceeding the design temperature of the MCO	Operational delays that cause an MCO to exceed its available transport window to the storage tube. Initial placement within a storage tube Equipment failure (e.g., storage tube seals, service cart components) Personnel injury Leakage criteria on MHM exceeded Leakage criteria of tube plug seals exceeded	MHM and storage tube are designed to withstand MCO's with temperatures of 270 °F (seals, cooling and venting system). Tube plug design seals with a test feature. The service cart sampling line includes equipment that measures the temperature of storage tube seals, providing an alarm if excessive temperatures are detected.	Procedures define the types of personal protective equipment that must be worn to protect against high temperatures on exposed surfaces. Each time the tube plug is installed, it is tested to verify seal integrity.	S2	F1	
CSB operating area OAE-01	Blocks 35, 42-45, 52-54, 61-62	Corrosives - acids (cart battery, rechargeable)	Leaking battery	Cracked battery case Overfill Overcharge Faulty battery	Acid leak on plug seals Acid on the floor Acid on personnel Acid on cart and cart equipment and electrical systems	Leaking seal Corroded floor Personnel injury Failure of cart and/or cart equipment and systems Electrical shorts		Periodic maintenance includes battery inspection. "Never-dill" batteries used (TBD). Written charging procedures used. Reputable battery vendor used.	S2	F1	ISSUE: The service cart design is not finalized. When it is, the hazardous analysis needs to evaluate future potential hazards. (Issue #19)
CSB operating area OAE-07	Blocks 37-39, 47-49, 56-58	Rotational kinetic - MHM turret	Rotating MHM turret creates a shearing force (a shearing force is created between the floor and the lowered MCO or its supporting lifting cable and pneumatic lines	Mechanical failure of the MHM Failure of the MHM's electrical interlocks Human error in activating turret rotation	Puncture or rip of the MCO resulting in a breach Shearing forces on the lifting cable and/or pneumatic lines result in the MCO being stuck in the storage tube with no controls or ungrappling capability An impact absorber being lowered into the storage tube is destroyed leaving pieces of the impact absorber in the storage tube	Damage to the MCO center cover hatch Loss of primary containment (i.e., the MCO) with contamination of the storage tube and/or MHM MHM drive damaged and locked up Lifting cable and/or pneumatic lines sheared off Operational delay to clean out pieces of an impact absorber	Interlocks (Electrical and Mechanical) are present that prohibit any horizontal movement, linear or rotational, while an MCO is loaded but not fully raised. MHM resolver indicates MCO's relative position within the storage tube and/or MHM while it is being lowered or raised. The MHM is provided with backup grappling disengagement capability. Secondary confinement provided by the MHM-tube plug interface is present at all times, with active, HEPA-filtered, ventilation.	Personnel are trained to MHM- related procedures regarding its safe operation.	S2	F1	ISSUE: The design of MHM interlocks and pneumatic lines is not yet complete. (Issue #6) It is assumed that secondary confinement is maintained.

Table 3-16. Canister Storage Building Hazard Analysis: Operating Area. (sheet 2 of 10)

Location/ checklist entry	Operating sequence/ mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
CSB operating area OAF-02	Blocks 35, 42-45, 52-54, 61-62	Linear kinetic - forklifts, dollies, carts (service cart and trailer)	Moving equipment	Personnel error Equipment failure	Impact with personnel Impact with other carts Impact with the crane and/or MHM Impact with the plug cover assembly Severed electrical cord supplying services on cart Damage to electrical cord, pulling it out Spill of hazardous material (oil, water, fuel)	Damage to equipment Personnel injury Operational delays Delay to specific operations (drawing a vacuum or pressurizing a storage tube) Spills getting to tube plug seals Broken purge and/or vent lines while connected to MCO	The cart speed has governors The service cart has brakes	Personnel are trained in the safe use of the service carts, forklifts, and other moving equipment.	S1	F3	
CSB operating area OAF-07	Blocks 36, 45, 46, 51, 55, 60	Linear kinetic - MHM lateral movement	MHM Impact; Mezco MHM creates a shearing force (at floor level) on the MCO or the MCO lifting cable and pneumatic lines of the MHM	Human error in moving the MHM Human error in misloading equipment where it is susceptible to MHM impacts Mechanical failure of the MHM Electrical interlock failure of the MHM	Impact with - Carts - Personnel - Misplaced equipment Puncture or rips of the MCO resulting in a breach Shearing forces on the lifting cable and/or the MCO result in the MCO being stuck in the storage tube with no controls or ungrappling capability	Personnel injury Damage to systems, structures, or components (e.g., service carts, MHM) Damage to the MCO center cover hatch Loss of primary containment (i.e., the MCO) and contamination of the storage tube and/or MHM MHM drive damaged and locked up Lifting cable and/or pneumatic lines sheared off Operational delays that cause the MCO to exceed its allowable dwell time result in MCO pressure relief before placement within the storage tube	Design of MHM is executed to cool the MCO for a long time The MHM is designed to ASME NCC-1 to preclude tipping. The "Trough" on the MHM's tracks have stops. Electrical interlocks relative to receiving crane and MHM positioning along their respective tracks preclude the presence of both the MHM and the receiving crane in the service area simultaneously. The MHM has auditory indication of its movement (i.e., alarms). The MHM has a collision avoidance system that detects obstacles to its movement. The MHM is limited to relatively slow movement. Interlocks (electrical and mechanical) prohibit any horizontal movement, linear or rotational, while an MCO is loaded but not fully raised. MHM resolver indicates MCO's relative position within the storage tube and/or MHM while it is being lowered or raised. The MHM is provided with backup grapple disengagement capability.	Personnel are trained to procedures detailing the safe sequence of operations. These procedures prohibit interferences between the receiving crane and the MHM. Personnel are trained to MHM- specific procedures regarding its safe operation.	S2	F2	The design of MHM interlocks and positioning features is not yet complete. ISSUE: It is currently unclear to the design team if the MCO and the MHM stops are adequate to stop after the receiving crane or the MHM. (Issue #6) ACTION ITEM: The design calculations for MHM stops relative to the receiving crane and MHM must be verified. (Action item #29)

Table 3-16. Canister Storage Building Hazard Analysis: Operating Area. (sheet 3 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
CSB operating area OAG-13	Blocks 36-38 SS-61	Mass, gravity, height - released (MCO)	MCO falling	Human error Mechanical failure (Would take multiple failures with mechanical and human error)	MCO impacts • MWM tumble • Top and sides of storage tube • Bottom impact absorber • Other MCO in the tube (Double failure if impact absorber not installed) MCO rupture disk ruptures Relief valve discharges Relief valve damaged	Damage to storage tube Damage to the MWM tumble Damage to the MCO (significant damage to the MCO, such as the failure of the relief valve, could result in a release of gas and contamination from the MCO) Damage to relief valve filter Damage to grapple point (inability to remove damaged MCO) Damage to MCO relief valves, valve ports, rupture disk Rublized contents Mark IA fuel basket centering tube moved off center	Impact absorbers, both bottom and intermediate The MCO is designed to survive a 2- ft drop onto an unyielding surface and a drop from any credible height within the CSB onto an impact absorber. The MWM grapple is designed such that it cannot release while a load is being suspended from it. For MCO retrieval, a pre-retrieval evaluation of the storage tube to represent the MCO is performed. The pre-retrieval evaluation also provides an indication of the susceptibility of the MCO to releases.	Personnel are trained to facility- specific procedures in the proper handling of the transportation task, MCO, receiving crane, and MWM. The drying process at the CVDF provides a calculated transport time for the MCO. The drying overpressure is prohibited. This will ensure MCO pressures are relatively low during the receiving process.	S2	F2	
CSB operating area OAG-14	Blocks 35-42 SS-61	Mass, gravity, height - dropped • Tube plug • Impact absorber • Cover plate assembly • Seel ring • Rigging equipment	Kinetic energy	Human error Equipment failure	Personnel injury Dropped plug Dropped impact absorber Dropped cover Dropped rigging gear, tools, lifting and handling equipment	Plug seal damage Tube sealing surface damage Damaged embuds Scratched tube Damage to impact absorber Impact absorber stuck in tube Damage to top of tube plug Damage to sealing surface (possible deformation)	The MWM grapple is designed such that it cannot release while a load is being suspended from it. Lifting devices used at the CSB are designed to handle the loads they will carry.	Personnel are trained to facility- specific procedures in the proper handling of the receiving crane and MWM.	S1	F2	

Table 3-16. Canister Storage Building Hazard Analysis: Operating Area. (sheet 4 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
CSB operating area OAH-06a	Blocks 38-43 53-62	Volume, pressure - pressure vessels (MCO)	Gases under high pressure reach release pressure	Excessive gas generation in MCO Inadequate conditioning at CVD Faulty relief valve Faulty rupture disk Damaged relief valve Faulty rupture disk Improperly closed ports at the CVD	MCO rupture disk ruptures MCO relief valve discharges Deflagration MCO exists in: - MCM until inserted in tube - In tube and MCM when removed to go to RCS - In MCM coming back from RCS - In tube after hot conditioning (At no time is MCO outside of a secondary confinement) Sufficient pressure in tube to lift tube plug after plug hold pressure is maintained and before MCM is in place	Contaminated personnel (during plug blowout potential scenario) Personnel injury Spread of contamination Contamination of storage tube sonic damage to ears Operations delay Potential flammable atmosphere (during plug blowout scenario)	Relief valve design (has HEPA) Secondary confinement (MCM and tube) provided Inert environments established in the MCO and storage tube, with periodic relieving of the storage tube	Drawing a vacuum in the storage tube before removing plug.	S2	F3	
CSB operating area OAH-06b	Blocks 38-43, 53-62	Volume, press., - pressure vessels (storage tube)	Hot gases under pressure reach release pressure	MCO relief valve relieves Rupture disk ruptures Failed MCO Excessive vault temperature Chemical reaction in MCO Human error leading to excessive heat and/or puffs during filler charge out	Release caused by leaking tube seals Release caused by tube relief valve actuation Release caused by tube failure (into vault) Excessive vault heat Tube contamination Flammable atmosphere on operating deck Contamination release to operating deck Flammable atmosphere in tube Flammable atmosphere in vault Contamination release to vault	The carbon steel tube material will maintain its integrity up to 700 °F. Building construction is type IIN. Stack monitors detect tube failure Sensors as its provide adequate warning to maintain nonflammable atmospheres. Area monitors detect releases to the operating deck	Periodic pressure monitoring, purging, and inerting will be performed by qualified operators using facility-specific procedures. A volumetric test of plug seals is conducted. Training and procedures on filler charge out operations.		S2	F2	
CSB operating area OAH-06c	Blocks 38-43, 53-62	Explosives or pyrophorics - hydrogen	Flammable hydrogen mixture and ignition source	Hydrogen release from tube to operating deck Hydrogen release from tube to vault Hydrogen release from MCO to tube plus air present.	Deflagration or detonation in operating deck Release to vaults Release to atmosphere Damage to tube Damage to MCO Runaway reaction in MCO	Controlled generation rates Minimize accumulation of hydrogen (building HVAC) Provide confinement with inert atmosphere to preclude leakage of air Oxygen sensors MCO penetrations are limited in size to reduce the rate of hydrogen release The carbon steel tube material will maintain its integrity up to 700 °F.	Periodic pressure monitoring, purging, and inerting will be performed by qualified operators using facility-specific procedures.		S3	F1	Refer also to V1-Q06. "Explosives or pyrophorics - hydrogen" for a discussion of hazards associated with hydrogen accumulation in the vault area. F1 was selected until the potential for runaway reaction and a relief valve is evaluated. It may then be changed to F-Q.

Table 3-16. Canister Storage Building Hazard Analysis: Operating Area. (sheet 5 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
CSB operating area OA-K-10	Blocks 36-43, 53-62	Explosives or radioisotopes and uranium metal	Pyrophoric materials exposed to air and insufficient surface area and insufficient temperature are present	MCO breach Human error in failing to inert the MCO	Pyrophoric material ignites	Personnel injury Contamination release Damage to the MCO	The structural design of the MCO is such that breaches have a very low probability of occurring.	CYOP personnel will be trained according to CYOP-specific procedures and following process for the MCO before shipment to the CSB	S3	F1	F-1 was selected until the potential for air ignites (such as through a breach in the vessel) is evaluated. It may then be changed to F-0.
CSB operating area OA-K-01	Blocks 36-43, 53-62	Nuclear critically - vaults					CSB cannot be flooded by rain or a water main break	General training of operators; operators will not disassemble an MCO		F0	This hazard is addressed in HNF-SD-SNF-RPT-004, Chapter 6.0, no new hazards were identified.
CSB operating area OA-K-04	Blocks 36-43, 53-62	Nuclear critically - filters (cart and tube plug)					CSB cannot be flooded by rain or a water main break	General training of operators; operators will not disassemble an MCO		F0	This hazard is addressed in HNF-SD-SNF-RPT-004, Chapter 6.0, no new hazards were identified.
CSB operating area OA-K-12	Blocks 36-43, 53-62	Nuclear critically - cranes and lifts					CSB cannot be flooded by rain or a water main break	General training of operators; operators will not disassemble an MCO		F0	This hazard is addressed in HNF-SD-SNF-RPT-004, Chapter 6.0, no new hazards were identified.
CSB operating area OA-L-11	Blocks 36-43, 53-62	Flammable materials - hydrogen									Refer to OA-J-03, "Explosives or radioisotopes" for an evaluation of this hazard.
CSB operating area OA-L-13	Blocks 35-62	Flammable materials - composites (MMW neutron absorber)									These hazards are addressed by the preliminary fire hazards analysis and the design of the composites on occupational classification" and the deviation and exemption request letters" that cover this topic.
CSB operating area OA-L-15	Blocks 35, 42-45, 52-54, 61-62	Flammable materials - hydraulic fluid for tube hoist cart, plug cover hoist	High heat	Leaky seals Breach of system Ignition source Sloppy housekeeping Human error	Fluid fire	Operations delay personnel injury Equipment damage Heating and exploding gas bottles Contamination (low levels) caused by damage to filters and other internally contaminated cart systems Toxic gases (fiss and up-bioslery)	Fire extinguishers on cart and throughout building TED (automatic and manual shutdown of hydraulic systems) TED (hoses are double encased)	Regular cart maintenance is performed using appropriate procedures.	S2	F2	The preliminary fire hazard analysis has addressed fires that fully involve the cart except internal low- level contaminant release. Heated or exploded gas bottles are addressed under SA-H-05; "Pressure/Volume - gas bottles." ISSUE: The service cart design is not finalized. When it is, the hazards analysis needs to evaluate further potential hazards. (Issue #16)
CSB operating area OA-M-05	Blocks 35, 42-45, 52-54, 61-62	Hazardous materials - corrosives (batteries)	Leaking battery	Cracked case Overfill Overcharge Faulty battery	Acid leak affects plug seals Acid on the floor Acid on personnel Acid on cart and cart equipment, and electrical systems	Leaking seal Corroded floor Personnel injury Failure of cart and/or cart equipment and systems Electrical shorts	Periodic maintenance includes battery inspection. "Never-kill" batteries used (TBD). Written charging procedures used. Reputable battery vendor used.		S1	F3	ISSUE: The service cart design is not finalized. When it is, the hazards analysis needs to evaluate further potential hazards. (Issue #16)

Table 3-16. Canister Storage Building Hazard Analysis: Operating Area. (sheet 6 of 10)

Location/ checklist entry	Operating sequence mode/ mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
CSB operating area OAH-07	Blocks 36-43, 53-62	Hazardous materials - toxics	Toxic material under high pressure	Excessive gas generation in MCO Improper or insufficient conditioning performed on the MCO before receipt at the CSB Failure of the MCO relief valve because of manufacturing flaws or damage Failure of the MCO rupture disk because of manufacturing flaws or damage Improperly closed ports at the CVDF Failure of MHHM floor seal	MCO rupture disk ruptures MCO relief valve discharges MCO exists in: - MHHM until inserted in tube - In tube and MHHM when removed to go to HCS - In MHHM coming back from HCS - In tube after hot conditioning (At no time is the MCO subl's of a secondary confinement) Sufficient pressure within the storage tube to let the tube plug after plug hold downs are undone and before MHHM is in place	Contaminated personnel (during plug blowdown scenario) Personnel injury Spread of contamination Contamination of storage tube Operations delay	Relief valve design (has HEPA) Secondary confinement (MHHM and tube) present	Drawing a vacuum in the storage tube before removing plug.	S2	F3	
CSB operating area OAH-01 OAH-03	Blocks 36-43, 53-62	Ionizing radiation sources - fissile and/or radioactive material	Contact exposure Release of fissile and/or radioactive materials in pressurized gases within the MCO	A process delay causes the MCO to exceed its calculated transport window before placement in a storage tube Improper or insufficient conditioning performed on the MCO before receipt at the CSB Failure of the MCO relief valve because of manufacturing flaws or damage Failure of the MCO rupture disk because of manufacturing flaws or damage Improper closing of the MCO process ports at the CVDF Tube plug not installed on empty tubes when adjacent tubes contain MCOs Failure of MHHM floor seal	Release of fissile and/or radioactive materials; MCO rupture disk relieves (because of excessive pressures within the MCO) - Failure of the rupture disk at the time of release of manufacturing flaws or damage	An MCO release inside the MHHM or storage tube, by itself, has no safety consequences beyond contamination of the MHHM or storage tube with fissile or radioactive materials. Any actions are dealt with separately, the MHHM or storage tube will contain the release. If the MHHM or storage tube fails to contain the release following an MCO release or breach, or the MCO release occurs while the tube plug is down, are the MCO materials released directly to the tube, fissile and/or radioactive materials are released to the operating area	The MCO rupture disk is designed with protective features such as a recessed location and a protective steel plate to minimize the potential for damage. The relief valve is recessed to minimize the potential for damage. The relief valve contains a HEPA filter to minimize the potential for radioactive particulate releases. The MHHM provides HEPA filtered secondary confinement in the event of an MCO pressure release.	Personnel are trained to facility specific procedures regarding MCO shipping, movement, handling, and site radiological control. The drying process at the CVDF window during which an MCO compression is precluded. This process is performed at a pressure relatively low until the MCO is installed in the storage tube CVDF personnel are trained in the proper procedures for closing the MCO process ports. A pressure test is performed on the MCO tubes and the tubes are removed. This prevents fissile and/or radioactive releases associated with exposing an MCO that has already experienced pressure relief. Tube pressures will be monitored on a regular schedule to alert operations to an MCO pressure relief situation. A pressure drawdown of the storage tube before moving the MCO to hot conditioning from staging will provide a period of time during which MCO pressure will not increase below the relief valve setpoint.	S2	F3	

Table 3-16. Canister Storage Building Hazard Analysis: Operating Area. (sheet 7 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
CSB operating area OA-P-04	Blocks 35-43; 35-62	Ionizing radiation sources - radioactive source	Exposure to direct radioactive shine	Direct shine associated with MCO during transfer and storage	Shine from MCO during transport if MHW shield skirt is not in place Shine from adjacent tube if tube plug is not in place	Worker exposure caused by shine from adjacent tubes during storage or from MCO during transfer into or out of storage tube	MHW, shielding, operating deck, and tube plug		S1	F1	ASSUMPTION: The tube plugs will be installed in all tubes before MCO installation in any single tube (Assumption #12)
CSB operating area OA-P-01	Blocks 35-62	External events - explosion	External explosion resulting in a shock wave from delivery truck, person, heat, and/or projectiles into the operating area	Explosion of nearby gas delivery truck, or gas station	Shock wave from the explosion impacts the facility Flying debris hits personnel Workers exposed to heat from the explosion	Structural damage or failure Personnel injury from flying debris Operational delays from structural damage, personnel injury, or from the need to secure the perimeter of the MCO to exceed its available transport window resulting in MCO pressure relief before placement within the storage tube Delays that cause the MCO to approach the relief valve set pressure after the pressure relief in the MHW	The CSB is isolated from major explosions outside the facility from affecting the CSB. The facility structure is designed to withstand major explosions and phenomena (e.g., tornado missiles, straight winds).	CSB personnel are trained in site-wide and facility-specific emergency response procedures that include steps to place the facility in the safest possible condition.	S1	F2	
CSB operating area OA-P-02	Blocks 35-62	External events - fire	External fire introduces heat into the service area (low visibility)								Based upon the current design, there is no external energy source that would have greater consequences than a fire inside the facility. The fire would be addressed by the preliminary fire hazards analysis. Refer to the white papers on occupational hazards analysis, fire protection, and the exemption request below that cover this topic.
CSB operating area OA-P-03	Blocks 35-62	External events - nearby facilities	Accidents at nearby facilities introduce radioactive material, and direct radiation into the facility	Descriptions of potential accidents at nearby facilities and their resulting consequences are addressed in HNF-SD-SNF-RPT-004 * HNF-SD-SNF-RPT-004 *	Descriptions of potential accidents at nearby facilities and their resulting consequences are addressed in Chapter 11.0 of the HNF-SD-SNF-RPT-004 *	Personnel exposure to radioactive and toxic material from the nearby facility Contamination of the CSB from nearby facility releases makes the building uninhabitable Operational delays evacuate the facility or take cover cause the MCO to exceed its available transport window and result in MCO pressure relief before placement within the storage tube Delays cause the MCO to approach the relief valve set pressure after the pressure dropdown resulting in MCO pressure relief in the MHW	The distance of the CSB from other facilities and the facility structure provides reduces the consequences of external events on the CSB.	S1	F1	CSB personnel are trained in site-wide and facility-specific emergency response procedures that include steps to place the facility in the safest possible condition.	

Table 3-16. Canister Storage Building Hazard Analysis: Operating Area. (sheet 8 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
CSB operating area OA-R-01a	Blocks 35-62	Natural phenomena - earthquake (equal to or less than the DBE) (storage tubes, MCOs)	Force on the facility from lateral and horizontal accelerations	Earthquake	Structural damage or collapse Damage to facility systems, structure or components (e.g., receiving crane, cable trays, MRM) Damage to MCOs (while in storage tube or MRM) Relief valve actuation on storage tubes resulting in gas pressure to the storage tubes and causing a release to the operating deck through the tube plug vent valves Increased surface exposure of MCO contents, providing the potential for increased reactions	Personal injury Release of radiation from a breached MCO Loss of facility power Operational delays that cause an MCO to exceed its available transport window and may result in MCO pressure relief before placement within the storage tube Flammable atmospheres formed on the operating deck	The facility (including both the facility structure and systems such as the receiving crane and MRM) is designed to resist seismic loads and impacts to safety systems from the failure of non-safety systems. The CSB is built to appropriate seismic criteria. The relief valves are designed with small internal areas and will be the strongest part of the storage tube storage tubes. This will minimize both the number of tubes that could vent and the amount of gas released from them.	CSB personnel are trained in site-wide and facility-specific emergency response procedures that include steps to place the facility in the safest possible condition.	S2	F2	
CSB operating area OA-R-01b	Blocks 35-62	Natural phenomena - earthquake (equal to or less than the DBE) (relief valve set pressure above a tube plug for purging)	Force from lateral and horizontal accelerations	Earthquake	Service cart movement or relocation Broken connection	Exposure of storage tube internals, with resulting - Hydrogen release - Contamination release - Air leakage and potential pyrolytic reactions and/or deflagration	The connections to the storage tube plug are designed to not fail when exposed to seismic forces.		S1	F2	This hazard is more of an initiator for pyrophoric reactions.
CSB operating area OA-R-03	Blocks 35-62	Natural phenomena - lightning	High electrical energy	Lightning strike	Strike on the facility	Loss of power Damage to systems, structures, or components Personal injury Operational delays that cause the MCO to exceed its available transport window and result in MCO pressure relief before placement within the storage tube Delays that cause the MCO to approach the relief valve set pressure above the tube pressure drawdown resulting in MCO pressure relief in the MRM	The CSB facility is equipped with lightning protection that includes lightning rods, grounding, and ground fault detectors. The facility provides shelter for workers.	CSB personnel are trained in site-wide and facility-specific emergency response procedures that include steps to place the facility in the safest possible condition.	S1	F2	

Table 3-16. Canister Storage Building Hazard Analysis: Operating Area. (sheet 9 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
CSB operating area OAR-04	Blocks 35-62	Natural phenomena - rain	Water intrusion operating area	Leaks through the roof Volume of rain exceeds the capacity of the facility grading and drainage system to carry off rainwater	Water in electrical systems such as cable trays or MIM components Flooded floors (including storage tubes)	Personnel injury from slips Loss of power Loss of equipment or personnel injury from electrical shorts Operational delays that cause the MCO to exceed its available transport window result in MCO pressure relief before placement within the storage tube	The facility is designed to prevent water intrusion and to provide shelter for workers. The electrical design within the facility minimizes potential consequences (electrical conduit initiates fire spread). Silt grading is designed to prevent rain intrusion into the facility. The facility design takes into consideration the need for tactile (non-skid) surfaces.		S0	F1	
CSB operating area OAR-05	Blocks 35-62	Natural phenomena - snow, freezing weather	Snow loading Extreme cold	Snow storm, cold weather	Roof collapse Ice buildup	Personnel injury from collapsed roof or cold exposure Operational delays that cause the MCO to exceed its available transport window result in MCO pressure relief before placement within the storage tube	The building is designed to withstand anticipated snow loads. The operating area is heated. The facility provides shelter for workers.	MCO shipping during adverse weather conditions is prohibited.	S0	F3	ACTION ITEM: The Safety Analysis Report for Packaging definition of weather conditions will be included here. (Action Item 18-4)
CSB operating area OAR-06	Blocks 35-62	Natural phenomena - straight wind	Wind pressure Flying debris Dust	Pressure gradient	Personnel struck by flying debris Systems, structures, or components damaged by flying debris Visibility reduced Debris accumulates	Personnel injury Restricted access to the facility Operational delays arising from restricted access to the facility clear debris cause the MCO to exceed its available transport window and result in MCO pressure relief before placement within the storage tube	The facility structure is designed to withstand a 200 mph wind. The facility provides shelter for workers.		S0	F3	Winds in excess of the design basis were not considered. The consequences of this phenomenon are less than they were in the truck vestibule. This phenomenon was not adaptable to straight winds.
CSB operating area OAR-06	Blocks 35-62	Natural phenomena - tornado 60 mph 100 mph rotational; missiles, 40 mph; wind loads, 200 mph)	Wind pressure Flying debris Dust	Pressure gradient	Personnel struck by flying debris Systems, structures, or components damaged by flying debris (e.g., MIM, service carts) Visibility reduced Debris accumulates	Personnel injury Restricted access to the facility Operational delays that arise from damaged equipment or the need to clear debris cause the MCO to exceed its available transport window and result in MCO pressure relief before placement within the storage tube	The facility superstructure is designed to withstand the forces of design basis tornado missiles and wind loads. The facility provides shelter for workers. A probability analysis for the vulnerability of all safety class systems to tornado missiles shows that it is incredible for a tornado missile to strike the safety class systems within the CSB.		S3	F0	
CSB operating area OAR-06	Blocks 35-62	Natural phenomena - ashfall	Ash loading on roof	Volcanic eruption	Roof collapse Ash intrusion	Personnel injury Equipment damage Operational delays that cause the MCO to exceed its available transport window result in MCO pressure relief before placement within the storage tube	The building is designed to withstand anticipated ash loadings.		S1	F2	

Table 3-16. Canister Storage Building Hazard Analysis: Operating Area. (sheet 10 of 10)

Location/ checklist entry	Operating sequence mode/ block	Hazardous energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
CSB operating area OAR-10	Blocks 35-62	Natural phenomena - range fire	Windborne embers Smoke	Dry conditions and ignition	Loss of power Reduced visibility Secondary fire caused by flying embers	Personnel injury Operational delays that cause the MCO to exceed its available transport window result in MCO pressure relief before preservation within the storage tube.	The facility is designed with non- combustible materials (Type I-IV), 	Personnel control and clear the CSB to reduce the impact of range fires.	S1	P3	The operating area is less than 100 ft from the building with regards to a range fire, except in the area of loss of power.
attendees	Fluor Daniel Northwest	Duke Engineering and Services Hanford, Incorporated		XXWest Group	Numatec Hanford Corporation	Fluor Daniel, Incorporated	Science Applications International Corporation				

* ASME, 1995, Rules for Construction of Overhead and Gantry Cranes (The Running Bridge, Multiple Girders), ASME NCC-1, 1995, American Society of Mechanical Engineers, New York, New York.
* Gavin, L. J., 1987, Canister Storage Building Safety Analysis Report - Phase 2, Safety Analysis Documentation Study, American Society of Mechanical Engineers, Inc., Warrendale, PA.
* Ares, 1998, Canister Storage Building Fire Code Equivalency Evaluation, Report 951107-001, Rev. 0, Ares Corporation, Richland, Washington.
* Ares, 1998, White Paper Presenting Recommended Approach to Fire Protection of the Operating Area of the Canister Storage Building, Report 951107-002, Ares Corporation, Richland, Washington.
* Williams, N. H., 1986, Project W-379, Spent Nuclear Fuel Canister Storage Building, Request for Deviation from the United States Department of Energy Order 6430 1A - Automatic Sprinkler Protection Requirements (Letter 9655218 to E. D. Sellers, U.S. Department of Energy, Richland Operations Office, November 14), Fluor Daniel Hanford, Incorporated, Richland, Washington.
* Williams, N. H., 1986, Project W-379, Spent Nuclear Fuel Canister Storage Building, Request for Deviation from the United States Department of Energy Order 5487 7A - Automatic Fire Suppression System Requirements (Letter 9655233 to E. D. Sellers, U.S. Department of Energy, Richland Operations Office, November 14).

CSB = Canister Storage Building
CVD = Cold Vacuum Drying Facility
DBE = design basis earthquake
HEPA = high-efficiency particulate air (filter)
HCS = Hot Conditioning System
HVAC = Heating, Ventilation, and Air Conditioning
MCO = multicanister overpack
MHM = multicanister overpack handling machine
TBD = to be determined.

Table 3-17. Canister Storage Building Hazard Analysis: Vault. (sheet 1 of 2)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
Vault (including intake structure and exhaust stack) VL-B-07 VL-B-10 VL-B-07 VL-R-09 VL-R-10		Thermal - radioactive decay heat and chemical reaction	High heat in vault tubes, and MCO	Excessive decay heat and/or chemical reactions Loss or degradation of natural connection caused by: - Accumulation of dust, tumbleweeds, ash, bugs, and other debris deposited within the vault by dust debris or other winds - Frost covering the inlet plenum - Oxidation layer forming on storage tubes - Failure of the inlet or exhaust stack caused by tornado forces, earthquake forces, or aircraft impact - Range fire smoke and heat	Rise in fuel temperature, resulting in runaway chemical reactions Pressurization of MCOs and storage tubes Structural degradation of vault Rise in fuel center line temperatures Rise in storage tube temperatures	Excessive temperatures for: - MCOs - Concrete - Storage tubes Design pressure limits for MCOs and storage tubes exceeded Multiple MCO pressure releases Loss of structural integrity of vault walls and ceiling	Height and orientation of inlets and outlets reduce the likelihood of blockage Temperature and radiation monitors are located on the outlet stack and provide indication of undesired trends and unexpected releases. The stacks are designed to withstand significant forces without failing.	S3	F2	ISSUE: There is no way to check the vault area for conditions that could lead to a fire under normal operating conditions. (Issue #20)	
Vault VL-H-08		Volume, pressure - pressure vessels									See OA-H-08
Vault VL-L-06		Explosives or pyrophorics - hydrogen	Flammable mixture of hydrogen and air present in the vault and an ignition source ignites it	Breach of storage tubes results in hydrogen leakage into the vault area	Deflagration in the vault area	Ignition of other combustible materials accumulated within the vault (e.g., tumbleweeds debris) Rise in vault temperature	The carbon steel tube material will maintain its integrity up to 700 °F. The design of the tubes denies intrusion (grated, elevated). Vault design provides for passive cooling. A temperature and radiation monitor is present for the exhaust stack. Tube pressure monitoring devices indicate pressure rises caused by temperature effects.	Periodic pressure monitoring of tubes is performed TBD (routine maintenance procedures, building and site-specific)	S0	F0	This is a potential initiator for VL-B-07. "Thermal - radioactive decay heat and chemical reaction." There will be a one-time integrity test conducted after tube installation in compliance with ASME Section 3 requirements. ACTION ITEM: Verification that the preoperational test procedures for the vault are adequate must be made. (Action Item #65)
Vault VL-L-11		Flammable materials - hydrogen									Refer to VL-L-06, "Explosives or pyrophorics - hydrogen," for evaluation of the hazard.
Vault VL-N-04		Ionizing radiation sources - radioactive sources									There is no access to this area, so this hazard, while present, is not a concern for worker safety.
Vault VL-R-01		Natural phenomena - earthquake	Forces on vault from lateral and horizontal accelerations	Earthquake			Vault structures are designed to withstand a design basis earthquake without failing.		S0	F2	
Vault VL-R-04		Natural phenomena - rain	Modified criticality parameters								This hazard is addressed in HNF-SD-SNF-RPT-04, "Chapter 6.0: no new hazards were identified."

Table 3-17. Canister Storage Building Hazard Analysis: Vault. (sheet 2 of 2)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
Vault V1-R-05		Natural phenomena - snow, freezing weather	Modified parameters								This hazard is addressed in HNF-SD-SNF-RPT-004*, Chapter 6.0, no new hazards were identified.
attendees	Fluor Daniel Northwest	Duke Engineering and Services Hanford, Incorporated	XWest Group	Numatec Hanford Corporation	Fluor Daniel, Incorporated	Science Applications International Corporation					

* Garvin, L. J., 1987, Canister Storage Building Safety Analysis Report -- Phase 3, Safety Analysis Documentation Supporting Canister Storage Building Construction, HNF-SD-SNF-RPT-004, Rev. 7, Duke Engineering and Services Hanford for Fluor Daniel Hanford, Incorporated, Richland, Washington.
CSB = Canister Storage Building.
MCO = multicanister overpack.
TBD = to be determined.

Table 3-18. Canister Storage Building Hazard Analysis: Support Building. (sheet 1 of 2)

Location/ checklist entry	Operating sequence/ mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Consq categ	Freq categ	Remarks
							Engineering features	Administrative features			
Support building SB-P-02		Linear kinetic - forklifts, dollies, carts	Moving equipment impacts facility support systems	Human error Mechanical failure	Damage to systems, structures, or components (e.g., ventilation ducts, fire protection system) from moving equipment or resulting missile hazard	Personnel injury Loss of power Operational delays Loss of primary inert gas supply	Vehicles are equipped with braking systems. Periodic maintenance of vehicles is performed according to established procedures to keep the vehicles in good working order.	Personnel are trained in the proper use of facility equipment and follow established procedures.	S1	F3	
Support building SB-L-01 SB-L-10 SB-L-02 SB-L-11 SB-L-13 SB-L-07 SB-L-08		Flammable materials - building contents, packing materials, rags, lubricating oil, greases, solvents, hydrogen, organics, clothing	Fire in the support building	Ignition caused by - Human error - Equipment failure (e.g., electrical wiring)	Fire in the support building (see SB-L-04)	Release of contamination from filters in the filter room Loss of electrical power (primary and backup)	Support building structural materials are selected to minimize flammability. The support building is equipped with a sprinkler system. A fire barrier separates the two diesel generators	Flammable material inventories are controlled (quantity and location). Emergency response procedures are in place.	S1	F3	Under normal operating conditions, support building filters do not contain a loading of radioactive material. ACTION ITEM: Filter housing design must be checked for fire retardation properties. (Action item #652)
Support building SB-N-03		Ionizing radiation sources - radioactive material (HVAC filters)	Radioactive material accumulates on HVAC filters	Previous release of radioactive materials from off-normal conditions	Fire involving HVAC filters (see SB-L-04) Pressure differential blowing out filters (ashfall, moisture, radioactivity) due from upstream deflagration) Personnel exposure	Release of contamination from filters Personnel injury	Facility CAMs alert personnel to presence of radioactive material. Stack monitor alerts personnel to presence of radioactive material.	Periodic filter testing and change out per NRC/AFR practices reduce the likelihood of radioactive material being present in the HVAC filters.	S1	F3	
Support building SB-P-01		External events - explosion	External explosion resulting in a shock wave impacts support building, heat, and/or projectiles into the support building	Explosion of nearby gas delivery truck, propane gas station	The shock wave from the explosion impacts the support building Flying debris hits personnel Workers exposed to heat from the explosion	Structural damage or failure (including loss of support structure) Personnel injury from flying debris	The CSB is isolated from major external explosions affecting the support building. The facility structure is designed to withstand significant external phenomena (e.g., tornado winds, design basis earthquake).	Personnel are trained in site-wide and facility-specific emergency response procedures.	S1	F2	
Support building SB-P-02		External events - fire	External fire introduces heat and smoke into support building (low visibility)								Based upon the current design, there is no external energy source that could cause a fire in the building other than a fire inside the facility. This hazard is addressed by the preliminary fire hazards analysis, the fire protection occupational safety and health analysis, and exemption request letters ¹ that cover this topic.
Support building SB-P-03		External events - nearby facilities	Radioactive material, toxic material, and other airborne contaminants introduced into the facility	Descriptions of potential accidents at nearby facilities and their resulting consequences are addressed in Chapter 1.10 of HNF-SD-SNF-RPT-004. ¹	Descriptions of potential accidents at nearby facilities and their resulting consequences are addressed in Chapter 1.10 of HNF-SD-SNF-RPT-004. ¹	Personnel exposure to radioactive and toxic material from the nearby facility Contamination of the support building making the building uninhabitable	The distance of the CSB and the support building from other facilities provides reduce the consequences of external events.	Personnel are trained in site-wide and facility-specific emergency response procedures that include steps to place the facility in the safest possible condition.	S1	F1	

Table 3-18. Canister Storage Building Hazard Analysis: Support Building. (sheet 2 of 2)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Consq categ	Freq categ	Remarks
							Engineering features	Administrative features			
Support building SB-R-01		Natural phenomena - earthquake	Force exerted from lateral and horizontal accelerations	Earthquake	Structural damage or collapse of building housed support functions	Loss of - Ventilation (primary) - Primary inert gas supply - Primary facility power Release of radiation caused by HVAC filter failure	The support building is designed to withstand a design basis earthquake and has emergency steps to place the facility in the safest possible condition.	Personnel are trained in sitewide and facility-specific emergency response procedures and have steps to place the facility in the safest possible condition.	S1	F2	
Support building SB-R-02 SB-R-04 SB-R-09 SB-R-05 SB-R-10 SB-R-06		Natural phenomena - Flood, wind, snow, ice, lightning, hail, straight wind, tornado, ashfall, large fire	Natural energy sources	Geological and/or meteorological effects	Damage to systems, structures, or components of support building (e.g., generators, inert gas line)	Personnel injury Loss of power Operational delays Loss of primary inert gas supply	The diesel generators are designed to withstand natural phenomena hazards		S1	F3	See also action items #69 and #69
attendees	Fluor Daniel Northwest	Duke Engineering and Services Hanford, Incorporated	XWest Group	NuScale Hanford Corporation	Fluor Daniel, Incorporated	Science Applications International Corporation					

¹ Sadranga, C. T., 1986, *Preliminary Hazard Analysis for the Canister Storage Building*, HNF-SD-SNF-FHA-002, Rev. 2, DRAFT, DynCorp Tri-Cities Services Northwest for Fluor Daniel Hanford, Incorporated, Richland, Washington.
² Williams, N. H., 1986, *White Paper Presenting Recommended Approach to the Protection of the Operation of the Canister Storage Building*, HNF-SD-SNF-FHA-001, Rev. 0, JRC Corporation, Richland, Washington.
³ Ares, 1988, *White Paper Presenting Recommended Approach to the Protection of the Operation of the Canister Storage Building*, HNF-SD-SNF-FHA-001, Rev. 0, JRC Corporation, Richland, Washington.
⁴ Williams, N. H., 1986, *Project W-379, Spent Nuclear Fuel Canister Storage Building Request for Deviation from the United States Department of Energy Order 6430.1A - Automatic Sprinkler Protection Requirements* (Letter #655213 to E. D. Sellers, U.S. Department of Energy, Richland Operations Office, November 14), Hanford, Incorporated, Richland, Washington.
⁵ Williams, N. H., 1986, *Project W-379, Spent Nuclear Fuel Canister Storage Building Request for Exemption from the United States Department of Energy Order 6430.1A - Automatic Fire Suppression System Requirements* (Letter #655233 to E. D. Sellers, U.S. Department of Energy, Richland Operations Office, November 14), Hanford, Incorporated, Richland, Washington.
⁶ Gavett, L. J., 1987, *Canister Storage Building Safety Analysis Report - Phase 3, Safety Analysis Documentation Supporting Canister Storage Building Construction*, HNF-SD-SNF-RPT-004, Rev. 7, Duke Engineering and Services Hanford for Fluor Daniel Hanford, Incorporated, Richland, Washington.

ALARA = as low as reasonably achievable.
CER = Canister Emergency Response
CSB = Canister Storage Building
MCO = multicanister overpack.
HVAC = heating, ventilating, and air conditioning.

Table 3-19. Canister Storage Building Hazard Analysis: Outside. (sheet 1 of 2)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
Outside OUI-F-01 OUI-F-02 OUI-F-05 OUI-F-06		Linear kinetic - trucks, forklifts, and crane loads	Vehicle collisions with equipment	Human error Equipment failure	Vehicle collision with - Inert gas supply - Diesel tanks - Gas bottles - Transformer	Personnel injury Loss of inert gas supply Missile damage Diesel spill, fire Operations delay Loss of power	Construction of access roads reduces the likelihood of vehicle collisions. The diesel fuel tank is protected by a concrete tub. The inert gas tube trailer is designed to withstand highway accidents.	Traffic is restricted around the CSB.	S1	F3	Additional engineered features may be included (e.g., bollards, barriers). ACTION ITEM: It must be determined whether a vehicle would have access to the transformer. (Action Item #60)
Outside OUI-H-05 OUI-H-06		Volume, pressure inert gas tube trailer	High pressure inert gas tube trailer vessel failure	Human error Equipment failure	Vehicle collision with inert gas tube trailer Tube trailer impacts facility	Operations delay Missile damage Loss of inert gas supply Personnel injury	Construction of access roads reduces the likelihood of vehicle collisions. The inert gas tube trailer is designed to withstand highway accidents.	Traffic is restricted around the CSB.	S1	F3	
Outside OUI-L-07		Flammable materials - diesel fuel									Refer to OUI-F-01 for a discussion of the consequences of the failure of the diesel fuel tanks.
Outside OUI-P-01		External events - explosion	External explosion resulting in a shock wave that causes dust, heat, and/or projectiles into the service area	Explosion from passing gas or propane delivery truck or from nearby gas station	Shock wave from explosion impacts personnel Personnel are hit by debris Personnel are exposed to heat from explosion	Damage to or failure of systems, including the possibility of inert gas tube trailer, diesel fuel tanks, transformers) Personnel injury	The CSB is isolated from major explosions, including the possibility of explosions occurring in the facility affecting the CSB.		S1	F2	
Outside OUI-P-02		External events - fire	External fire introduces heat and smoke								Based upon the current design, there is no external energy source that would have greater consequences than the current design. This hazard is addressed by the preliminary fire hazards analysis, the while papers on occupational classification, and the deviation request letters that cover this topic.
Outside OUI-P-03		External events - nearby facilities	Radioactive material, toxic material, and direct radiation	Descriptions of potential accidents at nearby facilities and their resulting consequences are addressed in Chapter 1.0 of HNF-SD-SNF-RPT-004. HNF-SD-SNF-RPT-004.	Descriptions of potential accidents at nearby facilities and their resulting consequences are addressed in Chapter 1.0 of HNF-SD-SNF-RPT-004. HNF-SD-SNF-RPT-004.	Personnel exposure to radioactive and lost material from the nearby facility	The distance of the CSB from other facilities reduces the consequences of external events.		S1	F1	
Outside OUI-Q-01		Vehicles in motion - airplane	Airplane crash	Loss of flight control	Impact to facility structure Impact with nearby power lines	Personnel injury Loss of offsite power Operational delays				F0	The possibility of an aircraft crash impacting the facility is considered unlikely based on the discussion in Chapter 1.0 of HNF-SD-SNF-RPT-004.

Table 3-19. Canister Storage Building Hazard Analysis: Outside. (sheet 2 of 2)

Location/ checklist entry	Operating sequence mode/ block	Hazard energy source/material	Hazardous condition	Cause	Potential accident	Consequence	Safety features		Conseq categ	Freq categ	Remarks
							Engineering features	Administrative features			
Outside OU-Q04		Vehicles in motion - truck/bulldozer									
Outside OUR-01		Natural phenomena - earthquake	Forces exerted on the facility from lateral and horizontal accelerations	Earthquake	Damage to or failure of systems, structures, or components	Loss of - Inert gas tube trailer - Diesel fuel tanks - Transformer	CSB facility structure is built to appropriate seismic criteria		S1	F2	
Outside OUR-03 OUR-04 OUR-05 OUR-06 OUR-10		Natural phenomena - lightning, rain, snow, freezing weather, ice, wind, hail, flood, dew, tornado, ashfall, range fire	Natural energy sources	Geological and/or meteorological effects	Damage to systems, structures, or components (e.g., inert gas tube trailer, diesel fuel tank, transformer)	Personnel injury Loss of power Operational delays Loss of primary inert gas supply	The CSB facility is equipped with lightning protection that includes lightning rods, grounding, and ground fault detectors. The facility structure is designed to withstand natural phenomena hazard loads.	CSB personnel are trained in sitewide and facility-specific emergency response procedures that include steps to place the facility in the safest possible condition.	S1	F3	
attendees	Fluor Daniel Northwest	Duke Engineering and Services Hanford, Incorporated	XWest Group	Numatec Hanford Corporation	Fluor Daniel, Incorporated	Science Applications International Corporation					

* Sadanaga, C. T., 1986, Preliminary Fire Hazard Analysis for the Canister Storage Building, HNF-SD-SNF-FHA-002, Rev. 2, DRAFT, DynCorp Tri-Cities Services Northwest for Fluor Daniel Hanford, Incorporated, Richland, Washington.

* Ares, 1986, Canister Storage Building Fire Code Equivalency Evaluation, Report 951107-001, Rev. 0, Ares Corporation, Richland, Washington.

* Williams, N. H., 1986, Operation of the Canister Storage Building, Report 951107-002, Ares Corporation, Richland, Washington.

* Williams, N. H., 1986, Project W-379, Spent Nuclear Fuel Canister Storage Building Request for Deviation from the United States Department of Energy Order 5483.7A - Automatic Spreader Protection Requirements (Letter 9655218 to E. D. Sellers, U.S. Department of Energy, Richland Operations Office, November 14), Fluor Daniel Hanford, Incorporated, Richland, Washington.

* Williams, N. H., 1986, Project W-379, Spent Nuclear Fuel Canister Storage Building Request for Exemption from the United States Department of Energy Order 5483.7A - Automatic Fire Suppression System Requirements (Letter 9655233 to E. D. Sellers, U.S. Department of Energy, Richland Operations Office, November 14), Fluor Daniel Hanford, Incorporated, Richland, Washington.

Gavin, L. J., 1987, Canister Storage Building Safety Analysis Report - Phase 3, Safety Analysis Documentation Supporting Canister Storage Building Construction, HNF-SD-SNF-RPT-004, Rev. 7, Duke Engineering and Services Hanford for Fluor Daniel Hanford, Incorporated, Richland, Washington.

CSB = Canister Storage Building

MCO = multicanister overpack

4.0 REFERENCES

- 29 CFR 1910, "Occupational Safety and Health Standards," Code of Federal Regulations, as amended.
- Ares, 1996a, *Canister Storage Building Fire Code Equivalency Evaluation*, Report 951107-001, Rev. 0, Ares Corporation, Richland, Washington.
- Ares, 1996b, *White Paper Presenting Recommended Approach to Fire Protection of the Operating Area of the Canister Storage Building*, Report 951107-002, Ares Corporation, Richland, Washington.
- DOE Order 5480.23, 1992, *Nuclear Safety Analysis Reports*, DOE 5480.23, U.S. Department of Energy, Washington, D.C.
- DOE Standard 3009-94, 1994, *Preparation Guide for U.S. Department of Energy Nonreactor Nuclear Facility Safety Analysis Reports*, DOE-STD-3009-94, U.S. Department of Energy, Washington, D.C.
- Garvin, L. J., 1997, *Canister Storage Building Safety Analysis Report — Phase 3: Safety Analysis Documentation Supporting Canister Storage Building Construction*, HNF-SD-SNF-RPT-004, Rev. 7, Duke Engineering and Services Hanford for Fluor Daniel Hanford, Incorporated, Richland, Washington.
- Lorenz, B. D., 1997, *Multicanister Overpack Topical Report*, HNF-SD-SNF-SARR-005, Rev. 0, Duke Engineering and Services Hanford for Fluor Daniel Hanford, Incorporated, Richland, Washington.
- NFPA, 1995, *Lightning Protection Systems*, NFPA 780, National Fire Protection Association, Quincy, Massachusetts.
- RFS, 1996, *Preliminary Safety Analysis Report for Packaging (Onsite) Multiple Canister Overpack Cask*, HNF-SD-TP-SARP-017, Rev. 0, DRAFT, Rust Federal Services Northwest for Fluor Daniel Hanford, Incorporated, Richland, Washington.
- Sadanaga, C. T., 1996, *Preliminary Fire Hazard Analysis for the Canister Storage Building*, HNF-SD-SNF-FHA-002, Rev. 2, DRAFT, DynCorp Tri-Cities Services, Incorporated, for Fluor Daniel Hanford, Incorporated, Richland, Washington.
- Williams, N. H., 1996a, *Project W-379, Spent Nuclear Fuel Canister Storage Building Request for Deviation from the United States Department of Energy Order 6430.1A — Automatic Sprinkler Protection Requirements* (Letter 9655218 to E. D. Sellers, U.S. Department of Energy, Richland Operations Office, November 14), Fluor Daniel Hanford, Incorporated, Richland, Washington.

Williams, N. H., 1996b, *Project W-379, Spent Nuclear Fuel Canister Storage Building Request for Exemption from the U.S. Department of Energy Order 5480.7A — Automatic Fire Suppression System Requirements* (Letter 9655233 to E. D. Sellers, U.S. Department of Energy, Richland Operations Office, November 14), Fluor Daniel Hanford, Incorporated, Richland, Washington.

ATTACHMENT 1

**CANISTER STORAGE BUILDING
OPERATIONS FLOW DIAGRAM**

This page intentionally left blank.



1. DIFFERENCE WITH SPIN: 1 TO 2 MOODS PER SPIN
2. SPIN: 1 TO 2 MOODS PER SPIN
2. IF WE'RE IN A BAD MOOD, WE'LL PROBABLY CONSIDER
OURSELVES NEGATIVE PEOPLE
3. BY AVOIDING OUR BAD PROBABILITIES, PROBABLY WE'LL
EVALUATE IT NOT IN NEGATIVE SCALE OF MOOD,
BUT IN POSITIVE
4. THE REASON WHY WE OVEREVALUATE HAS CAUGHT THE
NEGATIVE IMPACT, PROBABLY WE'LL BE STORED FIRST
IN THE OTHER SIDE, THEN WE'LL BE STORED IN THE
LEFT SIDE, THEN WE'LL BE STORED IN THE RIGHT SIDE
IN THE FIRST MOODS WHEN WE'VE BEEN FROM THEIR POSITIVITY
5. DIFFERENCE WITH SPIN: WE'LL BE STORED FIRST
IN THE OTHER SIDE, THEN WE'LL BE STORED IN THE
LEFT SIDE, THEN WE'LL BE STORED IN THE RIGHT SIDE
IN THE FIRST MOODS WHEN WE'VE BEEN FROM THEIR POSITIVITY
6. IF WE'RE IN A BAD MOOD, WE'LL PROBABLY CONSIDER
OURSELVES NEGATIVE PEOPLE
7. BY AVOIDING OUR BAD PROBABILITIES, PROBABLY WE'LL
EVALUATE IT NOT IN NEGATIVE SCALE OF MOOD,
BUT IN POSITIVE
8. THE REASON WHY WE OVEREVALUATE HAS CAUGHT THE
NEGATIVE IMPACT, PROBABLY WE'LL BE STORED FIRST
IN THE OTHER SIDE, THEN WE'LL BE STORED IN THE
LEFT SIDE, THEN WE'LL BE STORED IN THE RIGHT SIDE
IN THE FIRST MOODS WHEN WE'VE BEEN FROM THEIR POSITIVITY


OP = OPERATOR
HP = HEALTH PHYSICIAN
NM = NUTRITIONIST

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

2.9 1985



7A



ATTACHMENT 2
CANISTER STORAGE BUILDING
HAZARD ANALYSIS
TEAM MEMBERS

This page intentionally left blank.

ATTACHMENT 2

CANISTER STORAGE BUILDING HAZARD ANALYSIS TEAM MEMBERS

The key members of the Canister Storage Building (CSB) Hazards Analysis brought to the study the following experience.

Walter Alaconis

B.S., General Science, The University of the State of New York, Albany. Nearly 27 years of diversified nuclear safety and operations experience in the military, commercial, and U.S. Department of Energy (DOE) environments. Obtained registration with the National Registry of Radiation Protection Technologists in 1982. Over 16 years at the Hanford Site supporting major facility modifications and new facility design projects. Co-author of the Process Facility Modification Project Preliminary Safety Analysis Report. Manager over the development of the Hanford Site Quality Training and Resource Center Root Cause Analysis Training Program and the Accident/Event Trending Program. Managed the Nuclear Engineering/Safety Data Management Unit for 4 years. Technical advisor to the Liquid Effluent Services Program at the Hanford Site and the Environmental Restoration Programs at the Hanford Site and DOE-Headquarters. Facilities supported at the Hanford Site include the tank farms (east), PUREX, B Plant, Plutonium Finishing Plant, Treated Effluent Disposal Facility, and Effluent Treatment Facility.

Ralph D. Crowe

M.S., Nuclear Engineering and Engineering Management. Over 20 years experience in the nuclear industry performing calculations using multidimensional time-dependent neutron kinetics and thermal hydraulic codes. Six years experience performing safety analysis within the DOE environment for a number of facilities, including high-level waste tanks, Plutonium Finishing Plant, and spent fuel storage.

M. Guzman

Fourteen years experience in the nuclear industry. Started in the bargaining unit as a Chief Reactor Fuel operator at the N Reactor, worked up through the management chain as a shift supervisor responsible for around-the-clock operations loading, packaging, and shipping 120 metric tons of irradiated spent nuclear fuel per month. Transferred to the K Basins in a supervisory role and also served as a shift manager. Presently assigned to the CSB as a plant engineer in the Facility Startup and Operations organization providing input to the CSB design.

Taber G. Hersum

M.S., Nuclear Engineering, registered professional engineer (California). Twenty-six years experience in nuclear safety, reactor physics, fuel loading and power ascension testing, operations, and technical and quality consulting for nuclear power plants, nuclear fuel and nuclear waste in the United States, Europe, and Japan. Currently a member of the Fluor Daniel Hanford, Inc., Nuclear Safety organization providing oversight review of Project Hanford Management Contractor safety basis documents requiring DOE approval. Previously certified as a senior reactor operator and ANSI 45.2.6 Level III senior reactor operator test engineer.

Larry D. Kessie, AIA

B.S., Architectural Studies and B. of Architecture, Registered Architect. Fifteen years experience in architectural design, design management, cost account management, project management, and construction administration in both the private and government sectors. Positions have ranged from that of a project architect, a design office architect, to temporary facility and site infrastructure design authority. Currently consulting architect/design authority for site infrastructure and temporary facilities for project W-379, Spent Nuclear Fuel CSB.

Steve D. Kopelic

B.S., Mechanical Engineering. Twenty years experience related to commercial pressurized water reactor electric generation stations. Experience includes reactor core design and testing, primary and secondary cooling systems accident analysis, preparation and defense of plant licensing documentation, probabilistic risk assessment, and implementation of design modifications on operating plants. One year experience at the Hanford Site performing safety analyses and safety analysis report preparation for the Spent Nuclear Fuel Project.

Dwight E. Krahn

B.S., General Engineering, field of specialty in Operations Research. Eight years experience in engineering and safety analysis activities. Training includes safety analysis development, root cause analysis, and risk assessment. Most recent work has been in the area of Technical Safety Requirements for the Waste Encapsulation and Storage Facility and the tank farms.

Maryanne Kummerer

M.S., Mechanical Engineering. Fifteen years experience in engineering analysis in the area of heat transfer, multiphase fluid flow, thermodynamics, and chemical phenomena. Nine years performing calculations in support of safety analysis for various Hanford Site facilities, and providing accident analysis contributions to safety documentation, including safety assessments and safety analysis

reports. Currently team lead for accident analysis for the Spent Nuclear Fuel Project Cold Vacuum Drying Facility, CSB, and Hot Conditioning System.

David L. Scott

M.S., Chemical Engineering. Twenty-six years of professional experience in safety analysis, process engineering, project engineering and development work related to the nuclear and petrochemical industries. Over 5 years of experience at the Hanford Site working in safety analysis and risk assessment. Work in other areas includes fluid flow analysis, pump and piping system design, uranium processing, N Reactor modification engineering, N Reactor nuclear fuel manufacturing, and organic chemical production.

Others who participated in the hazards analysis meetings and provided information to assist the process included

- Jeff Parker, Ares Corporation, facilitator for the sessions
- Maurice Higuera, CSB design information
- Richard Hulskamp, multicaster overpack and receiving crane design information.

This page intentionally left blank.

ATTACHMENT 3

**RELEASE CHARACTERISTICS FOR HAZARDOUS CONDITIONS
ASSOCIATED WITH OFFSITE (SITE BOUNDARY) AND
ONSITE (COLLOCATED WORKER) RECEPTORS**


This page intentionally left blank.

Table A3-1. Three-by-Three Likelihood and Consequence Ranking Matrix.

F3	4		
F2	2	5	
F1	1	3	6
	S1	S2	S3



Combinations that identify situations of major concern



Combinations that identify situations of concern

Table A3-2. Release Characteristics for Hazardous Conditions Associated with Offsite (Site Boundary) and Onsite (Collocated Worker) Receptors.

Designator	Hazardous energy source	Hazardous condition and initiator(s)	Bin	Release energy	Consequence/frequency categories
TV-H-06	Pressure, volume - pressure vessels (cask-MCO system)	Gases under high pressure are released because of MCO pressure relief (rupture disk or pressure relief valve), cask is open or leaks.	Pressurized release	High	S2/F2
TV-J-10	Explosives or pyrophorics - uranium and/or plutonium metal, zirconium	Pyrophoric material is exposed to air because of MCO-cask breach or failure to inert.	Exothermic reaction	High	S3/F1
TV-R-01	Natural phenomena - earthquake	Earthquake forces cause the MCO and cask to breach or cause the MCO to breach or relieve pressure with subsequent cask opening.	Pressurized release	Medium	S2/F2
SA-E-07	Rotation kinetic - MHEM turret	Rotating MHEM turret exerts a shearing force on either • MCO, causing a breach • Lifting cable, causing MCO to impact the service pit with no retrieval capability.	Fuel exposure MCO drop	Low Low	S2/F1 S2/F1
SA-F-05	Linear kinetic - receiving crane	Receiving crane collision with service station enclosure over a service pit containing an MCO causes MCO failure and loss of service station enclosure.	Fuel exposure	Low	S2/F2
SA-F-06	Linear kinetic - pressure vessel (MCO) blowdown	Pressurized gases within the MCO are released because of • High pressure in the MCO • Relief valve failure, rupture disk failure, or improperly closed process port.	Pressurized release Pressurized release	High Medium	S2/F1 S2/F1

Table A3-2. Release Characteristics for Hazardous Conditions Associated with Offsite (Site Boundary) and Onsite (Collocated Worker) Receptors.

Designator	Hazardous energy source	Hazardous condition and initiator(s)	Bin	Release energy	Consequence/frequency categories
SA-F-07	Linear kinetic - MHM lateral movement	MHM collision with service station enclosure over a service pit containing an MCO causes MCO failure and loss of service station enclosure. MHM movement while raising an MCO causes a shear force on either • MCO, causing a breach • Lifting cable, causing MCO to impact the service pit with no retrieval capability.	Fuel exposure	Low	S2/F2
SA-G-01	Mass, gravity, height - human effort	Tools or other items are dropped into the service pit causing either • Failure of the MCO relief valve or rupture disk, resulting in a pressurized release • A trapped object between the MCO and service pit wall, resulting in galling of the MCO as it is lifted.	Fuel exposure	Low	S2/F2
			MCO drop	Low	S2/F2
SA-G-03a	Mass, gravity, height - 5-ton gantry crane	Small parts of the gantry crane fall off into the service pit causing either • Failure of the MCO relief valve or rupture disk, resulting in a pressurized release • A trapped object between the MCO and service pit wall, resulting in galling of the MCO as it is lifted.	Pressurized release	Medium	S2/F3
			Pressurized release	Medium	S2/F3

Table A3-2. Release Characteristics for Hazardous Conditions Associated with Offsite (Site Boundary) and Onsite (Collocated Worker) Receptors.

Designator	Hazardous energy source	Hazardous condition and initiator(s)	Ein	Release energy	Consequence/frequency categories
SA-G-13	Mass, gravity, height - vessels (transportation cask, MCO)	A release could occur as a result of either - An MCO-cask drop from the receiving crane as it is lowered - An MCO drop from the MHM as it is raised.	MCO drop	Low	S2/F2
SA-H-06	Pressure, volume - pressure vessels (MCO and MCO-transportation cask system)	Pressurized gases are released because of - Excessive pressure in an MCO - Failure of MCO rupture disk or relief valve due to flaws or damage.	Pressurized release Pressurized release	High Medium	S2/F2 S2/F2
SA-J-06	Explosives or pyrophorics - hydrogen	A flammable hydrogen-air mixture is ignited because of relief valve actuation or disk rupture.	Deflagration	High	S3/F1
SA-J-10	Explosives or pyrophorics - plutonium and uranium metal, zirconium	Pyrophoric material is exposed to air by MCO breach or failure to inert the MCO.	Exothermic reaction	High	S3/F1
SA-M-07	Hazardous materials - toxics (plutonium, uranium, beryllium, heavy metals)	Toxic materials are released with pressurized gases because of - Excessive pressure in an MCO - Failure of MCO rupture disk or relief valve due to flaws or damage.	Pressurized release Pressurized release	High Medium	S2/F3 S2/F3
SA-N-01	Ionizing radiation - fissile material	Fissile material is released because of - Excessive pressure in an MCO - Failure of MCO rupture disk or relief valve due to flaws or damage.	Pressurized release Pressurized release	High Medium	S2/F3 S2/F3

Table A3-2. Release Characteristics for Hazardous Conditions Associated with Offsite (Site Boundary) and Onsite (Collocated Worker) Receptors.

Designator	Hazardous energy source	Hazardous condition and initiator(s)	Bin	Release energy	Consequence/frequency categories
SA-N-03	Ionizing radiation - radioactive material	Radioactive material is released because of - Excessive pressure in an MCO - Failure of MCO rupture disk or relief valve due to flaws or damage.	Pressurized release Pressurized release	High Medium	S2/F3 S2/F3
SA-P-01	External events - explosion	MCO pressurizes after transport window is exceeded because of need to evacuate the facility.	Pressurized release	High	S2/F2
SA-P-03	External events - nearby facilities	MCO pressurizes after transport window is exceeded because of need to evacuate the facility.	Pressurized release	High	S2/F1
SA-R-01	Natural phenomena - earthquake (equal to or less than the design basis earthquake)	MCO undergoes pressure relief because of earthquake forces (includes potential loss of power and exceeding available transport window).	Pressurized release	High	S2/F2
SA-R-03	Natural phenomena - lightning	MCO pressurizes after transport window is exceeded because of loss of power.	Pressurized release	High	S2/F2
SA-R-05	Natural phenomena - snow, freezing weather	MCO pressurizes after transport window is exceeded because of delays in transport.	Pressurized release	High	S2/F3
SA-R-08	Natural phenomena - tornado	MCO pressurizes after transport window is exceeded because of delays caused by tornado.	Pressurized release	High	S3/F0*
SA-R-10	Natural phenomena - range fire	MCO pressurizes after transport window is exceeded because of loss of power or facility fire (secondary to range fire) requiring evacuation.	Pressurized release	High	S2/F3
OA-B-07	Thermal - radioactive decay heat and chemical reaction	Hot storage tube gases are released because high temperatures cause failure of the service cart.	Pressurized release	High	S2/F1
OA-D-01	Corrosives - acids (cart battery)	A leaking service cart battery causes the failure of the storage tube seals.	Pressurized release	Low	S2/F1

Table A3-2. Release Characteristics for Hazardous Conditions Associated with Offsite (Site Boundary) and Onsite (Collocated Worker) Receptors.

Designator	Hazardous energy source	Hazardous condition and initiator(s)	Bin	Release energy	Consequence/frequency categories
OA-E-07	Rotational kinetic - MHM turret	Rotation of the MHM turret before the MCO is fully lowered shears either • The MCO itself, causing a breach • The supporting cable, causing an MCO drop.	Fuel exposure MCO drop	High High	S2/F1 S2/F1
OA-F-07	Linear kinetic - MHM lateral movement	Movement of the MHM before the MCO is fully lowered shears either • The MCO itself, causing a breach • The supporting cable, causing an MCO drop.	Fuel exposure MCO drop MCO drop	High High High	S2/F2 S2/F2 S2/F2
OA-G-13	Mass, gravity, height - vessels (MCO)	Failure of the MHM supporting cable causes an MCO drop into the storage tube.			
OA-H-06a	Volume, pressure - pressure vessels (MCO)	Gases under high pressure are released from the MCO because of • High pressure in the MCO • Relief valve failure, rupture disk failure, or improperly closed process port.	Pressurized release Pressurized release	High Medium	S2/F3 S2/F3
OA-H-06b	Volume, pressure - pressure vessels (storage tube)	Gases under abnormally high pressure are released from the storage tube because of • Excessive vault temperatures and resultant chemical reactions in the MCO • MCO relief valve actuation with both tube relief paths closed off.	Pressurized release Pressurized release	High High	S2/F2 S2/F2

Table A3-2. Release Characteristics for Hazardous Conditions Associated with Offsite (Site Boundary) and Onsite (Collocated Worker) Receptors.

Designator	Hazardous energy source	Hazardous condition and initiator(s)	Bin	Release energy	Consequence/frequency categories
OA-1-06	Explosives or pyrophorics - hydrogen	A flammable hydrogen mixture is created and a deflagration occurs - Above the operating deck - Within the vault - Within the storage tube.	Deflagration Deflagration Deflagration	High High High	S3/F1 S3/F1 S3/F1
OA-1-10	Explosive or pyrophorics - plutonium and uranium metal	Pyrophoric material is exposed to the air because of an MCO breach that occurs with air present within the storage tube.	Exothermic reaction	High	S3/F1
OA-1-15	Flammable materials - hydraulic fluid for tube service cart, plug cover hoist	High heat from a fire fails the service cart while it is servicing a storage tube, resulting in releases from the service cart and potentially from the storage tube as well.	Pressurized release	Medium	S2/F2
OA-M-07	Hazardous materials - toxics	Toxic material is carried by gases under high pressure because of - High pressure in the MCO - Relief valve failure, rupture disk failure, or improperly closed process port.	Pressurized release Pressurized release	High Medium	S2/F3 S2/F3
OA-N-01, 03	Ionizing radiation sources - fissile and radioactive material	Radioactive materials are released because of MCO failure caused by - High pressure in the MCO (rupture disk actuation) - Relief valve failure, rupture disk failure, or improperly closed process port.	Pressurized release Pressurized release	High Medium	S2/F3 S2/F3
OA-R-01a	Natural phenomena - earthquake	Lateral and horizontal seismic forces cause relief valve actuation on multiple MCOs and increase reaction potential due to increased surface exposure.	Pressurized release	High	S2/F2

Table A3-2. Release Characteristics for Hazardous Conditions Associated with Offsite (Site Boundary) and Onsite (Collocated Worker) Receptors.

Designator	Hazardous energy source	Hazardous condition and initiator(s)	Bin	Release energy	Consequence/frequency categories
OA-R-08	Natural phenomena - tornado	Flying debris fails the storage tube plug, and/or MCO, or service cart while servicing the storage tube.	Pressurized release	High	S3/F0*
VL-B-07, 10	Thermal - radioactive decay heat and chemical reaction	High heat in the vault tubes causes pressurization of the MCOs, runaway chemical reactions, or structural degradation of the vault.	Exothermic reaction	High	S3/F2

*The likelihood of tornado missiles striking safety-class systems has been determined by analysis to be beyond extremely unlikely; therefore, these hazards are not binmed as candidate accidents.

F0 = too improbable to warrant consideration for further accident analysis development.

F1 = possible, but extremely unlikely.

F2 = foreseeable, but unlikely.

F3 = likely to occur during the lifetime of the facility.

MCO = multicannister overpack.

MHM = multicannister overpack handling machine.

S2 = sufficient material and release energy to affect an onsite receptor (collocated worker) 100 m from the source of the release.

S3 = sufficient material and release energy to affect a receptor at the nearest point of uncontrolled public access (Site boundary.)

Table A3-3. Binned Listing of Candidate Accidents Sorted by Release Energy and Risk Ranking.

Candidate accident	Release energy	Risk ranking	Reference designator
Pressurized releases			
MCO particulate release within the service pit due to high pressure ^a	High		
		3	SA-F-06
		5	SA-H-06
		7	SA-M-07
		7	SA-N-01
		7	SA-N-03
		5	SA-P-01
		3	SA-P-03
		5	SA-R-03
		7	SA-R-05
		7	SA-R-10
MCO particulate release within a storage tube due to high pressure	High		
		7	OA-H-06a
		7	OA-M-07
		7	OA-N-01
		7	OA-N-03
MCO pressurization in service pit due to earthquake forces	High	5	SA-R-01
		5	OA-H-06b
Storage tube pressurized release due to vault temperatures	High	5	
Storage tube pressurized release due to tube plug failure	High	5	OA-H-06b
Multiple MCO pressurized releases within storage tubes due to earthquake forces ^b	High	5	OA-R-01a
MCO pressurization within transportation cask with leak	High	5	TV-H-06
Service cart failure and pressurized release due to high storage tube temperatures	High	3	OA-B-07
MCO pressurized release within service pit due to MCO failure	Medium		
		3	SA-F-06
		7	SA-G-01
		7	SA-G-03a
		5	SA-H-06
		7	SA-M-07
		7	SA-N-01
		7	SA-N-03

Table A3-3. Binned Listing of Candidate Accidents Sorted by Release Energy and Risk Ranking.

Candidate accident	Release energy	Risk ranking	Reference designator
MCO pressurized release within a storage tube due to MCO failure	Medium	7 7 7	OA-H-06a OA-M-07 OA-N-01 OA-N-03
Earthquake-induced failure of MCO (coincident with transportation cask failure or lid removal)	Medium	5	TV-R-01
Storage tube pressurized release due to service cart failure	Medium/Low	3 5	OA-D-01 OA-L-15
Exothermic reactions			
Exothermic reaction in MCO due to excessive vault temperatures ^a	High	8 8	VL-B-07 VL-B-10
Exothermic reaction in MCO due to breach and loss of inert atmosphere	High	6 6 6	TV-J-10 SA-J-10 OA-J-10
Fuel exposure			
Fuel exposure in storage tube due to MHM impact ^a	High	3 5	OA-E-07 OA-F-07
Fuel exposure in service pit due to receiving crane or MHM impact	Low	3 5 5	SA-E-07 SA-F-05 SA-F-07
MCO drops			
MCO drop from MHM into storage tube ^a	High	3 5 5	OA-E-07 OA-F-07 OA-G-13
MCO drop from MHM into service pit	Low	3 5 5	SA-E-07 SA-F-07 SA-G-13
MCO drop from receiving crane	Low	5	SA-G-13

Table A3-3. Binned Listing of Candidate Accidents Sorted by Release Energy and Risk Ranking.

Candidate accident	Release energy	Risk ranking	Reference designator
Deflagrations			
Hydrogen deflagration within the service area ^a	High	6	SA-J-06
Hydrogen deflagration within the operating area (above deck or within storage tube)	High	6	OA-J-06
Hydrogen deflagration within the vault	High	6	OA-J-06

^aChosen as a representative and bounding accident for further accident analysis development.^bChosen as a unique hazardous condition.

MCO = multicannister overpack.

MHM = multicannister overpack handling machine.

This page intentionally left blank.

DISTRIBUTION SHEET

To	From	Page 1 of 1
Distribution	D. E. Krahn	Date 07/10/97
Project Title/Work Order		EDT No. 607691
Canister Storage Building Hazard Analysis Report, HNF-SD-SNF-HIE-001, Rev. 0		ECN No. N/A

Name	MSIN	Text With All Attach.	Text Only	Attach./ Appendix Only	EDT/ECN Only
W. C. Alaconis	R3-85	X			
G. D. Bazinet	S8-06	X			
R. D. Crowe	R3-15	X			
R. P. DiPiazza	R3-15	X			
L. J. Garvin	R3-15	X			
M. Guzman	R3-85	X			
T. D. Hays	S8-06	X			
T. G. Hersum	B1-19	X			
L. D. Kessie	E6-40	X			
S. D. Kopelic	R3-15	X			
D. E. Krahn	R3-15	X			
M. Kummerer	R3-15	X			
T. D. Merkling	X3-79	X			
R. P. Omberg	R3-15	X			
D. L. Scott	R3-15	X			
J. E. Turnbaugh	R3-15	X			
cc: M. J. Higuera	S0-04	X			
B. D. Lorenz	R3-15	X			
D. A. Reny	R3-15	X			
D. A. Smith	R3-15	X			
C. A. Thompson	R3-85	X			

Central Files	A3-88	X
---------------	-------	---