

AUG 21 1997

ENGINEERING DATA TRANSMITTAL

Page 1 of 1

1. EDT 620293

2. To: (Receiving Organization) Plutonium Finishing Plant		3. From: (Originating Organization) Criticality and Shielding		4. Related EDT No.: 620293	
5. Proj./Prog./Dept./Div.: PFP		6. Design Authority/ Design Agent/Cog. Engr.: W. D. Wittekind		7. Purchase Order No.: N/A	
8. Originator Remarks: Transmittal of Shielding Wall Calculations for PFP Vertical Calciner Glovebox				9. Equip./Component No.: N/A	
				10. System/Bldg./Facility: 234-5Z, PFP	
11. Receiver Remarks: 11A. Design Baseline Document? ☐ Yes ☒ No				12. Major Assm. Dwg. No.: N/A	
				13. Permit/Permit Application No.: N/A	
				14. Required Response Date: N/A	

15. DATA TRANSMITTED							
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	(F) Approval Designator	(G) Reason for Transmittal	(H) Originator Disposition
1	HNF-SD-CP-TI-218		0	PFP Vertical Calciner Shield Wall Dose Rate Calculations Using MCNP	S	1,2	/

16. KEY							
Approval Designator (F)		Reason for Transmittal (G)			Disposition (H) & (I)		
E, S, O, D or N/A (see WHC-CM-3-5, Sec.12.7)		1. Approval	4. Review		1. Approved	4. Reviewed no/comment	
		2. Release	5. Post-Review		2. Approved w/comment	5. Reviewed w/comment	
		3. Information	6. Dist. (Receipt Acknow. Required)		3. Disapproved w/comment	6. Receipt acknowledged	

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)											
(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN
1	1	Design Authority S.E. Huneyputt	<i>S.E. Huneyputt</i>	7-2-97	15-55						
1	1	Design Agent A.L. Ramble	<i>A.L. Ramble</i>	7-15-97	15-54						
1	1	Cog. Eng. W.D. Wittekind	<i>W.D. Wittekind</i>	7-18-97	H0-35						
1	1	Cog. Mgr. J. Greenberg	<i>J. Greenberg</i>	7-18-97	H0-35						
		QA N/A									
1	1	Safety S.E. Nunn	<i>S.E. Nunn</i>	8-19-97	15-11						
		Env. N/A									
1	1	Tech. Rev. H.J. Goldberg	<i>H.J. Goldberg</i>	7-18-97	H0-35						

18. <i>W.D. Wittekind</i> W.D. Wittekind Signature of EDT Originator 18 Jul 97		19. <i>S.E. Huneyputt</i> S.E. Huneyputt Authorized Representative for Receiving Organization 7-2-97		20. <i>J. Greenberg</i> J. Greenberg Design Authority / Cognizant Manager 7/18/97		21. DOE APPROVAL (if required) Ctrl. No. ☐ Approved ☐ Approved w/comments ☐ Disapproved w/comments	
---	--	---	--	--	--	---	--

PFP Vertical Calcliner Shield Wall Dose Rate Calculations Using MCNP

Warren D. Wittekind

Fluor Daniel Northwest, Richland, WA 99352

U.S. Department of Energy Contract DE-AC06-96RL13200

EDT/ECN: 620293

UC: 507

Org Code: 403

Charge Code: E56571

B&R Code: EW7003000

Total Pages: 86

Key Words: Calcliner, Vertical Calcliner, Dose Rate, Exposure, ALARA

Abstract: This report yields a neutron shield wall design for a full time occupancy dose rate of 0.25 mrem/h. ORIGEN2 generated gamma ray spectrum and neutron intensity for plutonium. MCNP modeled the calcliner glovebox and room for reflection of neutrons off concrete walls and ceiling. Neutron calculations used MCNP in mode n,p to include neutron capture gammas. Photon calculations used MCNP in mode p for gamma rays.


Neutron shield with lower 137.16 cm (4.5 feet) of 12.7 cm (5 inch) thick Lucite® and 0.3175 cm (0.125 inch) stainless steel on both sides, and upper 76.2 cm (2.5 feet) of 10.16 cm (4 inch) thick Lucite® and 1.905 cm (0.75 inch) thick glass on each side gave a total weighted dose rate of 0.23 mrem/h, fulfilling the design goal. Lucite® is considered to be equivalent to Plexiglas® since both are methylmethacrylate polymers.

¹Lucite is a registered trademark of E. I. du Pont de Nemours and Co.

²Plexiglas is a registered trademark of Rohm & Haas.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: WMC/BCS Document Control Services, P.O. Box 1970, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.



Warren D. Wittekind 8-21-97
Release Approval Date
Release Stamp

Approved for Public Release

PFP VERTICAL CALCINER SHIELD WALL DOSE RATE CALCULATIONS USING MCNP

CONTENTS

1.0	INTRODUCTION AND SUMMARY	1
2.0	DESCRIPTION OF SYSTEM AND FACILITY	2
3.0	PROCESS FLOW DESCRIPTION	2
4.0	GLOVEBOX MODELING FOR SHIELDING CALCULATIONS	2
4.1	CONCENTRATION AND COMPOSITION OF THE FISSILE MATERIAL	5
4.1.1	Feed Solution	5
4.1.2	Vertical Calciner Charge	6
4.1.3	Calcine (PuO_2) Product	6
4.2	ROOM 230C MODELING ASSUMPTIONS	6
4.3	GLOVEBOX	6
4.3.1	Calciner Section of Glovebox	7
4.3.2	Waste Section of Glovebox	7
4.3.3	Connecting Section of Glovebox	8
4.4	FEED SYSTEM	8
4.4.1	Feed Tanks	8
4.4.2	Other Feed System Volumes	9
4.5	VERTICAL CALCINER	9
4.5.1	The Lower Section	9
4.5.2	The Upper Section	10
4.5.3	Product Collection Tube	10
4.6	CONTAINERS	11
4.7	SCRUBBER SYSTEM	11
5.0	EVALUATION AND RESULTS	11
5.1	PLUTONIUM INVENTORY OF VERTICAL CALCINER GLOVEBOX	11
5.2	PLUTONIUM ACTIVITY CALCULATION BY ORIGEN2	12
5.3	COMPONENT DOSE RATE CALCULATION BY MCNP	12
5.4	EFFECTIVE DOSE RATE CALCULATION BY WEIGHTING	13
5.5	COMPARISON OF LUCITE AND LEXAN NEUTRON SHIELDING MATERIAL	14
5.6	COMPENSATION FOR INCREASED (α, n) IN PLUTONIUM NITRATE SOLUTION	15
5.7	DOSE RATE PATHWAYS TO OPERATOR BEHIND NEUTRON SHIELD	16
5.8	DOSE RATE ADJACENT TO CALCINER GLOVEBOX SOURCES	18
5.9	HANDS AROUND CONTAINERS	18
5.10	SHIELDS AROUND CONTAINERS	19
6.0	REFERENCES	21

APPENDICES

APPENDIX A	
INDEPENDENT REVIEW COMMENTS AND CHECKLIST	A-1
APPENDIX B	
ORIGEN2 PLUTONIUM INPUT FILE AND OUTPUT RESULTS	B-1
APPENDIX C	
NEUTRON SHIELDED OPERATOR DOSE RATE MCNP INPUT FILES	C-1
APPENDIX D	
HAND DOSE RATE MCNP INPUT FILES	D-1
APPENDIX E	
MISCELLANEOUS REFERENCE PAGES	E-1

LIST OF FIGURES

Figure 1. Vertical Calciner Glovebox and Neutron Shield Wall.	3
Figure 2. Vertical Calciner Glovebox Interior Measurements.	4

LIST OF TABLES

Table 4.1 Average Inventory Isotopic Composition	5
Table 4.2 Off-Gas Filter Dimensions	10
Table 5.1 Lucite® Neutron Shield	13
Table 5.2 Lexan® Neutron Shield	14
Table 5.3 Increased (α, n) Effect	15
Table 5.4 Lucite® Neutron Shield and Increased (α, n) in $\text{Pu}(\text{NO}_3)_4$	16
Table 5.5 Radiation Dose Rate From The Different Pathways	17
Table 5.6 Radiation Dose Adjacent to Unshielded Glovebox	18
Table 5.7 Hand Dose Rate From Receipt Cans	19
Table 5.8 Storage Can Cylindrical Shields - Dose Rates	20
Table 5.9 Storage Can Square Shields - Dose Rates	20

Title: PFP Vertical Calciner Shield Wall Dose Rate
Calculations using MCNP

Prepared by: W. D. Wittekind Date: 18 July 1997
W. D. Wittekind, Shielding Engineer
Criticality and Shielding

Reviewed by: H. J. Goldberg Date: 18 July 1997
H. J. Goldberg, Shielding Engineer
Criticality and Shielding

Approved by: J. Greenberg Date: 7/13/97
J. Greenberg, Manager
Criticality and Shielding

This page intentionally left blank

PFP VERTICAL CALCINER SHIELD WALL DOSE RATE CALCULATIONS USING MCNP

1.0 INTRODUCTION AND SUMMARY

This evaluation supports the fulfillment of the 0.25 mrem/h full time occupancy dose rate goal due to the calcining process inside this glovebox.

Assumptions for the source term included 350 g Pu/L in the $\text{Pu}(\text{NO}_3)_4$ solution with 10 Liters in both the feed tank (receipt) and feed tank (pump). The source term assumed in the vertical calciner is 3.5 kg Pu. The source term assumed 4.5 g Pu/cm³ in the PuO_2 compound in the two 1 L receipt cans and in four 0.5 L slip lid cans (total 4.0 L in cans). This quantities yielded a total of 7.0 kg Pu in the feed tanks, 3.5 kg Pu in the calciner, and 18.0 kg Pu in cans as the source term for the calciner glovebox. The dose rates from the different ²⁴⁰Pu wt% plutonium inventories were weighted according to their quantities for an effective average dose rate.

The design goal of 0.25 mrem/h for full time occupancy can be accomplished using 10.16 cm to 12.70 cm (4 in. to 5 in.) of Lucite^{®1} plastic neutron shielding with Stainless Steel and glass on each side of the Lucite[®] per the present design. The present design uses 12.70 cm (5 in.) of Lucite[®] with 0.3175 cm (0.125 in.) stainless steel on both sides on the lower 137.16 cm (4.5 ft) and uses 10.16 cm (4 in.) of Lucite[®] with 1.905 cm (0.75 in.) glass on both sides on the upper 76.20 cm (2.5 ft).

Lucite[®] is equivalent to Plexiglas^{®2} since both are methylmethacrylate ($:\text{CH}_2-\text{CH}_2-\text{C}(:-\text{CO}_2-\text{CH}_3 \text{ or } \text{C}_6\text{H}_5\text{O}_2)$) polymers. The main difference is that these are the trade names used by different manufacturers. The processing may be different, leading to different length polymer chains, but similar elemental composition and similar densities are anticipated. In this document, when Lucite[®] is stated, this is to be considered equivalent to Plexiglas[®] as far as neutron and gamma (photon) shielding is concerned.

Operator dose rate was summed for the gamma, capture gamma, and neutron dose contributions from the feed tanks, the calciner, and the plutonium oxide collected in cans. Annual dose rates were scaled proportionately for the three categories of ²⁴⁰Pu material. The conversion from flux to dose used the ANS 6.1.1 1991 standard with the factor of 2 multiplied times the calculated neutron dose, as specified in ANS 6.1.1 1991.

The Lucite[®] shield achieved the design goal of 0.25 mrem/h, replacement with Lexan^{®3} calculated to 0.30 mrem/h exceeding the design goal using the same plutonium source and shield thickness as for the Lucite[®] calculation. The Lexan[®] is polycarbonate ($:\text{O}-\text{C}_6\text{H}_4-\text{C}(\text{CH}_3)_2(\text{C}_6\text{H}_4)\text{OCO}:$ or $\text{C}_{16}\text{H}_{14}\text{O}_3$) and was modeled as 1.2 g/cm³, while Lucite was modeled as 1.185 g/cm³.

¹ Lucite is a registered trademark of E. I. duPont de Nemours & Company

² Plexiglas is a registered trademark of Rohm & Haas Company

³ Lexan is a registered trademark of General Electric Company, Chemical Materials Department

2.0 DESCRIPTION OF SYSTEM AND FACILITY

The 234-5Z Building, commonly referred to as PFP (Plutonium Finishing Plant), is located in the 200 West area. This facility was historically used to process plutonium into oxide or metal forms. The facility is undergoing cleanup to stabilize plutonium still stored there.

The plutonium stabilization program at PFP includes conversion of acidic plutonium nitrate solution into plutonium oxide. Conversion is facilitated through use of a vertical calciner installed in Glovebox HC-230C-2, which is to be installed in room 230C of this facility.

3.0 PROCESS FLOW DESCRIPTION

Feed material enters as plutonium nitrate solution ($\text{Pu}(\text{NO}_3)_4$) of at least 1.3M HNO_3 or greater (Stubbs, 1997) and is collected in the two feed tanks. This feed material is pumped over to the vertical calciner and heated to an overall process temperature of 1000 °C in excess oxygen/air. A residence time in the calciner of at least 4 hours assists in heating the product to obtain PuO_2 with a low loss of weight on ignition (LOI).

Plutonium nitrate suitable for calcination in the vertical calciner is transferred from the HC-227S glovebox through double encased transfer line to a feed receipt tank located in glovebox HC-230C-2, room 230C. A controlled volume is then gravity fed into the feed pump tank. Once the feed pump tank contains the appropriate amount of solution, the valve from the feed receipt tank is closed, and the solution in the feed pump tank is mixed with atomizing air flow into a preheated bed of PuO_2 powder in the vertical calciner. The vertical calciner agitates the injected mixture between external and internal heaters to 1000°C to form plutonium oxide (PuO_2).

Off-gases from this process are removed through the top of the calciner by vacuum. Sintered ceramic filter elements are used to remove any entrained plutonium dioxide powder. The off-gases are then circulated through a scrubber before leaving the glovebox. Spent scrubber solution is staged within the glovebox for sampling before removal from the glovebox. The scrubber system is not expected to contain more than a token amount of fissile material (less than 0.01 g Pu/cm^3) during normal operations.

4.0 GLOVEBOX MODELING FOR SHIELDING CALCULATIONS

General arrangement of the vertical calciner with the approximate location of the neutron shield wall and operator at the electrical control panel are shown in Figure 1, Vertical Calciner Glovebox and Neutron Shield Wall. Interior details of the Vertical Calciner Glovebox, from hand measurements are illustrated in Figure 2, Vertical Calciner Glovebox Interior Measurements.

Plutonium isotopic compositions were calculated in ORIGEN2 (Croff, 1980; Wittekind, 1994; Schmittroth, 1993) for the gamma ray intensity and energy spectrum and the neutron activity. The neutron activity came from spontaneous fission of, primarily ^{240}Pu , and from (α, n) reaction in light elements, primarily oxygen.





Figure 2. Vertical Calciner Glovebox Interior Measurements.



MCNP (Briesmeister, 1993; Carter, 1996) was used to calculate the radiation exposure from the gamma ray source using mode p. MCNP was also used to calculate the radiation exposure from the neutron source due to neutrons and gamma rays due to capture gammas using the mode n, p. MCNP modeled the vertical calciner glovebox and the entire room with concrete floor, concrete roof, two concrete walls and two metal walls.

The conversion from flux to dose used the ANS 6.1.1 1991 standard with the factor of 2 multiplied times the calculated neutron dose, as specified in ANS 6.1.1 1991. The one exception is that ANS 6.1.1 1977 was used to convert neutron flux to dose for hands around plutonium containers. The ANS 6.1.1 1991 standard with the factor of 2 multiplied times the calculated neutron dose was used for all whole body dose calculations. The ANS 6.1.1 1977 neutron and photon dose conversion factors were reported in (rem/hr)/(n/cm²-s) and were multiplied by (1000. mrem/rem) to get (mrem/hr)/(n/cm²-s) for use in MCNP. The ANS 6.1.1 1991 neutron and photon dose conversion factors were reported in (Sv-cm²) and were multiplied by (3600. s/hr)*(100. rem/Sv)*(1000. mrem/rem) to get (mrem/hr)/(n/cm²-s) for use in MCNP.

4.1 CONCENTRATION AND COMPOSITION OF THE FISSILE MATERIAL

Average inventory plutonium isotopic composition is shown in Table 4.1.

Table 4.1 Average Inventory Isotopic Composition Plutonium Finishing Plant Stabilization DE Estimate dated May 16, 1996			
Isotope	Low ²⁴⁰ Pu Wt%	Mid ²⁴⁰ Pu Wt%	High ²⁴⁰ Pu Wt%
Pu-238	0.01	0.15	0.18
Pu-239	92.40	85.63	80.06
Pu-240	6.12	12.45	17.84
Pu-241	0.26	1.20	1.22
Pu-242	0.04	0.37	0.73
Am-241	0.18	1.06	1.79
Total Mass (g)	1,542,620	586,298	1,520,313

4.1.1 Feed Solution

The feed tank plutonium inventory assumption of 3.5 kg plutonium in each 10 liter tank volume calculates to a concentration of 350 g Pu/L in the plutonium nitrate (Pu(NO₃)₄) solution. The density of plutonium nitrate solution is 1.58 g/cm³. Feed solution at PFP may vary in plutonium concentration in PFP and PUREX solution processes. This 350 g Pu/L plutonium concentration is conservative based on the material balance flow sheet expected concentration of 250 g Pu/L (Table 1 in Stubbs, 1997). This 350 g Pu/L plutonium concentration is reasonable based on the plutonium concentration upper limit is the criticality limit (Limit and Control #2 in Hillesland, 1997) of 450 g (²³⁹Pu plus ²³⁵U)/L.

4.1.2 Vertical Calciner Charge

The vertical denitration calciner is expected (Section 3.4 in Stubbs, 1997) to be precharged with approximately 3 kg of PuO_2 (2.65 kg Pu) and feed solution is added at 2 L to 3 L per hour (500 g Pu to 750 g Pu per hour) and the PuO_2 drops out into the receipt can as atomized solution is added into the vertical calciner for normal operating conditions. The assumption of 3.5 kg Pu mass in the vertical calciner is reasonable based on this reference.

4.1.3 Calcine (PuO_2) Product

The maximum expected tap density of the calcine product is 5.0 g Pu/cm^3 , or $5.67 \text{ g PuO}_2/\text{cm}^3$ for normal operating conditions. This is based on experience with the PFP laboratory calciner, where normal product tap density was found to be 4.0 to 4.3 g Pu/cm^3 . A product density of 4.75 g Pu/cm^3 was reached when it was continuously heated and stirred without addition of fresh feed solution.

Calcine product average density of 4.5 g Pu/cm^3 was assumed for evaluation of the radiation dose rate due to plutonium oxide in containers.

4.2 ROOM 230C MODELING ASSUMPTIONS

Room 230C is modeled with:

- Interior height (949.96 cm - 0.0000 cm =) 949.96 cm (31 ft 2 in.),
- Interior width (541.02 cm + 231.14 cm =) 772.16 cm (25 ft 4 in.),
- Interior depth (735.0125 cm + 327.3425 cm) 1062.355 cm (34 ft 10.25 in.),
- Roof Concrete 10.16 cm (4 in.),
- Floor Concrete 60.96 cm (24 in.),
- Walls -Steel 0.2913 cm (0.1146 in.) [corrugated 18 gauge (0.0516 in.)],
-Concrete 20.32 cm (8 in.),
- Glovebox distance from concrete wall 190.50 cm (75 in.),
- Glovebox distance from steel wall 243.84 cm (96 in.).

The corrugated steel was estimated to be 4.0 times as long as the distance covered for an effective increase in the 18 gauge thickness from 0.0516 in. to 0.1146 in.

4.3 GLOVEBOX

Most of glovebox HC-230C-2 was originally constructed for the Fuels and Materials Examination Facility (FMEF). One portion of the glovebox, calciner section, is primarily used for the calcination process. Another section, waste section, is used to process waste scrubber solution. The third section, connecting section, connects the HC-230C-2 glovebox to the HC-3 conveyor for further processing.

4.3.1 Calciner Section of Glovebox

The calciner section of glovebox is modeled with:

- Interior height (265.7475 cm -87.3125 cm =) 178.435 cm (70.25 in.).
- Interior width (220.6625 cm +39.6875 cm =) 260.35 cm (102.50 in.).
- Interior depth (21.2725 cm +82.5500 cm =) 103.8225 cm (40.875 in.).
- Walls -Stainless Steel 0.2381 cm (3/32 in.),
 -Lead 0.4763 cm (3/16 in.),
 -Stainless Steel 0.2381 cm (3/32 in.).
- Exterior height (266.7000 cm -86.3600 cm =) 180.34 cm (71.000 in.).
- Exterior width (221.6150 cm +40.6400 cm =) 262.255 cm (103.25 in.).
- Exterior depth (22.2250 cm +83.5025 cm =) 105.7275 cm (41.625 in.).
- Glovebox height above concrete floor 86.36 cm (34.00 in.).

These values are based on scaling from a preliminary drawing and hand measurements. The walls of the glovebox are made from lead sealed between two layers of steel. The lead is 0.476 cm (3/16 in.) thick between the stainless steel layers. The stainless steel layers are each 0.238 cm (3/32 in.) thick.

The basic model for the calciner section contains the following fissile quantities:

- Both feed tanks filled to 10 Liters of 350 g Pu/L solution is 7.0 kg Pu.
- The calciner contains 3.5 kg Pu. This section of the calciner is surrounded by 30.48 cm (12 in.) thick insulation.
- Product receiver can or storage cans may hold 3.6 kg Pu in a single container. Each container is filled with 4.5 g Pu/cm³ dry product. A 4 Liter volume at 4.5 g Pu/cm³ dry PuO₂ product is 18.0 kg Pu.

The calciner section of the glovebox, as compared to the waste section and the connection section of the glovebox, contains the bulk of the fissile material for analysis of the entire glovebox. This calciner section is used as the model throughout this analysis.

4.3.2 Waste Section of Glovebox

The waste section of the glovebox contains solution used for scrubbing of the off-gasses that come from the calciner. The width of the glovebox (minimum horizontal dimension) is indicated as 107 cm (42 in.) based on a preliminary drawing with dimensions, and scaling from a second preliminary drawing. The total length of the waste section is only 124.5 cm (49 in.). The waste section includes two tanks (four cylinders) for storage of spent scrubber solution. These tanks are referred to as spent scrubber receipt tanks (SSRTs).

Because the calciner section of the glovebox contains the bulk of the fissile material of the entire glovebox, the waste section was not modeled in the shielding calculations.

4.3.3 Connecting Section of Glovebox

The connecting section of the glovebox will provide access to one end of the HC-3 conveyer glovebox. Operators will need to move 0.5 L slip-lid cans 1.8 m (6 ft) by hand from the connecting section of the glovebox to the end of the conveyor to be transported to glovebox HC-21A for and into storage in the Hanford Convenience Can (HCC). The phase separation tank is on the border of this section and the calciner section.

Because the calciner section of the glovebox contains the bulk of the fissile material of the entire glovebox, the connecting section was not modeled in the shielding calculations.

4.4 FEED SYSTEM

The feed system for the calciner is mainly located within the calciner portion of the glovebox. The calciner portion of the glovebox includes two feed tanks, a flush tank, feed lines, valves, air supply, and a pump for the feed system. The vent catch tank in the waste section of the glovebox is used to catch overflow from the feed tanks and the flush tank.

4.4.1 Feed Tanks

A feed tank has a nominal capacity of 10 L, which means that a feed tank filled with 350 g Pu/cm³ feed solution holds a total of 3.5 kg.

Both feed tanks are made from 6 inch Pyrex^{®4} pipe. The feed receipt tank is modeled with:

- Inside radius 7.7610 cm (3.0555 in.),
 - Outside radius 8.4534 cm (3.3281 in.),
 - Pyrex[®] wall thickness 0.6924 cm (0.2726 in.).
- Assumes 5/16 in. wall less 0.040 in. tolerance.
- Height (233.6800 cm -171.7200 cm =) 61.96 cm (24.3937 in.),
 - Solution height (224.5663 cm -171.7200 cm =) 52.8463 cm (20.8056 in.),
 - Distance feed tank centerline to east wall 21.2725 cm (8.375 in.),
 - Distance feed tank centerline to south wall 39.6875 cm (15.625 in.),
 - Distance feed tank bottom to glovebox floor
(171.72 cm -87.3125 cm =) 84.4075 cm (33.2313 in.).

Vendor data indicates an inside diameter of 15.71 cm (6.186 in.) including tolerances. The height of both feed tanks is nominally 60.96 cm (24 in.). The bottom and top of each tank is a 28.575 cm (11.25 in.) diameter, 1.27 cm (1/2 in.) thick steel flange as measured in the fabrication shop. There is a second flange on both the top and bottom used to hold the pipe in place, which is not included in the model. The feed pump tank was not modeled.

⁴ Pyrex is a registered trademark of Corning Glass Works

The feed pump tank is about 109.5 cm (43 1/8 in.) from the south wall, and the feed receipt tank about 40.01 cm (15 3/4 in.) from the south wall, as determined by scaling from a preliminary drawing and confirmation by hand measurement. The bottom of the feed pump tank internal volume is 16.51 cm (6 1/2 in.) from the floor as determined by hand measurement, and the bottom of the internal volume for the feed receipt tank is 83.32 cm (33 in.) from the floor as determined by scaling from a preliminary drawing and confirmed by hand measurement. Dose rate from feed receipt tank was multiplied by two that assumes 350 g Pu/L in 10 Liters in both feed tanks.

4.4.2 Other Feed System Volumes

All pumps in the glovebox have negligible holdup volume for the purpose of this analysis. The waste section of the glovebox contains a vent catch tank, which collects liquid overflow from the feed system. There is a flush tank connected to the feed pump that is used to facilitate restart after unplanned shutdown, and an air supply tank used to atomize feed solution for injection into the calciner. The flush tank has a nominal capacity of only 4 L, the air supply has even less, and neither will contain fissile material under normal conditions.

No other feed system volumes were modeled in the shielding calculations.

4.5 VERTICAL CALCINER

The production vertical calciner is virtually identical to the prototype currently in the 188-1 glovebox at PFP. Drawing number H-2-95609 (BWHC, 1997) shows dimensions for this new production calciner. The outer vessel of the calciner consists of two sections of 310 stainless steel, 6 inch schedule 10 pipe. The dimensions for this pipe as modeled are 16.15 cm (6.357 in.) ID, 16.83 cm (6.625 in.) OD. Details specific to each section of pipe are given below.

4.5.1 The Lower Section

The heating and agitation of the product take place in the lower portion of the calciner. There is a dome made from 4 inch pipe and pipe cap in the center extending up 17.95 cm (7.066 in.) into the internal volume of the calciner from the bottom. Although the product collection tube will often be filled with product during normal operating conditions, it is of negligible importance for shielding calculations and because it only extends up into the annular region of the calciner.

This section is wrapped in a highly water absorbent insulation. The thickest portion of the insulation is 15.24 cm (6 in.), the insulation is modelled as a close-fitting annulus just over 30.48 cm (12 in.) thick along its entire axial length. The insulation is 10.16 cm (4 in.) thick and its inner surface is 9.366 cm (3.688 in.) from the outside surface of the calciner vessel along most of the middle portion of the insulation's axial length.

4.5.2 The Upper Section

The upper calcining section contains filter elements for filtering particulates from the off-gasses produced in the calcining process. The filters were modeled based on dimensions from the model used in CSER 95-005 for the calciner in glovebox 188-1 (Geiger, 1995a and 1995b) and a third party reference to personal correspondence with L.H. Rodgers, as there were no drawings made available for these dimensions. These dimensions were used in the base case model for the calciner section of the glovebox as described in Section 4.2.1. Later hand measurements of the production calciner filters by J.F. Durnil yielded different internal dimensions. A list of dimensions for both filter models is given in Table 4.2 below. The inside dimensions are important only for the case of feed solution filling the calciner.

Table 4.2 Off-Gas Filter Dimensions		
Dimension	From CSER 95-005 (Geiger, 1995a)	Measurement by J.F. Durnil
Total Length	30.48 cm (12 in.)	30.80 cm (12 1/8 in.) - modeled as 30.48 cm (12 in.)
Outside Diameter	5.080 cm (2 in.)	5.080 cm (2 in.)
Inside Diameter	2.870 cm (1.13 in.)	3.651 cm (1 7/16 in.)
Bottom Thickness	3.810 cm (1.5 in.)	2.858 cm (1 1/8 in.)

This section is wrapped in metal reflective insulation that does not absorb liquids (see Appendix B of Geiger, 1995b). The manufacturer supplied drawings show an outside diameter of 40 cm (15.75 in.) and a height of 36.83 cm (14.5 in) for the prototype calciner. These are the dimensions used for the production calciner, as there was no information available on these dimensions at the time of the analysis. The insulation was modeled as being 10% density 304L steel to accommodate the concentric sheets and narrow strips of sheet metal used to create many spaces of dead air within the insulation. In any case, the amount of steel modeled is small.

4.5.3 Product Collection Tube

A product collection tube is used to feed the final product from the calciner into product receipt cans. The outside pipe of the tube is 1 in. schedule 10s pipe. The top of the tube is inside the center dome of the calciner. There is a 11.43 cm (4.5 in.) tall slot in the side of the dome, and a slot cut into the side of the tube to allow product to flow from the calciner down the tube into an attached product receipt can. The height of the product inside the calciner is controlled by a weir inside the tube. The flow of product is controlled by a valve attached to the product collection tube. The tube was found to adjust such that the bottom may range between 12.7 cm (5 in.) to 30.48 cm (12 in.) from the glovebox floor based on hand measurement in the fabrication shop.

4.6 CONTAINERS

There are three types of plutonium oxide containers that will be allowed in the glovebox: product receiver vessels, 0.5 L containers (1 pound slip lid cans and polyjars), and 30 mL sample jars. A limit requires that no more than two unit masses of 2 L each be in the glovebox at one time.

Two receipt cans are considered: a 3.6 kg Pu can, and a 1.8 kg Pu can. The dimensions of the 3.6 kg Pu receipt can are:

4.6038 cm (1.8125 in. or 1 13/16 in.) Inside Radius
 4.7625 cm (1.8750 in. or 1 7/8 in.) Outside Radius
 11.2713 cm (4.4375 in. or 4 7/16 in.) Inside Height
 11.43 cm (4.5 in. or 4 1/2 in.) Outside Height

The dimensions of the 1.8 kg Pu receipt can are:

3.8894 cm (1.53125 in. or 1 17/32 in.) Inside Radius
 4.0481 cm (1.5937 in. or 1 19/32 in.) Outside Radius
 7.8582 cm (3.0938 in. or 3 3/32 in.) Inside Height
 8.0169 cm (3.1563 in. or 3 5/32 in.) Outside Height

The 0.5 L (nominal) containers proposed for use in the HC-230C-2 glovebox are the 1 pound slip lid can (part number 42-1500-300) with the dimensions of 8.89 cm (3.5 in.) OD x 8.89 cm (3.5 in.) height, and the polyjar (part number 57-6359-160) with the dimensions of 8.255 cm (3.25 in.) OD x 10.16 cm (4 in.) height. The total internal volume for the 1 pound slip lid can is 552 mL, and for the polyjar it is 543 mL.

A unit mass is considered to be 2 Liters. There are permitted to be two unit masses in containers inside the vertical calciner glovebox at the same time. This is a total volume of 4 Liters of PuO_2 . Because of the assumed density of 4.5 g Pu/L , this equates to $4 \text{ L} * 4.5 \text{ kg Pu/L} = 18 \text{ kg Pu total}$. The dose calculation is performed for 3.6 kg Pu per receipt can, so the contribution to the total radiation dose rate from PuO_2 in containers is calculated for five of these 3.6 kg Pu receipt cans.

4.7 SCRUBBER SYSTEM

The scrubber system is not expected to contain more than a token amount of fissile material (less than 0.01 g Pu/cm^3) during normal operations. No scrubber system volumes were modeled in the shielding calculations.

5.0 EVALUATION AND RESULTS

5.1 PLUTONIUM INVENTORY OF VERTICAL CALCINER GLOVEBOX

The vertical calciner glovebox plutonium inventory is assumed to be:

- 7.0 kg plutonium in $\text{Pu}(\text{NO}_3)_4$ solution in the two 10 Liter feed tanks,
- 3.5 kg plutonium in PuO_2 in the vertical calciner, and
- 18.0 kg plutonium in PuO_2 in 4 Liter total volume of containers.

There is sufficient plutonium assumed in these separate components to compensate for the plutonium solution in the piping into the feed tank in the glovebox, and between the feed tanks and the vertical calciner, as well as the possibility that there may be spilled plutonium on the glovebox floor.

The feed tank plutonium inventory assumption of 3.5 kg plutonium in each 10 Liter tank volume calculates to a concentration of 350 g Pu/L in the plutonium nitrate ($\text{Pu}(\text{NO}_3)_4$) solution. This plutonium concentration is conservative based on the material balance flow sheet assumption (Table 1 in Stubbs, 1997) of 250 g Pu/L. This plutonium concentration is reasonable based on the plutonium concentration upper limit, is the criticality limit (Limit and Control #2 in Hillesland, 1997) of 450 g (^{239}Pu plus ^{235}U)/L.

The vertical calciner plutonium inventory assumption is 3.5 kg plutonium. This plutonium inventory in the vertical calciner is reasonable based on the material balance flow sheet assumption of 3.0 kg plutonium for calciner bed holdup (Table 1 in Stubbs, 1997).

The container plutonium inventory in receipt cans (two at 1 Liter each) and storage cans (four slip lid cans at 0.5 Liters each) assumption of 18 kg plutonium in a total volume of 4 Liters calculates to a density of 4.5 g Pu/cm^3 . Normal tap density for a PFP laboratory calciner was reported to be 4.0 g Pu/cm^3 to 4.3 g Pu/cm^3 (Page 5 in Hillesland, 1997). This plutonium density is reasonable based on the 3.6 g PuO_2/cm^3 highest observed calcined plutonium density starting with plutonium nitrate (Page II.C.2-2 in ARC-600). The plutonium density upper limit is the criticality limit (Limit and Control #1 in Hillesland, 1997) of 5.5 g Pu/cm^3 .

5.2 PLUTONIUM ACTIVITY CALCULATION BY ORIGEN2

This radiation shielding calculation began with the isotopic compositions of the plutonium in the calciner feed stock. An ORIGEN2 calculation converted the plutonium into gamma ray intensity and energy spectrum, as well as a spontaneous neutron activity and an (α, n) neutron activity. The gamma ray intensity and energy spectrum were used for the source term in MCNP in mode p to calculate the direct gamma ray flux. The neutron activity was used for the source term in MCNP in mode n,p to calculate the neutron flux and the associated (n, γ) induced gamma ray flux.

The ORIGEN2 input file as well as calculated gamma ray energy spectrum and neutron sources are listed in Appendix B, ORIGEN2 Plutonium Input File and Output Results.

5.3 COMPONENT DOSE RATE CALCULATION BY MCNP

The conversion from flux to dose used the ANS 6.1.1 1991 standard. The photon flux to dose rate conversion was used directly, but the neutron flux to dose rate conversion was multiplied by the factor of 2, as specified in ANS 6.1.1 1991. The total radiation dose rate from a single plutonium source is the sum of these individual gamma ray, neutron, and induced gamma ray dose rate contributions. The total calciner glovebox radiation dose rate expected from the calciner glovebox is the sum of contributions from plutonium in all the individual sources within the glovebox such as the feed tank, the vertical calciner, and the storage cans. There are two feed tanks, one is the feed tank (receipt), and the other is the feed tank (pump), but both are the same 10 Liter volume. The vertical calciner is considered for its plutonium inventory. The plutonium oxide in storage cans without the shielding of the feed tank or the vertical calciner contributes more to the radiation dose rate for the same quantity of plutonium.

The plutonium mass assumed 350 g Pu/L in the $\text{Pu}(\text{NO}_3)_4$ solution with a total of 10 Liters in both the feed tank (receipt) and feed tank (pump). The plutonium mass assumed in the calciner is 3.5 kg Pu. The container plutonium mass assumed 4.5 g Pu/cm³ in the PuO_2 compound in the two 1 L receipt cans and in four 0.5 L slip lid cans (total 4.0 L in cans). This quantities yielded a total of 7.0 kg Pu in the feed tanks, 3.5 kg Pu in the calciner, and 18.0 kg Pu in cans as the source term for the calciner glovebox.

5.4 EFFECTIVE DOSE RATE CALCULATION BY WEIGHTING

Operator dose rate is added from gamma, capture gamma, and neutron dose contributions from feed tanks, vertical calciner, and plutonium oxide collected in cans. Annual dose rates were scaled proportionately for the three categories of ^{240}Pu material.

Table 5.1 neutron shield wall design with lower 137.16 cm (4.5 feet) of 12.7 cm (5 in.) thick Lucite® and 0.3175 cm (0.125 in.) stainless steel on both sides, and upper 76.20 cm (2.5 feet) of 10.16 cm (4 in.) thick Lucite® and 1.905 cm (0.75 in.) thick glass on each side gave a total dose rates of 0.034 mrem/h (high ^{240}Pu), 0.025 mrem/h (medium ^{240}Pu), and 0.012 mrem/h (low ^{240}Pu) for 3.5 kg plutonium inside the vertical calciner.

Table 5.1 Lucite® Neutron Shield Bottom 4.5 ft. is 5 in. Lucite® and 1/8 in. SST Both Sides Top 2.5 ft. is 4 in. Lucite® and 3/4 in. Glass Both Sides Source Term used High ^{240}Pu Category Plutonium 0.23 mrem/h = 1xCalciner + 2xFeed Tank + 5xStorage Can				
Calciner with 3.5 kg Plutonium - Dose Rates behind Neutron Shield (mrem/h)				
cca08anp.out		High Pu-240	Mid Pu-240	Low Pu-240
3.13090E-02 0.0680	Neutron	3.13090e-02	2.28184e-02	1.11439e-02
1.03211E-03 0.0648	Gamma (n, γ)	1.03211e-03	7.52216e-04	3.67361e-04
1.68063E-03 0.3923	Gamma	1.68063e-03	1.11423e-03	3.16599e-04
0.229874	0.023004	Total	3.40217e-02	2.46849e-02
Feed Tank with 3.5 kg Plutonium - Dose Rates behind Neutron Shield (mrem/h)				
cft08anp.out		High Pu-240	Mid Pu-240	Low Pu-240
3.47302E-02 0.0216	Neutron	3.47302e-02	2.53118e-02	1.23616e-02
1.90412E-03 0.0183	Gamma (n, γ)	1.90412e-03	1.38775e-03	6.77738e-04
6.89650E-03 0.0799	Gamma	6.89650e-03	4.57228e-03	1.29917e-03
	0.02905	Total	4.35308e-02	3.12719e-02
Storage Can's 3.6 kg Plutonium - Dose Rates behind Neutron Shield (mrem/h)				
csc08anp.out		High Pu-240	Mid Pu-240	Low Pu-240
4.10801E-02 0.0602	Neutron	4.10801e-02	2.99397e-02	1.46217e-02
1.44262E-03 0.0537	Gamma (n, γ)	1.44262e-03	1.05140e-03	5.13475e-04
1.38752E-03 0.2774	Gamma	1.38752e-03	9.19907e-04	2.61383e-04
	0.029754	Total	4.39102e-02	3.19110e-02

Weighting an annual dose rate proportional to plutonium quantities in the different ^{240}Pu wt% categories for an average radiation dose rate is:

$$(0.034 \times 1,542,620. + 0.025 \times 586,298. + 0.012 \times 1,520,313.) / 3,649,231. = 0.023 \text{ mrem/h}$$

for 3.5 kg plutonium in the vertical calciner. Similar calculations are performed in Table 5.1 for 3.5 kg plutonium in the feed tank, and for 3.6 kg plutonium in storage cans. Adding:

$$1 \times (\text{vertical calciner}) + 2 \times (\text{feed tank}) + 5 \times (\text{storage cans}) = \text{average mrem/h}$$

$$1 \times (0.023 \text{ mrem/h}) + 2 \times (0.029 \text{ mrem/h}) + 5 \times (0.030 \text{ mrem/h}) = 0.23 \text{ mrem/h}$$

satisfying the 0.25 mrem/h design limit, fulfilling the design goal.

5.5 COMPARISON OF LUCITE AND LEXAN NEUTRON SHIELDING MATERIAL

Table 5.2 neutron shield wall design with lower 4 1/2 feet of 5 inches thick Lexan® and 1/8 inch stainless steel on both sides, and upper 2 1/2 feet of 4 inches thick Lexan® and 3/4 inches thick glass on each side gave a total weighted dose rate of 0.30 mrem/h, exceeding the design goal.

Table 5.2 Lexan® Neutron Shield					
Bottom 4.5 ft. is 5 in. Lexan® and 1/8 in. SST Both Sides					
Top 2.5 ft. is 4 in. Lexan® and 3/4 in. Glass Both Sides					
Source Term used High ²⁴⁰ Pu Category Plutonium					
0.30 mrem/h = 1xCalciner + 2xFeed Tank + 5xStorage Can					
Calciner with 3.5 kg Plutonium - Dose Rates behind Neutron Shield (mrem/h)					
cca08bnp.out			High Pu-240	Mid Pu-240	Low Pu-240
3.92718E-02 0.0640		Neutron	3.92718e-02	2.86218e-02	1.39781e-02
8.50756E-04 0.0696		Gamma (n,γ)	8.50756e-04	6.20043e-04	3.02811e-04
1.90409E-03 0.3617		Gamma	1.90409e-03	1.26239e-03	3.58695e-04
0.295817	0.028431	Total	4.20266e-02	3.05042e-02	1.46396e-02
Feed Tank with 3.5 kg Plutonium - Dose Rates behind Neutron Shield (mrem/h)					
cft08bnp.out			High Pu-240	Mid Pu-240	Low Pu-240
4.26543E-02 0.0194		Neutron	4.26543e-02	3.10870e-02	1.51820e-02
1.79059E-03 0.0191		Gamma (n,γ)	1.79059e-03	1.30501e-03	6.37329e-04
7.12845E-03 0.0729		Gamma	7.12845e-03	4.72606e-03	1.34287e-03
	0.034501	Total	5.15733e-02	3.71181e-02	1.71622e-02
Storage Can's 3.6 kg Plutonium - Dose Rates behind Neutron Shield (mrem/h)					
csc08bnp.out			High Pu-240	Mid Pu-240	Low Pu-240
5.58616E-02 0.0513		Neutron	5.58616e-02	4.07127e-02	1.98829e-02
1.30592E-03 0.0590		Gamma (n,γ)	1.30592e-03	9.51772e-04	4.64819e-04
1.32357E-03 0.2906		Gamma	1.32357e-03	8.77509e-04	2.49336e-04
	0.039677	Total	5.84911e-02	4.25420e-02	2.05971e-02

The Lucite® was modeled as methyl methacrylate ($C_5H_8O_2$ at 1.185 g/cm^3), while the Lexan® was modeled as polycarbonate ($C_{16}H_{14}O_3$ at 1.2 g/cm^3) (Table 9.2-33 in Jaeger et. al. 1975).

5.6 COMPENSATION FOR INCREASED (α, n) IN PLUTONIUM NITRATE SOLUTION

The (α, n) activity for plutonium is calculated in ORIGEN2 according to the plutonium being plutonium oxide (PuO_2), while the plutonium in the feed tanks is actually in $Pu(NO_3)_4$ in aqueous solution. The (α, n) reaction could be twice as large in the solution as the (α, n) activity in PuO_2 .

Table 5.3 Increased (α, n) Effect Effect of Increased (α, n) Yield in Plutonium Nitrate Solution Compared to Plutonium Oxide			
	Low ^{240}Pu	Medium ^{240}Pu	High ^{240}Pu
(α, n) NEUTRON SOURCE (n/sec)			
TABLE	53.44	104.6	134.6
SPONTANEOUS FISSION NEUTRON SOURCE (n/sec)			
TABLE	50.5	108.1	155.6
OVERALL TOTAL			
TOTAL	103.9	212.7	290.2
2.0* (α, n) NEUTRON SOURCE (n/sec)			
TABLE	106.88	209.2	269.2
SPONTANEOUS FISSION NEUTRON SOURCE (n/sec)			
TABLE	50.5	108.1	155.6
OVERALL TOTAL			
TOTAL	157.38	317.3	424.8
RATIO OF TOTAL NEUTRON SOURCE WITH (α, n) DOUBLED TO ORIGINAL ORIGEN2 NEUTRON SOURCE			
	1.514726	1.491772	1.463818

Table 5.4 Lucite® Neutron Shield and Increased (α, n) in $\text{Pu}(\text{NO}_3)_4$ Factors from Table 1.3 Applied Bottom 4.5 ft. is 5 in. Lucite® and 1/8 in. SST Both Sides Top 2.5 ft. is 4 in. Lucite® and 3/4 in. Glass Both Sides Source Term used High ^{240}Pu Category Plutonium 0.25 mrem/h = 1xCalciner + 2xFeed Tank + 5xStorage Can				
Calciner with 3.5 kg Plutonium - Dose Rates behind Neutron Shield (mrem/h)				
cca08anp.out		High Pu-240	Mid Pu-240	Low Pu-240
3.13090E-02 0.0680	Neutron	3.13090e-02	2.28184e-02	1.11439e-02
1.03211E-03 0.0648	Gamma (n, γ)	1.03211e-03	7.52216e-04	3.67361e-04
1.68063E-03 0.3923	Gamma	1.68063e-03	1.11423e-03	3.16599e-04
0.253781	0.023004	Total	3.40217e-02	2.46849e-02
1.18278e-02				
Feed Tank with 3.5 kg Plutonium - Dose Rates behind Neutron Shield (mrem/h)				
cft08anp.out		High Pu-240	Mid Pu-240	Low Pu-240
3.47302E-02 0.0216	Neutron	3.47302e-02	2.53118e-02	1.23616e-02
1.90412E-03 0.0183	Gamma (n, γ)	1.90412e-03	1.38775e-03	6.77738e-04
6.89650E-03 0.0799	Gamma	6.89650e-03	4.57228e-03	1.29917e-03
	0.041003	Total	6.05225e-02	4.44020e-02
2.10502e-02				
Storage Can's 3.6 kg Plutonium - Dose Rates behind Neutron Shield (mrem/h)				
csc08anp.out		High Pu-240	Mid Pu-240	Low Pu-240
4.10801E-02 0.0602	Neutron	4.10801e-02	2.99397e-02	1.46217e-02
1.44262E-03 0.0537	Gamma (n, γ)	1.44262e-03	1.05140e-03	5.13475e-04
1.38752E-03 0.2774	Gamma	1.38752e-03	9.19907e-04	2.61383e-04
	0.029754	Total	4.39102e-02	3.19110e-02
1.53966e-02				

5.7 DOSE RATE PATHWAYS TO OPERATOR BEHIND NEUTRON SHIELD

The dose rate pathways were calculated by using MCNP to flag tallies that arrived at the cell behind the neutron shield after having traversed specified cells that completely surround the operator. The results are tabulated in Table 5.5, Radiation Dose Rate From The Different Pathways. These results can be tabulated as follows:

Plutonium Source:	Calciner	Feed Tank	Containers
Dominant Radiation:	Neutron	Neutron	Neutron
Principal Pathway(s):	F-L n Shield, &	Open End, &	F-L n Shield, &
F-L=Front Lower,	S-L n Shield.	F-U n Shield, &	Concrete Floor.
S-L=Side Lower, etc.		F-L n Shield.	

Table 5.5 Radiation Dose Rate From The Different Pathways Upper n Shield: Lucite® 4 inches, 3/4" Glass Both Sides Lower n Shield: Lucite® 5 inches, 1/8" Stainless Steel Both Sides End n Shield: Lucite® 1 inch, Glass on Upper, SST on Lower			
Radiation Leakage or Reflection Path	Neutron mrem/h	Gamma (n, γ) mrem/h	Gamma mrem/h
<u>3.5 kg Pu-Calcliner</u>	cca08anp.out		cca08ap.out
Open End Leakage	3.58199E-03 0.1537	9.99946E-05 0.2490	1.81439E-07 1.0000
Front Lower Leakage	8.89764E-03 0.1281	6.83875E-04 0.0802	1.53766E-03 0.4263
Front Upper Leakage	4.46445E-03 0.1578	2.71602E-04 0.1326	1.42788E-04 0.4964
Side Lower Leakage	9.02347E-03 0.1349	1.05918E-04 0.2128	1.23192E-05 1.0000
Side Upper Leakage	2.61693E-03 0.2266	4.47746E-05 0.3100	5.29858E-06 1.0000
Roof Reflection	6.58581E-03 0.1427	6.59565E-05 0.3428	0.00000E+00 0.0000
Steel Wall Reflect	3.60208E-04 0.8342	1.52006E-06 0.8779	0.00000E+00 0.0000
Concrete Floor Effect	1.02145E-02 0.1137	4.22720E-04 0.1016	7.52464E-05 0.8600
Total mrem/h	3.13090E-02 0.0680	1.03211E-03 0.0648	1.68063E-03 0.3923
<u>3.5 kg Pu-Feed Tank</u>	cft08anp.out		cft08ap.out
Open End Leakage	1.15342E-02 0.0383	1.68144E-04 0.0573	3.61090E-04 0.2958
Front Lower Leakage	8.53409E-03 0.0427	1.05428E-03 0.0248	2.75062E-03 0.1286
Front Upper Leakage	1.04826E-02 0.0393	7.24873E-04 0.0290	3.70877E-03 0.1096
Side Lower Leakage	2.22065E-03 0.0865	7.95798E-05 0.0892	5.76960E-05 0.7623
Side Upper Leakage	1.16436E-03 0.1189	3.21004E-05 0.1263	4.65579E-05 0.5542
Roof Reflection	7.92388E-03 0.0460	8.25587E-05 0.0870	1.70399E-04 0.3378
Steel Wall Reflect	2.42680E-05 0.2353	5.82765E-06 0.2999	3.79737E-05 1.0000
Concrete Floor Effect	6.02326E-03 0.0452	3.69543E-04 0.0394	1.33840E-04 0.3316
Total mrem/h	3.47302E-02 0.0216	1.90412E-03 0.0183	6.89650E-03 0.0799
<u>3.6 kg Pu-Container</u>	csc08anp.out		csc08ap.out
Open End Leakage	5.94915E-03 0.1369	1.03303E-04 0.2023	0.00000E+00 0.0000
Front Lower Leakage	1.68798E-02 0.0942	1.02927E-03 0.0646	7.40678E-04 0.4289
Front Upper Leakage	7.92102E-03 0.1416	3.75458E-04 0.1009	6.30898E-04 0.3438
Side Lower Leakage	6.53228E-03 0.1512	1.18019E-04 0.2268	1.47267E-05 0.9442
Side Upper Leakage	2.41222E-03 0.2851	1.91220E-05 0.4054	2.05582E-06 0.8855
Roof Reflection	6.53887E-03 0.1348	4.83391E-05 0.3522	2.64173E-07 1.0000
Steel Wall Reflect	3.57984E-05 0.4548	2.32480E-07 1.0000	0.00000E+00 0.0000
Concrete Floor Effect	1.23256E-02 0.0976	5.46129E-04 0.0895	1.91549E-05 0.7516
Total mrem/h	4.10801E-02 0.0602	1.44262E-03 0.0537	1.38752E-03 0.2774

5.8 DOSE RATE ADJACENT TO CALCINER GLOVEBOX SOURCES

Table 5.6 Radiation Dose Adjacent to Unshielded Glovebox		
Dose Rate Location	Neutron mrem/h	Gamma mrem/h
3.5 kg Pu-Calcliner	cca08anp.out	cca08ap.out
x,y,z=-1.68593E+02 6.98500E+01 1.25971E+02	7.84649E+00 0.0281	1.25636E+00 0.0689
x,y,z=-1.68593E+02 1.13502E+02 1.25971E+02	1.63511E+00 0.0170	4.64801E-02 0.0533
x,y,z=-1.68593E+02 2.35903E+02 1.25971E+02	3.44401E-01 0.0111	9.66447E-03 0.0706
3.5 kg Pu-Feed Tank	cft08anp.out	cft08ap.out
x,y,z= 0.00000E+00 3.84534E+01 2.00000E+02	6.96388E+00 0.0046	3.09575E+02 0.0041
x,y,z= 0.00000E+00 1.13502E+02 2.00000E+02	9.86556E-01 0.0060	1.64459E-01 0.0270
x,y,z= 0.00000E+00 2.35903E+02 2.00000E+02	5.13981E-02 0.0248	1.46022E-02 0.1000
3.6 kg Pu-Containers	csc08anp.out	csc08ap.out
x,y,z=-1.26693E+02 8.58800E+01 9.31068E+01	1.24164E+01 0.0428	2.80244E-01 0.0407
x,y,z=-1.26693E+02 1.13502E+02 9.31068E+01	3.81204E+00 0.0126	9.70591E-02 0.0474
x,y,z=-1.26693E+02 2.35903E+02 9.31068E+01	4.98551E-01 0.0689	1.14574E-02 0.0564

5.9 HANDS AROUND CONTAINERS

To study the effects of hands in the glovebox, case was modified to form a case by placing a latex, water, latex layers around the radius of the receipt cans. The inside latex is 0.2381 cm (0.0937 in. or 3/32 in.) thick, the water representing hands is 2.54 cm (1 in.) thick, and the outside latex is 0.2382 cm (0.0938 in. or 3/32 in.) thick. The neutron and activation gamma dose rate as well as the direct gamma dose rate is calculated in the water annulus. The containers each hold dry 3.6 kg Pu or 1.8 kg Pu.

The tabulated results in Table 5.7, Hand Dose Rate from Receipt Cans, indicates that the dose rate to hands while holding a can is:

- 680 mrem/h for a 3.6 kg Pu can, and
- 475 mrem/h for a 1.8 kg Pu can.

Table 5.7 Hand Dose Rate From Receipt Cans Source Term used High ^{240}Pu Category Plutonium Neutron, Gamma Activation from mode n,p Gamma Dose from mode p 3.6 kg Pu can and 1.8 kg Pu can		
MCNP Results	mrem/h	$\pm\sigma$
crch02np.out, 3.6 kg Pu can, mode n,p		
3.48344E+02 0.0096	3.48344e+02	0.0096
2.60610E+00 0.0277	2.60610e+00	0.0277
crch02p.out, 3.6 kg Pu can, mode p		
3.29047E+02 0.1057	3.29047e+02	0.1057
TOTAL mrem/h	6.79997e+02	0.0562
crch03np.out, 1.8 kg Pu can, mode n,p		
1.99876E+02 0.0090	1.99876e+02	0.0090
1.39118E+00 0.0295	1.39118e+00	0.0295
crch03p.out, 1.8 kg Pu can, mode p		
2.75128E+02 0.0971	2.75128e+02	0.0971
TOTAL mrem/h	4.76395e+02	0.0599

Calculation of the relative uncertainty for the total dose rate to the hands would be done differently depending upon the assumptions. If the assumption of correlated uncertainties is made, then the uncertainty is:

$$(0.0096*3.48344E+2 + 0.0277*2.60610E0 + 0.1057*3.29047E+2)/6.79997E+2 \\ = 0.0569 \text{ for a combined uncertainty on total mrem/h.}$$

If the assumption of uncorrelated uncertainties is made, then the uncertainty is:

$$\text{SQRT}((0.0096*3.48344E+2)^2 + (0.0277*2.60610E0)^2 + (0.1057*3.29047E+2)^2)/6.79997E+2 \\ = 0.0514 \text{ for a combined uncertainty on total mrem/h.}$$

5.10 SHIELDS AROUND CONTAINERS

The reduction of neutron and gamma dose rates from containers is possible by shielding the containers by a neutron shield.

Two geometries were considered:

- Cylindrical, and
- Square or box.

Three materials were considered for container neutron shielding material:

- Borated Polyethylene 207,
- Borated Polyethylene 210,
- Lucite® or Plexiglas® (both are methylmethacrylate polymers).

Table 5.8 Storage Can Cylindrical Shields - Dose Rates Neutron (n.) and Photon Dose Rates (p.) (mrem/h) Source Term is 3.6 kg Plutonium in Dry PuO ₂		
PuO ₂ +30 cm	glovebox +30 cm	glovebox +152.8 cm
csc002an.out, no additional shield		
1.43506E+01 0.0695	4.45063E+00 0.0462	5.71320E-01 0.0541
csc002ap.out, no additional shield		
2.72155E-01 0.1384	1.10414E-01 0.3093	1.19380E-02 0.2616
csc003an.out, 1" cylindrical shield of borated poly 207		
8.52330E+00 0.0845	2.71223E+00 0.0452	3.60051E-01 0.0616
csc003ap.out, 1" cylindrical shield of borated poly 207		
2.21859E-01 0.1557	9.69784E-02 0.3526	1.02630E-02 0.3003
csc003bn.out, 1" cylindrical shield of borated poly 210		
8.24647E+00 0.0486	2.84517E+00 0.0462	3.69602E-01 0.0549
csc003bp.out, 1" cylindrical shield of borated poly 210		
2.30997E-01 0.1517	9.78125E-02 0.3456	1.03615E-02 0.2933
csc003en.out, 1" cylindrical shield of Lucite®		
8.88006E+00 0.0505	3.03598E+00 0.0459	3.97229E-01 0.0479
csc003ep.out, 1" cylindrical shield of Lucite®		
2.28606E-01 0.1533	9.69384E-02 0.3503	1.01284E-02 0.3009
Table 5.9 Storage Can Square Shields - Dose Rates Neutron (n.) and Photon Dose Rates (p.) (mrem/h) Source Term is 3.6 kg Plutonium in Dry PuO ₂		
PuO ₂ +30 cm	glovebox +30 cm	glovebox +152.8 cm
csc002an.out, no additional shield		
1.43506E+01 0.0695	4.45063E+00 0.0462	5.71320E-01 0.0541
csc002ap.out, no additional shield		
2.72155E-01 0.1384	1.10414E-01 0.3093	1.19380E-02 0.2616
csc003cn.out, 1" square shield of borated poly 207		
1.44633E+01 0.3689	2.89555E+00 0.0601	3.80961E-01 0.0565
csc003cp.out, 1" square shield of borated poly 207		
2.14533E-01 0.1526	9.24376E-02 0.3626	9.88685E-03 0.3047
csc003dn.out, 1" square shield of borated poly 210		
8.41078E+00 0.0525	2.82536E+00 0.0437	3.81597E-01 0.0644
csc003dp.out, 1" square shield of borated poly 210		
2.22954E-01 0.1508	9.62518E-02 0.3510	1.03783E-02 0.2939
csc003fn.out, 1" square shield of Lucite®		
1.05240E+01 0.0664	3.31358E+00 0.0492	4.14267E-01 0.0551
csc003fp.out, 1" square shield of Lucite®		
2.21675E-01 0.1508	9.51206E-02 0.3542	1.04571E-02 0.2917

6.0 REFERENCES

- Aftanas, B. L., April 30, 1996, *PFP Solution Stabilization*, WHC-SD-CP-FDC-003 Rev. 0, Westinghouse Hanford Company, Richland, Washington.
- ANSI/ANS-6.1.1-1977, 1977, *Neutron and Gamma-Ray Flux-to-Dose-Rate Factors*, American Nuclear Society, La Grange Park, Illinois
- ANSI/ANS-6.1.1-1991, 1992, *Neutron and Gamma-Ray Fluence-to-Dose Factors*, American Nuclear Society, La Grange Park, Illinois
- Briesmeister, J. F., Editor, November 1993, *MCNP - A General Monte Carlo N-Particle Transport Code, Version 4A*, LA-12625, Los Alamos National Laboratory, Los Alamos, New Mexico.
- Carter, L. L., June 10, 1996, *Certification of MCNP Version 4A for the WHC Computer Platforms*, ECN-630773, WHC-SD-MP-SWD-30001, Rev. 8, Westinghouse Hanford Company, Richland, Washington.
- Carter, R. D., G. R. Kiel and K. R. Ridgeway, 1968, *Criticality Handbook*, ARH-600, Atlantic Richfield Hanford Company, Richland, Washington.
- Compton, J. A., January 23, 1997, *Prototype Vertical Calciner Introductory Guide*, HNF-SD-CP-LB-037, Rev. 0, Babcock & Wilcox Hanford Company, Richland, Washington.
- Croff, A. G., July 1980, *A User's Manual for the ORIGEN2 Computer Code*, ORNL/TM-7175, Oak Ridge National Laboratory, Oak Ridge, Tennessee.
- Durnil, J. F. and S. B. Dutta, January 26, 1996, *Location Assessment of Vertical Calciner*, WHC-SD-CP-TI-200, Rev. 0, Westinghouse Hanford Company, Richland, Washington.
- Geiger, J. L., 1995a, *CSER 95-005: PFP Vertical Denitration Calciner*, WHC-SD-SQA-20392, Rev. 0, Westinghouse Hanford Company, Richland, Washington.
- Geiger, J. L., 1995b, *CSER 95-005 Addendum 1 Stainless Steel Insulation*, WHC-SD-SQA-CSA-20404, Rev. 0, Westinghouse Hanford Company, Richland, Washington.
- General Electric, February 10, 1993, *234-5Z Building Elevation of Concrete Walls Enclosing Process Area*, H-2-16174, General Electric Co. Hanford Works, Richland, Washington.
- Hillesland, K. E., May 1997, *CSER 97-004: PFP Production Denitration Calciner System*, HNF-SD-SQA-CSA-529, Rev. 0, Fluor Daniel Northwest, Richland, Washington.
- Jaeger, R. G., E. P. Blizard, A. B. Chilton, M. Grotenhuis, A. Honig, Th. A. Jaeger, H. H. Eisenlohr, Editors, 1975, *Engineering Compendium on Radiation Shielding, Volume II Shielding Materials*, Springer-Verlag, New York, New York.

- Merrick, S. B., and P. M. Rickords, January 29, 1996, *Technical Assessment of the PFP Vertical Direct Denitration Calciner*, WHC-SD-CP-TA-009, Rev. 0, Westinghouse Hanford Company, Richland, Washington.
- Schmittroth, F. A., September 1993, *Conversion of ORIGEN2 to Sun Workstations*, ECN-186709, WHC-SD-NR-SWD-006, Rev. 0-A, Westinghouse Hanford Company, Richland, Washington.
- Stubbs, A. M., 1997, Plutonium Finishing Plant Process Flow Document; *Calcination of Plutonium Nitrate Solution*, PFD-Z-300-0Q1, Rev. A-0, Babcock and Wilcox Hanford Company, Richland, Washington.
- U. S. DOE, July 7, 1994, *First Floor Plan Part 'C' 234-5Z Building*, H-2-16170, Rev. 17, U.S. Department of Energy, DOE Field Office, Richland, Westinghouse Hanford Company, Richland, Washington.
- U. S. DOE, Expected in 1997, *Calciner Assembly*, H-2-95609, Rev. 0, U.S. Department of Energy, Richland Operations Office, B & W Hanford Company, Richland, Washington.
- Wittekind, W. D., July 19, 1994, *Software Configuration Control Package for the ORIGEN2 Code*, WHC-SD-NR-SWD-006, Westinghouse Hanford Company, Richland, Washington.

APPENDIX A
INDEPENDENT REVIEW COMMENTS AND CHECKLIST

This page intentionally left blank

TECHNICAL PEER REVIEW

H.J. Goldberg of the Criticality and Shielding group in Specialty Engineering carried out an independent, technical peer review of this shielding calculation.

APPENDIX B
ORIGEN2 PLUTONIUM INPUT FILE AND OUTPUT RESULTS

This page intentionally left blank

ORIGEN2 PLUTONIUM INPUT FILE

```

-1
-1
-1
TIT      ORIGIN-II CALCULATIONS FOR CALCINER PuO2
LIP      0 0 0
LIB      0 1 2 3 201 202 203 9 3 0 1 0
PHO      101 102 103 10
RDA      1 gram
INP      -1 1 -1 -1 1 1
MOV      -1 1 0 0.008908685969 original vector low Pu-240 wt%
INP      -2 1 -1 -1 1 1
MOV      -2 5 0 0.008745080892 original vector mid Pu-240 wt%
INP      -3 1 -1 -1 1 1
MOV      -3 9 0 0.008663259118 original vector high Pu-240 wt%
BUP
DEC      1.0          1 2 4 1      DECAY 1.0 DAYS
DEC      5.0          2 3 4 0      DECAY 5.0 DAYS
DEC      10.0         3 4 4 0      DECAY 10.0 DAYS
DEC      1.0          5 6 4 1      DECAY 1.0 DAYS
DEC      5.0          6 7 4 0      DECAY 5.0 DAYS
DEC      10.0         7 8 4 0      DECAY 10.0 DAYS
DEC      1.0          9 10 4 1     DECAY 1.0 DAYS
DEC      5.0          10 11 4 0    DECAY 5.0 DAYS
DEC      10.0         11 12 4 0    DECAY 10.0 DAYS
BUP
CUT      5 1.E-05 7 1.E-05 9 1.E-05 10 1.E-05 27 1.0 -1
RDA      ACTIVATION PRODUCTS OUTPUT TABLE OPTIONS
OPTL     8 8 8 8 7 8 7 8 7 8 8 8 8 8 8 8 8 8 8 8 8
RDA      FISSION PRODUCTS OUTPUT TABLE OPTIONS
OPTF     8 8 8 8 7 8 7 8 7 8 8 8 8 8 8 8 8 8 8 8 8
RDA      ACTINIDE AND DAUGHTER PRODUCTS OUTPUT TABLE OPTIONS
OPTA     8 8 8 8 7 8 7 8 7 8 8 8 8 8 8 8 8 8 8 8 8
HED      1 lo 0 D
HED      2 lo 1 D
HED      3 lo 5 D
HED      4 lo 10 D
HED      5 md 0 D
HED      6 md 1 D
HED      7 md 5 D
HED      8 md 10 D
HED      9 hi 0 D
HED      10 hi 1 D
HED      11 hi 5 D
HED      12 hi 10 D
OUT      12 1 -1 0
STP 4
2 942380 0.01 942390 92.40 942400 6.12 942410 0.26
2 942420 0.04 952410 0.18 000000 0.00 000000 0.00
1 80160 13.25 000000 0.00 000000 0.00 000000 0.00
0
2 942380 0.15 942390 85.63 942400 12.45 942410 1.20
2 942420 0.37 952410 1.06 000000 0.00 000000 0.00
1 80160 13.49 000000 0.00 000000 0.00 000000 0.00
0

```

2	942380	0.18	942390	80.06	942400	17.84	942410	1.22
2	942420	0.73	952410	1.79	000000	0.00	000000	0.00
1	80160	13.61	000000	0.00	000000	0.00	000000	0.00
0								

END

ORIGEN2 PLUTONIUM OUTPUT RESULTS

5 SUMMARY TABLE: CONCENTRATIONS, GRAMS

0	Lo	0	1	D	Lo	5	10.0D	md	0	D	md	1	D	md	5	10	D	hi	0	D	hi	1	D	hi	5	D
Pu238	8.909E-05	8.908E-05	8.907E-05	1.312E-03	1.312E-03	1.312E-03	1.312E-03	1.312E-03	1.312E-03	1.312E-03	1.312E-03	1.312E-03	1.312E-03	1.312E-03	1.312E-03	1.312E-03	1.312E-03	1.550E-03	1.550E-03	1.550E-03	1.550E-03	1.550E-03	1.550E-03	1.550E-03	1.550E-03	1.550E-03
Pu239	8.232E-01	8.232E-01	8.232E-01	7.489E-01	7.489E-01	7.489E-01	7.489E-01	7.489E-01	7.489E-01	7.489E-01	7.489E-01	7.489E-01	7.489E-01	7.489E-01	7.489E-01	7.489E-01	7.489E-01	6.529E-01	6.529E-01	6.529E-01	6.529E-01	6.529E-01	6.529E-01	6.529E-01	6.529E-01	6.529E-01
Pu240	5.452E-02	5.452E-02	5.452E-02	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.547E-01	1.547E-01	1.547E-01	1.547E-01	1.547E-01	1.547E-01	1.547E-01	1.547E-01	1.547E-01
Pu241	2.316E-03	2.316E-03	2.315E-03	1.049E-02	1.049E-02	1.049E-02	1.049E-02	1.049E-02	1.049E-02	1.049E-02	1.049E-02	1.049E-02	1.049E-02	1.049E-02	1.049E-02	1.049E-02	1.049E-02	1.057E-02	1.057E-02	1.057E-02	1.057E-02	1.057E-02	1.057E-02	1.057E-02	1.057E-02	1.057E-02
Pu242	3.563E-04	3.563E-04	3.563E-04	3.236E-03	3.236E-03	3.236E-03	3.236E-03	3.236E-03	3.236E-03	3.236E-03	3.236E-03	3.236E-03	3.236E-03	3.236E-03	3.236E-03	3.236E-03	3.236E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03
Am241	1.604E-01	1.604E-01	1.605E-01	1.407E-03	1.407E-03	1.407E-03	9.270E-03	9.270E-03	9.270E-03	9.270E-03	9.270E-03	9.270E-03	9.270E-03	9.270E-03	9.270E-03	9.270E-03	9.270E-03	1.551E-02	1.551E-02	1.551E-02	1.551E-02	1.551E-02	1.551E-02	1.551E-02	1.551E-02	1.551E-02
SUMTOT	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.821E-01	8.821E-01	8.821E-01	8.821E-01	8.821E-01	8.821E-01	8.821E-01	8.821E-01	8.821E-01
OTOTAL	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.820E-01	8.821E-01	8.821E-01	8.821E-01	8.821E-01	8.821E-01	8.821E-01	8.821E-01	8.821E-01	8.821E-01

7 SUMMARY TABLE: RADIOACTIVITY, Curies

0	Lo	0	1	D	Lo	5	10.0D	md	0	D	md	1	D	md	5	10	D	hi	0	D	hi	1	D	hi	5	D
U237	0.000E+00	5.707E-07	2.348E-06	3.751E-06	0.000E+00	2.586E-06	1.064E-05	1.700E-05	0.000E+00	2.604E-06	1.071E-05	1.712E-05	1.726E-05	1.526E-03	1.526E-03	2.247E-02	2.246E-02	2.246E-02	2.246E-02	2.246E-02	2.246E-02	2.246E-02	2.246E-02	2.246E-02	2.246E-02	2.246E-02
Pu238	1.526E-03	1.526E-03	1.526E-03	1.519E-02	1.519E-02	1.519E-02	4.657E-02	4.657E-02	4.657E-02	4.657E-02	4.657E-02	4.657E-02	4.657E-02	4.657E-02	4.657E-02	4.657E-02	4.657E-02	5.313E-02	5.313E-02	5.313E-02	5.313E-02	5.313E-02	5.313E-02	5.313E-02	5.313E-02	5.313E-02
Pu239	3.119E-02	3.119E-02	3.119E-02	5.119E-02	5.119E-02	5.119E-02	2.482E-02	2.482E-02	2.482E-02	2.482E-02	2.482E-02	2.482E-02	2.482E-02	2.482E-02	2.482E-02	2.482E-02	2.482E-02	3.523E-02	3.523E-02	3.523E-02	3.523E-02	3.523E-02	3.523E-02	3.523E-02	3.523E-02	3.523E-02
Pu240	2.246E-02	2.246E-02	2.246E-02	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.089E-01	1.547E-01	1.547E-01	1.547E-01	1.547E-01	1.547E-01	1.547E-01	1.547E-01	1.547E-01	1.547E-01
Pu241	1.361E-06	1.361E-06	1.361E-06	1.361E-06	1.361E-06	1.361E-06	1.236E-05	1.236E-05	1.236E-05	1.236E-05	1.236E-05	1.236E-05	1.236E-05	1.236E-05	1.236E-05	1.236E-05	1.236E-05	1.057E-02	1.057E-02	1.057E-02	1.057E-02	1.057E-02	1.057E-02	1.057E-02	1.057E-02	1.057E-02
Pu242	5.504E-03	5.507E-03	5.511E-03	5.514E-03	5.514E-03	5.514E-03	3.183E-02	3.183E-02	3.183E-02	3.183E-02	3.183E-02	3.183E-02	3.183E-02	3.183E-02	3.183E-02	3.183E-02	3.183E-02	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03
Am241	5.504E-03	5.507E-03	5.511E-03	5.514E-03	5.514E-03	5.514E-03	3.183E-02	3.183E-02	3.183E-02	3.183E-02	3.183E-02	3.183E-02	3.183E-02	3.183E-02	3.183E-02	3.183E-02	3.183E-02	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03	6.324E-03
SUMTOT	3.094E-01	3.093E-01	3.093E-01	3.091E-01	3.091E-01	3.091E-01	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.247E+00	1.247E+00	1.247E+00	1.247E+00	1.247E+00	1.247E+00	1.247E+00	1.247E+00	1.247E+00
OTOTAL	3.094E-01	3.093E-01	3.093E-01	3.091E-01	3.091E-01	3.091E-01	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.207E+00	1.247E+00	1.247E+00	1.247E+00	1.247E+00	1.247E+00	1.247E+00	1.247E+00	1.247E+00	1.247E+00

ORIGEN-II CALCULATIONS FOR CALCINER PLO2																	OUTPUT UNIT = 6				PAGE 27	
(ALPHA, N) NEUTRON SOURCE, NEUTRONS/SEC																						
BASIS=																						
Lo 0 0 Lo 1 0 Lo 5 0 10.00 md 10 0 md 1 0 md 5 0 hi 10 0 hi 1 0 d hi 5 0																						
P2U238																						
1.452E+01 1.452E+00 1.451E+00 1.451E+00 2.137E+01 2.137E+01 2.137E+01 2.541E+01 2.541E+01 2.541E+01 2.541E+01 3.142E+01 3.142E+01 3.142E+01 3.142E+01 3.142E+01 3.142E+01																						
P2U239																						
3.729E+01 3.729E+01 3.729E+01 3.729E+01 3.392E+01 3.392E+01 3.392E+01 3.932E+01 3.932E+01 3.932E+01 3.932E+01 4.581E+01 4.581E+01 4.581E+01 4.581E+01 4.581E+01 4.581E+01																						
P2U240																						
9.417E+00 9.417E+00 9.417E+00 9.417E+00 1.881E+01 1.881E+01 1.881E+01 1.881E+01 2.670E+01 2.670E+01 2.670E+01 2.670E+01 2.670E+01 2.670E+01 2.670E+01 2.670E+01																						
AM241																						
5.281E+00 5.282E+00 5.282E+00 5.282E+00 3.053E+01 3.053E+01 3.053E+01 3.053E+01 3.053E+01 3.053E+01 3.053E+01 3.053E+01 3.053E+01 3.053E+01 3.053E+01 3.053E+01																						
TOTALS																						
5.344E+01 5.344E+01 5.344E+01 5.344E+01 1.046E+02 1.046E+02 1.046E+02 1.047E+02 1.047E+02 1.047E+02 1.047E+02 1.346E+02 1.346E+02 1.346E+02 1.346E+02 1.346E+02																						
TABLE																						
5.344E+01 5.344E+01 5.344E+01 5.344E+01 1.046E+02 1.046E+02 1.046E+02 1.047E+02 1.047E+02 1.047E+02 1.047E+02 1.346E+02 1.346E+02 1.346E+02 1.346E+02 1.346E+02																						
ACTUAL																						
1																						
ORIGEN-II CALCULATIONS FOR CALCINER PLO2																	OUTPUT UNIT = 6				PAGE 28	
SPONTANEOUS FISSION NEUTRON SOURCE, NEUTRONS/SEC																						
BASIS=																						
Lo 0 0 Lo 1 0 Lo 5 0 10.00 md 10 0 md 1 0 md 5 0 hi 10 0 hi 1 0 d hi 5 0																						
P2U238																						
2.367E-01 2.367E-01 2.367E-01 2.367E-01 3.486E+00 3.486E+00 3.486E+00 3.486E+00 3.486E+00 3.486E+00 3.486E+00 4.144E+00 4.144E+00 4.144E+00 4.144E+00 4.144E+00																						
P2U240																						
4.964E+01 4.964E+01 4.964E+01 4.964E+01 9.913E+01 9.913E+01 9.913E+01 9.913E+01 9.913E+01 9.913E+01 9.913E+01 1.407E+02 1.407E+02 1.407E+02 1.407E+02 1.407E+02																						
P2U242																						
6.007E-01 6.007E-01 6.007E-01 6.007E-01 5.454E+00 5.454E+00 5.454E+00 5.454E+00 5.454E+00 5.454E+00 5.454E+00 1.066E+01 1.066E+01 1.066E+01 1.066E+01 1.066E+01																						
TOTALS																						
5.050E-01 5.050E-01 5.050E-01 5.050E-01 1.081E+02 1.081E+02 1.081E+02 1.081E+02 1.081E+02 1.081E+02 1.081E+02 1.556E+02 1.556E+02 1.556E+02 1.556E+02 1.556E+02																						
TABLE																						
5.050E-01 5.050E-01 5.050E-01 5.050E-01 1.081E+02 1.081E+02 1.081E+02 1.081E+02 1.081E+02 1.081E+02 1.081E+02 1.556E+02 1.556E+02 1.556E+02 1.556E+02 1.556E+02																						
ACTUAL																						
1																						
ORIGEN-II CALCULATIONS FOR CALCINER PLO2																	OUTPUT UNIT = 6				PAGE 30	
SPONTANEOUS FISSION NEUTRON SOURCE, NEUTRONS/SEC																						
BASIS=																						
Lo 0 0 Lo 1 0 Lo 5 0 10.00 md 10 0 md 1 0 md 5 0 hi 10 0 hi 1 0 d hi 5 0																						
1.039E+02 1.039E+02 1.039E+02 1.039E+02 2.127E+02 2.127E+02 2.127E+02 2.127E+02 2.127E+02 2.127E+02 2.127E+02 2.902E+02 2.902E+02 2.902E+02 2.902E+02 2.902E+02																						
TOTALS																						
1.039E+02 1.039E+02 1.039E+02 1.039E+02 2.127E+02 2.127E+02 2.127E+02 2.127E+02 2.127E+02 2.127E+02 2.127E+02 2.902E+02 2.902E+02 2.902E+02 2.902E+02 2.902E+02																						
TABLE																						
1.039E+02 1.039E+02 1.039E+02 1.039E+02 2.127E+02 2.127E+02 2.127E+02 2.127E+02 2.127E+02 2.127E+02 2.127E+02 2.902E+02 2.902E+02 2.902E+02 2.902E+02 2.902E+02																						
ACTUAL																						
1																					</	

This page intentionally left blank

APPENDIX C

NEUTRON SHIELDED OPERATOR DOSE RATE MCNP INPUT FILES

CCA08ANP.INP Vertical Calciner, 3.5 kg Pu, neutron and capture gammas
CCA08AP.INP Vertical Calciner, 3.5 kg Pu, gamma ray calculation
CFT08ANP.INP Feed Tank, 3.5 kg Pu, neutron and capture gammas
CFT08AP.INP Feed Tank, 3.5 kg Pu, gamma ray calculation
CSC08ANP.INP Storage Can, 3.6 kg Pu, neutron and capture gammas
CSC08AP.INP Storage Can, 3.6 kg Pu, gamma ray calculation

This page intentionally left blank

NEUTRON SHIELDED OPERATOR DOSE RATE MCNP INPUT FILES

CCOABAMP.INP Vertical Calclner, 3.5 kg Pu, neutron & capture gammas

NEUTRON Dose Rate Data for calclner CCOABAMP		Vertical Calclner, 3.5 kg Pu, neutron & capture gammas	
c	CALCLNER PuO2 Neutron Source is in Cell 3	44	10 -1.29e-3 42 -54 47 -39 41 -19
c	N Shield Lucite - 1.185 g/cm ³ - 4 inches top, 5 inches bottom	45	10 -1.29e-3 54 -43 47 -39 5 -41
c	Lower Shields are 1/8" inch of Stainless Steel (both sides)	46	10 -1.29e-3 54 -43 47 -39 41 -19
c	Upper Shields are 3/4" inch of glass (no boron)(both sides)	47	10 -1.29e-3 60 -20 30 -39 5 -19
c	Full Room Model with concrete walls, roof and Metal Partitions	48	10 -1.29e-3 60 -20 63 -30 3 -19
c		49	10 -1.29e-3 20 -52 63 -30 15 -57
c		50	7 -7.84 60 -20 63 -30 15 -57
c		51	7 -7.84 60 -20 63 -30 15 -57
c		52	7 -7.84 60 -20 63 -30 15 -57
c		53	11 -2.30 59 -61 62 -64 5 -57
c		54	11 -2.30 59 -61 62 -64 5 -57
c		55	11 -2.30 59 -61 62 -64 5 -57
c		56	11 -2.30 59 -61 62 -64 4 -5
c		57	0 61 -59 64 -62 -4: 58
c		1	cz 7.7610 \$ FEED TANK O.R. - (5/16" x 0.040")
c		2	cz 8.4534 \$ FEED TANK O.R.
c		3	cz 14.2875 \$ FEED TANK FLANGE bottom (24" thick)
c		4	pz -60.9600 \$ CONCRETE FLOOR surface
c		5	pz 0.0000 \$ GLOVEBOX bottom surface
c		6	pz 86.3600 \$ GLOVEBOX bottom surface
c		7	pz 86.3961 \$ GLOVEBOX Lead Shield (3/32")
c		8	pz 87.3125 \$ GLOVEBOX Stainless Steel (3/32")
c		9	pz 87.3125 \$ GLOVEBOX Stainless Steel (3/32")
c		10	pz 171.4500 \$ FEED TANK Bottom Flange top
c		11	pz 171.7200 \$ FEED TANK Bottom Flange top
c		12	pz 224.5663 \$ FEED TANK Solution level (10 L)
c		13	pz 233.6800 \$ FEED TANK Top Flange bottom
c		14	pz 234.9500 \$ FEED TANK Top Flange top
c		15	pz 265.7475 \$ GLOVEBOX top inside surface
c		16	pz 265.9856 \$ GLOVEBOX Stainless Steel (3/32")
c		17	pz 266.4619 \$ GLOVEBOX Lead Shield (3/16")
c		18	pz 266.7000 \$ GLOVEBOX Stainless Steel (3/32")
c		19	pz 366.7000 \$ MODEL TOP (GB roof +100 cm)
c		20	px -321.6150 \$ MODEL LEFT SIDE (GB side +100 cm)
c		21	px -321.6150 \$ GLOVEBOX left surface
c		22	px -521.3769 \$ GLOVEBOX Stainless Steel (3/32")
c		23	px -521.3769 \$ GLOVEBOX Lead Shield (3/16")
c		24	px -520.4626 \$ GLOVEBOX Stainless Steel (3/32")
c		25	px 39.6875 \$ GLOVEBOX right inside surface
c		26	px 39.9256 \$ GLOVEBOX Stainless Steel (3/32")
c		27	px 40.4019 \$ GLOVEBOX Lead Shield (3/16")
c		28	px 40.6400 \$ GLOVEBOX Stainless Steel (3/32")
c		29	px 121.1400 \$ MODEL RIGHT SIDE (GB back +75 cm)
c		30	py -232.2250 \$ GLOVEBOX back surface
c		31	py -22.2250 \$ GLOVEBOX back surface
c		32	py -21.9869 \$ GLOVEBOX Stainless Steel (3/32")
c		33	py -21.5106 \$ GLOVEBOX Lead Shield (3/16")
c		34	py -21.2725 \$ GLOVEBOX Stainless Steel (3/32")
c		35	py 82.5500 \$ GLOVEBOX front inside surface
c		36	py 82.7881 \$ GLOVEBOX Stainless Steel (3/32")
c		37	py 83.2644 \$ GLOVEBOX Lead Shield (3/16")

[illegible]

[illegible]

skyshine	7.416e-4	9.144e-4	1.076e-3	1.379e-3	1.656e-3	2.246e-3
c	log	-01	-015	-02	-03	-04
d644	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44-p	Photon dose behind Neutron Shield, Concrete Floor Effect					
ff44-p	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44	Photon dose behind Neutron Shield, Left Upper n Shield Leak Through					
ff44	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44	Photon dose behind Neutron Shield, Left Lower n Shield Leak Through					
ff44	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44	Photon dose behind Neutron Shield, Right Side Leak Around					
ff44	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44	Photon dose behind Neutron Shield, Front Lower n Shield Leak Through					
ff44	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44	Photon dose behind Neutron Shield, Front Upper n Shield Leak Through					
ff44	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44	Photon dose behind Neutron Shield, Left Upper n Shield Leak Through					
ff44	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44	Photon dose behind Neutron Shield, Left Upper n Shield Leak Through					
ff44	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44	Photon dose behind Neutron Shield, Left Upper n Shield Leak Through					
ff44	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44	Photon dose behind Neutron Shield, Left Upper n Shield Leak Through					
ff44	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44	Photon dose behind Neutron Shield, Left Upper n Shield Leak Through					
ff44	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44	Photon dose behind Neutron Shield, Left Upper n Shield Leak Through					
ff44	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44	Photon dose behind Neutron Shield, Left Upper n Shield Leak Through					
ff44	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44	Photon dose behind Neutron Shield, Left Upper n Shield Leak Through					
ff44	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
		2.0	3.0	4.0	5.0	6.0
ff44	Photon dose behind Neutron Shield, Left Upper n Shield Leak Through					
ff44	56 \$ Flagg Cells					
c	log	-01	-015	-02	-03	-04
ff44	log	-06	-08	-10	-15	-20
	</					

[illegible]

CCA08AP.INP Vertical Calciner, 3.5 kg Pu, gamma ray calculation

PHOTON	Dose Rate Calcs for calcitrn	CCAU5AP
c	CALCINR Lucite - 1.185 g/cm ³ - 4	Cells
c	N Shield Lucite - 1.185 g/cm ³ - 4	3
c	Upper Shields are 3/8 inch of Stainless Steel (both sides)	
c	Lower Shields are 3/4 inch of Stainless Steel (both sides)	
c	Full Room Shield with Concrete Walls, Roof, and Metal Partition	
c	xx - xx yy zz zz rr rr	
1	10 - 1.29e-3	65 -66
2	7 - 7.84	65 -66
3	4 - 5.00	65 -66
4	10 - 1.29e-3	66 -67
5	7 - 7.84	66 -67
6	10 - 1.29e-3	65 -67
7	7 - 7.84	65 -67
8	15 - 1.87	67 -71
9	10 - 1.29e-3	67 -71
10	7 - 7.84	67 -68
11	6 - 0.793	67 -68
12	10 - 1.29e-3	67 -68
13	10 - 1.29e-3	67 -68
14	7 - 7.84	67 -68
15	8 - 11.34	67 -68
16	7 - 7.84	67 -68
17	7 - 7.84	67 -68
18	7 - 7.84	67 -68
19	7 - 7.84	67 -68
20	7 - 7.84	67 -68
21	7 - 7.84	67 -68
22	7 - 7.84	67 -68
23	7 - 7.84	67 -68
24	7 - 7.84	67 -68
25	7 - 7.84	67 -68
26	7 - 7.84	67 -68
27	7 - 7.84	67 -68
28	7 - 7.84	67 -68
29	7 - 7.84	67 -68
30	7 - 7.84	67 -68
31	7 - 7.84	67 -68
32	7 - 7.84	67 -68
33	7 - 7.84	67 -68
34	7 - 7.84	67 -68
35	7 - 7.84	67 -68
36	7 - 7.84	67 -68
37	7 - 7.84	67 -68
38	7 - 7.84	67 -68
39	7 - 7.84	67 -68
40	7 - 7.84	67 -68
41	7 - 7.84	67 -68
42	7 - 7.84	67 -68
43	7 - 7.84	67 -68
44	7 - 7.84	67 -68
45	7 - 7.84	67 -68
46	7 - 7.84	67 -68
47	7 - 7.84	67 -68
48	7 - 7.84	67 -68
49	7 - 7.84	67 -68
50	7 - 7.84	67 -68
51	7 - 7.84	67 -68
52	7 - 7.84	67 -68
53	7 - 7.84	67 -68
54	7 - 7.84	67 -68
55	7 - 7.84	67 -68
56	7 - 7.84	67 -68
57	7 - 7.84	67 -68
58	7 - 7.84	67 -68
59	7 - 7.84	67 -68
60	7 - 7.84	67 -68
61	7 - 7.84	67 -68
62	7 - 7.84	67 -68
63	7 - 7.84	67 -68
64	7 - 7.84	67 -68
65	7 - 7.84	67 -68
66	7 - 7.84	67 -68
67	7 - 7.84	67 -68
68	7 - 7.84	67 -68
69	7 - 7.84	67 -68
70	7 - 7.84	67 -68
71	7 - 7.84	67 -68
72	7 - 7.84	67 -68
73	7 - 7.84	67 -68
74	7 - 7.84	67 -68
75	7 - 7.84	67 -68
76	7 - 7.84	67 -68
77	7 - 7.84	67 -68
78	7 - 7.84	67 -68
79	7 - 7.84	67 -68
80	7 - 7.84	67 -68
81	7 - 7.84	67 -68
82	7 - 7.84	67 -68
83	7 - 7.84	67 -68
84	7 - 7.84	67 -68
85	7 - 7.84	67 -68
86	7 - 7.84	67 -68
87	7 - 7.84	67 -68
88	7 - 7.84	67 -68
89	7 - 7.84	67 -68
90	7 - 7.84	67 -68
91	7 - 7.84	67 -68
92	7 - 7.84	67 -68
93	7 - 7.84	67 -68
94	7 - 7.84	67 -68
95	7 - 7.84	67 -68
96	7 - 7.84	67 -68
97	7 - 7.84	67 -68
98	7 - 7.84	67 -68
99	7 - 7.84	67 -68
100	7 - 7.84	67 -68

C-7

13	\$	Under	Glovebox	\$	233.6800	PZ	233.6800	\$	FEED TANK Top	Flange bottom
14	\$	Over	Glovebox	\$	234.9500	PZ	234.9500	\$	FEED TANK Top	Flange top
15	\$	Under	Glovebox	\$	265.7475	\$	GLOVEBOX top inside surface	\$	GLOVEBOX top inside surface	
16	\$	Left	Glovebox	\$	265.7475	\$	GLOVEBOX top inside surface	\$	GLOVEBOX top inside surface	
17	\$	L-B	Glovebox	\$	265.9856	PZ	265.9856	\$	GLOVEBOX Lead Shield (3/32")	
18	\$	Behind	Glovebox	\$	266.4619	PZ	266.4619	\$	GLOVEBOX Lead Shield (3/16")	
19	\$	R-B	Glovebox	\$	266.7000	PZ	266.7000	\$	GLOVEBOX Stainless Steel (3/32")	
20	\$	Right	Glovebox	\$	366.7000	PZ	366.7000	\$	MODEL TOP (GB roof +100 cm)	
21	\$	Front	Glovebox	\$	321.6150	PZ	321.6150	\$	MODEL LEFT SIDE (GB side +100 cm)	
22	\$	Front	Glovebox	\$	-221.6150	\$	GLOVEBOX left surface	\$	GLOVEBOX left surface	
23	\$	Bot Fr Outside	air	\$	-221.3769	PZ	-221.3769	\$	GLOVEBOX Stainless Steel (3/32")	
24	\$	Bot Fr Outside	air	\$	-220.6026	PZ	-220.6026	\$	GLOVEBOX Lead Shield (3/16")	
25	\$	Bot Fr Middle 5.0"	air	\$	-220.6625	\$	GLOVEBOX Stainless Steel (3/32")	\$	GLOVEBOX right inside surface	
26	\$	Bot Fr Middle 5.0"	air	\$	39.9256	PZ	39.9256	\$	GLOVEBOX Stainless Steel (3/32")	
27	\$	Bot Fr Inside air	\$	40.4019	PZ	40.4019	\$	GLOVEBOX Lead Shield (3/16")		
28	\$	Top Fr Outside air	\$	40.6400	PZ	40.6400	\$	GLOVEBOX Stainless Steel (3/32")		
29	\$	Top Fr Middle 4.0"	air	\$	231.4000	PZ	231.4000	\$	MODEL RIGHT SIDE (GB side +75")	
30	\$	Top Fr Middle 3/4"	air	\$	123.2250	PZ	123.2250	\$	GLOVEBOX SHIELD (GB back +100 cm)	
31	\$	Above Shield	air	\$	-21.9669	PZ	-21.9669	\$	GLOVEBOX Stainless Steel (3/32")	
32	\$	Bot L Outside air	\$	-21.5106	PZ	-21.5106	\$	GLOVEBOX Stainless Steel (3/32")		
33	\$	Bot L Middle 1.0"	air	\$	-21.2725	PZ	-21.2725	\$	GLOVEBOX Lead Shield (3/16")	
34	\$	Bot L Middle 1.0"	air	\$	82.5500	PZ	82.5500	\$	GLOVEBOX front inside surface	
35	\$	Bot L Inside air	\$	82.7881	PZ	82.7881	\$	GLOVEBOX Stainless Steel (3/32")		
36	\$	Top L Outside air	\$	83.2644	PZ	83.2644	\$	GLOVEBOX Lead Shield (3/16")		
37	\$	Top L Inside 1/8"	\$	83.5025	PZ	83.5025	\$	GLOVEBOX Stainless Steel (3/32")		
38	\$	Top L Middle 3/4"	\$	327.3425	PZ	327.3425	\$	MODEL FRONT SIDE (GB front +95")		
39	\$	Above Shield	air	\$	137.16	PZ	137.16	\$	4.5" High n Shield	
40	\$	Behind n Shield	\$	213.36	PZ	213.36	\$	*2.5" Top n Shield		
41	\$	Behind n Shield	\$	175.00	\$	Left End n Shield	\$	Right End n Shield		
42	\$	Room, Left Side	\$	191.4525	PZ	191.4525	\$	3/4" n Shield Material outside		
43	\$	Room, Left Side	\$	193.3575	PZ	193.3575	\$	4.0" n Shield Material outside		
44	\$	Room, Left Back	\$	203.5175	PZ	203.5175	\$	3/4" n Shield Material outside		
45	\$	Room, Left Back	\$	205.4225	PZ	205.4225	\$	Operator Side n Shield		
46	\$	Room to Ceiling	\$	191.4525	PZ	191.4525	\$	3/4" n Shield Material outside		
47	\$	SS Wall Back	\$	192.0375	PZ	192.0375	\$	5.0" n Shield Material outside		
48	\$	SS Wall Front	\$	205.1050	PZ	205.1050	\$	1/8" n Shield Material outside		
49	\$	Concrete Wall Left	\$	205.4225	PZ	205.4225	\$	Operator Side n Shield		
50	\$	Concrete Wall Right	\$	123.0950	PZ	123.0950	\$	3/4" n Shield Material outside		
51	\$	Concrete Floor	\$	-118.6500	PZ	-118.6500	\$	Operator Side n Shield		
52	\$	OUTSIDE WORLD	\$	-125.00	PZ	-125.00	\$	1.0" n Shield Material outside		
53	\$	FEED TANK O.R. - (5/16" n 0.040")	\$	-120.5550	PZ	-120.5550	\$	3/4" n Shield Material outside		
54	\$	FEED TANK O.R.	\$	-118.6500	PZ	-118.6500	\$	Operator Side n Shield		
55	\$	CONCRETE FLOOR bottom (24" n thick)	\$	-123.4125	PZ	-123.4125	\$	3/4" n Shield Material outside		
56	\$	CONCRETE FLOOR surface	\$	-123.0950	PZ	-123.0950	\$	1/8" n Shield Material outside		
57	\$	GLOVEBOX bottom surface	\$	-120.5550	PZ	-120.5550	\$	3/4" n Shield Material outside		
58	\$	GLOVEBOX Lead Shield (3/32")	\$	-120.2375	PZ	-120.2375	\$	1/8" n Shield Material inside		
59	\$	GLOVEBOX Stainless Steel (3/32")	\$	-118.6500	PZ	-118.6500	\$	Operator Side n Shield		
60	\$	FEED TANK Bottom Flange bottom	\$	949.96	PZ	949.96	\$	Ceiling surface (H-2-16174)		
61	\$	FEED TANK Bottom Flange top	\$	960.12	PZ	960.12	\$	4 inch concrete roof (H-2-16174)		
62	\$	FEED TANK Slope level (10 L)	\$	581.34	PZ	581.34	\$	8 inch concrete wall left side		

60	px -541.02	\$ Left Wall Surface [H-2-16140]	7.000e+00	1.0250e+00	50
61	px -251.46	\$ 8 inch concrete wall right side	1.1000e+01	1.6920e-01	14
62	py -735.3078	\$ 18 Gauge Metal (.0516in*(4.0/1.8))=> 2913 cm/c	TOTAL	1.6820e+09	
63	py -735.0125	\$ Back Wall Surface [H-2-16140]	(alpha,n) neutron source on OXYGEN from Jacom and Liskien		
64	py -327.6338	\$ 18 Gauge Metal (.0516in*(4.0/1.8))=> 2913 cm/c	Energy of the alpha particles = 5.5 MeV		
65	pz 118.11	\$ CALCINER Bottom	sp35		
66	pz 133.8326	\$ CALCINER Middle line	si35		
67	pz 142.24	\$ CALCINER Midline	0.0	0.00	
68	pz 156.24	\$ CALCINER Top	0.1	0.68	
69	c/z -168.5925	29.8450 5.4102 \$ S.STEEL Inside	0.2	0.76	
70	c/z -168.5925	29.8450 5.7150 \$ S.STEEL Outside	0.3	0.74	
71	c/z -168.5925	29.8450 8.0734 \$ S.STEEL Inside	0.4	0.88	
72	c/z -168.5925	29.8450 8.4138 \$ S.STEEL Outside	0.5	1.20	
73	c/z -168.5925	29.8450 16.0358 \$ Upper Insulation Outside	0.6	1.35	
74	c/z -168.5925	29.8450 16.4358 \$ Upper Insulation Inside	0.7	1.45	
75	c/z -168.5925	29.8450 17.1676 8.0734 \$ S.STEEL Inside	0.8	1.45	
76	s -168.5925	29.8450 127.1676 8.7851 \$ S.STEEL Outside	0.9	1.55	
			1.0	1.28	
			1.1	1.34	
			1.2	1.45	
			1.3	1.63	
			1.4	1.76	
			1.5	1.80	
			1.6	1.89	
			1.7	2.05	
			1.8	2.28	
			1.9	2.37	
			2.0	2.49	
			2.1	2.50	
			2.2	2.61	
			2.3	2.62	
			2.4	2.52	
			2.5	2.43	
			2.6	2.34	
			2.7	2.73	
			2.8	2.06	
			2.9	2.00	
			3.0	1.88	
			3.1	1.66	
			3.2	1.56	
			3.3	1.34	
			3.4	1.09	
			3.5	0.92	
			3.6	0.79	
			3.7	0.64	
			3.8	0.54	
			3.9	0.28	
			4.0	0.39	
			4.1	0.35	
			4.2	0.23	
			4.3	0.18	
			4.4	0.11	
			4.5	0.07	
			sp36	spontaneous fission source spectrum (Pu240)	
			-3	0.799 4.903 \$ Watt Fission Spectrum	

mode P 1 55r 0

c hgt = 3500*3.169E+8 = 1.109E+12 Low 240 PU Gamma

c hgt = 3500*1.115E+9 = 3.903E+12 Mid 240 PU Gamma

c hgt = 3500*1.682E+9 = 5.887E+12 High 240 PU Gamma

sdef cel= 3 erg= d5 pos = -168.5925 29.8450 0

rad= d5 ext= d4 axs = 0 0 1 hgt=5.887E+12

(alpha,n) and fission spectrum

s12 s 35 36

s12 s 0.504 0.496

s13 radius

s13 8.0734

s14 z111

s14 118.1100

s14 133.8326

s14 -21.0

s14 photon source from ORIGEN2

s14 TOTAL PHOTON SPECTRUM

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

s14 sb5

m1	94238	-0.000279	94239	-0.0124257	94240	-0.027669	7.416e-4	9.144e-4	1.076e-3	1.379e-3	1.656e-3	2.246e-3
	94241	-0.001894	94242	-0.001133	95241	-0.027778	7.528e-3	3.672e-3	5.050e-3	5.292e-3	5.126e-3	7.488e-3
	7014	-0.999011	8016	-0.693530	1001	-0.049129	8.892e-3	1.940e-2				
c	mt1	lwrrt.01t	94239	-0.823590	94240	-0.054517	fc4	Photon Dose behind Neutron Shield, Right Side Leak Around				
m2	94238	-0.000089	94242	-0.000356	95241	-0.001603	f4-p	45	\$ Operator behind Neutron Shield			
	94241	-0.002316	94239	-0.001312	94239	-0.001312	f4-p	45	\$ Flagging Cells for Leak-through,			
	8016	-0.010494	94242	-0.003236	95241	-0.009270	skyskine	fc4	Photon Dose behind Neutron Shield, Front Lower n Shield Leak Through,			
m3	94238	-0.011791	94242	-0.002346	95241	-0.009270	skyskine	fc4	Photon Dose behind Neutron Shield, Front Lower n Shield Leak Through,			
	8016	-0.011791	94242	-0.002346	95241	-0.009270	skyskine	fc4	Photon Dose behind Neutron Shield, Front Lower n Shield Leak Through,			
m4	94238	-0.000569	94242	-0.000324	95241	-0.015507	skyskine	fc4	Photon Dose behind Neutron Shield, Front Upper n Shield Leak Through,			
	8016	-0.011790	94242	-0.003236	95241	-0.015507	skyskine	fc4	Photon Dose behind Neutron Shield, Front Upper n Shield Leak Through,			
m5	14000	-0.376573	5010	-0.001796	5011	-0.032386	skyskine	fc34	Photon Dose behind Neutron Shield, Left Lower n Shield Leak Through,			
	11023	-0.039674	13027	-0.012173	19000	-0.000830	skyskine	fc34	Photon Dose behind Neutron Shield, Left Lower n Shield Leak Through,			
m6	8016	-0.540198	7740	PYREX Type I Glass [CALCINE1.WQ1]			f34-p	45	\$ Operator behind Neutron Shield			
	26000	-0.174	24000	-0.18	28000	-0.08	ss 304L	Flanges	fc34	Photon Dose behind Neutron Shield, Left Lower n Shield Leak Through,		
m7	26000	-0.98	28000	-0.02	\$ Stainless Steel Glovebox		skyskine	fc4	Photon Dose behind Neutron Shield, Left Upper n Shield Leak Through,			
m8	82000	-1.00			\$ Lead Steel Glovebox		1442-p	45	\$ Operator behind Neutron Shield			
m9	7014	-0.76884	8016	-0.20946	18000	-0.00934	1442-p	45	\$ Operator behind Neutron Shield			
m10	7014	-0.00036	\$ Air				skyskine	fc4	Photon Dose behind Neutron Shield, Roof Reflection			
c	mt2	lwrrt.01t	94239	-0.00036	94240	-0.01	skyskine	fc54	Photon Dose behind Neutron Shield, Roof Reflection			
m11	1001	-0.8016	-0.532	14000	-0.337		fc54	Photon Dose behind Neutron Shield, Roof Reflection				
	11023	-0.029	\$ Concrete (common Portland)	ARH-600	i.i.f. 1-3		fc54	Photon Dose behind Neutron Shield, Roof Reflection				
c	mt11	poly.01t	94239	-0.005925	5010	-0.02410	skyskine	fc64	Photon Dose behind Neutron Shield, Steel Wall Back Reflection			
m12	6000	-0.0854	14000	-0.0101	8016	-0.0076	fc64	Photon Dose behind Neutron Shield, Steel Wall Back Reflection				
	10001	-0.0038	13027	-0.0004	25955	-0.0002	fc64	Photon Dose behind Neutron Shield, Steel Wall Back Reflection				
c	mt12	poly.01t	grph.01t	\$ hydrogen, carbon in solid	(1.19		skyskine	fc74	Photon Dose behind Neutron Shield, Concrete Floor Effect			
m13	6000	-0.3649	6000	-0.3439	13027	-0.1906	fc74	Photon Dose behind Neutron Shield, Concrete Floor Effect				
	5010	-0.07628	2000	-0.00562	12000	-0.0006	fc84	Photon Dose behind Neutron Shield, Flagging Cells for Leak-through,				
	5010	-0.07628	2000	-0.00562	12000	-0.0006	fc84	Photon Dose behind Neutron Shield, Flagging Cells for Leak-through,				
	11023	-0.0035	39089	-0.0005	26000	-0.0001	fc84	Photon Dose behind Neutron Shield, Flagging Cells for Leak-through,				
c	mt13	poly.01t	grph.01t	\$ hydrogen, carbon in solid	(1.4		fc84	Photon Dose behind Neutron Shield, Flagging Cells for Leak-through,				
	19000	-0.0001	16032	-0.0001	\$ 189 substituted for Sr-		fc84	Photon Dose behind Neutron Shield, Flagging Cells for Leak-through,				
c	mt13	poly.01t	grph.01t	\$ hydrogen, carbon in solid	(1.4		skyskine	fc4	Photon Dose behind Neutron Shield, Concrete Floor Effect			
m14	6000	-0.599848	1001	-0.080538	8016	-0.319614	fc5	Photon Dose behind Neutron Shield, Concrete Floor Effect				
m14	6000	-0.599848	1001	-0.080538	8016	-0.319614	fc5	Photon Dose behind Neutron Shield, Concrete Floor Effect				
c	mt14	poly.01t	grph.01t	\$ hydrogen in solid	(1.185	g/cm3)	fc15	Photon Dose at 30 cm from outside surface of Glovebox				
Lucite	8016	-0.3649	13027	-0.1906	14000	-0.0009	f15-p	Total Dist from outside = 30.0 + 83.5025 = 113.5025 cm				
m15	6000	-0.757571	1001	-0.055491	8016	-0.188758	fc25	Photon Dose at 5 feet from outside surface of Glovebox				
m16	6000	-0.757571	1001	-0.055491	8016	-0.188758	fc25	Photon Dose at 5 feet from outside surface of Glovebox				
c	mt16	poly.01t	grph.01t	\$ hydrogen in solid	(1.2	g/cm3)	fc25	Total Dist from outside = 30.0 + 83.5025 = 113.5025 cm				
Lexan	8016	-0.3649	13027	-0.1906	14000	-0.0009	fc35	Photon Dose at 5 feet from outside surface of Glovebox				
de0	log	-0.1	0.05	0.2	0.3	0.4	fc35	Total Dist from outside = 30.0 + 83.5025 = 113.5025 cm				
	-0.4	0.5	0.6	0.7	0.8	0.9	fc35	Photon Dose at 5 feet from outside surface of Glovebox				
	-0.40	-0.50	-0.60	-0.70	-0.80	-0.90	fc45	Total Dist from outside = 191.4325 + 642.34 = 176.2125 cm				
	-0.40	-0.50	-0.60	-0.70	-0.80	-0.90	fc45	Photon Dose in middle of outer 1/4" SST in Shield				
	2.0	3.0	4.0	5.0	6.0	8.0	f42-p	0 191.9288 91.44				
	10.0	12.0					fc55	Photon Dose in middle of 5.0" outer n Shield				
dfo	Log	2.232e-5	5.652e-5	1.818e-4	1.184e-4	1.342e-4	fc55	Photon Dose in middle of 5.0" outer n Shield				
	1.440e-4	1.624e-4	1.916e-4	2.797e-4	3.700e-4	5.616e-4	fc55	Total Dist from outside = (192.0875 + 204.7875)/2 = 198.4375 cm				

\$55:p	0.198,4375	91.44	0	0.198,4375	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466	467	468	469	470	471	472	473	474	475	476	477	478	479	480	481	482	483	484	485	486	487	488	489	490	491	492	493	494	495	496	497	498	499	500	501	502	503	504	505	506	507	508	509	510	511	512	513	514	515	516	517	518	519	520	521	522	523	524	525	526	527	528	529	530	531	532	533	534	535	536	537	538	539	540
--------	------------	-------	---	------------	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

19	pz	366.7000	\$	MODEL TOP (GB roof +100 cm)	mode	n	p	
20	px	-321.6150	\$	MODEL LEFT SIDE (GB side +100 cm)	imp:n	1	49r	0
21	px	-221.6150	\$	GLOVEBOX left surface	imp:p	1	49r	0
22	px	-221.3769	\$	GLOVEBOX Stainless Steel (3/32")	c	wgt = 3500*105		= 367500 Low 240 Pu
23	px	-220.9006	\$	GLOVEBOX Lead Shield (3/16")	c	wgt = 3500*215		= 752500 Mid 240 Pu
24	px	-220.6825	\$	GLOVEBOX Stainless Steel (3/32")	c	wgt = 3500*295		= 1032500 High 240 Pu
25	px	39.6875	\$	GLOVEBOX right inside surface	sdef	erg= d2	pos = 0	0 rad= d3
26	px	39.9256	\$	GLOVEBOX Stainless Steel (3/32")	sc2	cel=1	ext= d4	axs = 0
27	px	40.4019	\$	GLOVEBOX Lead Shield (3/16")	sc2	(alpha,n)	and fission spectrum	wgt=1032500.
28	px	40.6400	\$	GLOVEBOX Stainless Steel (3/32")	si2	s	35	36
29	px	231.1400	\$	MODEL RIGHT SIDE (GB side +75")	sp2	r	0.504	0.496
30	px	-122.2250	\$	MODEL BACK SIDE (GB back +100 cm)	si3	radius		
31	py	-22.2250	\$	GLOVEBOX back surface	sp3	-21	1	
32	py	-21.9869	\$	GLOVEBOX Stainless Steel (3/32")	sp4	ext=1		
33	py	-21.5106	\$	GLOVEBOX Lead Shield (3/16")	si4	-21.7200	224.5663	
34	py	-21.2725	\$	GLOVEBOX Stainless Steel (3/32")	sc5	(alpha,n) neutron source on OXYGEN from Jacom and Liskien		
35	py	82.7881	\$	GLOVEBOX front inside surface	c	Energy of the alpha particles = 5.5 MeV		
36	py	82.7881	\$	GLOVEBOX Stainless Steel (3/32")	sp5	s35		
37	py	83.2644	\$	GLOVEBOX Lead Shield (3/16")	c	#		
38	py	83.5025	\$	GLOVEBOX Stainless Steel (3/32")				
39	py	327.3425	\$	MODEL FRONT SIDE (GB front +96")				
40	pz	137.16	\$	4.5' High n Shield		0.0	0.00	
41	pz	213.36	\$	+2.5' Top n Shield		0.1	0.68	
42	px	-125.00	\$	Left End n Shield		0.2	0.76	
43	px	175.00	\$	Right End n Shield		0.3	0.74	
44	px	191.4525	\$	3/4" n Shield Material outside		0.4	0.88	
45	py	193.5575	\$	4.0" n Shield Material outside		0.5	1.20	
46	py	203.5175	\$	3/4" n Shield Material outside		0.6	1.35	
47	py	205.4225	\$	Operator Side n Shield		0.7	1.48	
48	py	191.4525	\$	3/4" n Shield Material outside		0.8	1.62	
49	py	191.7700	\$	5.0" n Shield Material outside		0.9	1.95	
50	py	204.7875	\$	1.8" n Shield Material outside		1.0	1.36	
51	py	205.1050	\$	1/8" n Shield Material outside		1.1	1.45	
52	py	205.4225	\$	Operator Side n Shield		1.2	1.63	
53	px	-125.00	\$	3/4" n Shield Material outside		1.3	1.76	
54	px	-123.0950	\$	1.0" n Shield Material outside		1.4	1.80	
55	px	-120.5550	\$	3/4" n Shield Material outside		1.5	1.89	
56	px	-118.6500	\$	Operator Side n Shield		1.6	2.05	
57	px	-125.00	\$	3/4" n Shield Material outside		1.7	2.28	
58	px	-123.4125	\$	1/8" n Shield Material outside		1.8	2.37	
59	px	-120.5550	\$	3/4" n Shield Material outside		1.9	2.49	
60	px	-120.2375	\$	1.0" n Shield Material outside		2.0	2.50	
61	px	-118.6500	\$	3/4" n Shield Material outside		2.1	2.61	
62	px	-120.2375	\$	Operator Side n Shield		2.2	2.65	
63	pz	949.96	\$	Ceiling Surface (H=2-16174)		2.3	2.74	
64	pz	960.32	\$	8 inch concrete roof (H=2-16174)		2.4	2.83	
65	px	551.32	\$	Left Wall Surface (H=2-16100)		2.5	2.93	
66	px	551.02	\$	Right Wall Surface (H=2-16100)		2.6	3.02	
67	px	251.46	\$	8 inch concrete wall right side		2.7	3.11	
68	px	307.8	\$	Back Wall Surface (H=2-16140)		2.8	3.20	
69	px	735.0125	\$	18 Gauge Metal (.0516***(4.0/1.8)=> .2913 cm)		2.9	3.30	
70	px	735.0125	\$	Back Wall Surface (H=2-16140)		3.0	3.41	
71	px	735.0125	\$	18 Gauge Metal (.0516***(4.0/1.8)=> .2913 cm)		3.1	3.56	
72	px	735.0125	\$	Back Wall Surface (H=2-16140)		3.2	3.71	
73	px	735.0125	\$	18 Gauge Metal (.0516***(4.0/1.8)=> .2913 cm)		3.3	3.86	

[illegible]

df34	skyshine	10.0	12.0	Photon dose behind Neutron Shield, Left Lower n Shield Leak Through, \$ Operator behind Neutron Shield	log	2.232e-5	5.652e-5	8.568e-5	1.184e-4	1.314e-4	1.382e-4	c	Photon dose conversion factors from ANS 6.1.1 1991	de74	log	.01	.015	.02	.03	.04	.05	50 \$ Flaggng Cells	log	2.232e-5	5.652e-5	8.568e-5	1.184e-4	1.314e-4	1.382e-4	c	Photon dose conversion factors from ANS 6.1.1 1991	de74	log	.01	.015	.02	.03	.04	.05	50 \$ Flaggng Cells
		1.440e-4	1.624e-4	1.919e-4	2.279e-4	3.708e-4	5.616e-4	7.416e-4	9.144e-4	1.076e-3	1.259e-3			de74	log	.06	.08	.10	.15	.20	.30		log	1.440e-4	1.624e-4	1.919e-4	2.279e-4	3.708e-4	5.616e-4			de74	log	.06	.08	.10	.15	.20	.30	
		2.758e-3	3.672e-3	4.500e-3	5.292e-3	6.012e-3	7.488e-3	8.892e-3	1.040e-2					de74	log	.40	.50	.60	.80	1.0	1.5		log	2.758e-3	3.672e-3	4.500e-3	5.292e-3	6.012e-3	7.488e-3			de74	log	.40	.50	.60	.80	1.0	1.5	
		2.0	3.0	4.0	5.0	6.0	8.0							de74	log	2.0	3.0	4.0	5.0	6.0	8.0		log	2.0	3.0	4.0	5.0	6.0	8.0			de74	log	2.0	3.0	4.0	5.0	6.0	8.0	
		10.0	12.0	de74	log	10.0	12.0	log	10.0	12.0	de74			log	10.0	12.0																								
		1.440e-4	1.624e-4	1.919e-4	2.279e-4	3.708e-4	5.616e-4	7.416e-4	9.144e-4	1.076e-3	1.259e-3			de74	log	1.440e-4	1.624e-4	1.919e-4	2.279e-4	3.708e-4	5.616e-4		log	1.440e-4	1.624e-4	1.919e-4	2.279e-4	3.708e-4	5.616e-4	de74		log	1.440e-4	1.624e-4	1.919e-4	2.279e-4	3.708e-4	5.616e-4		
		2.758e-3	3.672e-3	4.500e-3	5.292e-3	6.012e-3	7.488e-3	8.892e-3	1.040e-2					de74	log	2.758e-3	3.672e-3	4.500e-3	5.292e-3	6.012e-3	7.488e-3		log	2.758e-3	3.672e-3	4.500e-3	5.292e-3	6.012e-3	7.488e-3	de74		log	2.758e-3	3.672e-3	4.500e-3	5.292e-3	6.012e-3	7.488e-3		
		2.0	3.0	4.0	5.0	6.0	8.0							de74	log	2.0	3.0	4.0	5.0	6.0	8.0		log	2.0	3.0	4.0	5.0	6.0	8.0	de74		log	2.0	3.0	4.0	5.0	6.0	8.0		
		10.0	12.0	de74	log	10.0	12.0	log	10.0	12.0	de74			log	10.0	12.0																								
		1.440e-4	1.624e-4	1.919e-4	2.279e-4	3.708e-4	5.616e-4	7.416e-4	9.144e-4	1.076e-3	1.259e-3			de74	log	1.440e-4	1.624e-4	1.919e-4	2.279e-4	3.708e-4	5.616e-4		log	1.440e-4	1.624e-4	1.919e-4	2.279e-4	3.708e-4	5.616e-4	de74		log	1.440e-4	1.624e-4	1.919e-4	2.279e-4	3.708e-4	5.616e-4		
df44	skyshine	10.0	12.0	Photon dose behind Neutron Shield, Left Upper																																				

```

skyshine
fc234  Neutron Dose behind Neutron Shield, Left Lower n Shield Leak
fc234n 39 $ Operator behind Neutron Shield
fc234n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc234 34 $ Flagging Cells for Leak-through,
skyshine
fc234  Neutron Dose behind Neutron Shield, Left Upper n Shield Leak
Through
fc244n 39 $ Operator behind Neutron Shield
fc244n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc244 37 $ Flagging Cells for Leak-through,
skyshine
fc254  Neutron Dose behind Neutron Shield, Roof Reflection
fc254n 39 $ Operator behind Neutron Shield
fc254n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc254 40 $ Flagging Cells for Leak-through,
skyshine
fc264  Neutron Dose behind Neutron Shield, Steel Wall, Back Reflection
fc264n 39 $ Operator behind Neutron Shield
fc264n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc264 45 $ Flagging Cells for Leak-through,
skyshine
fc274  Neutron Dose behind Neutron Shield, Concrete Floor Effect
fc274n 39 $ Operator behind Neutron Shield
fc274n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc274 50 $ Flagging Cells for Leak-through,
skyshine
fc284  Neutron Dose behind Neutron Shield, Sum of All Cells FLAGGING!!
fc284n 39 $ Operator behind Neutron Shield
fc284n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc284 40 25 28 34 37 40 45 50 $ Flagging Cells for Leak-through,
skyshine
fc5 Neutron dose at 30 cm from outside surface of 6 in. pipe
fc5 Total Dist from outside = 30.0 + 8.4534 = 38.4534 cm
fc5n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc5n 0.38.4534 200.0 0
fc5 Total Dist from outside = 30.0 + 83.5025 = 113.5025 cm
fc15 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc15n 0.113.5025 200.0 0
fc15 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc25 Total Dist from outside = 152.8 + 83.5025 = 235.9025 cm
fc25n 0.235.9025 200.0 0
fc25 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc35 Neutron dose at 6 in. in front of tower n Shield
fc35n Total Dist from outside = 191.4525 - 6'x2.54 = 176.2125 cm
fc35n 0.176.2125 91.44 0
fc35n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc45 Neutron dose in middle of inner 1/8" SST n Shield
fc45n Total Dist from outside = (191.7700 + 192.0875)/2 = 191.9288 cm
fc45n 0.191.9288 91.44 0
fc45n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc55 Neutron dose in middle of 5.0" lower n Shield
fc55n Total Dist from outside = (192.0875 + 204.7875)/2 = 198.4375 cm
fc55n 0.198.4375 91.44 0
fc55n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc65 Neutron dose in middle of inner 1/8" Stainless Steel n Shield
fc65n Total Dist from outside = (204.7875 + 205.1050)/2 = 204.9462 cm
fc65n 0.204.9462 91.44 0
fc65n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc75 Neutron dose at 6 in. behind inside lower n Shield
fc75n Total Dist from outside = 205.4225 + 6'x2.54 = 220.6225 cm
fc75n 0.220.6225 91.44 0
fc75n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc85 Neutron dose at 6 in. in front of upper n Shield
fc85n Total Dist from outside = 191.4525 - 6'x2.54 = 176.2125 cm
fc85n 0.176.2125 182.88 0
fc85n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc95 Neutron dose in middle of outer 3/4" glass n Shield
fc95n Total Dist from outside = (191.4525 + 193.3575)/2 = 192.4050 cm
fc95n 0.192.4050 182.88 0
fc95n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc105 Neutron dose in middle of 4.0" upper n Shield
fc105n Total Dist from outside = (193.3575 + 203.5175)/2 = 198.4375 cm
fc105n 0.198.4375 182.88 0
fc105n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc115 Neutron dose in middle of inner 3/4" glass n Shield
fc115n Total Dist from outside = (203.5175 + 205.4225)/2 = 204.4700 cm
fc115n 0.204.4700 182.88 0
fc115n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
fc125 Neutron dose at 6 in. behind inside upper n Shield
fc125n Total Dist from outside = 205.4225 + 6'x2.54 = 220.6225 cm
fc125n 0.220.6225 182.88 0
fc125n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard.
print 10 110 120
mps 576.0
mps 1.665

```

CFT08AP.INP Feed Tank, 3.5 kg Pu, gamma ray calculation

```

PHOTON Dose Rate Calcs for calciner - CFT08AP
c Pu(N03)4 and H2O Photon Source is in Cell 1
c N Shield Lucite - 1.185 g/cm3 - 4. inches top, 5 inches bottom
c Lower Shields are 1/8 inch of Stainless Steel (both sides)
c Upper Shields are 3/4 inch of Glass (no Boron)(both sides)
c Full Room Model With Concrete Walls, Roof, and Metal Partitions
c
c xx-xx yy-yy zz-zz rr-rr tt-tt
c 1 1-1.582 22-22 rr-rr tt-tt tt-tt tt-tt
c 2 10 129e-3 12-12 rr-rr tt-tt tt-tt
c 3 5 2.23 11-11 1-2 2 PPEX Tube
c 4 10 1.29e-3 11-13 2 -3 Air Annulus
c 5 6 6.793 10-11 2 -3 Flange
c 6 6 7.93 13-14 -3 Flange
c 7 10 1.29e-3 24-25 34-35 9-15 (-10:14:3) Inside Glovebox
c 8 7 7.84 23-26 33-36 8 -16(-24:25:-34:35:-9:15) $ SS Inside

```

9	8	-11	34	22	-27	32	37	7	-17C	-23	-26	-33	-36	-8	16	\$	Lead Shield
10	7	-84	21	28	31	-38	6	-18C	-22	-21	-32	-37	-7	11	\$	SS Outside	
11	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	SS Inside	
12	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
13	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
14	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
15	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
16	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
17	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
18	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
19	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
20	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
21	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
22	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
23	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
24	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
25	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
26	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
27	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
28	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
29	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
30	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
31	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
32	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
33	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
34	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
35	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
36	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
37	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
38	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
39	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
40	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
41	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
42	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
43	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
44	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
45	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
46	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
47	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
48	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
49	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
50	10	-1	-29e-3	31	-38	5	5	5	5	5	5	5	5	5	\$	Operator Side	
51	0														\$	Operator Side	
52	0														\$	Operator Side	
53	0														\$	Operator Side	
54	0														\$	Operator Side	
55	0														\$	Operator Side	
56	0														\$	Operator Side	
57	0														\$	Operator Side	
58	0														\$	Operator Side	
59	0														\$	Operator Side	
60	0														\$	Operator Side	
61	0														\$	Operator Side	
62	0														\$	Operator Side	
63	0														\$	Operator Side	
64	0														\$	Operator Side	
65	0														\$	Operator Side	
66	0														\$	Operator Side	
67	0														\$	Operator Side	
68	0														\$	Operator Side	
69	0														\$	Operator Side	
70	0														\$	Operator Side	
71	0														\$	Operator Side	
72	0														\$	Operator Side	
73	0														\$	Operator Side	
74	0														\$	Operator Side	
75	0														\$	Operator Side	
76	0														\$	Operator Side	
77	0														\$	Operator Side	
78	0														\$	Operator Side	
79	0														\$	Operator Side	
80	0														\$	Operator Side	
81	0														\$	Operator Side	
82	0														\$	Operator Side	
83	0														\$	Operator Side	
84	0														\$	Operator Side	
85	0														\$	Operator Side	
86	0														\$	Operator Side	
87	0														\$	Operator Side	
88	0														\$	Operator Side	
89	0														\$	Operator Side	
90	0														\$	Operator Side	

```

57 pz 949.96 $ Ceiling Surface [H-2-16174] 0.3 0.74
58 pz 960.12 $ 4 inch concrete roof [H-2-16174] 0.4 0.88
59 px -561.34 $ 8 inch concrete wall left side 0.5 1.20
60 px -541.02 $ Left Wall Surface [H-2-16140] 0.6 1.35
61 px -551.46 $ 8 inch concrete wall right side 0.7 1.48
62 py -725.3078 $ 18 Gauge Metal (.0516**(.4.0/1.8))=>.2913 cm 0.8 1.62
63 py -725.0125 $ Back Wall Surface [H-2-16140] 0.9 1.55
64 py -725.6338 $ 18 Gauge Metal (.0516**(.4.0/1.8))=>.2913 cm 1.0 1.28
    py 327.6338 1.1 1.34
    1.2 1.45
    1.3 1.63
    1.4 1.76
    1.5 1.80
    1.6 1.89
    1.7 2.05
    1.8 2.28
    1.9 2.37
    2.0 2.49
    2.1 2.50
    2.2 2.61
    2.3 2.65
    2.4 2.54
    2.5 2.43
    2.6 2.34
    2.7 2.73
    2.8 2.06
    2.9 2.00
    3.0 1.88
    3.1 1.66
    3.2 1.56
    3.3 1.44
    3.4 1.09
    3.5 0.92
    3.6 0.79
    3.7 0.64
    3.8 0.55
    3.9 0.48
    4.0 0.39
    4.1 0.35
    4.2 0.23
    4.3 0.18
    4.4 0.11
    4.5 0.07

mode p
imp:p 1 49r 0
c wgt = 3500*3.169E+8 = 1.109E+12 Low 240 Pu
c wgt = 3500*1.115E+9 = 3.903E+12 Mid 240 Pu
c wgt = 3500*1.682E+9 = 5.887E+12 High 240 Pu
sdef cel=1 erg=ds pos=0 0 0 rad=ds
sec2 (alpha,p) and fission spectrum
s12 s 0.504 0.496
s13 radius
s14 extent
s15 -21 1
s16 -21 0
s17 171.7200 224.5663
s18 photon source from ORIGEN2
s19 TOTAL PHOTON SPECTRUM
s20 s15 sb5
s21 0.0 0.0
s22 1.5000e-02 8.9240e+08 200790
s23 2.5000e-02 4.9830e+07 31144
s24 3.5000e-02 4.9830e+07 31144
s25 4.5000e-02 7.5350e+08 2425134
s26 5.5000e-02 6.1780e+05 4464
s27 6.5000e-01 7.10030e+05 10942
s28 7.5000e-01 7.9320e+04 4016
s29 8.5000e-01 1.2800e+05 18000
s30 9.5000e-01 1.7600e+04 5819
s31 1.0500e-01 5.1220e+03 3701
s32 1.1500e+00 1.6370e+02 256
s33 1.2500e+00 7.2840e+01 223
s34 1.3500e+00 4.1830e+01 212
s35 1.4500e+00 2.4080e+01 182
s36 1.5500e+00 2.1360e+01 262
s37 1.6500e+00 9.0380e+00 226
s38 1.7500e+00 1.0250e+00 50
s39 1.8500e+00 1.1690e-01 14
s40 TOTAL 1.6820e-09
s41 (alpha,n) neutron source on OXYGEN from Jacom and Liskien
s42 Energy of the alpha particles = 5.5 MeV
s43 s35
s44 s35
s45 0.0 0.00
s46 0.1 0.68
s47 0.2 0.76

c sc35 $ spontaneous fission source spectrum (Pu240)
# sp36 3 0.799 4.903 $ Watt Fission Spectrum
# m1 94238. -0.000279 94239. -0.124257 94240. -0.027689
94241. -0.001831 94242. -0.001831 94243. -0.001831
94244. -0.001831 8016. -0.493833 8016. -0.493833
# c m1 1.4E+01 $ hydrogen liquid (CALCINE4.W01)
# m2 94238. -0.000089 94239. -0.823090 94240. -0.054516
94241. -0.002316 94242. -0.000356 94243. -0.001603
8016. -0.118030 94244. -0.002 for Low 240 Weight % (CALCINE2.W01)
# m3 94238. -0.001312 94239. -0.748841 94240. -0.108876
94241. -0.010494 94242. -0.003236 94243. -0.009270

```

m4	8016.	-0.01179771	94029.	-0.693581	94240.	-0.154533				fc14.	Photon Dose behind Neutron Shield, Front Lower n Shield Leak Through
	94238.	-0.00159529		-0.003581	94240.	-0.154533				fc14:p	\$ Operator behind Neutron Shield
	94241.	-0.0105699	94242.	-0.006324	95241.	-0.015507				skyline	\$ Flagging Cells for Leak-through,
m5	8016.	-0.117907	\$ P02 for High 240 Weight %							fc24.	Photon Dose behind Neutron Shield, Front Upper n Shield Leak Through
	14000.	-0.0376753	5010.	-0.007986	5011.	-0.032368				fc24:p	\$ Operator behind Neutron Shield
	11023.	-0.029674	13027.	-0.012173	19001.	-0.000830				skyline	\$ Flagging Cells for Leak-through,
m6	8016.	-0.540198	\$ 7740 PYREX Type I Glass [CALCINE1, Wt1]							fc34.	Photon Dose behind Neutron Shield, Left Lower n Shield Leak Through
m7	26000.	-0.74	24000.	-0.18	28000.	-0.08	\$ SS 304L Flanges			fc34:p	\$ Operator behind Neutron Shield
m8	82000.	-0.98	28000.	-0.02	\$ Stainless Steel Glovebox					skyline	\$ Flagging Cells for Leak-through,
m9	26000.	-1.00			\$ SS 316S					fc44.	Photon Dose behind Neutron Shield, Left Upper n Shield Leak Through
m10	8016.	-0.78084	8016.	-0.20946	18000.35c	-0.00934				fc44:p	\$ Operator behind Neutron Shield
	1001.	-0.00036	\$ Air							skyline	\$ Flagging Cells for Leak-through,
c	1010.	Leak-01T			\$ hydrogen in liquid, gas					fc54.	Photon Dose behind Neutron Shield, Roof Reflection
m11	13027.	-0.34	20000.	-0.044	26000.	-0.014				skyline	\$ Operator behind Neutron Shield
	1001.	-0.001	8016.	-0.532	14000.	-0.337				fc54:p	\$ Operator behind Neutron Shield
	11023.	-0.029	\$ Concrete (Common Portland)	ARH-400 II.F-1.3						skyline	\$ Flagging Cells for Leak-through,
m12	6000.	-0.5925	5010.	-0.0590	5011.	-0.2410	\$ Neutron			fc54.	Photon Dose behind Neutron Shield, Roof Reflection
c	1001.	-0.0854	14000.	-0.0101	8016.	-0.0076	\$ Shield			skyline	\$ Operator behind Neutron Shield
	26000.	-0.0038	13027.	-0.0004	29055.	-0.0002	\$ 210			fc54:p	\$ Operator behind Neutron Shield
	1010.	poly-01T	grph-01T	\$ hydrogen, carbon in solid (1.19						skyline	\$ Flagging Cells for Leak-through,
g/cm3	8016.	-0.3569	6000.	-0.3439	13027.	-0.1906	\$ Neutron			fc64.	Photon Dose behind Neutron Shield, Steel Wall Back Reflection
m15	1001.	-0.0784	20000.	-0.0123	14000.	-0.0009	\$ Shield			skyline	\$ Operator behind Neutron Shield
	5010.	-0.00138	5011.	-0.00562	12000.	-0.0006	\$ 207			fc64:p	\$ Operator behind Neutron Shield
	11023.	-0.0006	39089.	-0.0005	26000.	-0.0001				skyline	\$ Flagging Cells
	19000.	-0.0001	16032.	-0.0001	\$ Y89 substituted for Sr.					fc64.	Photon Dose behind Neutron Shield, Sum of All Cells FLAGGING!!
m13	poly-01T	grph-01T	\$ hydrogen, carbon in solid (1.4							fc64:p	\$ Operator behind Neutron Shield
g/cm3	6000.	-0.599848	1001.	-0.080538	8016.	-0.316914	\$ Lucite			skyline	\$ Flagging Cells for Leak-through,
m14	1001.	poly-01T	grph-01T	\$ hydrogen in solid (1.185	g/cm3)					fc74.	Photon Dose behind Neutron Shield, Concrete Floor Effect
Lucite	14000.	-0.392463	\$ 7740 PYREX Type I Glass [no Boron, 2.14	g/cm3]						skyline	\$ Operator behind Neutron Shield
	11023.	-0.00238	13027.	-0.002463	19001.	-0.0001				fc74:p	\$ Operator behind Neutron Shield
m16	8016.	-0.562924	\$ 7740 PYREX Type I Glass [CALCINE1, Wt1]							skyline	\$ Flagging Cells
c	6000.	-0.755751	1001.	-0.055491	8016.	-0.188758	\$ Lexan			fc74.	Photon Dose behind Neutron Shield, Right Side Leak Around
Lexan	1010.	poly-01T	\$ hydrogen in solid (1.2	g/cm3)						fc74:p	\$ Operator behind Neutron Shield
c	1010.	Photon dose conversion factors from ANS 6.1.1	1991							skyline	\$ Flagging Cells for Leak-through,
d60	log	-0.01	-0.015	-0.02	-0.03	-0.04	-0.05			fc74:p	\$ Operator behind Neutron Shield
	1.06	-0.08	1.10	-0.15	-0.20	-0.30				skyline	\$ Flagging Cells for Leak-through,
	2.0	-0.50	-0.60	-0.80	-1.0	-1.5				fc74:p	\$ Operator behind Neutron Shield
	3.0	-0.70	-0.80	-1.0	-1.2	-1.5				skyline	\$ Flagging Cells for Leak-through,
	4.0	-0.80	-1.0	-1.2	-1.5	-1.8				fc74:p	\$ Operator behind Neutron Shield
	5.0	-0.90	-1.1	-1.3	-1.6	-1.9				skyline	\$ Flagging Cells for Leak-through,
	6.0	-1.0	-1.2	-1.4	-1.7	-2.0				fc74:p	\$ Operator behind Neutron Shield
d60	log	2.258e-5	5.652e-5	8.568e-5	1.184e-4	1.314e-4	1.382e-4			skyline	\$ Flagging Cells for Leak-through,
	7.145e-4	9.144e-4	1.076e-3	1.279e-3	1.486e-3	1.66e-3	1.81e-3			fc74:p	\$ Operator behind Neutron Shield
	2.358e-3	3.672e-3	4.500e-3	5.2292e-3	6.012e-3	7.488e-3	9.092e-3			skyline	\$ Flagging Cells for Leak-through,
	8.892e-3	1.040e-2								fc74:p	\$ Operator behind Neutron Shield
fc4	Photon Dose behind Neutron Shield, Right Side Leak Around									skyline	\$ Flagging Cells for Leak-through,
fc4:p	\$ Operator behind Neutron Shield									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20									skyline	\$ Flagging Cells for Leak-through,
fc4	20										

fc85	Photon dose at 6 in. in front of upper n shield	25	14	-1.185	52	-43	45	-46	40	-41	\$ Top Fr Middle 4.0"
c	Total Dist. from outside = $191.4525 - 6^{\circ}2.54 = 176.2125$ cm	26	15	-2.14	53	-43	46	-47	40	-41	\$ Top Fr Inside 3/4"
fc85:p	0 176.2125 182.88 0	27	16	-1.29e-3	42	-43	44	-47	41	-19	\$ Above Shield
fc95	Photon dose in middle of outer 3/4" glass n shield	28	10	-1.29e-3	42	-55	48	-39	5	-40	\$ Bot L Outside air
c	Total Dist. from outside = $(191.4525 + 195.3575)/2 = 192.4050$ cm	29	7	-7.84	55	-52	49	-39	5	-40	\$ Bot L Outer 1/8"
fc95:p	0 192.4050 182.88 0	30	14	-1.185	52	-53	50	-39	5	-40	\$ Bot L Middle 1.0"
fc105	Photon dose in middle of 4.0" upper n shield	31	7	-7.84	53	-56	51	-39	5	-40	\$ Bot L Inside 1/8"
c	Total Dist. from outside = $(193.3575 + 203.5175)/2 = 198.4375$ cm	32	10	-1.29e-3	56	-54	47	-39	5	-40	\$ Bot L Inside air
fc105:p	0 198.4375 182.88 0	33	15	-2.14	42	-52	45	-39	40	-41	\$ Top L Outer 3/4"
fc115	Photon dose in middle of inner 3/4" glass n shield	34	14	-1.185	52	-53	46	-39	40	-41	\$ Top L Middle 1.0"
c	Total Dist. from outside = $(203.5175 + 205.4225)/2 = 204.4700$ cm	35	15	-2.14	53	-54	47	-39	41	-19	\$ Above Shield
fc115:p	0 204.4700 182.88 0	36	10	-1.29e-3	42	-54	47	-39	5	-41	\$ Behind n Shield
fc125	Photon dose in middle of behind inside upper n shield	37	10	-1.29e-3	42	-54	47	-39	4	-19	\$ Behind n Shield
c	Total Dist. from outside = $(205.4225 + 205.4225) = 220.6225$ cm	38	10	-1.29e-3	42	-54	47	-39	4	-19	\$ Room, Left Side
fc125:p	0 220.6225 182.88 0	39	10	-1.29e-3	40	-30	30	-30	5	-19	\$ Room, Back
fc125:p	0 220.6225 182.88 0	40	10	-1.29e-3	40	-30	30	-30	5	-19	\$ Room, Back
print	10 110 120	41	10	-1.29e-3	20	-29	63	-39	5	-19	\$ Room to Ceiling
ctne	576.0	42	10	-1.29e-3	60	-29	63	-39	5	-17	\$ SS Wall Back
nps	1.667	43	7	-7.84	60	-29	62	-63	5	-57	\$ SS Wall Front
		44	7	-7.84	60	-29	39	-64	5	-57	\$ Concrete Wall Left
		45	11	-2.30	59	-60	62	-64	5	-57	\$ Concrete Wall Right
		46	11	-2.30	29	-61	62	-64	5	-57	\$ Concrete Roof
		47	11	-2.30	59	-61	62	-64	4	-5	\$ Concrete Floor
		48	11	-2.30	59	-61	62	-64	4	-5	\$ OUTSIDE WORLD
		49	0		61	-59	64	-62	-4	58	
		1			7	7610					\$ FEED TANK O.R. - (5/16"-0.040")
		2			8	4234					\$ FEED TANK O.R.
		3			10	5675					\$ FEED TANK FLANGE O.R.
		4			40	5675					\$ CONCRETE Floor surface
		5			0	0000					\$ CONCRETE Floor surface
		6			86	3400					\$ GLOVEBOX bottom surface
		7			86	5981					\$ GLOVEBOX Stainless Steel (3/32")
		8			87	0744					\$ GLOVEBOX Lead Shield (3/16")
		9			87	3125					\$ GLOVEBOX Stainless Steel (3/32")
		10			171	4500					\$ FEED TANK Bottom Flange top
		11			171	7200					\$ FEED TANK Bottom Flange top
		12			24	5663					\$ FEED TANK Solution Level (10 L)
		13			233	6800					\$ FEED TANK Top Flange bottom
		14			34	9500					\$ FEED TANK Top Flange top
		15			265	7475					\$ GLOVEBOX top inside surface
		16			265	9956					\$ GLOVEBOX Stainless Steel (3/32")
		17			266	4619					\$ GLOVEBOX Lead Shield (3/16")
		18			266	7000					\$ GLOVEBOX Stainless Steel (3/32")
		19			325	0000					\$ MODEL Top (db roof +100 cm)
		20			325	6150					\$ GLOVEBOX Lead Shield (db side +100 cm)
		21			221	3769					\$ GLOVEBOX Stainless Steel (3/32")
		22			221	6150					\$ GLOVEBOX Lead Shield (3/16")
		23			220	9006					\$ GLOVEBOX Stainless Steel (3/32")
		24			220	6625					\$ GLOVEBOX Right Inside surface
		25			39	6875					\$ GLOVEBOX Stainless Steel (3/32")
		26			39	9256					\$ GLOVEBOX Right Inside surface
		27			40	4019					\$ GLOVEBOX Lead Shield (3/16")
		28			40	6400					\$ GLOVEBOX Stainless Steel (3/32")

CSC08ANP.IMP Storage Cen, 3.6 kg Pu, neutron and capture gammas

c Ht 240Pu02 Storage Cen Neutron Source is in Cell 1
 c N Shield Lucite - 1.185 g/cm³ - 4 inches top, 5 inches bottom
 c Lower Shields are 3/16 inch of Stainless Steel (both sides)
 c Upper Shields are 1/8 inch of glass (no boron)(both sides)
 c Full Room Mode with Concrete Walls, floor and Metal Partitions

1	4	-5.438	xx	xx	yy	yy	zz	zz	rr	-68	-69	-65	\$ Hi 240Pu02		
2	9	-7.84	9	-68	-65	\$ Can SS Bot									
3	9	-7.84	9	-69	65	-66	\$ Can SS Wall								
4	8	-11.34	9	-69	66	-67	\$ Can Lead Shield								
5	10	-1.29e-3	24	-25	34	-35	9	-15	(69:67)	\$ Inside Glovebox					
6	7	-7.84	23	-26	33	-36	8	-16	-24	25	-34	35	-9	15	\$ SS Inside
7	8	-1.29e-3	22	-27	32	-37	7	-17	-23	26	-33	36	-8	16	\$ Lead Shield
8	7	-7.84	21	-28	31	-38	6	-18	-22	27	-32	37	-7	17	\$ SS Outside
9	10	-1.29e-3	21	-28	31	-38	5	-6							\$ Under Glovebox
10	10	-1.29e-3	21	-28	31	-38	18	-19							\$ Over Glovebox
11	10	-1.29e-3	20	-21	31	-38	5	-19							\$ Left Glovebox
12	10	-1.29e-3	20	-21	31	-38	5	-19							\$ L-R Glovebox
13	10	-1.29e-3	20	-21	31	-38	3	-19							\$ Behind Glovebox
14	10	-1.29e-3	20	-21	31	-38	3	-19							\$ R-B Glovebox
15	10	-1.29e-3	20	-21	31	-38	5	-19							\$ Right Glovebox
16	10	-1.29e-3	20	-21	31	-38	3	-19							\$ Front Glovebox
17	10	-1.29e-3	42	-43	38	-44	5	-19							\$ Front Glovebox
18	10	-1.29e-3	42	-43	38	-44	5	-19							\$ Front Glovebox
19	10	-1.29e-3	42	-43	48	-48	5	-40							\$ Bot Fr Outside air
20	7	-7.84	55	-43	44	-49	5	-40							\$ Bot Fr 1/8"
21	14	-1.185	52	-43	49	-50	5	-40							\$ Bot Fr Middle 5.0"
22	7	-7.84	53	-43	50	-51	5	-40							\$ Bot Fr Middle 1/8"
23	10	-1.29e-3	56	-43	51	-47	5	-40							\$ Bot Fr Inside air
24	15	-2.14	42	-43	44	-45	40	-41							\$ Top Fr Outer 3/4"

```

29 231.1400 $ MODEL RIGHT SIDE (GB side +75")
30 PY -122.2250 $ MODEL BACK SIDE (GB back +100 cm)
31 PY -122.2250 $ GLOVEBOX back surface
32 PY -21.9869 $ GLOVEBOX Stainless Steel (3/32")
33 PY -21.5106 $ GLOVEBOX Lead Shield (3/16")
34 PY -21.2725 $ GLOVEBOX front inside surface
35 PY 82.5500 $ GLOVEBOX front inside surface
36 PY 82.7881 $ GLOVEBOX Stainless Steel (3/32")
37 PY 83.2644 $ GLOVEBOX Lead Shield (3/16")
38 PY 83.5025 $ GLOVEBOX Stainless Steel (3/32")
39 PY 83.71425 $ MODEL FRONT SIDE (GB front +96")
40 PZ 213.16 $ 4.5" High n Shield
41 PX 125.36 $ 4.5" Top n Shield
42 PX 125.00 $ Left End n Shield
43 PX 175.00 $ 3/4" n Shield Material outside
44 PY 191.4525 $ 3/4" n Shield Material outside
45 PY 193.3575 $ 4.0" n Shield Material outside
46 PY 203.5175 $ 3/4" n Shield Material outside
47 PY 205.4225 $ Operator Side n Shield
48 PY 191.4525 $ 3/4" n Shield Material outside
49 PY 191.7700 $ 1/8" n Shield Material outside
50 PY 204.7875 $ 5.0" n Shield Material outside
51 PY 205.1050 $ 1/8" n Shield Material inside
52 PX -125.00 $ Operator Side n Shield
53 PX -123.5500 $ 3/4" n Shield Material outside
54 PX -118.6500 $ 3/4" n Shield Material outside
55 PX -123.4125 $ Operator Side n Shield
56 PX -123.0950 $ 3/4" n Shield Material outside
57 PX -120.5550 $ 1.0" n Shield Material outside
58 PX -120.2375 $ 1/8" n Shield Material inside
59 PX -118.6500 $ Operator Side n Shield
60 PZ 960.12 $ Ceiling Surface (H-2-16174)
61 PX -561.34 $ 4 inch concrete roof (H-2-16174)
62 PX -541.02 $ 8 inch concrete wall Left side
63 PX 251.46 $ 8 inch concrete wall right side
64 PY -735.3078 $ 10 Gauge Metal (.0516" (4.01718) => .2913 cm)
65 PY 32.1025 $ Back Wall Surface (H-2-16140)
66 C/2 50.8000 $ 50 Gauge Metal (.0516" (4.01718) => .2913 cm)
67 C/2 50.8000 $ Storage Can Inside Radius
68 C/2 50.8000 $ Storage Can Outside Radius
69 PZ 98.7425 $ Storage Can Height
mode n p
imp:n 1 47r 0
imp:p 1 47r 0
c wgt = 3600*105 = 378000 Low 240 Pu
c wgt = 3600*215 = 774000 Mid 240 Pu
c wgt = 3600*295 = 1062000 High 240 Pu
sdef cel=1 erg=d2 pos = -126.6933 50.8000 0
      rad=d3 ext=d4 axs = 0 0 1 wgt=1062000.
      (alpha,n) and fission spectrum
sc2 $ 35 36
sp2 $ 35 36
sc3 radius
sp3 4.6038
sp4 -21 1
sc4 extent
sp4 -21 0 98.7425
c sc35 (alpha,n) neutron source on OXYGEN from Jacom and Liskien
      Energy of the alpha particles = 5.5 MeV
      $ 35 36
      # 0.0 0.0
      0.0 0.68
      0.2 0.76
      0.3 0.74
      0.4 0.88
      0.5 1.20
      0.6 1.35
      0.7 1.48
      0.8 1.62
      0.9 1.55
      1.0 1.28
      1.1 1.34
      1.2 1.45
      1.3 1.93
      1.4 1.86
      1.5 1.80
      1.6 1.89
      1.7 2.05
      1.8 2.28
      1.9 2.37
      2.0 2.49
      2.1 2.50
      2.2 2.61
      2.3 2.65
      2.4 2.54
      2.5 2.43
      2.6 2.34
      2.7 2.73
      2.8 2.06
      2.9 2.80
      3.0 1.66
      3.1 1.66
      3.2 3.2
      3.3 1.56
      3.4 1.34
      3.5 1.09
      3.6 0.92
      3.7 0.79
      3.8 0.64
      3.9 0.55

```

[illegible]

fc34	Photon Dose behind Neutron Shield, Left Lower n Shield Leak Through	df74	Photon Dose behind Neutron Shield, Sum of ALL Cells FLAGGING!!
fc34:p	37	fc84	37
fc34	skyshine	fc84:p	37
c	\$ Operator behind Neutron Shield	c	\$ Operator behind Neutron Shield
de44	log	de54	log
10.0	12.0	10.0	12.0
log	2.232e-5 5.652e-5 8.568e-5 1.184e-4 1.314e-4 1.382e-4	log	2.232e-5 5.652e-5 8.568e-5 1.184e-4 1.314e-4 1.382e-4
1.440e-4 1.624e-4 1.919e-4 2.797e-4 3.708e-4 5.616e-4		1.440e-4 1.624e-4 1.919e-4 2.797e-4 3.708e-4 5.616e-4	
7.416e-4 9.144e-4 1.076e-3 1.379e-3 1.658e-3 2.246e-3		7.416e-4 9.144e-4 1.076e-3 1.379e-3 1.658e-3 2.246e-3	
2.738e-3 3.672e-3 4.500e-3 5.292e-3 6.012e-3 7.488e-3		2.738e-3 3.672e-3 4.500e-3 5.292e-3 6.012e-3 7.488e-3	
8.892e-3 1.040e-2		8.892e-3 1.040e-2	
fc74	Photon Dose behind Neutron Shield, Concrete Floor Effect	fc84	Photon Dose behind Neutron Shield, Right Side Leak Around
fc74:p	37	fc84:p	37
fc74	skyshine	fc84:p	37
c	\$ Operator behind Neutron Shield	c	\$ Operator behind Neutron Shield
de44	log	de54	log
10.0	12.0	10.0	12.0
log	2.232e-5 5.652e-5 8.568e-5 1.184e-4 1.314e-4 1.382e-4	log	2.232e-5 5.652e-5 8.568e-5 1.184e-4 1.314e-4 1.382e-4
1.440e-4 1.624e-4 1.919e-4 2.797e-4 3.708e-4 5.616e-4		1.440e-4 1.624e-4 1.919e-4 2.797e-4 3.708e-4 5.616e-4	
7.416e-4 9.144e-4 1.076e-3 1.379e-3 1.658e-3 2.246e-3		7.416e-4 9.144e-4 1.076e-3 1.379e-3 1.658e-3 2.246e-3	
2.738e-3 3.672e-3 4.500e-3 5.292e-3 6.012e-3 7.488e-3		2.738e-3 3.672e-3 4.500e-3 5.292e-3 6.012e-3 7.488e-3	
8.892e-3 1.040e-2		8.892e-3 1.040e-2	
fc44	Photon Dose behind Neutron Shield, Left Upper n Shield Leak Through	fc84	Photon Dose behind Neutron Shield, Right Side Leak Around
fc44:p	37	fc84:p	37
fc44	skyshine	fc84:p	37
c	\$ Operator behind Neutron Shield	c	\$ Operator behind Neutron Shield
de54	log	de54	log
10.0	12.0	10.0	12.0
log	2.232e-5 5.652e-5 8.568e-5 1.184e-4 1.314e-4 1.382e-4	log	2.232e-5 5.652e-5 8.568e-5 1.184e-4 1.314e-4 1.382e-4
1.440e-4 1.624e-4 1.919e-4 2.797e-4 3.708e-4 5.616e-4		1.440e-4 1.624e-4 1.919e-4 2.797e-4 3.708e-4 5.616e-4	
7.416e-4 9.144e-4 1.076e-3 1.379e-3 1.658e-3 2.246e-3		7.416e-4 9.144e-4 1.076e-3 1.379e-3 1.658e-3 2.246e-3	
2.738e-3 3.672e-3 4.500e-3 5.292e-3 6.012e-3 7.488e-3		2.738e-3 3.672e-3 4.500e-3 5.292e-3 6.012e-3 7.488e-3	
8.892e-3 1.040e-2		8.892e-3 1.040e-2	
fc54	Photon Dose behind Neutron Shield, Roof Reflection	fc84	Photon Dose behind Neutron Shield, Right Side Leak Around
fc54:p	37	fc84:p	37
fc54	skyshine	fc84:p	37
c	\$ Operator behind Neutron Shield	c	\$ Operator behind Neutron Shield
de64	log	de64	log
10.0	12.0	10.0	12.0
log	2.232e-5 5.652e-5 8.568e-5 1.184e-4 1.314e-4 1.382e-4	log	2.232e-5 5.652e-5 8.568e-5 1.184e-4 1.314e-4 1.382e-4
1.440e-4 1.624e-4 1.919e-4 2.797e-4 3.708e-4 5.616e-4		1.440e-4 1.624e-4 1.919e-4 2.797e-4 3.708e-4 5.616e-4	
7.416e-4 9.144e-4 1.076e-3 1.379e-3 1.658e-3 2.246e-3		7.416e-4 9.144e-4 1.076e-3 1.379e-3 1.658e-3 2.246e-3	
2.738e-3 3.672e-3 4.500e-3 5.292e-3 6.012e-3 7.488e-3		2.738e-3 3.672e-3 4.500e-3 5.292e-3 6.012e-3 7.488e-3	
8.892e-3 1.040e-2		8.892e-3 1.040e-2	
fc64	Photon Dose behind Neutron Shield, Steel Wall Back Reflection	fc84	Photon Dose behind Neutron Shield, Right Side Leak Around
fc64:p	37	fc84:p	37
fc64	skyshine	fc84:p	37
c	\$ Operator behind Neutron Shield	c	\$ Operator behind Neutron Shield
de74	log	de64	log
10.0	12.0	10.0	12.0
log	2.232e-5 5.652e-5 8.568e-5 1.184e-4 1.314e-4 1.382e-4	log	2.232e-5 5.652e-5 8.568e-5 1.184e-4 1.314e-4 1.382e-4
1.440e-4 1.624e-4 1.919e-4 2.797e-4 3.708e-4 5.616e-4		1.440e-4 1.624e-4 1.919e-4 2.797e-4 3.708e-4 5.616e-4	
7.416e-4 9.144e-4 1.076e-3 1.379e-3 1.658e-3 2.246e-3		7.416e-4 9.144e-4 1.076e-3 1.379e-3 1.658e-3 2.246e-3	
2.738e-3 3.672e-3 4.500e-3 5.292e-3 6.012e-3 7.488e-3		2.738e-3 3.672e-3 4.500e-3 5.292e-3 6.012e-3 7.488e-3	
8.892e-3 1.040e-2		8.892e-3 1.040e-2	
fc74	Photon Dose behind Neutron Shield, Front Upper n Shield Leak	fc84	Photon Dose behind Neutron Shield, Right Side Leak Around
fc74:p	37	fc84:p	37
fc74	skyshine	fc84:p	37
c	\$ Operator behind Neutron Shield	c	\$ Operator behind Neutron Shield
de74	log	de64	log
10.0	12.0	10.0	12.0
log	2.232e-5 5.652e-5 8.568e-5 1.184e-4 1.314e-4 1.382e-4	log	2.232e-5 5.652e-5 8.568e-5 1.184e-4 1.314e-4 1.382e-4
1.440e-4 1.624e-4 1.919e-4 2.797e-4 3.708e-4 5.616e-4		1.440e-4 1.624e-4 1.919e-4 2.797e-4 3.708e-4 5.616e-4	
7.416e-4 9.144e-4 1.076e-3 1.379e-3 1.658e-3 2.246e-3		7.416e-4 9.144e-4 1.076e-3 1.379e-3 1.658e-3 2.246e-3	
2.738e-3 3.672e-3 4.500e-3 5.292e-3 6.012e-3 7.488e-3		2.738e-3 3.672e-3 4.500e-3 5.292e-3 6.012e-3 7.488e-3	
8.892e-3 1.040e-2		8.892e-3 1.040e-2	
fc84	Photon Dose behind Neutron Shield, Front Lower n Shield Leak	fc84	Photon Dose behind Neutron Shield, Right Side Leak Around
fc84:p	37	fc84:p	37
fc84	skyshine	fc84:p	37
c	\$ Operator behind Neutron Shield	c	\$ Operator behind Neutron Shield
de74	log	de64	log
10.0	12.0	10.0	12.0
log	2.232e-5 5.652e-5 8.568e-5 1.184e-4 1.314e-4 1.382e-4	log	2.232e-5 5.652e-5 8.568e-5 1.184e-4 1.314e-4 1.382e-4
1.440e-4 1.624e-4 1.919e-4 2.797e-4 3.708e-4 5.616e-4		1.440e-4 1.624e-4 1.919e-4 2.797e-4 3.708e-4 5.616e-4	
7.416e-4 9.144e-4 1.076e-3 1.379e-3 1.658e-3 2.246e-3		7.416e-4 9.144e-4 1.076e-3 1.379e-3 1.658e-3 2.246e-3	
2.738e-3 3.672e-3 4.500e-3 5.292e-3 6.012e-3 7.488e-3		2.738e-3 3.672e-3 4.500e-3 5.292e-3 6.012e-3 7.488e-3	
8.892e-3 1.040e-2		8.892e-3 1.040e-2	

```

32      $ Flagging Cells for Leak-through,
cf234  skyshine
cf244  Neutron Dose behind Neutron Shield, Left Upper n Shield Leak
Through
fn244:n 37 $ Operator behind Neutron Shield
fn244:n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard,
cf244 35 $ Flagging Cells for Leak-through,
skyshine
cf254  Neutron Dose behind Neutron Shield, Roof Reflection
fn254:n 37 $ Operator behind Neutron Shield
fn254:n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard,
cf254 38 $ Flagging Cells for Leak-through,
skyshine
cf264  Neutron Dose behind Neutron Shield, Steel Wall Back Reflection
fn264:n 37 $ Operator behind Neutron Shield
fn264:n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard,
cf264 43 $ Flagging Cells for Leak-through,
skyshine
cf274  Neutron Dose behind Neutron Shield, Concrete Floor Effect
fn274:n 37 $ Operator behind Neutron Shield
fn274:n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard,
cf274 48 $ Flagging Cells for Leak-through,
skyshine
cf284  Neutron Dose behind Neutron Shield, Sum of All Cells FLAGGING!!
fn284:n 37 $ Operator behind Neutron Shield
fn284:n 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard,
cf284 18 23 26 32 35 38 43 48 $ Flagging Cells for Leak-through,
skyshine
cf29  dose at 30 cm from outside surface of 6 in. pipe
cf5  Total Dist from outside = 30.0 + 50.80 + 5.06 = 85.88 cm
fn5  126.6933 85.88 cm
cf5 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard,
cf15  dose at 30 cm from outside surface of Glovebox,
Total Dist from outside = 30.0 + 83.5025 = 113.5025 cm
fn15:n -126.6933 113.5025 93.1068 0
cf15 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard,
fn15  dose at 5 feet from outside surface of Glovebox
cf25  Total Dist from outside = 152.8 + 83.5025 = 235.9025 cm
fn25:n -126.6933 235.9025 93.1068 0
cf25 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard,
fn25  Neutron dose at 6 in. in front of lower n Shield
cf35  Total Dist from outside = 191.4525 - 6*2.54 = 176.2125 cm
fn35:n 0 176.2125 91.44 0
cf35 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard,
fn35  Neutron dose in middle of outer 1/8" SST n Shield
cf45  Total Dist from outside = (191.7700 + 192.0075)/2 = 191.9288 cm
fn45:n 0 91.9288 0
cf45 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard,
fn45  Neutron dose in middle of 5" lower n Shield
cf55  Total Dist from outside = (192.0875 + 204.7875)/2 = 198.4375 cm
fn55:n 0 198.4375 91.44 0
cf55 2.0 $ Factor of 2 times the ANS 6.1.1 1991 Standard,
fn55  Neutron dose in middle of inner 1/8" Stainless Steel n Shield
cf65  Total Dist from outside = (204.7875 + 205.1050)/2 = 204.9462 cm

```

14	10	-1.29e-3	28	-29	30	-31	5	-19	\$ R-B	Glovebox	18	2666.7000	\$ GLOVEBOX Stainless Steel (3/32")
15	10	-1.29e-3	28	-29	30	-38	5	-19	\$ Right	Glovebox	19	3666.7000	\$ MODEL TOP (GB side +100 cm)
16	10	-1.29e-3	28	-42	38	-39	5	-19	\$ Front	Glovebox	20	3666.7000	\$ MODEL LEFT SIDE (GB side +100 cm)
17	10	-1.29e-3	42	-43	38	-44	5	-19	\$ Front	Glovebox	21	221.6150	\$ GLOVEBOX Left surface
18	10	-1.29e-3	42	-43	38	-39	5	-19	\$ Front	Glovebox	22	221.6150	\$ GLOVEBOX Stainless Steel (3/32")
19	10	-1.29e-3	42	-43	44	-48	5	-40	\$ Bot Fr Outside air		23	220.9006	\$ GLOVEBOX Lead Shield (3/16")
20	7	-7.84	55	-43	48	-49	5	-40	\$ Bot Fr Outer 1/8"		24	39.6875	\$ GLOVEBOX Stainless Steel (3/32")
21	14	-1.185	53	-43	49	-50	5	-40	\$ Bot Fr Middle 5.0"		25	39.9256	\$ GLOVEBOX right inside surface
22	7	-7.84	55	-43	50	-51	5	-40	\$ Bot Fr Inside 1/8"		26	40.4019	\$ GLOVEBOX Stainless Steel (3/32")
23	10	-1.29e-3	56	-43	51	-47	5	-40	\$ Bot Fr Inside air		27	40.6400	\$ GLOVEBOX Lead Shield (3/16")
24	15	-2.14	42	-43	44	-45	40	-41	\$ Top Fr Inside 3/4"		28	221.1400	\$ GLOVEBOX Stainless Steel (3/32")
25	14	-1.185	52	-43	45	-46	40	-41	\$ Top Fr Middle 4.0"		29	221.2250	\$ MODEL RIGHT SIDE (GB side +75")
26	15	-2.14	53	-43	46	-47	40	-41	\$ Top Fr Inside 3/4"		30	22.9869	\$ GLOVEBOX back surface
27	10	-1.29e-3	42	-43	44	-47	41	-19	\$ Above Shield		31	22.9869	\$ GLOVEBOX Stainless Steel (3/32")
28	10	-1.29e-3	42	-43	48	-39	5	-40	\$ Bot L Outside air		32	51.3106	\$ GLOVEBOX Lead Shield (3/16")
29	7	-7.84	55	-32	49	-39	5	-40	\$ Bot L Outer 1/8"		33	83.5505	\$ GLOVEBOX front inside surface
30	7	-7.84	55	-32	50	-39	5	-40	\$ Bot L Middle 1.0"		34	83.5505	\$ GLOVEBOX Stainless Steel (3/32")
31	7	-7.84	55	-31	51	-39	5	-40	\$ Bot L Inside air		35	83.7881	\$ GLOVEBOX Lead Shield (3/16")
32	10	-1.29e-3	56	-47	39	-40	5	-40	\$ Bot L Outside air		36	83.7881	\$ GLOVEBOX front inside surface
33	15	-2.14	42	-52	45	-39	40	-41	\$ Top L Outer 3/4"		37	83.2644	\$ GLOVEBOX Lead Shield (3/16")
34	14	-1.185	52	-53	46	-39	40	-41	\$ Top L Middle 1.0"		38	83.5025	\$ GLOVEBOX Stainless Steel (3/32")
35	15	-2.14	53	-54	47	-39	40	-41	\$ Top L Inside 3/4"		39	237.3425	\$ MODEL FRONT SIDE (GB front +96")
36	10	-1.29e-3	42	-54	47	-39	41	-19	\$ Above Shield		40	137.16	\$ 4.5' High n Shield
37	10	-1.29e-3	54	-43	47	-39	5	-41	\$ Behind n Shield		41	123.36	\$ +2.5' Top n Shield
38	10	-1.29e-3	54	-43	47	-39	5	-41	\$ Behind n Shield		42	125.00	\$ Left End n Shield
39	10	-1.29e-3	60	-20	30	-39	5	-19	\$ Room, Left Side		43	175.00	\$ 3/4" n Shield Material
40	10	-1.29e-3	60	-20	30	-39	5	-19	\$ Room, Left Side		44	191.4525	\$ 4.0" n Shield Material outside
41	10	-1.29e-3	60	-20	63	-30	5	-19	\$ Room, Back Part		45	193.5375	\$ 3/4" n Shield Material outside
42	10	-1.29e-3	60	-29	63	-39	19	-57	\$ Room to Ceiling		46	203.5175	\$ Operator Side n Shield
43	7	-7.84	60	-29	62	-63	5	-57	\$ SS Wall Back		47	205.4225	\$ Operator Side n Shield
44	11	-7.84	60	-29	39	-64	5	-57	\$ SS Wall Front		48	191.4525	\$ 3/4" n Shield Material outside
45	11	-7.84	60	-29	39	-64	5	-57	\$ Concrete Wall Left		49	192.0375	\$ 5.0" n Shield Material outside
46	11	-7.84	60	-29	63	-64	5	-57	\$ Concrete Wall Right		50	204.7875	\$ 5.0" n Shield Material outside
47	11	-7.84	60	-29	63	-64	5	-57	\$ Concrete Wall		51	205.1050	\$ 1/8" n Shield Material inside
48	11	-2.30	59	-61	62	-64	4	-55	\$ Concrete Floor		52	205.4225	\$ Operator Side n Shield
49	0	61:-59:	64:-62:	-4:-58					\$ OUTSIDE WORLD		53	125.00	\$ 3/4" n Shield Material outside
1	CZ	7.7610							\$ FEED TANK O.R. - (5/16" n 0.040")		54	123.0950	\$ 1.0" n Shield Material outside
2	CZ	8.4534							\$ FEED TANK O.R.		55	120.5550	\$ 3/4" n Shield Material outside
3	CZ	14.2875							\$ FEED TANK FLANGE O.R.		56	118.6500	\$ Operator Side n Shield
4	CZ	-60.9600							\$ CONCRETE FLOOR bottom (24" thick)		57	125.00	\$ 3/4" n Shield Material outside
5	PZ	0.0000							\$ CONCRETE FLOOR surface		58	123.4125	\$ 1.0" n Shield Material outside
6	PZ	86.3600							\$ GLOVEBOX bottom surface		59	123.0950	\$ 3/4" n Shield Material outside
7	PZ	86.5981							\$ GLOVEBOX Stainless Steel (3/32")		60	120.5550	\$ 1/8" n Shield Material inside
8	PZ	87.0744							\$ GLOVEBOX Lead Shield (3/16")		61	118.6500	\$ Operator Side n Shield
9	PZ	87.3125							\$ GLOVEBOX Stainless Steel (3/32")		62	949.96	\$ Ceiling Surface (H=2-16174)
10	PZ	171.4500							\$ FEED TANK Bottom Flange bottom		63	564.32	\$ 8 inch concrete wall (H=2-16174)
11	PZ	274.5203							\$ FEED TANK Bottom Flange top		64	564.32	\$ 8 inch concrete wall (H=2-16174)
12	PZ	274.5203							\$ FEED TANK Bottom Flange bottom				
13	PZ	233.6800							\$ FEED TANK Top Flange top				
14	PZ	234.9500							\$ FEED TANK Top Flange bottom				
15	PZ	265.7475							\$ GLOVEBOX top inside surface				
16	PZ	265.9856							\$ GLOVEBOX Stainless Steel (3/32")				
17	PZ	266.4619							\$ GLOVEBOX Lead Shield (3/16")				

```

65 c/z -126.6933 50.8000 4.6038 $ Storage Can Inside Radius 1.35
66 c/z -126.6933 50.8000 4.7920 $ Storage Can Outside Radius 1.48
67 c/z -126.6933 50.8000 5.0800 $ Storage Can End Outside Radius 1.62
68 pz 87.4712 $ Storage Can Stainless Steel Floor 1.55
69 pz 98.7425 $ Storage Can Height 1.28

mode p
imp 1 w7r 0
c wgt = 3600*3.169E+8 = 1.141E+12 Low 240 Pu 1.35
c wgt = 3600*1.115E+9 = 4.014E+12 Mid 240 Pu 1.48
c wgt = 3600*1.682E+9 = 6.055E+12 High 240 Pu 1.62
sdef cel=1 erg=d5 pos = -126.6933 50.8000 0 1.55
rad=d3 ext=d4 axs = 0 0 1 wgt=6.055E+12 1.28
sc2 (alpha,n) and fission spectrum 1.35
si2 s 35 36 1.48
s 0.504 0.496 1.62
sp2 radius 1.55
sp3 -21.1 1.28
sp4 -21.0 1.35
s14 87.4712 98.7425 1.45
s15 87.4712 98.7425 1.62
c photon source from ORIGEN2 1.76
c TOTAL PHOTON SPECTRUM 1.80
# si5 sb5 1.89
0.0 0.0 2.05
1.5000e-02 8.9240e+08 200790 1.99
2.5000e-02 4.9830e+07 31144 2.00
3.7500e-02 4.6240e+06 6503 2.28
5.7500e-02 7.3350e+08 2425134 2.49
8.5000e-02 6.1780e+05 4464 2.50
1.2500e-01 7.0030e+05 10942 2.61
2.2500e-01 7.9320e+04 4016 2.52
3.7500e-01 1.2800e+05 5800 2.43
5.7500e-01 1.1810e+06 5919 2.34
8.5000e-01 5.1220e+03 3701 2.73
1.2500e+00 1.4370e+02 256 2.06
2.2500e+00 7.2840e+01 223 2.00
3.7500e+00 4.1830e+01 212 3.01
5.7500e+00 2.4080e+01 182 3.14
8.5000e+00 2.1360e+01 262 3.22
1.2500e+00 9.0380e+00 226 3.13
2.2500e+00 1.0250e+00 50 3.40
3.7500e+00 1.1690e-01 14 3.50
TOTAL 1.6820e+09 3.50
c (alpha,n) neutron source on OXGEN from Jacom and Liskien 3.50
c Energy of the alpha particles = 5.5 Mev 3.50
# si35 sp35 3.50
0.0 0.0 3.50
0.1 0.98 3.50
0.2 0.76 3.50
0.3 0.76 3.50
0.4 0.88 3.50
0.5 1.20 3.50

sc35 spontaneous fission source spectrum (Pu240) 4.5
sp36 -3 0.799 4.903 $ Watt Fission Spectrum 4.5
m1 94239 -0.197551 7014 -0.047731 8016 -0.682422 4.5
1001 -0.065371 $ Pu(240) 711.69 g/L, H2O 1000 g/L. 4.5
mt1 lwr-01t 4.5
c 94238 -0.000089 94239 -0.823090 94240 -0.054516 4.5
m2 94241 -0.002316 94242 -0.000356 95241 -0.001603 4.5
8016 -0.118030 $ Pu02 for Low 240 Weight % [CALCINE2.W01] 4.5
94238 -0.018440 94239 -0.768811 94240 -0.088965 4.5
94239 -0.010391 94240 -0.003236 95241 -0.009270 4.5
8016 -0.117971 $ Pu02 for Med 240 Weight % [CALCINE2.W01] 4.5
94238 -0.001559 94239 -0.693581 94240 -0.154553 4.5
94241 -0.010569 94242 -0.006324 95241 -0.015507 4.5
8016 -0.117907 $ Pu02 for High 240 Weight % [CALCINE2.W01] 4.5

```

m5	14000.	-0.376753	5010.	-0.007986	5011.	-0.032386	fc24	Photon Dose behind Neutron Shield, Front Upper n Shield Leak Through	
	11023.	-0.029674	13027.	-0.012173	19000.	-0.000830	fc24:p	\$ Operator behind Neutron Shield	
m6	8016.	-0.540198	\$ 7740	PIREX Type I Glass [CALCINE]1, W011			skyshine	26	
m7	26000.	-0.74	24000.	-0.18	28000.	-0.08	\$ SS 304L Flanges	fc34	Photon Dose behind Neutron Shield, Left Lower n Shield Leak Through,
m8	26000.	-0.98	28000.	-0.02	\$ Stainless Steel Glovebox		fc34:p	\$ Operator behind Neutron Shield	
m9	82000.	-1.00			\$ Lead Glovebox Shield		fc34	\$ Flagging Cells for Leak-through,	
m10	26000.	-1			\$ S 310S		skyshine	32	
m11	7014.	-78084	8016.	-0.20946	18000.35c	-0.00934	fc44	Photon Dose behind Neutron Shield, Left Upper n Shield Leak Through	
c	7014.	-0.00036	\$ Air			\$ hydrogen in liquid, gas	fc44:p	\$ Operator behind Neutron Shield	
m11	13027.	-0.034	20000.	-0.044	26000.	-0.014	fc54	Photon Dose behind Neutron Shield, Roof Reflection	
	1001.	-0.001	8016.	-0.552	14000.	-0.337	fc54:p	\$ Operator behind Neutron Shield	
c	11023.	-0.029	\$ Concrete (common Portland)	ARI-600 II-F.1-3			skyshine	35	
mt11	poly.01t			\$ hydrogen in solid			fc54:p	\$ Operator behind Neutron Shield	
mt12	6000.	-0.5925	5010.	-0.0590	5011.	-0.2410	\$ Neutron	38	
c	1001.	-0.0854	14000.	-0.0101	8016.	-0.0076	\$ Shield	38	
mt13	26000.	-0.0038	13027.	-0.0004	25055.	-0.0002	\$ 210	38	
c	poly.01t	grph.01t		\$ hydrogen, carbon in solid (1.19			fc64	Photon Dose behind Neutron Shield, Steel Wall Back Reflection	
mt13	8016.	-0.3649	6000.	-0.3439	13027.	-0.1906	\$ Neutron	43	
c	1001.	-0.0784	20000.	-0.0123	14000.	-0.0009	\$ Shield	43	
mt14	5010.	-0.00138	5011.	-0.00562	12000.	-0.0006	\$ 207	43	
c	11023.	-0.0001	39089.	-0.0005	26000.	-0.0001	\$ Y89 substituted for Sr.	43	
mt14	19000.	-0.0001	16032.	-0.0001	\$ Y89 substituted for Sr.		fc74	Photon Dose behind Neutron Shield, Concrete Floor Effect	
c	poly.01t	grph.01t		\$ hydrogen, carbon in solid (1.14			fc74:p	\$ Operator behind Neutron Shield	
mt15	6000.	-0.599848	1001.	-0.080538	8016.	-0.319614	\$ Lucite	48	
c	mt14	poly.01t	grph.01t	\$ hydrogen in solid (1.185	g/cm3)		fc84	Photon Dose behind Neutron Shield, Sum of All Cells FLAGGING!!	
Lucite	14000.	-0.392603	\$ 7740	PIREX Type I Glass Ino Borep, 2.14	g/cm3]		fc84:p	\$ Operator behind Neutron Shield	
m15	11023.	-0.030923	13027.	-0.012485	19000.	-0.00845	fc84	Photon dose at 30 cm from outside surface of 6 in. pipe	
m16	8016.	-0.562924	\$ 7740	PIREX Type I Glass [CALCINE]1, W011			fc85	Total Dist. from outside = 30.0 + 50.80 + 5.08 = 85.88 cm	
Lexan	6000.	-0.755751	1001.	-0.055491	8016.	-0.188758	\$ Lexan	85.88	
c	mt16	poly.01t	grph.01t	\$ hydrogen in solid (1.2	g/cm3)		fc95	Photon dose at 30 cm from outside surface of Glovebox	
de0	Photon dose conversion factors from ANS 6.1.1	1991					fc95:p	Total Dist. from outside = 5 feet from outside surface of Glovebox	
log	.01	.015	.02	.03	.04	.05	fc95	Photon dose at 6 in. in front of lower n Shield	
	.06	.08	.10	.15	.20	1.30	fc35	Total Dist. from outside = 191.4525 - 6*2.54 = 176.2125 cm	
	.40	.50	.60	.80	1.0	1.5	fc35:p	Photon dose in middle of outer 1/8" SST n Shield	
	2.0	3.0	4.0	5.0	6.0	8.0	fc45	Total Dist. from outside = (191.7700 + 192.0875)/2 = 191.9288 cm	
d0	log	2.23254	5.652e-5	8.568e-5	1.184e-4	1.314e-4	fc45:p	Photon dose in middle of 5.0" lower n Shield	
		1.440e-4	1.624e-4	1.797e-4	2.797e-4	3.708e-4	fc55	Photon dose at 6 in. in front of upper n Shield	
		2.416e-4	3.144e-4	4.106e-4	5.1379e-5	1.656e-3	fc55:p	Total Dist. from outside = (192.0875 + 204.7875)/2 = 198.4375 cm	
		8.892e-3	3.672e-2	4.500e-3	5.292e-3	6.012e-3	fc65	Photon dose in middle of inner 1/8" Stainless Steel n Shield	
		1.00	12.0				fc65:p	Photon dose at 6 in. behind inside lower n Shield	
fc4	Photon Dose behind Neutron Shield, Right Side Leak Around						c	Photon dose at 6 in. in front of upper n Shield	
fc4:p	\$ Operator behind Neutron Shield						fc75	Total Dist. from outside = 205.4225 + 6*2.54 = 220.6225 cm	
fc4	\$ Flagging Cells for Leak-through,						skyshine	0 220.6225 91.44 0	
fc14	Photon Dose behind Neutron Shield, Front Lower n Shield Leak Through/75:p						fc85	Photon dose at 6 in. in front of upper n Shield	
fc14:p	\$ Operator behind Neutron Shield						fc85:p	Total Dist. from outside = 191.4525 - 6*2.54 = 176.2125 cm	
skyshine	\$ Flagging Cells for Leak-through,						fc85:p	0 176.2125 182.88 0	

```

fc95 Photon dose in middle of outer 3/4" glass n Shield
c Total Dist from outside = (191.4525 + 193.3575)/2 = 192.4050 cm
f95:p 0 192.4050 182.88 0
fc105 Photon dose in middle of 4.0" upper n Shield
c Total Dist from outside = (193.3575 + 203.5175)/2 = 198.4375 cm
f105:p 0 198.4375 182.88 0
fc115 Photon dose in middle of inner 3/4" glass n Shield
c Total Dist from outside = (203.5175 + 205.4225)/2 = 204.4700 cm
f115:p 0 204.4700 182.88 0
fc125 Photon dose at 6 in. Behind inside upper n Shield
c Total Dist from outside = 205.4225 + 8*2.54 = 220.6225 cm
f125:p 0 220.6225 182.88 0
print 10 110 120
ctme 180.0
nps 1.0e7

```

This page intentionally left blank

APPENDIX D

HAND DOSE RATE MCNP INPUT FILES

CRCH02NP.INP 3.6 kg Pu Receipt Can with Hands, neutron and capture gammas
CRCH02P.INP 3.6 kg Pu Receipt Can with Hands, gamma ray calculation

This page intentionally left blank

D-3

	4.3	0.18	
	4.4	0.11	
	4.5	0.07	
sp36	spontaneous fission source spectrum (Pu240)		
sp36	-3	0.799	4.903 \$ Watt Fission Spectrum
m1	94239.55c	-0.197551	7014.50c -0.0477371 8016.50c -0.682422
	1001.50c	-0.065371	\$ Pu(N03)4 711.69 g/L, H2O 1000 g/L.
mt1	hydrogen in liquid		
mt2	94238.50c	-0.000089	94239.55c -0.823090 94240.50c -0.054516
	94241.50c	-0.002316	94242.50c -0.000356 95241.50c -0.001603
m3	8016.50c	-0.118030	\$ PuO2 for Low 240 Weight % [CALCINE2.W01]
	94238.50c	-0.001312	94239.55c -0.748884 94240.50c -0.108876
	94239.55c	-0.002328	95241.50c -0.009270
m4	8016.50c	-0.117971	\$ PuO2 for High 240 Weight % [CALCINE2.W01]
	94238.50c	-0.117971	94239.55c -0.695381 94240.50c -0.152541
	94241.50c	-0.010569	94242.50c -0.006324 95241.50c -0.015507
m5	8016.50c	-0.117907	\$ PuO2 for High 240 Weight % [CALCINE2.W01]
	14000.50c	-0.376733	5010.50c -0.007986 5011.55c -0.002386
	11023.50c	-0.029674	13027.50c -0.012173 19000.50c -0.000830
m6	8016.50c	-0.540198	\$ 7740 PYREX Type I glass [CALCINE1.W01]
m7	26000.55c	-0.74	24000.50c -0.18 28000.50c -0.08 \$ SS 304L Flanges
m8	82000.55c	-0.98	28000.50c -0.02 \$ Stainless Steel Glovebox
m9	26000.55c	-1.00	\$ Lead Glovebox Shield
m10	1001.50c	-0.78084	\$ SS 310S
	1001.50c	-0.00056	\$ Air
mt10	13027.50c	-0.034	20000.50c -0.044 \$ hydrogen in liquid, gas
mt11	1001.50c	-0.001	8016.50c -0.532 14000.50c -0.337
	11023.50c	-0.029	\$ Concrete (common Portland) ARH-600 II.F.1-3
mt11	poly.01t \$ hydrogen in solid		
mt12	6000.50c	-0.5925	5010.50c -0.0590 5011.55c -0.2410 \$ Neutron
	1001.50c	-0.0854	14000.50c -0.0101 8016.50c -0.0076 \$ Shield
	26000.55c	-0.0038	13027.50c -0.0004 25055.50c -0.0002 \$ 210
mt12	poly.01t \$ hydrogen, carbon in solid (1.19 g/cm3)		
mt15	8016.50c	-0.3647	6000.50c -0.34359 13027.50c -0.1906 \$ Neutron
	5010.50c	-0.00138	5011.55c -0.00140 5012.50c -0.0009 \$ Shield
	5010.50c	-0.00138	5011.55c -0.00562 12000.50c -0.0009 \$ 207
	11023.50c	-0.0006	29009.50c -0.0005 26000.55c -0.0001
	19000.50c	-0.0001	16032.50c -0.0001 \$ Y89 substituted for Sr-
mt13	poly.01t \$ hydrogen, carbon in solid (1.4 g/cm3)		
mt14	6000.50c	-0.5999	8016.50c -0.3196 1001.50c -0.0805 \$ Lucite
mt14	poly.01t \$ hydrogen in solid (1.2 g/cm3)		
mt15	6000.50c	-0.64	1001.50c -0.07 8016.50c -0.29 \$ LATEX 11 g/cm3
mt15	poly.01t \$ hydrogen, carbon in solid (1.1 g/cm3)		
mt16	1001.50c	-0.333333	8016.50c 0.666667 \$ Water hands (1.00 g/cm3)
mt16	Lwtr.01t \$ hydrogen in liquid, gas		
c	Neutron dose conversion factors from ANSI 6.1.1 1991		
de0	2.08e-05	1.00e-05	1.00e-04 1.00e-03
	1.00e-02	2.00e-02	1.00e-01 2.00e-01
	1.00e+00	1.50e+00	3.00e+00 4.00e+00
	6.00e+00	7.00e+00	8.00e+00 1.00e+01 1.40e+01
df0	1.440e-03	1.584e-03	1.735e-03 1.605e-03 1.490e-03 1.379e-03
	1.631e-03	2.113e-03	3.924e-03 7.120e-03 1.390e-02 3.132e-02

[illegible]

sc4	extent	2.5	2.43
sc4	-21.0	2.6	2.34
sc4	photon source from ORIGEN2	2.7	2.73
sc5	photon source from ORIGEN2	2.8	2.06
c	TOTAL PHOTON SPECTRUM	2.9	2.00
#	sb5	3.0	1.88
	sp5	3.1	1.66
	0.0	3.2	1.56
1.5000e-02	8.9240e+08	3.3	1.34
2.5000e-02	4.9830e+07	3.4	1.09
3.7500e-02	4.6240e+06	3.5	0.92
5.7500e-02	7.3350e+08	3.6	0.79
8.5000e-02	6.1780e+05	3.7	0.64
1.2500e-01	7.0050e+05	3.8	0.35
2.2500e-01	7.320e+04	3.9	0.16
3.2500e-01	1.260e+04	4.0	0.36
4.2500e-01	1.7600e+02	4.1	0.35
5.2500e-01	5.1220e+03	4.2	0.23
6.2500e-01	1.6370e+02	4.3	0.18
7.2500e-01	7.2840e+01	4.4	0.11
8.2500e-01	4.1830e+01	4.5	0.07
9.2500e-01	2.4080e+01	sp36	spontaneous fission source spectrum (Pu240)
1.0000e+00	2.1360e+01	sp36	-3 0.799 4.903 \$ Watt Fission Spectrum
1.0000e+00	9.0380e+00	m1	94239. -0.197551 7014. -0.047731 8016. -0.682422
1.0000e+00	1.0250e+00	m2	1001. -0.065371 \$ Pu(N03)4 711.69 g/L, H2O 1000 g/L.
1.0000e+01	1.7690e-01	m2	94238. -0.000089 94239. -0.823090 94240. -0.054516
TOTAL	1.6820e+09	m2	94241. -0.002316 94242. -0.000356 95241. -0.001603
(alpha,n) neutron source on OXYGEN from Jacom and Liskien		m3	8016. -0.178030 \$ Pu02 for Low 240 Weight \$ [CALCINE2.W01]
Energy of the alpha particles = 5.5 Mev		m3	94238. -0.001312 94239. -0.748841 94240. -0.108876
sp35		m3	94241. -0.001794 94242. -0.003259 95241. -0.009270
0.0	0.48	m4	8016. -0.117974 \$ Pu02 for High 240 Weight \$ [CALCINE2.W01]
0.1	0.76	m4	94238. -0.001559 94239. -0.695581 94240. -0.154553
0.2	0.76	m4	94241. -0.010569 94242. -0.006324 95241. -0.015507
0.3	0.74	m5	8016. -0.117907 \$ Pu02 for High 240 Weight \$ [CALCINE2.W01]
0.4	0.88	m5	14000. -0.376753 5010. -0.007986 5011. -0.032386
0.5	1.20	m5	11023. -0.029674 13027. -0.012173 19000. -0.000830
0.6	1.35	m6	8016. -0.540198 \$ 7740 PYREX Type I Glass [CALCINE1.W01]
0.7	1.48	m6	26000. -0.74 24000. -0.18 28000. -0.08 \$ SS 304L Flanges
0.8	1.62	m7	26000. -0.98 28000. -0.02 \$ Stainless Steel glovebox
0.9	1.55	m8	82000. -1.00 \$ Lead Glovebox Shield
1.0	1.28	m9	26000. -1 \$ SS 310S
1.1	1.34	m10	7014. -78084 8016. -0.20946 18000. -0.00934
1.2	1.45	m11	1001. -0.00036 \$ Air
1.3	1.63	m11	13027. -0.034 20000. -0.044 26000. -0.014
1.4	1.76	m12	1001. -0.00036 \$ Concrete (Common Portland) ARM-600 II.F. 1-3
1.5	1.80	m12	14000. -0.532 14000. -0.337
1.6	2.05	m12	1001. -0.0525 \$ Neutron
1.7	2.05	m12	1001. -0.0852 13027. -0.0101 8016. -0.0072 \$ Shield
1.8	2.28	m13	26000. -0.00338 13027. -0.0004 25055. -0.0002 \$ 210
1.9	2.37	m13	26000. -0.00338 13027. -0.0004 25055. -0.0002 \$ Neutron
2.0	2.49	m13	8016. -0.3649 6000. -0.0123 14000. -0.0009 \$ Shield
2.1	2.50		5010. -0.00784 20000. -0.00562 12000. -0.0006 \$ 207
2.2	2.61		11023. -0.0006 39089. -0.0005 26000. -0.0001
2.3	2.65		19000. -0.0001 16032. -0.0001 \$ Y89 substituted for Sr.
2.4	2.54		

```

m14 6000, -0.5999 8016, -0.3196 1001, -0.0805 $ Lucite
m15 6000, -0.44 1001, -0.07 8016, -0.29 $ LATEX 1.1 g/cm3
m16 6000, -0.33333 8016, 0.666667 $ Water Hanks (1.00 g/cm3)
c Photon dose conversion factors from ANS 6.1-1.1991
d60 Log 0.010 0.015 0.02 0.03 0.04 0.05
0.6 0.06 0.08 0.10 0.15 0.2 0.3
0.4 0.5 0.6 0.8 1.0 1.5
2.0 3.0 4.0 5.0 6.0 8.0
10.0 12.0
df0 Log 2.232e-05 5.652e-05 8.568e-05 1.184e-04 1.314e-04 1.382e-04
1.440e-04 1.624e-04 1.919e-04 2.797e-04 3.708e-04 5.616e-04
7.416e-04 9.144e-04 1.076e-03 1.379e-03 1.656e-03 2.246e-03
2.750e-03 3.672e-03 4.500e-03 5.292e-03 6.012e-03 7.488e-03
8.892e-03 1.040e-02
c Photon dose conversion factors from ANS 6.1-1.1977
d64 Log 0.01 0.02 0.03 0.04 0.05 0.06 0.07 0.1 0.15
0.2 0.3 0.4 0.5 0.6 0.7 0.8 1.0 1.5
0.6 0.9 0.55 0.40 0.35 0.45 0.70 0.80 1.0
1.00 1.40 1.80 2.20 2.60 3.20 4.25 5.00 5.25
3.25 3.75 4.25 4.75 5.00 5.25
5.75 6.25 6.75 7.50 9.00 11.00
13.00 15.00
df4 Log 3.606e-03 5.820e-04 2.900e-04 2.580e-04 2.830e-04 3.790e-04
5.010e-04 6.310e-04 7.590e-04 8.780e-04 9.850e-04 1.080e-03
1.170e-03 1.270e-03 1.360e-03 1.440e-03 1.520e-03 1.680e-03
1.980e-03 2.510e-03 2.990e-03 3.420e-03 3.820e-03 4.010e-03
4.410e-03 4.830e-03 5.230e-03 5.600e-03 5.800e-03 6.010e-03
6.370e-03 6.740e-03 7.110e-03 7.660e-03 8.770e-03 1.030e-02
1.180e-02 1.330e-02
5 dose in hands modeled by water 1 inch thick (Cell 5)
fc4 5
fc5 dose at 30 cm from outside surface of Receipt Can
Y Dist = 30.0 + 4.4038 = 29.8650 = 64.4488 cm
fc15 -168.5925 64.4488 93.10685 0
dose at 30 cm from outside surface of Glovebox
Y Dist = 30.0 + 83.5025 = 113.5025 cm
fc15:p -168.5925 113.5025 93.10685 0
fc25 dose at 5 feet from outside surface of Glovebox
Y Dist = 152.8 + 83.5025 = 235.9025 cm
fc25:p -168.5925 235.9025 93.10685 0
fc35 dose at 6 in. in front of lower n Shield
Total Dist from outside = 198.4375 - 6*2.54 = 183.1975 cm
fc35:p 0 183.1975 135.0 0
fc45 dose in middle of outer 3/4" PYREX n Shield
Total Dist from outside = (198.4375 + 200.3425)/2 = 199.3900 cm
fc45:p 0 199.3900 135.0 0
fc55 dose in middle of 1.0" n Shield
Total Dist from outside = (200.3425 + 202.8825)/2 = 201.6125 cm
fc55:p 0 201.6125 135.0 0
fc65 dose in middle of inner 3/4" PYREX n Shield
Total Dist from outside = (202.8825 + 204.7875)/2 = 203.8350 cm
fc65:p 0 203.8350 135.0 0
fc75 dose in middle of inside 1/4" n Shield
Total Dist from outside = (204.7875 + 205.4225)/2 = 205.1050 cm
fc75:p 0 205.1050 135.0 0
fc85 dose at 6 in. behind inside n Shield
Total Dist from outside = 205.4225 + 6*2.54 = 220.6225 cm
fc85:p 0 220.6225 135.0 0
fc95 dose at 6 in. in front of upper n Shield
Total Dist from outside = 198.4375 - 6*2.54 = 183.1975 cm
fc95:p 0 183.1975 200.0 0
fc105 dose in middle of outer 3/4" PYREX n Shield
Total Dist from outside = (198.4375 + 200.3425)/2 = 199.3900 cm
fc105:p 0 199.3900 200.0 0
fc115 dose in middle of 1.0" n Shield
Total Dist from outside = (200.3425 + 202.8825)/2 = 201.6125 cm
fc115:p 0 201.6125 200.0 0
fc125 dose in middle of inner 3/4" PYREX n Shield
Total Dist from outside = (202.8825 + 204.7875)/2 = 203.8350 cm
fc125:p 0 203.8350 200.0 0
fc135 dose in middle inside 1/4" n Shield
Total Dist from outside = (204.7875 + 205.4225)/2 = 205.1050 cm
fc135:p 0 205.1050 200.0 0
fc145 dose at 6 in. behind inside n Shield
Total Dist from outside = 205.4225 + 6*2.54 = 220.6225 cm
fc145:p 0 220.6225 200.0 0
print 10 110 120
ctne 90.0
nps 3.e6

```

APPENDIX E
MISCELLANEOUS REFERENCE PAGES

Calciner Shield Wall Specifications

7740 Corning Trademark PYREX⁵ Composition for Feed Tank Glass

Physical Properties Glass Composition of Code 7740 Glass

Physical Dimensions of Glass Pipe Straight Lengths

Plutonium Nitrate Feed material composition by Jerome F. Durnil

Material Data for Borated Polyethylene products 210, 207 by Scott Huneycutt

⁵PYREX is a registered trademark of the Corning Company.

This page intentionally left blank

Calcliner Shield Wall Specifications.

Scope

A shield wall will need to be constructed to minimize the dose from the calcliner components to the worker located at the calcliner control panel. The upper portion of this wall will need to be transparent for security purposes.

Design Criteria

The optimum design for a shield to reduce exposure from neutron radiation should consist of three layers. The first layer, the layer closest to the neutron source, should be a hydrogenous material to thermalize the neutron energy spectra. The second layer should be a Borated material to capture the thermal neutrons. The third layer, the layer most distant from the neutron source, should be a high Z material, such as steel or lead, to attenuate the gamma rays produced from the capture of the neutrons in the Borated material.

Note:

The suggested shield design is one possible configuration based on preliminary dose-rate calculations. Further analysis is being conducted.

Due to security and fire safety requirements, this shield wall will have a slightly different layer configuration.

Lower Portion (approximately 5 feet)

The first layer of the lower portion of the shield wall, the layer closest to the calcliner glovebox, should have a 19.0 mm ($\frac{3}{4}$ ") layer of 7740 PYREX® glass. The second layer should have a 25.4 mm (1 ") layer of Borated Polyethylene #210 which has a 30% Boron content. The third layer should be a 6.4 mm ($\frac{1}{4}$ ") layer of Stainless Steel.

Upper Portion (approximately 2 feet)

The first layer of the upper portion of the shield wall, the layer closest to the calcliner glovebox, should have a 19.0 mm ($\frac{3}{4}$ ") layer of 7740 PYREX® glass. The second layer should have a 25.4 mm (1 ") layer of clear Acrylic, Lexan, or Plexiglas. The third layer should be another layer of 19.0 mm ($\frac{3}{4}$ ") layer of 7740 PYREX® glass. A fourth layer will be required. The fourth layer should be a 6.4 mm ($\frac{1}{4}$ ") layer of 2.0 mm equivalent Leaded Glass.

These sandwiched materials will need to be fit together in a way that no two seams line-up to produce a gap in the shield.


Materials

Listed below are some possible Vendors, their contacts and latest cost estimate, for the required materials.

<u>Vendor</u>	<u>Thickness</u>	<u>Sheet size</u>	<u>Est. Price</u>
PYREX® 7740	19.0 mm	305 mm x 610 mm	255.00
ABRJSA Industrial Glass, Inc.	(0.75")	(12" x 24")	
John Kolinke		845 mm x 1150 mm	768.00
1456 Fleet Ave.		(33.25" x 45.25")	
PO Box 3053	[sheet edges are unfinished]		
Ventura, CA 93003	[comes in various thicknesses (3/32" to 2 1/4")]		
(800) 350-5000			
Borated Polyethylene	25.0 mm	610 mm x 610 mm	
Catalog # 210	(1.0")	(24" x 24")	
Reactor Experiments, Inc.		1219 mm x 1219 mm	
Dean White, ext. 352		(48" x 48")	
1275 Hammerwood Ave.			
Sunnyvale, CA 94088-2231			
(408) 745-6770			
Leaded Glass (= 2.0 mm Pb)	6.4 mm	305 mm x 305 mm	
Shielding International	(0.25")	(12" x 12")	
Bill Chisolm		to	
182 NW Earl Street		914 mm x 1220 mm	
PO Box Z		(36" x 48")	
Madras, OR 97741-0069			
(800) 292-2247			
Leaded Glass	6.4 mm		
Hot Cell Services	(0.25")		
22626 85 th Place South			
Kent, WA 98031			
Mike Caulkworth			
(206) 854-4945			

7740 Corning Trademark PYREX[®] Composition for Feed Tank Glass
<http://www.corninglabware.com/techpages/techpagenf6.html>
Warnings

1. Do not use in heat applications.


 Weight Loss (Borosilicate)
 Transmittance is Percent

 0.11 Transmittance
 Approx 1 mm thick

7740
 Corning Trademark:
 PYREX[®]

Common Names
 Borosilicate - Low Expansion - Type I Glass

Standards

Type I, Class A Borosilicate conforming to federal specification DD-G-54 1b and ASTM E-438. Also meets the U.S. Pharmacopoeia specs for Type I Borosilicate Glass.

Composition	(percent approx.)
SiO ₂	80.6%
B ₂ O ₃	13.0%
Na ₂ O	4.0%
Al ₂ O ₃	2.3%
Na ₂ O	0.1%

 $H_2O \rightarrow$
Properties

Coeff. of Exp.	32.5 3 1027cm/cm/°C
Strain Point	510°C
Anneal Point	560°C
Soften Point	821°C
Density	2.53 g/cm ³
Youngs Mod.	76 x 10 ³ Kg/mm ²
Refract. Index	1.474 @ Sodium D Line
Temp. Limits	490°C (Extreme Service) 230°C (Normal Service)
Max. Thermal Shock	160°C

2.23

Applications

Designed for use in all products requiring very high resistance to strong acids, alkalis and products intended for use in heat applications such as

⁶PYREX is a registered trademark of the Corning Company.

Physical Properties Glass Composition of Code 7740 Glass


BASIC ENGINEERING DATA

CHEMICAL PROPERTIES


Chemical Durability

All of Corning's piping systems are resistant to more acids and acidic materials than any other pipe.

By exception there are only these chemicals to avoid: hydrofluoric acid and hot alkalis. See the two graphs for more specific data. The graphs apply only to Corning's Code 7740 glass and show order-of-magnitude data, since operating conditions greatly affect performance.



Concentrated hydrofluoric acid attacks Code 7740 glass at all temperatures. Mild solutions dumped into drainlines can be tolerated at room temperatures.



Alkaline solutions attack glass very slowly at room temperatures, but as temperature is increased over 100°F, the corrosion rate rises rapidly.

PHYSICAL PROPERTIES

Glass Composition

Physical Properties Of Code 7740 Glass

4.04 wt% B

Mole %

B	9.39
Al	0.98
K	0.28
Na	33.23
Si	33.73
O	52.36
	100.01

Composition

Corning's code 7740 low-expansion borosilicate glass has the following approximate chemical composition:

SiO ₂	80.5%
Na ₂ O	4.0%
K ₂ O	0.5%
B ₂ O ₃	13.0%
Al ₂ O ₃	2.0%

For further details please refer to ASTM C 599, "Standard Specification for Process Glass Pipe and Fittings."

Linear Coefficient of Expansion:
(between 32°F and 572°F [0°C and 300°C], per ASTM Method E 228)

$$18.1 \times 10^{-7} \text{ in/in/}^{\circ}\text{F}$$

$$32.5 \times 10^{-7} \text{ cm/cm/}^{\circ}\text{C}$$

Annealing

All fittings and all straight lengths under 60" in length are annealed to reduce internal stress. This also makes the pipe under 60" easier to field fabricate.

Tempering

All pipe ends on lengths 60" and longer are tempered, the distance varying between 4" and 8" depending on the pipe system. The tempered area blends gradually into the center portion of the straight length. This is to permit pipe lengths to be cut in the central portion.

Thermal Conductivity:

$$0.73 \text{ Btu/hr-ft}^2 \cdot ^{\circ}\text{F/ft}$$

$$0.0035 \text{ cal/sec-cm}^2 \cdot ^{\circ}\text{C/cm}$$

Specific Heat:

$$0.20 \text{ Btu/lb} \cdot ^{\circ}\text{F}$$

$$0.20 \text{ cal/gm} \cdot ^{\circ}\text{C}$$

Dielectric Constant:

at 23°C and 1 M Hz, per ASTM Method D 150: 4.6 ± 0.2 .

Density:

Approximately 139 lb/ft³ (2.23 gm/cm³).

Young's Modulus:


per ASTM Method C215: in the range of 9×10^6 to 10×10^6 psi.

Physical Dimensions of Glass Pipe Straight Lengths

CONICAL SYSTEM

PYREXTM

PIPE



Straight Length

Pipe Size D	Pipe O.D. D_0	Cone O.D. D_1	Wall Thickness* d_1	Cone Angle A	Approx. Weight Per Foot
1" (25mm)	$1\frac{1}{16}" \pm .016"$ (33mm ± 0.4 mm)	$1\frac{1}{16}" \pm .016"$ (40mm ± 0.4 mm)	$\frac{5}{32}" \pm .016"$ (4.0mm ± 0.4 mm)	12°	0.6 lb (0.27 kg)
1½" (38mm)	$1\frac{7}{32}" \pm .020"$ (47mm ± 0.5 mm)	$2\frac{1}{8}" \pm .016"$ (54mm ± 0.4 mm)	$1\frac{1}{64}" \pm .016"$ (4.4mm ± 0.4 mm)	12°	1.0 lb (0.45 kg)
2" (51mm)	$2\frac{1}{32}" \pm .040"$ (60mm ± 1.0 mm)	$2\frac{5}{8}" \pm .020"$ (67mm ± 0.5 mm)	$1\frac{1}{64}" \pm .020"$ (4.4mm ± 0.5 mm)	12°	1.13 lb (0.51 kg)
3" (76mm)	$3\frac{13}{32}" \pm .056"$ (87mm ± 1.4 mm)	$3\frac{25}{32}" \pm .031"$ (96mm ± 0.8 mm)	$1\frac{3}{64}" \pm .021"$ (5.2mm ± 0.5 mm)	12°	2.0 lb (0.91 kg)
4" (102mm)	$4\frac{17}{32}" \pm .068"$ (115mm ± 1.7 mm)	$5\frac{29}{64}" \pm .016"$ (136mm ± 0.4 mm)	$1\frac{1}{64}" \pm .025"$ (6.7mm ± 0.6 mm)	21°	3.4 lb (1.5 kg)
6" (152mm)	$6\frac{7}{32}" \pm .075"$ (169mm ± 1.9 mm)	$7\frac{55}{32}" \pm .016"$ (192mm ± 0.4 mm)	$\frac{5}{16}" \pm .040"$ (7.9mm ± 1.0 mm)	21°	6.3 lb (2.9 kg)

Codes

Pipe Size	Minimum Length	6" L (152mm)	12" L (305mm)	18" L (457mm)	24" L (610mm)
1" (25mm)	3" (70mm)	72-1590	72-1550	72-7010	72-7020
1½" (38mm)	3½" (89mm)	72-1600	72-1560	72-7100	72-7105
2" (51mm)	4" (102mm)	72-1610	72-1570	72-7190	72-7195
3" (76mm)	5" (127mm)	72-1620	72-1580	72-7280	72-7285
4" (102mm)	6" (152mm)	72-2560	72-2560	72-7370	72-7375
6" (152mm)	6" (152mm)	72-2610	72-2610	72-1360	72-1365

Codes

Pipe Size	30" L (762mm)	36" L (914mm)	48" L (1219mm)	60" L (1524mm)	72" L (1829mm)	84" L (2134mm)	96" L (2438mm)	108" L (2743mm)	120" L (3048mm)
1" (25mm)	72-7540	72-7030	72-7040	72-7050	72-7500	72-7070	72-7510	72-7520	72-4500
1½" (38mm)	72-7530	72-7120	72-7130	72-7140	72-7501	72-7160	72-7511	72-7521	72-4510
2" (51mm)	72-7541	72-7210	72-7220	72-7230	72-7502	72-7250	72-7512	72-7522	72-4520
3" (76mm)	72-7542	72-7300	72-7310	72-7320	72-7503	72-7340	72-7513	72-7523	72-4530
4" (102mm)	72-7543	72-7390	72-7400	72-7410	72-7504	72-7430	72-7514	72-7524	72-4540
6" (152mm)	72-7544	72-1410	72-1430	72-1450	72-7505	72-1470	72-7515	72-7525	72-1490

Plutonium Nitrate Feed material composition by Jerome F. Durnil

Author: Jerome F (Jerry) Durnil at ~HANFORD03B
Date: 5/12/97 1:15 PM
Priority: Normal
TO: Scott E Huneycutt at ~HANFORD03D
TO: Warren D Wittekind at ~HANFORD02A
CC: Jerome F (Jerry) Durnil
Subject: Re: Plutonium Nitrate Feed material composition
----- Message Contents -----

Warren: See below.

Thanks
Jerry Durnil

Hi:

Unless there is an over-riding concern, I am going to use an assumed composition from "Calcination of Plutonium Nitrate Solution" by A.M. Stubbs, document number PFD-Z-300-001 Rev A-0.

The composition is in Table I Material Balance Flow Sheet Assumptions, page 15, which is:

250.00 gPu/L
509.37 gPu(NO₃)₄/L
441.07 gHNO₃/L
631.54 gH₂O/L
1,581.98 g/L TOTAL

OK? OK!

$SpG = 1 + 0.031*[H+ M] + 0.00138*[Pu \text{ g/L}]$

For VDC feed sol'n:

6 % 240, 250 g Pu/L, 4 M H+ (min)
12 % 240, 150 g Pu/L, 4 M H+ (min)
22.7 % 240, 190 g Pu/L, 2 M H+ (min)

Please page me at 85-3299 or call me at 373-2150 if you need additional info.

Thanks

Jerry Durnil

Material Data for Borated Polyethylene products 210, 207 by Scott Huneycutt

Author: Scott E Huneycutt at HANFORD03D
Date: 5/6/97 1:47 PM
Priority: Normal
TO: Warren D Wittekind at HANFORD02A
TO: Scott E Huneycutt
Subject: material data

----- Message Contents -----

Warren,

Here is a percent weight distribution of the elements in the 210 and 207 Borated Polyethylene products.

210	element	percent weight	density (g/cc)
	C	59.25	1.19
	B	30.0	
	H	8.54	
	Si	1.01	
	O	0.76	
	Fe	0.38	
	Al	0.04	
	Mn	0.02	
207	H	7.84	1.4
	B	0.70	
	C	34.39	
	Al	19.06	
	Ca	1.23	
	Fe	0.01	
	K	0.01	
	Mg	0.06	
	Na	0.06	
	O	36.49	
	S	0.01	
	Si	0.09	
	Sr	0.05	

I hope these are of value.

Scott

This page intentionally left blank

DISTRIBUTION SHEET

To	From	Page 1 of 1
Distribution	Criticality and Shielding	Date 07/17/97
Project Title/Work Order		EDT No. 620293
PFP Vertical Calciner Shield Wall Dose Rate Calculations Using MCNP		ECN No. N/A

Name	MSIN	Text With All Attach.	Text Only	Attach./ Appendix Only	EDT/ECN Only
G.G. Bergquist	T5-55	X			
E.P. Bonadie	T5-55	X			
K.D. Dobbin	H0-35	X			
D.G. Erickson	H0-35	X			
S.R. Gedeon	H0-35	X			
M.W. Gibson	T5-55	X			
J. Greenborg	H0-35	X			
K.E. Hillesland	H0-35	X			
S.E. Huneycutt	T5-57	X			
S.F. Kessler	H0-35	X			
C.M. Kronvall	T5-15	X			
J.S. Lan	H0-35	X			
W.S. Lewis	T5-55	X			
E.M. Miller	H0-35	X			
L.T. Nirider	T5-04	X			
S.E. Nunn	T5-11	X			
L.L. Pedersen (3)	H0-35	X			
A.L. Ramble	T5-54	X			
R.F. Richards	H0-35	X			
S.P. Roblyer	H0-35	X			
R.H. Ruben	H0-35	X			
K.N. Schwinkendorf	H0-35	X			
W.T. Watson	H0-31	X			
C.L. Whalen	H8-67	X			
W.D. Wittekind (2)	H0-35	X			
Central Files	A3-88	X			