

Sta 4. (2)
JUN 04 1997

ENGINEERING DATA TRANSMITTAL

Page 1 of 1

1. EDT

610295

2. To: (Receiving Organization) Operations and Project Safety Support				3. From: (Originating Organization) Tank Waste Operations Process Engineering				4. Related EDT No.: N/A			
5. Proj./Prog./Dept./Div.: Process Control/Process Engineering/Engineering and Safety/Tank Waste Operations				6. Design Authority/ Design Agent/Cog. Engr.: S.D. Estey				7. Purchase Order No.: N/A			
8. Originator Remarks: Calculation Note to support safety basis analyses for Project W-320, sluicing of tank 241-C-106.								9. Equip./Component No.: N/A			
								10. System/Bldg./Facility: N/A			
11. Receiver Remarks: 11A. Design Baseline Document? ☐ Yes ☒ No								12. Major Assm. Dwg. No.: N/A			
								13. Permit/Permit Application No.: N/A			
								14. Required Response Date: 6/02/97			

15. DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Designator	Reason for Transmittal	Originator Disposition	Receiver Disposition
1	HNF-SD-WM-CN-114		0	Calculation Note: Project W-320 Primary Ventilation Air Flow Requirements for Mitigation of Steady State Flammable Gas Concentrations in the Headspaces of Tanks 241-C-106 and 241-AY-102	N/A	2	1	6

16. KEY					
Approval Designator (F)		Reason for Transmittal (G)		Disposition (H) & (I)	
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)		1. Approval 2. Release 3. Information	4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)	1. Approved 2. Approved w/comment 3. Disapproved w/comment	4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)											
(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN
1	1	Cog.Eng. S.D. Estey	<i>S.D. Estey</i>	6/2/97	R2-11	1	1	S.A. Barker	<i>S.A. Barker</i>	6/3/97	R2-11
1	1	Cog. Mgr. N.W. Kirch	<i>N.W. Kirch</i>	6/2/97	R2-11	1	1	J.G. Kristofzski	<i>J.G. Kristofzski</i>	6/3/97	R2-12
		QA									
		Safety									
		Env.									

18. <i>S.D. Estey</i> 6/2/97 S.D. Estey Signature of EDT Originator		19. <i>N.W. Kirch</i> 6/4/97 R.G. Stickney Authorized Representative Date for Receiving Organization		20. <i>N.W. Kirch</i> 6/2/97 N.W. Kirch Design Authority/ Cognizant Manager		21. DOE APPROVAL (if required) Ctrl. No. ☐ Approved ☐ Approved w/comments ☐ Disapproved w/comments	
--	--	---	--	--	--	---	--

Calculation Note: Project W-320 Primary Ventilation Air Flow Requirements for Mitigation of Steady State Flammable Gas Concentrations in the Headspaces of Tanks 241-C-106 and 241-AY-102

S.D. Estey

Lockheed Martin Hanford Company, Richland, WA 99352
U.S. Department of Energy Contract DE-AC06-96RL13200

EDT/ECN: 610295

UC: 2070

Org Code: 74650

Charge Code: NB602

B&R Code: F2W3120074

Total Pages: 21


Key Words: Hydrogen, Flammable Gas, Headspace, Steady-State, Ventilation Rates, Response Times, LFL


Abstract: This Calculation Note analyzes the concentration of flammable gases in the headspaces of tanks 241-C-106 and 241-AY-102. Using measured and/or estimated hydrogen generation rates, the required minimum air flow rates and response times to a loss of ventilation condition are calculated. The conditions analyzed include: 1) tank 241-C-106 before sluicing, 2) tank 241-AY-102 before sluicing, and 3) tank 241-AY-102 after sluicing, assuming all of the waste contained in tank 241-C-106 has been transferred to it.

MathCad is a trademark of MathSoft

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: Document Control Services, P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.


Release Approval Date 6/4/97



Approved for Public Release

Author L. D. Estey Date 6/2/97 Checked by St. Bueh Date 6-2-97

Title:

Calculation Note: Project W-320 Primary Ventilation Air Flow Requirements for Mitigation of Steady State Flammable Gas Concentrations in the Headspaces of Tanks 241-C-106 and 241-AY-102.

Purpose:

This calculation note analyzes headspace concentrations of hydrogen dependent upon assumed ventilation flow rates provided for tanks 241-C-106 and 241-AY-102. The analyses are based on measured or estimated steady state hydrogen release rates. Tank 241-C-106 is analyzed prior to sluicing; tank 241-AY-102 is analyzed both prior to and after completion of sluicing. Specific analyses, using both best estimated and bounding hydrogen generation rates, include:

- 1) The minimum primary ventilation flow rates required in the tanks to ensure that the steady state hydrogen concentration in the respective tank headspace does not exceed 25% and 100% of the LFL.
- 2) The headspace hydrogen concentration as a function of time as well as the time required to reach 25% and 100% of LFL (i.e., the required response time) upon complete loss of active ventilation, starting from the steady state hydrogen concentration based on a 200 CFM minimum flow rate in tank 241-C-106 and a 100 CFM minimum flow rate in tank 241-AY-102.
- 3) The headspace hydrogen concentration as a function of time following partial loss of active ventilation (i.e., step changes to 160, 120, 80, and 40 CFM ventilation flow rates) in tank 241-C-106, starting from a 200 CFM flow rate and the corresponding steady state hydrogen concentration based on the 200 CFM flow rate.
- 4) The headspace hydrogen concentration as a function of time following partial loss of active ventilation (i.e., step changes to 80, 60, 40, and 20 CFM ventilation flow rates) in tank 241-AY-102, starting from a 100 CFM flow rate and the corresponding steady state hydrogen concentration based on the 100 CFM flow rate.

Methodology:

The calculations utilize referenced values of steady-state hydrogen release rates in both tanks. The calculations are performed and documented using Mathcad V6.0.

Once the total hydrogen generation rate is known for each of the tanks (gr), the required ventilation flow rate (vr) to control the gas concentration in the headspace equivalent to a specified steady state hydrogen concentration is the quantity (vr) such that the expression $100(gr/(gr+vr))$ equals the desired headspace hydrogen concentration measured in volume percent.

The transient response of hydrogen concentration in the tank headspace to a step change in ventilation flow rate is also calculated using the determined hydrogen generation rate for each tank, an initial tank ventilation rate, the tank headspace volume, and the initial tank headspace hydrogen concentration.

Author L.D. Estey Date 4/2/97 Checked by SA Baker Date 6-2-97

Assumptions:

- The hydrogen generation rates in the tanks are 20 SCFD best estimate and 45 SCFD bounding value for tank 241-C-106 before sluicing; 51 SCFD best estimate and 60 SCFD bounding value for tank 241-AY-102 before sluicing; 71 SCFD best estimate and 105 SCFD bounding value for tank 241-AY-102 after sluicing.
- The models for the headspace hydrogen concentrations are mathematical constructs needing no assumptions other than complete, instantaneous mixing of hydrogen in the tank headspace.
- The assumed minimum active ventilation flow rate is 200 CFM in tank 241-C-106, 100 CFM in tank 241-AY-102.
- The headspace volume of tank 241-C-106 is assumed as 95,000 ft³ before sluicing. The headspace volume of tank 241-AY-102 is assumed as 33,000 ft³ both before and after sluicing. Both values are referenced.
- When active ventilation is occurring in a tank, the contribution of passive ventilation to the total ventilation rate is assumed to be negligible.
- The passive ventilation rate in the tanks is assumed as a referenced value of 0.45 volume percent turnover per day.
- The assumed composition of gases generated in the tanks cause the LFL to occur at 2.5 volume % hydrogen, and 25% LFL to occur at 0.625 volume % hydrogen.

Author L. D. Estey Date 6/2/97 Checked by SA Barker Date 6-2-97

Input Data:

cases evaluated:

$n := 1..6$

n

1
2
3
4
5
6

$n = 1$ corresponds to tank C-106 pre-sludging best estimate
 $n = 2$ corresponds to tank C-106 pre-sludging bounding value
 $n = 3$ corresponds to tank AY-102 pre-sludging best estimate
 $n = 4$ corresponds to tank AY-102 pre-sludging bounding value
 $n = 5$ corresponds to tank AY-102 post-sludging best estimate
 $n = 6$ corresponds to tank AY-102 post-sludging bounding value

hydrogen generation rate:

n

1
2
3
4
5
6

$gr_n :=$

$20 \cdot \text{ft}^3 \cdot \text{day}^{-1}$
$45 \cdot \text{ft}^3 \cdot \text{day}^{-1}$
$51 \cdot \text{ft}^3 \cdot \text{day}^{-1}$
$60 \cdot \text{ft}^3 \cdot \text{day}^{-1}$
$71 \cdot \text{ft}^3 \cdot \text{day}^{-1}$
$105 \cdot \text{ft}^3 \cdot \text{day}^{-1}$

Reference:

- 1 (Pasamehmetoglu 1997)
- 2 (Pasamehmetoglu 1997)
- 3 (LANL estimate from SHMS data)
- 4 (LANL estimate from SHMS data)
- 5 sum of 1 & 3
- 6 sum of 2 & 4

tank ventilation rates:

n

1
2
3
4
5
6

$vr_n :=$

$200 \cdot \text{ft}^3 \cdot \text{min}^{-1}$
$200 \cdot \text{ft}^3 \cdot \text{min}^{-1}$
$100 \cdot \text{ft}^3 \cdot \text{min}^{-1}$
$100 \cdot \text{ft}^3 \cdot \text{min}^{-1}$
$100 \cdot \text{ft}^3 \cdot \text{min}^{-1}$
$100 \cdot \text{ft}^3 \cdot \text{min}^{-1}$

Reference:

- 1 (assumption)
- 2 (assumption)
- 3 (Estey 1997)
- 4 (Estey 1997)
- 5 (Estey 1997)
- 6 (Estey 1997)

Author L.O. Estey Date 6/2/97 Checked by SA Bunker Date 6-2-97

tank headspace volumes:

n	vol _n :=
1	95000·ft ³
2	95000·ft ³
3	33000·ft ³
4	33000·ft ³
5	33000·ft ³
6	33000·ft ³

Reference:

- 1 (Pasamehmetoglu 1997)
- 2 (Pasamehmetoglu 1997)
- 3 (Estey 1997)
- 4 (Estey 1997)
- 5 (Estey 1997)
- 6 (Estey 1997)

Calculations

Derivation of ventilation equations

$$\begin{aligned}
 gr &= \text{tank H}_2 \text{ generation rate} & \text{volH}_2 &= \text{H}_2 \text{ volume} & \% \text{H}_2 &= 100 \cdot \frac{\text{volH}_2}{\text{vol}} \\
 vr &= \text{tank ventilation rate} & \text{volH}_2 &= \text{initial H}_2 \text{ volume} \\
 \text{vol} &= \text{tank headspace volume} & \text{volH}_2 &= \text{current H}_2 \text{ volume}
 \end{aligned}$$

The rate of change of hydrogen volume in a tank headspace equals the volumetric hydrogen generation rate [gr] minus the volumetric hydrogen loss rate [volumetric flow rate exiting the tank (i.e., gr + vr) times the volume percent hydrogen in exhaust air (i.e., volH₂/vol)].

$$\frac{d(\text{volH}_2)}{dt} = (\text{H}_2 \text{ generation rate} - \text{H}_2 \text{ loss rate}) = \left[gr - (gr + vr) \cdot \frac{\% \text{H}_2}{100} \right] = \left[gr - (gr + vr) \cdot \frac{\text{volH}_2}{\text{vol}} \right]$$

$$\frac{d(\text{volH}_2)}{dt} = \left[gr - (gr + vr) \cdot \frac{\text{volH}_2}{\text{vol}} \right]$$

Separating the variables,

$$dt = \frac{d(\text{volH}_2)}{\left[gr - (gr + vr) \cdot \frac{\text{volH}_2}{\text{vol}} \right]} = \frac{d(\text{volH}_2)}{\left[gr - \left(\frac{gr + vr}{\text{vol}} \right) \cdot \text{volH}_2 \right]}$$

Factoring the equation by the differential of the volH₂ term,

$$- \left(\frac{gr + vr}{\text{vol}} \right) dt = \frac{- \left(\frac{gr + vr}{\text{vol}} \right) \cdot d(\text{volH}_2)}{\left[gr - \left(\frac{gr + vr}{\text{vol}} \right) \cdot \text{volH}_2 \right]}$$

Author L. D. Estey Date 6/6/97 Checked by SA Barber Date 6-2-97

Integrating the equation and evaluating between the limits of time = 0 to time = t, and volH2i to volH2t = volH2t,

$$\int_0^t - \left(\frac{gr + vr}{vol} \right) dt = \int_{volH2_i}^{volH2_t} \frac{- \left(\frac{gr + vr}{vol} \right)}{\left[gr - \left(\frac{gr + vr}{vol} \right) \cdot volH2 \right]} d(volH2)$$

$$- \left(\frac{gr + vr}{vol} \right) \cdot t = \ln \left[gr - \left(\frac{gr + vr}{vol} \right) \cdot volH2_t \right] - \ln \left[gr - \left(\frac{gr + vr}{vol} \right) \cdot volH2_i \right]$$

Solving for time (t) as a function of the current volume of hydrogen contained in the tank headspace, (volH2t),

$$t = \left(\frac{vol}{gr + vr} \right) \cdot \left[\ln \left[gr - \left(\frac{gr + vr}{vol} \right) \cdot volH2_t \right] - \ln \left[gr - \left(\frac{gr + vr}{vol} \right) \cdot volH2_i \right] \right]$$

$$t = \left(\frac{vol}{gr + vr} \right) \cdot \left[\ln \left[\frac{gr - \left(\frac{gr + vr}{vol} \right) \cdot volH2_t}{gr - \left(\frac{gr + vr}{vol} \right) \cdot volH2_i} \right] \right]$$

Solving for the current concentration of hydrogen contained in the tank headspace, (volH2t/vol), as a function of time t,

$$\ln \left[gr - \left(\frac{gr + vr}{vol} \right) \cdot volH2_t \right] = \ln \left[gr - \left(\frac{gr + vr}{vol} \right) \cdot volH2_i \right] - \left(\frac{gr + vr}{vol} \right) \cdot t$$

$$\left[gr - \left(\frac{gr + vr}{vol} \right) \cdot volH2_t \right] = \left[gr - \left(\frac{gr + vr}{vol} \right) \cdot volH2_i \right] \cdot \exp \left[- \left(\frac{gr + vr}{vol} \right) \cdot t \right]$$

$$\left(\frac{gr + vr}{vol} \right) \cdot volH2_t = gr - \left[gr - \left(\frac{gr + vr}{vol} \right) \cdot volH2_i \right] \cdot \exp \left[- \left(\frac{gr + vr}{vol} \right) \cdot t \right]$$

$$(gr + vr) \cdot \frac{volH2_t}{vol} = gr - \left[gr - \left(\frac{gr + vr}{vol} \right) \cdot volH2_i \right] \cdot \exp \left[- \left(\frac{gr + vr}{vol} \right) \cdot t \right]$$

$$\frac{volH2_t}{vol} = \%H2_t = \frac{gr - \left[gr - \left(\frac{gr + vr}{vol} \right) \cdot volH2_i \right] \cdot \exp \left[- \left(\frac{gr + vr}{vol} \right) \cdot t \right]}{(gr + vr)}$$

Author S.D. Ertley Date 6/2/97 Checked by SA Barber Date 6-2-97

At steady state (equivalent to $t = \infty$), the exponential term drops out and,

$$\frac{\text{volH2}_t}{\text{vol}} = \frac{\%H2_t}{100} = \left(\frac{\text{gr}}{\text{gr} + \text{vr}} \right)$$

Required tank ventilation rate to maintain steady state hydrogen concentration:

$$\text{vr} = 100 \cdot \left(\frac{\text{gr}}{\%H2_t} \right) - \text{gr}$$

Required ventilation rate (m^3 per second; CFM) to keep tank headspace concentration below 100% LFL (equivalent to 2.5% hydrogen):

$$\text{vrfl}_n := 100 \cdot \left(\frac{\text{gr}_n}{2.5} \right) - \text{gr}_n$$

n	vrfl_n $\left(\frac{\text{m}^3}{\text{sec}} \right)$	vrfl_n $\left(\frac{\text{ft}^3}{\text{min}} \right)$
1	$2.556 \cdot 10^{-4}$	0.542
2	$5.752 \cdot 10^{-4}$	1.219
3	$6.519 \cdot 10^{-4}$	1.381
4	$6.519 \cdot 10^{-4}$	1.625
5	$7.669 \cdot 10^{-4}$	1.923
6	$9.075 \cdot 10^{-4}$	2.844
	$1.342 \cdot 10^{-3}$	

Required ventilation rate (m^3 per second; CFM) to keep tank headspace concentration below 25% LFL (equivalent to 0.625% hydrogen):

$$\text{vr25}_n := 100 \cdot \left(\frac{\text{gr}_n}{0.625} \right) - \text{gr}_n$$

n	vr25_n $\left(\frac{\text{m}^3}{\text{sec}} \right)$	vr25_n $\left(\frac{\text{ft}^3}{\text{min}} \right)$
1	$1.042 \cdot 10^{-3}$	2.208
2	$2.345 \cdot 10^{-3}$	4.969
3	$2.658 \cdot 10^{-3}$	5.631
4	$2.658 \cdot 10^{-3}$	6.625
5	$3.127 \cdot 10^{-3}$	7.84
6	$3.7 \cdot 10^{-3}$	11.594
	$5.472 \cdot 10^{-3}$	

Author L. W. Cetty Date 6/2/97 Checked by SA Burke Date 6-2-97

Determine the steady state hydrogen concentration (% hydrogen) in the tank headspace at the minimum per tank W-030 ventilation flow rate of 200 CFM for tank 241-C-106 and 100 CFM for tank 241-AY-102:

$$\%H_{2i_n} := 100 \cdot \left(\frac{gr_n}{gr_n + vr_n} \right)$$

n	$\%H_{2i_n}$
1	0.0069
2	0.0156
3	0.0354
4	0.0416
5	0.0493
6	0.0729

Natural ventilation flow rate in tanks 241-C-106 and 241-AY-102 (m³ per second; CFM):

$$vr_{passive_n} := 0.0045 \cdot \frac{vol_n}{day}$$

Reference: (Crippen 1993)

n	$vr_{passive_n}$ $\left(\frac{m^3}{sec} \right)$	$vr_{passive_n}$ $\left(\frac{ft^3}{min} \right)$
1	$1.401 \cdot 10^{-4}$	0.297
2	$1.401 \cdot 10^{-4}$	0.297
3	$4.867 \cdot 10^{-5}$	0.103
4	$4.867 \cdot 10^{-5}$	0.103
5	$4.867 \cdot 10^{-5}$	0.103
6	$4.867 \cdot 10^{-5}$	0.103

Author L. D. Estey Date 6/2/97 Checked by SA Baker Date 6-2-97

Determine the time to exceed 25% LFL (equivalent to 0.625% hydrogen) upon complete loss of active ventilation (seconds; days):

$$t_{25_n} := - \left(\frac{\text{vol}_n}{gr_n + vr_{\text{passive}_n}} \right) \cdot \ln \left[\frac{gr_n - \left(\frac{gr_n + vr_{\text{passive}_n}}{\text{vol}_n} \right) \cdot \frac{0.625 \cdot \text{vol}_n}{100}}{gr_n - \left(\frac{gr_n + vr_{\text{passive}_n}}{\text{vol}_n} \right) \cdot \frac{\%H_{2i_n} \cdot \text{vol}_n}{100}} \right]$$

n	t_{25_n} (sec)	t_{25_n} (day)
1	$2.735 \cdot 10^6$	31.65
2	$1.151 \cdot 10^6$	13.317
3	$3.339 \cdot 10^5$	3.865
4	$2.805 \cdot 10^5$	3.246
5	$2.336 \cdot 10^5$	2.704
6	$1.512 \cdot 10^5$	1.75

Determine the time to exceed 100% LFL (equivalent to 2.5% hydrogen) upon complete loss of active ventilation (seconds; days):

$$t_{100_n} := - \left(\frac{\text{vol}_n}{gr_n + vr_{\text{passive}_n}} \right) \cdot \ln \left[\frac{gr_n - \left(\frac{gr_n + vr_{\text{passive}_n}}{\text{vol}_n} \right) \cdot \frac{2.5 \cdot \text{vol}_n}{100}}{gr_n - \left(\frac{gr_n + vr_{\text{passive}_n}}{\text{vol}_n} \right) \cdot \frac{\%H_{2i_n} \cdot \text{vol}_n}{100}} \right]$$

n	t_{100_n} (sec)	t_{100_n} (day)
1	$1.5 \cdot 10^7$	173.655
2	$5.261 \cdot 10^6$	60.89
3	$1.451 \cdot 10^6$	16.794
4	$1.223 \cdot 10^6$	14.155
5	$1.025 \cdot 10^6$	11.864
6	$6.804 \cdot 10^5$	7.875

Author L. D. Estey Date 4/2/97 Checked by M. Barker Date 6-2-97

Resulting hydrogen concentration (volume percent) in tank headspace upon total loss of active ventilation as a function of time (days):

$t_{narrow} := 0..20$

$$\%H_{2_{n,t_{narrow}}} := 100 \cdot \frac{gr_n - \left[gr_n - \left(\frac{gr_n + vr_{passive_n}}{vol_n} \right) \cdot \frac{\%H_{2i_n} \cdot vol_n}{100} \right] \cdot \exp \left[- \left(\frac{gr_n + vr_{passive_n}}{vol_n} \cdot t_{narrow} \cdot \text{day} \right) \right]}{(gr_n + vr_{passive_n})}$$

$t_{twide} := 0, 20..1000$

$$\%H_{2_{n,t_{twide}}} := 100 \cdot \frac{gr_n - \left[gr_n - \left(\frac{gr_n + vr_{passive_n}}{vol_n} \right) \cdot \frac{\%H_{2i_n} \cdot vol_n}{100} \right] \cdot \exp \left[- \left(\frac{gr_n + vr_{passive_n}}{vol_n} \cdot t_{twide} \cdot \text{day} \right) \right]}{(gr_n + vr_{passive_n})}$$

Determine the response of hydrogen concentration (volume percent) in tank headspace upon partial loss of active ventilation as a function of time (hours) and the reduced ventilation flow rate:

$t_{hours} := 0, 6..240$

$p := 1..5$

$vr_p := p \cdot 20 \cdot \text{ft}^3 \cdot \text{min}^{-1}$

$$C106pre\%H_{2_{p,t_{hours}}} := 100 \cdot \frac{gr_2 - \left[gr_2 - \left(\frac{gr_1 + 2 \cdot vr_p}{vol_2} \right) \cdot \frac{\%H_{2i_2} \cdot vol_2}{100} \right] \cdot \exp \left[- \left(\frac{gr_2 + 2 \cdot vr_p}{vol_2} \right) \cdot t_{hours} \cdot \text{hr} \right]}{(gr_2 + 2 \cdot vr_p)}$$

$$AY102pre\%H_{2_{p,t_{hours}}} := 100 \cdot \frac{gr_4 - \left[gr_4 - \left(\frac{gr_4 + vr_p}{vol_4} \right) \cdot \frac{\%H_{2i_4} \cdot vol_4}{100} \right] \cdot \exp \left[- \left(\frac{gr_4 + vr_p}{vol_4} \right) \cdot t_{hours} \cdot \text{hr} \right]}{(gr_4 + vr_p)}$$

$$AY102post\%H_{2_{p,t_{hours}}} := 100 \cdot \frac{gr_6 - \left[gr_6 - \left(\frac{gr_6 + vr_p}{vol_6} \right) \cdot \frac{\%H_{2i_6} \cdot vol_6}{100} \right] \cdot \exp \left[- \left(\frac{gr_6 + vr_p}{vol_6} \right) \cdot t_{hours} \cdot \text{hr} \right]}{(gr_6 + vr_p)}$$

Author

L.D. Estey

Date

6/2/97


Checked by

St. Burdon

Date

6-2-97

Tank [H2] Upon Active Ventilation Loss



- x- C-106 pre-slucing best estimate
- o- C-106 pre-slucing bounding value
- x- A.Y-102 pre-slucing best estimate
- o- A.Y-102 pre-slucing bounding value
- x- A.Y-102 post-slucing best estimate
- o- A.Y-102 post-slucing bounding value

Author

L. O. Estey

Date

4/2/97


Checked by

S. A. Becker

Date


6-2-97

Tank [H2] Upon Active Ventilation Loss




- x- C-106 pre-slucing best estimate
- o- C-106 pre-slucing maximum value
- x- AY-102 pre-slucing best estimate
- o- AY-102 pre-slucing maximum value
- x- AY-102 post-slucing best estimate
- o- AY-102 post-slucing maximum value


Author L. D. Early Date 6/2/97 Checked by M. Barker Date 6-2-97



Author L. D. Estay Date 6/2/97 Checked by SA Baker Date 6-2-97



Author S. D. Estey Date 6/2/97 Checked by SA Beshar Date 6-2-97



Author S. D. Estey Date 6/2/97 Checked by St. Burt Date 6-2-97

Results:

1) The minimum primary ventilation flow rates required to ensure that the tank headspaces do not reach 25% and 100% of the LFL are shown on page 6.

2) Following complete loss of forced ventilation, the headspace hydrogen concentration as a function of time, and the times to reach 25% and 100% of the LFL, are shown on pages 10 & 11, and page 8, respectively.

3 & 4) Headspace hydrogen concentrations following various partial losses of forced ventilation are shown as a function of time, using the bounding hydrogen generation rates, on pages 12 and 13 for tank 241-C-106, and on page 14 for tank 241-AY-102.

The results show that the hydrogen generation rates in the tanks utilized by Project W-320 are low enough that only a very small ventilation rate is needed to ensure that a steady state release of gas with the assumed composition will not result in a uniform tank headspace fuel loading exceed 25% of the LFL. A ventilation flow rate of 100 CFM is calculated to be roughly an order of magnitude greater than the flow rate required to satisfy the <25% LFL criteria for these tanks at any of the analyzed conditions. The flammable limits would become a concern in the tank headspaces following complete loss of forced ventilation. In all cases, the requirement to remain < 25% LFL cannot be met by passive ventilation alone. As a rough order of magnitude estimate, using bounding hydrogen generation rates, the < 25% LFL limit would be reached at 1.75 days for tank 241-AY-102 in its limiting waste condition, and at 13.3 days for tank 241-C-106 in its initial condition. If an extended loss of forced ventilation were long enough, the tank headspaces would eventually exceed the LFL in all the analyzed conditions.

Conclusions:

A 100 CFM primary ventilation flow rate is sufficient to prevent the formation of a uniformly flammable tank headspace composition in the tanks utilized by Project W-320, even if all the waste resides in tank 241-AY-102. However, using bounding hydrogen generation rates, if forced ventilation were completely lost on these tanks, the 0.625 percent hydrogen control limit is predicted to occur at 1.75 days for tank 241-AY-102 in its limiting condition (i.e., following complete retrieval of tank 241-C-106 wastes), and at 13.3 days for tank 241-C-106 in its initial condition.

References:

Estey, S.D., 1997, "Calculation Note: AY/AZ Waste Tank Primary Ventilation Requirements for Mitigation of Steady State Flammable Gas Concentrations in the Tank Headspace," HNF-SD-WM-CN-106, Rev. 0, Lockheed Martin Hanford Company, Richland, Washington.

Pasamehmetoglu, K.O., W. L. Kubic, Jr., P. Sadasivan, 1997, "DISCUSSION OF FLAMMABLE GAS ISSUES FOR PROJECT W-320", LA-UR-97-1330, Rev. 0, Los Alamos National Laboratory, Los Alamos, New Mexico.

Crippen, M.D., 1993, "Barometric Pressure Variations," WHC-EP-0651, Westinghouse Hanford Company, Richland, Washington.


CHECKLIST FOR PEER REVIEW

Document Reviewed: HNF-SD-WM-CN-114, Rev. 0

Scope of Review:

Yes No NA

- ☐ ☐ ☐ ☒ * Previous reviews complete and cover analysis, up to scope of this review, with no gaps.
- ☒ ☐ ☐ ☐ Problem completely defined.
- ☐ ☐ ☐ ☒ Accident scenarios developed in a clear and logical manner.
- ☒ ☐ ☐ ☐ Necessary assumptions explicitly stated and supported.
- ☒ ☐ ☐ ☐ Computer codes and data files documented.
- ☒ ☐ ☐ ☐ Data used in calculations explicitly stated in document.
- ☒ ☐ ☐ ☐ Data checked for consistency with original source information as applicable.
- ☒ ☐ ☐ ☐ Mathematical derivations checked including dimensional consistency of results.
- ☒ ☐ ☐ ☐ Models appropriate and used within range of validity or use outside range of established validity justified.
- ☒ ☐ ☐ ☐ Hand calculations checked for errors. Spreadsheet results should be treated exactly the same as hand calculations.
- ☒ ☐ ☐ ☐ Software input correct and consistent with document reviewed.
- ☒ ☐ ☐ ☐ Software output consistent with input and with results reported in document reviewed.
- ☒ ☐ ☐ ☐ Limits/criteria/guidelines applied to analysis results are appropriate and referenced. Limits/criteria/guidelines checked against references.
- ☒ ☐ ☐ ☐ Safety margins consistent with good engineering practices.
- ☒ ☐ ☐ ☐ Conclusions consistent with analytical results and applicable limits.
- ☒ ☐ ☐ ☐ Results and conclusions address all points required in the problem statement.
- ☐ ☐ ☐ ☒ Format consistent with appropriate NRC Regulatory Guide or other standards
- ☒ ☐ ☐ ☐ Review calculations, comments, and/or notes are attached.
- ☒ ☐ ☐ ☐ **Document approved.**

S. A. Barker / 
 Reviewer (Printed Name and Signature)

6-2-97
 Date

* Any calculations, comments, or notes generated as part of this review should be signed, dated and attached to this checklist. Such material should be labeled and recorded in such a manner as to be intelligible to a technically qualified third party.

		B	C	D	E	F	G	H	I	J	K	L
2	Check of Calc Note: HNF-SD-WM-CON-114 Rev 0.											
3												
4												
5												
6												
7	Tank											
8	Conversion factor - days to second	86400									conv_day_sec	ovdaysec
9	Conversion factor - liters to meter^3	0.001									conv_L_m3	ovm3
10	Conversion factor - feet to meter	0.3048									conv_ft_m	ovftm
11	Conversion factor - gallons to meter^3	0.00379									conv_gal_m3	ovgalm3
12	Conversion factor - Bu to joules	1.05506									conv_btu_joules	ovbtujoules
13	Conversion factor - m^3/sec to ft^3/min	2,118.88									conv_m3s_ftm3m	ovm3sftm
14	Volume headspace	95,000	95,000	33,000	33,000	33,000	33,000	33,000	Given		vol	
15	Hydrogen generation rate total	20	45	51	60	71	105	Given			gr	
16	Hydrogen generation rate total	6.55E-05	1.47E-05	1.07E-05	1.97E-05	2.33E-05	3.44E-05	+113 * (SD5893) / SD586			gr	
17	Hydrogen generation rate total	200	200	100	100	100	100	Given			vr	
18	Hydrogen generation rate total	9.44E-02	9.44E-02	4.72E-02	4.72E-02	4.72E-02	4.72E-02	+115 * (SD5893) / SD586			vr	
19	Hydrogen generation rate total	2.595E-04	5.752E-04	6.519E-04	7.699E-04	9.075E-04	1.342E-03	100 * (1425 - 114) / (1425 - 114)			vr	
20	Hydrogen generation rate total	0.542	1.219	1.381	1.623	1.923	2.844	+117 * S430511.S430511			vr	
21	Hydrogen generation rate total	1.042E-03	2.345E-03	2.653E-03	3.127E-03	3.700E-03	5.472E-03	100 * (1425 - 114) / (1425 - 114)			vr	
22	Hydrogen generation rate total	0.0039	0.0166	0.0354	0.0632	0.0862	0.129	+119 * S30311.S30311			vr	
23	Natural Ventilation Flow Rate (No Connection)	0.0045	0.0166	0.0354	0.0632	0.0862	0.129	+119 * (115 + 115 * 24 * 60) / 100			vr_passiveV	
24	Natural Ventilation Flow Rate (No Connection)	1.401E-14	1.401E-14	4.867E-05	4.867E-05	4.867E-05	4.867E-05	S3262 * (12 * S50311) / 24 / 60			vr_passiveE	
25	Time to exceed 25% LFL, loss of ventilation	31.650	13,317	3,865	3,246	2,704	1,750	0.0233 * (114 + 123) * 0.625 / 100 / (114 - (114 + 123) * 0.625 / 100) * (114 + 123) * 0.625 / 100			125	
26	Time to exceed 25% LFL, loss of ventilation	2.755E-06	1.151E-06	3.339E-05	2.805E-05	2.336E-05	1.512E-05	+123 * S3058			125	
27	Time to exceed 100% LFL, loss of ventilation	173,655	60,890	16,794	14,155	11,854	7,675	0.0233 * (114 + 123) * 2.5 / 100 / (114 - (114 + 123) * 2.5 / 100) * (114 + 123) * 2.5 / 100			100	
28	Time to exceed 8% H ₂ , loss of ventilation	1.500E-07	5.261E-06	1.451E-06	1.223E-06	1.025E-06	6.804E-05	+427 * S3058			15	
29												
30	H ₂ concentration - loss of vent											
31	1time=1 day	0.02791	0.06260	0.18927	0.22263	0.26339	0.38927	(S13 * (S13 - (S13 + S24 * 60 * 24) * S21 / 100) * (S13 + S24 * 60 * 24) * S21 / 100) * (S13 + S24 * 60 * 24) * S21 / 100			%H2_innarrow	
32	2time=2 day	0.048379	0.10974	0.34221	0.40247	0.47608	0.70323	(S13 * (S13 - (S13 + S24 * 60 * 24) * S21 / 100) * (S13 + S24 * 60 * 24) * S21 / 100) * (S13 + S24 * 60 * 24) * S21 / 100			%H2_innarrow	
33	4time=4 day	0.050024	0.20292	0.64533	0.75877	0.89725	1.32403	(S13 * (S13 - (S13 + S24 * 60 * 24) * S21 / 100) * (S13 + S24 * 60 * 24) * S21 / 100) * (S13 + S24 * 60 * 24) * S21 / 100			%H2_innarrow	
34	6time=6 day	0.13130	0.29517	0.94480	1.11059	1.31284	1.93534	(S13 * (S13 - (S13 + S24 * 60 * 24) * S21 / 100) * (S13 + S24 * 60 * 24) * S21 / 100) * (S13 + S24 * 60 * 24) * S21 / 100			%H2_innarrow	

B																J	K	L								
2 Check of Calc Note: HNF-SD-WM-CN-114 Rev.0.																I	H	G	F	E	D	C	B	A		
3 Tank																6	5	4	3	2	1					
4																AY102-After	AY102-After	AY102-After	AY102-After	AY102-After	AY102-After	AY102-After	AY102-After	AY102-After	AY102-After	
5																Bounding	Best Est	Bounding	Best Est	Bounding	Best Est	Bounding	Best Est	Bounding	Best Est	
6																Variable	Name									
35 time=8 day																100*((IS13-(IS13+(IS24*60*24)*	IS21/100)*ES24-(IS13+IS24*60*24)/	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)
36 time=10 day																2.53734	1.72295	1.45799	1.24067	0.38652	0.17197	0.38652	1.24067	1.45799	1.72295	
37 time=15 day																3.13015	2.12763	1.80103	1.53239	0.47696	0.21227	0.47696	1.53239	1.80103	2.12763	
38 time=20 day																4.57295	3.11610	2.63991	2.24851	0.69917	0.31136	0.69917	2.24851	2.63991	3.11610	
39 time=100 day																5.96138	4.07224	3.45270	2.94273	0.91592	0.40815	0.91592	2.94273	3.45270	4.07224	
40 time=1000 day																22.24096	15.73929	13.50058	11.61711	3.74161	1.68324	3.74161	11.61711	13.50058	15.73929	
41 H2 concentration - loss of ventilation																41.40105	32.30451	28.72516	25.50344	9.49804	4.42911	9.49804	25.50344	28.72516	32.30451	
42 vent rate =																20	20	20	40	40	40	40	40	40	40	
43																										
44 time = 6 hours																100*((IS13-(IS13+(IS24*60*24)*	IS21/100)*ES24-(IS13+IS24*60*24)/	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)
45 time = 30 hours																0.12997	0.07430	0.07430	0.02441	0.02441	0.02441	0.02441	0.02441	0.02441	0.02441	0.02441
46 time = 90 hours																100*((IS13-(IS13+(IS24*60*24)*	IS21/100)*ES24-(IS13+IS24*60*24)/	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)
47 time = 120 hours																0.26610	0.15218	0.15218	0.04882	0.04882	0.04882	0.04882	0.04882	0.04882	0.04882	0.04882
48 time = 240 hours																0.35238	0.20164	0.20164	0.07165	0.07165	0.07165	0.07165	0.07165	0.07165	0.07165	0.07165
49 time = 240 hours																100*((IS13-(IS13+(IS24*60*24)*	IS21/100)*ES24-(IS13+IS24*60*24)/	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)
50 vent rate =																0.35962	0.20787	0.20787	0.07792	0.07792	0.07792	0.07792	0.07792	0.07792	0.07792	0.07792
51 time = 3 hours																100*((IS13-(IS13+(IS24*60*24)*	IS21/100)*ES24-(IS13+IS24*60*24)/	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)	IS21/100)
52																0.36321	40	40	0.06374	0.06374	0.06374	0.06374	0.06374	0.06374	0.06374	0.06374
53																										
54																										
55																										
56																										
57																										
58																										
59																										
60																										
61																										
62																										
63																										
64																										
65																										
66																										
67																										
68																										
69																										
70																										
71																										
72																										
73																										
74																										
75																										
76																										
77																										
78																										
79																										
80																										
81																										
82																										
83																										
84																										
85																										
86																										
87																										
88																										
89																										
90																										
91																										
92																										
93																										
94																										
95																										
96																										
97																										
98																										
99																										
100																										

CN114

B										J	K	L
2	Check of Calc Note: HNF-SD-WM-CN-114 Rev 0.	C	D	E	F	G	H	I	6			
3	Tank		1	2	3	4	5		AY102-After		Variable	Range
4			C-106	C-106	Best Est	Best Est	Best Est	Bounding	Formula		Name	Name
5			Best Est	Bounding					Bounding			
62	time = 30 hours	%		0.03391		0.09703			100 * ((S13 - (S13 + S50 * 60 * 24) * S21 / 100) * EXP(-(S13 + S50 * 60 * 24) / (S12 * 30 / 24))) / (S13 + S50 * 60 * 24)	%H2		
63	time = 90 hours	%		0.03860		0.10397			100 * ((S13 - (S13 + S50 * 60 * 24) * S21 / 100) * EXP(-(S13 + S50 * 60 * 24) / (S12 * 90 / 24))) / (S13 + S50 * 60 * 24)	%H2		
64	time = 120 hours	%		0.03899		0.10405			100 * ((S13 - (S13 + S50 * 60 * 24) * S21 / 100) * EXP(-(S13 + S50 * 60 * 24) / (S12 * 120 / 24))) / (S13 + S50 * 60 * 24)	%H2		
65	time = 240 hours	%		0.03905		0.10406			100 * ((S13 - (S13 + S50 * 60 * 24) * S21 / 100) * EXP(-(S13 + S50 * 60 * 24) / (S12 * 240 / 24))) / (S13 + S50 * 60 * 24)	%H2		
66	vent rate =	#/3min		120		60			60			
67	time = 3 hours	%		0.01943		0.05498			100 * ((S13 - (S13 + S57 * 60 * 24) * S21 / 100) * EXP(-(S13 + S57 * 60 * 24) / (S12 * 3 / 24))) / (S13 + S57 * 60 * 24)	%H2		
68	time = 30 hours	%		0.02496		0.06935			100 * ((S13 - (S13 + S57 * 60 * 24) * S21 / 100) * EXP(-(S13 + S57 * 60 * 24) / (S12 * 30 / 24))) / (S13 + S57 * 60 * 24)	%H2		
69	time = 90 hours	%		0.02602		0.06939			100 * ((S13 - (S13 + S57 * 60 * 24) * S21 / 100) * EXP(-(S13 + S57 * 60 * 24) / (S12 * 90 / 24))) / (S13 + S57 * 60 * 24)	%H2		
70	time = 120 hours	%		0.02603		0.06940			100 * ((S13 - (S13 + S57 * 60 * 24) * S21 / 100) * EXP(-(S13 + S57 * 60 * 24) / (S12 * 120 / 24))) / (S13 + S57 * 60 * 24)	%H2		
71	time = 240 hours	%		0.02603		0.06940			100 * ((S13 - (S13 + S57 * 60 * 24) * S21 / 100) * EXP(-(S13 + S57 * 60 * 24) / (S12 * 240 / 24))) / (S13 + S57 * 60 * 24)	%H2		
72	vent rate =	#/3min		160		80			80			
73	time = 3 hours	%		0.01740		0.04771			100 * ((S13 - (S13 + S54 * 60 * 24) * S21 / 100) * EXP(-(S13 + S54 * 60 * 24) / (S12 * 3 / 24))) / (S13 + S54 * 60 * 24)	%H2		
74	time = 30 hours	%		0.01934		0.05192			100 * ((S13 - (S13 + S54 * 60 * 24) * S21 / 100) * EXP(-(S13 + S54 * 60 * 24) / (S12 * 30 / 24))) / (S13 + S54 * 60 * 24)	%H2		
75	time = 90 hours	%		0.01953		0.05206			100 * ((S13 - (S13 + S54 * 60 * 24) * S21 / 100) * EXP(-(S13 + S54 * 60 * 24) / (S12 * 90 / 24))) / (S13 + S54 * 60 * 24)	%H2		
76	time = 120 hours	%		0.01953		0.05206			100 * ((S13 - (S13 + S54 * 60 * 24) * S21 / 100) * EXP(-(S13 + S54 * 60 * 24) / (S12 * 120 / 24))) / (S13 + S54 * 60 * 24)	%H2		

B										J				K	L
2	Check or Calc Note: HNF-SD-WM-CN-114 Rev 0.	C	D	E	F	G	H	I	6	AY102-After Bounding Best Est				Variable Name	Range Name
3	Tank		1	2	3	4	5			AY102-After Bounding Best Est					
4			C-106 Best Est	C-106 Bounding	AY102 Before Best Est	AY102 Before Bounding	AY102-After Best Est								
5															
69	time = 240 hours	%		0.01953		0.05205				100 * ((S13 - (S13 - (S13 + S84 + 60 * 24)) * S21 / 100) * @S91 - (S13 + S84 + 60 * 24)) / (S13 + S84 + 60 * 24))				%H2	
70	R=3min			200		100			100						
71	vent rate =														
72	time = 3 hours	%		0.01562		0.04165				100 * ((S13 - (S13 - (S13 + S71 + 60 * 24)) * S21 / 100) * @S91 - (S13 + S71 + 60 * 24)) / (S13 + S71 + 60 * 24))				%H2	
73	time = 30 hours	%		0.01562		0.04165				100 * ((S13 - (S13 - (S13 + S71 + 60 * 24)) * S21 / 100) * @S91 - (S13 + S71 + 60 * 24)) / (S13 + S71 + 60 * 24))				%H2	
74	time = 90 hours	%		0.01562		0.04165				100 * ((S13 - (S13 - (S13 + S71 + 60 * 24)) * S21 / 100) * @S91 - (S13 + S71 + 60 * 24)) / (S13 + S71 + 60 * 24))				%H2	
75	time = 120 hours	%		0.01562		0.04165				100 * ((S13 - (S13 - (S13 + S71 + 60 * 24)) * S21 / 100) * @S91 - (S13 + S71 + 60 * 24)) / (S13 + S71 + 60 * 24))				%H2	
76	time = 240 hours	%		0.01562		0.04165				100 * ((S13 - (S13 - (S13 + S71 + 60 * 24)) * S21 / 100) * @S91 - (S13 + S71 + 60 * 24)) / (S13 + S71 + 60 * 24))				%H2	