



NUREG/IA-0130
CAMP002

International Agreement Report

Assessment of RELAP5/MOD3.1 With the LSTF SB-SG-06 Experiment Simulating a Steam Generator Tube Rupture Transient

RECEIVED
OCT 10 1996
OSTI

Prepared by
Kwang Won Seul, Young Seok Bang, Sukho Lee, Hho Jung Kim

Korea Institute of Nuclear Safety
P.O. Box 16, Daeduck Danji
Taejon, 305-600 Korea

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

September 1996

Prepared as part of
The Agreement on Research Participation and Technical Exchange
under the International Thermal-Hydraulic Code Assessment
and Application Program (ICAP)

Published by
U.S. Nuclear Regulatory Commission

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

AVAILABILITY NOTICE

Availability of Reference Materials Cited in NRC Publications

Most documents cited in NRC publications will be available from one of the following sources:

1. The NRC Public Document Room, 2120 L Street, NW., Lower Level, Washington, DC 20555-0001
2. The Superintendent of Documents, U.S. Government Printing Office, P. O. Box 37082, Washington, DC 20402-9328
3. The National Technical Information Service, Springfield, VA 22161-0002

Although the listing that follows represents the majority of documents cited in NRC publications, it is not intended to be exhaustive.

Referenced documents available for inspection and copying for a fee from the NRC Public Document Room include NRC correspondence and internal NRC memoranda; NRC bulletins, circulars, information notices, inspection and investigation notices; licensee event reports; vendor reports and correspondence; Commission papers; and applicant and licensee documents and correspondence.

The following documents in the NUREG series are available for purchase from the Government Printing Office: formal NRC staff and contractor reports, NRC-sponsored conference proceedings, international agreement reports, grantee reports, and NRC booklets and brochures. Also available are regulatory guides, NRC regulations in the *Code of Federal Regulations*, and *Nuclear Regulatory Commission Issuances*.

Documents available from the National Technical Information Service include NUREG-series reports and technical reports prepared by other Federal agencies and reports prepared by the Atomic Energy Commission, forerunner agency to the Nuclear Regulatory Commission.

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions. *Federal Register* notices, Federal and State legislation, and congressional reports can usually be obtained from these libraries.

Documents such as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings are available for purchase from the organization sponsoring the publication cited.

Single copies of NRC draft reports are available free, to the extent of supply, upon written request to the Office of Administration, Distribution and Mail Services Section, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at the NRC Library, Two White Flint North, 11545 Rockville Pike, Rockville, MD 20852-2738, for use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from the American National Standards Institute, 1430 Broadway, New York, NY 10018-3308.

DISCLAIMER NOTICE

This report was prepared under an international cooperative agreement for the exchange of technical information. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product, or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.



NUREG/IA-0130
CAMP002

International Agreement Report

Assessment of RELAP5/MOD3.1 With the LSTF SB-SG-06 Experiment Simulating a Steam Generator Tube Rupture Transient

Prepared by
Kwang Won Seul, Young Seok Bang, Sukho Lee, Hho Jung Kim

Korea Institute of Nuclear Safety
P.O. Box 16, Daeduck Danji
Taejon, 305-600 Korea

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

September 1996

Prepared as part of
The Agreement on Research Participation and Technical Exchange
under the International Thermal-Hydraulic Code Assessment
and Application Program (ICAP)

Published by
U.S. Nuclear Regulatory Commission

NUREG/IA-0130 has been reproduced
from the best available copy.

DISCLAIMER

**Portions of this document may be illegible
in electronic image products. Images are
produced from the best available original
document.**

Assessment of RELAP5/MOD3.1 with the LSTF SB-SG-06 Experiment
Simulating a Steam Generator Tube Rupture (SGTR) Transient

Abstract

The objective of the present work is to identify the predictability of RELAP5/MOD3.1 regarding thermal-hydraulic behavior during a steam generator tube rupture (SGTR). To evaluate the computed results, LSTF SB-SG-06 test data simulating the SGTR that occurred at the Mihama Unit 2 in 1991 are used. Also, some sensitivity studies of the code change in RELAP5, the break simulation model, and the break valve discharge coefficient are performed. The calculation results indicate that the RELAP5/MOD3.1 code predicted well the sequence of events and the major phenomena during the transient, such as the asymmetric loop behavior, reactor coolant system (RCS) cooldown and heat transfer by natural circulation, the primary and secondary system depressurization by the pressurizer auxiliary spray and the steam dump using the intact loop steam generator (SG) relief valve, and so on. However, there are some differences from the experimental data in the number of the relief valve cycling in the affected SG, and the flow regime of the hot leg with the pressurizer, and the break flow rates. Finally, the calculation also indicates that the coolant in the core could remain in a subcooled state as a result of the heat transfer caused by the natural circulation flow even if the reactor coolant pumps (RCPs) turned off and that the affected SG could be properly isolated to minimize the radiological release after the SGTR.

Contents

Abstract	iii
Contents	v
List of Tables	vi
List of Figures	vi
Acknowledgements	viii
Executive Summary.....	ix
I. Introduction	1
II. Experimental Facility, Conditions and Procedures	4
II.1 Facility Description	4
II.2 Experimental Conditions and Procedures	5
III. Code and Modeling	6
III.1 Code Description	6
III.2 Modeling Description	6
IV. Analysis Results and Discussion	8
IV.1 Analysis Conditions	8
IV.2 Analysis Results	9
IV.3 Code Predictability	13
IV.4 Sensitivity Study	15
IV.5 Run Statistics	17
V. Conclusions	18
References	20
Appendix A. Input Deck for Steady State Calculation	
Appendix B. Input Deck for SGTR Transient Calculation	

List of Tables

- Table 1 Comparison of Initial Conditions
- Table 2 Setpoints and Conditions used in RELAP5/MOD3.1 Calculation
- Table 3 Event Sequence of SGTR Transient
- Table 4 Lists of Measured Data and Corresponding Calculated Parameters
- Table 5 Comparison of Integrated Total Mass Flows during Transient

List of Figures

- Figure 1 ROSA-IV LSTF Flow Diagram
- Figure 2 RELAP5 Nodalization of ROSA-IV LSTF for SGTR Transient Assessment
- Figure 3 Break Simulation and Nodalization
- Figure 4 Break Line Configuration in LSTF SB-SG-06 Test
- Figure 5 Comparison of Primary Pressure between Experiment and Calculation
- Figure 6 Comparison of Secondary Pressures between Experiment and Calculation
- Figure 7 Comparison of Core Fluid Temperatures
- Figure 8 Comparison of Broken Loop Secondary Side Fluid Temperatures
- Figure 9 Comparison of Intact Loop Hot Leg Temperature
- Figure 10 Comparison of Broken Loop Hot Leg Temperature
- Figure 11 Comparison of Pressurizer Water Level
- Figure 12 Comparison of SG Water Levels
- Figure 13 Comparison of Intact Loop Mass Flow rate
- Figure 14 Comparison of Broken Loop Mass Flow rate
- Figure 15 Comparison of HPSI-core upper plenum Mass Flow rate
- Figure 16 Comparison of HPSI-cold legs Mass Flow rate
- Figure 17 Comparison of Break Mass Flow rate between Experiment and Calculation
- Figure 18 Integrated Break Mass Flow and HPSI Mass Flow
- Figure 19 The Calculated Feedwater Flow rate in Intact Loop Secondary Side
- Figure 20 The Calculated Feedwater Flow rate in Broken Loop Secondary Side

- Figure 21 The Pressurizer Auxiliary Spray Mass Flow rate
- Figure 22 The Atmospheric Steam Dump Flow rate through Intact Loop Relief Valve
- Figure 23 The Calculated Heat Flux on U-tube wall in Broken Loop SG
- Figure 24 The Calculated Heat Flux on Steam dome wall in Broken Loop SG
- Figure 25 The Calculated Flow rate on Pressurizer Surge Line
- Figure 26 The Calculated Void Fraction in Pzr Surge Line and Hot Leg
- Figure 27 Comparison of Primary Pressure between MOD3.0 and MOD3.1
- Figure 28 Comparison of Break Mass Flow rates on Break Simulation Model
- Figure 29 Comparison of Break Mass Flow rates on Break Discharge Coefficient
- Figure 30 Comparison of CPU Times
- Figure 31 Courant Time Step and Advanced Time Step Size

Acknowledgements

This report was performed under the sponsorship of Korea Ministry of Science and Technology (MOST). Dr. Yong Gyu LIM, President of the Korea Institute of Nuclear Safety (KINS), contributed significantly to the administration of the project. Authors express an appreciation to him. And authors also appreciate to Dr. Kukita (JAERI) who provided a presentation materials on LSTF experiment, and to Mr. Donald E. Solberg (USNRC) who is a CAMP project manager.

Executive Summary

The RELAP5 code has been developed as one of the best-estimate codes. The code is based on a non-homogeneous and non-equilibrium model for one dimensional, two-phase flow. Recently, the RELAP5/MOD3 code development program has been initiated to develop a code version suitable for the analysis of all transient and postulated accidents in PWR systems

The objective of present work is to evaluate the predictability of the RELAP5/MOD3.1 on major thermal-hydraulic behavior during the Steam Generator Tube Rupture (SGTR) accident. Such a transient behavior includes following phenomena; the asymmetric loop behavior, the RCS cooldown and heat transfer by the natural circulation, system depressurization, and so on. To do this, the calculation results are assessed and compared with the LSTF SB-SG-06 test data simulating the single SGTR accident occurred at Mihama Unit 2 in 1991. Also, some sensitivity studies are performed on items which may have influence on the prediction of the transient behavior; RELAP5 code version, break simulation model and break valve discharge coefficients. Finally, from these analysis results, the capability of core recovery and contaminated coolant isolation following the SGTR accident are discussed briefly.

The LSTF is large scale facility which is a 1/48 volumetrical scale of PWR and also the LSTF test data agreed well with the transient behavior observed in Mihama Unit 2 power plant. Thus, it is expected that the RELAP5/MOD3.1 can give reliable calculation results to applicable to real plant if the present calculation predicts well the LSTF test data. Comparing the present calculation results with the the SB-SG-06 test data, overall transient behavior predicted by using RELAP5/MOD3.1 was in a good agreement with the experiment and the following conclusions were obtained.

- 1) The RELAP5/MOD3.1 predicted well the sequence of events and the major phenomena during the transient, such as the asymmetric loop behavior, the RCS cooldown and heat transfer by the natural circulation, primary and secondary system depressurization by the pressurizer auxiliary spray and the steam dump using the intact loop SG relief valve, and so on. However, there were differences in some items, such

as the number of the relief valve cycling in the affected SG, the flow regime of the hot leg with the pressurizer and the break flow rates.

2) The RELAP5/MOD3.1 overestimated the number of the RV cycling in the isolated SG. In the experiment, the pressurization rate in the affected SG steam dome was determined as a result of the condensation and compression of the steam by the ascending SG water level rather than the vaporization. However, the code may not properly predict this type of the wall and steam-water interface condensation phenomena. The frequent RV opening had influence on the break flow rate and caused the overestimated break flow rate. Hence, to obtain the accurate transient behavior including the break flow rate, it may be necessary to improve the model on the wall and steam-water interface condensation under superheated situation in the RELAP5/MOD3.1.

3) The results of sensitivity studies shows that, in the early phase of the transient, the results using the RELAP5/MOD3.1 agreed better with the experiment than that of the MOD3.0 code. Also the break flow rate was sensitive to the break simulation model and the break valve discharge coefficient. Especially, the break nozzle model based on the LSTF test configuration provided better agreement with the experiment than the break valve model. Also, in case simulating the SG U-tube rupture as the break valves, the discharge coefficient, C_d of the break valves had strong influence on the break flow rate.

I. Introduction

A Steam Generator Tube Rupture (SGTR) Accident is initiated from the break of the barrier between the Reactor Coolant System (RCS) and the secondary Main Steam System (MSS), which results from the failure of Steam Generator (SG) U-tube. In general, the degradation of the SG U-tube integrity is caused due to the vibration, corrosion and crack for the long plant operation. Because the occurrence probability of the SG U-tube rupture is relatively higher than the RCS piping, the issue on the degradation of SG U-tube integrity has been studied as one of the Unresolved Safety Issues (USIs) by the USNRC for a long time [1].

In the view point of radiological release, the integrity of the barrier between the RCS and the secondary MSS is very significant. Such a SGTR accident could provide the direct release path of contaminated coolant to the environment. Also SGTR accident induces a rather complex phenomena on the plant responses, such as the asymmetric loop behavior, RCS cooldown using natural circulation in intact loop, depressurization of each system and energy transfer between primary and secondary systems. As a consequence, it is necessary that an operator understand precisely the plant behavior during the accident and some actions to minimize the radiological consequences be prepared. Almost all the reports analyzing the SGTR accident clearly show that there are the substantial operator involvements required to mitigate the consequence of the events. Such operator actions may include the isolation of the affected SG to contain the contaminated coolant, the pressurizer power operated relief valve (PORV) open or auxiliary spray actuation to depressurize the primary pressure, the atmospheric steam dump in intact SG, high pressure safety injection (HPSI) pumps termination, reactor coolant pumps (RCPs) restart, and so on.

On February 9, 1991, a single tube in steam generator was ruptured in Mihama Unit 2 in Japan. The Mihama Unit 2 has been operated since 1972, and its nuclear steam supply system design was supplied by Westinghouse with Model 44 steam generator. The cause of the tube rupture was reported as the incorrect insertion of anti-vibration

bars, which could not protect the tube from the fatigue by fluid elastic vibration. The Japan Atomic Energy Research Institute (JAERI) carried out the integral simulation experiments on the SGTR incident that occurred at the Mihama Unit 2 power station. The experiment was conducted at the Large Scale Test Facility (LSTF) of the ROSA-IV Program [2,3]. The objective of the experiment was to provide the detailed thermal-hydraulic experimental data, that supplement the plant records, to be used for in-depth evaluation of the SGTR incident and for validation of computer-code. The experimental results indicated that the sequence of events and the behavior of system parameters agree well with Mihama Unit 2 records, and confirmed that there is a large margin in the core cooling capability during the SGTR incident.

The objective of present work is to evaluate the predictability of the RELAP5/MOD3.1[4] on major thermal-hydraulic behavior during the SGTR accident. Such a transient behavior includes following phenomena; the asymmetric loop behavior, the RCS cooldown and heat transfer by the natural circulation, primary and secondary system depressurization by the pressurizer auxiliary spray and the steam dump using the relief valve, and so on. To do this, the calculation results are assessed and compared with the LSTF SB-SG-06 test data simulating the single SGTR accident occurred at Mihama Unit 2. As mentioned above, the LSTF test data agreed well with the transient behavior observed in Mihama Unit 2 nuclear power plant. Also, the LSTF is large scale facility which is a 1/48 volumetrical scale of PWR. Thus, it is expected that the RELAP5/MOD3.1 can give reliable calculation results to applicable to real plant if the present calculation predicts well the LSTF test data. Also, in present work, some sensitivity studies will be performed on items which may have influence on the prediction of the transient behavior, such as RELAP5 code version and break simulation model. Finally, from these analysis results, the capability of core recovery and contaminated coolant isolation following the SGTR accident will be briefly discussed.

The Chapter II includes a description of the LSTF and experimental conditions and procedures. A code description and modelling of the facility including nodalization

and control logics are described in Chapter III. The calculation results are discussed in detail with a experimental data in Chapter IV. In particular, the discussion involves an assessment of the major phenomena during SGTR accident. The code predictability and run statistics are also described in this chapter. The conclusions obtained through the present study are summarized in Chapter V. Finally, the RELAP5/MOD3.1 input deck for steady state run and transient run are attached as an Appendix A and B, respectively.

II. Experimental Facility, Conditions and Procedures

II.1 Facility Description

The LSTF is a 1/48 volumetrically scaled model of a Westinghouse type 3423 MWt four loop PWR[2]. The LSTF has the same elevations as the reference PWR to simulate the natural circulation phenomena and large loop pipes to simulate the two-phase regimes and major phenomena in an actual plant. Figure 1 shows the flow diagram of the LSTF. The facility was designed to be operated at the same pressures and temperatures as the reference PWR.

The LSTF facility simulates the major components of the PWR primary system (for example, pressure vessel, pressurizer, SGs, RCPs, etc.) and the reactor protection system (for example, emergency core cooling system, auxiliary feedwater system, etc.) that have an impact on the plant behavior during the operational transients. Equipment controls allow the test operators to either follow procedures defined in standard plant manual or follow variations of standard procedures. Other systems, such as the secondary and various auxiliary systems, are capable of achieving pretest steady-state conditions and simulating the primary to secondary interactions. These systems include feedwater, condensate and steam systems together with component service systems such as the cooling water, water purification etc.

The fuel assembly dimensions, i.e. the fuel rod and the guide thimble diameter, pitch and length, and the ratio of the number of fuel rods to the number of guide thimbles were designed to be the same as the 17 x 17 fuel assembly of the reference PWR to preserve the heat transfer characteristics of the core. The total number of rod which was scaled by 1/48, is 1064 for the electrically heated and 104 for the unheated rods. The most important design scaling compromise is the 10 MW maximum core power limitation, 14% of the scaled reference PWR rated power. The steady-state condition is therefore restricted to a core mass flow rate that is 14% of the scaled value, to simulate the reference PWR temperature distribution in the primary loop.

The four primary loops of the reference PWR were represented by two equal-volume loops. The hot and cold legs were sized to conserve the volume scaling and the ratio

of the length to square root of the pipe diameter, $L/D^{0.5}$ for the reference PWR, in expectation that the flow regime transitions in the primary loops can be simulated appropriately by taking this scaling approach.

II.2 Experimental Conditions and Procedures

The experiment (SB-SG-06 test simulated an accident with SG single tube rupture) was initiated by opening a break valve nearly at the same RCS pressure and temperature as in Mihama Unit 2. The reactor trip signal and safety injection signal were sent automatically at the same RCS setpoint pressures as in Mihama Unit 2. Then, the HPSI systems were actuated and the HPSI flow was directed to the cold legs and vessel upper plenum. The damaged SG was isolated at 12 minutes after reactor trip. At the same time, depressurization of intact SG secondary side was initiated. Such a depressurization was terminated according to the Mihama Unit 2 Emergency Operating Procedure (EOP). Subsequently, the atmospheric relief valve (RV) on the damaged SG opened and closed automatically.

In order to stop the break flow by reducing the primary pressure, the pressurizer PORVs were tried to open in the real plant, but it failed to open. Thus the pressurizer auxiliary spray was used instead of the PORV. The pressurizer auxiliary spray was actuated 44 minutes after reactor trip to depressurize the RCS. The HPSI pumps were turned off after the pressurizer water level recovered. The pressurizer auxiliary spray was turned off after the RCS pressure equilibrated with the damaged SG pressure. Finally, the RCP in intact loop was restarted at 65 minutes after reactor trip. The experiment was ended when the RCS conditions were stabilized. The overall event sequences of the SGTR transient can be shown in Table 3.

The measurement systems were developed and installed to measure the various thermal hydraulic phenomena associated with the experiment. Installed locations and measuring range for all instruments and data acquisition system in LSTF were in detail described in reference 2. In particular, the estimated accuracy of the experimental data used in this study was presented with the origin of the measured data in Table 4.

III. Code and Modeling

III.1 Code Description

The RELAP5 code has been developed as one of the best-estimate codes. The code is based on a non-homogeneous and non-equilibrium model for one dimensional, two-phase system that is solved by a fast, partially implicit numerical scheme to permit economical evaluation of system transients. Recently, the RELAP5/MOD3 code development program has been initiated to develop a code version suitable for the analysis of all transient and postulated accidents in PWR systems including both large and small break LOCAs as well as the full range of operational transient. Although the emphasis of the RELAP5/MOD3 development is on large break LOCA, improvements to existing code models, based on the results of assessments against operational transient test data, are also being made. In this code assessment on the SGTR transient, the unmodified released code version, RELAP5/MOD3.1 and MOD 3.0 are used.

III.2 Modeling Description

The nodalization used to simulate the LSTF facility of the ROSA-IV program with the RELAP5 code is represented in Figure 2. The model is based on 177 volumes connected by 186 junction and 166 heat structures composed of 947 mesh points for averaged U-tube model case. In the reactor vessel elements (volumes 100 to 156) the volumes corresponding to the downcomer, the lower plenum and upper plenum, the core, the upper head and the guide thimble channel are defined. In the schematization of the upper part of the LSTF downcomer (volumes 100 and 104), care was taken to correctly simulate the steady-state mass flow rates in the connection with the hot legs (bypasses), the upper plenum (unintentional leak path) and the upper head (spray nozzles) to obtain the requested values, i.e. 0.1 %, 0.085 % and 0.3 % of the core inlet flow rate, respectively. The core is modeled by one channel arranged in 6 hydraulic volumes, in which only one series of heat structures is adopted to simulate the fuel

assembly (i.e. a flat radial core power profile is assumed). The reason for this choice resides in the attempt to perform the simplest modeling of the LSTF facility as possible. A pipe connection (volume 156) between the upper head and the upper plenum of the pressure vessel is introduced in the scheme to simulate the guide thimble channel path existing in the facility.

The two loops of the LSTF system are represented by the intact-loop (volumes 200 to 299) and the broken-loop (volumes 400 to 499) in an almost symmetrical way. In fact, each of the two loops presents the hot leg, the SG inlet and outlet plena, the SG U-tube channel, the loop seal, the reactor coolant pump, the cold leg. In addition, the pressurizer is connected to the intact-loop hot leg by means of the surge line element. In the volumes representing the pressurizer vessel, an additional heat structure is introduced to simulate the effects of the proportional and back-up heaters. But the pressurizer heaters are not used in this case of SGTR transient. The two SG secondary sides (volumes 300 to 399 and 500 to 599) are simulated using an identical schematization. They can be subdivided into the downcomer, the boiling section, the steam separator and the steam dome. The steam and feedwater lines are simulated by using Time Dependent Junctions with imposed flow rates. The relief and safety valves are also connected to the SG steam dome using valve components in which the operational setpoints and conditions are specified to be the same as the experiment.

The U-tube break models are examined for two cases as shown in Figure 3. Case 1 is to simulate the double-ended break as a single-ended break nozzle based on the LSTF SB-SG-06 test configuration. Figure 4 shows the break line arrangement in LSTF. The break nozzle is a straight, cylindrical pipe of 6.2 mm in inner diameter and 1.8 m in length. Such a nozzle is to simulate the scaled break area and length as well as the pressure drop along the ruptured tube. In this report, this break nozzle modelling case, i.e., Case 1 will be regarded as a base case calculation. Case 2 is to simulate the U-tube rupture as two break valves between a single broken U-tube channel and secondary SG. The valve junction diameter is 6.2 mm and the single broken U-tube size is 19.6 mm in inner diameter as in LSTF experiment. The remaining SG U-tubes are modeled as an averaged single U-tube.

IV. Analysis Results and Discussion

IV.1 Analysis Conditions

As a base calculation, the released code version without modification, RELAP5/MOD3.1 is used to identify the code predictability on the thermal-hydraulic behavior during the SGTR accident. Table 1 represents the comparison of initial conditions between the LSTF SB-SG-06 test and the calculation. The calculated values were obtained from the steady state run. It is indicated that the major calculated parameters of the primary and secondary coolant systems agree well with the measured values in LSTF SB-SG-06 test.

Table 2 represents the setpoints and conditions used in calculation. These conditions are based on the specified operational setpoints and conditions of the experiment. However, the experimental information was not enough to accurately simulate the transient behavior. Thus, some control logics such as timing of termination of HPSI into upper plenum were modelled in accordance with the experimental results. The calculation was attempted up to 5000 seconds when the operator's recovery procedure is initiated as in experiment.

Table 3 represents the major sequence of the events during the SGTR transient. The major events are composed of the reactor trip, auxiliary feedwater actuation, high pressure safety injection (HPSI), affected SG isolation (MSIV close) and intact SG depressurization (RV open), RV cycling in affected SG, pressurizer auxiliary spray actuation, and so on. Two calculations depending on the break simulation model were performed and the table is showing the similar sequence of the events. As a base calculation, the computed results of the Case 1, which based on the LSTF SB-SG-06 test configuration, are compared with experimental data and are in detail discussed in following section. The experimental data compared in this study were obtained by digitizing curves of the figures in open literatures [5,6]. The origin of the experimental data including the estimated accuracy and the corresponding calculated parameters are listed in Table 4.

Also, in these base and sensitivity calculations, the general and specific practices for

applying RELAP5 including standard procedures, option selection related to volume and junction, special model applications such as break model and crossflow model, control and trip logics and so on, are used. Hence there are no deviations from the user guidelines described in RELAP5/MOD3 code manual volume V.

IV.2 Analysis Results

1. RCS Pressure Response

Figure 5 shows the primary system pressure behavior during the SGTR transient. After the initiation of single SG U-tube rupture, the pressurizer pressure and water level decrease monotonically because the amount of break flow to SG secondary side is larger than the coolant supplied by the charging pumps. The reactor scram occurs when the RCS pressure reaches 13.42 MPa. After that, the pressure and water level continue to decrease. The pressurizer water level behavior will be discussed later (Figure 11). Following the continuous decrease of the RCS pressure, the pressure reaches to the setpoint of the safety injection signal and the RCP trip. The high pressure safety injection (HPSI) into cold legs and upper plenum of the reactor vessel begin to deliver at 98 seconds and 300 seconds after the safety injection signal, respectively. The RCPs coastdown at 80 seconds after the reactor scram. The pressurizer is emptied completely at about 335 seconds.

The HPSI water continues to inject into primary side in order to recover the core inventory, while break flow enters secondary side through the break nozzle. The pressurizer auxiliary spray system instead of the pressurizer relief valves, is used to increase a depressurization rate at 2660 seconds after the reactor scram and the pressurizer water level is recovered from 3000 seconds. The HPSI systems are terminated after the pressurizer water level is recovered. When the RCS pressure becomes identical to the broken loop SG pressure, the pressurizer auxiliary spray is turned off. Finally, the RCP in intact loop is restarted about 4000 seconds after reactor scram, and the experiment and calculation are terminated at 5000 seconds when the primary system conditions are stabilized. The overall transient response of the calculated primary pressure agrees well with the LSTF SB-SG-06 test data.

2. Secondary Pressure Response

Figure 6 represents the secondary pressure behavior during the SGTR transient. The broken loop SG is isolated by closing the main steam isolation valve (MSIV) at 722 seconds after reactor scram and simultaneously the intact loop SG is depressurized by the latched open of the SG relief valve (RV). Such actions are to contain the contaminated coolant in the affected SG and to maintain the heat removal from primary to secondary through the intact SG, respectively. The pressure of broken loop SG increases due to the primary coolant inflow with high enthalpy and is controlled by opening and closing the SG RV. The break flow rate entered into the secondary side can be shown in Figure 17. Consequently the general trend of the calculated secondary pressure is analogous to the experiment. However, there exists the difference in the number of the RV cycling of broken loop SG. The RV was opened once in experiment, while it was opened several times in calculation. The difference will be discussed in detail in section IV.3.

3. Thermal Response

Figure 7 represents fluid temperatures at inlet, mid section and outlet of reactor vessel core. The RCS saturation temperature is also plotted in the figure. Figure 8 shows fluid temperatures on the broken loop SG secondary side. From this figures, it is found that there exists the sufficient subcooled margin in the primary side and the superheated steam in the broken loop secondary side during the SGTR transient. The RCS fluid temperatures decrease rapidly after the reactor scram. However, the core outlet fluid temperature increases slightly after RCPs trip, which is due to reduction of the heat transfer between primary side and secondary side.

The RCS fluid temperatures continue to decrease gradually by the atmospheric steam dump and feedwater in the secondary side and the HPSI cold water in the primary side. This explains that the core heat is removed by the natural circulation in the intact loop. Thus, the subcooled margin of RCS coolant becomes larger sufficiently to prevent the core voiding. They decrease rapidly at about 4300 seconds because of the forced convection caused from restart of the intact loop RCP. Figures 9 and 10 are the hot

leg fluid temperatures in intact loop and broken loop, respectively. The similar trends to the RCS fluid temperature are found. The overall transient responses of the calculated fluid temperatures agree well with the experimental data. However, in the early phase of the transient, there exists the bump in the experiment, while it is not seen in the calculation. The bump occurs when the hot water and steam in the pressurizer is penetrated into the hot leg after emptying of pressurizer at about 400 seconds.

4. Water Level Behavior

Figure 11 shows that the pressurizer is emptied completely at about 335 seconds and the water level is recovered from about 3000 seconds. The calculation result agrees well with the experiment. Figure 12 shows the SG water levels behavior in broken and intact loop SGs. After MSIV closure of the broken loop SG, the water level increases gradually by the primary coolant inflow through the break nozzle. The calculated water level increases with the similar rate as that in experimental data, however, the value of water level is slightly higher than that of experimental data. Such a calculation result is because the SG inventory is controlled to remain a reference water level up to main feedwater trip. Supposed that a detailed experimental information on the main feedwater and main steam flow rate will be given, this difference is expected to be reduced. The water level in intact loop SG rapidly decreases due to the atmospheric steam dump. However, to keep the heat removal from the primary side by the natural circulation, the SG inventory continues to be made up by the auxiliary feedwater system. The feedwater supply can be shown in Figure 19.

5. Loop Mass Flow Behavior

Figures 13 and 14 show the loop mass flow rates in the intact and broken loop, respectively. Although the mass flow in broken loop reduces to approximately zero after the RCP trip, the natural circulation flow through the intact loop is maintained more than 5 kg/sec, which is large enough to keep the core coolant subcooled. It is shown that the heat removal from primary side to secondary side is remained by the natural circulation during SGTR transient. The intact loop mass flow increases rapidly

at about 4000 seconds after reactor scram by restarting the RCP to stabilize the RCS conditions. Consequently, the calculation predicts well the experimental behavior.

Figures 15 and 16 show the HPSI flow rates into cold legs and core upper plenum, respectively. In general, the HPSI flow rate is depending on the RCS pressure. Thus the curves representing HPSI flow rate as a function of RCS pressure were used in calculation. As shown in Figure 15, the measured HPSI flow rate into core upper plenum has somewhat uncertainty, especially in the starting point and termination point. However, the overall behavior of the HPSI flow rate agrees well with the experimental data.

6. Break Flow Behavior

Figure 17 shows the break flow rate through the break nozzle during the SGTR transient. The break flow rate is influenced by the pressure difference between primary and secondary systems. Initially the pressure difference is very large, thus the critical flow is formed immediately after break initiation, and the break flow rate gradually decreases as reduction of the pressure difference. After the HPSI system actuation, the break flow rate again increases slightly depending on the RCS pressure. When the RV in the broken loop SG is opened, the break inflow from the primary side is increased instantaneously by the SG pressure drop. This rapid increase of the break flow rate appears several times periodically (due to RV cycling) in the calculation. After the RCS depressurization using the pressurizer auxiliary spray at about 2900 seconds, the pressures of both systems are nearly identical and the break flow rate becomes much smaller. This figure shows the RV cycling has strong influence on the break mass flow. The integrated break flow was calculated 3177 kg during the transient, which is larger than the measured value of 2600 kg approximately. Table 5 shows the comparison of the integrated total mass flow during transient and Figure 18 shows the integrated break flow and HPSI flow. Consequently, it is found that the frequent RV opening results in the large amount of the break mass flow. The sensitivity study on the break simulation model will be discussed in following section.

7. Others

Figures 19 and 20 show the calculated main and auxiliary feedwater flow rate into the secondary side. The main feedwater stops at about 280 seconds in both loops, while to ensure the secondary side inventory, the auxiliary feedwater continues to be supplied to the intact loop secondary side. Figure 21 shows the calculated mass flow rate of the pressurizer auxiliary spray to depressurize the RCS. Figure 22 shows the atmospheric steam dump mass flow rate in the intact loop secondary side through the latched open RV to keep the heat removal between primary and secondary side.

Comparing the present calculation results with the experimental data, it was found that the RELAP5/MOD3.1 code predicts well the single SGTR transient behavior and the timing of sequence of events. Also, it was found that the coolant in the core could remains as subcooled state by the heat transfer, which resulted from the natural circulation flow even during RCPs turned off, and the affected SG could be properly isolated to minimize the radiological release following the SGTR accident.

IV.3 Code Predictability

As discussed in the above section, the comparison between the available LSTF SB-SG-06 test data and the calculation results, indicates that the RELAP5/MOD3.1 code yields in general agreeable results for SGTR transient. However, there exist differences in some parameters from the experiment as follows.

Figure 6 shows the behavior of the SG secondary pressure for both intact loop and broken loop sides. The general trend agrees well with the experiment. However, the number of the relief valve opening in the broken loop SG is overestimated; several times in calculation, while once in experiment (three times in Mihama Unit 2). This difference may come from the insufficient nodalization and/or the modelling on the heat transfer in the secondary side. However, the code model on wall and steam-water interface condensation can be considered as one of the reason for the difference if the current modelling is reasonable one. As shown in Figures 8 and 10, the steam in the broken loop SG steam dome is superheated after about 1000 seconds and the break

flow entered from the primary system is subcooled. Also, since the SG water temperature becomes higher than the break flow (or hot leg) temperature, the heat transfer across the U-tube wall is reversed from secondary side to primary side. Figure 23 shows the reversed heat flux across the U-tube walls in the affected SG. Hence, one can conclude that the pressurization of affected SG mainly occurs as a result of compression of the steam phase by the ascending SG water level rather than the vaporization in SG. In the experiment, the pressure increasing rate was reduced by condensation on the wall and steam-water interface, but in the calculation, it was not predicted appropriately. Figure 24 shows the calculated heat flux across the SG steam dome wall. The experimental data relevant to the parameter was not available. However, the heat flux from the steam dome to environment, after 1000 seconds, may be not enough to reduce the pressure increasing rate to the experimental value. Those overprediction of pressure increasing rate is considered as a reason for the frequent RV opening/closing. Such a frequent RV opening, which results in the larger pressure difference between primary and secondary systems, had influence on the break flow rate and caused the overestimated break flow rate. Thus, to obtain the accurate secondary pressure behavior including the break flow rate, it may be necessary to improve the model on the wall and steam-water interface condensation under superheated steam situation in the RELAP5/MOD3.1 code.

In the experiment, as shown in Figure 9, the fluid temperature "bumps" appeared at the top of the hot leg to which the pressurizer was connected. It is a temporal increase of the fluid temperature only at the top of the hot leg. Most hot leg water remains subcooled. This phenomena occurred, after emptying of the pressurizer, when the hot water and steam in the pressurizer are penetrated into the hot leg where the subcooled water is flowing toward the SG. In addition, the experiment indicated that the slight stratified two-phase flow with small void fraction was observed at the top of the hot leg. However, the calculated hot leg bulk fluid temperature was just slightly increased and the "bumps" was not observed as shown in Figure 9. Also, the flow regime in the intact loop hot leg was predicted as a bubbly flow, which has the very small void fraction less than 0.1. This discrepancy may be caused from the difference in measured

location and the code limitation to calculate the temperature stratification in one dimensional model. The experimental data were measured at the top of the hot leg, while in analysis, the bulk temperature of the hot leg was computed. In fact, the averaged bulk fluid temperature measured in experiment may be lower than that of Figure 9. Figures 25 and 26 show that the pressurizer steam is penetrated into the hot leg through surge line around 400 seconds and the void is formed in the hot leg in the calculation.

IV.4 Sensitivity Study

Sensitivity study was performed on some items which may influence on the prediction of transient behavior, such as the primary pressure, the break flow rate, etc. The chosen items are the RELAP5 code version (MOD3.0 vs MOD3.1), the break simulation model as described in section III.2 and the break valve discharge coefficient, C_d for the break valve model case (from 0.15 to 0.2).

Figure 27 shows the comparison of the primary pressures which were calculated using RELAP5/MOD3.0 and RELAP5/MOD3.1, respectively. Although the pressure behavior for both cases after the HPSI was almost identical, the MOD3.1 predicted better the pressure trend in the early phase of the transient than the MOD3.0. The MOD3.1 was known to improve some deficiencies and errors from the MOD3.0 for following items; condensation model, spherical accumulator model, boron transport model and error corrections such as undamped flow oscillations in stagnant crossflow junctions, etc.[7] Although, from this calculation, it couldn't clearly find out the improved point of the code, the present calculation results indicated that the MOD3.1 was improved, especially in capability to predict the thermal-hydraulic behavior around the reactor trip.

Figure 28 shows the comparison of break flow rates calculated using the two different break simulation models. In the early phase, the break flow rates for the both cases were nearly identical, but, after the HPSI, the break flow rate for the Case 2 was

larger than that for the Case 1. As mentioned previously, the rapid increase of the break flow for the Case 1 was caused by the RV cycling in broken loop SG. However, even though the RV cycling also occurred in the Case 2, the rapid increase of the break flow rate was not occurred. It indicated that the critical flow was formed at the break valves in Case 2, that is, the break flow behavior was determined from the primary pressure instead of the pressure difference between primary and secondary systems. Consequently, it is found that the Case 1 simulating the double ended SG tube rupture as the break nozzle, based on the LSTF SB-SG-06 test configuration, agreed better with the experimental data than the Case 2 with break valve model. Therefore, it is found that the break nozzle model is more realistic; though the number of the RV opening was overestimated.

Figure 29 shows the comparison of the break flow rates calculated with a variation of discharge coefficient, C_d from 0.15 to 0.2, for the Case 2 modelling. As described above section, the critical flow was formed at the break valves in this case. The break flow rate from RCS to secondary side increased with increasing discharge coefficient. Especially, in case of $C_d=0.15$, the break flow rate after the reactor trip was nearly identical to the experiment. However, the break flow rate before the reactor trip was lower than that of experiment, and consequently the reactor trip time was delayed 200 seconds approximately. Therefore this case was not in good agreement with the experiment in the early phase of the transient. Table 5 describes the total break flow, total HPSI flow and total discharged steam flow throughout the transient. It can be stated that the total break and total HPSI flows increase with increasing C_d . In addition, the break flow and HPSI flow for the Case 1 were overestimated. As discussed above, the overestimated total break flow was caused by the frequent opening of the RV in the isolated SG, which results in the larger pressure difference between primary side and secondary side. Although the experimental data has somewhat its uncertainty range, Table 5 shows that the total discharged steam flow through the RV was predicted quite high. Because of this increased break flow, the total HPSI flow integrated during transient was also overestimated.

IV.5 Run Statistics

The main computer used in the present calculation was a DEC workstation 5000/240 with UNIX operating system. Figure 30 presents a plot of the required CPU time for the two cases during the SGTR transient. It is shown that Case 1 was required about ten times larger CPU time than that of Case 2. It may be because the Case 1 has another minor flow path between primary and secondary systems, which consists of some volumes and junctions. Figure 31 shows Courant time step and advanced time step size with respect to a real transient time. The time step size was reduced down to about 0.01 second.

The Case 1 transient run using RELAP5/MOD3.1 was terminated at 5000 seconds, and the required CPU time was 114,737 seconds including 11.6 seconds for input processing. The attempted advancement was 291,357 time steps. Therefore, the grind time can be calculated as follows,

CPU time	$CPU = 114,737 - 11.6 = 114,725.4 \text{ sec}$
Number of time step	$DT = 291,357$
Number of Volume	$C = 177$
Transient Real Time	$RT = 5000 \text{ sec}$
Grind Time	$GT = CPU \times 1000 / (C \times DT) = 2.2246 \text{ CPU msec/vol/step}$

V. Conclusions

The RELAP5/MOD3.1 was assessed using the LSTF SB-SG-06 test simulating the SGTR incident which occurred at the Mihama Unit 2 in 1991. To evaluate the code predictability on major thermal-hydraulic behavior, the calculation results are assessed and compared with the experimental data. LSTF is large scale facility of PWR, thus, it is expected that the RELAP5/MOD3.1 can give reliable calculation results to applicable to real plant if the present calculation predicts well the LSTF test data. Overall RELAP5/MOD3.1 calculation provided a good agreement with the SB-SG-06 test data for the SGTR transient and the following conclusions were obtained.

- 1) The RELAP5/MOD3.1 predicted well the transient behavior during the SGTR accident, such as the primary and secondary pressures, the temperatures of the core and hot legs, the break flow rate, HPSI flow rates, the pressurizer and SG water level, and so on. The calculation results also predicted well the sequence of events and the major phenomena during the transient, such as the asymmetric loop behavior, the RCS cooldown and heat transfer by the natural circulation, primary and secondary system depressurization by the pressurizer auxiliary spray and the steam dump using the intact loop SG relief valve, and so on. However, there were differences in some items when compared to the applicable test data. Those items are the number of the relief valve cycling in the affected SG, the flow regime of the hot leg with the pressurizer and the break flow rates.
- 2) The RELAP5/MOD3.1 overestimated the number of the RV cycling in the isolated SG. In the experiment, the pressurization rate in the affected SG steam dome was determined as a result of the condensation and compression of the steam by the ascending SG water level rather than the vaporization. However, the code may not properly predict this type of the wall and steam-water interface condensation phenomena. The frequent RV opening had influence on the break flow rate and caused the overestimated break flow rate. Hence, to obtain the accurate transient behavior including the break flow rate, it may be necessary to improve the model on the wall

and steam-water interface condensation under superheated situation in the RELAP5/MOD3.1.

3) The sensitivity study was performed on the RELAP5 code version, the break simulation model and the break valve discharge coefficient. In the early phase of the transient, the results using the RELAP5/MOD3.1 agreed better with the experiment than that of the MOD3.0 code. Also the break flow rate was sensitive to the break simulation model and the break valve discharge coefficient. Especially, the break nozzle model based on the LSTF test configuration provided better agreement with the experiment than the break valve model. Also, in case simulating the SG U-tube rupture as the break valves, the discharge coefficient, C_d of the break valves had strong influence on the break flow rate.

4) Finally, the analysis results indicated that the core coolant remained subcooled state by the heat transfer resulted from the natural circulation flow even during RCPs turned off, and the affected SG could be properly isolated to minimize the radiological release following the SGTR accident.

References

- [1] USNRC, "A Prioritization of Generic Safety Issues", NUREG-0933, September 1993.
- [2] ROSA-IV Group, "ROSA-IV Large Scale Test Facility (LSTF) System Description", JAERI-M 84-273, Japan Atomic Energy Research Institute, January 1985.
- [3] Y.Anoda, H.Nakamura, T.Wadanabe, M.Hirano and Y.Kukida, "Steam Generator Tube Rupture Simulations", International Conference on New Trends in Nuclear System Thermohydraulics, Pisa, Italy, May 30 - June 2, 1994.
- [4] EG&G, "RELAP5 Input Data Requirements, Appendix A to RELAP5/MOD3 Code Manual", January 1990.
- [5] Y.Kukida, et al., "Integral Simulation Experiments on the Mihama Unit 2 Steam Generator Tube Rupture (SGTR) Incident with Use of the ROSA-IV/LSTF", the material presented by JAERI at KINS/KAERI, March 10-11, 1992.
- [6] M.Hirano, et al., "Analyses of SGTR Event at Mihama-2", Presented at KINS/INS Meeting, March 10-11, 1992.
- [7] Gray E. Wilson, "Proposed CAMP Protocols", Presented at the second CAMP Meeting, Tractebel, Belgium, May 1993.

Table 1 Comparison of Initial Conditions

Parameters	LSTF SB-SG-06 Measured		RELAP5/MOD3.1 Case 1		RELAP5/MOD3.1 Case 2	
Primary Coolant System	(Intact : Broken)		(Intact : Broken)		(Intact : Broken)	
Hot leg temperature (K)	587.4	585.9	586.02	586.02	586.0	586.0
Cold leg temperature (K)	560.5	560.0	560.85	560.76	560.74	560.72
Loop mass flow rate (kg/s)	34.65	33.84	36.580	35.478	36.579	35.480
Core mass flow rate (kg/s)	-		71.707		71.708	
Pump speed (rad/s)	128.3	124.3	128.3	124.3	128.3	124.3
Core power (MW)	10		10		10	
Pressurizer						
Pzr. pressure (MPa)	15.38		15.380		15.380	
Pzr. water level (m)	2.64		2.680		2.679	
Pzr. temperature (K)	-		616.28		616.28	
Secondary Coolant System						
SG steamdome pres.(MPa)	6.89	6.89	6.858	6.860	6.857	6.860
SG steam dome temp.(K)	-		557.56	557.58	557.55	557.57
SG steam flow rate (kg/s)	2.68	2.58	2.799	2.722	2.741	2.673
Main feed flow rate (kg/s)	-		2.7447	2.6701	2.7692	2.7244
SG downcomer water level (m)	9.22	9.19	9.251	9.273	9.251	9.271

* Case 1 : averaged U-tube model (regarded as Base Case)

* Case 2 : single broken U-tube and averaged U-tube model

Table 2 Setpoints and Conditions used in RELAP5/MOD3.1 Calculation

Events	Setpoints and Conditions
-Tube Break	-Break valve open at $t=0$
-Reactor Trip	- $P_{Pzr} < 13.42$ MPa -Experimental core power decay curve
-Main Feedwater Trip	- $P_{Pzr} < 12.97$ MPa
-Safety Injection Signal (SI)	- $P_{Pzr} < 12.87$ MPa
-Pump Coastdown	-Experimental coastdown curve
-IL RCP Restarted	-Rx Trip+3979s
-HPSI Flow rate	-Experimental pressure vs. flow rate curve
-HPSI into Cold legs	-Safety injection from SI+98s, plus charging
-HPSI into Core Upper Plenum	-Safety injection from SI+300s
-HPSI Turned off (stop)	-Pzr water level recovered - HPSI-CL: $L_{Pzr} > 1.0$ m - HPSI-UP: SI+2900s - Charging: no termination(0.265kg/s)
-Accumulator Injection	-Not used
-LPSI System	-Not used
-Aux. Feedwater Start	-BL: hot water: 1.14kg/s for 81s from SI+37s cold water: none -IL: hot water: 1.5kg/s for 200s from SI+37s cold water: 1.0kg/s from SI+237s until $L_{IL-SG} > 12.85$ m
-Affected SG Isolation	-BL-MSIV close from Rx Trip+722s
-Intact SG Depressurization	-IL-RV open from Rx Trip+722s
-Intact SG Depres. Termination	-IL-RV close if ($T_{IL-hotleg} < 531.4$ K)
-Affected SG RV Cycling	-6.4 MPa $< P_{BL-SGdome} < 7.3$ MPa
-SG Safety Valves Cycling	-7.69 MPa $< P_{BL-SGdome} < 8.68$ MPa
-Pzr. Aux. Spray Flow rate	-0.1 kg/s
-Pzr. Aux. Spray Start	-Rx Trip+2666s
-Pzr. Aux. Spray Turned off	- $P_{Pzr} = P_{IL-SGdome}$

Table 3 Event Sequences of SGTR Transient

Major Events (unit : second)	LSTF SB-SG-06	RELAP5/MOD3.1	
		(Case 1)	(Case 2)
- Tube Break	0	0	0
- Reactor Trip	266	251	246
- Main Feedwater Trip	300	280	280
- Safety Injection Signal	305	289	287
- Pzr. Empty	331	335	335
- Pump Coastdown	348	331	326
- Aux. Feedwater Start	342	326	324
- HPSI into Cold legs	403	387	385
- HPSI into Core Upper Plenum	605	589	587
- Affected SG Isolated(MSIV close)	988	973	971
- Intact SG Depressurized(RV open)	988	973	971
- Intact SG Depressurization Terminated (RV close)	1751	1744	1740
- Affected SG RV Opened	2635(once)	cycling	cycling
- Pzr. Aux. Spray Start	2932	2917	2915
- HPSI Turned off (stop)	3390	3390	3390
- Pzr. Aux. Spray Turned off	3617	3527	3742
- Intact Loop RCP Restarted	4245	4230	4225
- Termination	5000	5000	5000

* Case 1 : break nozzle model based on SB-SG-06 test configuration
(regarded as Base Case)

* Case 2 : break valve model with single averaged and broken U-tube

Table 4 Lists of Measured Data and Corresponding Calculated Parameters

Items	Origin of Measured Data	Full Scale Accuracy*	Calculated Parameters
-Primary pressure	Ref. 3 & 5	0.32 FS	p-610010000
-Secondary pressure	Ref. 3 & 5	0.32 FS	p-516010000, p-316010000
-Core inlet temperature	not used	-	tempf-120010000
-Core mid temperature	Ref. 5	0.616 FS	tempf-124030000
-Core outlet temperature	not used	-	tempf-128010000
-RCS saturation temperature	Ref. 3 & 5	0.777 FS	sattemp-200010000
-Steam dome steam temperature	unavailable	-	tempg-516010000
-SG saturation temperature	unavailable	-	sattemp-516010000
-SG water temperature	unavailable	-	tempf-504040000
-Intact loop hot leg temperature	Ref. 5	0.616 FS	tempf-206010000
-Broken loop hot leg temperature	Ref. 5	0.616 FS	tempf-406010000
-Pzr water level	Ref. 5	0.32 FS	cntrlvar 610
-SG water level	Ref. 3	0.32 FS	cntrlvar 312, 512
-Intact loop mass flow rate	Ref. 5	1.12 FS	mflowj-206020000
-Broken loop mass flow rate	Ref. 5	1.12 FS	mflowj-406020000
-HPSI-up mass flow rate	Ref. 5	1.62 FS	mflowj-722000000
-HPSI-cold legs mass flow rate	Ref. 5	1.62 FS	cntrlvar 922
-Break mass flow rate	Ref. 5	1.12 FS	cntrlvar 916
-Integrated break & HPSI flow	unavailable	-	cntrlvar 915, 921
-Intact SG feedwater flow rate	unavailable	-	cntrlvar 917
-Broken SG feedwater flow rate	unavailable	-	cntrlvar 918
-Pzr aux spray mass flow rate	unavailable	-	mflowj-612000000
-Steam dump flow rate	unavailable	-	mflowj-369000000
-Heat flux on U-tube wall	unavailable	-	htnr-420100101
-Heat flux on steam dome wall	unavailable	-	htnr-500300400
-Flow rate in Pzr surge line	unavailable	-	mflowj-206040000
-Void fraction in Pzr surge line	unavailable	-	voidg-600030000

* Detailed Information was described in Ref. 2

Table 5 Comparison of Integrated Total Mass Flows during Transient

Mass Flows (unit : kg)	LSTF SB-SG-06	Case 1	Case 2 (RELAB5/MOD3.1)		
			Cd=0.15	Cd=0.18	Cd=0.20
- Total break flow into secondary side	about 2600	3177	3212	3482	3765
- Total HPSI flow into RCS (up/cl)	about 2900 (1000/1900)	3497 (1216/2281)	3535	3947 (1373/2574)	4248
- Discharged steam flow through MSL	about 1200	1277	-	1185	-
- Discharged steam flow through RV	about 20	133	-	153	-
- Aux. Feedwater flow into SG	about 500	669	-	605	-

* Case 1 : break nozzle model based on SB-SG-06 test configuration

* Case 2 : break valve model with single averaged and broken U-tube




Figure 1 ROSA-IV LSTF Flow Diagram





Figure 2 RELAP5 Nodalization of ROSA-IV LSTF for SGTR Transient Assessment

(LSTFND-2 INCT)

(1) Case 1 (Base Case): Break Nozzle Model Based on Facility Configuration



(2) Case 2 : Break Valve Model with Single Averaged and Broken U-Tube




Figure 3 Break Simulation and Nodalization




Figure 4 Break Line Configuration in LSTF SB-SG-06 Test

Figure 5 Comparison of Primary Pressure between Experiment and Calculation




Figure 6 Comparison of Secondary Pressures between Experiment and Calculation




Figure 7 Comparison of Core Fluid Temperatures




Figure 8 Comparison of Broken Loop Secondary Side Fluid Temperatures




Figure 9 Comparison of Intact Loop Hot leg Temperature




Figure 10 Comparison of Broken Loop Hot leg Temperature




Figure 11 Comparison of Pressurizer Water Level




Figure 12 Comparison of SG Water Levels




Figure 13 Comparison of Intact Loop Mass Flow rate




Figure 14 Comparison of Broken Loop Mass Flow rate




Figure 15 Comparison of HPSI-core upper plenum Mass Flow rate




Figure 16 Comparison of HPSI-cold legs Mass Flow rate




Figure 17 Comparison of Break Mass Flow rate between Experiment and Calculation




Figure 18 Integrated Break Mass Flow and HPSI Mass Flow




Figure 19 The Calculated Feedwater Flow rate in Intact Loop Secondary Side




Figure 20 The Calculated Feedwater Flow rate in Broken Loop Secondary Side




Figure 21 The Pressurizer Auxiliary Spray Mass Flow rate




Figure 22 The Atmospheric Steam Dump Flow rate through Intact Loop Relief Valve




Figure 23 The Calculated Heat Flux on U-tube Wall in Broken Loop SG




Figure 24 The Calculated Heat Flux on Steamdome Wall in Broken Loop SG




Figure 25 The Calculated Flow rate on Pressurizer Surge Line




Figure 26 The Calculated Void Fraction in Pzr Surge Line and Hot Leg




Figure 27 Comparison of Primary Pressure between MOD3.0 and MOD3.1




Figure 28 Comparison of Break Mass Flow rates on Break Simulation Model




Figure 29 Comparison of Break Mass Flow rates on Break Discharge Coefficient




Figure 30 Comparison of CPU Times





Figure 31 Courant Time Step and Advanced Time Step Size



Appendix A Input Deck for Steady State Calculation


```

*****
*
= lstf sgtr base input deck with relap5/mod3.1
*
*****
*
0000100      new      stdy-st
*
0000101      run
0000102      si      si
0000105      1.0      2.0
*
0000110      nitrogen
0000115      1.0
*
0000120      124010000      0.00      h2o      primary
*0000121      504010000      7.9639      h2o      secndry
0000121      900010000      0.00      h2o      contain
*
* time step control
*
0000201      3000.0      1.0-6      0.5      3      10      200      200
*
*****
* minor edits
*****
*
301 p      610010000      *pzs pressure
302 p      516010000      *sg-b steam pressure
303 p      316010000      *sg-i steam pressure
304 mflowj      208010000      *loop-i hot leg flow
305 mflowj      408010000      *loop-b hot leg flow
306 mflowj      248010000      *loop-i cold leg flow
307 mflowj      452010000      *loop-b cold leg flow
308 mflowj      108010000      *core bypass flow
309 mflowj      120010000      *core inlet flow
310 tempf      104010000      *vessel inlet temp
311 tempf      136010000      *vessel outlet temp
312 tempf      120010000      *core inlet temp
313 tempf      128010000      *core outlet temp
314 tempf      316010000      *sg-i steam temp
315 tempf      516010000      *sg-b steam temp
316 prmpvel      240
317 prmphead      240
318 prmpvel      440
319 prmphead      440
320 cntrlvar      512      *sg-b wr level
321 cntrlvar      508      *sg-b nr level

```

```

322 cntrlvar      504      *sg-b boiling water level
323 cntrlvar      312      *sg-i wr level
324 cntrlvar      308      *sg-i nr level
325 cntrlvar      304      *sg-i boiling water level
326 cntrlvar      610      *pzs level
327 cntrlvar      720      *primary mass
328 cntrlvar      309      *sg-i mass
329 cntrlvar      509      *sg-b mass
*
*****
* variable trips
*****
*
0000501 p      610010000      lt      null      0      1.342e+7      l *rx scram signal
0000502 time      0      ge      null      0      1.e6      l *power
0000505 p      610010000      lt      null      0      1.287e+7      l *rcp&si
0000506 time      0      ge      timeof      505      17.0      l *lpsi delay
0000507 time      0      ge      null      0      1.0e6      n *rcp delay
0000510 time      0      ge      timeof      505      10.0      l *il hpi
0000511 time      0      ge      timeof      505      300.0      l *il hppi to up
0000512 time      0      ge      timeof      505      10.0      n *bl hpi
0000514 cntrlvar      30      ge      cntrlvar      31      0.0      n *mean temp
0000516 cntrlvar      30      lt      cntrlvar      31      0.0      n
0000520 p      610010000      ge      null      0      1.646e+7      l *high pres
0000522 p      610010000      ge      null      0      1.726e+7      n *pzs sfty
0000524 p      610010000      ge      null      0      1.568e+7      n *pzs spry
0000526 p      610010000      gt      null      0      1.607e+7      n *porv
0000528 p      610010000      gt      null      0      1.620e+7      n
0000529 time      0      ge      null      0      0.0      l *pzs prp. htrs
0000530 p      610010000      lt      null      0      1.540e+7      n *pzs bkup htrs
0000531 p      610010000      lt      null      0      1.534e+7      n
0000532 cntrlvar      610      lt      null      0      0.25656      n *lo nrm pr lvl
0000535 time      0      ge      null      0      1000.0      l *tube break
0000536 time      0      ge      null      0      0.0      l *bl flow
0000537 time      0      lt      null      0      0.0      l *valve
0000538 time      0      lt      null      0      0.0      l *il flow
0000539 time      0      lt      null      0      0.0      l *valve
0000540 time      0      le      null      0      10000.0      n
0000550 p      610010000      ge      null      0      1.297e+7      l *main feed
0000552 time      0      ge      timeof      505      44.0      l *aux fed
*0000553 time      0      le      timeof      552      200.0      l *auxfeed
0000554 cntrlvar      308      lt      null      0      0.44      n *aux feed
0000555 cntrlvar      508      lt      null      0      0.44      n
*0000556 time      0      le      timeof      552      81.0      l *auxfeed
0000560 p      316010000      gt      null      0      7.82e+6      n *bl sg rel
0000561 p      316010000      gt      null      0      8.2e+6      n
0000564 p      316010000      gt      null      0      7.69e+6      n *bl sg saf
0000565 p      316010000      gt      null      0      8.68e+6      n

```

0000568	time	0	lt	null	0	0.0	n * bl msiv	*										
0000569	p	316010000	lt	null	0	4.235e+6	l	*****										
0000570	p	516010000	gt	null	0	7.82e+6	n * il sg rel	* reactor vessel										
0000571	p	516010000	gt	null	0	8.2e+6	n	*****										
0000574	p	516010000	gt	null	0	7.69e+6	n * il sg saf	1000000	inannl	snglvol								
0000575	p	516010000	gt	null	0	8.68e+6	n	1000101	0.0	1.5684	0.13609	0.0	-90.	-1.5684				
0000578	time	0	lt	null	0	0.0	n * il msiv	1000102	4.57e-5	0.106	00							
0000579	p	516010000	lt	null	0	4.235e+6	l	1000200	003	15479968.	569.1							
0000580	cntrlvar	308	lt	null	0	0.25	l * low sg lev	*										
0000581	cntrlvar	508	lt	null	0	0.25	l	*****										
0000583	time	0	ge	null	0	0.0	n * stm hdr vlv	1040000	inann	branch								
0000585	time	0	lt	null	0	0.0	n * stm thrd	1040001	4	0								
0000586	time	0	ge	null	0	11.0	n * valve	1040101	0.0	0.600	0.05425	0.0	-90.0	-0.600	4.57e-5			
0000599	time	0	lt	null	0	1000.0	n * ss pres	1040102	0.106	00								
*****								1040200	003	15487916.	560.4							
* logical trips								1041101	104000000	100010000	0.0		0.0	0.0	0000			
*****								1042101	104010000	108000000	0.0		0.0	0.0	0000			
0000601	-603	and	571	n	*	il sec relief valve		1043101	252010000	104000000	0.03365	0.345	0.345	0101				
0000602	603	and	570	n				1044101	452010000	104000000	0.03365	0.345	0.345	0101				
0000603	601	or	602	n				1041201	5.42622-3	5.42622-3	0.0				*	24192712		
0000604	-606	and	575	n	*	il sec safety valve		1042201	1.0373539	1.0373539	0.0				*	48.158681		
0000605	606	and	574	n				1043201	1.4005447	1.4005447	0.0				*	24.199945		
0000606	604	or	605	n				1044201	1.4006109	1.4006109	0.0				*	24.200657		
0000607	-609	and	561	n	*	bl sec relief valve		*										
0000608	609	and	560	n				*****										
0000609	607	or	608	n				1080000	downcmer	annulus								
0000610	-612	and	565	n	*	bl sec safety valve		1080001	9									
0000611	612	and	564	n				1080101	0.09774	9								
0000612	610	or	611	n				1080301	0.6757	1								
0000613	-615	and	528	n	*	porv		1080302	0.8670	2								
0000614	615	and	526	n				1080303	0.610	8								
0000615	613	or	614	n				1080304	1.2588	9								
0000620	580	or	581	l	*	reactor trip		1080601	-90.0	9								
0000621	520	or	620	l				1080701	-0.6757	1								
0000622	621	or	501	l				1080702	-0.8670	2								
0000623	552	and	554	n	*	sg aux feed, bl		1080703	-0.610	8								
0000624	552	and	555	n	*	, il		1080704	-1.2588	9								
0000625	-586	or	-586	n	*	steam sink pressure		1080801	4.573e-5	0.106	9							
0000626	579	or	568	l	*	hpi		1081001	00	9								
0000627	626	or	505	l				1081101	0000	8								
0000630	-632	and	531	n	*	p2r backup heater cntl		1081201	003	15482417.	560.5	0.0	0.0	0.0	1			
0000631	632	and	530	n				1081202	003	15498051.	560.5	0.0	0.0	0.0	2			
0000632	630	or	631	n				1081203	003	15493443.	560.5	0.0	0.0	0.0	3			
0000633	-505	and	-532	n	*	p2r htrs off on sis or low p2r lvl		1081204	003	15497895.	560.5	0.0	0.0	0.0	4			
0000634	632	and	633	n	*	p2r htrs off on low p2r level		1081205	003	15502346.	560.5	0.0	0.0	0.0	5			
*****								1081206	003	15506796.	560.5	0.0	0.0	0.0	6			
* hydrodynamic components								1081207	003	15511245.	560.5	0.0	0.0	0.0	7			
*****								1081208	003	15515694.	560.5	0.0	0.0	0.0	8			

1081209	003	15522509.	560.5	0.	0.	0.	0.	9	1240401	0.07312	6								
1081300	0								1240601	90.0	6								
1081301	.96071571	.96071571	0.0	1				* 48.158687	1240701	0.610	6								
1081302	.96098280	.96098280	0.0	2				* 48.158693	1240801	4.57e-5	0.00832	6							
1081303	.96122606	.96122606	0.0	3				* 48.158697	1240901	0.68	0.68	5							
1081304	.96145084	.96145084	0.0	4				* 48.158699	1241001	00100	6								
1081305	.96163484	.96163484	0.0	5				* 48.158700	1241101	0000	5								
1081306	.96176032	.96176032	0.0	6				* 48.158700	1241201	003	15513996.	563.05	0.	0.	0.	0.	1		
1081307	.96182512	.96182512	0.0	7				* 48.158698	1241202	003	15518831.	567.6	0.	0.	0.	0.	2		
1081308	.96184417	.96184417	0.0	8				* 48.158695	1241203	003	15503749.	574.15	0.	0.	0.	0.	3		
*									1241204	003	15508764.	580.70	0.	0.	0.	0.	4		
*****									1241205	003	15493863.	584.25	0.	0.	0.	0.	5		
1120000	lplovol	snglvol							1241206	003	15499012.	586.5	0.	0.	0.	0.	6		
1120101	0.0	0.626	0.1661	0.0	90.0	0.626	4.57e-5		1241300	0									
1120102	0.0104	00							1241301	1.4034412	1.4034412	0.0	1				* 48.158578		
1120200	003	15532812.	560.5						1241302	1.4215501	1.4215501	0.0	2				* 48.158541		
*									1241303	1.4586451	1.4586451	0.0	3				* 48.158496		
*****									1241304	1.4601781	1.4601781	0.0	4				* 48.158441		
1160000	lowrplnm	branch							1241305	1.4627423	1.4627423	0.0	5				* 48.158378		
1160001	3	0							1241401	0.00832	1.0	1.0	1.0	5					
1160101	0.0	0.4762	0.0943	0.0	90.0	0.4762	4.57e-5		*										
1160102	0.0104	00							*****										
1160200	003	15538774.	560.5						1280000	creoutlt	branch								
1161101	108010000	116010000	0.09774	1.0	1.0	0100			1280001	3	0								
1162101	112010000	116000000	0.23623	0.0	0.0	0000			1280101	0.0	0.867	0.1522	0.0	90.0	0.867	4.57e-5			
1163101	116010000	120000000	0.15931	8.34	8.34	0000			1280102	0.0	00								
1161201	.96183851	.96183851	0.0					* 48.158680	1280200	003	15480901.	586.5							
1162201	.167004-9	.167679-9	0.0					* 17.0061-9	1281101	124010000	128000000	0.15255	1.272	1.272	0000				
1163201	.90531130	.90531130	0.0					* 48.158664	1282101	1280									

```

1360200 003 15481715. 586.5
1361101 136000000 200000000 0.05520 0.265 0.265 0102 1560000 gdetub pipe
1362101 136000000 400000000 0.05520 0.265 0.265 0102 1560001 2
1363101 132010000 136000000 0.15669 0.0 0.0 0000 1560101 0.0 2
1364101 140000000 136010000 0.14305 0.0 0.0 0000 1560201 0.0102 1
1365101 104000000 136000000 1.0e-4 40. 40. 0103 1560301 1.9260 1
1361201 .95933557 .95933557 0.0 * 24.200218 1560302 1.6431 2
1362201 .95930429 .95930429 0.0 * 24.199069 1560401 0.06209 1
1363201 .67669046 .67669046 0.0 * 48.399714 1560402 0.06286 2
1364201 -5.8944-6 -5.8944-6 0.0 * -326.21-6 1560601 -90.0 2
1365201 0.802075 0.802175 0.0 * 0.041000 1560701 -1.9260 1
1363110 0.321 1.0 1.0 1.0 1560702 -1.6431 2
1364110 0.321 1.0 1.0 1.0 1560801 4.57e-5 0.0 2
* 1560901 3.34 3.34 1
***** 1561001 00 2
1400000 uptopvol snglvol 1561101 0000 1
1400101 0.0 0.3674 0.0445 0.0 90.0 0.3674 4.57e-5 1561201 003 15469815. 578. 0. 0. 0. 1
1400102 0.321 00 1561202 003 15472498. 584. 0. 0. 0. 2
1400200 003 15488458. 577.5 1561300 0
* 1561301 .04675404 .04675404 0.0 1 * 24169252
*****
1400000 tophat snglvol * loop with pressurizer (broken loop)
1440101 0.0 0.897 0.1655 0.0 90.0 0.897 4.57e-5 *****
1440102 0.95 00 *
1440200 003 15461376. 577.0
*
*****
1480000 uhmldvol branch
1480001 2 0
1480101 0.0 0.725 0.1970 0.0 90.0 0.725 4.57e-5
1480102 0.256 00
1480200 003 15455440. 576.0
1481101 100000000 148000000 9.5e-5 0.0 0.0 0100 *uh/dc leak
1482101 144010000 148000000 0.0 0.0 0.0 0000
1481201 5.44012-3 5.44012-3 0.0 * 24180655
1482201 -519.36-9 -519.32-9 0.0 * -49.179-6
*
*****
1520000 uhtopvol branch
1520001 2 0
1520101 0.0 0.504 0.1475 0.0 90.0 0.504 4.57e-5
1520102 0.0 00
1520200 003 15450939. 576.0
1521101 148010000 152000000 0.0 0.0 0.0 0000
1522101 152000000 156000000 0.00199 1.472 1.472 0000
1521201 1.73108-3 1.73108-3 0.0 * 24167128
1522201 .23663527 23663526 0.0 * 24176700
*
*****
2000000 nphotleg snglvol
2000101 0.0337 1.3246 0.0 0.0 0.0 0.0 4.57e-5 0.207 00
2000200 003 15471308. 586.5
*
*****
2020000 blhlbyps branch
2020001 1 0
2020101 3.53e-4 2.65 0.0 0.0 0.0 0.0 4.57e-5 0.0 00
2020200 003 15481269. 560.5
2021101 104010000 202000000 3.53e-4 0.0 0.0 0100
2021201 0.0 0.0 0.0
*
*****
2030000 blhlbyp valve
2030101 202010000 204000000 3.53e-4 27.6 27.6 0100
2030201 0 0.913 0.913 0.0
2030300 srvvlv
2030301 203
*
*****
2040000 blhlbyps branch
2040001 1 0
2040101 3.53e-4 1.66 0.0 0.0 90.0 0.30 4.57e-5 0.0 00
2040200 003 15471269. 558.5

```

2041101	204010000	200000000	3.53e-4	0.0	0.0	0.0101				2130101	212010000	216000000	0.2093	0.0	0.0	0000
2041201	0.0	0.0	0.0							2130201	0	25232836	25232836	0.0		* 24.199962

2060000	wphotleg	branch								2160000	npsgfb	snglvol				
2060001	3	0								2160101	0.0	1.1035	0.2323	0.0	90.0	1.1035 4.57e-5
2060101	0.0337	1.3195	0.0	0.0	0.0	0.0	4.57e-5	0.207	00	2160102	0.4474	00				
2060200	003	15471270.	586.5							2160200	003	15460476.	586.5			
2062101	200010000	206000000	0.0337		0.0	0.0	0000			*****						
2063101	206010000	208000000	0.0337		0.0	0.0	0000			2170000	npsgin	sngljun				
2064101	600010000	206010000	0.00352		1.0	0.5	0001			2170101	216010000	220000000	0.0425		0.0	0.0 100100
2062201	1.5682911	1.5682911	0.0					* 24.199021		2170110	0.	0.	0.725	1.		
2063201	1.5683730	1.5683730	0.0					* 24.200785		2170201	0	1.2407596	1.2407596	0.0		* 24.199843
2064201	1154.53-6	1154.53-6	0.0					* 1.80819-3		*****						

2080000	wphotleg	pipe								2200000	npsgtube	pipe				
2080001	2									2200001	8					
2080101	0.0337	2								2200101	0.0425	8				
2080301	0.7043	1								2200301	2.8724	1				
2080302	0.5278	2								2200302	2.5654	3				
2080601	0.0	1								2200303	2.1728	5				
2080602	50.0	2								2200304	2.5654	7				
2080701	0.0	1								2200305	2.8724	8				
2080702	0.4043	2								2200601	90.0	4				
2080801	4.57e-5	0.207	2							2200604	-90.0	8				
2080901	0.05	0.05	1							2200701	2.8724	1				
2081001	00	2								2200702	2.5654	3				
2081101	100000	1								2200703	2.0980	4				
2081201	003	15471238.	586.5	0.0	0.0	0.1				2200704	-2.0980	5				
2081202	003	15479897.	586.5	0.0	0.0	0.2				2200705	-2.5654	7				
2081300	0									2200706	-2.8724	8				
2081301	1.5683412	1.5683412	0.0		1			* 24.200096		2200801	1.524-6	0.0196	8			
2081401	0.	0.	0.55	0.785	1					2200901	0.0	0.0	3			

2090000	nphotleg	sngljun								2200902	0.006	0.0	4			
2090101	208010000	212000000	0.0337		0.0	0.0	0100			2200903	0.006	0.006	5			
2090201	0	1.5683441	1.5683441	0.0				* 24.200078		2200904	0.0	0.006	6			

2120000	npsgin	snglvol								2200905	0.0					

2201300	0									2320703	0.0	5					
2201301	1.1888998	1.1568998	0.0	1						* 24.199823	2320801	4.57e-5	0.1682	5			
2201302	1.1564485	1.1564485	0.0	2						* 24.199820	2320901	0.036	0.036	1			
2201303	1.1372354	1.1372354	0.0	3						* 24.199823	2320902	0.0	0.0	3			
2201304	1.1276379	1.1276379	0.0	4						* 24.199828	2320903	0.065	0.065	4			
2201305	1.1209604	1.1209604	0.0	5						* 24.199833	2321001	00	5				
2201306	1.1142686	1.1142686	0.0	6						* 24.199839	2321101	0000	4				
2201307	1.1111250	1.1111250	0.0	7						* 24.199844	2321201	003	15466371.	560.5	0.0	0.0	1
*											2321202	003	15462314.	560.5	0.0	0.0	2
*****											2321203	003	15447133.	560.5	0.0	0.0	3
2210000	npsgout	sngljun									2321204	003	15480360.	560.5	0.0	0.0	4
2210101	220010000	224000000	0.0425	0.0	0.0	0100					2321205	003	15494826.	560.5	0.0	0.0	5
2210201	0	1.1089645	1.1089645	0.0						* 24.199848	2321300	0					
*											2321301	2.1244352	2.1244352	0.0	1		* 24.199886
*****											2321302	2.1244240	2.1244240	0.0	2		* 24.199890
2240000	npsgfbo	snglvol									2321303	2.1244071	2.1244071	0.0	3		* 24.199894
2240101	0.0	1.1035	0.2323	0.0	-90.0	-1.1035	4.57e-5				2321304	2.1243903	2.1243903	0.0	4		* 24.199899
2240102	0.4474	00									*						
2240200	003	15456792.	560.5								*****						
*											2330000	npfcv	valve				
*****											2330101	232010000	236000000	0.0222	0.0	0.0	0100
2250000	npsgfbo	sngljun									2330201	0	2.1243819	2.1243819	0.0		* 24.199903
2250101	224010000	228000000	0.2093	0.0	0.0	0000					2330300	mtrvlv					
2250201	0	2.2448286	2.2448286	0.0						* 24.199869	2330301	536	537	1.4200000	1.0000000	0	
*											*						
*****											*****						
2280000	npsgout	snglvol									2360000	npctrlu	pipe				
2280101	0.0	0.706	0.125	0.0	-90.0	-0.706	4.57e-5				2360001	4					
2280102	0.377	00									2360101	0.0222	4				
2280200	003	15463429.	560.5								2360301	1.3202	1				
*											2360302	1.1222	2				
*****											2360303	1.1417	3				
2290000	npctrlu	sngljun									2360304	1.1222	4				
2290101	228010000	232000000	0.0222	0.0	0.0	0100					2360601	0.0	1				
2290201	0	2.1244407	2.1244407	0.0						* 24.199885	2360602	90.0	4				
*											2360701	0.0	1				
*****											2360702	1.1222	4				
2320000	npctrlu	pipe									2360801	4.57e-5	0.1682	4			
2320001	5										2360901	0.065	0.065	1			
2320101	0.0222	5									2360902	0.0	0.0	3			
2320301	0.516	1									2361001	00	4				
2320302	1.2422	4									2361101	0000	3				
2320303	1.1919	5									2361201	003	15494735.	560.5	0.0	0.0	1
2320601	-50.0	1									2361202	003	15480528.	560.5	0.0	0.0	2
2320602	-90.0	4									2361203	003	15472206.	560.5	0.0	0.0	3
2320603	0.0	5									2361204	003	15463883.	560.5	0.0	0.0	4
2320701	-0.3953	1									2361300	0					
2320702	-1.2422	4									2361301	2.1243819	2.1243819	0.0	1		* 24.199907

```

2361302 2.1243895 2.1243895 0.0 2 * 24.199912 *
2361303 2.1244048 2.1244048 0.0 3 * 24.199916
*
*****
2400000 nprcpump pump
2400101 0.0 0.802 0.0235 0.0 90.0 0.351 0
2400108 236010000 0.0222 0.0 0.0 0000
2400109 244000000 0.0337 0.0525 0.0525 0000
2400200 003 15473807. 560.5
2400201 0 2.1244201 2.1244201 0.0 * 24.199921
2400202 0 1.3993350 1.3993350 0.0 * 24.199925
2400301 0 0 0 -1 0 0 0
2400302 188.50000 .680636 .05400000 10.000000 55.200000
2400303 0.54 750.0 0.0 0.0 0.0 0.0 0.0
*
*****
* single phase head and torque data from lstf sys. description
*****
*
2401100 1 1 0.00 1.36 0.10 1.38 0.24 1.42 0.40 1.41
2401101 0.60 1.32 0.80 1.19 1.00 1.00
2401200 1 2 0.00 -0.97 0.20 -0.68 0.50 -0.20 0.65 0.07
2401201 0.80 0.40 1.00 1.00
2401300 1 3 -1.0 3.20 -0.90 2.80 -0.80 2.46 -0.60 1.94
2401301 -0.40 1.57 -0.20 1.41 0.00 1.36
2401400 1 4 -1.00 3.20 -0.80 2.76 -0.60 2.41 -0.40 2.09
2401401 -0.20 1.81 0.00 1.58
2401500 1 5 0.00 0.00 1.00 0.00
2401600 1 6 0.00 0.00 1.00 0.00
2401700 1 7 -1.00 0.00 0.00 0.00
2401800 1 8 -1.00 0.00 0.00 0.00
*
* torque data
*
2401900 2 1 0.00 0.36 0.12 0.38 0.20 0.44 0.30 0.58
2401901 0.50 0.73 0.70 0.81 1.00 1.00
2402000 2 2 0.00 -1.26 0.10 -0.88 0.30 -0.31 0.50 0.09
2402001 0.65 0.30 0.86 0.63 1.00 1.00
2402100 2 3 -1.00 2.40 -0.85 1.70 -0.65 1.12 -0.50 0.84
2402101 -0.40 0.69 -0.20 0.59 0.00 0.36
2402200 2 4 -1.00 2.40 -0.80 2.12 -0.60 1.80 -0.30 1.32
2402201 0.00 0.80
2402300 2 5 0.00 0.00 1.00 0.00
2402400 2 6 0.00 0.00 1.00 0.00
2402500 2 7 -1.00 0.00 0.00 0.00
2402600 2 8 -1.00 0.00 0.00 0.00
*
* two phase multiplier tables for head of rc pump 240
*
2403000 0 0.0 0.0
2403001 0.10 0.0
2403002 0.15 0.05
2403003 0.24 0.80
2403004 0.30 0.96
2403005 0.40 0.98
2403006 0.60 0.97
2403007 0.80 0.90
2403008 0.90 0.80
2403009 0.96 0.50
2403010 1.00 0.0
*
* two phase multiplier tables for torque of rc pump 240
*
2403100 0 0.0 0.0
2403101 1.0 0.0
*
* two-phase diff curves from r5 built-in data
* head difference curves
*
2404100 1 1 0.00 0.00 0.10 0.83 0.20 1.09 0.50 1.02
2404101 0.70 1.01 0.90 0.94 1.00 1.00
2404200 1 2 0.00 0.00 0.10 -0.40 0.20 0.00 0.30 0.10
2404201 0.40 0.21 0.80 0.67 0.90 0.80 1.00 1.00
2404300 1 3 -1.00 -1.16 -0.90 -1.24 -0.80 -1.77 -0.70 -2.36
2404301 -0.60 -2.79 -0.50 -2.91 -0.40 -2.67 -0.25 -1.69
2404302 -0.10 -0.50 0.00 0.00
2404400 1 4 -1.00 -1.16 -0.90 -0.78 -0.80 -0.50 -0.70 -0.31
2404401 -0.60 -0.17 -0.50 -0.08 -0.35 0.00 -0.20 0.05
2404402 -0.10 0.08 0.00 0.11
2404500 1 5 0.00 0.00 1.00 0.00
2404600 1 6 0.00 0.00 1.00 0.00
2404700 1 7 -1.00 0.00 0.00 0.00
2404800 1 8 -1.00 0.00 0.00 0.00
*
* torque difference curves
*
2404900 2 1 0.0 0.0 0.0 0.0
2405000 2 2 0.0 0.0 0.0 0.0
2405100 2 3 0.0 0.0 0.0 0.0
2405200 2 4 0.0 0.0 0.0 0.0
2405300 2 5 0.0 0.0 0.0 0.0
2405400 2 6 0.0 0.0 0.0 0.0
2405500 2 7 0.0 0.0 0.0 0.0
2405600 2 8 0.0 0.0 0.0 0.0
*
* pump coastdown data

```

```

*
2406100 501 * norm speed
2406101 0.0 128.3 * 160.22
2406102 80.0 128.3 * 160.22
2406103 83.0 122.0 * 153.75
2406104 86.0 118.9 * 149.87
2406105 89.0 114.9 * 144.86
2406106 101.0 96.7 * 121.90
2406107 110.0 82.6 * 104.12
2406108 119.0 74.4 * 93.77
2406109 131.0 63.4 * 79.86
2406110 140.0 56.7 * 71.46
2406111 149.0 51.8 * 65.31
2406112 161.0 46.3 * 58.36
2406113 170.0 41.7 * 52.54
2406114 179.0 38.2 * 48.18
2406115 191.0 34.8 * 43.81
2406116 200.0 32.3 * 40.74
2406117 209.0 30.0 * 37.38
2406118 221.0 27.3 * 34.43
2406119 230.0 25.3 * 31.85
2406120 239.0 23.2 * 29.26
2406121 251.0 21.4 * 27.00
2406122 260.0 20.3 * 25.54
2406123 269.0 19.0 * 23.92
2406124 281.0 16.3 * 20.53
2406125 290.0 14.6 * 18.43
2406126 299.0 12.4 * 15.60
2406127 320.0 9.9 * 12.48
2406128 341.0 7.4 * 9.36
2406129 359.0 5.0 * 6.24
2406130 380.0 2.5 * 3.12
2406131 400.0 0.0
2406132 1000.0 0.0
*
*****
2440000 wpcolleg snglvol
2440101 0.0337 1.0562 0.0 0.0 0.0 0.0 457e-5 0.207 00
2440200 003 15487643. 560.5
*
*****
2480000 wpcolleg branch
2480001 3 0
2480101 0.0337 1.1945 0.0 0.0 0.0 0.0 457e-5 0.207 00
2480200 003 15487614. 560.5
2481101 244010000 248000000 0.0337 0.0 0.0 0000
2482101 248010000 252000000 0.0337 0.0 0.0 0000
2483101 790010000 248010000 0.0060 1.0 0.5 0001

2481201 1.3993524 1.3993524 0.0 * 24200649
2482201 1.3993528 1.3993528 0.0 * 24200653
2483201 .574788-9 .574777-9 0.0 * 2.38120-9
*
*****
2520000 wpcolleg snglvol
2520101 0.0337 1.3125 0.0 0.0 0.0 0.0 457e-7 0.207 00
2520200 003 15487585. 560.5
*
*****
* secondary loop for the broken loop
*
*****
3000000 npstgdcn annulus
3000001 5
3000101 0.0 1
3000102 0.0296 4
3000103 0.0 5
3000201 0.0 3
3000202 0.005281 4
3000301 2.8965 1
3000302 2.0980 2
3000303 2.5654 4
3000304 3.4395 5
3000401 0.3228 1
3000402 0.0 4
3000403 0.1302 5
3000501 0.0 5
3000601 -90.0 5
3000701 -2.0223 1
3000702 -2.0980 2
3000703 -2.5654 4
3000704 -2.5464 5
3000801 457e-5 0.3689 1
3000802 457e-5 0.0971 4
3000803 457e-5 0.0801 5
3000901 0.0 0.0 4
3001001 00 5
3001101 0000 3
3001102 0100 4
3001201 003 6850719. 546. 0. 0. 0. 1
3001202 003 6865934. 546. 0. 0. 0. 2
3001203 003 6883272. 546. 0. 0. 0. 3
3001204 003 6912349. 546. 0. 0. 0. 4
3001205 003 69371666. 546. 0. 0. 0. 5
3001300 0
3001301 .61390359 .61390359 0.0 1 * 13.834317

```

3001302	.61389325	.61389325	0.0	2	* 13.834278	*
3001303	.61387866	.61387866	0.0	3	* 13.834214	*****
3001304	.61386007	.61386007	0.0	4	* 13.834133	3080000 npsepar separatr
*						3080001 3 0
*****						3080101 0.0 2.120 0.572 0.0 90.0 2.120 4.57e-5
3010000 npstgdcn sngljun						3080102 0.2134 00
3010101 300010000 304000000 0.0 100.0 100.0 0000						3080200 0 6844590.2 1263471.6 2580768.1 50638217
3010201 0 .48038520 .69708130 0.0 * 13.833941						3081101 308010000 316000000 0.0615 0.0 0.0 0100 0.2
*						3082101 308000000 300000000 0.03964 100.0 100.0 0000
*****						3083101 304010000 308000000 0.1986 0.0 0.0 0000
3040000 blsteamg pipe						3081201 -.3840036 .27406855 0.0 * 2.7469745
3040001 5						3082201 .37743398 -1.777076 0.0 * 11.041964
3040101 0.2293 3						3083201 .11701332 1.0458935 0.0 * 13.801835
3040102 0.0 5						*
3040201 0.2293 2						*****
3040202 0.2323 3						3120000 npsgsbp branch
3040203 0.3138 4						3120001 2 0
3040301 2.5464 1						3120101 0.0 2.120 0.6288 0.0 90.0 2.120 4.57e-5
3040302 2.5654 3						3120102 0.1242 00
3040303 2.0980 4						3120200 0 6841893.0 1236857.5 2584233.4 .87891994
3040304 2.0223 5						3121101 300000000 312000000 0.3164 0.0 0.0 0000
3040401 0.0 3						3122101 312010000 316000000 0.0392 1.5 1.5 0000
3040402 0.4951 4						3121201 30.0480-6 1.1555824 0.0 * 7.23798-3
3040403 0.7979 5						3122201 -42.50990 -1.5229-3 0.0 * -2.6126-3
3040501 0.0 5						*
3040601 90.0 5						*****
3040701 2.5464 1						3160000 stndome snglvol
3040702 2.5654 3						3160101 0.0 3.7778 2.0288 0.0 90.0 3.7778 4.57e-5
3040703 2.0980 4						3160102 0.7696 00
3040704 2.0223 5						3160200 0 6849946.7 1262926.9 2580859.5 .99999968
3040801 4.57e-5 0.036 4						*
3040802 4.57e-5 0.219 5						*****
3040901 1.435 1.435 4						* blsg steam line
3041001 00 5						*****
3041101 0000 3						3200000 blstm1n1 branch
3041102 0000 4						3200001 2 0
3041201 0 6900485.9 1261112.3 2580244.6 14219192 0.0 1						3200101 0.0286 5.286 0.0 0.0 0.0 0.0 4.57e-5
3041202 0 6887036.6 1264931.2 2580399.8 28828728 0.0 2						3200102 0.1909 00
3041203 0 6874704.9 1264683.5 2580530.3 28643954 0.0 3						3200200 0 6849057.2 1262882.9 2580880.3 .99999786
3041204 0 6863302.6 1264128.3 2580649.9 27887377 0.0 4						3201101 316010000 320000000 0.0286 0.0 0.0 0100
3041205 0 6853423.5 1263801.8 2580702.3 27518532 0.0 5						3202101 320010000 324000000 0.0286 0.0 0.0 0000
3041300 0						3201201 2.4791454 2.5876488 0.0 * 2.7470311
3041301 .09940788 .37087476 0.0 1 * 13.810074						3202201 2.4234202 2.5881767 0.0 * 2.7472440
3041302 .11458638 .49504010 0.0 2 * 13.804585						*
3041303 .10794204 .71300003 0.0 3 * 13.802420						*****
3041304 .09899163 .87128853 0.0 4 * 13.799040						3240000 blstm1n2 branch
3041401 0.036 1.0 1.0 1.0 3						3240001 1 0
3041402 0.1258 1.0 1.0 1.0 4						3240101 0.0286 9.9213 0.0 0.0 0.0 0.0 4.57e-5

```

3240102 0.1909 00
3240200 0 6848966.1 1262878.4 2580896.2 .99999675
3241101 324010000 328000000 0.00429 0.0 0.0 0000
3241201 14.028836 17.257852 0.0 * 2.7477108
*
*****
3280000 blstmln3 snglvol
3280101 0.00429 8.3215 0.0 0.0 0.0 0.0 4.57e-5
3280102 0.0739 00
3280200 0 6828063.0 1262339.0 2580962.3 .99998690
*
*****
3290000 blmsiv valve
3290101 328010000 332000000 0.00429 0.0 0.0 0100
3290201 0 12.637699 17.284590 0.0 * 2.7477202
3290300 mtrvlv
3290301 568 501 2.0000000 1.0000000 0
*
*****
3320000 vlvtoiv snglvol
3320101 0.00429 6.446 0.0 0.0 0.0 0.0 4.57e-5
3320102 0.0739 00
3320200 0 6828346.0 1261857.2 2581064.5 .99997696
*
*****
3330000 blchkvl valve
3330101 332010000 804000000 0.00429 0.0 0.0 0000
3330201 0 10.389571 17.310434 0.0 * 2.7477882
3330300 chkvlv
3330310 0 0 0.0 0.0
*
*****
3500000 auxfed tmdpvvol
3500101 8.0 5.0 0.0 0.0 0.0 0.0 0 0 00
3500200 3
3500201 0.0 5.95300e+6 313.0
*
*****
3510000 auxfed tmdpjvun
3510101 350000000 300000000 0.004
3510200 1 623
3510201 0.0 0.0 0.0 0.0
3510202 0.01 1.500 0.0 0.0
3510203 5000.0 1.500 0.0 0.0
*
*****
3600000 npstegfv tmdpvvol
3600101 0.139 5.0 0.0 0.0 0.0 0.0 0 0 00
3600200 3

```

```

3600201 0.0 5.83400e+6 -495.35
*
*****
3610000 npstegfv tmdpjvun
3610101 360000000 300000000 4.00e-3
3610200 1 550 cntrivar 361
3610201 0.0 0.0 0.0 0.0
3610202 5.0 5.0 0.0 0.0
3610203 7.0 7.0 0.0 0.0
3610204 1000.0 7.0 0.0 0.0
*
*****
* secondary relief and safety valves, broken loop
*****
*
3690000 blsgrv valve
3690101 320010000 370000000 2.96e-4 0.0149 0.0 0100
3690201 0 0.0 0.0 0.0 * 0.0
3690300 trpvlv
3690301 609
*
*****
3700000 contain tmdpvvol
3700101 1.0e+8 10.0 0.0 0.0 0.0 0.0 0.0 0.0 00
3700200 3
3700201 0.0 1.01325e+5 293.15
*
*****
3790000 blsgsv valve
3790101 324010000 380000000 0.00195 0.00055 0.0 0100
3790201 0 0.0 0.0 0.0 * 0.0
3790300 trpvlv
3790301 612
*
*****
3800000 contain tmdpvvol
3800101 1.0e+8 10.0 0.0 0.0 0.0 0.0 0.0 0.0 00
3800200 3
3800201 0.0 1.01325e+5 293.15
*
*****
* loop without pressurizer (intact loop)
*****
*
4000000 wphotleg snglvol
4000101 0.0337 1.3246 0.0 0.0 0.0 0.0 4.57e-5 0.207 00
4000200 003 15471308. 586.5
*

```

```

*****
4020000  ilhlbyps  branch
4020001  1      0
4020101  3.53e-4  2.65  0.0  0.0  0.0  0.0  4.57e-5  0.0  00
4020200  003      15481269.  560.5
4021101  104010000  402000000  3.53e-4  0.0  0.0  0100
4021201  0.0  0.0  0.0
*
*****
4030000  blhlbyp  valve
4030101  402010000  404000000  3.53e-4  27.6  27.6  0100
4030201  0      0.913  0.913  0.0
4030300  srvvlv
4030301  403
*
*****
4040000  blhlbyps  branch
4040001  1      0
4040101  3.53e-4  1.66  0.0  0.0  90.0  0.30  4.57e-5  0.0  00
4040200  003      15471269.  558.5
4041101  404010000  400000000  3.53e-4  0.0  0.0  0101
4041201  0.0  0.0  0.0
*
*****
4060000  nphotleg  branch
4060001  2      0
4060101  0.0337  1.3843  0.0  0.0  0.0  0.0  4.57e-5  0.207  00
4060200  003      15471269.  586.5
4061101  400010000  406000000  0.0337  0.0  0.0  0000
4062101  406010000  408000000  0.0337  0.0  0.0  0000
4061201  1.5683423  1.5683423  0.0      * 24.200171
4062201  1.5683417  1.5683417  0.0      * 24.200126
*
*****
4080000  wphotleg  pipe
4080001  2
4080101  0.0337      2
4080301  0.7043      1
4080302  0.5278      2
4080601  0.0      1
4080602  50.0      2
4080701  0.0      1
4080702  0.4043      2
4080801  4.57e-5  0.207  2
4080901  0.05  0.05  1
4081001  00      2
4081101  100000      1
4081201  003      15471238.  586.5  0.0  0.0  0.0  1
*****
4081202  003      15479897.  586.5  0.0  0.0  0.0  2
4081300  0
4081301  1.5683725  1.5683725  0.0      1      * 24.200756
4081401  0.0  0.0  0.55  0.785  1
*
*****
4090000  wphotleg  sngljun
4090101  408010000  412000000  0.0337  0.0  0.0  0100
4090201  0      1.5683754  1.5683754  0.0      * 24.200738
*
*****
4120000  wpsgin  snglvol
4120101  0.0  0.706  0.125  0.0  90.0  0.706  4.57e-5
4120102  0.377  00
4120200  003      15466381.  586.5
*
*****
4160000  wpsgfb  branch
4160001  3      0
4160101  0  1.1035  0.2323  0.0  90.0  1.1035  4.57e-5
4160102  0.4474  00
4160200  003  15460476.  586.5
4162101  412010000  416000000  0.2093  0.0  0.0  0000
4163101  416010000  420000000  0.04254  0.0  0.0  0000
4164101  416010000  417000000  5.0e-4  0.0  0.0  0100
4162201  1.247  1.247  0.0
4163201  1.247  1.247  0.0
4164201  0.1  0.1  0.0
*
*****
4170000  bktln1  snglvol
4170101  5.0e-4  1.18  0.0  0.0  0.0  0.0  4.57e-5  0.0  00
4170200  003      15453426.  560.5
*
4180000  bktln4  branch
4180001  2      0
4180101  5.0e-4  2.06  0.0  0.0  -90.0  -2.06  4.57e-5  0.0  00
4180200  003      15441269.  586.5
4181101  417010000  418000000  5.0e-4  0.0  0.0  0000
4182101  418010000  419000000  5.0e-4  0.0  0.0  0000
4181201  0.1  0.1  0.0
4182201  0.1  0.1  0.0
*
4190000  bktln5  snglvol
4190101  5.0e-4  1.9  0.0  0.0  0.0  0.0  4.57e-5  0.0  00
4190200  003      15433426.  560.5

```

*														
4930000	break	valve												
4930101	419010000	494000000	5.0e-4	0.0	0.0	0.0000								
4930201	1	0.0	0.0	0.0										
4930300	trpvlv													
4930301	535													

*														
4940000	bklm5	snglvol												
4940101	5.0e-4	0.24	0.0	0.0	0.0	0.0	4.57e-5	0.0	0.0					
4940200	003	7310426.	540.5											
*														
4950000	bklm4	branch												
4950001	2	0												
4950101	5.0e-4	0.35	0.0	0.0	90.0	0.35	4.57e-6	0.0	0.0					
4950200	003	7311269.	546.5											
4951101	495010000	496000000	3.02e-5	0.0	0.0	0.0	0.0	0.0						
4952101	494010000	495000000	5.0e-4	0.0	0.0	0.0	0.0	0.0						
4951201	0.1	0.1	0.0											
4952201	0.1	0.1	0.0											
*														
4960000	brknoz1	pipe												
4960001	3													
4960101	3.02e-5	3												
4960301	0.6	3												
4960401	0.0	3												
4960601	90.0	3												
4960701	0.6	3												
4960801	1.2e-7	0.0062	3											
4960901	0.0	0.0	2											
4961001	00	3												
4961101	01000	2												
4961201	003	7315536.	546.50	0.0	0.0	0.0	1							
4961202	003	7325536.	546.50	0.0	0.0	0.0	2							
4961203	003	7330536.	546.50	0.0	0.0	0.0	3							
4961300	0													
4961301	0.1	0.1	0.0	1										
4961302	0.1	0.1	0.0	2										
*														
4970000	bklm2	branch												
4970001	2	0												
4970101	5.0e-4	0.75	0.0	0.0	90.0	0.75	4.57e-6	0.0	0.0					
4970200	003	7331269.	546.5											
4971101	496010000	497000000	3.02e-5	0.0	0.0	0.0	0.0	0.0						
4972101	497010000	498000000	5.0e-4	0.0	0.0	0.0	0.0	0.0						
4971201	0.1	0.1	0.0											
4972201	0.1	0.1	0.0											

*														
4980000	bklm2	pipe												
4980001	2													
4980101	5.0e-4	2												
4980301	1.25	2												
4980601	0.0	2												
4980701	0.0	2												
4980801	4.57e-5	0.0	2											
4980901	0.0	0.0	1											
4981001	00	2												
4981101	0000	1												
4981201	003	7344729.	540.5	0.0	0.0	0.0	1							
4981202	003	7350523.	540.5	0.0	0.0	0.0	2							
4981300	0													
4981301	0.1	0.1	0.0	1										
*														
4990000	bklm1	sngljun												
4990101	498010000	504010003	5.0e-4	0.0	0.0	0.0	0.0	0.0						
4990201	0	0.1	0.1	0.0										

4200000	wpsgtube	pipe												
4200001	5													
4200101	0.04254	5												
4200301	2.8724	1												
4200302	2.5654	3												
4200303	2.1728	5												
4200601	90.0	4												
4200602	-90.0	5												
4200701	2.8724	1												
4200702	2.5654	3												
4200703	2.0980	4												
4200704	-2.0980	5												
4200801	1.524-6	0.0196	5											
4200901	0.0	0.0	3											
4200902	0.006	0.0	4											
4201001	00	5												
4201101	0000	4												
4201201	003	15446206.	578.83	0.0	0.0	0.0	1							
4201202	003	15426457.	572.17	0.0	0.0	0.0	2							
4201203	003	15407432.	568.5	0.0	0.0	0.0	3							
4201204	003	15389928.	566.83	0.0	0.0	0.0	4							
4201205	003	15389291.	564.17	0.0	0.0	0.0	5							
4201300	0													
4201301	1.1884545	1.1884545	0.0	1										
4201302	1.1561451	1.1561451	0.0	2										
4201303	1.1379927	1.1379927	0.0	3										
4201304	1.1274428	1.1274428	0.0	4										
* 24.200508														
* 24.200513														
* 24.200523														
* 24.200534														

```

*
*****
4220000  wpsgtub2  pipe
4220001      3
4220101  0.04254  3
4220301  2.5654  2
4220302  2.8724  3
4220601  -90.0  3
4220701  -2.5654  2
4220702  -2.8724  3
4220801  1.524-6  0.0196  3
4220901  0.0  0.006  1
4220902  0.0  0.0  2
4221001  00  3
4221101  0000  2
4221201  003  15405536. 562.50  0. 0. 0. 1
4221202  003  15423494. 561.83  0. 0. 0. 2
4221203  003  15442580. 560.17  0. 0. 0. 3
4221300  0
4221301  1.1140999 1.1140999 0.0 1 * 24.200557
4221302  1.1119639 1.1119639 0.0 2 * 24.200568
*
*****
4230000  bsgtjun  sngljun
4230101  420010000 422000000 0.04254 0.4 0.4 00100
4230201  0 1.1200999 1.1200999 0.0
*
*****
4240000  wpsgfbo  branch
4240001  2 0
4240101  0 1.1035 0.2323 0.0 -90.0 -1.1035 4.57e-5
4240102  0.4474 00
4240200  003 15456790. 560.5
4242101  422010000 424000000 0.04254 0.0 0.0 0000
4243101  424010000 430000000 0.2093 0.0 0.0 0000
4242201  1.247 1.247 0.0
4243201  1.247 1.247 0.0
*
*****
4300000  wpsgout  snglvol
4300101  0.0 0.706 0.125 0.0 -90.0 -0.706 4.57e-5
4300102  0.377 00
4300200  003 15463426. 560.5
*
*****
4290000  wpcrsleg  sngljun
4290101  430010000 432000000 0.0222 0.0 0.0 0100
4290201  0 2.1246026 2.1246026 0.0 * 24.200614

```

```

*
*****
4320000  wpcrsleg  pipe
4320001      5
4320101  0.0222  5
4320301  0.516  1
4320302  1.2422  4
4320303  1.1919  5
4320601  -50.0  1
4320602  -90.0  4
4320603  0.0  5
4320701  -0.3953  1
4320702  -1.2422  4
4320703  0.0  5
4320801  4.57e-5  0.1682  5
4320901  0.036  0.036  1
4320902  0.0  0.0  3
4320903  0.065  0.065  4
4321001  00  5
4321101  0000  4
4321201  003  15466368. 560.5  0. 0. 0. 1
4321202  003  15462310. 560.5  0. 0. 0. 2
4321203  003  15471332. 560.5  0. 0. 0. 3
4321204  003  15480354. 560.5  0. 0. 0. 4
4321205  003  15494820. 560.5  0. 0. 0. 5
4321300  0
4321301  2.1245970 2.1245970 0.0 1 * 24.200615
4321302  2.1245858 2.1245858 0.0 2 * 24.200619
4321303  2.1245689 2.1245689 0.0 3 * 24.200622
4321304  2.1245520 2.1245520 0.0 4 * 24.200625
*
*****
4330000  wpcfvalve
4330101  432010000 436000000 0.0222 0.0 0.0 0100
4330201  0 2.1245435 2.1245435 0.0 * 24.200629
4330300  mtrvrv
4330301  538 539 1.4200000 1.0000000 0
*
*****
4360000  wpcrslegu  pipe
4360001      4
4360101  0.0222  4
4360301  1.1919  1
4360302  1.1222  2
4360303  1.1763  3
4360304  1.1222  4
4360601  0.0  1
4360602  90.0  4

```

✱

✱

4406118	221.0	26.5	* 34.43
4406119	230.0	24.5	* 31.85
4406120	239.0	22.5	* 29.26
4406121	251.0	20.8	* 27.00
4406122	260.0	19.6	* 25.54
4406123	269.0	18.4	* 23.92
4406124	281.0	15.8	* 20.53
4406125	290.0	14.2	* 18.43
4406126	299.0	12.0	* 15.60
4406127	320.0	9.6	* 12.48
4406128	341.0	7.2	* 9.36
4406129	359.0	4.8	* 6.24
4406130	380.0	2.4	* 3.12
4406131	400.0	0.0	
4406132	1000.0	0.0	

✱

-A.14-

```

*
*****
*
* secondary loop for the primary loop with pressurizer
*
*****
5000000    wpstgdcn    annulus
5000001    5
5000101    0.0        1
5000102    0.0296     4
5000103    0.0        5
5000201    0.0        3
5000202    0.005281   4
5000301    2.8965     1
5000302    2.0980     2
5000303    2.5654     4
5000304    3.4395     5
5000401    0.3228     1
5000402    0.0        4
5000403    0.1302     5
5000501    0.0        5
5000601    -90.0      5
5000701    -2.0223    1
5000702    -2.0980    2
5000703    -2.5654    4
5000704    -2.5464    5
5000801    4.57e-5    0.3689 1
5000802    4.57e-5    0.0971 4
5000803    4.57e-5    0.0801 5
5000901    0.0        0.0    4
5001001    00         5
5001101    0000       3
5001102    0100       4
5001201    0          6854312.9 1200751.2 2580753.5 0.0 0.0 1
5001202    0          6879527.0 1200829.9 2580590.8 0.0 0.0 2
5001203    0          6886864.0 1200899.7 2580405.7 0.0 0.0 3
5001204    0          6905938.6 1200941.7 2580202.5 0.0 0.0 4
5001205    0          6915253.0 1202649.1 2580103.4 0.0 0.0 5
5001300    0
5001301    .61387739 .61387739 0.0 1 * 13.832253
5001302    .61388537 .61388537 0.0 2 * 13.832171
5001303    .61388694 .61388694 0.0 3 * 13.832038
5001304    .61387788 .61387788 0.0 4 * 13.831877
*
*****
5010000    wpstgdcn    sngljun
5010101    500010000 504000000 0.0 100.0 100.0 0000
5010201    0          .48039121 .69720931 0.0 * 13.831555

```

```

*
*****
5040000    wpsteamg    pipe
5040001    5
5040101    0.2293     3
5040102    0.0        5
5040201    0.2293     2
5040202    0.2293     3
5040203    0.3138     4
5040301    2.5464     1
5040302    2.5654     3
5040303    2.0980     4
5040304    2.0223     5
5040401    0.0        3
5040402    0.4951     4
5040403    0.7979     5
5040501    0.0        5
5040601    90.0       5
5040701    2.5464     1
5040702    2.5654     3
5040703    2.0980     4
5040704    2.0223     5
5040801    4.57e-5    0.036 4
5040802    4.57e-5    0.219 5
5040901    1.5 1.5 4
5041001    00         5
5041101    0100       3
5041102    0000       4
5041201    0          6904072.6 1261303.5 2580206.5 .14246717 0.0 1
5041202    0          6890625.7 1265108.6 2580362.4 .28828137 0.0 2
5041203    0          6878293.4 1264860.6 2580492.4 .28643270 0.0 3
5041204    0          6866890.7 1264305.8 2580611.9 .27887426 0.0 4
5041205    0          6857011.3 1263978.6 2580664.8 .27519078 0.0 5
5041300    0
5041301    .09947453 .37096577 0.0 1 * 13.814456
5041302    .11462864 .49520300 0.0 2 * 13.809526
5041303    .10797253 .71294955 0.0 3 * 13.805859
5041304    .09902432 .87101253 0.0 4 * 13.802399
5041401    0.036 1.0 1.0 1.0 3
5041402    0.1258 1.0 1.0 1.0 4
*
*****
5080000    wpsepar    separatr
5080001    3 0
5080101    0.0 2.120 0.572 0.0 90.0 2.120 4.57e-5
5080102    0.2134 00
5080200    0          6848284.2 1263648.5 2580734.6 .52097025
5081101    508010000 516000000 0.0715 0.0 0.0 0100 0.2

```

5082101	508000000	500000000	0.03964	100.0	100.0	0000	
5083101	504010000	508000000	0.1986	0.0	0.0	0000	
5081201	-4037061	27393586	0.0				* 2.7472266
5082201	37739895	-1.743057	0.0				* 11.039985
5083201	11699245	1.0455258	0.0				* 13.799421

5120000	wpsgspbp	branch					
5120001	2	0					
5120101	0.0	2.120	0.6288	0.0	90.0	2.120	457e-5
5120102	0.1242	00					
5120200	0	6845583.4	1236787.3	2582575.1	89235283		
5121101	500000000	512000000	0.3164	0.0	0.0	0000	
5122101	512010000	516000000	0.0392	1.5	1.5	0000	
5121201	30.5398-6	1.3297404	0.0				* 7.35566-3
5122201	-46.00500	-1.6715-3	0.0				* -2.8209-3

5160000	strndome	snglvol					
5160101	0.0	3.7778	2.0288	0.0	90.0	3.7778	457e-5
5160102	0.7696	00					
5160200	0	6843731.5	1263114.0	2580824.8	99999971		

* ilsg steam line							

5200000	ilstmln1	branch					
5200001	2	0					
5200101	0.0286	5.282	0.0	0.0	0.0	0.0	457e-5
5200102	0.1909	00					
5200200	0	6842807.7	1263069.3	2580824.5	99991553		
5201101	516010000	520000000	0.0286	0.0	0.0	0100	
5202101	520010000	524000000	0.0286	0.0	0.0	0000	
5201201	1.8244014	2.5842639	0.0				* 2.7450542
5202201	27793749	2.5848676	0.0				* 2.7455870

5240000	ilstmln2	branch					
5240001	1	0					
5240101	0.0286	8.5867	0.0	0.0	0.0	0.0	457e-5
5240102	0.1909	00					
5240200	0	6842699.9	1263063.4	2580835.0	99967266		
5241101	524010000	528000000	0.00429	0.0	0.0	0000	
5241201	1.5658958	17.236995	0.0				* 2.7466368

5280000	ilstmln3	snglvol					
5280101	0.00429	10.9965	0.0	0.0	0.0	0.0	457e-5

5280102	0.0739	00					
5280200	0	6820393.8	1262454.1	2580955.8	99988240		

5290000	ilmsiv	valve					
5290101	528010000	532000000	0.00429	0.0	0.0	0100	
5290201	0	5.7878014	17.263954	0.0			* 2.7467386
5290300	mtrvlv						
5290301	578	501	2.0000000	1.0000000	0		

5320000	vlvtovlv	snglvol					
5320101	0.00429	5.5275	0.0	0.0	0.0	0.0	457e-5
5320102	0.0739	00					
5320200	0	6828376.3	1261858.7	2581063.9	99978697		

5330000	ilchkvl	valve					
5330101	532010000	800000000	0.00429	0.0	0.0	0000	
5330201	0	3.7947922	17.296149	0.0			* 2.7468079
5330300	chkvlv						
5330310	0	0	0.0	0.0			

5500000	auxfed	tmdpvol					
5500101	8.0	5.0	0.0	0.0	0.0	0.0	0 00
5500200	3						
5500201	0.0	5.95300e+6				313.0	

5510000	auxfed	tmdpjvn					
5510101	550000000	500000000	0.004				
5510200	1	624					
5510201	0.0	0.0	0.0	0.0			
5510202	0.01	1.140	0.0	0.0			
5510203	5000.0	1.140	0.0	0.0			

5600000	wpstegfw	tmdpvol					
5600101	0.139	5.0	0.0	0.0	0.0	0.0	0 00
5600200	3						
5600201	0.0	5.83400e+6				495.35	

5610000	wpstegfw	tmdpjvn					
5610101	560000000	500000000	4.00e-3				
5610200	1	550	cntrlvar	561			
5610201	0.0	0.0	0.0	0.0			
5610202	5.0	5.0	0.0	0.0			

[illegible]

-A.18-

```

7210218      8.8e6      0.405      0.0      0.0
7210219      9.0e6      0.379      0.0      0.0
7210220      9.2e6      0.352      0.0      0.0
7210221      9.4e6      0.319      0.0      0.0
7210222      9.6e6      0.289      0.0      0.0
7210223      9.8e6      0.255      0.0      0.0
7210224     10.0e6      0.202      0.0      0.0
7210225     10.2e6      0.124      0.0      0.0
7210226     10.35e6      0.0        0.0      0.0
*
*7500000      ilsi      tmdpv0l
*7500101      4.375      10.0      0.0      0.0      0.0      0.0      0.0      0.0
*7500200      3
*7500201      0.0        1.013e+5      310.00
*
*7220000      ilsi      tmdpj0n
*7220101      750000000      152000000      2.552e-3
*7210200      1      511      p      152010000
*7220201      -1.0      0.0      0.0      0.0
*7220202      0.0      0.0      0.0      0.0
*7220203      0.0      1.388      0.0      0.0
*7220204      6.0e6      1.388      0.0      0.0
*7220205      6.2e6      1.343      0.0      0.0
*7220206      6.4e6      1.305      0.0      0.0
*7220207      6.6e6      1.268      0.0      0.0
*7220208      6.8e6      1.238      0.0      0.0
*7220209      7.0e6      1.200      0.0      0.0
*7220210      7.2e6      1.155      0.0      0.0
*7220211      7.4e6      1.125      0.0      0.0
*7220212      7.6e6      1.080      0.0      0.0
*7220213      7.8e6      1.043      0.0      0.0
*7220214      8.0e6      0.998      0.0      0.0
*7220215      8.2e6      0.953      0.0      0.0
*7220216      8.4e6      0.900      0.0      0.0
*7220217      8.6e6      0.855      0.0      0.0
*7220218      8.8e6      0.810      0.0      0.0
*7220219      9.0e6      0.758      0.0      0.0
*7220220      9.2e6      0.705      0.0      0.0
*7220221      9.4e6      0.638      0.0      0.0
*7220222      9.6e6      0.578      0.0      0.0
*7220223      9.8e6      0.510      0.0      0.0
*7220224     10.0e6      0.405      0.0      0.0
*7220225     10.2e6      0.248      0.0      0.0
*7220226     10.35e6      0.0        0.0      0.0
*
*****
7300000      ilchrg      tmdpv0l
7300101      4.375      10.0      0.0      0.0      0.0      0.0      0.0      0.0

```

```

7300200      3
7300201      0.0        1.013e+5      300.00
*
*****
7310000      ilchrg      tmdpj0n
7310101      730000000      740000000      2.552e-3
7310200      1      505      p      448010000
7310201      -1.0      0.0      0.0      0.0
7310202      0.0      0.0      0.0      0.0
7310203      0.0      0.13      0.0      0.0
7310204      15.0e6      0.13      0.0      0.0
*
*****
7400000      ileccsln      snglv0l
7400101      2.552e-3      16.0      0.0      0.0      0.0      0.0      3.333e-5
7400102      0.0      0.0
7400200      0      15598371.      83230.665      2445532.2      0.0
*
*****
7700000      blsi      tmdpv0l
7700101      4.375      10.0      0.0      0.0      0.0      0.0      0.0      0.0
7700200      3
7700201      0.0        1.013e+5      293.15
*
*****
* eccs flows from zion deck, assume even flow split between loops
*****
*
7710000      blsi      tmdpj0n
7710101      770000000      790000000      2.552e-3
7710200      1      512      p      248010000
7710201      -1.0      0.0      0.0      0.0
7710202      0.0      0.0      0.0      0.0
7710203      0.0      0.694      0.0      0.0
7710204      6.0e6      0.694      0.0      0.0
7710205      6.2e6      0.671      0.0      0.0
7710206      6.4e6      0.6525      0.0      0.0
7710207      6.6e6      0.634      0.0      0.0
7710208      6.8e6      0.619      0.0      0.0
7710209      7.0e6      0.600      0.0      0.0
7710210      7.2e6      0.577      0.0      0.0
7710211      7.4e6      0.562      0.0      0.0
7710212      7.6e6      0.540      0.0      0.0
7710213      7.8e6      0.521      0.0      0.0
7710214      8.0e6      0.499      0.0      0.0
7710215      8.2e6      0.476      0.0      0.0
7710216      8.4e6      0.450      0.0      0.0
7710217      8.6e6      0.427      0.0      0.0

```

```

7710218      8.8e6      0.405      0.0      0.0
7710219      9.0e6      0.379      0.0      0.0
7710220      9.2e6      0.352      0.0      0.0
7710221      9.4e6      0.319      0.0      0.0
7710222      9.6e6      0.289      0.0      0.0
7710223      9.8e6      0.255      0.0      0.0
7710224     10.0e6      0.202      0.0      0.0
7710225     10.2e6      0.124      0.0      0.0
7710226     10.35e6      0.0        0.0      0.0

```

*

```

7800000      blchrg      tmdpvcl
7800101      4.375      10.0      0.0      0.0      0.0      0.0      0.0      0.0
7800200      3
7800201      0.0        1.013e+5      293.15

```

*

```

7810000      blchrg      tmdpjun
7810101      7800000000      7900000000      2.552e-3
7810200      1      505      p      248010000
7810201      -1.0      0.0      0.0      0.0
7810202      0.0      0.0      0.0      0.0
7810203      0.0      0.13      0.0      0.0
7810204      15.0e6      0.13      0.0      0.0

```

*

```

7900000      bleccsln      snglvcl
7900101      9.079e-4      16.0      0.0      0.0      0.0      0.0      3.333e-5
7900102      0.0      0.0
7900200      0      15488401.      83231.356      2445531.5      0.0

```

*

* common steam header to jet condensor

*

```

8000000      header1      snglvcl
8000101      0.00741      3.2      0.0      0.0      0.0      0.0      4.57e-5
8000102      0.0      0.0
8000200      0      6728063.0      1261843.5      2581117.8      .99983487

```

*

```

8010000      headvcl      valve
8010101      800010000      8040000000      0.00741      0.0      0.0      0.000
8010201      0      2.8818423      10.014497      0.0      * 2.7468959
8010300      trpvcl
8010301      583

```

*

```

8030000      trbbpvcl      valve
8030101      8000000000      8080000000      5.56e-4      0.0      0.0      0100
8030201      0      0.0      0.0      0.0      * 0.0
8030300      srvvcl
8030301      40

```

*

```

8040000      header2      snglvcl
8040101      0.00741      3.2      0.0      0.0      0.0      0.0      4.57e-5
8040102      0.0      0.0
8040200      0      6710989.5      1261492.4      2581112.5      .99991458

```

*

```

8050000      thrvcl      valve
8050101      804010000      8120000000      0.00741      0.0      0.0      0100
8050201      0      8.6399460      20.055846      0.0      * 5.4949115
8050300      srvvcl
8050301      805

```

*

```

8080000      trbbpcln      snglvcl
8080101      0.00741      13.3305      0.0      0.0      0.0      0.0      4.57e-5
8080102      0.0971      0.0
8080200      0      6658740.0      1262372.2      2580999.5      .99988891

```

*

```

8090000      bplnjc      sngljun
8090101      808010000      8160000000      0.00741      0.0      0.0      0100
8090201      0      2.13640-3      -237.33-9      0.0      * 1.23347-6

```

*

```

8120000      trbthrln      snglvcl
8120101      0.00741      8.730      0.0      0.0      0.0      0.0      4.57e-5
8120102      0.0971      0.0
8120200      0      6506022.4      1248286.1      2583199.0      .99913646

```

*

```

8130000      thrlnjc      sngljun
8130101      812010000      8200000000      0.00741      0.0      0.0      0100
8130201      0      8.3986178      20.802777      0.0      * 5.4948355

```

*

```

8160000      jctdvcl      tmdpvcl
8160101      1.0e+8      10.0      0.0      0.0      0.0      0.0      0.0      0.0
8160200      2
8160201      0.0      6.54e+6      1.0

```

*

```

8200000 jctdv2 tmdpv0l
8200101 1.0e-8 10.0 0.0 0.0 0.0 0.0 0.0 0.0 00
8200200 2
8200201 0.0 6.54e+6 1.0
*
*****
* containment volume for environmental heat losses
*****
9000000 envsink snglv0l
9000101 2000. 100. 0.0 0.0 0.0 0.0 4.57e-5
9000102 0.0 00
9000200 0 1.034e5 322.0 1.0
*
9100000 envsijn sngljun
9100101 900010000 920000000 0.00741 0.0 0.0 0100
9100201 1 1.0e-5 1.0e-5 0.0
*
9200000 envsink tmdpv0l
9200101 2000. 100. 0.0 0.0 0.0 0.0 0.0 0 10
9200200 4
9200201 0.0 1.034e5 322.0 1.0
*
*****
* boundary system for steady state
*****
*
9900000 bdryvol tmdpv0l
9900101 0.255 0.69 0.0 0.0 0.0 0.0 0.0 0.0 0000
9900200 2
9900201 0.0 1.538e+7 1.0
*
9890000 bdryv0l valve
9890101 990000000 610000000 1.0 0.0 0.0 0000
9890201 0 1.62936-3 5.59379-6 0.0
9890300 trpv0l
9890301 599
*
*****
* reactor vessel heat structures
*****
*
*****
* 100-1; vessel wall above nozzles, below upper head flange
*****
*
11001000 1 7 2 1 0.320
11001100 0 1
11001101 1 0.323

```

```

11001102 4 0.476
11001103 1 0.601
11001201 5 1
11001202 6 5
11001203 9 6
11001301 0.0 6
11001400 0
11001401 562.2 7
11001501 100010000 0 1 1 0.823 1
11001601 900010000 0 1 1 0.823 1
11001701 0 0 0 0 1
11001801 0.10.0 10.0 0.0 0.0 0.1. 1
11001901 0.10.0 10.0 0.0 0.0 0.1. 1
*
*****
* 104-1; reactor vessel wall below nozzles
*****
*
11041000 12 7 2 1 0.320
11041100 0 1
11041101 1 0.323
11041102 4 0.381
11041103 1 0.506
11041201 5 1
11041202 6 5
11041203 9 6
11041301 0.0 6
11041400 0
11041401 562.2 7
11041501 104010000 0 1 1 0.600 1
11041502 108010000 0 1 1 0.677 2
11041503 108020000 0 1 1 0.867 3
11041504 108030000 10000 1 1 0.610 9
11041510 108090000 0 1 1 1.2588 10
11041511 112010000 0 1 1 0.445 11
11041512 116010000 0 1 1 0.4762 12
11041601 900010000 0 1 1 0.600 1
11041602 900010000 0 1 1 0.677 2
11041603 900010000 0 1 1 0.867 3
11041604 900010000 0 1 1 0.610 9
11041610 900010000 0 1 1 1.2588 10
11041611 900010000 0 1 1 0.445 11
11041612 900010000 0 1 1 0.4762 12
11041701 0 0 0 0 12
11041801 0.10.0 10.0 0.0 0.0 0.1. 12
11041901 0.10.0 10.0 0.0 0.0 0.1. 12
*****
* 112-1; vessel bottom and flange

```

```

*****
*
11121000 1 7 1 1 0.0
11121100 0 1
11121101 1 0.003
11121102 4 0.724
11121103 1 0.849
11121201 5 1
11121202 6 5
11121203 9 6
11121301 0.0 6
11121400 0
11121401 562.2 7
11121501 112010000 0 1 0 0.686 1
11121601 900010000 0 1 1 0.686 1
11121701 0 0 0 0 1
11121801 0 10.0 10.0 0.0 0.0 0.1 1
11121901 0 10.0 10.0 0.0 0.0 0.1 1
*****
* 112-2: heater rods, below heated section
*****
*
11122000 3 4 2 1 0.0
11122100 0 1
11122101 1 0.002
11122102 1 0.00295
11122103 1 0.00375
11122201 3 1
11122202 1 2
11122203 4 3
11122301 0.0 3
11122400 0
11122401 562.2 4
11122501 0 0 0 1 731.2 1
11122502 0 0 0 1 556.2 2
11122503 0 0 0 1 1470.3 3
11122601 112010000 0 1 1 731.2 1
11122602 116910000 0 1 1 556.2 2
11122603 120910000 0 1 1 1470.3 3
11122701 0 0 0 0 3
11122901 0 10.0 10.0 0.0 0.0 0.1 3
*****
* 120-1: core barrel
*****
*
11201000 12 5 2 1 0.257
11201100 0 1
11201101 4 0.267

11201201 5 4
11201301 0.0 4
11201400 0
11201401 562.2 5
11201501 120010000 0 1 1 1.2588 1
11201502 124010000 10000 1 1 0.610 7
11201503 128010000 0 1 1 0.867 8
11201504 132010000 0 1 1 0.677 9
11201505 136010000 0 1 1 0.600 10
11201506 140010000 0 1 1 0.3674 11
11201507 144010000 0 1 1 0.897 12
11201601 108090000 0 1 1 1.2588 1
11201602 108080000 -10000 1 1 0.6100 7
11201603 108020000 0 1 1 0.867 8
11201604 108010000 0 1 1 0.677 9
11201605 104010000 0 1 1 0.600 10
11201606 100010000 0 1 1 0.3674 11
11201607 100010000 0 1 1 0.897 12
11201701 0 0 0 0 12
11201801 0 10.0 10.0 0.0 0.0 0.1 12
11201901 0 10.0 10.0 0.0 0.0 0.0 1 12
*****
*
*****
* 124-1: heated section of heater rods
*****
*
11241000 6 9 2 1 0.0
11241100 0 1
11241101 2 0.00200
11241102 2 0.00260
11241103 2 0.00375
11241104 2 0.00475
11241201 7 2
11241202 2 4
11241203 1 6
11241204 4 8
11241301 0.0 2
11241302 1.0 4
11241303 0.0 8
11241400 0
11241401 600.6 9
11241501 0 0 0 1 649.00 6
11241601 124010000 10000 1 1 649.00 6
11241701 888 0.08568 0.0 0.0 1
11241702 888 0.17532 0.0 0.0 2
11241703 888 0.23900 0.0 0.0 3
11241704 888 0.23900 0.0 0.0 4
11241705 888 0.17532 0.0 0.0 5

```

11241706	888	0.08568	0.0	0.0	6
11241901	0.	0.305	3.355	0. 0.	0. 0. 1.0 1
11241902	0.	0.915	2.745	0. 0.	0. 0. 1.0 2
11241903	0.	1.525	2.135	0. 0.	0. 0. 1.0 3
11241904	0.	2.135	1.525	0. 0.	0. 0. 1.0 4
11241905	0.	2.745	0.915	0. 0.	0. 0. 1.0 5
11241906	0.	3.355	0.305	0. 0.	0. 0. 1.0 6

*

* 124-2: unheated instrument rods

*

11242000	6	6	2	1	0.0
----------	---	---	---	---	-----

11242100	0	1
----------	---	---

11242101	3	0.00432
----------	---	---------

11242102	2	0.00612
----------	---	---------

11242201	1	2
----------	---	---

11242202	5	5
----------	---	---

11242301	0.0	5
----------	-----	---

11242400	0
----------	---

11242401	600.6	6
----------	-------	---

11242501		0	0	0	1	63.44	6
----------	--	---	---	---	---	-------	---

11242601	124010000	10000	1	1	63.44	6
----------	-----------	-------	---	---	-------	---

11242701	0	0	0	0	6
----------	---	---	---	---	---

11242901	0.	10.0	10.0	0. 0.	0.0 0. 1. 6
----------	----	------	------	-------	-------------

*

* 128-1: upper plenum internals

*

11281000	1	5	1	1	0.0
----------	---	---	---	---	-----

11281100	0	1
----------	---	---

11281101	4	0.023
----------	---	-------

11281201	5	4
----------	---	---

11281301	0.0	4
----------	-----	---

11281400	0
----------	---

11281401	584.2	5
----------	-------	---

11281501	128010000	0	1	0	0.773	1
----------	-----------	---	---	---	-------	---

11281601	128010000	0	1	0	0.773	1
----------	-----------	---	---	---	-------	---

11281701	0	0	0	0	1
----------	---	---	---	---	---

11281801	0.	10.0	10.0	0. 0.0	0. 0. 1. 1
----------	----	------	------	--------	------------

11281901	0.	10.0	10.0	0. 0.0	0. 0. 1. 1
----------	----	------	------	--------	------------

*

* 132-1: guide tubes

*

11321000	5	4	2	1	0.04405
----------	---	---	---	---	---------

11321100	0	1
----------	---	---

11321101	3	0.04655
----------	---	---------

11321201	5	3
----------	---	---

11321301	0.0	3
----------	-----	---

11321400	0
----------	---

11321401	600.6	4
----------	-------	---

11321501	156020000	0	1	1	5.406	1
----------	-----------	---	---	---	-------	---

11321502	156020000	0	1	1	4.800	2
----------	-----------	---	---	---	-------	---

11321503	156010000	0	1	1	2.939	3
----------	-----------	---	---	---	-------	---

11321504	156010000	0	1	1	7.176	4
----------	-----------	---	---	---	-------	---

11321505	156010000	0	1	1	5.800	5
----------	-----------	---	---	---	-------	---

11321601	132010000	0	1	1	5.406	1
----------	-----------	---	---	---	-------	---

11321602	136010000	0	1	1	4.800	2
----------	-----------	---	---	---	-------	---

11321603	140010000	0	1	1	2.939	3
----------	-----------	---	---	---	-------	---

11321604	144010000	0	1	1	7.176	4
----------	-----------	---	---	---	-------	---

11321605	148010000	0	1	1	5.800	5
----------	-----------	---	---	---	-------	---

11321701	0	0	0	0	5
----------	---	---	---	---	---

11321801	0.	10.0	10.0	0. 0.	0.0 0. 1. 5
----------	----	------	------	-------	-------------

11321901	0.	10.0	10.0	0. 0.	0.0 0. 1. 5
----------	----	------	------	-------	-------------

* 144-1: upper core support plate

*

11441000	1	9	1	1	0.0
----------	---	---	---	---	-----

11441100	0	1
----------	---	---

11441101	8	0.304
----------	---	-------

11441201	5	8
----------	---	---

11441301	0.0	8
----------	-----	---

11441400	0
----------	---

11441401	562.2	9
----------	-------	---

11441501	144010000	0	1	0	0.156	1
----------	-----------	---	---	---	-------	---

11441601	140010000	0	1	0	0.156	1
----------	-----------	---	---	---	-------	---

11441701	0	0	0	0	1
----------	---	---	---	---	---

11441801	0.	10.0	10.0	0. 0.0	0. 0. 1. 1
----------	----	------	------	--------	------------

11441901	0.	10.0	10.0	0. 0.0	0. 0. 1. 1
----------	----	------	------	--------	------------

*

* 148-1: reactor vessel wall above upper plenum flange

*

11481000	1	7	2	1	0.320
----------	---	---	---	---	-------

11481100	0	1
----------	---	---

11481101	1	0.323
----------	---	-------

11481102	4	0.522
----------	---	-------

11481103	1	0.647
----------	---	-------

11481201	5	1
----------	---	---

11481202	6	5
----------	---	---

11481203	9	6
----------	---	---

```

11481301 0.0 6
11481400 0
11481401 562.2 7
11481501 148010000 0 1 1 0.404 1
11481601 900010000 0 1 1 0.404 1
11481701 0 0 0 0 1
11481801 0. 10.0 10.0 0. 0.0 0. 0. 1. 1
11481901 0. 10.0 10.0 0. 0.0 0. 0. 1. 1
*
*****
* 152-1: reactor vessel upper head
*****
*
11521000 1 7 3 1 0.320
11521100 0 1
11521101 1 0.324
11521102 4 0.354
11521103 1 0.479
11521201 5 1
11521202 6 5
11521203 9 6
11521301 0.0 6
11521400 0
11521401 562.2 7
11521501 152010000 0 1 1 0.5 1
11521601 900010000 0 1 1 0.5 1
11521701 0 0 0 0 1
11521801 0. 10.0 10.0 0. 0.0 0. 0. 1. 1
11521901 0. 10.0 10.0 0. 0.0 0. 0. 1. 1
*
*****
*
* loop heat structures
*
*****
* ht str no. 212-1 blsg inlet/outlet plnm hemisph
*-----*
12121000 2 6 3 1 0.377 0
12121100 0 1
12121101 1 0.380
12121102 2 0.430
12121103 2 0.555
12121201 5 1
12121202 6 3
12121203 9 5
12121301 0.0 5
12121400 -1
12121401 583.000 583.000 583.000 583.000 583.000

```

```

+ 583.000
12121402 557.000 557.000 557.000 557.000 557.000
+ 557.000
12121501 212010000 0 1 1 0.1872 1
12121502 228010000 0 1 1 0.1872 2
12121601 900010000 0 1 1 0.1872 2
12121701 0 0 0 0 2
12121801 0. 10.0 10.0 0. 0. 0. 0. 1. 2
12121901 0. 10.0 10.0 0. 0. 0. 0. 1. 2
*
*****
* ht str no. 212-2 blsg inlet/outlet plnm walls
*-----*
12122000 4 6 2 1 0.365 0
12122100 0 1
12122101 1 0.368
12122102 2 0.434
12122103 2 0.559
12122201 5 1
12122202 6 3
12122203 9 5
12122301 0.0 5
12122400 -1
12122401 583.000 583.000 583.000 583.000 583.000
+ 583.000
12122402 557.000 557.000 557.000 557.000 557.000
+ 557.000
12122403 583.000 583.000 583.000 583.000 583.000
+ 583.000
12122404 557.000 557.000 557.000 557.000 557.000
+ 557.000
12122501 212010000 0 1 1 0.4237 1
12122502 228010000 0 1 1 0.4237 2
12122503 216010000 0 1 1 1.1035 3
12122504 224010000 0 1 1 1.1035 4
12122601 900010000 0 1 1 0.4237 2
12122602 900010000 0 1 1 1.1035 4
12122701 0 0 0 0 4
12122801 0. 10.0 10.0 0. 0. 0. 0. 1. 2
12122902 0. 10.0 10.0 0. 0. 0. 0. 1. 4
12122901 0. 10.0 10.0 0. 0. 0. 0. 1. 4
*
*****
* ht str no. 220-2 blsg inlet/outlet tube sheet
*-----*
12202000 2 4 2 1 0.0098 0
12202100 0 1
12202101 3 0.0163

```

12202201	5		3						
12202301	0.0		3						
12202400			-1						
12202401	583.000	583.000	583.000	583.000					
12202402	557.000	557.000	557.000	557.000					
12202501	220010000	0	1	1	45.40	1			
12202502	220080000	0	1	1	45.40	2			
12202601	0	0	0	1	45.40	2			
12202701	0	0	0	0	0	2			
12202801	0.	10.0	10.0	0.0	0.	1.	2		

* steam generator in the loop without pressurizer									

*									
12201000	8	8	2	1	0.00980				
12201100	0	1							
12201101	7	0.0127							
12201201	5	7							
12201301	0.0	7							
12201400	0								
12201401	562.4	8							
12201501	220010000	0	1	1	359.04	1			
12201502	220020000	10000	1	1	361.72	3			
12201503	220040000	10000	1	1	306.36	5			
12201504	220060000	10000	1	1	361.72	7			
12201505	220080000	0	1	1	359.04	8			
12201601	304010000	0	1	1	359.04	1			
12201602	304020000	10000	1	1	361.72	3			
12201603	304040000	0	1	1	306.36	5			
12201604	304030000	-10000	1	1	361.72	7			
12201605	304010000	0	1	1	359.04	8			
12201701	0	0	0	0	8				
12201801	0.	10.0	10.0	0.0	0.	0.	1.	8	
12201901	0.	10.0	10.0	0.0	0.	0.	1.	8	

13001000	5	5	2	1	0.0486	0			
13001100	0			1					
13001101	2			0.0572					
13001102	2			0.1572					
13001201	5			2					
13001202	9			4					
13001301	0.0			4					
13001401	564.0			5					
13001501	300010000	0	1	1	9.0016	1			
13001502	300020000	0	1	1	8.3920	2			
13001503	300030000	10000	1	1	10.2616	4			
13001504	300050000	0	1	1	10.2380	5			

13001601	900010000	0	1	1	9.0016	1			
13001602	900010000	0	1	1	8.3920	2			
13001603	900010000	0	1	1	10.2616	4			
13001604	900010000	0	1	1	10.2380	5			
13001701	0	0	0	0	0	5			
13001801	0.	10.0	10.0	0.	0.	0.	0.	1.	5
13001901	0.	10.0	10.0	0.	0.	0.	0.	1.	5

* ht str no. 300-2 blsg upper dc to separator									

13002000	2	2	2	1	0.2514	0			
13002100	0			1					
13002101	1			0.2554					
13002201	5			1					
13002301	0.0			1					
13002400				0					
13002401	560.			2					
13002501	304050000	0	1	1	0.6461	1			
13002502	308010000	0	1	1	2.120	2			
13002601	300010000	0	1	1	0.6461	1			
13002602	308010000	0	1	1	2.120	2			
13002701	0	0	0	0	0	2			
13002801	0.	10.0	10.0	0.	0.	0.	0.	1.	2
13002901	0.	10.0	10.0	0.	0.	0.	0.	1.	1
13002902	0.	10.0	10.0	0.	0.	0.	0.	1.	2

* ht str no. 300-3 blsg upper sg shell to environ									

13003000	4	6	2	1	0.4375	0			
13003100	0			1					
13003101	1			0.4405					
13003102	2			0.4785					
13003103	2			0.6035					
13003201	5			1					
13003202	6			3					
13003203	9			5					
13003301	0.0			5					
13003400				0					
13003401	530.			6					
13003501	300010000	0	1	1	0.6461	1			
13003502	304050000	0	1	1	1.0104	2			
13003503	312010000	0	1	1	2.120	3			
13003504	316010000	0	1	1	3.4278	4			
13003601	900010000	0	1	1	0.6461	1			
13003602	900010000	0	1	1	1.0104	2			
13003603	900010000	0	1	1	2.120	3			

-A.26-

-A.27-

14003506	452010000	10000	1	1	0.9752	7	14122401	583.000	583.000	583.000	583.000	583.000					
14003601	900010000	0	1	1	1.0562	1	+	583.000									
14003602	900010000	0	1	1	1.1067	2	14122402	557.000	557.000	557.000	557.000	557.000					
14003603	900010000	0	1	1	1.3125	3	+	557.000									
14003604	900010000	0	1	1	0.647	4	14122403	583.000	583.000	583.000	583.000	583.000					
14003605	900010000	0	1	1	0.878	5	+	583.000									
14003606	900010000	0	1	1	0.9752	7	14122404	557.000	557.000	557.000	557.000	557.000					
14003701	0	0		0	0	7	+	557.000									
14003801	0.	10.0	10.0	0.	0.	0.	0.	1.	7	14122501	412010000	0	1	1	0.4237	1	
14003901	0.	10.0	10.0	0.	0.	0.	0.	1.	7	14122502	430010000	0	1	1	0.4237	2	

* ht str no. 412-1 ilsg inlet/outlet plnm hemisph																	

14121000	2	6	3	1	0.377	0	14122503	416010000	0	1	1	1.1035	3				
14121100		0		1			14122504	424010000	0	1	1	1.1035	4				
14121101		1		0.380			14122601	900010000	0	1	1	0.4237	2				
14121102		2		0.430			14122602	900010000	0	1	1	1.1035	4				
14121103		2		0.555			14122701	0	0	0	0	0	4				
14121201		5		1			14122801	0.	10.0	10.0	0.	0.	0.	0.	1.	2	
14121202		6		3			14122802	0.	10.0	10.0	0.	0.	0.	0.	1.	4	
14121203		9		5			14122901	0.	10.0	10.0	0.	0.	0.	0.	1.	4	
14121301	0.0			5			*****										
14121400				-1			*****										
14121401	583.000	583.000		583.000	583.000	583.000	* ht str no. 420-1 intact loop sg tubes						*****				
+	583.000						*****										
14121402	557.000	557.000		557.000	557.000	557.000	14201000	8	8	2	1	0.00980					
+	557.000						14201100	0	1								
14121501	412010000	0	1	1	0.1872	1	14201101	7	0.0127								
14121502	430010000	0	1	1	0.1872	2	14201201	5	7								
14121601	900010000	0	1	1	0.1872	2	14201301	0.0	7								
14121701	0	0		0	0	2	14201400	0									
14121801	0.	10.0	10.0	0.	0.	0.	0.	1.	2	14201401	562.4	8					
14121901	0.	10.0	10.0	0.	0.	0.	0.	1.	2	14201501	420010000	0	1	1	359.04	1	

* ht str no. 412-2 ilsg inlet/outlet plnm walls																	

14122000	4	6	2	1	0.365	0	14201502	420020000	10000	1	1	361.72	3				
14122100		0		1			14201503	420040000	10000	1	1	306.36	5				
14122101		1		0.368			14201504	422010000	10000	1	1	361.72	7				
14122102		2		0.434			14201505	422030000	0	1	1	359.04	8				
14122103		2		0.559			14201601	504010000	0	1	1	359.04	1				
14122201		5		1			14201602	504020000	10000	1	1	361.72	3				
14122202		6		3			14201603	504040000	0	1	1	306.36	5				
14122203		9		5			14201604	504030000	-10000	1	1	361.72	7				
14122301	0.0			5			14201605	504010000	0	1	1	359.04	8				
14122400				-1			14201701	0	0	0	0	8					

* ht str no. 420-2 ilsg inlet/outlet tube sheet																	

14202000	2	4	2	1	0.0098	0	
14202100		0		1			
14202101		3		0.0163			
14202201		5		3			
14202301		0.0		3			
14202400				-1			
14202401	583.000		583.000		583.000	583.000	
14202402	557.000		557.000		557.000	557.000	
14202501	420010000	0	1	1	45.40		1
14202502	422030000	0	1	1	45.40		2
14202601	0	0	0	1	45.40		2
14202701	0	0	0	0	0		2
14202801	0.	10.0	10.0	0.	0.	0. 0. 1.	2

* ht str no. 421-1 intact loop sg tubes							

* 14211000 8 8 2 1 0.00980							
* 14211100 0 1							
* 14211101 7 0.0127							
* 14211201 5 7							
* 14211301 0.0 7							
* 14211400 0							
* 14211401 562.4 8							
* 14211501 428010000 0 1 1 2.8724 1							
* 14211502 428020000 10000 1 1 2.5654 3							
* 14211503 428040000 10000 1 1 2.1728 5							
* 14211504 419010000 10000 1 1 2.5654 7							
* 14211505 419030000 0 1 1 2.8724 8							
* 14211601 504010000 0 1 1 2.8724 1							
* 14211602 504020000 10000 1 1 2.5654 3							
* 14211603 504040000 0 1 1 2.1728 5							
* 14211604 504030000 -10000 1 1 2.5654 7							
* 14211605 504010000 0 1 1 2.8724 8							
* 14211701 0 0 0 0 8							
* 14211801 0. 10.0 10.0 0.0 0. 0.0 0. 1. 8							
* 14211901 0. 10.0 10.0 0.0 0. 0.0 0. 1. 8							
* *****							
* ht str no. 421-2 ilsg inlet/outlet tube sheet							
* *****							
* 14212000	2	4	2	1	0.0098	0	
* 14212100		0		1			
* 14212101		3		0.0163			
* 14212201		5		3			
* 14212301		0.0		3			
* 14212400				-1			
* 14212401	583.000		583.000		583.000	583.000	

*14212402	557.000	557.000	557.000	557.000			
*14212501	428010000	0	1	1	2.8724		1
*14212502	419030000	0	1	1	2.8724		2
*14212601	0	0	0	1	2.8724		2
*14212701	0	0	0	0	0		2
*14212801	0.	10.0	10.0	0.	0.	0. 0. 1.	2

* ht str no. 500-1 ilsg external dc pipe to environ							

15001000	5	5	2	1	0.0486	0	
15001100		0		1			
15001101		2			0.0572		
15001102		2			0.1572		
15001201		5			2		
15001202		9			4		
15001301		0.0			4		
15001401	564.0				5		
15001501	500010000	0	1	1	9.0016		1
15001502	500020000	0	1	1	8.3920		2
15001503	500030000	10000	1	1	10.2616		4
15001504	500050000	0	1	1	10.2380		5
15001601	900010000	0	1	1	9.0016		1
15001602	900010000	0	1	1	8.3920		2
15001603	900010000	0	1	1	10.2616		4
15001604	900010000	0	1	1	10.2380		5
15001701	0	0	0	0	0		5
15001801	0.	10.0	10.0	0.	0.	0. 0. 1.	5
15001901	0.	10.0	10.0	0.	0.	0. 0. 1.	5

* ht str no. 500-2 ilsg upper dc to separator							

15002000	2	2	2	1	0.2514	0	
15002100		0		1			
15002101		1			0.2554		
15002201		5			1		
15002301		0.0			1		
15002400					0		
15002401	560.				2		
15002501	504050000	0	1	1	0.6461		1
15002502	508010000	0	1	1	2.120		2
15002601	500010000	0	1	1	0.6461		1
15002602	508010000	0	1	1	2.120		2
15002701	0	0	0	0	0		2
15002801	0.	10.0	10.0	0.	0.	0. 0. 1.	2
15002901	0.	10.0	10.0	0.	0.	0. 0. 1.	1
15002902	0.	10.0	10.0	0.	0.	0. 0. 1.	2

* ht str no. 500-3 ilsg upper sg shell to environ									

15003000	4	6	2	1	0.4375	0			
15003100		0		1					
15003101		1			0.4405				
15003102		2			0.4785				
15003103		2			0.6035				
15003201		5		1					
15003202		6		3					
15003203		9		5					
15003301		0.0		5					
15003400				0					
15003401		530.		6					
15003501	500010000	0		1	0.6461		1		
15003502	504050000	0		1	1.0104		2		
15003503	512010000	0		1	2.120		3		
15003504	516010000	0		1	3.4278		4		
15003601	900010000	0		1	0.6461		1		
15003602	900010000	0		1	1.0104		2		
15003603	900010000	0		1	2.120		3		
15003604	900010000	0		1	3.4278		4		
15003701	0	0		0	0		4		
15003801	0.	10.0	10.0	0.	0.	0. 0. 1.	1		
15003802	0.	10.0	10.0	0.	0.	0. 0. 1.	2		
15003803	0.	10.0	10.0	0.	0.	0. 0. 1.	3		
15003804	0.	10.0	10.0	0.	0.	0. 0. 1.	4		
15003901	0.	10.0	10.0	0.	0.	0. 0. 1.	4		

* ht str no. 500-4 ilsg lower sg dc to boiler									

15004000	1	2	2	1	0.345	0			
15004100		0		1					
15004101		1			0.351				
15004201		5		1					
15004301		0.0		1					
15004400				0					
15004401		560.		2					
15004501	504010000	0		1	1.0637		1		
15004601	500050000	0		1	1.0637		1		
15004701	0	0		0	0		1		
15004801	0.	10.0	10.0	0.	0.	0. 0. 1.	1		
15004901	0.	10.0	10.0	0.	0.	0. 0. 1.	1		

* ht str no. 500-5 ilsg lower sg dc wall to environ									

15005000	1	6	2	1	0.370	0			
15005100		0		1					
15005101		1			0.373				
15005102		2			0.405				
15005103		2			0.530				
15005201		5		1					
15005202		6		3					
15005203		9		5					
15005301		0.0		5					
15005400				0					
15005401		530.		6					
15005501	500050000	0		1	1.2637		1		
15005601	900010000	0		1	1.2637		1		
15005701	0	0		0	0		1		
15005801	0.	10.0	10.0	0.	0.	0. 0. 1.	1		
15005901	0.	10.0	10.0	0.	0.	0. 0. 1.	1		

* ht str no. 504-1 ilsg boiler wall to environ									

15041000	5	6	2	1	0.347	0			
15041100		0		1					
15041101		1			0.350				
15041102		2			0.380				
15041103		2			0.505				
15041201		5		1					
15041202		6		3					
15041203		9		5					
15041301		0.0		5					
15041400				0					
15041401		550.		6					
15041501	504010000	0		1	1.2827		1		
15041502	504020000	10000		1	2.5654		3		
15041503	504040000	0		1	2.098		4		
15041504	504050000	0		1	0.3658		5		
15041601	900010000	0		1	1.2827		1		
15041602	900010000	0		1	2.5654		3		
15041603	900010000	0		1	2.098		4		
15041604	900010000	0		1	0.3658		5		
15041701	0	0		0	0		5		
15041801	0.	10.0	10.0	0.	0.	0. 0. 1.	4		
15041802	0.	10.0	10.0	0.	0.	0. 0. 1.	5		
15041901	0.	10.0	10.0	0.	0.	0. 0. 1.	5		

* ht str no. 512-1 ilsg separator to sep bypass									

15121000	1	2	2	1	0.2982	0			

-A.32-

20100252	1073.15	4.61e+6	1173.15	4.73e+6	1273.15	4.95e+6	20288818	600.0	1.6257e+6
20100253	1473.15	5.29e+6	10000.0	5.29e+6			20288819	800.0	1.5419e+6
*							20288820	1000.0	1.5357e+6
* copper							20288821	1500.0	1.3603e+6
20100351	3.43e6						20288822	2000.0	1.2058e+6
*							20288823	3000.0	1.0656e+6
* inconel 600							20288824	4000.0	0.97510e+6
20100451	373.15	3.94e+6	573.15	4.18e+6	873.15	4.71e+6	20288825	5000.0	0.91049e+6
20100452	1173.15	5.17e+6					20288826	6000.0	0.86154e+6
*							20288827	8000.0	0.79102e+6
*stainless steel							20288828	10000.0	0.74152e+6
20100551	273.15	3.83e+6	366.5	3.83e+6	477.59	4.19e+6	20288829	20000.0	0.61196e+6
20100552	588.59	4.336e+6	699.82	4.504e+6	810.93	4.639e+6	20288830	50000.0	0.47759e+6
20100553	922.04	4.773e+6	1144.26	5.076e+6	1366.5	5.376e+6	20288831	100000.0	0.39343e+6
20100554	1477.59	5.546e+6	10000.0	5.546e+6			*		
*							*****		
* aluminum oxide							* pressurizer heater power		
20100751	373.15	3.015e+6	473.15	3.482e+6	573.15	3.796e+6	*****		
20100752	673.15	3.946e+6	773.15	4.093e+6	873.15	4.239e+6	*		
20100753	973.15	4.384e+6	1073.16	4.373e+6	1173.16	4.529e+6	20260000	reac-t	* backup heaters
20100754	1373.16	4.529e+6	1473.16	4.685e+6			20260001	15.34e6	1.125e5
*							20260002	15.40e6	1.125e5
* rockwool							20260003	15.40e6	0.0
20100951	1.36e+5						*		
*							20260100	reac-t	* proportional heaters
*****							20260101	15.41e6	7.5e3
*****							20260102	15.62e6	0.0
* core power							*		
*****							*****		
*							* control systems		
20288800	power	501					*****		
20288801	-1.0	10.00e+6					*		
20288802	0.0	10.00e+6					*****		
20288803	10.0	10.00e+6					* calculate time step		
20288804	13.94	10.00e+6					*****		
20288805	15.0	8.5093e+6					*		
20288806	20.0	5.5464e+6					20500100	"time stp"	sum 1.0000000 .20000000 1
20288807	30.0	3.6521e+6					20500101	0.0 1.0	time 0
20288808	40.0	3.0656e+6					20500102	-1.0	cntrlvar 2
20288809	50.0	2.6580e+6					*		
20288810	60.0	2.5579e+6					20500200	"old time"	mult 1.0000000 0.0 1
20288811	80.0	2.3982e+6					20500201	time 0	
20288812	100.0	2.3092e+6					*		
20288813	150.0	2.0900e+6					*****		
20288814	200.0	2.0261e+6					* control system turbine bypass valve control	*	
20288815	300.0	1.8832e+6					* during loca calculations	*	
20288816	400.0	1.7569e+6					* based on mean primary temperature control	*	
20288817	500.0	1.6865e+6					*****		

```

*
*****
* calculate il + bl mean temperature and select the larger
*****
*
20503000 "ilmtmp"      sum      1.0000000 580.37388 1
20503001  0.0    0.5  tempf 452010000
20503002      0.5  tempf 400010000
*
20503100 "blmtmp"      sum      1.0000000 580.35764 1
20503101  0.0    0.5  tempf 252010000
20503102      0.5  tempf 200010000
*
20503200 "ilmtmpl"      tripunit 1.0000000 1.0000000 1
20503201  514
*
20503300 "blmtmpl"      tripunit 1.0000000 0.0      1
20503301  516
*
20503400 "cilmtmp "      mult      1.0000000 580.37388 1
20503401  cntrlvar 32  cntrlvar 30
*
20503500 "blmtmpl"      mult      1.0000000 0.0      1
20503501  cntrlvar 33  cntrlvar 31
*
20503600 "pmtmp "      sum      1.0000000 580.37388 1
20503601  0.0    1.0  cntrlvar 34
20503602      1.0  cntrlvar 35
*
*****
* input to tb valve control after core trip-pmt setpt = 564.9 k
*****
*
20503700 "pmterra "      sum      -0.0902500 1.1456230 1
20503701  566.3    -1.0  cntrlvar 36
*
*****
* check for reactor scram
*****
*
20503800 "arctrp "      tripunit 1.0000000 0.0      1
20503801  501
*
20503900 "arctrpc"      mult      1.0000000 0.0      1
20503901  cntrlvar 38  cntrlvar 37
*
*****
* tb valve control

```

```

*****
*
20504000 "tbp area"      sum      1.0000000 0.0      1
+      3      0.0      1.0000000
20504001  0.0      1.0      cntrlvar 39
*
*****
* calculate core collapsed liquid level
*****
*
20512400 "core lvl"      sum      1.0000000 3.6600000 1
20512401      0.0      0.610      voidf 124010000
20512402      0.610      voidf 124020000
20512403      0.610      voidf 124030000
20512404      0.610      voidf 124040000
20512405      0.610      voidf 124050000
20512406      0.610      voidf 124060000
*
*****
* calculate core collapsed liquid level ---vessel---
*****
*
20512500 "core lvl"      sum      1.0000000 5.8027000 1
20512501      0.0      0.610      voidf 124010000
20512502      0.610      voidf 124020000
20512503      0.610      voidf 124030000
20512504      0.610      voidf 124040000
20512505      0.610      voidf 124050000
20512506      0.610      voidf 124060000
20512507      0.867      voidf 128010000
20512508      0.6757     voidf 132010000
20512509      0.6        voidf 136010000
*
*****
* calculate core heat input
*****
*
20512600 "coreheat"      sum      1.00000-6 9.8651798 1
20512601      0.0      1.0      q      124010000
20512602      1.0      q      124020000
20512603      1.0      q      124030000
20512604      1.0      q      124040000
20512605      1.0      q      124050000
20512606      1.0      q      124060000
*
*****
* calculate vessel dc collapsed level
*****
*

```

20510900	"vsldclvl"	sum	1.0000000	3.6600000	1
20510901	0.0	voidf	108030000		
20510902	0.610	voidf	108040000		
20510903	0.610	voidf	108050000		
20510904	0.610	voidf	108060000		
20510905	0.610	voidf	108070000		
20510906	0.610	voidf	108080000		

*

* energy transferred to generators

*

20530000	"blsgheat"	sum	1.00000-6	4.9783641	1
20530001	0.0	1.0	q	304010000	
20530002	1.0		q	304020000	
20530003	1.0		q	304030000	
20530004	1.0		q	304040000	

*

20550000	"ilsgheat"	sum	1.00000-6	4.9752834	1
20550001	0.0	1.0	q	504010000	
20550002	1.0		q	504020000	
20550003	1.0		q	504030000	
20550004	1.0		q	504040000	

*

* calculate sg recirculation ratios

*

20530100	"recircbl"	div	1.0000000	5.0243769	1
20530101	mflowj	308010000	mflowj	301000000	
20550100	"recircil"	div	1.0000000	5.0230369	1
20550101	mflowj	508010000	mflowj	501000000	

*

* calculate narrow range sg liquid levels

*

20530800	"ilsgll "	sum	.15390000	.13184474	1
20530801	0.0	0.600	voidf	300010000	
20530802	2.12		voidf	312010000	
20530803	3.7778		voidf	316010000	

*

20550800	"blsgll "	sum	.15390000	.12746200	1
20550801	0.0	0.600	voidf	500010000	
20550802	2.12		voidf	512010000	
20550803	3.7778		voidf	516010000	

*

* set il main feedwater on 9.5 m wide range sg level

*

20535900	"il lv er"	sum	1.000000	0.	1
20535901	2450.	-1.0	cntrlvar	309	

*

20536100	"il feed "	sum	1.0000000	2.8000000	1
20536101	0.0	1.0	mflowj	329000000	
20536102	2.0		cntrlvar	359	

*

* set bl main feedwater on 9.6 m wide range sg level

*

20555900	"bl lv er"	sum	1.000000	0.	1
20555901	2450.	-1.0	cntrlvar	509	

*

20556100	"bl feed "	sum	1.0000000	2.8000000	1
20556101	0.0	1.0	mflowj	529000000	
20556102	2.0		cntrlvar	559	
*20556103	1.0		mflowj	493000000	

*

* pressurizer heater power

*

20560000	"pbkuphr"	function	1.0000000	0.0	1
20560001	p	610010000	600		

*

20560100	"pprohr "	function	1.0000000	836.59446	1
20560101	p	610010000	601		

*

20560200	"bkphtrp"	tripunit	1.0000000	0.0	1
20560201	634				

*

20560300	"bkphtrpw"	mult	1.0000000	0.0	1
20560301	cntrlvar	600	cntrlvar	602	

*

20560400	"pzhrtrpw"	sum	1.0000000	836.59446	1
20560401	0.0	1.0	cntrlvar	601	
20560402	1.0		cntrlvar	603	

*

20560500	"pzhrtrp"	tripunit	1.0000000	0.0	1
20560501	633				

*

20560600	"pzhrtrpw"	mult	1.0000000	0.0	1
20560601	cntrlvar	604	cntrlvar	605	

```

*
*****
* calculate collapsed prssurizer liquid level
*****
*
20561000 "pzs lev "      sum      1.00000000      2.594213
1
20561001      0.0      0.201      voidf      610010000
20561002      0.470      voidf      610020000
20561003      0.470      voidf      610030000
20561004      0.600      voidf      610040000
20561005      0.682      voidf      610050000
20561006      0.682      voidf      610060000
20561007      0.5375     voidf      610070000
20561008      0.5375     voidf      610080000
*
*****
* calculate broken loop steam generator mass
*****
*
20530900 "sgb mass"      sum      1.0000000 2860.9843 1
20530901      0.0      0.3228      rho      300010000
20530902      0.0621     rho      300020000
20530903      0.0759     rho      300030000
20530904      0.0759     rho      300040000
20530905      0.1302     rho      300050000
20530906      0.5839     rho      304010000
20530907      0.5882     rho      304020000
20530908      0.5882     rho      304030000
20530909      0.4951     rho      304040000
20530910      0.7979     rho      304050000
20530911      0.5720     rho      308010000
20530912      0.6288     rho      312010000
20530913      2.0288     rho      316010000
*
*****
* calculate intact loop steam generator mass
*****
*
20550900 "sga mass"      sum      1.0000000 2848.8553 1
20550901      0.0      0.3228      rho      500010000
20550902      0.0621     rho      500020000
20550903      0.0759     rho      500030000
20550904      0.0759     rho      500040000
20550905      0.1302     rho      500050000
20550906      0.5839     rho      504010000
20550907      0.5882     rho      504020000
20550908      0.5882     rho      504030000

20550909      0.4951     rho      504040000
20550910      0.7979     rho      504050000
20550911      0.5720     rho      508010000
20550912      0.6288     rho      512010000
20550913      2.0288     rho      516010000
*
*****
* calculate intact primary loop mass
*****
*
20570000 "ihl mass"      sum      1.0000000 2848.8553 1
20570001      0.0      0.04463902     rho      400010000
20570002      0.00093545     rho      402010000
20570003      0.00058598     rho      404010000
20570004      0.04665091     rho      406010000
20570005      0.02373491     rho      408010000
20570006      0.01778686     rho      408020000
20570007      0.1250      rho      412010000
20570008      0.2323      rho      416010000
*
*****
*
20570100 "isg mass"      sum      1.000000 2500.0 1
20570101      0.0      0.1212112     rho      420010000
20570102      0.1082557     rho      420020000
20570103      0.1082557     rho      420030000
20570104      0.091689     rho      420040000
20570105      0.091689     rho      420050000
20570106      0.1082557     rho      422010000
20570107      0.1082557     rho      422020000
20570108      0.1212112     rho      422030000
*20570109      0.0008658     rho      428010000
*20570110      0.0007733     rho      428020000
*20570111      0.0007733     rho      428030000
*20570112      0.000655     rho      428040000
*20570113      0.000655     rho      428050000
*20570114      0.0007733     rho      419010000
*20570115      0.0007733     rho      419020000
*20570116      0.0008658     rho      419030000
*
*****
*
20570200 "ils mass"      sum      1.000000 2500.0 1
20570201      0.0      0.2323      rho      424010000
20570202      0.125      rho      430010000
20570203      0.0114552     rho      432010000
20570204      0.02757684     rho      432020000
20570205      0.02757684     rho      432030000
20570206      0.02757684     rho      432040000
20570207      0.02646018     rho      432050000
20570208      0.02646018     rho      436010000
20570209      0.02491284     rho      436020000

```

20570210	0.02611386	rho	436030000	20570701	0.0	0.122077	rho	220010000
20570211	0.02491284	rho	436040000	20570702		0.109029	rho	220020000
*				20570703		0.109029	rho	220030000
20570300 "icl mass"	sum	1.000000	2500.0	1	20570704	0.092344	rho	220040000
20570301 0.0	0.0235	rho	440010000	20570705	0.092344	rho	220050000	
20570302	0.02476276	rho	444010000	20570706	0.109029	rho	220060000	
20570303	0.03177573	rho	448010000	20570707	0.109029	rho	220070000	
20570304	0.03286424	rho	452010000	20570708	0.122077	rho	220080000	
20570305	0.03286424	rho	452020000	*				
20570306	0.040832	rho	740010000	20570800 "bls mass"	sum	1.000000	2500.0	1
*				20570801	0.0	0.2323	rho	224010000
20570400 "pr mass"	sum	1.000000	2500.0	1	20570802	0.125	rho	228010000
20570401 0.0	0.0325	rho	610010000	20570803	0.0114552	rho	232010000	
20570402	0.132869	rho	610020000	20570804	0.02757684	rho	232020000	
20570403	0.132869	rho	610030000	20570805	0.02757684	rho	232030000	
20570404	0.169620	rho	610040000	20570806	0.02757684	rho	232040000	
20570405	0.192801	rho	610050000	20570807	0.02646018	rho	232050000	
20570406	0.192801	rho	610060000	20570808	0.02930844	rho	236010000	
20570407	0.146791	rho	610070000	20570809	0.02491284	rho	236020000	
20570408	0.146791	rho	610080000	20570810	0.02534574	rho	236030000	
20570409	0.02382748	rho	600010000	20570811	0.02491284	rho	236040000	
20570410	0.03249617	rho	600020000	*				
20570411	0.01905868	rho	600030000	20570900 "bcl mass"	sum	1.000000	2500.0	1
20570412	0.00791779	rho	620010000	20570901	0.0	0.0235	rho	240010000
20570413	0.00791779	rho	620020000	20570902		0.03559394	rho	244010000
*				20570903		0.04025465	rho	248010000
20570500 "il mass"	sum	1.000000	2500.0	1	20570904	0.04423125	rho	252010000
20570501 0.0	1.0	cntrlvar	700	20570905	0.0145264	rho	790010000	
20570502	1.0	cntrlvar	701	*				
20570503	1.0	cntrlvar	702	20571000 "bl mass"	sum	1.000000	2500.0	1
20570504	1.0	cntrlvar	703	20571001	0.0	1.0	cntrlvar	706
20570505	1.0	cntrlvar	704	20571002		1.0	cntrlvar	707
*				20571003		1.0	cntrlvar	708
*****				20571004		1.0	cntrlvar	709
* calculate broken primary loop mass				*				
*****				*****				
*				* pressure vessel mass				
20570600 "bhl mass"	sum	1.000000	2848.8553	1	*****			
20570601 0.0	0.04463902	rho	200010000	*				
20570602	0.00093545	rho	202010000	20571100 "pvd mass"	sum	1.000000	2500.0	1
20570603	0.00058598	rho	204010000	20571101	0.0	0.136090	rho	100010000
20570604	0.04446715	rho	206010000	20571102		0.054250	rho	104010000
20570605	0.02373491	rho	208010000	20571103		0.06604292	rho	108010000
20570606	0.01778686	rho	208020000	20571104		0.08474058	rho	108020000
20570607	0.1250	rho	212010000	20571105		0.0596214	rho	108030000
20570608	0.2323	rho	216010000	20571106		0.0596214	rho	108040000
*				20571107		0.0596214	rho	108050000
20570700 "bsg mass"	sum	1.000000	2500.0	1	20571108	0.0596214	rho	108060000

20571109	0.0596214	rho	108070000	20575001	0.0	1.0	p	416010000
20571110	0.0596214	rho	108080000	20575002		-1.0	p	420040000
20571111	0.123035	rho	108090000	*				
*				20575100 "dp060d"		sum	1.00000	80000. 1
20571200 "pvipmass"	sum	1.000000	2500.0 1	20575101	0.0	1.0	p	424010000
20571201 0.0	0.1661	rho	112010000	20575102		-1.0	p	420050000
20571202	0.0943	rho	116010000	*				
*				20575200 "dpe070"		sum	1.00000	45000. 1
20571300 "pvc mass"	sum	1.000000	2500.0 1	20575201	0.0	1.0	p	424010000
20571301 0.0	0.1821	rho	120010000	20575202		-1.0	p	436010000
20571302	0.07312	rho	124010000	*				
20571303	0.07312	rho	124020000	20575300 "dpe080"		sum	1.00000	266000. 1
20571304	0.07312	rho	124030000	20575301	0.0	1.0	p	436010000
20571305	0.07312	rho	124040000	20575302		-1.0	p	440010000
20571306	0.07312	rho	124050000	*				
20571307	0.07312	rho	124060000	20575400 "dp190d"		sum	1.00000	80000. 1
20571308	0.15220	rho	128010000	20575401	0.0	1.0	p	216010000
20571309	0.10600	rho	132010000	20575402		-1.0	p	220040000
20571310	0.09389	rho	136010000	*				
20571311	0.04450	rho	140010000	20575500 "dp200d"		sum	1.00000	80000. 1
20571312	0.06209	rho	156010000	20575501	0.0	1.0	p	224010000
20571313	0.06288	rho	156020000	20575502		-1.0	p	220050000
*				*				
20571400 "pvupmass"	sum	1.000000	2500.0 1	20575600 "dpe210"		sum	1.00000	45000. 1
20571401 0.0	0.1655	rho	144010000	20575601	0.0	1.0	p	224010000
20571402	0.1970	rho	148010000	20575602		-1.0	p	236010000
20571403	0.1475	rho	152010000	*				
*				20575700 "dpe220"		sum	1.00000	266000. 1
20571500 "pv mass"	sum	1.000000	2500.0 1	20575701	0.0	1.0	p	236010000
20571501 0.0	1.0	cntrlvar	711	20575702		-1.0	p	240010000
20571502	1.0	cntrlvar	712	*				
20571503	1.0	cntrlvar	713	20576100 "dpe300"		sum	1.00000	32000. 1
20571504	1.0	cntrlvar	714	20576101	0.0	1.0	p	124010000
*				20576102		-1.0	p	128010000
*****				*				
* primary mass				*****				
*****				* control steam valve to give sg pressure of 7.10 mpa.				
*				*****				
20572000 "pv mass"	sum	1.000000	2500.0 1	*				
20572001 0.0	1.0	cntrlvar	705	20580300 "pres err"		sum	100.000-9	-5.3342-6 1
20572002	1.0	cntrlvar	710	+		3	-.05	.05
20572003	1.0	cntrlvar	715	20580301	-6.90e6	1.0	p	316010000
*				*				
*****				20580400 "del area"		mult	1.0000000	-1.0668-6 1
* differential pressure calculations				20580401	cntrlvar 1	cntrlvar	803	
*****				*				
*				20580500 "vlv area"		sum	1.0000000	.2300 1
20575000 "dp050d"	sum	1.00000	80000. 1	-		3	0.0	1.0000000

```

20580501 0.0 1.0 cntrlvar 805
*
*****
* calculate wide range sg liquid levels
*****
*
20531200 "blsglwde" sum 1.000000 8.9221049 1
20531201 0.0 2.5464 voidf 304010000
20531202 2.5654 voidf 304020000
20531203 2.5654 voidf 304030000
20531204 2.0980 voidf 304040000
20531205 2.0223 voidf 304050000
20531206 2.1200 voidf 308010000
20531207 3.7778 voidf 316010000
*
20551200 "ilsglwde" sum 1.000000 8.8904978 1
20551201 0.0 2.5464 voidf 504010000
20551202 2.5654 voidf 504020000
20551203 2.5654 voidf 504030000
20551204 2.0980 voidf 504040000
20551205 2.0223 voidf 504050000
20551206 2.1200 voidf 508010000
20551207 3.7778 voidf 516010000
*
*****
* set rcp speed to control to loop flow of 24.2 kg/s
*****
*
20523800 "spd err" sum 2.000000 158.365-6 1
+ 3 -5.000000 5.0000000
20523801 34.65 -1.0 mflowj 240010000
*
20523900 "delspeed" mult 1.000000 31.6731-6 1
20523901 cntrlvar 1 cntrlvar 238
*
20524000 "rcpspeed" sum 1.000000 89.403724 1
20524001 0.0 1.0 cntrlvar 239
20524002 1.0 cntrlvar 240
*
*****
* set hot leg bypass valve areas to 0.0
*****
*
20520300 "blhtlbyp" constant 0.0985
*
20540300 "ilhtlbyp" constant 0.0985
*
*****

```

```

* calculate net flow to secondary
*****
*
20585000 "netsecl" sum 1.000000 0. 1
20585001 0.0 1. mflowj 361000000
20585002 1. mflowj 351000000
20585003 1. mflowj 561000000
20585004 1. mflowj 551000000
20585005 -1. mflowj 805000000
20585006 -1. mflowj 803000000
20585007 -1. mflowj 369000000
20585008 -1. mflowj 379000000
20585009 -1. mflowj 569000000
20585010 -1. mflowj 579000000
*
*****
* calculate the overall pressure vessel liquid level
*****
*
20512800 "uh level" sum 1.000000 10.657100 1
20512801 0.0 0.626 voidf 112010000
20512802 0.4762 voidf 116010000
20512803 1.2588 voidf 120010000
20512804 0.610 voidf 124010000
20512805 0.610 voidf 124020000
20512806 0.610 voidf 124030000
20512807 0.610 voidf 124040000
20512808 0.610 voidf 124050000
20512809 0.610 voidf 124060000
20512810 0.867 voidf 128010000
20512811 0.6757 voidf 132010000
20512812 0.600 voidf 136010000
20512813 0.3674 voidf 140010000
20512814 0.897 voidf 144010000
20512815 0.725 voidf 148010000
20512816 0.504 voidf 152010000
*
*****
* calculate the steam generator liquid level
*****
*
20551600 "sga lvl" sum 1.000000 17.695300 1
20551601 0.0 2.5464 voidf 504010000
20551602 2.5654 voidf 504020000
20551603 2.5654 voidf 504030000
20551604 2.0980 voidf 504040000
20551605 2.0223 voidf 504050000
20551606 2.1200 voidf 508010000

```

```

20551607      3.7778      voidf      516010000
*
20531600      "sgb lvl"      sum      1.000000      17.695300      1
20531601      0.0      2.5464      voidf      304010000
20531602      2.5654      voidf      304020000
20531603      2.5654      voidf      304030000
20531604      2.0980      voidf      304040000
20531605      2.0223      voidf      304050000
20531606      2.120      voidf      308010000
20531607      3.7778      voidf      316010000
*
*****
* calculate the steam generator level in the boiler section
*****
*
20550400      "sga blvl"      sum      1.000000      11.797500      1
20550401      0.0      2.5464      voidf      504010000
20550402      2.5654      voidf      504020000
20550403      2.5654      voidf      504030000
20550404      2.0980      voidf      504040000
20550405      2.0223      voidf      504050000
*
20530400      "sgb blvl"      sum      1.000000      11.797500      1
20530401      0.0      2.5464      voidf      304010000
20530402      2.5654      voidf      304020000
20530403      2.5654      voidf      304030000
20530404      2.0980      voidf      304040000
20530405      2.0223      voidf      304050000
*
*****
* core power
*****
*
20588800      "core pow"      function      1.000000      10.020e+6      1
20588801      time      0      888
*
*****
* total break flowrate
*****
*
20591600      break      sum      1.0      0.0      1
20591601      0.0      1.0      mflowj      493000000
*
*****
* calculate time-integrated break mass flow
*****
*
20591500      "int bflw"      integral      1.000000      0.000000      1
20591501      cntrivar      916
*
*****
* intact total feedwater flow
*****
*
20591700      intfeed      sum      1.0      0.0      1
20591701      0.0      1.0      mflowj      361000000
20591702      1.0      mflowj      351000000
*
*****
* broken total feedwater flow
*****
*
20591800      intfeed      sum      1.0      0.0      1
20591801      0.0      1.0      mflowj      561000000
20591802      1.0      mflowj      551000000
*
*****
* calculate the mass error
*****
*
20574000      "mass err"      sum      1.000000      0.000000      1
20574001      -14560.577      1.0      cntrivar      720
20574002      1.0      cntrivar      915
*
*****
* differential pressure calculations
*****
*
20576500      "dpe140"      sum      1.000000      5000.      1
20576501      0.0      1.0      p      104010000
20576502      -1.0      p      136010000
*
20576800      "dpe055"      sum      1.000000      2000.      1
20576801      0.0      1.0      p      416010000
20576802      -1.0      p      424010000
*
20576900      "dpe195"      sum      1.000000      2000.      1
20576901      0.0      1.0      p      216010000
20576902      -1.0      p      224010000
*
*
*
. zzz

```

Input Deck for SGTR Transient Calculation


```

*****
*
= lstf sgtr transient input deck with relap5/mod3.1
*
*****
*
0000100 restart transnt
*
0000101 run
0000102 si si
0000103 4265
*
* time step control
*
0000201 3000.0 1.0-6 0.5 3 10 1000 1000
0000202 5000.0 1.0-6 0.1 3 50 5000 5000
*
20800001 dt 0.0
20800002 dtcmt 0.0
*
*****
* minor edits
*****
*
301 p 610010000 *pzz pressure
302 p 516010000 *sg-b steam pressure
303 p 316010000 *sg-i steam pressure
304 mflowj 208010000 *loop-i hot leg flow
305 mflowj 408010000 *loop-b hot leg flow
306 mflowj 248010000 *loop-i cold leg flow
307 mflowj 452010000 *loop-b cold leg flow
308 mflowj 108010000 *core bypass flow
309 mflowj 120010000 *core inlet flow
310 tempf 104010000 *vessel inlet temp
311 tempf 136010000 *vessel outlet temp
312 tempf 120010000 *core inlet temp
313 tempf 128010000 *core outlet temp
314 tempf 316010000 *sg-i steam temp
315 tempf 516010000 *sg-b steam temp
316 tempf 200010000 *loop-i hot leg temp
317 tempf 400010000 *loop-b hot leg temp
318 tempf 124010000 *core fluid temp-1
319 tempf 124020000 *core fluid temp-2
320 tempf 124030000 *core fluid temp-3
321 tempf 124040000 *core fluid temp-4
322 tempf 124050000 *core fluid temp-5
323 tempf 124060000 *core fluid temp-6
324 sattemp 248010000 *hot leg sat. temp

```

```

325 sattemp 208010000 *cold leg sat. temp
326 voidg 152010000 *upper head voidf
327 pmpvel 240
328 pmphead 240
329 pmpvel 440
330 pmphead 440
331 cntrivar 512 *sg-b wr level
332 cntrivar 508 *sg-b nr level
333 cntrivar 504 *sg-b boiling water level
334 cntrivar 312 *sg-i wr level
335 cntrivar 308 *sg-i nr level
336 cntrivar 304 *sg-i boiling water level
337 cntrivar 610 *pzz level
338 cntrivar 720 *primary mass
339 cntrivar 309 *sg-i mass
340 cntrivar 509 *sg-b mass
341 cntrivar 888 *rx power
342 cputime 0 *cpu time
343 cntrivar 916 *break flowrate
344 cntrivar 915 *integrated break flow
345 cntrivar 917 *total feedwater to sg-a
346 cntrivar 918 *total feedwater to sg-b
*347 mflowj 391000000 *sg-a steam dump
348 mflowj 612000000 *pzz aux spray
349 mflowj 351000000 *aux feed a (hot)
350 mflowj 353000000 *aux feed a (cold)
351 mflowj 551000000 *aux feed b (hot)
352 cntrivar 919 *aux feed a (total)
353 mflowj 771000000 *hpsi to cl-i
354 mflowj 721000000 *hpsi to cl-b
355 mflowj 722000000 *hpsi to up
356 tempf 152010000 *up head temp
357 tempf 108040000 *mid downcomer temp
358 cntrivar 921 *total water inject
359 cntrivar 922 *HPSI-CL total flow
*
*****
* variable trips
*****
*
0000501 p 610010000 lt null 0 1.342e+7 1 *rx trip signal
0000502 time 0 ge null 0 1.e6 1 *power
0000505 p 610010000 lt null 0 1.287e+7 1 *rcp&si
0000506 time 0 ge timeof 505 17.0 1 *lpsi delay
0000507 cntrivar 610 le null 0 1.0 n *hpsi termi.
0000508 time 0 le timeof 505 2900.0 n *hpsi termi.
0000510 time 0 ge timeof 505 98.0 n *il hpi
0000511 time 0 ge timeof 505 300.0 n *il hppi to up

```

0000512	time	0	ge	timeof	505	98.0	n *bl hpi	0000601	-603	and	571	n * bl sec relief valve
0000514	cntrlvar	30	ge	cntrlvar	31	0.0	n *mean temp	0000602	603	and	570	n
0000516	cntrlvar	30	lt	cntrlvar	31	0.0	n	0000603	601	or	602	n
0000520	p	610010000	ge	null	0	1.646e+7	l *high pres	0000604	-606	and	575	n * bl sec safety valve
0000522	p	610010000	ge	null	0	1.726e+7	n *pzs sfty	0000605	606	and	574	n
0000524	p	610010000	ge	null	0	1.568e+7	n *pzs spry	0000606	604	or	605	n
0000525	time	0	ge	timeof	501	2666.0	l *pzs aux spray	0000607	-609	and	561	n * il sec relief valve
0000526	p	610010000	gt	null	0	1.607e+7	n * porv	0000608	609	and	560	n
0000527	p	516010000	gt	p	610010000	0.0	l *aux spray term.	0000609	607	or	608	n
0000528	p	610010000	gt	null	0	1.620e+7	n	0000610	-612	and	565	n * il sec safety valve
0000529	time	0	ge	null	0	0.0	l *pzs prp. htrs	0000611	612	and	564	n
0000530	p	610010000	lt	null	0	1.540e+7	n *pzs bkup htrs	0000612	610	or	611	n
0000531	p	610010000	lt	null	0	1.534e+7	n	0000613	-615	and	528	n * porv
0000532	cntrlvar	610	lt	null	0	0.25656	n *lo nrm pr lvl	0000614	615	and	526	n
0000535	time	0	ge	null	0	0.0	l *tube break	0000615	613	or	614	n
0000536	time	0	ge	null	0	0.0	l *bl flow	0000616	510	and	507	n * hpsi to il cl
0000537	time	0	lt	null	0	0.0	l *valve	0000617	511	and	508	n * hpsi to core up
0000538	time	0	lt	null	0	0.0	l *il flow	0000618	512	and	507	n * hpsi to il
0000539	time	0	lt	null	0	0.0	l *valve	0000619	525	and	-527	n * aux spray
*0000540	time	0	le	null	0	10000.0	n	0000620	580	or	581	l * reactor trip
0000550	p	610010000	ge	null	0	1.297e+7	n *main feed	0000621	520	or	620	l
0000552	time	0	ge	timeof	505	37.0	n *aux feed	0000622	621	or	501	l
0000553	time	0	le	timeof	552	200.0	n *aux feed	0000623	552	and	553	n * sg aux feed, il
0000554	cntrlvar	312	lt	null	0	12.85	n *aux feed	0000624	552	and	556	n * , bl
0000555	time	0	gt	timeof	505	237.0	n *aux feed a cold	0000625	-586	or	-586	n * steam sink pressure
0000556	time	0	le	timeof	552	81.0	n *aux feed	0000626	579	or	568	l * hpi
0000557	tempf	206010000	ge	null	0	531.4	n * termi. of stdump	0000627	626	or	505	l
0000560	p	316010000	gt	null	0	6.4e+6	n *il sg rel	0000630	-632	and	531	n * pzs backup heater cntl
0000561	p	316010000	gt	null	0	7.3e+6	n	0000631	632	and	530	n
0000564	p	316010000	gt	null	0	7.69e+6	n *il sg saf	0000632	630	or	631	n
0000565	p	316010000	gt	null	0	8.68e+6	n	0000633	-505	and	-532	n * pzs htrs off on sis or low pzs lvl
0000568	p	316010000	le	null	0	0.0	l *il msiv	0000634	632	and	633	n * pzs htrs off on low pzs level
0000569	p	316010000	lt	null	0	4.235e+6	l	0000635	-568	and	-568	n 0
0000570	p	516010000	gt	null	0	6.4e+6	n *bl sg rel	0000636	-578	and	-578	n 0
0000571	p	516010000	gt	null	0	7.3e+6	n	0000637	555	and	554	n
0000574	p	516010000	gt	null	0	7.69e+6	n *bl sg saf	0000638	578	and	557	n * intact loop RV manual open
0000575	p	516010000	gt	null	0	8.68e+6	n	0000700	-535	and	-535	n 0 *break close
0000578	time	0	ge	timeof	501	722.0	l *bl msiv	*				
0000579	p	516010000	lt	null	0	4.235e+6	l					
0000580	cntrlvar	308	lt	null	0	0.25	l *low sg lev					
0000581	cntrlvar	508	lt	null	0	0.25	l					
0000583	time	0	ge	null	0	0.0	n *stm hdr vlv					
0000585	time	0	lt	null	0	0.0	n *stm thrtl	2400000	nprcpump	pump		
0000586	time	0	ge	null	0	11.0	n * valve	2400101	0.0	0.802	0.0235	0.0 90.0 0.351 0
0000599	time	0	lt	null	0	1000.0	n * ss pres	2400108	236010000	0.0222	0.0	0.0 0000
								2400109	244000000	0.0337	0.0525	0.0525 0000
								2400200	003	15471507.	560.76	
								2400201	0	2.0813	2.2480	0.0

* logical trips

2400202 0 1.3711 1.3711 0.0
 2400301 0 0 0 -1 0 505 0
 2400302 188.50000 .680636 .05400000 10.000000 55.200000
 2400303 0.54 750.0 0.0 0.0 0.0 0.0 0.0

*

* single phase head and torque data from 1stf sys. description

*

2401100 1 1 0.00 1.36 0.10 1.38 0.24 1.42 0.40 1.41
 2401101 0.60 1.32 0.80 1.19 1.00 1.00
 2401200 1 2 0.00 -0.97 0.20 -0.68 0.50 -0.20 0.65 0.07
 2401201 0.80 0.40 1.00 1.00
 2401300 1 3 -1.0 3.20 -0.90 2.80 -0.80 2.46 -0.60 1.94
 2401301 -0.40 1.57 -0.20 1.41 0.00 1.36
 2401400 1 4 -1.00 3.20 -0.80 2.76 -0.60 2.41 -0.40 2.09
 2401401 -0.20 1.81 0.00 1.58
 2401500 1 5 0.00 0.00 1.00 0.00
 2401600 1 6 0.00 0.00 1.00 0.00
 2401700 1 7 -1.00 0.00 0.00 0.00
 2401800 1 8 -1.00 0.00 0.00 0.00

*

* torque data

*

2401900 2 1 0.00 0.36 0.12 0.38 0.20 0.44 0.30 0.58
 2401901 0.50 0.73 0.70 0.81 1.00 1.00
 2402000 2 2 0.00 -1.26 0.10 -0.88 0.30 -0.31 0.50 0.09
 2402001 0.65 0.30 0.86 0.63 1.00 1.00
 2402100 2 3 -1.00 2.40 -0.85 1.70 -0.65 1.12 -0.50 0.84
 2402101 -0.40 0.69 -0.20 0.59 0.00 0.36
 2402200 2 4 -1.00 2.40 -0.80 2.12 -0.60 1.80 -0.30 1.32
 2402201 0.00 0.80
 2402300 2 5 0.00 0.00 1.00 0.00
 2402400 2 6 0.00 0.00 1.00 0.00
 2402500 2 7 -1.00 0.00 0.00 0.00
 2402600 2 8 -1.00 0.00 0.00 0.00

*

* two phase multiplier tables for head of rc pump 240

*

2403000 0 0.0 0.0
 2403001 0.10 0.0
 2403002 0.15 0.05
 2403003 0.24 0.80
 2403004 0.30 0.96
 2403005 0.40 0.98
 2403006 0.60 0.97
 2403007 0.80 0.90
 2403008 0.90 0.80

2403009 0.96 0.50
 2403010 1.00 0.0

*

* two phase multiplier tables for torque of rc pump 240

*

2403100 0 0.0 0.0
 2403101 1.0 0.0

*

* two-phase diff curves from r5 built-in data

* head difference curves

*

2404100 1 1 0.00 0.00 0.10 0.83 0.20 1.09 0.50 1.02
 2404101 0.70 1.01 0.90 0.94 1.00 1.00
 2404200 1 2 0.00 0.00 0.10 -0.40 0.20 0.00 0.30 0.10
 2404201 0.40 0.21 0.80 0.67 0.90 0.80 1.00 1.00
 2404300 1 3 -1.00 -1.16 -0.90 -1.24 -0.80 -1.77 -0.70 -2.36
 2404301 -0.60 -2.79 -0.50 -2.91 -0.40 -2.67 -0.25 -1.69
 2404302 -0.10 -0.50 0.00 0.00
 2404400 1 4 -1.00 -1.16 -0.90 -0.78 -0.80 -0.50 -0.70 -0.31
 2404401 -0.60 -0.17 -0.50 -0.08 -0.35 0.00 -0.20 0.05
 2404402 -0.10 0.08 0.00 0.11
 2404500 1 5 0.00 0.00 1.00 0.00
 2404600 1 6 0.00 0.00 1.00 0.00
 2404700 1 7 -1.00 0.00 0.00 0.00
 2404800 1 8 -1.00 0.00 0.00 0.00

*

* torque difference curves

*

2404900 2 1 0.0 0.0 0.0 0.0
 2405000 2 2 0.0 0.0 0.0 0.0
 2405100 2 3 0.0 0.0 0.0 0.0
 2405200 2 4 0.0 0.0 0.0 0.0
 2405300 2 5 0.0 0.0 0.0 0.0
 2405400 2 6 0.0 0.0 0.0 0.0
 2405500 2 7 0.0 0.0 0.0 0.0
 2405600 2 8 0.0 0.0 0.0 0.0

*

* pump coastdown data

*

2406100 501 * norm speed
 2406101 0.0 128.3 * 160.22
 2406102 80.0 128.3 * 160.22
 2406103 83.0 122.0 * 153.75
 2406104 86.0 118.9 * 149.87
 2406105 89.0 114.9 * 144.86
 2406106 101.0 96.7 * 121.90
 2406107 110.0 82.6 * 104.12
 2406108 119.0 74.4 * 93.77


```

3700200 3
3700201 0.0 1.01325e+5 293.15
*
*****
3790000 blsgsv valve
3790101 324010000 380000000 0.00195 0.00055 0.0 0100
3790201 0 0.0 0.0 0.0 * 0.0
3790300 trpvlv
3790301 612
*
*****
3800000 contain tmdpvov
3800101 1.0e+8 10.0 0.0 0.0 0.0 0.0 0.0 0.0 00
3800200 3
3800201 0.0 1.01325e+5 293.15
*
*****
*
4160000 wpsgfb branch
4160001 3 0
4160101 0 1.1035 0.2323 0.0 90.0 1.1035 4.57e-5
4160102 0.4474 00
4160200 003 15460476. 586.5
4162101 412010000 416000000 0.2093 0.0 0.0 0000
4163101 416010000 420000000 0.04254 0.0 0.0 0000
4164101 416010000 417000000 5.0e-4 0.0 0.0 0100
4162201 1.247 1.247 0.0
4163201 1.247 1.247 0.0
4164201 0.1 0.1 0.0
*
*****
*
4170000 bktln1 snglvov
4170101 5.0e-4 1.18 0.0 0.0 0.0 0.0 4.57e-5 0.0 00
4170200 003 15453426. 560.5
*
4180000 bktln4 branch
4180001 2 0
4180101 5.0e-4 2.06 0.0 0.0 -90.0 -2.06 4.57e-5 0.0 00
4180200 003 15441269. 586.5
4181101 417010000 418000000 5.0e-4 0.0 0.0 0000
4182101 418010000 419000000 5.0e-4 0.0 0.0 0000
4181201 0.1 0.1 0.0
4182201 0.1 0.1 0.0
*
4190000 bktln5 snglvov
4190101 5.0e-4 1.9 0.0 0.0 0.0 0.0 4.57e-5 0.0 00
4190200 003 15433426. 560.5

```

```

*
4930000 break valve
4930101 419010000 494000000 5.0e-4 0.0 0.0 0000
4930201 1 0.0 0.0 0.0
4930300 trpvlv
4930301 535
*
*****
*
4940000 bktln5 snglvov
4940101 5.0e-4 0.24 0.0 0.0 0.0 0.0 4.57e-5 0.0 00
4940200 003 7310426. 540.5
*
4950000 bktln4 branch
4950001 2 0
4950101 5.0e-4 0.35 0.0 0.0 90.0 0.35 4.57e-6 0.0 00
4950200 003 7311269. 546.5
4951101 495010000 496000000 3.02e-5 0.0 0.0 0100
4952101 494010000 495000000 5.0e-4 0.0 0.0 0000
4951201 0.1 0.1 0.0
4952201 0.1 0.1 0.0
*
4960000 brknoz1 pipe
4960001 3
4960101 3.02e-5 3
4960301 0.6 3
4960401 0.0 3
4960601 90.0 3
4960701 0.6 3
4960801 1.2e-6 0.0062 3
4960901 0.0 0.0 2
4961001 00 3
4961101 01000 2
4961201 003 15315536. 586.50 0. 0. 0. 1
4961202 003 11325536. 569.50 0. 0. 0. 2
4961203 003 7330536. 552.50 0. 0. 0. 3
4961300 0
4961301 0.1 0.1 0.0 1
4961302 0.1 0.1 0.0 2
*
*4960000 brknoz1 pipe
*4960001 12
*4960101 3.02e-5 12
*4960301 0.15 12
*4960401 0.0 12
*4960601 90.0 12
*4960701 0.15 12
*4960801 1.2e-6 0.0062 12

```

```

*4960901  0.0      0.0    11
*4961001  00      12
*4961101  01000    11
*4961201  003     15315536. 586.50 0. 0. 0. 1
*4961202  003     14625536. 583.50 0. 0. 0. 2
*4961203  003     13930536. 580.50 0. 0. 0. 3
*4961204  003     13295536. 577.50 0. 0. 0. 4
*4961205  003     12625536. 574.50 0. 0. 0. 5
*4961206  003     11930536. 571.50 0. 0. 0. 6
*4961207  003     11215536. 568.50 0. 0. 0. 7
*4961208  003     10625536. 565.50 0. 0. 0. 8
*4961209  003     9949276. 562.50 0. 0. 0. 9
*4961210  003     9278626. 559.50 0. 0. 0. 10
*4961211  003     7935536. 556.50 0. 0. 0. 11
*4961212  003     7330536. 552.50 0. 0. 0. 12
*4961300  0
*4961301  0.1  0.1  0.0  1
*4961302  0.1  0.1  0.0  2
*4961303  0.1  0.1  0.0  3
*4961304  0.1  0.1  0.0  4
*4961305  0.1  0.1  0.0  5
*4961306  0.1  0.1  0.0  6
*4961307  0.1  0.1  0.0  7
*4961308  0.1  0.1  0.0  8
*4961309  0.1  0.1  0.0  9
*4961310  0.1  0.1  0.0  10
*4961311  0.1  0.1  0.0  11
*
4970000  bkln2  branch
4970001  2      0
4970101  5.0e-4  0.75  0.0  0.0  90.0  0.75  4.57e-6  0.0  0.0
4970200  003     7331269. 546.5
4971101  496010000  497000000  3.02e-5  0.0  0.0  0100
4972101  497010000  498000000  5.0e-4  0.0  0.0  0000
4971201  0.1  0.1  0.0
4972201  0.1  0.1  0.0
*
4980000  bkln2  pipe
4980001  2
4980101  5.0e-4  2
4980301  1.25  2
4980601  0.0  2
4980701  0.0  2
4980801  4.57e-5  0.0  2
4980901  0.0  0.0  1
4981001  00  2
4981101  0000  1
4981201  003     7344729. 540.5 0. 0. 0. 1

```

```

4981202  003     7350523. 540.5 0. 0. 0. 2
4981300  0
4981301  0.1  0.1  0.0  1
*
4990000  bkln1  sngljun
4990101  498010000  504010003  5.0e-4  0.0  0.0  0100
4990201  0      0.1  0.1  0.0
*
*****
*
4400000  wprcpump  pump
4400101  0.0  0.802  0.0235  0.0  90.0  0.351  0.0
4400108  436010000  0.0222  0.0  0.0  0000
4400109  444000000  0.0337  0.0525  0.0525  0000
4400200  003     15471901. 560.6
4400201  0      2.0050  2.1683  0.0
4400202  0      1.3208  1.3208  0.0
4400301  240  240  240  -1  0  505  0
4400302  188.50000  .65942  .05400000  10.000000  55.200000
4400303  0.54  750.0  0.0  0.0  0.0  0.0  0.0
*
* pump coastdown data
*
4406100  501      * norm speed
4406101  0.0  124.3  * 160.22
4406102  80.0  124.3  * 160.22
4406103  83.0  118.2  * 153.75
4406104  86.0  115.2  * 149.87
4406105  89.0  111.4  * 144.86
4406106  101.0  93.7  * 121.90
4406107  110.0  80.1  * 104.12
4406108  119.0  72.1  * 93.77
4406109  131.0  61.4  * 79.86
4406110  140.0  54.9  * 71.46
4406111  149.0  50.2  * 65.31
4406112  161.0  44.9  * 58.36
4406113  170.0  40.4  * 52.54
4406114  179.0  37.0  * 48.18
4406115  191.0  33.7  * 43.81
4406116  200.0  31.3  * 40.74
4406117  209.0  29.1  * 37.38
4406118  221.0  26.5  * 34.43
4406119  230.0  24.5  * 31.85
4406120  239.0  22.5  * 29.26
4406121  251.0  20.8  * 27.00
4406122  260.0  19.6  * 25.54
4406123  269.0  18.4  * 23.92
4406124  281.0  15.8  * 20.53

```

4406125	290.0	14.2	* 18.43
4406126	299.0	12.0	* 15.60
4406127	320.0	9.6	* 12.48
4406128	341.0	7.2	* 9.36
4406129	359.0	4.8	* 6.24
4406130	380.0	2.4	* 3.12
4406131	400.0	0.0	
4406132	1000.0	0.0	

*

5290000	ilmsiv	valve						
5290101	528010000	532000000	0.00429	0.0	0.0	0.00		
5290201	0	5.7878014	17.263954	0.0			* 2.7467386	
5290300	mrtrlv							
5290301	636	578	2.0000000	1.0000000	0			

*

5500000	auxfed	tmdpvul						
5500101	8.0	5.0	0.0	0.0	0.0	0.0	0	00
5500200	3							
5500201	0.0	5.95300e+6		495.2				

*

5510000	auxfed	tmdpjun						
5510101	550000000	500000000	0.004					
5510200	1	624						
5510201	0.0	0.0	0.0	0.0				
5510202	0.01	1.140	0.0	0.0				
5510203	5000.0	1.140	0.0	0.0				

*

5610000	wpstegfw	tmdpjun						
5610101	560000000	500000000	4.00e-3					
5610200	1	550	cntrivar	561				
5610201	-1.0e75	0.0	0.0	0.0				
5610202	0.0	0.0	0.0	0.0				
5610203	5.0	5.0	0.0	0.0				
5610204	7.0	7.0	0.0	0.0				
5610205	1000.0	7.0	0.0	0.0				

*

* p2r aux spray

*

6110000	auxtank	tmdpvul						
6110101	1.0e+5	10.0	0.0	0.0	0.0	0.0	0	00
6110200	3							
6110201	0.0	16.0e+6	310.0					

*

6120000	auxjun	tmdpjun						
6120101	611000000	610010001	2.552e-3					
6120200	1	619						
6120201	-1.0	0.0	0.0	0.0				
6120202	0.0	0.1	0.0	0.0				
6120203	10.0	0.1	0.0	0.0				
6120204	700.0	0.1	0.0	0.0				
6120205	1000.0	0.1	0.0	0.0				

*

* eccs

*

7200000	ilsi	tmdpvul						
7200101	4.375	10.0	0.0	0.0	0.0	0.0	0.0	00
7200200	3							
7200201	0.0	1.013e-5	310.00					

*

* high pressure safety injection to cold leg

*

7210000	ilsi	tmdpjun						
7210101	720000000	740000000	2.552e-3					
7210200	1	616	p	448010000				
7210201	-1.0	0.0	0.0	0.0				
7210202	0.0	0.0	0.0	0.0				
7210203	0.0	0.629	0.0	0.0				
7210204	5.88e6	0.629	0.0	0.0				
7210205	6.08e6	0.6065	0.0	0.0				
7210206	6.28e6	0.5875	0.0	0.0				
7210207	6.47e6	0.569	0.0	0.0				
7210208	6.67e6	0.554	0.0	0.0				
7210209	6.86e6	0.535	0.0	0.0				
7210210	7.06e6	0.5125	0.0	0.0				
7210211	7.26e6	0.4975	0.0	0.0				
7210212	7.45e6	0.475	0.0	0.0				
7210213	7.65e6	0.4565	0.0	0.0				
7210214	7.85e6	0.434	0.0	0.0				
7210215	8.04e6	0.4115	0.0	0.0				
7210216	8.24e6	0.385	0.0	0.0				
7210217	8.43e6	0.3625	0.0	0.0				
7210218	8.63e6	0.340	0.0	0.0				
7210219	8.83e6	0.314	0.0	0.0				
7210220	9.02e6	0.2875	0.0	0.0				
7210221	9.22e6	0.254	0.0	0.0				
7210222	9.41e6	0.224	0.0	0.0				

```

7210223      9.61e6      0.190      0.0      0.0
7210224      9.81e6      0.1375     0.0      0.0
7210225     10.0e6      0.059      0.0      0.0
7210226     10.15e6      0.0        0.0      0.0
*
7500000      ilsi      tmdpvvol
7500101      4.375      10.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
7500200      3
7500201      0.0        1.013e+5      310.00
*
7220000      ilsi      tmdpjun
7220101      750000000      140000000      2.552e-3
7220200      1 617 p 140010000
7220201      -1.0      0.0 0.0 0.0
7220202      0.0      0.0 0.0 0.0
7220203      0.0      1.388      0.0 0.0
7220204      5.88e6      1.388      0.0 0.0
7220205      6.08e6      1.343      0.0 0.0
7220206      6.28e6      1.305      0.0 0.0
7220207      6.47e6      1.268      0.0 0.0
7220208      6.67e6      1.238      0.0 0.0
7220209      6.86e6      1.200      0.0 0.0
7220210      7.06e6      1.155      0.0 0.0
7220211      7.26e6      1.125      0.0 0.0
7220212      7.45e6      1.080      0.0 0.0
7220213      7.65e6      1.043      0.0 0.0
7220214      7.85e6      0.998      0.0 0.0
7220215      8.04e6      0.953      0.0 0.0
7220216      8.24e6      0.900      0.0 0.0
7220217      8.43e6      0.855      0.0 0.0
7220218      8.63e6      0.810      0.0 0.0
7220219      8.83e6      0.758      0.0 0.0
7220220      9.02e6      0.705      0.0 0.0
7220221      9.22e6      0.638      0.0 0.0
7220222      9.41e6      0.578      0.0 0.0
7220223      9.61e6      0.510      0.0 0.0
7220224      9.81e6      0.405      0.0 0.0
7220225     10.0e6      0.248      0.0 0.0
7220226     10.15e6      0.0        0.0 0.0
*
*****
7300000      ilchrg      tmdpvvol
7300101      4.375      10.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
7300200      3
7300201      0.0        1.013e+5      310.00
*
*****
7310000      ilchrg      tmdpjun

```

```

7310101      730000000      740000000      2.552e-3
7310200      1 510 p 444010000
7310201      -1.0      0.0      0.0 0.0
7310202      0.0      0.0      0.0 0.0
7310203      0.0      0.13      0.0 0.0
7310204      15.0e6      0.13      0.0 0.0
*
*****
7400000      ileccsln      snglvol
7400101      2.552e-3      16.0 0.0 0.0 0.0 0.0 3.333e-5
7400102      0.0 0.0
7400200      0      15593371. 83230.665 2445532.2 0.0
*
*****
7700000      blsi      tmdpvvol
7700101      4.375      10.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
7700200      3
7700201      0.0        1.013e+5      310.0
*
*****
*
7710000      blsi      tmdpjun
7710101      770000000      790000000      2.552e-3
7710200      1 618 p 248010000
7710201      -1.0      0.0 0.0 0.0
7710202      0.0      0.0 0.0 0.0
7710203      0.0      0.629      0.0 0.0
7710204      5.88e6      0.629      0.0 0.0
7710205      6.08e6      0.6065      0.0 0.0
7710206      6.28e6      0.5875      0.0 0.0
7710207      6.47e6      0.569      0.0 0.0
7710208      6.67e6      0.554      0.0 0.0
7710209      6.86e6      0.535      0.0 0.0
7710210      7.06e6      0.5125      0.0 0.0
7710211      7.26e6      0.4975      0.0 0.0
7710212      7.45e6      0.475      0.0 0.0
7710213      7.65e6      0.4565      0.0 0.0
7710214      7.85e6      0.434      0.0 0.0
7710215      8.04e6      0.4115      0.0 0.0
7710216      8.24e6      0.385      0.0 0.0
7710217      8.43e6      0.3625      0.0 0.0
7710218      8.63e6      0.340      0.0 0.0
7710219      8.83e6      0.314      0.0 0.0
7710220      9.02e6      0.2875      0.0 0.0
7710221      9.22e6      0.254      0.0 0.0
7710222      9.41e6      0.224      0.0 0.0
7710223      9.61e6      0.190      0.0 0.0
7710224      9.81e6      0.1375      0.0 0.0

```

```

7710225    10.0e6    0.059    0.0    0.0
7710226    10.15e6    0.0    0.0    0.0
*
*****
7800000    blchrg    tmdpv0l
7800101    4.375    10.0    0.0    0.0    0.0    0.0    0.0    0.0
7800200    3
7800201    0.0    1.013e+5    310.0
*
*****
7810000    blchrg    tmdpv0l
7810101    7800000000    7900000000    2.552e-3
7810200    1    510    p    248010000
7810201    -1.0    0.0    0.0    0.0
7810202    0.0    0.0    0.0    0.0
7810203    0.0    0.13    0.0    0.0
7810204    15.0e6    0.13    0.0    0.0
*
*****
7900000    bleccsln    snglv0l
7900101    9.079e-4    16.0    0.0    0.0    0.0    0.0    3.333e-5
7900102    0.0    0.0
7900200    0    15488401.    83231.356    2445531.5    0.0
*
*****
* intact loop secondary pressure control
*****
*8160000    jctdv1    tmdpv0l
*8160101    1.0e+8    10.0    0.0    0.0    0.0    0.0    0.0    0.0    0.0
*8160200    2
*8160201    0.0    6.54e+6    1.0
*8160202    2900.0    6.54e+6    1.0
*8160203    3000.0    2.70e+6    1.0
*8160204    5000.0    2.70e+6    1.0
*
8200000    jctdv2    tmdpv0l
8200101    1.0e+8    10.0    0.0    0.0    0.0    0.0    0.0    0.0    0.0
8200200    2
8200201    0.0    6.54e+6    1.0
8200202    2500.0    6.54e+6    1.0
8200203    2600.0    2.70e+6    1.0
8200204    5000.0    2.70e+6    1.0
*
*****
* boundary system for steady state
*****
9900000    bdryvol    delete
*
*****
9890000    bdryvol    delete
*
*****
20574000    "mass err"    sum    1.000000    0.000000    1
20574001    -14488.61    1.0    cntrivar    720
20574002    1.0    cntrivar    915
*
20591900    auxfeed    sum    1.0    0.0    1
20591901    0.0    1.0    mflowj    351000000
20591902    1.0    mflowj    353000000
*
20591700    intfeed    sum    1.0    0.0    1
20591701    0.0    1.0    mflowj    361000000
20591702    1.0    mflowj    351000000
20591703    1.0    mflowj    353000000
*
20591800    brkfeed    sum    1.0    0.0    1
20591801    0.0    1.0    mflowj    561000000
20591802    1.0    mflowj    551000000
*
20592000    totwatr    sum    1.0    0.0    1
20592001    0.0    1.0    mflowj    771000000
20592002    1.0    mflowj    721000000
20592003    1.0    mflowj    722000000
20592004    1.0    mflowj    731000000
20592005    1.0    mflowj    781000000
*
20592100    totalinj    integral    1.0    0.0    1
20592101    cntrivar    920
*
20592200    tothpicl    sum    1.0    0.0    1
20592201    0.0    1.0    mflowj    771000000
20592202    1.0    mflowj    721000000
20592204    1.0    mflowj    731000000
20592205    1.0    mflowj    781000000
*
*****
* integrated flow in broken loop
*****
*
20592300    "si-clot"    integral    1.0    0.0    1
20592301    cntrivar    922
*
20592500    "feedtot"    integral    1.0    0.0    1
20592501    cntrivar    917
*

```

20592600	"auxtot"	integral	1.0	0.0	1
20592601	cntrlvar	918			
*					
20592800	"arvtot"	integral	1.0	0.0	1
20592801	mflowj	569000000			
*					
20592900	"msltot"	integral	1.0	0.0	1
20592901	mflowj	529000000			
*					
. zzz					

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

1. REPORT NUMBER
(Assigned by NRC, Add Vol., Supp., Rev.,
and Addendum Numbers, If any.)NUREG/IA-0130
CAMP002

2. TITLE AND SUBTITLE

Assessment of RELAP5/MOD3.1 With the LSTF SB-SG-06 Experiment Simulating a Steam
Generator Tube Rupture Transient

3. DATE REPORT PUBLISHED

MONTH | YEAR
September | 1996

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

K.W. Seul, Y.S. Bang, S. Lee, H.J. Kim

6. TYPE OF REPORT

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Korea Institute of Nuclear Safety
P.O. Box 16, Daeduck Danji
Taejon, 305-600 Korea

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

The objective of the present work is to identify the predictability of RELAP5/MOD3.1 regarding thermal-hydraulic behavior during a steam generator tube rupture (SGTR). To evaluate the computed results, LSTF SB-SG-06 test data simulating the SGTR that occurred at the Mihama Unit 2 in 1991 are used. Also, some sensitivity studies of the code change in RELAP5, the break simulation model, and the break valve discharge coefficient are performed. The calculation results indicate that the RELAP5/MOD3.1 code predicted well the sequence of events and the major phenomena during the transient, such as the asymmetric loop behavior, reactor coolant system (RCS) cooldown and heat transfer by natural circulation, the primary and secondary system depressurization by the pressurizer auxiliary spray and the steam dump using the intact loop steam generator (SG) relief valve, and so on. However, there are some differences from the experimental data in the number of the relief valve cycling in the affected SG, and the flow regime of the hot leg with the pressurizer, and the break flow rates. Finally, the calculation also indicates that the coolant in the core could remain in a subcooled state as a result of the heat transfer caused by the natural circulation flow even if the reactor coolant pumps (RCPs) turned off and that the affected SG could be properly isolated to minimize the radiological release after the SGTR.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

RELAP5/MOD3, CAMP, SGTR

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)


unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program